



LOS ANGELES COUNTY CLERK
CEQA FILING COVER SHEET

2023 196256


FILED
Sep 06 2023

Dean C. Logan, Registrar - Recorder/County Clerk

Electronically signed by ANNA MOVSIYAN

THIS NOTICE WAS POSTED

ON September 06 2023

UNTIL October 06 2023

REGISTRAR - RECORDER/COUNTY CLERK

Complete and attach this form to each CEQA Notice filed with the County Clerk

TYPE OR PRINT CLEARLY

Project Title

Riverside Dr Mainline Replacement Project

Check Document being Filed:

- Environmental Impact Report (EIR)
- Mitigated Negative Declaration (MND) or Negative Declaration (ND)
- Notice of Exemption (NOE)
- Other (Please fill in type):

Filing fees are due at the time a Notice of Determination/Exemption is filed with our office. For more information on filing fees and No Effect Determinations, please refer to California Code of Regulations, Title 14, section 753.5.


NOTICE OF EXEMPTION

(City CEQA Guidelines)

Submission of this form is optional. The form shall be filed with the County Clerk, 12400 Imperial Highway, Norwalk, CA 90650, pursuant to Public Resources Code Section 21152(b). Pursuant to Public Resources Code Section 21168(d), the filing of this notice starts a 35-day statute of limitations on Court challenges to the approval of the project. Failure to file the notice results in the statute of limitations being extended to 180 days.

LEAD CITY AGENCY AND ADDRESS: Los Angeles Department of Water and Power (LADWP) 111 N. Hope Street, Room 1044 Los Angeles, CA 90012		COUNCIL DISTRICT 4 - Raman	
PROJECT TITLE Riverside Dr Mainline Replacement		LOG REFERENCE Not Applicable	
PROJECT LOCATION The project site is located at 14060 Riverside Dr, Los Angeles, CA 91423			
DESCRIPTION OF NATURE, PURPOSE, AND BENEFICIARIES OF PROJECT: The Riverside Dr Mainline Replacement Project proposes to replace approximately 2,426 feet of 6-inch and 5,430 feet of 8-inch mainline water distribution on Riverside Dr, Calhoun Ave, Murieta Ave, Huston St, Tilden Ave, Sylmar Ave, Lennox Ave, Tyrone Ave, Katherine Ave, and Stansbury Ave. Construction would include installation of new laterals for fire hydrants. Trenches will be 2 feet wide and 5 feet deep and will be back-filled with slurry to the base of the asphalt concrete pavement. The purpose of this project is to replace aging and leaking infrastructure in order to provide a reliable source of water to LADWP customers.			
CONTACT PERSON David Norris		AREA CODE (213)	TELEPHONE NUMBER EXT. 367-3509
EXEMPT STATUS: Section 15302 Class 2 Categorical Exemption: Replacement or Reconstruction			
JUSTIFICATION FOR PROJECT EXEMPTION: The Riverside Dr Mainline Replacement Project is categorically exempt pursuant to California Environmental Quality Act (CEQA) Guidelines 15302 (c). This section states that Class 2 exemptions consist of replacement or reconstruction of existing structures and facilities where the new structure will be located on the same site as the structure replaced and will have substantially the same purpose and capacity as the structure replaced, including but not limited to: (c) replacement or reconstruction of existing utility systems and/or facilities involving negligible or no expansion of capacity. The project involves replacement of existing mainline water distribution piping with negligible expansion of capacity.			
IF FILED BY APPLICANT, ATTACH CERTIFIED DOCUMENT OF EXEMPTION FINDING			
SIGNATURE Jane Hauptman		TITLE: Manager of Environmental Planning and Assessment	DATE 08/10/2023
FEE: \$75.00	RECEIPT NO.	REC'D BY	DATE

DISTRIBUTION: (1) County Clerk (2) City Clerk (3) Agency Record
 Form Gen. 153 (9/91) (Appendix A)

2023 196256

 FILED
 Sep 06 2023
 Dean C. Logan, Registrar - Recorder/County Clerk
 Electronically signed by ANNA MDVSIKYAN

Attachment A: Area Map



Attachment B: Mainline Replacement Maps

