LORP Synopsis for December 2015

Compliance Comments

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting and increased sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

Here are the flow changes during the month:

LORP Langemann Gate from 4 cfs to 3 cfs on December 1st, 2015

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2015-16)
The runoff forecast for runoff year 2015-16 is 36%, so the waterfowl acreage goal for this year is 180 acres.

On April 1st, 2015 the Thibaut Waterfowl Area inflow was reduced to 0 cfs, the Drew Slough Waterfowl Area was reduced to 0 cfs and the Winterton Waterfowl Area inflows were turned on to 6.6 cfs.

On May 1st, 2015 the flows to the Winterton area were reduced to 5.6 CFS.

On May 6th, 2015 the wetted perimeter was measured with GPS. The wetted area for the middle of the spring season was measured to be 235 acres for Drew Slough and Winterton was measured to have an area of 86 acres.

On June 1st, 2015 the flows to the Winterton area were increased to 6.0 CFS.

On July 10th, 2015 the Winterton wetted area was measured with GPS and was 171 acres.

On September 15th, the Winterton wetted area was measured with GPS and was 221 acres. Fall flows to Winterton remained at 6.0 cfs.

On October 16th, flows to Winterton were decreased to 1.6 cfs, and flows to Thibaut Waterfowl Area were increased to 0.5 cfs.

On November 22nd, flows to Thibaut Waterfowl Area were increased to 5 cfs from 1 cfs.

On November 24th, flows to Thibaut Waterfowl Area were decreased to 1 cfs from 5 cfs.

Drew Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
0 cfs	4/1/15	235	5/6/14

Waggoner Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
N/A		N/A	

Winterton Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
6.6 cfs	4/1/15	86	5/6/15
5.6 cfs	5/1/15	171	7/10/15
6.0 cfs	6/1/15	221	9/15/15
1.6 cfs	10/15/15		

Thibaut Unit

Inflow	Date Set	Wetted Acreage	Date of GPS
0	4/1/15	N/A	
0.5 cfs	10/15/15		
5 cfs	11/22/15		
1 cfs	11/24/15		

December 2015 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes
LORP Intake	12/3/2015	42.3	42.3	42.3	0	gage height 4.37
At Mazourka Canyon Road	12/3/2015	45.7	44.26	44.18	1	gage height 4.14
At Reinhackle Springs	12/3/2015	61.6	72.48	71.54	-10	gage height 4.76
LORP Intake	12/30/2015	42.6	42.3	42.3	0	gage height 4.54
At Mazourka Canyon Road	12/30/2015	43.6	41.9	40.2	3	gage height 4.15
At Reinhackle Springs	12/30/2015	48.2	48.3	47.9	0	gage height 4.30

Date	Intake			Blackrock Ditch Return		Goose Lake Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	**River Daily Avg**
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date			
12/01/15	42	42	15	0	1	1	1	1.2	1	45	47	15	5	4	18	10	68	59	15	0	1	63	54	15	47	47	3	13	**55**
12/02/15	42	42	15	1	1	1	1	1.2	1	45	46	15	5	4	18	11	68	60	15	0	1	65	55	15	47	47	3	15	**55**
12/03/15	42	42	15	0	1	1	1	1.2	1	46	46	15	6	4	18	13	66	61	15	0	1	66	56	15	47	47	3	16	**55**
12/04/15	41	42	15	1	1	1	1	1.2	1	48	46	15	6	5	18	14	64	62	15	0	1	67	58	15	47	47	3	17	**55**
12/05/15	41	42	15	1	1	1	1	1.2	1	47	46	15	4	5	14	15	64	63	15	0	1	67	59	15	47	47	3	17	**55**
12/06/15	41	42	15	1	1	1	1	1.3	1	46	46	15	0	5	0	15	56	64	15	0	1	69	60	15	47	47	3	19	**53**
12/07/15	41	42	15	1	1	1	1	1.3	1	46	46	15	0	5	1	15	48	64	15	0	1	69	61	15	47	47	3	19	**51**
12/08/15	42	42	15	2	1	1	1	1.2	1	45	46	15	0	5	0	14	44	63	15	0	0	70	62	15	47	47	3	20	**50**
12/09/15	43	42	15	1	1	1	1	1.2	1	46	46	15	0	4	0	13	42	61	15	0	0	70	63	15	46	47	3	21	**50**
12/10/15	43	42	15	1	1	1	1	1.3	1	47	46	15	0	4	0	11	42	60	15	0	0	71	65	15	46	47	3	22	**51**
12/11/15	43	42	15	1	1	1	1	1.3	1	49	46	15	0	3	0	10	42	58	15	0	0	68	66	15	47	47	3	18	**51**
12/12/15	43	42	15	1	1	1	1	1.3	1	50	46	15	0	3	0	9	41	57	15	0	0	63	66	15	47	47	3	13	**49**
12/13/15	43	42	15	1	1	1	1	1.3	1	51	47	15	0	3	0	8	41	55	15	0	0	59	66	15	47	47	3	9	**49**
12/14/15	42	42	15	1	1	1	1	1.3	1	54	47	15	0	2	0	7	41	53	15	0	0	53	65	15	47	47	3	3	**48**
12/15/15	41	42	15	1	1	1	1	1.2	1	53	48	15	0	2	0	6	42	51	15	0	0	51	65	15	47	47	3	1	**47**
12/16/15	42	42	15	1	1	1	1	1.2	1	50	48	15	0	1	0	5	41	49	15	0	0	51	64	15	47	47	3	1	**46**
12/17/15	41	42	15	1	1	1	1	1.1	1	50	49	15	0	1	0	3	43	48	15	0	0	50	63	15	47	47	3	0	**46**
12/18/15	42	42	15	1	1	1	1	1.1	1	49	49	15	0	1	0	2	42	46	15	0	0	50	62	15	47	47	3	0	**46**
12/19/15	42	42	15	1	1	1	1	1.1	1	49	49	15	0	0	0	1	42	45	15	0	0	50	61	15	47	47	3	0	**46**
12/20/15	43	42	15	1	1	1	1	1.1	1	46	49	15	0	0	0	0	41	43	15	0	0	50	60	15	47	47	3	0	**45**
12/21/15	43	42	15	1	1	1	1	1.1	1	44	49	15	0	0	0	0	41	42	15	0	0	50	58	15	47	47	3	0	**45**
12/22/15	43	42	15	1	1	1	1	1.1	1	49	49	15	0	0	0	0	43	42	15	0	0	49	57	15	38	47	3	8	**46**
12/23/15	43	42	15	1	1	1	1	1.1	1	49	49	15	0	0	0	0	42	42	15	0	0	53	56	15	38	46	3	12	**47**
12/24/15	42	42	15	1	1	1	1	1.1	1	49	49	15	0	0	1	0	41	42	15	0	0	52	55	15	47	46	3	2	**46**
12/25/15	42	42	15	1	1	1	1	1.1	1	49	49	15	0	0	1	0	42	42	15	0	0	52	53	15	47	46	3	2	**46**
12/26/15	41	42	15	1	1	1	1	1.1	1	50	49	15	0	0	1	0	42	42	15	0	0	52	52	15	47	46	3	2	**46**
12/27/15	41	42	15	1	1	1	1	1.2	1	47	49	15	0	0	0	0	39	42	14	0	0	53	52	15	47	46	3	3	**45**
12/28/15	42	42	15	1	1	1	1	1.2	1	47	49	15	0	0	0	0	38	41	13	0	0	53	51	15	47	46	3	3	**45**
12/29/15	42	42	15	1	1	1	1	1.2	1	42	48	15	0	0	0	0	40	41	13	0	0	53	51	15	47	46	3	3	**44**
12/30/15	41	42	15	1	1	1	1	1.2	1	47	48	15	0	0	0	0	46	42	13	0	0	53	51	15	47	46	3	3	**47**
12/31/15	41	42	15	1	1	1	1	1.2	1	51	48	15	0	0	0	0	52	42	13	0	0	53	52	15	47	46	3	3	**49**

Lower Owens River Project Flow Report for 12/01/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	0.4	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**45**	**47**	15
Locust Ditch Return (augmentation)	5	4			
Georges Ditch Return (augmentation)	18	10			
Reinhackle Springs			**68**	**59**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**63**	**54**	15
Pump Station			47	46	
Langemann Gate to Delta			3	4	
Weir to Delta			13	4	
LORP In Channel Average Flow [2]			**55**	**51**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.29 ft	(Last Collected: 11/18/2015)
Lower Twin Lake Gage Read	2.08 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/02/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**45**	**46**	15
Locust Ditch Return (augmentation)	5	4			
Georges Ditch Return (augmentation)	18	11			
Reinhackle Springs			**68**	**60**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**65**	**55**	15
Pump Station			47	46	
Langemann Gate to Delta			3	4	
Weir to Delta			15	5	
LORP In Channel Average Flow [2]			**55**	**51**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.29 ft	(Last Collected: 11/18/2015)
Lower Twin Lake Gage Read	2.08 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/03/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	0.4	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**46**	**46**	15
Locust Ditch Return (augmentation)	6	4			
Georges Ditch Return (augmentation)	18	13			
Reinhackle Springs			**66**	**61**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**66**	**56**	15
Pump Station			47	47	
Langemann Gate to Delta			3	4	
Weir to Delta			16	6	
LORP In Channel Average Flow [2]			**55**	**52**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.29 ft	(Last Collected: 11/18/2015)
Lower Twin Lake Gage Read	2.08 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/04/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**48**	**46**	15
Locust Ditch Return (augmentation)	6	5			
Georges Ditch Return (augmentation)	18	14			
Reinhackle Springs			**64**	**62**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**67**	**58**	15
Pump Station			47	47	
Langemann Gate to Delta			3	4	
Weir to Delta			17	7	
LORP In Channel Average Flow [2]			**55**	**52**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/05/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**47**	**46**	15
Locust Ditch Return (augmentation)	4	5			
Georges Ditch Return (augmentation)	14	15			
Reinhackle Springs			**64**	**63**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**67**	**59**	15
Pump Station			47	47	
Langemann Gate to Delta			3	4	
Weir to Delta			17	8	
LORP In Channel Average Flow [2]			**55**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/06/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**46**	**46**	15
Locust Ditch Return (augmentation)	0	5			
Georges Ditch Return (augmentation)	0	15			
Reinhackle Springs			**56**	**64**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**69**	**60**	15
Pump Station			47	47	
Langemann Gate to Delta			3	4	
Weir to Delta			19	9	
LORP In Channel Average Flow [2]			**53**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/07/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**46**	**46**	15
Locust Ditch Return (augmentation)	0	5			
Georges Ditch Return (augmentation)	1	15			
Reinhackle Springs			**48**	**64**	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station [1]			**69**	**61**	15
Pump Station			47	47	
Langemann Gate to Delta			3	4	
Weir to Delta			19	11	
LORP In Channel Average Flow [2]			**51**	**54**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/08/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**45**	**46**	15
Locust Ditch Return (augmentation)	0	5			
Georges Ditch Return (augmentation)	0	14			
Reinhackle Springs			**44**	**63**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**70**	**62**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			20	12	
LORP In Channel Average Flow [2]			**50**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/09/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**46**	**46**	15
Locust Ditch Return (augmentation)	0	4			
Georges Ditch Return (augmentation)	0	13			
Reinhackle Springs			**42**	**61**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**70**	**63**	15
Pump Station			46	47	
Langemann Gate to Delta			3	3	
Weir to Delta			21	13	
LORP In Channel Average Flow [2]			**50**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/10/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**47**	**46**	15
Locust Ditch Return (augmentation)	0	4			
Georges Ditch Return (augmentation)	0	11			
Reinhackle Springs			**42**	**60**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**71**	**65**	15
Pump Station			46	47	
Langemann Gate to Delta			3	3	
Weir to Delta			22	14	
LORP In Channel Average Flow [2]			**51**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/11/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**49**	**46**	15
Locust Ditch Return (augmentation)	0	3			
Georges Ditch Return (augmentation)	0	10			
Reinhackle Springs			**42**	**58**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**68**	**66**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			18	15	
LORP In Channel Average Flow [2]			**51**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/12/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**50**	**46**	15
Locust Ditch Return (augmentation)	0	3			
Georges Ditch Return (augmentation)	0	9			
Reinhackle Springs			**41**	**57**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**63**	**66**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			13	16	
LORP In Channel Average Flow [2]			**49**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/13/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**51**	**47**	15
Locust Ditch Return (augmentation)	0	3			
Georges Ditch Return (augmentation)	0	8			
Reinhackle Springs			**41**	**55**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**59**	**66**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			9	16	
LORP In Channel Average Flow [2]			**49**	**53**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/14/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			**54**	**47**	15
Locust Ditch Return (augmentation)	0	2			
Georges Ditch Return (augmentation)	0	7			
Reinhackle Springs			**41**	**53**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**65**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			3	15	
LORP In Channel Average Flow [2]			**48**	**52**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/15/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**53**	**48**	15
Locust Ditch Return (augmentation)	0	2			
Georges Ditch Return (augmentation)	0	6			
Reinhackle Springs			**42**	**51**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**51**	**65**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			1	15	
LORP In Channel Average Flow [2]			**47**	**52**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.35 ft	(Last Collected: 12/04/2015)
Lower Twin Lake Gage Read	2.28 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/16/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**50**	**48**	15
Locust Ditch Return (augmentation)	0	1			
Georges Ditch Return (augmentation)	0	5			
Reinhackle Springs			**41**	**49**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**51**	**64**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			1	14	
LORP In Channel Average Flow [2]			**46**	**51**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/17/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**50**	**49**	15
Locust Ditch Return (augmentation)	0	1			
Georges Ditch Return (augmentation)	0	3			
Reinhackle Springs			**43**	**48**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**63**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			0	13	
LORP In Channel Average Flow [2]			**46**	**51**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/18/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	1			
Georges Ditch Return (augmentation)	0	2			
Reinhackle Springs			**42**	**46**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**62**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			0	12	
LORP In Channel Average Flow [2]			**46**	**50**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/19/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	1			
Reinhackle Springs			**42**	**45**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**61**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			0	11	
LORP In Channel Average Flow [2]			**46**	**49**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/20/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**46**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**41**	**43**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**60**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			0	10	
LORP In Channel Average Flow [2]			**45**	**49**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/21/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**44**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**41**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**50**	**58**	15
Pump Station			47	47	
Langemann Gate to Delta			3	3	
Weir to Delta			0	8	
LORP In Channel Average Flow [2]			**45**	**48**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/22/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**43**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**49**	**57**	15
Pump Station			38	46	
Langemann Gate to Delta			3	3	
Weir to Delta			8	8	
LORP In Channel Average Flow [2]			**46**	**48**	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/23/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**43**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**42**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**56**	15
Pump Station			38	46	
Langemann Gate to Delta			3	3	
Weir to Delta			12	7	
LORP In Channel Average Flow [2]			**47**	**47**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/24/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			**41**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**52**	**55**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			2	6	
LORP In Channel Average Flow [2]			**46**	**47**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/25/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**49**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			**42**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**52**	**53**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			2	5	
LORP In Channel Average Flow [2]			**46**	**47**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/26/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			**50**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			**42**	**42**	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**52**	**52**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			2	4	
LORP In Channel Average Flow [2]			**46**	**47**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/27/2015

LORP Measuring Station	Augmenting Flows: Daily Avg Flow(cfs)	Augmenting Flows: 15 Day Avg Flow(cfs)	Owens River Flows: Daily Avg Flow(cfs)	Owens River Flows: 15 Day Avg Flow(cfs)	Owens River Flows: # Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**47**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**39**	**42**	14
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**52**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			3	3	
LORP In Channel Average Flow [2]			**45**	**46**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/28/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**47**	**49**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**38**	**41**	13
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**51**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			3	2	
LORP In Channel Average Flow [2]			**45**	**46**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/29/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**42**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**42**	**48**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**40**	**41**	13
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**51**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			3	2	
LORP In Channel Average Flow [2]			**44**	**46**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.3 ft	(Last Collected: 12/16/2015)
Lower Twin Lake Gage Read	2.15 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/30/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**47**	**48**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**46**	**42**	13
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station [1]			**53**	**51**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			3	3	
LORP In Channel Average Flow [2]			**47**	**46**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.37 ft	(Last Collected: 12/29/2015)
Lower Twin Lake Gage Read	2.18 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

Lower Owens River Project Flow Report for 12/31/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			**41**	**42**	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			**51**	**48**	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			**52**	**42**	13
Alabama Gates Return (augmentation)	0	17			
At Pumpback Station [1]			**53**	**52**	15
Pump Station			47	46	
Langemann Gate to Delta			3	3	
Weir to Delta			3	3	
LORP In Channel Average Flow [2]			**49**	**46**	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut [3]	28 Acres	03/09/2015	1 cfs	11/24/2015
Winterton	221 Acres	09/15/2015	1.6 cfs	10/16/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner [3]	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	484 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.37 ft	(Last Collected: 12/29/2015)
Lower Twin Lake Gage Read	2.18 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.
Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer: http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Robert Olin/Chad Galvin

DATE: Monday November 30th, 2015

REQUESTED BY: Eric Tillemans x30256

FLOW CHANGE LOCATION **Langemann Gate at Pumpstation**

START DATE: Tuesday December 1st, 2015 TIME: Any time

CHANGE FLOW: FROM: 4 cfs TO: 3 cfs at LORPS Langemann

C:
James Yannotta
Greg Loveland
Steve Howe
Bob Strub
Jason Olin
Larry Benbrook
Neal Gordon
Eric Tillemans
Clarence Martin
Gary Reiser
Bruce Peterson
Ben Butler
Chad Lamacchia

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.
Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information	
File Name	070706.ORABR.LOR.WAD
Start Date and Time	2007/07/06 07:48:17

Site Details	
Site Name	ORABR
Operator(s)	DJT

System Information	
Sensor Type	FlowTracker
Serial #	P1685
CPU Firmware Version	3.2
Software Ver	2.11

Units	(English Units)
Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Summary			
Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	**44.3025**

Discharge Uncertainty		
Category	**ISO**	**Stats**
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	**2.1%**	**1.8%**

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	*08:12*	*40.00*	*0.2/0.8*	*1.490*	*0.2*	*1.192*	*0.8245*	*1.00*	*0.6321*	*2.980*	*1.8837*	*4.3*
13	*08:13*	*40.00*	*0.2/0.8*	*1.490*	*0.8*	*0.298*	*0.4396*					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

SonTek FlowTracker v2.11

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD







Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek FlowTracker ... | 2:44 PM

SonTek FlowTracker v2.11

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

Open a FlowTracker file

Open many FlowTracker files/folders

The current export settings are:

- [x] Show Discharge Summary Report
- [x] Export ASCII Discharge file (DIS)
- [x] Export ASCII Control file (CTL)
- [x] Export ASCII Summary file (SUM)
- [x] Export ASCII Data file (DAT)
- [x] Export FlowPack file (FPX)
- [x] Put Headers on ASCII files

Connect to a FlowTracker

To download data and run diagnostics

Program Settings

Quality Control Settings

Show User's Manual

Show Technical Manual

Show Quick Start

About FlowTracker

English

SonTek
A YSI Environmental Company

070706.ORABR.LOR.WAD







Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



- Noise level check - Pass
- SNR check - Pass
- Peak location check - Pass
- Peak shape check - Pass

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek FlowTracker ... | 2:44 PM

SonTek Argonaut Data Processing - [FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)]

File Edit View Processing Argonaut Config Window Help

FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz
File	BROR_070801_a
File Size	65.18 kB
Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:

V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:

V Beam (m)	0.426
Stage (m)	1.304 V
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:

SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

start | Inbox - Microsoft Out... | Document2 - Microsof... | SonTek Argonaut Dat... | 2:49 PM

Station Number: 0088 Meas. No: 008

Station Name: LOR @ INTAKE Date: 12/03/2015

Party: MKH / BRP	Width: 29.6 ft	Processed by: MKH
Boat/Motor:	Area: 184 ft²	Mean Velocity: 0.231 ft/s
Gage Height: 7.02 ft	G.H.Change: 0.000 ft	Discharge: 42.3 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 2.64 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 8.00 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 6.21 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 74.29	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 49.7 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151203 intake000r.mmt

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	3	3	41	3.53	32.2	4.73	1.48	1.77	43.8	30	189	15:14	15:14	0.63	0.23	17	0
001	*R*	*3*	*3*	*35*	*3.64*	*33.8*	*4.91*	*0.918*	*1.52*	*44.8*	*29*	*180*	*15:15*	*15:15*	*0.70*	*0.25*	*9*	*0*
002	*L*	*3*	*3*	*40*	*3.04*	*28.5*	*4.03*	*1.41*	*1.70*	*38.7*	*29*	*183*	*15:16*	*15:16*	*0.63*	*0.21*	*15*	*2*
003	R	*3*	*3*	*41*	*3.43*	*31.4*	*4.48*	*0.989*	*2.05*	*42.3*	*29*	*178*	*15:17*	*15:17*	*0.59*	*0.24*	*20*	*0*
004	L	*3*	*3*	*37*	*3.46*	*31.1*	*4.91*	*1.48*	*1.62*	*42.6*	*30*	*184*	*15:18*	*15:19*	*0.67*	*0.23*	*11*	*0*
008	R	*3*	*3*	*37*	*3.46*	*31.5*	*4.56*	*0.353*	*1.77*	*41.6*	*31*	*190*	*15:21*	*15:22*	*0.67*	*0.22*	*14*	*1*
Mean		3	3	38	3.43	31.4	4.60	1.11	1.74	42.3	30	184	**Total**	00:08	0.65	0.23	14	0
SDev		0	0	3	0.205	1.71	0.333	0.446	0.179	2.09	0.8	4.8			0.04	0.01		
SD/M		0.00	0.00	0.07	0.06	0.05	0.07	0.40	0.10	0.05	0.03	0.03			0.06	0.06		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Station Number: 0088 Meas. No: 003

Station Name: LOR @ INTAKE Date: 12/30/2015

Party: MKH / BRP	Width: 28.4 ft	Processed by: MKH
Boat/Motor:	Area: 145 ft²	Mean Velocity: 0.294 ft/s
Gage Height: 5.87 ft	G.H.Change: 0.000 ft	Discharge: 42.6 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 1.57 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 6.68 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 5.10 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 69.55	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 50.1 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151230 INTAKE000r.mmt

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	3	3	36	4.03	28.5	5.54	1.06	3.46	42.6	28	144	15:27	15:27	0.71	0.30	11	0
001	R	3	3	35	4.06	29.6	4.70	1.06	3.14	42.6	29	145	15:28	15:28	0.59	0.30	6	0
002	L	3	3	36	4.10	29.9	5.16	0.600	2.54	42.3	30	151	15:29	15:29	0.63	0.28	6	0
003	R	3	3	35	4.03	30.5	4.48	0.848	3.07	42.9	27	139	15:30	15:30	0.70	0.31	6	0
Mean		3	3	35	4.05	29.6	4.97	0.892	3.05	42.6	28	145	**Total**	00:03	0.66	0.29	7	0
SDev		0	0	1	0.034	0.849	0.474	0.218	0.381	0.233	1.1	5.1			0.05	0.01		
SD/M		0.00	0.00	0.02	0.01	0.03	0.10	0.24	0.12	0.01	0.04	0.04			0.08	0.04		

Remarks:

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information

File Name	151229BR.RTN.WAD
Start Date and Time	2015/12/29 10:35:45

Site Details

Site Name	BLACKROCK RTN
Operator(s)	MKH

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	1.4%	2.2%
Width	0.2%	0.2%
Method	2.7%	-
# Stations	5.8%	-
Overall	**6.6%**	**2.4%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	6.000
Mean SNR	3.6 dB	Total Area	6.600
Mean Temp	33.53 °F	Mean Depth	1.100
Disch. Equation	Mid-Section	Mean Velocity	0.1714
		Total Discharge	**1.1313**

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Tue Dec 29 10:33:27 PST 2015	0.000	1.100		
2	Tue Dec 29 10:44:42 PST 2015	6.500	1.100		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	10:35	0.50	None	1.100	0.0	0.0	0.0000	1.00	0.1591	0.275	0.0438	3.9
1	*10:35*	*1.00*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1591*	*1.00*	*0.1591*	*0.550*	*0.0875*	*7.7*
2	*10:37*	*1.50*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1512*	*1.00*	*0.1512*	*0.825*	*0.1248*	*11.0*
3	*10:38*	*2.50*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1640*	*1.00*	*0.1640*	*1.100*	*0.1805*	*16.0*
4	*10:39*	*3.50*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1821*	*1.00*	*0.1821*	*1.100*	*0.2003*	*17.7*
5	*10:40*	*4.50*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1759*	*1.00*	*0.1759*	*1.100*	*0.1934*	*17.1*
6	*10:41*	*5.50*	*0.6*	*1.100*	*0.6*	*0.440*	*0.1939*	*1.00*	*0.1939*	*0.825*	*0.1600*	*14.1*
7	10:42	6.00	0.6	1.100	0.6	0.440	0.1709	1.00	0.1709	0.550	0.0940	8.3
8	10:42	6.50	None	1.100	0.0	0.0	0.0000	1.00	0.1709	0.275	0.0470	4.2

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information	
File Name	151229BR.RTN.WAD
Start Date and Time	2015/12/29 10:35:45

Site Details	
Site Name	BLACKROCK RTN
Operator(s)	MKH







Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information		Site Details	
File Name	151229BR.RTN.WAD	Site Name	BLACKROCK RTN
Start Date and Time	2015/12/29 10:35:45	Operator(s)	MKH

Quality Control

St	Loc	%Dep	Message
1	1.00	0.6	Low SNR: 2.5,3.8
2	1.50	0.6	Low SNR: 3.4,4.7
3	2.50	0.6	Low SNR: 3.0,3.0
4	3.50	0.6	Low SNR: 3.0,3.4
5	4.50	0.6	Low SNR: 3.8,4.3
6	5.50	0.6	High number of spikes: 7
		0.6	Low SNR: 2.1,3.8
		0.6	Boundary QC is Good; possible boundary interference

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information

File Name	151216BR.RTN.WAD
Start Date and Time	2015/12/16 10:36:34

Site Details

Site Name	BLACKROCK RTN
Operator(s)	MKH

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	2.2%	2.1%
Width	0.2%	0.2%
Method	2.7%	-
# Stations	5.8%	-
Overall	**6.8%**	**2.3%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	4.9 dB	Total Area	6.831
Mean Temp	33.09 °F	Mean Depth	1.150
Disch. Equation	Mid-Section	Mean Velocity	0.1883
		Total Discharge	**1.2863**

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Wed Dec 16 10:35:47 PST 2015	0.000	1.150		
2	Wed Dec 16 10:44:50 PST 2015	5.940	1.150		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	10:36	0.00	None	1.150	0.0	0.0	0.0000	1.00	0.1932	0.287	0.0556	4.3
1	*10:36*	*0.50*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1932*	*1.00*	*0.1932*	*0.575*	*0.1111*	*8.6*
2	*10:37*	*1.00*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1732*	*1.00*	*0.1732*	*0.862*	*0.1494*	*11.6*
3	*10:38*	*2.00*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1627*	*1.00*	*0.1627*	*1.150*	*0.1871*	*14.5*
4	*10:39*	*3.00*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1854*	*1.00*	*0.1854*	*1.150*	*0.2132*	*16.6*
5	*10:41*	*4.00*	*0.6*	*1.150*	*0.6*	*0.460*	*0.2139*	*1.00*	*0.2139*	*1.150*	*0.2460*	*19.1*
6	*10:42*	*5.00*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1975*	*1.00*	*0.1975*	*0.862*	*0.1703*	*13.2*
7	*10:43*	*5.50*	*0.6*	*1.150*	*0.6*	*0.460*	*0.1936*	*1.00*	*0.1936*	*0.540*	*0.1046*	*8.1*
8	10:43	5.94	None	1.150	0.0	0.0	0.0000	1.00	0.1936	0.253	0.0490	3.8

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information	
File Name	151216BR.RTN.WAD
Start Date and Time	2015/12/16 10:36:34

Site Details	
Site Name	BLACKROCK RTN
Operator(s)	MKH







Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information		Site Details	
File Name	151216BR.RTN.WAD	Site Name	BLACKROCK RTN
Start Date and Time	2015/12/16 10:36:34	Operator(s)	MKH

Quality Control

St	Loc	%Dep	Message
1	0.50	0.6	Boundary QC is Poor; possible boundary interference
2	1.00	0.6	High number of spikes: 6
		0.6	Low SNR: 3.0,4.3
		0.6	Boundary QC is Good; possible boundary interference
3	2.00	0.6	Low SNR: 4.7,3.8
		0.6	Boundary QC is Fair; possible boundary interference
4	3.00	0.6	High number of spikes: 9
5	4.00	0.6	High number of spikes: 5
		0.6	Boundary QC is Good; possible boundary interference
6	5.00	0.6	High number of spikes: 9
		0.6	Boundary QC is Good; possible boundary interference
7	5.50	0.6	High number of spikes: 10
		0.6	Boundary QC is Good; possible boundary interference

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information

File Name	151204BR.RTN.WAD
Start Date and Time	2015/12/04 09:56:14

Site Details

Site Name	BLACKROCK RTN
Operator(s)	MKH

System Information

Sensor Type	FlowTracker
Serial #	P2352
CPU Firmware Version	3.7
Software Ver	2.30
Mounting Correction	0.0%

Units (English Units)

Distance	ft
Velocity	ft/s
Area	ft^2
Discharge	cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.5%	1.5%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	**6.5%**	**1.8%**

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	10.5 dB	Total Area	6.653
Mean Temp	40.61 °F	Mean Depth	1.120
Disch. Equation	Mid-Section	Mean Velocity	0.1980
		Total Discharge	**1.3174**

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Fri Dec 4 09:55:20 PST 2015	0.000	1.120		
2	Fri Dec 4 10:03:26 PST 2015	5.940	1.120		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:56	0.00	None	1.120	0.0	0.0	0.0000	1.00	0.1617	0.280	0.0453	3.4
1	*09:56*	*0.50*	*0.6*	*1.120*	*0.6*	*0.448*	*0.1617*	*1.00*	*0.1617*	*0.560*	*0.0906*	*6.9*
2	*09:57*	*1.00*	*0.6*	*1.120*	*0.6*	*0.448*	*0.1913*	*1.00*	*0.1913*	*0.840*	*0.1607*	*12.2*
3	09:58	2.00	0.6	1.120	0.6	0.448	0.2018	1.00	0.2018	1.120	0.2260	17.2
4	09:59	3.00	0.6	1.120	0.6	0.448	0.2083	1.00	0.2083	1.120	0.2333	17.7
5	10:00	4.00	0.6	1.120	0.6	0.448	0.2182	1.00	0.2182	1.120	0.2444	18.5
6	10:01	5.00	0.6	1.120	0.6	0.448	0.1988	1.00	0.1988	0.840	0.1670	12.7
7	10:02	5.50	0.6	1.120	0.6	0.448	0.1942	1.00	0.1942	0.526	0.1022	7.8
8	10:02	5.94	None	1.120	0.0	0.0	0.0000	1.00	0.1942	0.246	0.0479	3.6

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information	
File Name	151204BR.RTN.WAD
Start Date and Time	2015/12/04 09:56:14

Site Details	
Site Name	BLACKROCK RTN
Operator(s)	MKH







Discharge Measurement Summary

Date Generated: Mon Jan 25 2016

File Information	
File Name	151204BR.RTN.WAD
Start Date and Time	2015/12/04 09:56:14

Site Details	
Site Name	BLACKROCK RTN
Operator(s)	MKH

Quality Control

St	Loc	%Dep	Message
1	0.50	0.6	Boundary QC is Fair; possible boundary interference
2	1.00	0.6	Boundary QC is Good; possible boundary interference

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	0	5	10	0	-0.095	0.86	0.039	0.036	0	33.5	33.1	76.1	113	111	0	35	34
2015	12	1	0	15	10	0.059	-0.118	0.86	0.033	0.03	0	34.4	33.1	76.1	114	111	0	34	34
2015	12	1	0	25	10	0.092	-0.154	0.86	0.033	0.03	0	34	32.7	76.1	113	110	0	34	34
2015	12	1	0	35	10	0.112	-0.128	0.86	0.033	0.03	0	34.4	32.7	76.1	114	110	0	34	34
2015	12	1	0	45	10	0.075	-0.102	0.86	0.03	0.03	0	34	32.7	75.3	114	110	0	35	34
2015	12	1	0	55	10	0.151	-0.23	0.86	0.033	0.03	0	34	32.7	76.1	113	109	0	34	33
2015	12	1	1	5	10	0.167	-0.194	0.86	0.033	0.03	0	34	33.1	75.3	113	111	0	34	34
2015	12	1	1	15	10	0.039	-0.102	0.86	0.033	0.03	0	33.5	33.1	75.7	112	111	0	34	34
2015	12	1	1	25	10	0.22	-0.269	0.86	0.033	0.03	0	34	32.7	75.3	114	110	0	35	34
2015	12	1	1	35	10	0.072	-0.066	0.86	0.036	0.033	0	34	32.3	74.8	114	109	0	35	34
2015	12	1	1	45	10	0.253	-0.246	0.86	0.033	0.03	0	34	32.3	75.7	113	109	0	34	34
2015	12	1	1	55	10	0.121	-0.121	0.86	0.033	0.03	0	34	31.8	75.3	114	109	0	35	35
2015	12	1	2	5	10	0.082	-0.102	0.86	0.033	0.03	0	34	32.7	75.3	114	110	0	35	34
2015	12	1	2	15	10	0.049	-0.075	0.86	0.03	0.026	0	33.5	33.1	75.7	113	111	0	35	34
2015	12	1	2	25	10	0.075	-0.049	0.86	0.036	0.033	0	33.5	32.7	75.3	113	109	0	35	33
2015	12	1	2	35	10	-0.03	0.046	0.86	0.03	0.026	0	34	33.1	75.7	113	110	0	34	33
2015	12	1	2	45	10	0.052	0.007	0.86	0.033	0.03	0	33.5	32.3	75.3	113	108	0	35	33
2015	12	1	2	55	10	-0.039	0.092	0.856	0.033	0.03	0	33.5	32.7	75.3	113	110	0	35	34
2015	12	1	3	5	10	0.154	-0.039	0.86	0.033	0.03	0	33.5	32.7	74.8	113	110	0	35	34
2015	12	1	3	15	10	0.102	0	0.86	0.033	0.03	0	33.5	31.8	74.8	112	109	0	34	35
2015	12	1	3	25	10	0	0.079	0.86	0.033	0.03	0	34.4	32.7	75.3	114	110	0	34	34
2015	12	1	3	35	10	0.23	-0.089	0.86	0.033	0.03	0	33.5	32.3	74.8	113	109	0	35	34
2015	12	1	3	45	10	0.148	0.079	0.86	0.033	0.03	0	34	32.3	74.8	113	109	0	34	34
2015	12	1	3	55	10	0.243	-0.144	0.86	0.033	0.03	0	33.5	32.7	74.4	113	109	0	35	33
2015	12	1	4	5	10	0.171	0	0.856	0.033	0.03	0	34	31.8	74.4	113	108	0	34	34
2015	12	1	4	15	10	0.131	0.151	0.856	0.033	0.03	0	33.1	31.8	75.3	112	108	0	35	34
2015	12	1	4	25	10	0.246	-0.052	0.86	0.03	0.03	0	34.4	31.4	74.4	114	108	0	34	35
2015	12	1	4	35	10	0.23	-0.03	0.86	0.033	0.033	0	33.5	31.4	74.8	113	107	0	35	34
2015	12	1	4	45	10	0.243	-0.016	0.86	0.033	0.033	0	33.1	31.8	74.4	112	107	0	35	33
2015	12	1	4	55	10	0.289	-0.039	0.86	0.033	0.03	0	33.5	31.8	74.4	112	108	0	34	34
2015	12	1	5	5	10	0.187	0.066	0.86	0.03	0.03	0	33.5	32.3	74.8	113	109	0	35	34
2015	12	1	5	15	10	0.308	0.01	0.856	0.039	0.036	0	33.5	31.8	74	113	108	0	35	34
2015	12	1	5	25	10	0.112	0.105	0.856	0.033	0.03	0	34	31.4	74.8	113	107	0	34	34
2015	12	1	5	35	10	0.2	-0.046	0.856	0.033	0.03	0	34	31.8	74.4	113	108	0	34	34
2015	12	1	5	45	10	0.187	0.082	0.856	0.039	0.036	0	34	32.3	74	113	109	0	34	34
2015	12	1	5	55	10	0.194	0.052	0.856	0.033	0.03	0	33.5	31.8	74	113	108	0	35	34
2015	12	1	6	5	10	0.259	-0.039	0.86	0.033	0.03	0	34	32.3	74	113	109	0	34	34
2015	12	1	6	15	10	0.049	0.039	0.856	0.033	0.03	0	34	31.8	74.4	113	108	0	34	34
2015	12	1	6	25	10	-0.02	0.135	0.856	0.033	0.03	0	33.5	31.8	74.4	113	109	0	35	35
2015	12	1	6	35	10	0.128	0.026	0.856	0.036	0.033	0	33.5	32.3	74.4	113	109	0	35	34
2015	12	1	6	45	10	0.066	0.066	0.856	0.033	0.03	0	33.5	31	74.4	112	107	0	34	35
2015	12	1	6	55	10	0.164	-0.007	0.856	0.036	0.033	0	33.5	31.8	74	113	108	0	35	34
2015	12	1	7	5	10	0.039	0.01	0.856	0.036	0.033	0	33.1	31	75.3	112	106	0	35	34
2015	12	1	7	15	10	0.157	0	0.856	0.033	0.03	0	33.1	31.8	74.4	112	108	0	35	34
2015	12	1	7	25	10	0.125	0.046	0.856	0.036	0.033	0	33.1	31.4	74.4	112	107	0	35	34
2015	12	1	7	35	10	0.144	-0.007	0.856	0.033	0.03	0	33.5	32.3	74.4	113	109	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	7	45	10	0.118	-0.016	0.856	0.036	0.033	0	34.4	32.7	74	115	109	0	35	33
2015	12	1	7	55	10	0.167	-0.013	0.856	0.033	0.03	0	34.4	32.7	74.4	115	110	0	35	34
2015	12	1	8	5	10	0.131	-0.108	0.856	0.03	0.03	0	34	33.1	74.4	114	111	0	35	34
2015	12	1	8	15	10	0.157	-0.033	0.856	0.03	0.026	0	34	33.1	74.4	114	111	0	35	34
2015	12	1	8	25	10	0.131	-0.161	0.856	0.039	0.039	0	34	32.3	74.4	114	109	0	35	34
2015	12	1	8	35	10	0.144	-0.013	0.856	0.033	0.03	0	34.4	31.8	74.8	115	108	0	35	34
2015	12	1	8	45	10	0.082	-0.079	0.856	0.033	0.03	0	34	31.8	74.4	114	108	0	35	34
2015	12	1	8	55	10	0.105	-0.049	0.856	0.033	0.03	0	34.4	31.8	74.8	115	108	0	35	34
2015	12	1	9	5	10	0.184	-0.151	0.856	0.033	0.03	0	34.4	31.8	74.8	114	109	0	34	35
2015	12	1	9	15	10	0.22	-0.089	0.856	0.033	0.03	0	34.4	31.4	74.8	114	108	0	34	35
2015	12	1	9	25	10	0.135	-0.089	0.856	0.033	0.03	0	34.4	31	74.8	114	107	0	34	35
2015	12	1	9	35	10	0.052	-0.049	0.856	0.036	0.033	0	34	32.3	74.8	114	109	0	35	34
2015	12	1	9	45	10	-0.007	0.105	0.856	0.039	0.036	0	34	31.4	75.7	114	107	0	35	34
2015	12	1	9	55	10	0.135	0.003	0.856	0.033	0.03	0	34.4	32.7	75.3	115	109	0	35	33
2015	12	1	10	5	10	0.272	-0.141	0.856	0.036	0.033	0	34.4	31.4	75.3	115	108	0	35	35
2015	12	1	10	15	10	0.22	-0.046	0.856	0.033	0.03	0	34.8	32.7	75.7	116	110	0	35	34
2015	12	1	10	25	10	0.072	0.098	0.856	0.03	0.026	0	34.4	32.7	75.7	115	110	0	35	34
2015	12	1	10	35	10	0.052	0.108	0.856	0.036	0.033	0	34.8	32.3	75.7	116	109	0	35	34
2015	12	1	10	45	10	0.22	0.052	0.856	0.033	0.03	0	34.8	32.7	75.7	116	110	0	35	34
2015	12	1	10	55	10	0.177	0.056	0.856	0.033	0.03	0	34.8	32.3	76.1	115	109	0	34	34
2015	12	1	11	5	10	0.121	0.049	0.856	0.036	0.033	0	34.8	32.7	75.7	116	110	0	35	34
2015	12	1	11	15	10	0.105	0.033	0.856	0.033	0.033	0	34.4	31.8	76.1	114	108	0	34	34
2015	12	1	11	25	10	0.118	-0.102	0.856	0.033	0.03	0	34.4	32.7	76.1	115	110	0	35	34
2015	12	1	11	35	10	0.069	-0.016	0.856	0.033	0.03	0	34.8	32.7	76.1	115	110	0	34	34
2015	12	1	11	45	10	0.092	-0.046	0.856	0.033	0.03	0	34	33.1	76.5	114	111	0	35	34
2015	12	1	11	55	10	0.121	-0.177	0.856	0.033	0.03	0	34.8	33.1	77	115	110	0	34	33
2015	12	1	12	5	10	0.184	-0.184	0.856	0.033	0.03	0	34.8	32.7	77	115	110	0	34	34
2015	12	1	12	15	10	0.161	-0.164	0.856	0.033	0.03	0	34.4	32.7	77	115	110	0	35	34
2015	12	1	12	25	10	0.112	-0.118	0.856	0.033	0.03	0	34.4	33.1	77	114	111	0	34	34
2015	12	1	12	35	10	0.036	-0.125	0.856	0.036	0.033	0	33.5	33.1	77	113	111	0	35	34
2015	12	1	12	45	10	0.052	-0.102	0.856	0.033	0.03	0	34.4	33.1	77	114	111	0	34	34
2015	12	1	12	55	10	0.036	-0.089	0.856	0.033	0.03	0	34.8	34	77.4	115	113	0	34	34
2015	12	1	13	5	10	0.062	-0.141	0.856	0.036	0.033	0	35.7	34.8	77.4	118	115	0	35	34
2015	12	1	13	15	10	0.118	-0.016	0.856	0.039	0.036	0	35.7	34.4	77.4	117	114	0	34	34
2015	12	1	13	25	10	0.226	-0.095	0.856	0.043	0.043	0	34.8	34.4	77.4	115	113	0	34	33
2015	12	1	13	35	10	0.148	-0.062	0.856	0.036	0.033	0	35.3	34	77	116	113	0	34	34
2015	12	1	13	45	10	0.2	-0.154	0.856	0.036	0.033	0	34.8	34	77.4	115	113	0	34	34
2015	12	1	13	55	10	0.141	-0.095	0.856	0.039	0.036	0	34.8	34	77.4	115	113	0	34	34
2015	12	1	14	5	10	0.075	-0.033	0.856	0.036	0.033	0	34.8	34	77.8	115	113	0	34	34
2015	12	1	14	15	10	0.171	0.013	0.856	0.033	0.03	0	34.4	34	77.8	114	113	0	34	34
2015	12	1	14	25	10	0.151	-0.069	0.856	0.033	0.03	0	34	33.5	78.3	114	112	0	35	34
2015	12	1	14	35	10	0.112	-0.023	0.856	0.039	0.036	0	34.4	33.5	78.3	114	112	0	34	34
2015	12	1	14	45	10	0.069	0.043	0.856	0.039	0.036	0	34.4	34.4	78.3	114	113	0	34	33
2015	12	1	14	55	10	0.092	-0.098	0.856	0.039	0.039	0	34.4	33.5	78.3	114	112	0	34	34
2015	12	1	15	5	10	0.161	-0.144	0.856	0.039	0.036	0	34.8	34.4	78.7	115	113	0	34	33
2015	12	1	15	15	10	0.197	-0.128	0.856	0.036	0.033	0	34.8	34.4	78.3	116	114	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	15	25	10	0.19	-0.072	0.856	0.043	0.039	0	37.8	37	77.4	122	119	0	34	33
2015	12	1	15	35	10	0.184	-0.112	0.856	0.039	0.036	0	35.7	34.8	78.3	117	115	0	34	34
2015	12	1	15	45	10	0.236	-0.246	0.856	0.033	0.03	0	35.3	34.8	78.7	116	114	0	34	33
2015	12	1	15	55	10	0.151	-0.184	0.856	0.039	0.036	0	35.3	34.4	78.3	116	114	0	34	34
2015	12	1	16	5	10	0.138	-0.072	0.856	0.036	0.033	0	37	35.7	78.3	120	117	0	34	34
2015	12	1	16	15	10	0.059	0	0.856	0.039	0.036	0	35.3	33.5	78.3	116	112	0	34	34
2015	12	1	16	25	10	0.082	-0.135	0.856	0.039	0.039	0	34.8	34.4	78.3	116	114	0	35	34
2015	12	1	16	35	10	0.151	-0.125	0.856	0.036	0.033	0	37	36.1	78.3	120	118	0	34	34
2015	12	1	16	45	10	0.197	-0.141	0.856	0.033	0.03	0	36.1	36.1	78.3	119	118	0	35	34
2015	12	1	16	55	10	0.115	-0.046	0.856	0.039	0.036	0	37	36.5	77.8	120	119	0	34	34
2015	12	1	17	5	10	0.125	-0.046	0.856	0.036	0.033	0	37.4	36.5	78.3	120	119	0	33	34
2015	12	1	17	15	10	0.141	-0.072	0.856	0.039	0.036	0	37.4	36.5	78.7	121	119	0	34	34
2015	12	1	17	25	10	0.154	0.013	0.856	0.039	0.039	0	36.5	36.1	77.8	119	118	0	34	34
2015	12	1	17	35	10	0.112	-0.039	0.856	0.039	0.036	0	36.5	36.5	77.8	119	118	0	34	33
2015	12	1	17	45	10	0.184	-0.125	0.856	0.033	0.03	0	37.4	36.5	78.3	121	118	0	34	33
2015	12	1	17	55	10	0.144	-0.059	0.856	0.036	0.033	0	38.7	37.8	77.4	124	122	0	34	34
2015	12	1	18	5	10	0.095	0.003	0.856	0.033	0.03	0	37	36.5	77.8	120	119	0	34	34
2015	12	1	18	15	10	0.138	-0.085	0.856	0.039	0.039	0	37	36.1	78.3	120	118	0	34	34
2015	12	1	18	25	10	0.18	-0.075	0.856	0.033	0.03	0	36.1	36.5	77.8	119	118	0	35	33
2015	12	1	18	35	10	0.154	-0.046	0.856	0.039	0.036	0	37	37	77.8	120	119	0	34	33
2015	12	1	18	45	10	0.03	-0.003	0.856	0.036	0.033	0	37	36.5	77.8	120	119	0	34	34
2015	12	1	18	55	10	0.079	-0.056	0.856	0.039	0.036	0	37	37.4	77.8	120	120	0	34	33
2015	12	1	19	5	10	0.164	0.036	0.856	0.036	0.033	0	37.4	37	77.8	121	120	0	34	34
2015	12	1	19	15	10	0.148	-0.013	0.856	0.036	0.033	0	37	37.4	77.4	121	120	0	35	33
2015	12	1	19	25	10	0.171	0.039	0.856	0.046	0.043	0	37	37	78.3	121	119	0	35	33
2015	12	1	19	35	10	0.154	-0.013	0.856	0.039	0.036	0	36.5	37	77.8	120	119	0	35	33
2015	12	1	19	45	10	0.194	0.016	0.856	0.033	0.03	0	36.5	36.5	77.8	119	118	0	34	33
2015	12	1	19	55	10	0.2	0.003	0.856	0.039	0.036	0	36.5	36.1	77.8	119	117	0	34	33
2015	12	1	20	5	10	0.184	-0.007	0.856	0.049	0.046	0	36.1	35.7	78.3	118	117	0	34	34
2015	12	1	20	15	10	0.167	-0.112	0.856	0.039	0.036	0	35.7	34.8	78.3	117	115	0	34	34
2015	12	1	20	25	10	0.033	-0.118	0.856	0.039	0.036	0	34.8	34.4	78.3	116	114	0	35	34
2015	12	1	20	35	10	0.118	-0.197	0.856	0.036	0.033	0	35.3	34.4	78.3	116	114	0	34	34
2015	12	1	20	45	10	0.167	-0.128	0.856	0.036	0.033	0	35.3	34.4	78.3	116	113	0	34	33
2015	12	1	20	55	10	0.148	-0.148	0.856	0.039	0.036	0	34.8	34.4	78.7	115	113	0	34	33
2015	12	1	21	5	10	0.18	-0.128	0.856	0.033	0.03	0	34.4	33.5	78.3	114	112	0	34	34
2015	12	1	21	15	10	0.184	-0.085	0.856	0.036	0.033	0	36.1	34.8	77.8	117	114	0	33	33
2015	12	1	21	25	10	0.075	-0.092	0.856	0.039	0.036	0	35.3	34.4	78.3	116	113	0	34	33
2015	12	1	21	35	10	0.144	-0.154	0.856	0.036	0.033	0	34.8	33.5	78.3	115	112	0	34	34
2015	12	1	21	45	10	0.167	-0.072	0.856	0.033	0.03	0	34.4	34.4	78.3	114	113	0	34	33
2015	12	1	21	55	10	0.213	-0.21	0.856	0.033	0.03	0	34.4	33.5	78.7	114	111	0	34	33
2015	12	1	22	5	10	0.141	-0.02	0.856	0.043	0.039	0	34	33.1	78.7	113	111	0	34	34
2015	12	1	22	15	10	0.266	-0.2	0.856	0.039	0.036	0	34	33.1	78.3	113	111	0	34	34
2015	12	1	22	25	10	0.262	-0.203	0.856	0.039	0.039	0	34	33.5	78.3	113	112	0	34	34
2015	12	1	22	35	10	0.223	-0.167	0.856	0.039	0.039	0	33.5	33.5	78.3	113	111	0	35	33
2015	12	1	22	45	10	0.226	-0.21	0.856	0.036	0.033	0	34	33.1	78.3	113	111	0	34	34
2015	12	1	22	55	10	0.249	-0.161	0.856	0.033	0.03	0	33.5	33.1	78.3	112	111	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	23	5	10	0.069	0.023	0.856	0.039	0.039	0	34.4	33.5	78.3	114	111	0	34	33
2015	12	1	23	15	10	0.18	-0.128	0.856	0.039	0.036	0	33.5	33.5	78.3	112	111	0	34	33
2015	12	1	23	25	10	0.161	-0.102	0.856	0.039	0.036	0	33.1	33.1	77.8	112	111	0	35	34
2015	12	1	23	35	10	0.151	-0.154	0.856	0.036	0.033	0	34	33.5	78.3	113	111	0	34	33
2015	12	1	23	45	10	0.276	-0.22	0.856	0.036	0.033	0	33.1	33.5	78.3	112	111	0	35	33
2015	12	1	23	55	10	0.354	-0.19	0.856	0.039	0.036	0	34	33.1	78.3	113	111	0	34	34
2015	12	2	0	5	10	0.259	-0.157	0.856	0.039	0.036	0	34	32.7	77.8	113	110	0	34	34
2015	12	2	0	15	10	0.095	-0.026	0.856	0.039	0.039	0	34	32.7	77.8	113	110	0	34	34
2015	12	2	0	25	10	0.066	-0.007	0.856	0.036	0.033	0	34.4	33.1	78.3	114	111	0	34	34
2015	12	2	0	35	10	0.115	-0.154	0.856	0.033	0.03	0	34	33.1	77.8	113	111	0	34	34
2015	12	2	0	45	10	0.21	-0.285	0.856	0.039	0.036	0	33.5	33.1	77.8	113	110	0	35	33
2015	12	2	0	55	10	0.289	-0.295	0.856	0.033	0.03	0	34	33.1	77.8	113	111	0	34	34
2015	12	2	1	5	10	0.164	-0.174	0.856	0.039	0.036	0	33.5	32.7	77.8	113	110	0	35	34
2015	12	2	1	15	10	0.108	-0.266	0.856	0.03	0.03	0	33.5	33.1	77	112	111	0	34	34
2015	12	2	1	25	10	0	-0.115	0.856	0.039	0.036	0	33.5	33.1	77.4	112	111	0	34	34
2015	12	2	1	35	10	0.026	-0.092	0.856	0.033	0.03	0	34	32.7	77.4	113	109	0	34	33
2015	12	2	1	45	10	0	-0.154	0.856	0.033	0.03	0	33.5	32.3	77.8	112	109	0	34	34
2015	12	2	1	55	10	0.039	-0.108	0.856	0.033	0.03	0	33.1	32.3	77.4	112	110	0	35	35
2015	12	2	2	5	10	0.069	-0.18	0.856	0.033	0.03	0	34	32.3	77.4	113	109	0	34	34
2015	12	2	2	15	10	0.079	-0.167	0.856	0.033	0.03	0	34.4	33.1	77.4	115	111	0	35	34
2015	12	2	2	25	10	0.069	-0.089	0.856	0.03	0.03	0	37	36.5	76.1	121	119	0	35	34
2015	12	2	2	35	10	0.19	-0.121	0.856	0.039	0.036	0	36.5	35.3	76.5	119	117	0	34	35
2015	12	2	2	45	10	0.059	-0.121	0.856	0.03	0.03	0	34.8	34.4	77	116	114	0	35	34
2015	12	2	2	55	10	0.141	-0.157	0.856	0.036	0.033	0	34	33.1	76.5	114	111	0	35	34
2015	12	2	3	5	10	0.164	-0.164	0.856	0.039	0.036	0	34.4	32.7	77	114	111	0	34	35
2015	12	2	3	15	10	0.161	-0.098	0.856	0.033	0.03	0	33.5	32.7	76.5	113	110	0	35	34
2015	12	2	3	25	10	0.266	-0.282	0.856	0.033	0.03	0	33.5	32.3	77	113	109	0	35	34
2015	12	2	3	35	10	0.18	-0.19	0.856	0.033	0.03	0	33.1	33.1	77	112	111	0	35	34
2015	12	2	3	45	10	0.039	-0.066	0.856	0.033	0.03	0	33.5	31.8	77	113	109	0	35	35
2015	12	2	3	55	10	0.128	-0.075	0.856	0.033	0.03	0	33.1	32.3	76.5	112	109	0	35	34
2015	12	2	4	5	10	-0.007	0.039	0.856	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	2	4	15	10	0.036	-0.056	0.856	0.03	0.026	0	34	32.7	77	113	110	0	34	34
2015	12	2	4	25	10	0.043	0.049	0.856	0.033	0.03	0	33.5	32.7	77	113	109	0	35	33
2015	12	2	4	35	10	0.062	-0.062	0.856	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	2	4	45	10	0.095	-0.144	0.856	0.039	0.036	0	34	32.7	77	113	110	0	34	34
2015	12	2	4	55	10	-0.023	0.049	0.856	0.033	0.03	0	33.5	32.7	77.4	112	110	0	34	34
2015	12	2	5	5	10	0.141	-0.164	0.856	0.026	0.023	0	33.1	31.8	77	112	109	0	35	35
2015	12	2	5	15	10	0.121	-0.075	0.856	0.033	0.03	0	33.1	32.7	77	112	110	0	35	34
2015	12	2	5	25	10	0.121	-0.095	0.856	0.033	0.03	0	33.1	32.7	77	112	109	0	35	33
2015	12	2	5	35	10	0.262	-0.167	0.856	0.033	0.03	0	33.1	31.8	76.5	112	109	0	35	35
2015	12	2	5	45	10	0.22	-0.115	0.856	0.033	0.03	0	33.5	32.3	76.5	113	109	0	35	34
2015	12	2	5	55	10	-0.049	0.128	0.853	0.033	0.03	0	33.5	32.3	77	112	109	0	34	34
2015	12	2	6	5	10	0.089	0.052	0.853	0.033	0.03	0	33.5	32.3	77	112	108	0	34	33
2015	12	2	6	15	10	0	0.164	0.853	0.033	0.03	0	33.5	32.3	76.5	112	109	0	34	34
2015	12	2	6	25	10	0.062	0.092	0.853	0.03	0.026	0	33.5	31.8	76.5	112	108	0	34	34
2015	12	2	6	35	10	0.056	0.052	0.853	0.036	0.033	0	34	31.8	76.5	113	107	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	6	45	10	0.262	-0.141	0.853	0.033	0.03	0	33.1	31.8	77	112	108	0	35	34
2015	12	2	6	55	10	0.016	0.213	0.853	0.033	0.03	0	33.5	32.3	77	112	108	0	34	33
2015	12	2	7	5	10	0.269	-0.108	0.853	0.033	0.03	0	33.1	31	77	112	106	0	35	34
2015	12	2	7	15	10	0.331	-0.177	0.853	0.033	0.03	0	32.7	31.4	77.4	111	107	0	35	34
2015	12	2	7	25	10	0.062	0.151	0.853	0.03	0.026	0	33.1	31.8	77.4	112	108	0	35	34
2015	12	2	7	35	10	0.157	-0.115	0.853	0.033	0.033	0	34	31.8	77.4	113	108	0	34	34
2015	12	2	7	45	10	0.318	-0.079	0.853	0.036	0.033	0	33.5	31.8	77	113	108	0	35	34
2015	12	2	7	55	10	0.328	-0.118	0.853	0.033	0.033	0	33.5	31.8	77	113	108	0	35	34
2015	12	2	8	5	10	0.315	-0.148	0.853	0.033	0.03	0	33.5	32.7	77.4	113	110	0	35	34
2015	12	2	8	15	10	0.249	-0.079	0.853	0.033	0.033	0	33.5	32.3	77.4	113	109	0	35	34
2015	12	2	8	25	10	0.285	-0.056	0.853	0.033	0.03	0	34	32.3	77.4	114	109	0	35	34
2015	12	2	8	35	10	0.118	0.108	0.853	0.033	0.033	0	33.5	32.3	77.8	113	109	0	35	34
2015	12	2	8	45	10	0.121	-0.023	0.853	0.033	0.03	0	33.5	32.3	77.4	113	109	0	35	34
2015	12	2	8	55	10	0.177	0.03	0.853	0.033	0.03	0	33.5	32.7	77.4	113	109	0	35	33
2015	12	2	9	5	10	0.423	-0.243	0.853	0.033	0.03	0	33.1	32.7	77.8	112	110	0	35	34
2015	12	2	9	15	10	0.187	-0.007	0.853	0.03	0.026	0	33.5	32.7	77	113	110	0	35	34
2015	12	2	9	25	10	0.105	-0.033	0.853	0.033	0.03	0	33.5	32.7	77.4	113	110	0	35	34
2015	12	2	9	35	10	0.259	-0.135	0.853	0.033	0.03	0	33.5	32.3	77.8	113	109	0	35	34
2015	12	2	9	45	10	0.079	0	0.853	0.036	0.033	0	34	32.7	77.8	114	110	0	35	34
2015	12	2	9	55	10	0.066	0	0.853	0.033	0.03	0	33.5	32.3	77.4	113	109	0	35	34
2015	12	2	10	5	10	0.138	-0.075	0.853	0.033	0.03	0	33.5	32.3	77.8	113	109	0	35	34
2015	12	2	10	15	10	0.174	-0.125	0.853	0.033	0.03	0	34.4	32.3	77.8	114	110	0	34	35
2015	12	2	10	25	10	0.092	-0.043	0.853	0.036	0.033	0	34	33.5	77.8	114	111	0	35	33
2015	12	2	10	35	10	0.161	-0.18	0.853	0.033	0.03	0	34.4	33.5	77.4	115	112	0	35	34
2015	12	2	10	45	10	0.112	-0.112	0.853	0.033	0.03	0	34	33.5	77.8	114	112	0	35	34
2015	12	2	10	55	10	0.171	-0.207	0.853	0.033	0.03	0	34.4	32.7	77.8	114	111	0	34	35
2015	12	2	11	5	10	0.079	-0.184	0.853	0.036	0.033	0	34	32.7	78.3	113	110	0	34	34
2015	12	2	11	15	10	-0.039	-0.112	0.853	0.033	0.03	0	34	33.5	78.7	114	112	0	35	34
2015	12	2	11	25	10	-0.01	-0.151	0.853	0.033	0.03	0	34	32.7	78.7	113	110	0	34	34
2015	12	2	11	35	10	0.052	-0.092	0.853	0.036	0.033	0	34.4	33.1	78.7	114	111	0	34	34
2015	12	2	11	45	10	0.052	-0.19	0.853	0.033	0.03	0	33.5	33.1	78.7	112	111	0	34	34
2015	12	2	11	55	10	0.115	-0.095	0.853	0.036	0.033	0	34	34	78.7	113	112	0	34	33
2015	12	2	12	5	10	0.236	-0.243	0.853	0.033	0.03	0	34	32.7	79.1	113	111	0	34	35
2015	12	2	12	15	10	0.207	-0.141	0.856	0.033	0.03	0	34	34	78.7	113	112	0	34	33
2015	12	2	12	25	10	0.03	0.013	0.853	0.036	0.033	0	34.4	33.5	78.7	114	112	0	34	34
2015	12	2	12	35	10	0.095	0.02	0.853	0.036	0.033	0	37	37	78.3	121	119	0	35	33
2015	12	2	12	45	10	0.082	-0.112	0.853	0.039	0.039	0	36.1	36.5	78.3	119	119	0	35	34
2015	12	2	12	55	10	0.082	-0.098	0.853	0.039	0.036	0	34.8	33.5	79.1	115	112	0	34	34
2015	12	2	13	5	10	0.03	0.003	0.856	0.033	0.03	0	34.4	34	79.1	114	113	0	34	34
2015	12	2	13	15	10	-0.056	0.052	0.856	0.033	0.03	0	34	33.5	79.1	114	111	0	35	33
2015	12	2	13	25	10	-0.023	0.059	0.856	0.039	0.039	0	34.4	33.5	79.1	114	112	0	34	34
2015	12	2	13	35	10	0.043	0.016	0.856	0.039	0.036	0	34.4	33.5	79.1	114	112	0	34	34
2015	12	2	13	45	10	0.056	-0.095	0.856	0.036	0.033	0	33.5	33.5	79.1	112	111	0	34	33
2015	12	2	13	55	10	0.2	-0.138	0.856	0.039	0.036	0	33.1	33.1	79.1	111	111	0	34	34
2015	12	2	14	5	10	0.141	-0.167	0.856	0.039	0.036	0	33.1	32.3	79.6	112	109	0	35	34
2015	12	2	14	15	10	0.2	-0.115	0.856	0.039	0.039	0	33.1	32.7	79.6	111	110	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	14	25	10	0.135	-0.135	0.856	0.036	0.033	0	33.5	33.1	79.1	112	110	0	34	33
2015	12	2	14	35	10	0.128	-0.033	0.856	0.033	0.03	0	35.7	36.1	79.1	117	117	0	34	33
2015	12	2	14	45	10	0.125	-0.075	0.856	0.036	0.033	0	34.8	35.3	79.1	116	115	0	35	33
2015	12	2	14	55	10	0.161	-0.023	0.853	0.039	0.036	0	41.7	41.3	76.5	130	129	0	33	33
2015	12	2	15	5	10	0.187	0	0.856	0.039	0.036	0	39.1	38.7	77.8	125	124	0	34	34
2015	12	2	15	15	10	0.108	-0.03	0.856	0.033	0.03	0	36.1	36.1	79.1	118	117	0	34	33
2015	12	2	15	25	10	0.144	-0.102	0.856	0.039	0.036	0	34.8	34.8	79.1	115	114	0	34	33
2015	12	2	15	35	10	0.213	-0.118	0.856	0.046	0.043	0	34.4	34	79.1	114	113	0	34	34
2015	12	2	15	45	10	0.036	0.046	0.853	0.043	0.039	0	34.8	35.3	79.1	115	115	0	34	33
2015	12	2	15	55	10	0.085	0.098	0.853	0.039	0.036	0	43.9	43	74.4	136	133	0	34	33
2015	12	2	16	5	10	0.095	0.033	0.853	0.036	0.033	0	40	39.1	77	127	125	0	34	34
2015	12	2	16	15	10	0.177	-0.059	0.853	0.036	0.033	0	36.5	37	78.3	119	119	0	34	33
2015	12	2	16	25	10	0.118	-0.033	0.853	0.043	0.039	0	40	39.6	77	127	125	0	34	33
2015	12	2	16	35	10	0.141	0.003	0.853	0.036	0.033	0	46.9	46	71.4	143	141	0	34	34
2015	12	2	16	45	10	0.184	0.007	0.853	0.039	0.036	0	42.1	41.3	75.3	132	129	0	34	33
2015	12	2	16	55	10	0.108	-0.033	0.853	0.036	0.033	0	38.3	38.3	77.8	123	122	0	34	33
2015	12	2	17	5	10	0.151	0.016	0.853	0.043	0.039	0	37.4	37	78.3	121	119	0	34	33
2015	12	2	17	15	10	0.131	0.043	0.853	0.033	0.03	0	37.8	37	78.3	121	119	0	33	33
2015	12	2	17	25	10	0.128	0.02	0.853	0.036	0.033	0	37	37.4	77.8	120	120	0	34	33
2015	12	2	17	35	10	0.177	-0.082	0.853	0.043	0.039	0	43.4	42.1	74	135	132	0	34	34
2015	12	2	17	45	10	0.2	-0.043	0.853	0.039	0.036	0	39.6	38.7	76.5	126	124	0	34	34
2015	12	2	17	55	10	0.203	0	0.853	0.036	0.033	0	38.7	38.7	77	124	123	0	34	33
2015	12	2	18	5	10	0.144	0.026	0.853	0.036	0.033	0	37.4	37	77.8	121	119	0	34	33
2015	12	2	18	15	10	0.157	0.046	0.853	0.033	0.03	0	38.3	37.4	77.4	123	121	0	34	34
2015	12	2	18	25	10	0.141	-0.023	0.853	0.033	0.03	0	37.8	38.3	78.3	122	122	0	34	33
2015	12	2	18	35	10	0.21	0.033	0.853	0.033	0.03	0	37.8	37.8	77.8	121	121	0	33	33
2015	12	2	18	45	10	0.154	0.095	0.853	0.043	0.039	0	36.5	37	77.8	119	119	0	34	33
2015	12	2	18	55	10	0.112	0.059	0.853	0.039	0.039	0	37	37	78.3	120	119	0	34	33
2015	12	2	19	5	10	0.128	0	0.853	0.036	0.033	0	36.1	36.1	77.8	117	118	0	33	34
2015	12	2	19	15	10	0.171	-0.013	0.853	0.039	0.039	0	35.7	35.3	78.3	117	116	0	34	34
2015	12	2	19	25	10	0.121	0.079	0.853	0.043	0.039	0	35.7	35.7	78.3	117	116	0	34	33
2015	12	2	19	35	10	0.184	-0.089	0.856	0.039	0.036	0	35.3	35.7	78.7	117	116	0	35	33
2015	12	2	19	45	10	0.21	-0.069	0.856	0.033	0.03	0	35.7	35.3	78.7	117	115	0	34	33
2015	12	2	19	55	10	0.22	-0.102	0.856	0.033	0.03	0	35.3	35.3	78.7	116	115	0	34	33
2015	12	2	20	5	10	0.194	-0.108	0.856	0.036	0.033	0	35.3	34.8	78.7	116	115	0	34	34
2015	12	2	20	15	10	0.161	-0.128	0.856	0.039	0.039	0	34.8	34.8	78.7	115	114	0	34	33
2015	12	2	20	25	10	0.138	-0.069	0.856	0.036	0.033	0	34.4	34.4	79.6	114	113	0	34	33
2015	12	2	20	35	10	0.098	-0.01	0.856	0.039	0.036	0	34.8	34.8	78.3	115	114	0	34	33
2015	12	2	20	45	10	0.003	-0.003	0.856	0.033	0.03	0	35.3	34.4	78.7	116	114	0	34	34
2015	12	2	20	55	10	0.02	0.026	0.856	0.039	0.036	0	34	34.4	79.1	114	114	0	35	34
2015	12	2	21	5	10	0.069	0.003	0.856	0.033	0.03	0	34	34.4	79.1	113	113	0	34	33
2015	12	2	21	15	10	0	0	0.856	0.039	0.036	0	34	34.4	79.1	114	113	0	35	33
2015	12	2	21	25	10	-0.059	0.043	0.853	0.033	0.03	0	34	33.5	79.1	113	112	0	34	34
2015	12	2	21	35	10	0.098	-0.013	0.853	0.043	0.039	0	34	34.4	79.1	113	113	0	34	33
2015	12	2	21	45	10	0.075	-0.016	0.856	0.039	0.036	0	34	34	79.1	113	112	0	34	33
2015	12	2	21	55	10	0.089	-0.154	0.853	0.043	0.039	0	34.4	33.5	79.1	114	112	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	22	5	10	0.095	-0.085	0.853	0.039	0.036	0	33.5	33.5	79.1	112	111	0	34	33
2015	12	2	22	15	10	0.125	-0.085	0.853	0.033	0.033	0	34	33.1	79.1	113	111	0	34	34
2015	12	2	22	25	10	0.125	-0.098	0.853	0.036	0.033	0	33.5	33.1	79.1	112	111	0	34	34
2015	12	2	22	35	10	0.154	-0.072	0.853	0.036	0.033	0	34	33.5	79.1	113	111	0	34	33
2015	12	2	22	45	10	0.059	-0.023	0.853	0.049	0.046	0	34	33.1	78.7	113	111	0	34	34
2015	12	2	22	55	10	0.075	-0.043	0.853	0.039	0.036	0	34	33.5	79.1	113	111	0	34	33
2015	12	2	23	5	10	0.282	-0.305	0.853	0.039	0.036	0	34	33.1	79.1	113	111	0	34	34
2015	12	2	23	15	10	0.167	-0.161	0.853	0.033	0.03	0	34	34	78.7	113	112	0	34	33
2015	12	2	23	25	10	0.174	-0.003	0.853	0.049	0.046	0	33.1	33.5	78.7	112	111	0	35	33
2015	12	2	23	35	10	0.203	-0.197	0.853	0.039	0.039	0	34	34	79.1	113	112	0	34	33
2015	12	2	23	45	10	0.095	-0.095	0.853	0.039	0.036	0	34.4	34	79.6	114	112	0	34	33
2015	12	2	23	55	10	0.174	-0.105	0.853	0.036	0.033	0	34	33.5	79.1	113	112	0	34	34
2015	12	3	0	5	10	0.144	-0.056	0.853	0.039	0.039	0	37	37	77.8	120	119	0	34	33
2015	12	3	0	15	10	0.052	0.039	0.853	0.049	0.046	0	34.8	34.4	78.3	115	114	0	34	34
2015	12	3	0	25	10	0.085	0.059	0.853	0.043	0.039	0	33.5	34	79.6	113	112	0	35	33
2015	12	3	0	35	10	0	-0.039	0.853	0.039	0.039	0	34.4	34	78.7	114	112	0	34	33
2015	12	3	0	45	10	0.141	-0.072	0.85	0.039	0.039	0	35.3	35.3	78.7	117	115	0	35	33
2015	12	3	0	55	10	0.118	0	0.85	0.036	0.033	0	34	34	78.7	113	112	0	34	33
2015	12	3	1	5	10	0.154	-0.128	0.85	0.036	0.033	0	37.4	37.4	77.4	121	120	0	34	33
2015	12	3	1	15	10	0.108	-0.049	0.85	0.043	0.043	0	34.8	34.8	78.3	115	114	0	34	33
2015	12	3	1	25	10	0.131	-0.095	0.85	0.036	0.033	0	36.1	35.3	78.3	118	116	0	34	34
2015	12	3	1	35	10	0.085	-0.016	0.85	0.03	0.03	0	36.1	35.7	77.8	118	117	0	34	34
2015	12	3	1	45	10	0.151	-0.082	0.85	0.039	0.039	0	37.8	37	77	122	120	0	34	34
2015	12	3	1	55	10	0.194	-0.092	0.85	0.039	0.039	0	36.5	35.7	77.8	119	117	0	34	34
2015	12	3	2	5	10	0.21	-0.121	0.85	0.036	0.033	0	35.7	34.8	77.8	117	115	0	34	34
2015	12	3	2	15	10	0.164	-0.092	0.85	0.052	0.049	0	37	36.1	77.8	120	118	0	34	34
2015	12	3	2	25	10	0.157	-0.115	0.85	0.036	0.033	0	40	38.7	76.1	127	124	0	34	34
2015	12	3	2	35	10	0.118	-0.144	0.85	0.039	0.036	0	37	36.5	77.4	120	118	0	34	33
2015	12	3	2	45	10	0.217	-0.036	0.85	0.033	0.03	0	39.6	40.4	75.7	127	127	0	35	33
2015	12	3	2	55	10	0.128	-0.082	0.85	0.033	0.03	0	36.5	35.7	77.4	119	117	0	34	34
2015	12	3	3	5	10	0.072	-0.069	0.85	0.043	0.039	0	36.1	35.7	77.8	118	117	0	34	34
2015	12	3	3	15	10	0.154	-0.144	0.85	0.036	0.033	0	35.3	35.7	77.8	116	116	0	34	33
2015	12	3	3	25	10	0.036	-0.082	0.846	0.036	0.033	0	35.7	35.7	77.8	117	116	0	34	33
2015	12	3	3	35	10	0.082	-0.121	0.846	0.039	0.039	0	36.1	36.1	77.4	119	117	0	35	33
2015	12	3	3	45	10	0.164	-0.046	0.846	0.043	0.039	0	43.9	42.6	73.5	135	132	0	33	33
2015	12	3	3	55	10	0.144	-0.007	0.846	0.036	0.033	0	38.3	37.8	77	124	121	0	35	33
2015	12	3	4	5	10	0.112	-0.144	0.846	0.036	0.033	0	40.4	39.1	75.7	128	125	0	34	34
2015	12	3	4	15	10	0.108	-0.026	0.846	0.039	0.036	0	37.4	37.4	77	122	121	0	35	34
2015	12	3	4	25	10	0.108	-0.079	0.846	0.039	0.036	0	37.4	36.1	77.4	121	118	0	34	34
2015	12	3	4	35	10	0.059	-0.049	0.846	0.036	0.033	0	35.3	34.8	77.4	116	115	0	34	34
2015	12	3	4	45	10	0.023	-0.118	0.846	0.046	0.043	0	34.8	34.4	77	115	114	0	34	34
2015	12	3	4	55	10	0.125	-0.079	0.846	0.036	0.033	0	35.3	34.8	77.4	117	114	0	35	33
2015	12	3	5	5	10	0.082	-0.082	0.846	0.039	0.036	0	37	37	76.1	121	120	0	35	34
2015	12	3	5	15	10	0.135	-0.049	0.846	0.036	0.033	0	38.7	38.7	76.1	124	123	0	34	33
2015	12	3	5	25	10	0.082	-0.079	0.846	0.036	0.033	0	35.7	35.3	77	117	115	0	34	33
2015	12	3	5	35	10	0.013	-0.108	0.846	0.036	0.033	0	33.5	33.5	77.8	113	111	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	5	45	10	0.059	-0.187	0.846	0.033	0.03	0	34.4	33.5	77.4	114	111	0	34	33
2015	12	3	5	55	10	-0.03	-0.207	0.846	0.036	0.033	0	34	32.7	77	113	110	0	34	34
2015	12	3	6	5	10	0.052	-0.21	0.846	0.036	0.033	0	34	33.5	77	114	112	0	35	34
2015	12	3	6	15	10	0.013	-0.21	0.843	0.033	0.03	0	33.5	33.1	77	113	110	0	35	33
2015	12	3	6	25	10	-0.01	-0.279	0.843	0.036	0.033	0	34.4	32.7	77.4	114	110	0	34	34
2015	12	3	6	35	10	-0.026	-0.2	0.843	0.039	0.036	0	33.1	32.7	76.5	112	110	0	35	34
2015	12	3	6	45	10	0	-0.171	0.843	0.039	0.036	0	34	32.7	77	113	110	0	34	34
2015	12	3	6	55	10	0.105	-0.262	0.843	0.039	0.036	0	34	33.1	77	113	110	0	34	33
2015	12	3	7	5	10	-0.072	-0.167	0.843	0.033	0.03	0	34	33.1	77.4	114	110	0	35	33
2015	12	3	7	15	10	0.016	-0.171	0.843	0.036	0.033	0	34	33.1	77	113	111	0	34	34
2015	12	3	7	25	10	-0.043	-0.197	0.843	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	3	7	35	10	-0.089	-0.115	0.843	0.033	0.03	0	33.5	32.7	76.5	113	109	0	35	33
2015	12	3	7	45	10	-0.102	-0.108	0.843	0.033	0.03	0	33.5	32.7	77	113	110	0	35	34
2015	12	3	7	55	10	0.036	-0.108	0.843	0.036	0.033	0	33.5	32.3	77	113	109	0	35	34
2015	12	3	8	5	10	-0.177	-0.121	0.843	0.033	0.033	0	33.5	32.7	76.5	113	109	0	35	33
2015	12	3	8	15	10	-0.102	-0.026	0.843	0.033	0.03	0	33.5	32.7	77	113	110	0	35	34
2015	12	3	8	25	10	-0.085	-0.052	0.843	0.033	0.03	0	33.5	32.3	77	113	109	0	35	34
2015	12	3	8	35	10	-0.121	-0.085	0.843	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	3	8	45	10	-0.023	-0.108	0.843	0.03	0.026	0	34	32.7	76.5	113	110	0	34	34
2015	12	3	8	55	10	-0.062	-0.108	0.843	0.033	0.03	0	33.5	32.7	76.1	113	110	0	35	34
2015	12	3	9	5	10	-0.128	-0.056	0.843	0.033	0.033	0	33.5	32.7	76.5	113	110	0	35	34
2015	12	3	9	15	10	-0.108	-0.069	0.843	0.033	0.033	0	34	32.3	76.5	113	109	0	34	34
2015	12	3	9	25	10	-0.121	-0.105	0.843	0.03	0.026	0	33.5	32.3	76.1	112	109	0	34	34
2015	12	3	9	35	10	-0.121	-0.164	0.843	0.033	0.03	0	33.5	32.7	76.1	113	109	0	35	33
2015	12	3	9	45	10	-0.098	-0.138	0.843	0.03	0.026	0	33.1	32.7	76.1	112	109	0	35	33
2015	12	3	9	55	10	-0.013	-0.19	0.843	0.03	0.03	0	33.1	32.3	75.7	112	109	0	35	34
2015	12	3	10	5	10	-0.056	-0.217	0.84	0.033	0.03	0	34	33.1	76.1	113	110	0	34	33
2015	12	3	10	15	10	0.003	-0.253	0.843	0.036	0.033	0	34	32.7	76.1	113	110	0	34	34
2015	12	3	10	25	10	-0.013	-0.259	0.84	0.033	0.03	0	33.1	33.1	75.7	112	110	0	35	33
2015	12	3	10	35	10	-0.095	-0.194	0.84	0.036	0.033	0	33.5	33.1	75.3	112	110	0	34	33
2015	12	3	10	45	10	0.046	-0.138	0.84	0.039	0.039	0	33.5	32.3	75.3	112	110	0	34	35
2015	12	3	10	55	10	-0.033	-0.177	0.84	0.036	0.033	0	33.5	32.7	75.7	112	110	0	34	34
2015	12	3	11	5	10	0.016	-0.066	0.84	0.039	0.039	0	34	33.5	75.3	113	112	0	34	34
2015	12	3	11	15	10	0.026	0.043	0.84	0.036	0.033	0	35.3	35.3	74.8	116	115	0	34	33
2015	12	3	11	25	10	0.082	0.013	0.84	0.039	0.036	0	35.3	34.4	74.8	117	114	0	35	34
2015	12	3	11	35	10	0.148	0.026	0.84	0.033	0.03	0	35.3	35.3	74.8	116	115	0	34	33
2015	12	3	11	45	10	0.082	-0.069	0.84	0.033	0.03	0	36.1	35.7	74.4	118	116	0	34	33
2015	12	3	11	55	10	0.164	-0.095	0.84	0.039	0.039	0	36.1	36.1	74	118	117	0	34	33
2015	12	3	12	5	10	0.095	-0.069	0.84	0.049	0.046	0	37	35.7	73.5	120	117	0	34	34
2015	12	3	12	15	10	0.167	-0.03	0.84	0.039	0.036	0	38.3	37.4	73.5	123	121	0	34	34
2015	12	3	12	25	10	0.154	-0.016	0.837	0.039	0.039	0	39.1	39.1	72.7	125	124	0	34	33
2015	12	3	12	35	10	0.135	0.007	0.837	0.033	0.03	0	41.3	40	71.8	130	127	0	34	34
2015	12	3	12	45	10	0.131	-0.131	0.837	0.036	0.033	0	39.6	38.7	72.2	126	124	0	34	34
2015	12	3	12	55	10	0.167	-0.105	0.833	0.036	0.033	0	39.1	39.1	72.2	125	125	0	34	34
2015	12	3	13	5	10	0.125	-0.154	0.83	0.036	0.033	0	42.6	42.6	71.4	133	132	0	34	33
2015	12	3	13	15	10	0.125	-0.052	0.833	0.039	0.036	0	41.3	40.9	71.8	130	129	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	13	25	10	0.089	-0.079	0.83	0.036	0.033	0	42.6	42.1	71	133	131	0	34	33
2015	12	3	13	35	10	0.164	-0.098	0.833	0.036	0.033	0	41.7	42.1	71.4	132	131	0	35	33
2015	12	3	13	45	10	0.164	0.069	0.833	0.039	0.039	0	40.9	40.9	71.8	130	129	0	35	34
2015	12	3	13	55	10	0.108	0.023	0.83	0.039	0.036	0	40.4	40	71.8	127	127	0	33	34
2015	12	3	14	5	10	0.157	-0.026	0.833	0.039	0.036	0	40.4	39.6	72.2	128	126	0	34	34
2015	12	3	14	15	10	0.144	-0.056	0.833	0.039	0.039	0	40.4	40.4	71.8	128	127	0	34	33
2015	12	3	14	25	10	0.164	-0.095	0.837	0.036	0.033	0	40.4	40.4	72.2	128	127	0	34	33
2015	12	3	14	35	10	0.18	-0.026	0.837	0.039	0.039	0	39.6	38.7	72.2	126	124	0	34	34
2015	12	3	14	45	10	0.125	-0.092	0.833	0.039	0.039	0	41.7	40.4	72.2	130	128	0	33	34
2015	12	3	14	55	10	0.141	-0.115	0.837	0.039	0.036	0	40.9	40.9	71.4	129	128	0	34	33
2015	12	3	15	5	10	0.171	0.003	0.84	0.036	0.033	0	40.9	40.9	71.8	129	128	0	34	33
2015	12	3	15	15	10	0.141	-0.085	0.843	0.036	0.033	0	40.4	40	72.2	128	126	0	34	33
2015	12	3	15	25	10	0.157	-0.03	0.843	0.039	0.039	0	40.4	40	72.2	128	127	0	34	34
2015	12	3	15	35	10	0.102	0	0.843	0.033	0.03	0	40.9	40.9	72.7	128	128	0	33	33
2015	12	3	15	45	10	0.177	0.043	0.846	0.039	0.036	0	40.4	40	73.1	128	126	0	34	33
2015	12	3	15	55	10	0.102	0	0.846	0.036	0.033	0	40.4	40.4	73.5	128	127	0	34	33
2015	12	3	16	5	10	0.18	-0.036	0.846	0.039	0.036	0	38.3	37.8	74.8	123	121	0	34	33
2015	12	3	16	15	10	0.062	-0.062	0.85	0.033	0.03	0	37.8	37.4	76.1	122	120	0	34	33
2015	12	3	16	25	10	0.098	0.049	0.85	0.036	0.033	0	37	37.4	76.1	120	120	0	34	33
2015	12	3	16	35	10	0.112	0.043	0.85	0.036	0.033	0	36.5	36.5	76.5	119	118	0	34	33
2015	12	3	16	45	10	0.151	0.033	0.853	0.036	0.033	0	36.5	35.7	76.5	118	117	0	33	34
2015	12	3	16	55	10	0.18	-0.089	0.853	0.039	0.036	0	36.5	36.5	77	119	119	0	34	34
2015	12	3	17	5	10	0.112	0.02	0.853	0.033	0.03	0	37.8	37.4	77	122	121	0	34	34
2015	12	3	17	15	10	0.194	0.016	0.853	0.033	0.03	0	37.8	37	77.4	122	120	0	34	34
2015	12	3	17	25	10	0.161	-0.013	0.853	0.039	0.036	0	38.7	37.8	77	124	122	0	34	34
2015	12	3	17	35	10	0.177	0	0.856	0.033	0.03	0	37.4	37	77.8	121	119	0	34	33
2015	12	3	17	45	10	0.154	-0.036	0.856	0.039	0.036	0	37	36.5	78.3	120	119	0	34	34
2015	12	3	17	55	10	0.151	-0.013	0.856	0.033	0.03	0	38.3	38.3	77.8	123	122	0	34	33
2015	12	3	18	5	10	0.213	-0.052	0.856	0.039	0.039	0	37.4	36.1	78.3	121	118	0	34	34
2015	12	3	18	15	10	0.197	-0.052	0.856	0.036	0.033	0	37	37.8	78.7	120	120	0	34	32
2015	12	3	18	25	10	0.171	0	0.86	0.036	0.033	0	36.5	36.1	78.3	119	117	0	34	33
2015	12	3	18	35	10	0.19	-0.069	0.86	0.033	0.03	0	36.1	35.7	77.8	118	117	0	34	34
2015	12	3	18	45	10	0.167	0.023	0.86	0.039	0.036	0	37	36.1	77.8	120	117	0	34	33
2015	12	3	18	55	10	0.118	0.013	0.86	0.043	0.039	0	36.5	35.7	77.8	119	116	0	34	33
2015	12	3	19	5	10	0.18	0	0.86	0.033	0.03	0	35.7	35.3	77.8	117	116	0	34	34
2015	12	3	19	15	10	0.151	-0.023	0.863	0.039	0.039	0	35.3	35.3	77.4	116	115	0	34	33
2015	12	3	19	25	10	0.174	0.026	0.863	0.039	0.039	0	35.7	34.8	77.4	117	114	0	34	33
2015	12	3	19	35	10	0.157	0.03	0.863	0.039	0.036	0	36.1	34.8	77	117	114	0	33	33
2015	12	3	19	45	10	0.135	-0.085	0.863	0.036	0.033	0	35.7	34.4	77.4	116	113	0	33	33
2015	12	3	19	55	10	0.121	0.072	0.863	0.039	0.039	0	35.7	34	77	116	113	0	33	34
2015	12	3	20	5	10	0.213	-0.102	0.866	0.046	0.043	0	34.8	34	76.5	115	112	0	34	33
2015	12	3	20	15	10	0.154	-0.075	0.866	0.036	0.033	0	35.3	34.4	76.1	116	113	0	34	33
2015	12	3	20	25	10	0.226	-0.085	0.866	0.036	0.033	0	35.7	35.3	75.7	117	115	0	34	33
2015	12	3	20	35	10	0.177	-0.056	0.866	0.033	0.03	0	37	36.1	75.3	119	117	0	33	33
2015	12	3	20	45	10	0.243	0	0.866	0.033	0.03	0	36.5	36.1	74.8	119	117	0	34	33
2015	12	3	20	55	10	0.226	-0.049	0.866	0.036	0.033	0	36.5	35.7	75.3	119	116	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	21	5	10	0.174	-0.03	0.869	0.036	0.033	0	36.1	35.7	74.8	118	116	0	34	33
2015	12	3	21	15	10	0.259	-0.085	0.869	0.039	0.039	0	35.7	34.8	74.8	116	114	0	33	33
2015	12	3	21	25	10	0.187	-0.007	0.869	0.039	0.039	0	35.3	35.3	74.4	117	115	0	35	33
2015	12	3	21	35	10	0.197	-0.098	0.873	0.039	0.036	0	35.3	34.4	73.5	116	113	0	34	33
2015	12	3	21	45	10	0.256	-0.125	0.876	0.033	0.03	0	34.8	34	74	115	112	0	34	33
2015	12	3	21	55	10	0.18	-0.069	0.876	0.046	0.043	0	34.4	34	74	114	112	0	34	33
2015	12	3	22	5	10	0.118	-0.013	0.879	0.036	0.033	0	34.4	34.4	74	114	113	0	34	33
2015	12	3	22	15	10	0.282	-0.121	0.883	0.033	0.03	0	34.8	34.4	74.4	115	113	0	34	33
2015	12	3	22	25	10	0.279	-0.187	0.883	0.036	0.033	0	34.8	34	74.4	115	113	0	34	34
2015	12	3	22	35	10	0.22	-0.039	0.883	0.036	0.033	0	35.3	34.4	74.8	116	113	0	34	33
2015	12	3	22	45	10	0.23	-0.157	0.883	0.036	0.033	0	35.3	34.4	74.8	117	113	0	35	33
2015	12	3	22	55	10	0.226	-0.161	0.883	0.039	0.036	0	34.8	34.8	75.3	116	113	0	35	32
2015	12	3	23	5	10	0.164	-0.121	0.883	0.039	0.036	0	35.3	35.7	75.3	116	115	0	34	32
2015	12	3	23	15	10	0.23	-0.023	0.883	0.036	0.033	0	34.8	34.4	75.7	116	114	0	35	34
2015	12	3	23	25	10	0.21	-0.121	0.883	0.033	0.03	0	35.7	34.8	76.1	117	114	0	34	33
2015	12	3	23	35	10	0.223	-0.072	0.886	0.033	0.03	0	35.7	34.8	75.3	116	114	0	33	33
2015	12	3	23	45	10	0.18	-0.128	0.886	0.036	0.033	0	36.1	34.8	75.7	118	114	0	34	33
2015	12	3	23	55	10	0.203	-0.161	0.886	0.03	0.03	0	35.7	34.4	75.7	117	114	0	34	34
2015	12	4	0	5	10	0.246	-0.151	0.886	0.036	0.033	0	35.3	34.8	76.1	117	114	0	35	33
2015	12	4	0	15	10	0.22	-0.092	0.886	0.039	0.036	0	35.3	34.8	76.1	116	115	0	34	34
2015	12	4	0	25	10	0.22	-0.069	0.886	0.033	0.03	0	34.8	34.8	76.1	115	114	0	34	33
2015	12	4	0	35	10	0.197	-0.092	0.886	0.033	0.03	0	35.3	35.3	76.5	116	115	0	34	33
2015	12	4	0	45	10	0.141	-0.098	0.886	0.036	0.033	0	34.4	34.4	77	115	113	0	35	33
2015	12	4	0	55	10	0.154	-0.033	0.886	0.033	0.03	0	35.3	34.4	77	116	113	0	34	33
2015	12	4	1	5	10	0.135	-0.144	0.886	0.033	0.03	0	35.7	35.7	76.5	117	115	0	34	32
2015	12	4	1	15	10	0.24	-0.079	0.886	0.036	0.033	0	35.3	34.4	77	116	114	0	34	34
2015	12	4	1	25	10	0.154	-0.108	0.886	0.036	0.033	0	35.3	34.8	77.4	116	115	0	34	34
2015	12	4	1	35	10	0.095	-0.085	0.886	0.033	0.033	0	35.3	34.4	77	116	114	0	34	34
2015	12	4	1	45	10	0.167	-0.092	0.886	0.033	0.03	0	35.7	35.7	77	118	116	0	35	33
2015	12	4	1	55	10	0.164	-0.036	0.886	0.036	0.033	0	37.8	37.4	76.1	122	120	0	34	33
2015	12	4	2	5	10	0.125	-0.052	0.886	0.036	0.033	0	37	36.1	77	120	118	0	34	34
2015	12	4	2	15	10	0.171	-0.112	0.886	0.033	0.03	0	37.4	37	77	121	119	0	34	33
2015	12	4	2	25	10	0.197	-0.121	0.886	0.033	0.03	0	36.1	36.1	77	118	117	0	34	33
2015	12	4	2	35	10	0.19	-0.085	0.886	0.039	0.039	0	36.5	35.7	77.4	118	117	0	33	34
2015	12	4	2	45	10	0.079	-0.056	0.886	0.039	0.036	0	36.1	35.7	77.4	118	116	0	34	33
2015	12	4	2	55	10	0.184	-0.056	0.886	0.039	0.036	0	35.3	34.8	77.4	117	115	0	35	34
2015	12	4	3	5	10	0.121	-0.138	0.886	0.039	0.036	0	35.7	34.8	77.4	117	115	0	34	34
2015	12	4	3	15	10	0.128	-0.069	0.886	0.033	0.03	0	37.4	37	76.5	121	120	0	34	34
2015	12	4	3	25	10	0.2	-0.062	0.886	0.039	0.039	0	36.1	35.3	77	118	116	0	34	34
2015	12	4	3	35	10	0.171	-0.125	0.886	0.036	0.033	0	35.7	35.7	77.4	118	116	0	35	33
2015	12	4	3	45	10	0.148	-0.138	0.886	0.036	0.033	0	39.1	38.7	76.5	125	123	0	34	33
2015	12	4	3	55	10	0.19	-0.098	0.886	0.036	0.033	0	38.3	37.4	76.5	123	121	0	34	34
2015	12	4	4	5	10	0.177	-0.072	0.886	0.033	0.03	0	37.4	36.5	77	121	119	0	34	34
2015	12	4	4	15	10	0.223	-0.085	0.886	0.039	0.039	0	40.9	40	75.7	129	127	0	34	34
2015	12	4	4	25	10	0.148	-0.131	0.886	0.033	0.03	0	37.4	36.5	77	121	118	0	34	33
2015	12	4	4	35	10	0.125	-0.138	0.886	0.033	0.03	0	36.5	35.3	77.4	119	115	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	4	45	10	0.141	-0.016	0.886	0.033	0.03	0	40.4	39.1	75.3	127	125	0	33	34
2015	12	4	4	55	10	0.18	-0.128	0.886	0.033	0.03	0	39.6	39.1	76.1	126	124	0	34	33
2015	12	4	5	5	10	0.207	-0.115	0.886	0.033	0.03	0	37	36.5	76.5	120	119	0	34	34
2015	12	4	5	15	10	0.098	-0.157	0.886	0.046	0.043	0	37	35.7	77.4	120	117	0	34	34
2015	12	4	5	25	10	0.125	-0.138	0.886	0.039	0.036	0	36.5	35.7	77.4	119	117	0	34	34
2015	12	4	5	35	10	0.174	-0.098	0.886	0.033	0.033	0	36.5	36.1	77	119	117	0	34	33
2015	12	4	5	45	10	0.194	-0.082	0.886	0.033	0.03	0	35.7	35.7	77	118	116	0	35	33
2015	12	4	5	55	10	0.131	-0.115	0.886	0.036	0.033	0	36.5	35.7	77	119	117	0	34	34
2015	12	4	6	5	10	0.187	-0.056	0.886	0.03	0.03	0	37	36.5	77	120	118	0	34	33
2015	12	4	6	15	10	0.187	-0.098	0.886	0.036	0.033	0	36.5	37.4	77.4	120	120	0	35	33
2015	12	4	6	25	10	0.135	-0.075	0.886	0.033	0.03	0	37.4	37.4	77	121	120	0	34	33
2015	12	4	6	35	10	0.2	-0.052	0.886	0.033	0.03	0	40	38.7	75.7	127	124	0	34	34
2015	12	4	6	45	10	0.141	-0.102	0.886	0.033	0.03	0	36.5	36.1	77.8	119	118	0	34	34
2015	12	4	6	55	10	0.105	-0.115	0.886	0.033	0.03	0	35.3	34.4	77.8	116	114	0	34	34
2015	12	4	7	5	10	0.135	-0.039	0.886	0.033	0.03	0	34.8	33.5	77.8	115	112	0	34	34
2015	12	4	7	15	10	0.217	-0.026	0.886	0.039	0.036	0	37.4	37	77	121	119	0	34	33
2015	12	4	7	25	10	0.164	-0.026	0.886	0.033	0.03	0	35.3	34.4	77.4	116	113	0	34	33
2015	12	4	7	35	10	0.184	-0.02	0.886	0.033	0.03	0	35.7	33.5	78.7	117	112	0	34	34
2015	12	4	7	45	10	0.079	-0.112	0.886	0.03	0.026	0	35.3	33.1	77.8	116	111	0	34	34
2015	12	4	7	55	10	0.167	-0.082	0.886	0.033	0.03	0	35.3	34	77.8	116	112	0	34	33
2015	12	4	8	5	10	0.131	-0.046	0.886	0.036	0.033	0	35.3	34	78.3	116	112	0	34	33
2015	12	4	8	15	10	0.164	-0.056	0.886	0.033	0.03	0	34.8	34.4	77.8	115	113	0	34	33
2015	12	4	8	25	10	0.2	-0.036	0.886	0.03	0.03	0	34	33.1	77.8	114	111	0	35	34
2015	12	4	8	35	10	0.148	-0.062	0.886	0.033	0.03	0	35.3	33.1	77.8	115	111	0	33	34
2015	12	4	8	45	10	0.125	-0.075	0.886	0.033	0.03	0	36.5	35.3	77.4	119	116	0	34	34
2015	12	4	8	55	10	0.135	-0.108	0.886	0.033	0.03	0	35.3	34.8	77	116	114	0	34	33
2015	12	4	9	5	10	0.18	-0.115	0.883	0.033	0.03	0	36.5	37.4	74.4	120	120	0	35	33
2015	12	4	9	15	10	0.194	-0.066	0.886	0.033	0.03	0	37.8	37	75.7	122	120	0	34	34
2015	12	4	9	25	10	0.262	0.007	0.886	0.039	0.036	0	37.4	37.4	74.4	122	121	0	35	34
2015	12	4	9	35	10	0.18	-0.072	0.886	0.036	0.033	0	40.9	40.9	74	129	128	0	34	33
2015	12	4	9	45	10	0.21	-0.072	0.886	0.039	0.036	0	42.6	42.1	72.7	133	132	0	34	34
2015	12	4	9	55	10	0.23	-0.049	0.886	0.039	0.036	0	41.7	41.3	72.7	131	129	0	34	33
2015	12	4	10	5	10	0.262	0.043	0.886	0.036	0.033	0	40.4	40.9	73.5	128	128	0	34	33
2015	12	4	10	15	10	0.157	0.03	0.886	0.036	0.033	0	40.4	40.9	74	129	128	0	35	33
2015	12	4	10	25	10	0.19	-0.095	0.886	0.036	0.033	0	40.9	39.6	74.4	129	126	0	34	34
2015	12	4	10	35	10	0.213	-0.03	0.886	0.036	0.033	0	40.9	40	73.5	129	127	0	34	34
2015	12	4	10	45	10	0.217	-0.098	0.886	0.033	0.03	0	40	40	74.4	127	127	0	34	34
2015	12	4	10	55	10	0.187	0.007	0.886	0.039	0.036	0	40	40	74.4	127	126	0	34	33
2015	12	4	11	5	10	0.243	-0.036	0.886	0.036	0.033	0	40.9	40.4	74	129	127	0	34	33
2015	12	4	11	15	10	0.213	-0.013	0.886	0.039	0.036	0	40	40	74.4	127	126	0	34	33
2015	12	4	11	25	10	0.213	-0.016	0.886	0.039	0.039	0	40	40	74.4	127	126	0	34	33
2015	12	4	11	35	10	0.256	-0.046	0.886	0.036	0.033	0	43	43	72.7	134	133	0	34	33
2015	12	4	11	45	10	0.131	-0.03	0.886	0.049	0.046	0	41.7	41.3	74	131	129	0	34	33
2015	12	4	11	55	10	0.194	-0.108	0.886	0.033	0.03	0	39.6	39.1	74.4	126	124	0	34	33
2015	12	4	12	5	10	0.197	0.03	0.886	0.036	0.033	0	39.1	37.8	74.4	125	122	0	34	34
2015	12	4	12	15	10	0.23	0.016	0.886	0.033	0.03	0	38.3	37.8	74.8	124	121	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	12	25	10	0.184	0.043	0.886	0.036	0.033	0	38.3	37.4	75.3	122	120	0	33	33
2015	12	4	12	35	10	0.207	-0.036	0.886	0.036	0.033	0	38.3	37.8	74.4	122	121	0	33	33
2015	12	4	12	45	10	0.22	0	0.883	0.033	0.03	0	41.7	41.3	72.7	131	130	0	34	34
2015	12	4	12	55	10	0.167	-0.056	0.886	0.039	0.039	0	42.1	41.7	73.1	132	130	0	34	33
2015	12	4	13	5	10	0.223	-0.072	0.886	0.036	0.033	0	41.3	40.4	73.5	130	128	0	34	34
2015	12	4	13	15	10	0.197	0.013	0.886	0.036	0.033	0	40.4	39.6	73.1	127	125	0	33	33
2015	12	4	13	25	10	0.233	-0.013	0.883	0.033	0.03	0	46	45.2	69.7	141	138	0	34	33
2015	12	4	13	35	10	0.207	-0.056	0.886	0.033	0.03	0	42.6	41.7	72.2	133	130	0	34	33
2015	12	4	13	45	10	0.167	-0.016	0.886	0.036	0.033	0	41.3	41.3	72.7	130	128	0	34	32
2015	12	4	13	55	10	0.2	-0.033	0.886	0.033	0.03	0	40.4	39.6	73.5	128	125	0	34	33
2015	12	4	14	5	10	0.23	-0.026	0.883	0.033	0.03	0	39.1	39.1	73.5	124	124	0	33	33
2015	12	4	14	15	10	0.184	-0.049	0.883	0.036	0.033	0	43.4	43.4	71.4	134	133	0	33	32
2015	12	4	14	25	10	0.217	0.026	0.883	0.039	0.039	0	42.1	42.1	71.8	132	131	0	34	33
2015	12	4	14	35	10	0.174	0	0.883	0.039	0.039	0	40.4	40.9	72.7	128	128	0	34	33
2015	12	4	14	45	10	0.233	0.062	0.883	0.036	0.033	0	39.6	40	72.7	126	126	0	34	33
2015	12	4	14	55	10	0.174	0	0.883	0.039	0.039	0	41.7	41.3	72.2	131	129	0	34	33
2015	12	4	15	5	10	0.197	0.052	0.883	0.03	0.026	0	40	39.6	73.1	127	125	0	34	33
2015	12	4	15	15	10	0.161	-0.026	0.879	0.043	0.039	0	39.1	38.7	72.7	125	123	0	34	33
2015	12	4	15	25	10	0.236	0.092	0.879	0.033	0.03	0	42.1	42.1	71.4	132	131	0	34	33
2015	12	4	15	35	10	0.236	0.19	0.876	0.036	0.033	0	46.9	46	68.8	142	140	0	33	33
2015	12	4	15	45	10	0.19	0.203	0.876	0.043	0.039	0	48.2	47.3	67.5	146	143	0	34	33
2015	12	4	15	55	10	0.236	0.157	0.876	0.046	0.043	0	47.3	47.3	67.9	143	143	0	33	33
2015	12	4	16	5	10	0.157	0.135	0.876	0.039	0.036	0	46.9	46	68.8	142	140	0	33	33
2015	12	4	16	15	10	0.295	0.174	0.876	0.036	0.033	0	45.6	44.7	69.7	140	137	0	34	33
2015	12	4	16	25	10	0.19	0.085	0.876	0.036	0.033	0	43.9	43	71.4	135	133	0	33	33
2015	12	4	16	35	10	0.213	0.121	0.876	0.036	0.033	0	41.3	41.3	71.8	130	129	0	34	33
2015	12	4	16	45	10	0.177	0.082	0.879	0.033	0.03	0	40.9	40	72.7	128	126	0	33	33
2015	12	4	16	55	10	0.187	0.043	0.879	0.033	0.03	0	40	40	72.7	127	125	0	34	32
2015	12	4	17	5	10	0.262	0.007	0.879	0.033	0.033	0	39.1	39.1	73.1	124	124	0	33	33
2015	12	4	17	15	10	0.213	0.062	0.879	0.036	0.033	0	39.1	39.1	72.7	124	123	0	33	32
2015	12	4	17	25	10	0.23	-0.072	0.879	0.036	0.033	0	38.7	38.7	72.7	124	123	0	34	33
2015	12	4	17	35	10	0.171	0	0.879	0.036	0.033	0	39.1	39.1	73.1	124	123	0	33	32
2015	12	4	17	45	10	0.161	0.039	0.879	0.033	0.03	0	37.8	37.8	73.5	122	121	0	34	33
2015	12	4	17	55	10	0.21	0.007	0.879	0.033	0.03	0	38.7	37.8	73.1	124	122	0	34	34
2015	12	4	18	5	10	0.154	0.01	0.879	0.036	0.033	0	37.8	36.5	73.5	121	118	0	33	33
2015	12	4	18	15	10	0.098	0	0.879	0.033	0.03	0	36.5	36.5	74	119	118	0	34	33
2015	12	4	18	25	10	0.177	-0.023	0.879	0.033	0.03	0	37.4	36.5	73.5	120	118	0	33	33
2015	12	4	18	35	10	0.18	-0.085	0.883	0.043	0.039	0	37.4	36.5	74	120	118	0	33	33
2015	12	4	18	45	10	0.19	-0.039	0.883	0.039	0.036	0	40	39.1	72.2	126	124	0	33	33
2015	12	4	18	55	10	0.194	0.013	0.879	0.043	0.039	0	40.4	39.6	72.7	127	125	0	33	33
2015	12	4	19	5	10	0.085	0.046	0.883	0.036	0.033	0	37.8	37	73.1	121	119	0	33	33
2015	12	4	19	15	10	0.22	-0.03	0.886	0.036	0.033	0	37	36.1	74	120	117	0	34	33
2015	12	4	19	25	10	0.19	-0.036	0.883	0.033	0.03	0	37	36.5	73.5	120	118	0	34	33
2015	12	4	19	35	10	0.118	0.039	0.883	0.036	0.033	0	36.5	37	74.4	119	118	0	34	32
2015	12	4	19	45	10	0.138	-0.03	0.886	0.033	0.03	0	37.4	37.8	74	121	120	0	34	32
2015	12	4	19	55	10	0.144	-0.033	0.886	0.043	0.039	0	37	36.5	74	120	118	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	20	5	10	0.082	-0.082	0.886	0.039	0.039	0	36.1	35.7	74.8	118	116	0	34	33
2015	12	4	20	15	10	0.135	-0.056	0.886	0.036	0.033	0	36.1	36.1	74	118	116	0	34	32
2015	12	4	20	25	10	0.098	-0.098	0.886	0.036	0.033	0	36.1	35.3	74.4	118	115	0	34	33
2015	12	4	20	35	10	0.233	-0.102	0.886	0.033	0.03	0	36.1	34.8	74.4	118	114	0	34	33
2015	12	4	20	45	10	0.305	-0.131	0.886	0.043	0.043	0	36.5	35.3	74.4	118	115	0	33	33
2015	12	4	20	55	10	0.217	-0.115	0.886	0.033	0.03	0	35.7	35.7	74	117	116	0	34	33
2015	12	4	21	5	10	0.174	-0.177	0.886	0.036	0.033	0	35.3	36.1	74.8	116	116	0	34	32
2015	12	4	21	15	10	0.151	-0.066	0.883	0.039	0.039	0	35.7	35.3	74	117	115	0	34	33
2015	12	4	21	25	10	0.285	-0.056	0.883	0.039	0.039	0	35.7	35.3	74.4	117	115	0	34	33
2015	12	4	21	35	10	0.135	-0.023	0.883	0.036	0.033	0	36.1	35.7	74.4	118	116	0	34	33
2015	12	4	21	45	10	0.144	0	0.883	0.033	0.03	0	36.5	36.5	73.5	119	118	0	34	33
2015	12	4	21	55	10	0.148	-0.02	0.883	0.036	0.033	0	36.5	37	74.4	118	118	0	33	32
2015	12	4	22	5	10	0.174	0	0.883	0.036	0.033	0	36.1	35.7	74	118	116	0	34	33
2015	12	4	22	15	10	0.144	-0.075	0.883	0.033	0.03	0	36.5	36.1	74	118	117	0	33	33
2015	12	4	22	25	10	0.095	-0.062	0.883	0.033	0.03	0	36.1	36.1	74	117	116	0	33	32
2015	12	4	22	35	10	0.141	-0.108	0.883	0.043	0.039	0	36.1	36.1	74	118	117	0	34	33
2015	12	4	22	45	10	0.131	-0.131	0.883	0.033	0.03	0	36.1	36.1	74	118	117	0	34	33
2015	12	4	22	55	10	0.194	-0.151	0.883	0.033	0.03	0	35.7	35.7	74	117	116	0	34	33
2015	12	4	23	5	10	0.141	-0.072	0.879	0.036	0.033	0	36.5	34.8	74	118	115	0	33	34
2015	12	4	23	15	10	0.141	-0.118	0.879	0.039	0.036	0	36.1	36.1	73.5	118	117	0	34	33
2015	12	4	23	25	10	0.213	-0.112	0.879	0.033	0.03	0	36.1	36.1	74.4	118	117	0	34	33
2015	12	4	23	35	10	0.213	-0.108	0.879	0.033	0.03	0	36.1	35.3	74	118	116	0	34	34
2015	12	4	23	45	10	0.226	-0.062	0.876	0.043	0.039	0	36.5	35.3	73.5	119	115	0	34	33
2015	12	4	23	55	10	0.128	-0.108	0.876	0.033	0.03	0	36.5	35.3	74	118	116	0	33	34
2015	12	5	0	5	10	0.217	-0.121	0.873	0.033	0.03	0	36.5	36.1	73.5	118	117	0	33	33
2015	12	5	0	15	10	0.112	-0.066	0.873	0.033	0.03	0	38.7	37.8	73.1	124	121	0	34	33
2015	12	5	0	25	10	0.105	-0.089	0.873	0.043	0.043	0	38.3	38.3	73.1	123	122	0	34	33
2015	12	5	0	35	10	0.171	-0.115	0.869	0.043	0.039	0	37	36.5	73.5	120	118	0	34	33
2015	12	5	0	45	10	0.197	-0.118	0.869	0.036	0.033	0	37	37	73.5	120	119	0	34	33
2015	12	5	0	55	10	0.243	-0.138	0.869	0.036	0.033	0	37.4	36.5	74.4	121	118	0	34	33
2015	12	5	1	5	10	0.105	-0.085	0.869	0.033	0.03	0	40	39.1	73.1	127	124	0	34	33
2015	12	5	1	15	10	0.105	-0.072	0.866	0.039	0.036	0	37.8	37.4	74	122	120	0	34	33
2015	12	5	1	25	10	0.164	-0.184	0.866	0.033	0.03	0	36.5	36.1	74.8	119	117	0	34	33
2015	12	5	1	35	10	0.154	-0.128	0.866	0.039	0.036	0	36.5	37.4	74.8	119	119	0	34	32
2015	12	5	1	45	10	0.167	-0.154	0.866	0.039	0.039	0	37	35.7	74.8	119	117	0	33	34
2015	12	5	1	55	10	0.144	-0.167	0.866	0.03	0.03	0	36.1	36.5	74.8	119	118	0	35	33
2015	12	5	2	5	10	0.128	-0.161	0.866	0.033	0.033	0	36.5	36.5	75.3	119	119	0	34	34
2015	12	5	2	15	10	0.144	-0.102	0.866	0.033	0.03	0	36.5	35.7	75.7	119	116	0	34	33
2015	12	5	2	25	10	0.138	-0.118	0.863	0.036	0.033	0	36.1	36.1	75.7	119	117	0	35	33
2015	12	5	2	35	10	0.157	-0.089	0.863	0.033	0.03	0	36.5	36.5	75.7	119	119	0	34	34
2015	12	5	2	45	10	0.177	-0.033	0.863	0.033	0.03	0	38.7	38.7	74.8	124	123	0	34	33
2015	12	5	2	55	10	0.151	-0.075	0.863	0.033	0.03	0	37.8	37.4	76.1	122	120	0	34	33
2015	12	5	3	5	10	0.23	-0.102	0.863	0.036	0.033	0	39.1	39.6	74.8	126	125	0	35	33
2015	12	5	3	15	10	0.18	-0.177	0.863	0.046	0.043	0	38.7	38.3	75.7	124	123	0	34	34
2015	12	5	3	25	10	0.24	-0.22	0.863	0.033	0.03	0	37.4	37.4	75.7	121	120	0	34	33
2015	12	5	3	35	10	0.197	-0.089	0.86	0.033	0.03	0	40.4	40	75.3	128	126	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	3	45	10	0.164	-0.115	0.86	0.036	0.033	0	38.7	38.3	76.1	124	122	0	34	33
2015	12	5	3	55	10	0.105	-0.184	0.86	0.033	0.03	0	37.4	36.1	76.5	121	118	0	34	34
2015	12	5	4	5	10	0.167	-0.039	0.86	0.039	0.039	0	38.7	37.8	75.7	124	122	0	34	34
2015	12	5	4	15	10	0.125	-0.043	0.86	0.039	0.036	0	39.6	40	75.7	126	125	0	34	32
2015	12	5	4	25	10	0.19	-0.056	0.86	0.033	0.03	0	41.7	40.9	74.8	130	128	0	33	33
2015	12	5	4	35	10	0.197	-0.046	0.86	0.036	0.033	0	37.8	37.8	76.5	123	121	0	35	33
2015	12	5	4	45	10	0.161	-0.056	0.86	0.036	0.033	0	39.1	37.4	76.5	125	121	0	34	34
2015	12	5	4	55	10	0.118	-0.092	0.86	0.036	0.033	0	38.7	37.8	76.5	124	122	0	34	34
2015	12	5	5	5	10	0.233	-0.03	0.856	0.036	0.033	0	37.8	37.4	76.5	123	121	0	35	34
2015	12	5	5	15	10	0.128	-0.075	0.856	0.039	0.036	0	41.3	41.3	74.8	131	129	0	35	33
2015	12	5	5	25	10	0.174	-0.131	0.856	0.039	0.036	0	38.7	37.8	76.5	124	122	0	34	34
2015	12	5	5	35	10	0.157	-0.112	0.856	0.033	0.03	0	39.1	37.4	76.1	125	121	0	34	34
2015	12	5	5	45	10	0.312	-0.115	0.856	0.033	0.03	0	37.8	37.4	77.4	122	121	0	34	34
2015	12	5	5	55	10	0.203	0.007	0.856	0.036	0.033	0	39.6	39.1	76.5	126	124	0	34	33
2015	12	5	6	5	10	0.194	-0.069	0.856	0.033	0.03	0	37.8	37.4	77	123	121	0	35	34
2015	12	5	6	15	10	0.223	-0.03	0.856	0.039	0.036	0	41.7	42.1	74.4	132	131	0	35	33
2015	12	5	6	25	10	0.217	-0.036	0.856	0.036	0.033	0	40	39.1	76.5	127	125	0	34	34
2015	12	5	6	35	10	0.151	-0.082	0.856	0.033	0.03	0	37.8	37.4	77.8	123	120	0	35	33
2015	12	5	6	45	10	0.138	-0.069	0.856	0.036	0.033	0	38.3	37.4	77.4	123	120	0	34	33
2015	12	5	6	55	10	0.082	-0.046	0.856	0.039	0.036	0	37	36.1	77.8	121	118	0	35	34
2015	12	5	7	5	10	0.184	-0.089	0.853	0.036	0.033	0	36.5	34.4	77.8	119	114	0	34	34
2015	12	5	7	15	10	0.164	0	0.853	0.036	0.033	0	35.7	34.4	78.7	118	114	0	35	34
2015	12	5	7	25	10	0.194	-0.059	0.853	0.043	0.039	0	35.7	33.5	78.3	117	112	0	34	34
2015	12	5	7	35	10	0.121	-0.066	0.853	0.039	0.039	0	36.1	34	79.1	117	113	0	33	34
2015	12	5	7	45	10	0.23	0	0.853	0.036	0.033	0	35.7	34	79.1	116	112	0	33	33
2015	12	5	7	55	10	0.069	0.033	0.853	0.039	0.036	0	35.3	34	79.1	117	112	0	35	33
2015	12	5	8	5	10	0.253	-0.039	0.853	0.039	0.036	0	35.3	34	79.1	117	112	0	35	33
2015	12	5	8	15	10	0.108	0.007	0.853	0.036	0.033	0	34.8	33.1	79.1	116	112	0	35	35
2015	12	5	8	25	10	0.266	-0.177	0.853	0.039	0.039	0	35.7	34	79.1	117	112	0	34	33
2015	12	5	8	35	10	0.138	-0.003	0.853	0.036	0.033	0	35.7	34	78.7	117	113	0	34	34
2015	12	5	8	45	10	0.135	-0.023	0.853	0.039	0.039	0	35.3	33.5	79.6	116	112	0	34	34
2015	12	5	8	55	10	0.095	0.056	0.853	0.043	0.043	0	35.3	33.5	79.1	116	112	0	34	34
2015	12	5	9	5	10	0.007	-0.007	0.853	0.033	0.03	0	35.7	33.5	79.6	117	112	0	34	34
2015	12	5	9	15	10	-0.043	0.052	0.853	0.033	0.033	0	35.7	34	78.7	117	113	0	34	34
2015	12	5	9	25	10	0.161	0	0.853	0.036	0.033	0	35.7	33.5	79.1	117	112	0	34	34
2015	12	5	9	35	10	0.144	0.069	0.853	0.033	0.033	0	35.7	33.5	79.6	117	112	0	34	34
2015	12	5	9	45	10	0.069	0.039	0.853	0.039	0.036	0	35.7	34	79.6	117	113	0	34	34
2015	12	5	9	55	10	0.082	0.056	0.853	0.033	0.03	0	35.3	34	79.1	117	113	0	35	34
2015	12	5	10	5	10	0.128	-0.03	0.853	0.033	0.033	0	35.3	34	79.1	116	112	0	34	33
2015	12	5	10	15	10	-0.013	0.052	0.853	0.036	0.033	0	34.8	34	79.1	116	112	0	35	33
2015	12	5	10	25	10	0.095	-0.043	0.853	0.036	0.033	0	35.3	34	79.1	116	112	0	34	33
2015	12	5	10	35	10	0.187	-0.056	0.853	0.039	0.036	0	35.3	34.4	78.7	117	113	0	35	33
2015	12	5	10	45	10	0.21	-0.105	0.853	0.036	0.033	0	35.7	34.4	78.7	117	113	0	34	33
2015	12	5	10	55	10	0.167	-0.148	0.853	0.039	0.036	0	36.1	34.8	78.7	118	115	0	34	34
2015	12	5	11	5	10	0.102	-0.108	0.853	0.039	0.036	0	36.1	33.1	79.1	117	111	0	33	34
2015	12	5	11	15	10	0.043	-0.144	0.853	0.036	0.033	0	36.1	34.4	79.1	117	112	0	33	32

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	11	25	10	0.098	-0.079	0.856	0.036	0.033	0	36.1	34.8	79.1	118	115	0	34	34
2015	12	5	11	35	10	0.108	-0.108	0.856	0.039	0.036	0	35.3	34.4	79.1	116	113	0	34	33
2015	12	5	11	45	10	0.121	-0.02	0.856	0.036	0.033	0	37.8	37	77.4	122	119	0	34	33
2015	12	5	11	55	10	0.161	-0.069	0.856	0.046	0.043	0	36.5	36.1	78.7	119	117	0	34	33
2015	12	5	12	5	10	0.135	-0.108	0.856	0.036	0.033	0	36.5	35.3	78.7	119	115	0	34	33
2015	12	5	12	15	10	0.171	0	0.856	0.036	0.033	0	39.1	37.4	78.7	124	120	0	33	33
2015	12	5	12	25	10	0.197	-0.148	0.856	0.039	0.036	0	37.4	35.7	78.7	121	116	0	34	33
2015	12	5	12	35	10	0.151	-0.085	0.856	0.033	0.03	0	39.6	39.6	77.4	126	125	0	34	33
2015	12	5	12	45	10	0.187	-0.069	0.86	0.036	0.033	0	39.1	37.8	77.8	125	122	0	34	34
2015	12	5	12	55	10	0.18	-0.128	0.86	0.049	0.046	0	36.5	35.7	78.7	119	116	0	34	33
2015	12	5	13	5	10	0.157	-0.01	0.86	0.036	0.033	0	42.6	42.6	75.3	133	131	0	34	32
2015	12	5	13	15	10	0.144	-0.03	0.86	0.036	0.033	0	43	41.7	75.3	134	130	0	34	33
2015	12	5	13	25	10	0.131	-0.062	0.86	0.039	0.036	0	40	38.7	77.4	126	123	0	33	33
2015	12	5	13	35	10	0.121	-0.043	0.86	0.043	0.039	0	37.4	37	78.7	121	119	0	34	33
2015	12	5	13	45	10	0.148	-0.046	0.86	0.033	0.03	0	37.8	37	77.8	122	120	0	34	34
2015	12	5	13	55	10	0.174	-0.003	0.863	0.039	0.036	0	37.8	37	77.8	122	120	0	34	34
2015	12	5	14	5	10	0.157	0.02	0.863	0.036	0.033	0	37.8	38.3	77.4	122	121	0	34	32
2015	12	5	14	15	10	0.128	0.013	0.863	0.033	0.03	0	38.7	37	77.8	124	119	0	34	33
2015	12	5	14	25	10	0.039	-0.01	0.863	0.036	0.033	0	37.8	38.3	77	123	122	0	35	33
2015	12	5	14	35	10	0.075	-0.056	0.863	0.039	0.036	0	37.4	37	76.5	121	119	0	34	33
2015	12	5	14	45	10	0.141	-0.016	0.866	0.036	0.033	0	37.8	37.4	77	122	120	0	34	33
2015	12	5	14	55	10	0.151	-0.016	0.866	0.036	0.033	0	38.3	37.8	76.5	123	121	0	34	33
2015	12	5	15	5	10	0.18	-0.03	0.866	0.033	0.03	0	38.3	37.8	76.5	123	122	0	34	34
2015	12	5	15	15	10	0.138	0.02	0.866	0.036	0.033	0	42.6	42.1	74.8	133	131	0	34	33
2015	12	5	15	25	10	0.2	0.049	0.863	0.039	0.039	0	52.9	52.9	64.5	157	156	0	34	33
2015	12	5	15	35	10	0.223	0.085	0.866	0.036	0.033	0	46.4	46.4	71	142	141	0	34	33
2015	12	5	15	45	10	0.22	0.125	0.866	0.033	0.033	0	40.9	40.9	74	129	128	0	34	33
2015	12	5	15	55	10	0.23	-0.046	0.866	0.039	0.036	0	48.2	47.7	69.7	146	144	0	34	33
2015	12	5	16	5	10	0.187	0.003	0.869	0.033	0.03	0	43.4	42.6	72.7	135	132	0	34	33
2015	12	5	16	15	10	0.246	-0.03	0.869	0.036	0.033	0	38.7	38.7	74.8	124	123	0	34	33
2015	12	5	16	25	10	0.112	0.046	0.869	0.033	0.03	0	37.4	37.4	74.4	121	119	0	34	32
2015	12	5	16	35	10	0.23	0.026	0.869	0.039	0.036	0	39.1	38.7	74.4	125	123	0	34	33
2015	12	5	16	45	10	0.171	-0.052	0.869	0.033	0.03	0	37.8	37.4	74.4	122	120	0	34	33
2015	12	5	16	55	10	0.19	0.02	0.869	0.036	0.033	0	37.4	37.8	74.8	121	121	0	34	33
2015	12	5	17	5	10	0.233	-0.131	0.873	0.036	0.033	0	37.4	36.5	75.3	120	118	0	33	33
2015	12	5	17	15	10	0.112	-0.036	0.873	0.036	0.033	0	36.5	36.1	74	119	117	0	34	33
2015	12	5	17	25	10	0.21	0	0.873	0.043	0.039	0	37.8	37.4	74	122	120	0	34	33
2015	12	5	17	35	10	0.148	-0.01	0.876	0.043	0.039	0	37.4	37.4	73.1	121	120	0	34	33
2015	12	5	17	45	10	0.069	0.003	0.879	0.039	0.036	0	37.8	37	74	121	119	0	33	33
2015	12	5	17	55	10	0.154	-0.02	0.879	0.039	0.036	0	37.8	37.4	73.1	122	120	0	34	33
2015	12	5	18	5	10	0.207	-0.026	0.883	0.033	0.03	0	38.3	37	73.5	122	120	0	33	34
2015	12	5	18	15	10	0.161	-0.026	0.886	0.036	0.033	0	38.3	37.8	73.5	122	121	0	33	33
2015	12	5	18	25	10	0.138	-0.043	0.886	0.033	0.03	0	37.4	37	74.8	121	119	0	34	33
2015	12	5	18	35	10	0.167	0.007	0.886	0.036	0.033	0	37	37	74.8	120	119	0	34	33
2015	12	5	18	45	10	0.089	0.052	0.886	0.039	0.039	0	37.4	36.5	74.8	120	118	0	33	33
2015	12	5	18	55	10	0.092	-0.033	0.889	0.039	0.039	0	36.5	36.5	75.3	119	118	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	19	5	10	0.18	-0.043	0.889	0.036	0.033	0	36.1	36.1	75.7	118	117	0	34	33
2015	12	5	19	15	10	0.069	-0.069	0.889	0.033	0.03	0	36.1	36.1	75.7	118	117	0	34	33
2015	12	5	19	25	10	0.121	-0.102	0.889	0.039	0.036	0	36.1	35.3	76.5	118	115	0	34	33
2015	12	5	19	35	10	0.19	-0.118	0.889	0.036	0.033	0	35.7	35.3	76.5	117	114	0	34	32
2015	12	5	19	45	10	0.079	-0.062	0.889	0.033	0.03	0	36.1	35.3	77	118	115	0	34	33
2015	12	5	19	55	10	0.187	-0.171	0.892	0.033	0.03	0	35.3	34.8	77.4	116	114	0	34	33
2015	12	5	20	5	10	0.108	-0.092	0.892	0.039	0.036	0	35.3	34.8	77.8	116	114	0	34	33
2015	12	5	20	15	10	0.154	-0.105	0.892	0.046	0.043	0	35.7	35.3	77.8	116	114	0	33	32
2015	12	5	20	25	10	0.016	-0.039	0.892	0.033	0.03	0	35.7	34.4	77.8	116	113	0	33	33
2015	12	5	20	35	10	0.052	-0.052	0.892	0.039	0.039	0	35.7	34.4	78.3	116	113	0	33	33
2015	12	5	20	45	10	0.177	-0.072	0.896	0.036	0.033	0	36.1	34.4	78.7	117	113	0	33	33
2015	12	5	20	55	10	0.056	-0.062	0.896	0.039	0.036	0	35.7	34.8	78.7	117	114	0	34	33
2015	12	5	21	5	10	0.098	-0.075	0.896	0.039	0.036	0	36.5	35.3	79.1	118	115	0	33	33
2015	12	5	21	15	10	0.151	-0.108	0.896	0.036	0.033	0	35.7	35.3	79.6	117	115	0	34	33
2015	12	5	21	25	10	0.144	-0.125	0.896	0.033	0.03	0	36.1	35.3	79.1	118	115	0	34	33
2015	12	5	21	35	10	0.2	-0.098	0.896	0.033	0.03	0	37	35.7	79.6	119	116	0	33	33
2015	12	5	21	45	10	0.226	-0.125	0.896	0.036	0.033	0	36.1	35.7	79.1	118	116	0	34	33
2015	12	5	21	55	10	0.236	-0.144	0.896	0.043	0.039	0	36.5	34.8	78.7	119	114	0	34	33
2015	12	5	22	5	10	0.125	-0.082	0.896	0.039	0.036	0	36.1	35.7	79.6	118	116	0	34	33
2015	12	5	22	15	10	0.249	-0.144	0.896	0.039	0.039	0	35.7	34.8	78.7	117	114	0	34	33
2015	12	5	22	25	10	0.135	-0.03	0.896	0.033	0.03	0	36.5	35.7	79.1	118	116	0	33	33
2015	12	5	22	35	10	0.144	-0.075	0.896	0.036	0.033	0	36.5	35.7	78.7	119	116	0	34	33
2015	12	5	22	45	10	0.118	-0.082	0.896	0.033	0.03	0	36.5	34.8	78.7	119	115	0	34	34
2015	12	5	22	55	10	0.177	-0.131	0.896	0.033	0.03	0	37	35.7	78.3	119	116	0	33	33
2015	12	5	23	5	10	0.174	-0.121	0.896	0.033	0.03	0	36.5	35.7	78.7	119	116	0	34	33
2015	12	5	23	15	10	0.108	-0.056	0.899	0.043	0.043	0	37	36.1	78.7	120	117	0	34	33
2015	12	5	23	25	10	0.141	-0.062	0.896	0.039	0.036	0	37.4	36.5	78.3	121	118	0	34	33
2015	12	5	23	35	10	0.135	-0.118	0.899	0.033	0.03	0	37.4	37	77.4	121	119	0	34	33
2015	12	5	23	45	10	0.128	-0.102	0.899	0.039	0.036	0	37.4	37.4	78.3	121	120	0	34	33
2015	12	5	23	55	10	0.194	-0.108	0.899	0.039	0.036	0	37.4	37	77.8	120	119	0	33	33
2015	12	6	0	5	10	0.125	-0.105	0.899	0.036	0.033	0	37	36.5	77	120	118	0	34	33
2015	12	6	0	15	10	0.184	-0.102	0.899	0.033	0.03	0	37.4	36.5	77.8	121	118	0	34	33
2015	12	6	0	25	10	0.226	-0.052	0.899	0.039	0.036	0	37	36.5	77.8	120	119	0	34	34
2015	12	6	0	35	10	0.243	-0.108	0.899	0.046	0.043	0	38.3	37.4	77	122	120	0	33	33
2015	12	6	0	45	10	0.266	-0.121	0.899	0.039	0.036	0	38.7	37	77	123	120	0	33	34
2015	12	6	0	55	10	0.161	-0.144	0.899	0.033	0.03	0	37	36.5	77	120	119	0	34	34
2015	12	6	1	5	10	0.24	-0.085	0.899	0.033	0.03	0	37	37	76.5	120	119	0	34	33
2015	12	6	1	15	10	0.184	-0.013	0.899	0.033	0.03	0	37	36.5	77	120	118	0	34	33
2015	12	6	1	25	10	0.217	-0.105	0.899	0.033	0.03	0	38.3	37.4	76.1	123	121	0	34	34
2015	12	6	1	35	10	0.23	-0.059	0.899	0.033	0.03	0	37.8	37	76.5	122	120	0	34	34
2015	12	6	1	45	10	0.141	-0.013	0.899	0.033	0.03	0	37	36.5	77	120	119	0	34	34
2015	12	6	1	55	10	0.226	-0.154	0.899	0.043	0.043	0	37	36.5	76.1	120	118	0	34	33
2015	12	6	2	5	10	0.19	-0.072	0.899	0.036	0.033	0	37	37	76.1	120	119	0	34	33
2015	12	6	2	15	10	0.167	-0.039	0.899	0.033	0.03	0	36.1	36.1	76.5	119	118	0	35	34
2015	12	6	2	25	10	0.217	-0.095	0.899	0.033	0.03	0	37	37	76.5	119	119	0	33	33
2015	12	6	2	35	10	0.223	-0.157	0.902	0.033	0.03	0	37	36.1	75.7	121	118	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	2	45	10	0.203	-0.066	0.899	0.033	0.03	0	37.4	36.1	75.7	121	117	0	34	33
2015	12	6	2	55	10	0.23	-0.128	0.902	0.033	0.03	0	36.5	36.5	76.1	119	118	0	34	33
2015	12	6	3	5	10	0.115	0.01	0.899	0.033	0.03	0	37	36.1	76.1	120	118	0	34	34
2015	12	6	3	15	10	0.164	-0.056	0.902	0.033	0.03	0	36.5	36.5	75.7	119	118	0	34	33
2015	12	6	3	25	10	0.174	-0.095	0.902	0.033	0.03	0	37.4	36.5	75.7	120	119	0	33	34
2015	12	6	3	35	10	0.207	-0.105	0.902	0.036	0.033	0	37.4	37	75.7	121	119	0	34	33
2015	12	6	3	45	10	0.226	-0.164	0.902	0.033	0.03	0	37	37	76.1	120	119	0	34	33
2015	12	6	3	55	10	0.171	-0.082	0.902	0.033	0.03	0	37.4	37	74.8	120	119	0	33	33
2015	12	6	4	5	10	0.164	-0.138	0.902	0.033	0.03	0	36.5	37	75.3	120	119	0	35	33
2015	12	6	4	15	10	0.184	-0.062	0.902	0.033	0.03	0	37	37	75.3	120	119	0	34	33
2015	12	6	4	25	10	0.226	-0.167	0.902	0.033	0.03	0	36.5	36.1	74.8	119	117	0	34	33
2015	12	6	4	35	10	0.24	-0.082	0.902	0.036	0.033	0	36.5	37	75.3	119	120	0	34	34
2015	12	6	4	45	10	0.151	-0.141	0.902	0.033	0.03	0	37	36.5	74.8	120	118	0	34	33
2015	12	6	4	55	10	0.197	-0.125	0.902	0.039	0.036	0	37	36.1	75.3	121	118	0	35	34
2015	12	6	5	5	10	0.164	-0.112	0.902	0.03	0.03	0	37	36.5	74.8	120	118	0	34	33
2015	12	6	5	15	10	0.21	-0.043	0.902	0.033	0.03	0	36.5	36.1	74.8	119	118	0	34	34
2015	12	6	5	25	10	0.177	-0.066	0.902	0.033	0.03	0	37	36.5	74.4	120	118	0	34	33
2015	12	6	5	35	10	0.148	-0.072	0.902	0.033	0.03	0	37.4	37	74.8	121	119	0	34	33
2015	12	6	5	45	10	0.154	-0.115	0.902	0.033	0.03	0	37	36.5	75.3	120	119	0	34	34
2015	12	6	5	55	10	0.161	-0.108	0.902	0.033	0.03	0	37	36.1	74.4	120	117	0	34	33
2015	12	6	6	5	10	0.207	-0.115	0.902	0.033	0.03	0	36.1	36.1	74.4	119	117	0	35	33
2015	12	6	6	15	10	0.157	-0.085	0.902	0.03	0.026	0	37	35.7	74.4	120	117	0	34	34
2015	12	6	6	25	10	0.112	-0.056	0.902	0.033	0.03	0	36.5	36.1	74	120	118	0	35	34
2015	12	6	6	35	10	0.141	-0.046	0.902	0.03	0.03	0	37	35.7	74.4	120	117	0	34	34
2015	12	6	6	45	10	0.141	-0.046	0.902	0.03	0.026	0	36.1	35.3	74.4	118	116	0	34	34
2015	12	6	6	55	10	0.18	-0.085	0.906	0.036	0.033	0	36.1	34.8	74.4	118	115	0	34	34
2015	12	6	7	5	10	0.141	-0.046	0.906	0.033	0.03	0	35.3	35.7	74.4	116	115	0	34	32
2015	12	6	7	15	10	0.167	-0.095	0.902	0.033	0.03	0	36.5	35.3	74.4	119	115	0	34	33
2015	12	6	7	25	10	0.151	-0.059	0.902	0.033	0.03	0	36.1	34.4	74.8	118	114	0	34	34
2015	12	6	7	35	10	0.161	-0.092	0.902	0.026	0.023	0	35.3	34.4	74.4	117	113	0	35	33
2015	12	6	7	45	10	0.069	-0.089	0.906	0.033	0.03	0	36.1	34	74	118	113	0	34	34
2015	12	6	7	55	10	0.2	-0.141	0.906	0.033	0.03	0	36.5	35.3	74.8	119	115	0	34	33
2015	12	6	8	5	10	0.151	-0.066	0.906	0.03	0.026	0	35.7	34.8	74.4	117	114	0	34	33
2015	12	6	8	15	10	0.135	-0.075	0.906	0.03	0.026	0	35.7	34.4	74.4	117	113	0	34	33
2015	12	6	8	25	10	0.105	-0.112	0.909	0.026	0.023	0	35.7	34.4	74.4	117	113	0	34	33
2015	12	6	8	35	10	0.082	-0.082	0.906	0.033	0.03	0	35.7	34	74.4	117	113	0	34	34
2015	12	6	8	45	10	0.135	-0.072	0.906	0.03	0.026	0	36.1	34	74.4	118	113	0	34	34
2015	12	6	8	55	10	0.112	-0.128	0.909	0.033	0.03	0	35.7	34.8	74.4	117	113	0	34	32
2015	12	6	9	5	10	0.161	-0.102	0.906	0.03	0.026	0	37	34.8	74.4	119	114	0	33	33
2015	12	6	9	15	10	0.118	-0.092	0.909	0.033	0.03	0	35.7	34	74.4	117	113	0	34	34
2015	12	6	9	25	10	0.148	-0.082	0.906	0.033	0.03	0	36.1	34.8	74.4	118	114	0	34	33
2015	12	6	9	35	10	0.131	-0.131	0.909	0.033	0.03	0	36.5	34.8	74.4	119	115	0	34	34
2015	12	6	9	45	10	0.148	-0.072	0.906	0.039	0.036	0	37	35.3	74.8	120	116	0	34	34
2015	12	6	9	55	10	0.098	-0.052	0.906	0.036	0.033	0	37.8	37.4	74	123	120	0	35	33
2015	12	6	10	5	10	0.095	-0.043	0.906	0.033	0.033	0	35.7	35.7	74.4	118	116	0	35	33
2015	12	6	10	15	10	0.112	-0.075	0.902	0.036	0.033	0	36.1	34	74.8	118	113	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	10	25	10	0.154	-0.056	0.902	0.033	0.03	0	35.3	34	74.4	116	113	0	34	34
2015	12	6	10	35	10	0.108	-0.075	0.906	0.03	0.026	0	35.7	34.8	74	117	114	0	34	33
2015	12	6	10	45	10	0.128	-0.098	0.906	0.036	0.033	0	34.8	34.4	74.4	116	113	0	35	33
2015	12	6	10	55	10	0.161	-0.056	0.902	0.033	0.03	0	35.3	33.5	74.8	116	112	0	34	34
2015	12	6	11	5	10	0.154	-0.052	0.906	0.033	0.03	0	34.4	33.5	74.8	114	112	0	34	34
2015	12	6	11	15	10	0.167	-0.092	0.906	0.033	0.03	0	34.8	34	74.8	115	112	0	34	33
2015	12	6	11	25	10	0.112	-0.062	0.906	0.036	0.033	0	34.8	34	74.8	115	113	0	34	34
2015	12	6	11	35	10	0.154	-0.02	0.906	0.033	0.03	0	34.8	34.4	75.3	115	112	0	34	32
2015	12	6	11	45	10	0.197	-0.056	0.906	0.033	0.03	0	35.3	34	75.3	116	112	0	34	33
2015	12	6	11	55	10	0.174	-0.089	0.906	0.033	0.03	0	35.3	34.8	75.7	116	114	0	34	33
2015	12	6	12	5	10	0.184	-0.026	0.906	0.033	0.03	0	35.7	34.8	75.3	117	115	0	34	34
2015	12	6	12	15	10	0.121	-0.003	0.906	0.033	0.03	0	36.5	35.7	75.3	119	116	0	34	33
2015	12	6	12	25	10	0.21	-0.043	0.906	0.036	0.033	0	36.1	35.3	74.8	118	116	0	34	34
2015	12	6	12	35	10	0.292	-0.089	0.906	0.033	0.03	0	37.8	37	74.8	122	119	0	34	33
2015	12	6	12	45	10	0.184	-0.062	0.906	0.039	0.036	0	38.7	38.3	74	124	123	0	34	34
2015	12	6	12	55	10	0.194	-0.049	0.906	0.043	0.039	0	40	39.6	73.5	127	125	0	34	33
2015	12	6	13	5	10	0.197	-0.062	0.906	0.039	0.036	0	40	40.4	74.4	127	127	0	34	33
2015	12	6	13	15	10	0.217	-0.036	0.906	0.039	0.039	0	39.6	39.6	74	126	125	0	34	33
2015	12	6	13	25	10	0.243	-0.043	0.906	0.036	0.033	0	41.7	41.3	74	131	129	0	34	33
2015	12	6	13	35	10	0.184	-0.059	0.906	0.039	0.036	0	40.4	40	74.8	128	126	0	34	33
2015	12	6	13	45	10	0.161	-0.043	0.906	0.036	0.033	0	39.1	39.1	75.3	125	124	0	34	33
2015	12	6	13	55	10	0.121	-0.02	0.906	0.039	0.036	0	38.3	37.4	75.3	123	121	0	34	34
2015	12	6	14	5	10	0.19	0.02	0.906	0.033	0.03	0	37.4	37.4	75.7	121	121	0	34	34
2015	12	6	14	15	10	0.213	-0.016	0.906	0.033	0.03	0	38.3	37.8	75.3	123	121	0	34	33
2015	12	6	14	25	10	0.2	-0.033	0.906	0.036	0.033	0	39.6	39.6	74.4	126	125	0	34	33
2015	12	6	14	35	10	0.285	0.135	0.906	0.039	0.039	0	44.3	43.9	72.7	136	135	0	33	33
2015	12	6	14	45	10	0.174	-0.007	0.906	0.033	0.03	0	40	40.4	75.3	126	127	0	33	33
2015	12	6	14	55	10	0.157	-0.026	0.906	0.033	0.03	0	38.3	38.7	76.5	123	123	0	34	33
2015	12	6	15	5	10	0.19	0.026	0.906	0.036	0.033	0	40	39.1	75.3	126	123	0	33	32
2015	12	6	15	15	10	0.154	-0.01	0.906	0.033	0.03	0	37.4	37.4	76.1	121	120	0	34	33
2015	12	6	15	25	10	0.115	0.02	0.906	0.033	0.03	0	37	35.7	76.1	119	116	0	33	33
2015	12	6	15	35	10	0.112	0	0.906	0.036	0.033	0	36.1	35.3	76.5	118	116	0	34	34
2015	12	6	15	45	10	-0.062	0.128	0.906	0.033	0.03	0	35.3	34.8	76.5	116	114	0	34	33
2015	12	6	15	55	10	0.039	0.092	0.906	0.033	0.03	0	35.3	34.8	77	116	114	0	34	33
2015	12	6	16	5	10	-0.092	0.141	0.906	0.036	0.033	0	34.4	34.4	77.4	114	113	0	34	33
2015	12	6	16	15	10	-0.049	0.144	0.906	0.033	0.03	0	34.8	34	76.5	115	113	0	34	34
2015	12	6	16	25	10	-0.03	0.141	0.906	0.036	0.033	0	35.7	34	77	116	113	0	33	34
2015	12	6	16	35	10	0.043	-0.007	0.906	0.033	0.03	0	34.8	34.8	77.4	115	114	0	34	33
2015	12	6	16	45	10	0.089	0.046	0.906	0.033	0.03	0	34.8	34.8	77	115	114	0	34	33
2015	12	6	16	55	10	0.148	0.062	0.906	0.036	0.033	0	37	36.5	76.5	120	119	0	34	34
2015	12	6	17	5	10	0.194	0.023	0.906	0.033	0.03	0	38.7	38.7	76.1	124	122	0	34	32
2015	12	6	17	15	10	0.266	0.052	0.906	0.033	0.03	0	39.1	39.1	75.3	125	124	0	34	33
2015	12	6	17	25	10	0.233	0.043	0.906	0.033	0.03	0	39.1	39.1	75.3	125	125	0	34	34
2015	12	6	17	35	10	0.144	0.112	0.906	0.039	0.036	0	39.6	39.1	75.7	125	124	0	33	33
2015	12	6	17	45	10	0.174	0.052	0.906	0.033	0.03	0	39.1	39.1	75.3	125	124	0	34	33
2015	12	6	17	55	10	0.217	0.007	0.906	0.033	0.03	0	40	39.6	75.3	127	125	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	18	5	10	0.164	-0.013	0.906	0.036	0.033	0	39.1	38.7	74.8	125	124	0	34	34
2015	12	6	18	15	10	0.23	-0.026	0.906	0.033	0.03	0	38.7	38.3	75.7	123	122	0	33	33
2015	12	6	18	25	10	0.217	0.013	0.906	0.033	0.03	0	37.4	37.8	76.1	121	120	0	34	32
2015	12	6	18	35	10	0.135	0.013	0.906	0.033	0.03	0	37.4	36.5	75.7	121	118	0	34	33
2015	12	6	18	45	10	0.112	0.131	0.906	0.036	0.033	0	36.5	36.5	76.5	119	118	0	34	33
2015	12	6	18	55	10	0.098	0.056	0.906	0.036	0.033	0	36.1	35.7	75.7	118	116	0	34	33
2015	12	6	19	5	10	0.171	-0.026	0.906	0.036	0.033	0	35.7	35.3	76.1	117	115	0	34	33
2015	12	6	19	15	10	0.115	0.069	0.906	0.036	0.033	0	35.3	34.4	76.1	117	114	0	35	34
2015	12	6	19	25	10	0.197	-0.043	0.906	0.039	0.039	0	35.3	34.4	75.7	116	114	0	34	34
2015	12	6	19	35	10	0.112	-0.115	0.906	0.033	0.03	0	34.8	34.8	76.1	115	114	0	34	33
2015	12	6	19	45	10	0.24	-0.062	0.906	0.033	0.03	0	35.7	34	76.5	116	113	0	33	34
2015	12	6	19	55	10	0.2	-0.102	0.906	0.033	0.03	0	35.3	34.4	75.7	116	113	0	34	33
2015	12	6	20	5	10	0.167	-0.066	0.906	0.039	0.036	0	35.7	34.8	75.7	117	114	0	34	33
2015	12	6	20	15	10	0.207	-0.095	0.906	0.033	0.03	0	34.8	34.8	75.3	115	114	0	34	33
2015	12	6	20	25	10	0.174	-0.026	0.906	0.033	0.03	0	35.3	34.8	75.7	116	114	0	34	33
2015	12	6	20	35	10	0.174	-0.095	0.906	0.03	0.026	0	35.7	35.3	75.3	117	115	0	34	33
2015	12	6	20	45	10	0.203	-0.135	0.906	0.039	0.039	0	35.7	35.3	75.3	117	115	0	34	33
2015	12	6	20	55	10	0.243	-0.046	0.906	0.033	0.03	0	36.1	35.3	75.3	117	115	0	33	33
2015	12	6	21	5	10	0.144	-0.049	0.906	0.033	0.03	0	35.3	35.7	74.8	116	116	0	34	33
2015	12	6	21	15	10	0.161	-0.085	0.906	0.033	0.03	0	35.3	35.3	74.8	116	115	0	34	33
2015	12	6	21	25	10	0.138	-0.043	0.906	0.039	0.036	0	35.7	35.7	74.8	117	116	0	34	33
2015	12	6	21	35	10	0.082	0.026	0.906	0.036	0.033	0	35.7	36.1	74.4	117	116	0	34	32
2015	12	6	21	45	10	0.213	-0.013	0.906	0.043	0.043	0	35.7	35.3	74.4	117	115	0	34	33
2015	12	6	21	55	10	0.184	-0.079	0.906	0.033	0.03	0	36.1	35.7	74.4	118	116	0	34	33
2015	12	6	22	5	10	0.108	-0.013	0.906	0.033	0.03	0	36.1	35.3	74.4	117	115	0	33	33
2015	12	6	22	15	10	0.194	-0.085	0.906	0.033	0.03	0	35.3	36.5	74.4	116	118	0	34	33
2015	12	6	22	25	10	0.253	-0.102	0.906	0.033	0.03	0	35.7	35.7	74	117	117	0	34	34
2015	12	6	22	35	10	0.236	-0.059	0.906	0.033	0.03	0	36.5	36.1	74.4	119	117	0	34	33
2015	12	6	22	45	10	0.226	-0.056	0.906	0.033	0.033	0	37	35.7	74	119	116	0	33	33
2015	12	6	22	55	10	0.207	-0.069	0.906	0.033	0.03	0	36.5	35.7	74	119	117	0	34	34
2015	12	6	23	5	10	0.197	-0.066	0.906	0.033	0.033	0	37	36.1	74	120	117	0	34	33
2015	12	6	23	15	10	0.138	-0.056	0.909	0.033	0.03	0	36.1	36.1	74.4	118	117	0	34	33
2015	12	6	23	25	10	0.262	-0.085	0.909	0.033	0.03	0	37.4	37	74	120	119	0	33	33
2015	12	6	23	35	10	0.184	-0.072	0.909	0.039	0.036	0	36.5	36.5	74	119	118	0	34	33
2015	12	6	23	45	10	0.197	-0.052	0.909	0.033	0.03	0	36.5	36.5	74	119	118	0	34	33
2015	12	6	23	55	10	0.167	-0.125	0.909	0.033	0.03	0	36.1	36.5	74	118	118	0	34	33
2015	12	7	0	5	10	0.223	-0.082	0.909	0.03	0.026	0	37.4	37.4	73.1	121	121	0	34	34
2015	12	7	0	15	10	0.18	-0.043	0.909	0.033	0.03	0	37	37	74	120	119	0	34	33
2015	12	7	0	25	10	0.21	-0.072	0.909	0.033	0.03	0	37.4	37.4	73.5	120	120	0	33	33
2015	12	7	0	35	10	0.164	-0.052	0.912	0.039	0.036	0	37	36.5	73.5	120	119	0	34	34
2015	12	7	0	45	10	0.118	-0.085	0.912	0.033	0.03	0	37.4	37	73.5	121	120	0	34	34
2015	12	7	0	55	10	0.19	-0.121	0.912	0.033	0.03	0	37.8	37.4	74	122	120	0	34	33
2015	12	7	1	5	10	0.151	-0.033	0.909	0.033	0.03	0	37.4	37.4	74	121	120	0	34	33
2015	12	7	1	15	10	0.207	-0.072	0.912	0.033	0.03	0	37	37	74	120	120	0	34	34
2015	12	7	1	25	10	0.167	-0.043	0.912	0.03	0.026	0	36.5	36.5	73.5	119	119	0	34	34
2015	12	7	1	35	10	0.164	-0.098	0.912	0.033	0.03	0	37	37	73.1	120	120	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	1	45	10	0.18	-0.128	0.912	0.033	0.03	0	37.8	37.4	74	121	120	0	33	33
2015	12	7	1	55	10	0.19	-0.072	0.912	0.033	0.03	0	37	37	73.5	120	119	0	34	33
2015	12	7	2	5	10	0.154	-0.023	0.912	0.036	0.033	0	36.5	37	74	119	119	0	34	33
2015	12	7	2	15	10	0.22	-0.108	0.912	0.036	0.033	0	37.4	37.4	73.5	121	120	0	34	33
2015	12	7	2	25	10	0.197	-0.105	0.912	0.033	0.03	0	37.4	36.5	73.5	121	119	0	34	34
2015	12	7	2	35	10	0.197	-0.069	0.912	0.033	0.03	0	36.5	37	74.4	119	119	0	34	33
2015	12	7	2	45	10	0.226	-0.138	0.912	0.033	0.03	0	36.5	37.4	73.5	119	120	0	34	33
2015	12	7	2	55	10	0.203	-0.075	0.912	0.033	0.03	0	36.5	36.5	74	119	119	0	34	34
2015	12	7	3	5	10	0.161	-0.056	0.912	0.033	0.03	0	37	36.5	74	120	118	0	34	33
2015	12	7	3	15	10	0.098	0.01	0.912	0.039	0.036	0	36.5	36.5	73.5	119	118	0	34	33
2015	12	7	3	25	10	0.157	-0.046	0.912	0.033	0.03	0	37	36.5	73.5	120	119	0	34	34
2015	12	7	3	35	10	0.174	-0.121	0.912	0.033	0.03	0	36.5	36.5	74	119	119	0	34	34
2015	12	7	3	45	10	0.157	-0.026	0.912	0.03	0.03	0	36.5	37.4	74	120	120	0	35	33
2015	12	7	3	55	10	0.22	-0.085	0.912	0.03	0.026	0	37	37	74	120	119	0	34	33
2015	12	7	4	5	10	0.21	-0.092	0.912	0.03	0.03	0	36.5	37	73.5	119	119	0	34	33
2015	12	7	4	15	10	0.21	-0.056	0.912	0.033	0.03	0	37	37	73.5	120	120	0	34	34
2015	12	7	4	25	10	0.161	-0.135	0.912	0.033	0.03	0	36.1	37	73.5	119	120	0	35	34
2015	12	7	4	35	10	0.21	-0.095	0.912	0.033	0.03	0	36.5	37.4	73.1	119	120	0	34	33
2015	12	7	4	45	10	0.246	-0.023	0.912	0.03	0.03	0	37	36.5	73.5	120	119	0	34	34
2015	12	7	4	55	10	0.095	-0.072	0.912	0.033	0.03	0	37	36.1	74	120	118	0	34	34
2015	12	7	5	5	10	0.21	-0.033	0.912	0.033	0.03	0	36.5	37	73.5	120	119	0	35	33
2015	12	7	5	15	10	0.164	-0.062	0.912	0.039	0.036	0	36.5	36.1	73.5	119	118	0	34	34
2015	12	7	5	25	10	0.177	-0.03	0.912	0.033	0.03	0	37	36.5	73.5	120	119	0	34	34
2015	12	7	5	35	10	0.141	-0.112	0.912	0.036	0.033	0	36.5	36.5	74	119	118	0	34	33
2015	12	7	5	45	10	0.135	-0.075	0.912	0.033	0.03	0	37	37.4	73.5	120	121	0	34	34
2015	12	7	5	55	10	0.256	-0.112	0.912	0.033	0.03	0	37.4	37.4	73.5	121	120	0	34	33
2015	12	7	6	5	10	0.207	-0.105	0.912	0.033	0.03	0	37	37.4	73.5	120	120	0	34	33
2015	12	7	6	15	10	0.21	-0.059	0.912	0.033	0.03	0	37	37.8	73.1	121	121	0	35	33
2015	12	7	6	25	10	0.2	-0.043	0.912	0.033	0.03	0	36.5	37	74	120	119	0	35	33
2015	12	7	6	35	10	0.18	-0.039	0.912	0.033	0.03	0	37.4	36.5	74	121	119	0	34	34
2015	12	7	6	45	10	0.184	-0.085	0.912	0.033	0.033	0	37.4	37	73.5	121	120	0	34	34
2015	12	7	6	55	10	0.154	-0.125	0.912	0.033	0.03	0	35.7	36.1	74	117	117	0	34	33
2015	12	7	7	5	10	0.194	-0.135	0.912	0.033	0.03	0	39.6	39.6	72.7	126	125	0	34	33
2015	12	7	7	15	10	0.194	-0.085	0.912	0.033	0.033	0	38.7	37.8	73.5	124	121	0	34	33
2015	12	7	7	25	10	0.138	-0.056	0.912	0.033	0.03	0	36.1	35.3	74	118	116	0	34	34
2015	12	7	7	35	10	0.207	-0.046	0.915	0.039	0.036	0	39.6	39.6	73.1	126	125	0	34	33
2015	12	7	7	45	10	0.184	-0.128	0.912	0.033	0.03	0	36.5	36.1	74	119	117	0	34	33
2015	12	7	7	55	10	0.174	-0.079	0.912	0.033	0.03	0	36.5	35.7	74.4	119	117	0	34	34
2015	12	7	8	5	10	0.135	-0.092	0.915	0.033	0.03	0	35.7	34.8	74.8	117	115	0	34	34
2015	12	7	8	15	10	0.128	-0.069	0.915	0.03	0.026	0	35.7	34.8	74.8	117	114	0	34	33
2015	12	7	8	25	10	0.164	-0.115	0.912	0.036	0.033	0	35.7	34.8	74	117	114	0	34	33
2015	12	7	8	35	10	0.125	-0.125	0.912	0.033	0.03	0	35.7	35.3	74.4	117	115	0	34	33
2015	12	7	8	45	10	0.141	-0.144	0.915	0.033	0.03	0	34.8	34.4	74.8	116	114	0	35	34
2015	12	7	8	55	10	0.112	-0.102	0.912	0.03	0.026	0	34.8	34.8	74.4	115	113	0	34	32
2015	12	7	9	5	10	0.125	-0.125	0.912	0.033	0.03	0	35.7	34.4	74.8	117	113	0	34	33
2015	12	7	9	15	10	0.138	-0.095	0.909	0.03	0.026	0	34.8	34.8	74.4	115	114	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	9	25	10	0.154	-0.128	0.909	0.033	0.03	0	36.5	36.1	74.4	119	117	0	34	33
2015	12	7	9	35	10	0.22	-0.21	0.909	0.033	0.03	0	35.7	34.4	74	117	114	0	34	34
2015	12	7	9	45	10	0.131	-0.115	0.909	0.033	0.03	0	35.7	34.8	74.4	117	114	0	34	33
2015	12	7	9	55	10	0.217	-0.098	0.906	0.033	0.03	0	36.1	35.3	74.8	118	115	0	34	33
2015	12	7	10	5	10	0.167	-0.128	0.906	0.033	0.03	0	34.8	34.8	74.4	116	115	0	35	34
2015	12	7	10	15	10	0.161	-0.059	0.906	0.033	0.03	0	36.1	34.8	75.3	118	114	0	34	33
2015	12	7	10	25	10	0.128	-0.108	0.906	0.039	0.036	0	35.7	35.3	74.8	117	115	0	34	33
2015	12	7	10	35	10	0.128	-0.066	0.906	0.033	0.03	0	35.7	34.4	74.8	117	114	0	34	34
2015	12	7	10	45	10	0.19	-0.052	0.906	0.039	0.036	0	34.8	34.4	74.8	115	114	0	34	34
2015	12	7	10	55	10	0.21	-0.098	0.906	0.03	0.03	0	34.8	34.8	75.3	115	114	0	34	33
2015	12	7	11	5	10	0.157	-0.016	0.906	0.033	0.03	0	35.7	34.8	74.8	117	114	0	34	33
2015	12	7	11	15	10	0.154	-0.072	0.906	0.033	0.03	0	35.3	34.8	75.3	116	114	0	34	33
2015	12	7	11	25	10	0.22	-0.056	0.906	0.033	0.03	0	35.3	34.8	75.7	116	114	0	34	33
2015	12	7	11	35	10	0.226	-0.043	0.906	0.043	0.039	0	37.4	36.5	74.8	121	119	0	34	34
2015	12	7	11	45	10	0.21	-0.016	0.906	0.039	0.036	0	36.5	36.5	75.3	119	118	0	34	33
2015	12	7	11	55	10	0.194	-0.03	0.906	0.03	0.03	0	36.1	35.3	75.3	118	116	0	34	34
2015	12	7	12	5	10	0.154	0.046	0.906	0.033	0.03	0	36.1	35.7	75.3	118	116	0	34	33
2015	12	7	12	15	10	0.18	-0.059	0.906	0.036	0.033	0	36.5	35.7	76.1	119	116	0	34	33
2015	12	7	12	25	10	0.194	-0.043	0.906	0.03	0.026	0	36.5	36.1	75.7	118	117	0	33	33
2015	12	7	12	35	10	0.217	-0.03	0.906	0.036	0.033	0	41.7	39.6	74	130	126	0	33	34
2015	12	7	12	45	10	0.233	0.01	0.906	0.039	0.036	0	38.3	38.3	75.7	123	122	0	34	33
2015	12	7	12	55	10	0.131	-0.089	0.906	0.033	0.03	0	37.4	37.8	76.5	121	121	0	34	33
2015	12	7	13	5	10	0.092	0.033	0.906	0.033	0.03	0	37.8	37	76.1	122	120	0	34	34
2015	12	7	13	15	10	0.105	-0.02	0.906	0.039	0.036	0	37	36.5	76.1	120	119	0	34	34
2015	12	7	13	25	10	0.098	0.049	0.906	0.033	0.03	0	37.4	36.5	76.1	120	118	0	33	33
2015	12	7	13	35	10	0.167	-0.039	0.906	0.033	0.03	0	37.4	37.8	76.1	121	121	0	34	33
2015	12	7	13	45	10	0.161	-0.108	0.906	0.033	0.03	0	37	37.8	76.5	120	120	0	34	32
2015	12	7	13	55	10	0.138	-0.043	0.906	0.033	0.03	0	37.4	37.4	76.1	121	120	0	34	33
2015	12	7	14	5	10	0.249	-0.052	0.906	0.036	0.033	0	38.3	38.7	75.7	123	122	0	34	32
2015	12	7	14	15	10	0.2	0.033	0.906	0.036	0.033	0	38.7	38.7	75.7	124	122	0	34	32
2015	12	7	14	25	10	0.161	0.085	0.906	0.033	0.033	0	40.4	40.9	75.7	128	128	0	34	33
2015	12	7	14	35	10	0.305	0.062	0.906	0.033	0.03	0	40.4	40.9	74.4	127	128	0	33	33
2015	12	7	14	45	10	0.187	0.013	0.906	0.036	0.033	0	43	43	74	133	133	0	33	33
2015	12	7	14	55	10	0.22	0.01	0.906	0.036	0.033	0	40.4	40.9	75.7	128	127	0	34	32
2015	12	7	15	5	10	0.236	0.039	0.906	0.033	0.03	0	39.1	39.6	76.5	125	125	0	34	33
2015	12	7	15	15	10	0.23	-0.01	0.906	0.033	0.03	0	38.3	38.3	76.5	123	122	0	34	33
2015	12	7	15	25	10	0.279	0.016	0.906	0.033	0.03	0	37.8	38.3	76.5	121	122	0	33	33
2015	12	7	15	35	10	0.217	0.059	0.906	0.033	0.03	0	38.3	37.4	77.4	122	121	0	33	34
2015	12	7	15	45	10	0.381	-0.072	0.906	0.033	0.03	0	35.7	36.1	77.8	117	117	0	34	33
2015	12	7	15	55	10	0.144	0.016	0.906	0.039	0.039	0	35.3	34.8	77.8	115	114	0	33	33
2015	12	7	16	5	10	0.262	-0.046	0.906	0.033	0.033	0	34.8	35.3	77.4	115	115	0	34	33
2015	12	7	16	15	10	0.148	0.013	0.906	0.036	0.033	0	37.4	36.5	77.4	120	118	0	33	33
2015	12	7	16	25	10	0.174	-0.062	0.902	0.036	0.033	0	40.4	40	75.7	128	126	0	34	33
2015	12	7	16	35	10	0.098	0.039	0.902	0.039	0.036	0	38.7	38.3	76.5	124	122	0	34	33
2015	12	7	16	45	10	0.226	-0.033	0.906	0.033	0.03	0	37	36.1	78.3	119	117	0	33	33
2015	12	7	16	55	10	0.089	0.01	0.906	0.039	0.036	0	35.7	34.4	78.3	116	114	0	33	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	17	5	10	0.243	-0.115	0.906	0.033	0.03	0	35.7	35.7	77.4	116	115	0	33	32
2015	12	7	17	15	10	0.108	0.039	0.906	0.03	0.03	0	37.4	37.8	77.4	121	120	0	34	32
2015	12	7	17	25	10	0.269	-0.046	0.902	0.036	0.033	0	38.7	37.8	77	123	121	0	33	33
2015	12	7	17	35	10	0.194	-0.013	0.906	0.033	0.03	0	37.8	37.4	77	121	120	0	33	33
2015	12	7	17	45	10	0.174	-0.016	0.906	0.039	0.036	0	37	36.5	77.4	119	118	0	33	33
2015	12	7	17	55	10	0.233	0.01	0.906	0.033	0.03	0	40	39.6	76.5	126	124	0	33	32
2015	12	7	18	5	10	0.217	-0.046	0.906	0.036	0.033	0	38.3	37.8	77	123	121	0	34	33
2015	12	7	18	15	10	0.18	0.036	0.906	0.036	0.033	0	37.4	37.4	76.5	121	120	0	34	33
2015	12	7	18	25	10	0.098	0.075	0.906	0.039	0.036	0	37.8	37.4	77.4	121	120	0	33	33
2015	12	7	18	35	10	0.203	-0.039	0.906	0.033	0.03	0	36.5	37	77.4	119	119	0	34	33
2015	12	7	18	45	10	0.19	-0.072	0.906	0.039	0.039	0	36.5	36.1	77	119	117	0	34	33
2015	12	7	18	55	10	0.144	-0.003	0.906	0.033	0.03	0	37	36.1	77.4	119	117	0	33	33
2015	12	7	19	5	10	0.187	-0.016	0.906	0.039	0.036	0	36.1	35.7	77	117	116	0	33	33
2015	12	7	19	15	10	0.295	-0.085	0.906	0.043	0.039	0	36.1	36.1	77	118	117	0	34	33
2015	12	7	19	25	10	0.276	-0.023	0.906	0.039	0.039	0	37.8	37.8	76.5	122	121	0	34	33
2015	12	7	19	35	10	0.174	0.003	0.906	0.033	0.03	0	36.1	36.1	77	118	117	0	34	33
2015	12	7	19	45	10	0.151	-0.03	0.906	0.039	0.036	0	36.1	35.7	77.4	118	117	0	34	34
2015	12	7	19	55	10	0.213	-0.102	0.906	0.039	0.036	0	35.7	35.7	77	117	116	0	34	33
2015	12	7	20	5	10	0.292	-0.092	0.906	0.039	0.039	0	36.1	35.7	77	117	116	0	33	33
2015	12	7	20	15	10	0.217	-0.125	0.906	0.033	0.03	0	35.7	35.3	77	117	115	0	34	33
2015	12	7	20	25	10	0.243	0.007	0.906	0.033	0.03	0	36.5	36.5	77	119	117	0	34	32
2015	12	7	20	35	10	0.161	-0.089	0.906	0.039	0.036	0	41.7	40.4	74.4	130	127	0	33	33
2015	12	7	20	45	10	0.2	-0.013	0.906	0.036	0.033	0	38.3	38.3	75.7	123	121	0	34	32
2015	12	7	20	55	10	0.154	-0.03	0.906	0.043	0.043	0	39.1	38.3	75.7	124	122	0	33	33
2015	12	7	21	5	10	0.154	-0.03	0.906	0.039	0.036	0	38.7	37.4	75.7	123	120	0	33	33
2015	12	7	21	15	10	0.253	-0.056	0.906	0.033	0.03	0	36.5	37.4	76.1	119	119	0	34	32
2015	12	7	21	25	10	0.213	-0.062	0.906	0.043	0.043	0	36.1	36.5	76.5	118	118	0	34	33
2015	12	7	21	35	10	0.161	-0.082	0.906	0.039	0.036	0	36.5	36.1	76.1	119	117	0	34	33
2015	12	7	21	45	10	0.141	-0.03	0.906	0.036	0.033	0	37.4	37	76.1	121	119	0	34	33
2015	12	7	21	55	10	0.115	-0.052	0.906	0.033	0.03	0	37.8	37	75.7	121	119	0	33	33
2015	12	7	22	5	10	0.052	-0.03	0.906	0.033	0.03	0	37.4	37	75.7	120	119	0	33	33
2015	12	7	22	15	10	0.131	-0.069	0.906	0.033	0.03	0	37.4	37.4	75.7	120	119	0	33	32
2015	12	7	22	25	10	0.203	-0.059	0.906	0.039	0.039	0	37	37.4	75.3	120	120	0	34	33
2015	12	7	22	35	10	0.23	-0.131	0.906	0.043	0.043	0	37.8	37	75.7	121	119	0	33	33
2015	12	7	22	45	10	0.144	-0.075	0.906	0.036	0.033	0	37	37	75.7	120	119	0	34	33
2015	12	7	22	55	10	0.236	-0.098	0.906	0.039	0.036	0	37.4	37.4	75.3	121	120	0	34	33
2015	12	7	23	5	10	0.174	-0.079	0.906	0.036	0.033	0	37.4	37	75.7	121	120	0	34	34
2015	12	7	23	15	10	0.22	-0.089	0.906	0.03	0.026	0	38.3	39.1	75.3	123	124	0	34	33
2015	12	7	23	25	10	0.243	-0.085	0.906	0.033	0.03	0	37.8	38.7	75.3	122	123	0	34	33
2015	12	7	23	35	10	0.213	-0.075	0.906	0.033	0.03	0	37.4	39.1	74.4	121	124	0	34	33
2015	12	7	23	45	10	0.213	-0.095	0.906	0.033	0.03	0	38.3	38.3	75.3	123	122	0	34	33
2015	12	7	23	55	10	0.174	-0.069	0.906	0.033	0.03	0	38.3	38.3	74.8	122	123	0	33	34
2015	12	8	0	5	10	0.2	-0.092	0.906	0.033	0.03	0	38.7	39.6	74.8	123	125	0	33	33
2015	12	8	0	15	10	0.272	-0.052	0.906	0.033	0.03	0	38.3	38.7	74.8	123	124	0	34	34
2015	12	8	0	25	10	0.187	-0.033	0.906	0.033	0.03	0	37.8	39.1	74.8	122	124	0	34	33
2015	12	8	0	35	10	0.187	0.056	0.906	0.033	0.03	0	38.7	38.7	74.8	123	123	0	33	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	0	45	10	0.167	-0.056	0.906	0.033	0.03	0	37.4	38.7	75.3	122	123	0	35	33
2015	12	8	0	55	10	0.171	0.01	0.906	0.033	0.03	0	39.1	40	74.4	125	125	0	34	32
2015	12	8	1	5	10	0.164	-0.003	0.902	0.033	0.03	0	38.3	39.6	74.8	123	125	0	34	33
2015	12	8	1	15	10	0.194	-0.049	0.906	0.036	0.033	0	38.7	39.1	74.8	124	124	0	34	33
2015	12	8	1	25	10	0.2	-0.072	0.902	0.033	0.033	0	37.8	39.1	75.3	122	124	0	34	33
2015	12	8	1	35	10	0.262	-0.085	0.902	0.039	0.036	0	38.7	39.1	74.8	124	125	0	34	34
2015	12	8	1	45	10	0.266	-0.01	0.902	0.039	0.036	0	40.4	40.9	74	128	128	0	34	33
2015	12	8	1	55	10	0.154	-0.075	0.902	0.033	0.03	0	37.8	38.7	75.7	122	123	0	34	33
2015	12	8	2	5	10	0.203	-0.059	0.902	0.033	0.03	0	38.3	38.7	74.8	123	124	0	34	34
2015	12	8	2	15	10	0.157	-0.033	0.902	0.036	0.033	0	38.3	40	75.3	123	125	0	34	32
2015	12	8	2	25	10	0.213	-0.043	0.902	0.033	0.03	0	39.6	40	74.8	125	126	0	33	33
2015	12	8	2	35	10	0.223	0.003	0.902	0.033	0.03	0	38.3	39.6	74.8	123	125	0	34	33
2015	12	8	2	45	10	0.187	-0.066	0.902	0.036	0.033	0	39.1	39.1	74.4	125	124	0	34	33
2015	12	8	2	55	10	0.243	-0.075	0.902	0.036	0.033	0	38.7	39.6	75.3	124	125	0	34	33
2015	12	8	3	5	10	0.246	-0.069	0.902	0.039	0.036	0	39.1	39.6	74.4	125	124	0	34	32
2015	12	8	3	15	10	0.21	-0.013	0.902	0.033	0.033	0	39.1	39.1	75.3	125	124	0	34	33
2015	12	8	3	25	10	0.243	-0.072	0.902	0.039	0.036	0	38.3	39.6	74.8	123	125	0	34	33
2015	12	8	3	35	10	0.184	-0.102	0.902	0.033	0.03	0	37.8	39.1	75.7	123	124	0	35	33
2015	12	8	3	45	10	0.184	-0.02	0.902	0.033	0.03	0	38.3	39.1	75.3	123	124	0	34	33
2015	12	8	3	55	10	0.213	-0.03	0.902	0.033	0.03	0	39.1	40.9	74.4	125	127	0	34	32
2015	12	8	4	5	10	0.197	-0.066	0.902	0.03	0.03	0	38.7	40	74.8	124	126	0	34	33
2015	12	8	4	15	10	0.197	-0.072	0.902	0.036	0.033	0	39.6	39.1	74.8	126	124	0	34	33
2015	12	8	4	25	10	0.226	-0.082	0.902	0.036	0.033	0	38.7	38.7	74.8	124	124	0	34	34
2015	12	8	4	35	10	0.187	-0.069	0.902	0.03	0.03	0	38.3	40	74.8	123	126	0	34	33
2015	12	8	4	45	10	0.217	-0.112	0.902	0.033	0.033	0	39.6	40.9	74.8	126	128	0	34	33
2015	12	8	4	55	10	0.197	-0.062	0.902	0.036	0.033	0	38.7	40.4	74.8	124	127	0	34	33
2015	12	8	5	5	10	0.138	-0.105	0.902	0.033	0.03	0	39.1	39.6	75.7	125	126	0	34	34
2015	12	8	5	15	10	0.19	-0.112	0.902	0.033	0.03	0	40	40.4	74.4	127	127	0	34	33
2015	12	8	5	25	10	0.23	-0.085	0.902	0.036	0.033	0	39.6	39.6	75.3	126	125	0	34	33
2015	12	8	5	35	10	0.223	-0.089	0.902	0.036	0.033	0	39.1	39.6	74.4	125	126	0	34	34
2015	12	8	5	45	10	0.161	-0.092	0.902	0.033	0.03	0	39.1	40	75.3	126	126	0	35	33
2015	12	8	5	55	10	0.177	-0.056	0.902	0.033	0.03	0	38.7	39.6	75.3	124	125	0	34	33
2015	12	8	6	5	10	0.262	-0.016	0.902	0.033	0.03	0	38.7	40	74.8	124	126	0	34	33
2015	12	8	6	15	10	0.217	-0.036	0.902	0.043	0.039	0	39.1	39.6	75.3	125	125	0	34	33
2015	12	8	6	25	10	0.184	-0.049	0.902	0.03	0.03	0	38.7	40	75.3	124	126	0	34	33
2015	12	8	6	35	10	0.223	-0.043	0.902	0.039	0.036	0	38.3	39.1	75.3	123	124	0	34	33
2015	12	8	6	45	10	0.174	-0.079	0.902	0.036	0.033	0	37.8	38.7	74.8	123	123	0	35	33
2015	12	8	6	55	10	0.184	-0.085	0.902	0.033	0.03	0	37	37.8	76.1	120	121	0	34	33
2015	12	8	7	5	10	0.177	-0.072	0.902	0.033	0.03	0	37.4	37.4	75.7	121	120	0	34	33
2015	12	8	7	15	10	0.197	-0.069	0.902	0.033	0.03	0	36.5	37	75.7	119	119	0	34	33
2015	12	8	7	25	10	0.187	-0.118	0.902	0.033	0.03	0	36.1	36.5	76.1	118	118	0	34	33
2015	12	8	7	35	10	0.151	-0.056	0.902	0.036	0.033	0	36.1	36.5	76.5	118	118	0	34	33
2015	12	8	7	45	10	0.197	-0.023	0.902	0.033	0.03	0	36.1	35.7	76.1	117	117	0	33	34
2015	12	8	7	55	10	0.151	-0.092	0.902	0.033	0.03	0	36.5	36.1	76.5	119	118	0	34	34
2015	12	8	8	5	10	0.197	-0.052	0.902	0.033	0.03	0	35.7	36.1	75.7	116	118	0	33	34
2015	12	8	8	15	10	0.21	-0.115	0.902	0.036	0.033	0	36.1	37	76.1	118	119	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	8	25	10	0.151	-0.085	0.902	0.036	0.033	0	36.1	36.5	77	118	118	0	34	33
2015	12	8	8	35	10	0.131	-0.069	0.902	0.036	0.033	0	36.1	36.1	76.1	118	118	0	34	34
2015	12	8	8	45	10	0.141	-0.066	0.902	0.033	0.03	0	36.5	35.7	76.5	119	116	0	34	33
2015	12	8	8	55	10	0.18	-0.128	0.902	0.039	0.036	0	36.5	37.4	76.5	119	120	0	34	33
2015	12	8	9	5	10	0.141	-0.03	0.902	0.033	0.03	0	37	37	77	120	119	0	34	33
2015	12	8	9	15	10	0.184	-0.066	0.902	0.036	0.033	0	36.1	36.5	76.5	118	118	0	34	33
2015	12	8	9	25	10	0.164	-0.069	0.902	0.033	0.03	0	35.7	36.5	77	118	118	0	35	33
2015	12	8	9	35	10	0.112	-0.056	0.902	0.033	0.03	0	35.7	37	77	118	119	0	35	33
2015	12	8	9	45	10	0.118	-0.03	0.902	0.033	0.03	0	36.5	36.5	77.4	119	118	0	34	33
2015	12	8	9	55	10	0.184	0	0.902	0.033	0.03	0	35.7	36.5	77.4	117	117	0	34	32
2015	12	8	10	5	10	0.21	-0.059	0.902	0.033	0.03	0	35.7	36.1	77	117	117	0	34	33
2015	12	8	10	15	10	0.105	0	0.902	0.033	0.03	0	36.1	36.5	77	118	118	0	34	33
2015	12	8	10	25	10	0.161	-0.082	0.902	0.033	0.03	0	37	36.1	77.4	119	117	0	33	33
2015	12	8	10	35	10	0.184	-0.059	0.902	0.033	0.03	0	36.1	36.1	77.4	117	117	0	33	33
2015	12	8	10	45	10	0.154	0.036	0.902	0.033	0.03	0	36.5	36.1	77.8	119	118	0	34	34
2015	12	8	10	55	10	0.171	0.013	0.902	0.033	0.03	0	37	37	76.5	120	119	0	34	33
2015	12	8	11	5	10	0.125	-0.102	0.902	0.039	0.036	0	37	37	77.4	120	119	0	34	33
2015	12	8	11	15	10	0.2	-0.079	0.902	0.036	0.033	0	37.4	37.4	77.4	121	120	0	34	33
2015	12	8	11	25	10	0.148	-0.02	0.902	0.043	0.039	0	37	37.4	77.4	120	120	0	34	33
2015	12	8	11	35	10	0.177	-0.098	0.902	0.033	0.03	0	37	36.1	77.4	120	117	0	34	33
2015	12	8	11	45	10	0.259	-0.049	0.902	0.033	0.03	0	36.5	37	77.4	119	119	0	34	33
2015	12	8	11	55	10	0.144	-0.085	0.902	0.039	0.036	0	36.5	36.5	77.8	119	118	0	34	33
2015	12	8	12	5	10	0.085	-0.03	0.902	0.033	0.03	0	37.4	37.4	77.4	121	120	0	34	33
2015	12	8	12	15	10	0.085	-0.023	0.902	0.033	0.03	0	39.1	38.3	77	124	122	0	33	33
2015	12	8	12	25	10	0.089	0.02	0.902	0.033	0.03	0	38.7	38.3	77	124	122	0	34	33
2015	12	8	12	35	10	0.062	-0.069	0.902	0.033	0.03	0	39.6	38.7	77.4	125	123	0	33	33
2015	12	8	12	45	10	0.174	-0.043	0.902	0.033	0.03	0	38.7	38.3	77.4	123	122	0	33	33
2015	12	8	12	55	10	0.203	-0.062	0.902	0.033	0.03	0	39.1	37.8	77.4	125	121	0	34	33
2015	12	8	13	5	10	0.164	0.01	0.902	0.033	0.03	0	38.7	39.6	77	124	125	0	34	33
2015	12	8	13	15	10	0.249	0.079	0.902	0.033	0.03	0	39.6	40	77.8	125	125	0	33	32
2015	12	8	13	25	10	0.157	-0.066	0.902	0.03	0.03	0	38.7	40.4	78.3	124	127	0	34	33
2015	12	8	13	35	10	0.203	0.003	0.902	0.036	0.033	0	40	40	77.4	127	127	0	34	34
2015	12	8	13	45	10	0.262	-0.036	0.902	0.033	0.03	0	39.6	40.4	77.4	126	127	0	34	33
2015	12	8	13	55	10	0.174	-0.059	0.902	0.033	0.03	0	39.6	39.6	77	126	125	0	34	33
2015	12	8	14	5	10	0.249	-0.072	0.902	0.033	0.03	0	39.6	40.4	77	125	126	0	33	32
2015	12	8	14	15	10	0.177	0.036	0.902	0.033	0.03	0	39.1	40.4	77.4	125	127	0	34	33
2015	12	8	14	25	10	0.246	0.036	0.902	0.033	0.033	0	38.7	40	77.8	124	125	0	34	32
2015	12	8	14	35	10	0.213	-0.059	0.902	0.033	0.03	0	39.6	38.7	77.8	125	123	0	33	33
2015	12	8	14	45	10	0.249	0.023	0.902	0.036	0.033	0	40.4	40.4	77	127	127	0	33	33
2015	12	8	14	55	10	0.282	0.033	0.902	0.039	0.039	0	40.4	40.4	77	128	127	0	34	33
2015	12	8	15	5	10	0.249	-0.013	0.902	0.033	0.03	0	40	40	77	126	125	0	33	32
2015	12	8	15	15	10	0.236	0.026	0.902	0.036	0.033	0	39.6	39.1	77.4	125	125	0	33	34
2015	12	8	15	25	10	0.282	0.003	0.902	0.033	0.03	0	37.8	37.8	77.8	121	121	0	33	33
2015	12	8	15	35	10	0.236	0.033	0.902	0.03	0.03	0	40.4	42.1	76.5	128	131	0	34	33
2015	12	8	15	45	10	0.217	0.075	0.902	0.039	0.036	0	42.1	42.1	76.1	132	131	0	34	33
2015	12	8	15	55	10	0.197	0.046	0.902	0.033	0.03	0	40.9	40.9	76.5	128	128	0	33	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	16	5	10	0.233	-0.016	0.902	0.036	0.033	0	40.4	40.4	77	127	126	0	33	32
2015	12	8	16	15	10	0.259	0.007	0.902	0.039	0.036	0	37.4	38.3	77.4	121	122	0	34	33
2015	12	8	16	25	10	0.233	0.007	0.902	0.033	0.03	0	37.4	37.4	78.3	120	120	0	33	33
2015	12	8	16	35	10	0.223	0.02	0.902	0.036	0.033	0	37.8	38.3	77.8	122	121	0	34	32
2015	12	8	16	45	10	0.223	-0.01	0.902	0.039	0.036	0	37.8	37.4	78.7	121	120	0	33	33
2015	12	8	16	55	10	0.164	-0.075	0.902	0.036	0.033	0	36.1	36.1	79.1	118	117	0	34	33
2015	12	8	17	5	10	0.161	-0.102	0.902	0.033	0.03	0	35.7	35.3	78.7	116	115	0	33	33
2015	12	8	17	15	10	0.112	-0.069	0.902	0.033	0.03	0	35.3	35.3	79.6	116	115	0	34	33
2015	12	8	17	25	10	0.154	-0.052	0.902	0.036	0.033	0	35.3	34.8	78.7	115	114	0	33	33
2015	12	8	17	35	10	0.2	-0.046	0.902	0.039	0.036	0	35.3	35.3	79.1	116	115	0	34	33
2015	12	8	17	45	10	0.18	-0.043	0.902	0.036	0.033	0	37	36.5	78.7	120	118	0	34	33
2015	12	8	17	55	10	0.223	-0.016	0.902	0.033	0.03	0	37.8	37.4	78.7	122	120	0	34	33
2015	12	8	18	5	10	0.19	0.03	0.902	0.036	0.033	0	38.3	38.7	77.8	122	122	0	33	32
2015	12	8	18	15	10	0.213	-0.052	0.902	0.033	0.03	0	37.4	37.8	78.7	121	121	0	34	33
2015	12	8	18	25	10	0.194	-0.066	0.902	0.039	0.036	0	37.8	37.8	77.8	122	121	0	34	33
2015	12	8	18	35	10	0.194	-0.023	0.902	0.039	0.036	0	36.5	37	78.7	119	119	0	34	33
2015	12	8	18	45	10	0.118	-0.007	0.902	0.036	0.033	0	36.5	36.5	78.7	118	117	0	33	32
2015	12	8	18	55	10	0.266	-0.039	0.902	0.036	0.033	0	36.5	36.5	78.7	118	118	0	33	33
2015	12	8	19	5	10	0.19	-0.092	0.902	0.033	0.03	0	36.1	36.1	78.3	118	117	0	34	33
2015	12	8	19	15	10	0.154	-0.003	0.902	0.033	0.03	0	36.1	36.1	78.7	118	116	0	34	32
2015	12	8	19	25	10	0.23	-0.095	0.902	0.039	0.036	0	35.7	35.3	78.3	117	115	0	34	33
2015	12	8	19	35	10	0.285	-0.033	0.902	0.039	0.039	0	36.5	35.7	79.1	118	116	0	33	33
2015	12	8	19	45	10	0.22	-0.036	0.902	0.036	0.033	0	36.5	36.5	78.7	118	117	0	33	32
2015	12	8	19	55	10	0.2	-0.059	0.902	0.033	0.03	0	36.1	36.5	78.7	117	118	0	33	33
2015	12	8	20	5	10	0.144	-0.01	0.902	0.033	0.03	0	36.1	36.1	78.3	117	117	0	33	33
2015	12	8	20	15	10	0.207	-0.046	0.902	0.039	0.036	0	36.1	36.1	77.8	118	117	0	34	33
2015	12	8	20	25	10	0.161	-0.072	0.902	0.043	0.043	0	36.1	36.1	77.8	118	117	0	34	33
2015	12	8	20	35	10	0.2	-0.049	0.902	0.036	0.033	0	36.5	36.1	77.8	118	117	0	33	33
2015	12	8	20	45	10	0.22	-0.118	0.902	0.033	0.03	0	36.5	37	77	119	119	0	34	33
2015	12	8	20	55	10	0.148	-0.095	0.902	0.03	0.03	0	37	37.4	77	119	120	0	33	33
2015	12	8	21	5	10	0.184	-0.039	0.902	0.039	0.036	0	36.5	36.5	78.3	118	118	0	33	33
2015	12	8	21	15	10	0.164	0.02	0.902	0.039	0.036	0	37	37.4	77.4	120	120	0	34	33
2015	12	8	21	25	10	0.194	-0.059	0.902	0.033	0.03	0	37	37.8	76.5	119	121	0	33	33
2015	12	8	21	35	10	0.236	-0.072	0.902	0.03	0.03	0	37	38.3	76.5	120	122	0	34	33
2015	12	8	21	45	10	0.23	0.013	0.902	0.03	0.03	0	36.5	37.4	77	119	120	0	34	33
2015	12	8	21	55	10	0.262	-0.049	0.902	0.039	0.036	0	37.4	38.3	76.1	120	122	0	33	33
2015	12	8	22	5	10	0.217	-0.072	0.902	0.033	0.03	0	37.8	38.3	76.5	122	122	0	34	33
2015	12	8	22	15	10	0.197	-0.059	0.902	0.039	0.036	0	37.8	38.3	76.5	122	122	0	34	33
2015	12	8	22	25	10	0.253	-0.108	0.902	0.033	0.03	0	37.4	38.7	77	121	122	0	34	32
2015	12	8	22	35	10	0.243	-0.03	0.902	0.033	0.03	0	38.3	38.3	77	122	122	0	33	33
2015	12	8	22	45	10	0.22	-0.056	0.902	0.033	0.03	0	37.4	38.7	76.1	120	123	0	33	33
2015	12	8	22	55	10	0.207	-0.02	0.902	0.033	0.03	0	38.3	39.6	75.7	122	124	0	33	32
2015	12	8	23	5	10	0.22	-0.016	0.902	0.033	0.03	0	38.3	38.3	76.5	123	122	0	34	33
2015	12	8	23	15	10	0.236	0.026	0.906	0.036	0.033	0	38.3	39.1	75.7	122	125	0	33	34
2015	12	8	23	25	10	0.167	-0.059	0.906	0.039	0.036	0	39.1	39.1	76.5	124	124	0	33	33
2015	12	8	23	35	10	0.223	-0.026	0.906	0.039	0.039	0	38.3	39.1	75.7	123	124	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	23	45	10	0.262	-0.056	0.906	0.033	0.03	0	39.1	39.6	75.3	125	125	0	34	33
2015	12	8	23	55	10	0.217	0	0.906	0.033	0.03	0	40	39.1	75.7	126	125	0	33	34
2015	12	9	0	5	10	0.226	-0.007	0.906	0.033	0.03	0	38.7	40.4	74.8	124	127	0	34	33
2015	12	9	0	15	10	0.246	-0.033	0.902	0.039	0.036	0	40	40.4	74.8	127	126	0	34	32
2015	12	9	0	25	10	0.213	-0.046	0.906	0.033	0.03	0	39.6	40	75.3	125	126	0	33	33
2015	12	9	0	35	10	0.203	-0.059	0.906	0.039	0.036	0	39.6	40	75.3	126	125	0	34	32
2015	12	9	0	45	10	0.246	-0.043	0.906	0.033	0.03	0	40	40	75.3	126	126	0	33	33
2015	12	9	0	55	10	0.187	-0.059	0.906	0.033	0.03	0	39.6	40	74.8	126	126	0	34	33
2015	12	9	1	5	10	0.279	-0.102	0.906	0.039	0.039	0	39.1	40	74.8	125	126	0	34	33
2015	12	9	1	15	10	0.187	-0.023	0.906	0.03	0.03	0	39.6	40	74	126	126	0	34	33
2015	12	9	1	25	10	0.256	-0.062	0.906	0.033	0.03	0	40.4	40	74.8	127	126	0	33	33
2015	12	9	1	35	10	0.285	-0.085	0.906	0.033	0.03	0	40.4	41.3	75.3	127	129	0	33	33
2015	12	9	1	45	10	0.22	-0.023	0.906	0.033	0.03	0	40	41.3	74.4	126	129	0	33	33
2015	12	9	1	55	10	0.217	-0.085	0.906	0.039	0.039	0	40	40.4	74.4	127	127	0	34	33
2015	12	9	2	5	10	0.23	-0.052	0.906	0.033	0.03	0	40	39.6	74.8	126	125	0	33	33
2015	12	9	2	15	10	0.2	-0.072	0.906	0.033	0.03	0	39.6	40.9	74	126	128	0	34	33
2015	12	9	2	25	10	0.217	-0.013	0.906	0.033	0.03	0	40	40.4	74	127	127	0	34	33
2015	12	9	2	35	10	0.184	-0.072	0.906	0.033	0.03	0	42.1	41.7	74.4	131	130	0	33	33
2015	12	9	2	45	10	0.24	-0.062	0.906	0.036	0.033	0	40.4	40.4	74.4	128	127	0	34	33
2015	12	9	2	55	10	0.2	-0.049	0.906	0.039	0.036	0	39.1	40.4	74	125	127	0	34	33
2015	12	9	3	5	10	0.233	-0.02	0.906	0.033	0.03	0	41.3	43	73.5	130	133	0	34	33
2015	12	9	3	15	10	0.243	-0.052	0.906	0.033	0.03	0	41.3	42.6	74	130	132	0	34	33
2015	12	9	3	25	10	0.236	-0.102	0.906	0.039	0.036	0	40	41.3	74.8	126	129	0	33	33
2015	12	9	3	35	10	0.197	-0.095	0.906	0.039	0.036	0	40	40.9	74	127	129	0	34	34
2015	12	9	3	45	10	0.23	-0.112	0.906	0.036	0.033	0	40	40.9	74.4	127	128	0	34	33
2015	12	9	3	55	10	0.299	-0.026	0.902	0.033	0.03	0	40	40.9	74.8	127	128	0	34	33
2015	12	9	4	5	10	0.184	-0.056	0.902	0.033	0.03	0	40.9	41.3	75.3	128	129	0	33	33
2015	12	9	4	15	10	0.243	-0.056	0.906	0.039	0.039	0	40	40.9	74.8	127	128	0	34	33
2015	12	9	4	25	10	0.19	-0.089	0.902	0.033	0.03	0	40.4	40.9	74	128	128	0	34	33
2015	12	9	4	35	10	0.177	-0.056	0.902	0.033	0.03	0	40	40.9	74	127	128	0	34	33
2015	12	9	4	45	10	0.2	-0.03	0.902	0.033	0.03	0	39.6	41.3	74.4	126	129	0	34	33
2015	12	9	4	55	10	0.259	-0.102	0.902	0.036	0.033	0	41.3	42.1	74	130	131	0	34	33
2015	12	9	5	5	10	0.223	-0.026	0.902	0.036	0.033	0	44.7	44.7	71.8	138	137	0	34	33
2015	12	9	5	15	10	0.24	-0.069	0.902	0.033	0.03	0	41.7	41.7	73.5	131	130	0	34	33
2015	12	9	5	25	10	0.226	-0.033	0.906	0.033	0.03	0	40.4	40.4	75.3	128	128	0	34	34
2015	12	9	5	35	10	0.233	-0.112	0.902	0.043	0.039	0	40.9	41.3	74.8	129	130	0	34	34
2015	12	9	5	45	10	0.167	-0.043	0.902	0.033	0.03	0	40.9	41.7	73.5	129	130	0	34	33
2015	12	9	5	55	10	0.262	-0.049	0.902	0.033	0.03	0	40.4	41.7	74.4	128	130	0	34	33
2015	12	9	6	5	10	0.18	0.03	0.906	0.036	0.033	0	43.9	43.4	72.7	136	134	0	34	33
2015	12	9	6	15	10	0.259	-0.089	0.902	0.036	0.033	0	40.4	41.3	74.4	128	130	0	34	34
2015	12	9	6	25	10	0.23	-0.085	0.902	0.03	0.03	0	40.9	41.3	74.8	128	129	0	33	33
2015	12	9	6	35	10	0.23	-0.085	0.902	0.039	0.036	0	40.4	41.3	74.4	128	129	0	34	33
2015	12	9	6	45	10	0.187	-0.052	0.906	0.033	0.03	0	40.9	40.9	74.4	128	128	0	33	33
2015	12	9	6	55	10	0.24	-0.052	0.902	0.033	0.03	0	40	40.4	74.4	127	127	0	34	33
2015	12	9	7	5	10	0.256	-0.052	0.902	0.033	0.03	0	38.7	39.6	75.7	124	125	0	34	33
2015	12	9	7	15	10	0.164	-0.026	0.902	0.036	0.033	0	37.8	37.4	76.1	121	121	0	33	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	7	25	10	0.197	-0.046	0.902	0.036	0.033	0	37.8	37.4	74.8	122	120	0	34	33
2015	12	9	7	35	10	0.217	-0.03	0.906	0.033	0.03	0	37	37.8	75.3	120	121	0	34	33
2015	12	9	7	45	10	0.22	-0.023	0.906	0.033	0.03	0	37.8	37.8	75.3	121	121	0	33	33
2015	12	9	7	55	10	0.19	-0.046	0.906	0.03	0.03	0	37	37.4	75.3	120	121	0	34	34
2015	12	9	8	5	10	0.213	-0.013	0.906	0.036	0.033	0	37	37.8	75.7	120	121	0	34	33
2015	12	9	8	15	10	0.197	-0.036	0.906	0.043	0.039	0	37	37.4	75.3	119	120	0	33	33
2015	12	9	8	25	10	0.213	-0.089	0.906	0.033	0.03	0	37.4	37	75.3	120	119	0	33	33
2015	12	9	8	35	10	0.144	-0.016	0.906	0.036	0.033	0	37.8	37.4	75.3	122	120	0	34	33
2015	12	9	8	45	10	0.22	-0.043	0.902	0.033	0.03	0	37.4	37.8	75.7	120	121	0	33	33
2015	12	9	8	55	10	0.23	-0.105	0.906	0.033	0.03	0	37	38.3	75.7	120	122	0	34	33
2015	12	9	9	5	10	0.207	-0.121	0.906	0.033	0.03	0	36.5	37	75.7	119	119	0	34	33
2015	12	9	9	15	10	0.144	-0.059	0.902	0.033	0.03	0	37	37.8	75.7	120	121	0	34	33
2015	12	9	9	25	10	0.22	-0.056	0.906	0.039	0.036	0	36.5	37	76.1	119	119	0	34	33
2015	12	9	9	35	10	0.207	-0.03	0.906	0.033	0.03	0	37	38.3	76.5	120	122	0	34	33
2015	12	9	9	45	10	0.157	0.007	0.906	0.033	0.03	0	37	37.4	76.1	120	120	0	34	33
2015	12	9	9	55	10	0.161	-0.059	0.906	0.03	0.026	0	37	38.3	76.1	119	122	0	33	33
2015	12	9	10	5	10	0.246	-0.079	0.906	0.033	0.03	0	37.4	37	76.1	120	119	0	33	33
2015	12	9	10	15	10	0.223	-0.046	0.906	0.033	0.03	0	37.4	37.4	75.7	121	120	0	34	33
2015	12	9	10	25	10	0.213	-0.085	0.906	0.036	0.033	0	37.4	37	76.1	121	120	0	34	34
2015	12	9	10	35	10	0.141	-0.059	0.906	0.033	0.03	0	37	37.8	75.7	120	121	0	34	33
2015	12	9	10	45	10	0.177	-0.023	0.906	0.033	0.03	0	37.4	37.4	75.3	121	120	0	34	33
2015	12	9	10	55	10	0.157	-0.039	0.906	0.033	0.03	0	37.8	37.8	76.1	121	120	0	33	32
2015	12	9	11	5	10	0.105	-0.079	0.906	0.033	0.033	0	37.8	38.7	76.1	122	123	0	34	33
2015	12	9	11	15	10	0.151	-0.023	0.906	0.033	0.03	0	38.7	39.6	76.5	124	124	0	34	32
2015	12	9	11	25	10	0.184	0.059	0.906	0.036	0.033	0	37.8	37.8	75.7	122	121	0	34	33
2015	12	9	11	35	10	0.115	0.007	0.906	0.033	0.03	0	38.7	38.7	76.1	123	123	0	33	33
2015	12	9	11	45	10	0.102	0	0.906	0.033	0.03	0	39.6	39.1	75.7	125	124	0	33	33
2015	12	9	11	55	10	0.121	-0.043	0.906	0.033	0.03	0	39.6	38.3	76.5	126	122	0	34	33
2015	12	9	12	5	10	0.223	-0.02	0.906	0.03	0.026	0	40	39.6	74.4	126	125	0	33	33
2015	12	9	12	15	10	0.19	-0.102	0.906	0.036	0.033	0	40	40	75.3	127	126	0	34	33
2015	12	9	12	25	10	0.2	-0.033	0.906	0.033	0.03	0	40	40.4	74.8	127	126	0	34	32
2015	12	9	12	35	10	0.2	-0.039	0.906	0.036	0.033	0	40.9	40.9	76.1	128	128	0	33	33
2015	12	9	12	45	10	0.21	-0.016	0.906	0.03	0.03	0	40.4	41.3	75.3	128	129	0	34	33
2015	12	9	12	55	10	0.279	0.056	0.906	0.033	0.03	0	42.6	42.1	74.8	132	130	0	33	32
2015	12	9	13	5	10	0.217	-0.046	0.906	0.033	0.03	0	41.7	41.7	75.7	130	130	0	33	33
2015	12	9	13	15	10	0.18	-0.016	0.906	0.033	0.03	0	42.6	42.6	74	132	132	0	33	33
2015	12	9	13	25	10	0.203	-0.043	0.906	0.033	0.03	0	42.6	43	74.4	133	133	0	34	33
2015	12	9	13	35	10	0.164	-0.046	0.906	0.033	0.03	0	41.7	43.4	74.4	131	134	0	34	33
2015	12	9	13	45	10	0.187	-0.02	0.906	0.036	0.033	0	41.7	43.9	74.8	131	134	0	34	32
2015	12	9	13	55	10	0.197	-0.016	0.906	0.03	0.026	0	42.1	43	74.8	132	134	0	34	34
2015	12	9	14	5	10	0.171	-0.003	0.906	0.033	0.03	0	43.9	43.9	75.3	135	134	0	33	32
2015	12	9	14	15	10	0.2	0.007	0.906	0.036	0.033	0	43	42.6	75.3	133	132	0	33	33
2015	12	9	14	25	10	0.217	0.016	0.906	0.033	0.03	0	43	43	75.7	133	133	0	33	33
2015	12	9	14	35	10	0.144	-0.026	0.906	0.036	0.033	0	43.4	43.4	75.7	135	133	0	34	32
2015	12	9	14	45	10	0.19	-0.098	0.906	0.036	0.033	0	44.3	43.4	74.4	135	133	0	32	32
2015	12	9	14	55	10	0.135	-0.016	0.906	0.033	0.03	0	41.7	42.6	75.7	131	132	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	15	5	10	0.177	-0.066	0.906	0.033	0.03	0	42.6	42.1	75.7	133	131	0	34	33
2015	12	9	15	15	10	0.177	-0.02	0.906	0.039	0.036	0	40.9	40.9	75.3	128	128	0	33	33
2015	12	9	15	25	10	0.197	-0.059	0.906	0.03	0.03	0	40.4	42.1	75.7	128	130	0	34	32
2015	12	9	15	35	10	0.174	-0.105	0.906	0.033	0.03	0	40	40.4	76.5	127	126	0	34	32
2015	12	9	15	45	10	0.18	0.013	0.906	0.039	0.036	0	37.4	37.4	76.5	120	120	0	33	33
2015	12	9	15	55	10	0.22	-0.085	0.906	0.036	0.033	0	37.4	36.1	77.8	121	117	0	34	33
2015	12	9	16	5	10	0.184	-0.03	0.906	0.033	0.03	0	37.4	36.1	77.8	119	117	0	32	33
2015	12	9	16	15	10	0.203	-0.121	0.906	0.033	0.03	0	35.7	36.5	77.4	117	117	0	34	32
2015	12	9	16	25	10	0.243	-0.046	0.906	0.036	0.033	0	38.3	37.4	77.8	122	120	0	33	33
2015	12	9	16	35	10	0.253	-0.125	0.906	0.043	0.043	0	37	37	77.4	120	119	0	34	33
2015	12	9	16	45	10	0.125	-0.007	0.906	0.043	0.039	0	35.7	35.7	78.3	117	116	0	34	33
2015	12	9	16	55	10	0.069	0.059	0.906	0.036	0.033	0	35.3	36.1	77.8	116	116	0	34	32
2015	12	9	17	5	10	0.072	0.049	0.906	0.036	0.033	0	35.7	35.3	78.3	116	115	0	33	33
2015	12	9	17	15	10	0.305	-0.128	0.906	0.039	0.036	0	35.3	35.7	78.3	116	115	0	34	32
2015	12	9	17	25	10	0.177	-0.046	0.906	0.033	0.03	0	36.1	34.8	78.3	117	114	0	33	33
2015	12	9	17	35	10	0.164	-0.026	0.906	0.033	0.03	0	36.1	36.1	78.3	117	116	0	33	32
2015	12	9	17	45	10	0.194	-0.03	0.906	0.033	0.03	0	36.1	36.1	77.4	117	116	0	33	32
2015	12	9	17	55	10	0.151	0	0.906	0.033	0.03	0	37	36.1	77.8	118	117	0	32	33
2015	12	9	18	5	10	0.24	0.056	0.906	0.036	0.033	0	36.5	36.5	77.8	118	117	0	33	32
2015	12	9	18	15	10	0.171	-0.003	0.906	0.033	0.03	0	36.5	36.1	77.4	118	117	0	33	33
2015	12	9	18	25	10	0.243	-0.007	0.909	0.043	0.039	0	35.7	36.1	77.4	117	117	0	34	33
2015	12	9	18	35	10	0.203	-0.079	0.909	0.033	0.03	0	37.4	36.1	77.4	120	117	0	33	33
2015	12	9	18	45	10	0.207	-0.066	0.906	0.036	0.033	0	36.1	35.7	77.8	117	115	0	33	32
2015	12	9	18	55	10	0.148	-0.023	0.906	0.033	0.03	0	35.7	36.1	77	117	116	0	34	32
2015	12	9	19	5	10	0.194	0.013	0.909	0.039	0.036	0	36.1	35.7	77.4	118	116	0	34	33
2015	12	9	19	15	10	0.262	-0.118	0.909	0.039	0.036	0	36.5	35.7	77.4	118	116	0	33	33
2015	12	9	19	25	10	0.144	-0.095	0.909	0.033	0.03	0	36.1	36.5	77.4	117	118	0	33	33
2015	12	9	19	35	10	0.194	-0.052	0.909	0.043	0.043	0	37	37	77.4	119	118	0	33	32
2015	12	9	19	45	10	0.236	-0.072	0.909	0.036	0.033	0	37	36.5	77	119	118	0	33	33
2015	12	9	19	55	10	0.23	-0.112	0.909	0.039	0.039	0	37.4	37.4	76.5	120	120	0	33	33
2015	12	9	20	5	10	0.226	-0.059	0.909	0.033	0.03	0	36.5	37	76.5	118	119	0	33	33
2015	12	9	20	15	10	0.207	-0.026	0.909	0.036	0.033	0	36.5	37.4	77	118	119	0	33	32
2015	12	9	20	25	10	0.154	-0.036	0.909	0.043	0.039	0	37.4	36.5	76.1	120	118	0	33	33
2015	12	9	20	35	10	0.22	-0.095	0.909	0.033	0.03	0	37.4	37.4	76.5	119	119	0	32	32
2015	12	9	20	45	10	0.194	0.007	0.909	0.036	0.033	0	37	37.8	75.7	119	120	0	33	32
2015	12	9	20	55	10	0.259	-0.059	0.909	0.036	0.033	0	37	37.8	76.1	119	121	0	33	33
2015	12	9	21	5	10	0.22	-0.056	0.909	0.033	0.03	0	37.4	37.4	75.7	120	120	0	33	33
2015	12	9	21	15	10	0.246	-0.043	0.909	0.036	0.033	0	36.5	37.8	75.7	119	120	0	34	32
2015	12	9	21	25	10	0.22	-0.003	0.909	0.033	0.03	0	37.4	37.8	75.7	120	120	0	33	32
2015	12	9	21	35	10	0.262	0.003	0.909	0.036	0.033	0	37	38.3	75.7	119	121	0	33	32
2015	12	9	21	45	10	0.249	0	0.909	0.033	0.03	0	37.4	38.3	75.3	121	122	0	34	33
2015	12	9	21	55	10	0.121	-0.046	0.909	0.036	0.033	0	38.3	38.7	75.7	122	123	0	33	33
2015	12	9	22	5	10	0.24	-0.052	0.909	0.036	0.033	0	38.3	38.7	75.3	122	123	0	33	33
2015	12	9	22	15	10	0.302	-0.056	0.909	0.03	0.03	0	38.7	39.1	75.7	124	124	0	34	33
2015	12	9	22	25	10	0.262	-0.098	0.909	0.039	0.036	0	38.3	39.6	74.8	123	125	0	34	33
2015	12	9	22	35	10	0.233	-0.052	0.909	0.039	0.036	0	38.7	39.6	74	124	126	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	22	45	10	0.233	-0.036	0.909	0.03	0.03	0	38.7	40	74	124	126	0	34	33
2015	12	9	22	55	10	0.233	0.007	0.909	0.033	0.03	0	39.1	40	74.4	124	126	0	33	33
2015	12	9	23	5	10	0.207	-0.138	0.909	0.033	0.03	0	40	40	74.8	126	126	0	33	33
2015	12	9	23	15	10	0.174	-0.016	0.909	0.033	0.03	0	38.7	40.4	74.8	124	127	0	34	33
2015	12	9	23	25	10	0.236	-0.016	0.909	0.033	0.03	0	40	40.9	74.4	127	127	0	34	32
2015	12	9	23	35	10	0.262	0	0.909	0.036	0.033	0	39.6	40.4	73.1	126	127	0	34	33
2015	12	9	23	45	10	0.21	0.007	0.909	0.033	0.033	0	40	40.9	74.4	127	127	0	34	32
2015	12	9	23	55	10	0.223	-0.03	0.909	0.03	0.03	0	40.4	41.3	73.5	128	128	0	34	32
2015	12	10	0	5	10	0.2	-0.092	0.909	0.03	0.026	0	40.4	40.4	73.5	127	127	0	33	33
2015	12	10	0	15	10	0.233	0.02	0.909	0.033	0.03	0	40	40.4	73.1	127	127	0	34	33
2015	12	10	0	25	10	0.213	-0.026	0.909	0.033	0.03	0	40.4	40.9	72.7	127	128	0	33	33
2015	12	10	0	35	10	0.174	-0.085	0.909	0.033	0.03	0	39.6	40.9	73.5	126	129	0	34	34
2015	12	10	0	45	10	0.22	-0.013	0.906	0.033	0.03	0	40.4	40.9	74	127	128	0	33	33
2015	12	10	0	55	10	0.23	-0.062	0.909	0.03	0.03	0	40.9	40.9	73.1	128	128	0	33	33
2015	12	10	1	5	10	0.197	-0.01	0.909	0.03	0.03	0	40	40.9	73.1	127	128	0	34	33
2015	12	10	1	15	10	0.18	-0.013	0.906	0.039	0.036	0	40.4	42.1	73.5	128	131	0	34	33
2015	12	10	1	25	10	0.279	-0.049	0.906	0.03	0.03	0	41.3	40.4	73.1	129	128	0	33	34
2015	12	10	1	35	10	0.266	0.01	0.909	0.033	0.03	0	40.4	41.7	73.1	128	130	0	34	33
2015	12	10	1	45	10	0.217	-0.01	0.909	0.033	0.03	0	40.4	41.7	73.5	128	130	0	34	33
2015	12	10	1	55	10	0.23	-0.026	0.909	0.033	0.03	0	39.6	42.1	73.1	126	131	0	34	33
2015	12	10	2	5	10	0.276	-0.098	0.906	0.033	0.033	0	41.3	42.1	74	130	131	0	34	33
2015	12	10	2	15	10	0.236	-0.043	0.906	0.033	0.03	0	41.3	41.7	72.7	129	130	0	33	33
2015	12	10	2	25	10	0.256	-0.046	0.906	0.033	0.03	0	41.7	42.1	73.5	130	131	0	33	33
2015	12	10	2	35	10	0.2	-0.033	0.906	0.036	0.033	0	40.9	41.7	72.7	129	130	0	34	33
2015	12	10	2	45	10	0.194	-0.013	0.906	0.033	0.03	0	40.4	42.1	72.7	128	131	0	34	33
2015	12	10	2	55	10	0.223	-0.062	0.906	0.033	0.03	0	42.1	43	71.8	132	134	0	34	34
2015	12	10	3	5	10	0.187	0	0.906	0.036	0.033	0	42.6	43	72.7	133	133	0	34	33
2015	12	10	3	15	10	0.259	0	0.906	0.036	0.033	0	41.3	41.7	72.7	130	130	0	34	33
2015	12	10	3	25	10	0.217	-0.095	0.906	0.039	0.039	0	41.3	43	72.2	130	133	0	34	33
2015	12	10	3	35	10	0.23	-0.056	0.906	0.03	0.03	0	40.4	41.7	72.7	128	130	0	34	33
2015	12	10	3	45	10	0.213	-0.013	0.906	0.033	0.03	0	42.1	42.6	71.8	131	132	0	33	33
2015	12	10	3	55	10	0.253	-0.066	0.906	0.033	0.03	0	41.3	42.1	72.7	129	131	0	33	33
2015	12	10	4	5	10	0.249	-0.052	0.906	0.03	0.03	0	41.7	42.6	72.7	131	132	0	34	33
2015	12	10	4	15	10	0.24	-0.01	0.906	0.033	0.03	0	40.9	42.6	72.2	129	132	0	34	33
2015	12	10	4	25	10	0.21	-0.039	0.906	0.03	0.03	0	41.7	42.1	74	131	131	0	34	33
2015	12	10	4	35	10	0.2	-0.043	0.906	0.033	0.03	0	41.3	42.1	72.7	129	131	0	33	33
2015	12	10	4	45	10	0.217	-0.039	0.906	0.033	0.033	0	40.9	41.7	72.7	129	130	0	34	33
2015	12	10	4	55	10	0.259	-0.072	0.906	0.036	0.033	0	40.4	42.6	73.5	128	132	0	34	33
2015	12	10	5	5	10	0.18	-0.036	0.906	0.033	0.03	0	41.7	41.7	72.7	130	130	0	33	33
2015	12	10	5	15	10	0.249	-0.059	0.906	0.033	0.03	0	41.3	42.6	73.1	130	132	0	34	33
2015	12	10	5	25	10	0.236	-0.059	0.906	0.033	0.03	0	40.9	43	72.7	129	133	0	34	33
2015	12	10	5	35	10	0.249	-0.059	0.906	0.039	0.036	0	42.1	42.6	73.1	131	131	0	33	32
2015	12	10	5	45	10	0.203	-0.056	0.906	0.033	0.033	0	40.9	42.1	72.7	129	131	0	34	33
2015	12	10	5	55	10	0.276	-0.056	0.909	0.033	0.03	0	41.3	42.1	72.7	129	131	0	33	33
2015	12	10	6	5	10	0.174	-0.085	0.906	0.033	0.03	0	41.7	42.1	72.7	131	132	0	34	34
2015	12	10	6	15	10	0.259	-0.03	0.906	0.03	0.03	0	41.7	42.1	73.1	130	132	0	33	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	6	25	10	0.2	-0.043	0.909	0.036	0.033	0	41.7	42.6	72.7	130	132	0	33	33
2015	12	10	6	35	10	0.223	-0.043	0.909	0.033	0.03	0	41.7	42.1	71.8	130	131	0	33	33
2015	12	10	6	45	10	0.259	-0.098	0.906	0.036	0.033	0	40.9	42.1	72.7	129	131	0	34	33
2015	12	10	6	55	10	0.256	-0.013	0.906	0.036	0.033	0	39.6	41.3	73.1	126	128	0	34	32
2015	12	10	7	5	10	0.203	-0.033	0.906	0.033	0.03	0	39.1	39.6	73.5	125	126	0	34	34
2015	12	10	7	15	10	0.22	-0.098	0.906	0.033	0.03	0	39.1	39.6	74	125	125	0	34	33
2015	12	10	7	25	10	0.24	-0.056	0.902	0.043	0.039	0	41.7	42.6	69.2	131	132	0	34	33
2015	12	10	7	35	10	0.259	-0.059	0.902	0.039	0.036	0	46	46.4	64.9	141	140	0	34	32
2015	12	10	7	45	10	0.246	-0.026	0.906	0.043	0.039	0	48.6	48.6	65.4	147	145	0	34	32
2015	12	10	7	55	10	0.197	-0.026	0.906	0.036	0.033	0	49	48.6	67.5	147	146	0	33	33
2015	12	10	8	5	10	0.246	-0.016	0.906	0.036	0.033	0	49.9	49.5	65.8	150	148	0	34	33
2015	12	10	8	15	10	0.259	-0.062	0.906	0.033	0.03	0	49	49	67.5	148	147	0	34	33
2015	12	10	8	25	10	0.259	-0.072	0.906	0.039	0.036	0	46.9	46.4	68.8	143	142	0	34	34
2015	12	10	8	35	10	0.236	-0.007	0.906	0.033	0.03	0	46	45.6	70.5	141	139	0	34	33
2015	12	10	8	45	10	0.233	-0.013	0.909	0.036	0.033	0	43.9	44.3	71.4	136	136	0	34	33
2015	12	10	8	55	10	0.203	-0.013	0.906	0.039	0.039	0	42.1	42.6	72.7	132	132	0	34	33
2015	12	10	9	5	10	0.217	-0.02	0.906	0.033	0.03	0	43.9	43.4	72.2	135	134	0	33	33
2015	12	10	9	15	10	0.276	0.01	0.906	0.036	0.033	0	44.7	44.7	70.1	139	137	0	35	33
2015	12	10	9	25	10	0.249	-0.046	0.906	0.033	0.03	0	45.2	44.7	71	138	137	0	33	33
2015	12	10	9	35	10	0.246	-0.007	0.906	0.046	0.043	0	45.6	45.2	71	139	138	0	33	33
2015	12	10	9	45	10	0.203	-0.066	0.909	0.036	0.033	0	44.7	44.3	71.4	137	137	0	33	34
2015	12	10	9	55	10	0.21	-0.013	0.906	0.049	0.046	0	43.4	43	72.7	134	134	0	33	34
2015	12	10	10	5	10	0.187	0.013	0.909	0.036	0.033	0	42.6	42.6	71.8	133	133	0	34	34
2015	12	10	10	15	10	0.259	-0.016	0.906	0.036	0.033	0	48.6	47.7	67.1	147	145	0	34	34
2015	12	10	10	25	10	0.256	-0.052	0.906	0.036	0.033	0	48.2	47.3	69.2	146	143	0	34	33
2015	12	10	10	35	10	0.325	0.013	0.906	0.043	0.039	0	47.7	46.9	70.1	145	142	0	34	33
2015	12	10	10	45	10	0.21	-0.033	0.906	0.043	0.039	0	48.6	48.2	69.2	147	144	0	34	32
2015	12	10	10	55	10	0.22	-0.036	0.906	0.036	0.033	0	46.4	46	70.5	141	140	0	33	33
2015	12	10	11	5	10	0.256	0.026	0.906	0.033	0.03	0	48.2	47.3	68.4	145	143	0	33	33
2015	12	10	11	15	10	0.233	0.023	0.906	0.039	0.036	0	48.2	47.7	69.2	145	143	0	33	32
2015	12	10	11	25	10	0.233	-0.062	0.906	0.036	0.033	0	46.9	46.4	71	142	141	0	33	33
2015	12	10	11	35	10	0.18	-0.02	0.906	0.039	0.036	0	47.3	46	71	143	140	0	33	33
2015	12	10	11	45	10	0.23	-0.062	0.906	0.039	0.036	0	45.6	45.2	70.5	139	138	0	33	33
2015	12	10	11	55	10	0.23	-0.062	0.906	0.043	0.043	0	47.7	46.4	69.7	144	141	0	33	33
2015	12	10	12	5	10	0.213	-0.003	0.906	0.036	0.033	0	48.2	47.7	68.8	146	144	0	34	33
2015	12	10	12	15	10	0.177	0	0.906	0.036	0.033	0	49.9	49	69.2	149	147	0	33	33
2015	12	10	12	25	10	0.23	-0.01	0.906	0.036	0.033	0	49.9	48.6	68.8	149	146	0	33	33
2015	12	10	12	35	10	0.22	0.007	0.906	0.033	0.03	0	48.6	48.6	68.4	146	145	0	33	32
2015	12	10	12	45	10	0.226	-0.059	0.906	0.033	0.03	0	46.9	46.4	70.1	142	141	0	33	33
2015	12	10	12	55	10	0.295	-0.03	0.906	0.036	0.033	0	47.3	48.2	66.2	144	145	0	34	33
2015	12	10	13	5	10	0.154	0.059	0.906	0.039	0.036	0	49	48.6	69.2	148	146	0	34	33
2015	12	10	13	15	10	0.217	-0.007	0.906	0.039	0.036	0	50.3	50.7	67.1	151	150	0	34	32
2015	12	10	13	25	10	0.226	0.03	0.906	0.039	0.039	0	50.3	49.9	67.9	151	149	0	34	33
2015	12	10	13	35	10	0.23	-0.01	0.906	0.039	0.036	0	48.2	48.6	68.4	145	145	0	33	32
2015	12	10	13	45	10	0.233	0.043	0.906	0.033	0.03	0	48.2	47.3	70.5	146	143	0	34	33
2015	12	10	13	55	10	0.246	0.095	0.906	0.036	0.033	0	47.7	48.2	71	145	145	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	14	5	10	0.262	-0.01	0.906	0.039	0.036	0	46.9	46.4	65.4	142	141	0	33	33
2015	12	10	14	15	10	0.24	-0.02	0.906	0.033	0.03	0	47.7	47.3	70.5	145	143	0	34	33
2015	12	10	14	25	10	0.243	0.03	0.906	0.033	0.03	0	47.3	46.9	71.4	143	142	0	33	33
2015	12	10	14	35	10	0.22	0.049	0.906	0.033	0.03	0	47.3	47.3	70.1	143	143	0	33	33
2015	12	10	14	45	10	0.253	-0.03	0.906	0.033	0.03	0	45.2	45.6	71.4	138	138	0	33	32
2015	12	10	14	55	10	0.213	0.059	0.906	0.039	0.036	0	44.7	44.7	67.9	137	136	0	33	32
2015	12	10	15	5	10	0.207	-0.052	0.906	0.033	0.03	0	43.4	44.3	70.5	135	135	0	34	32
2015	12	10	15	15	10	0.269	0.026	0.909	0.039	0.036	0	44.3	43.9	71	136	135	0	33	33
2015	12	10	15	25	10	0.253	0.049	0.909	0.036	0.033	0	43	43.4	73.1	133	133	0	33	32
2015	12	10	15	35	10	0.233	0.007	0.906	0.033	0.03	0	42.6	42.6	74.4	132	132	0	33	33
2015	12	10	15	45	10	0.256	0.046	0.909	0.033	0.03	0	42.1	41.7	73.5	131	130	0	33	33
2015	12	10	15	55	10	0.2	0.013	0.909	0.036	0.033	0	41.3	41.3	74.8	129	128	0	33	32
2015	12	10	16	5	10	0.246	0.072	0.909	0.036	0.033	0	41.3	41.3	74.8	129	128	0	33	32
2015	12	10	16	15	10	0.22	0.036	0.909	0.033	0.03	0	40	40.9	74	127	127	0	34	32
2015	12	10	16	25	10	0.217	0.016	0.909	0.039	0.036	0	40.4	40	74.4	127	126	0	33	33
2015	12	10	16	35	10	0.19	-0.016	0.909	0.033	0.03	0	40	40	74.4	126	125	0	33	32
2015	12	10	16	45	10	0.167	0.016	0.909	0.033	0.03	0	39.6	39.6	74.8	125	125	0	33	33
2015	12	10	16	55	10	0.213	-0.003	0.909	0.033	0.03	0	39.1	39.1	76.1	124	124	0	33	33
2015	12	10	17	5	10	0.243	-0.023	0.909	0.036	0.033	0	38.3	38.7	76.1	122	123	0	33	33
2015	12	10	17	15	10	0.266	0	0.909	0.033	0.03	0	38.3	38.7	75.3	122	122	0	33	32
2015	12	10	17	25	10	0.23	-0.026	0.909	0.036	0.033	0	38.7	39.1	73.1	124	123	0	34	32
2015	12	10	17	35	10	0.194	0.043	0.906	0.039	0.036	0	45.2	45.6	71.8	138	138	0	33	32
2015	12	10	17	45	10	0.253	-0.007	0.906	0.039	0.036	0	46.4	46.4	71	141	140	0	33	32
2015	12	10	17	55	10	0.266	0.072	0.906	0.036	0.033	0	48.6	49.5	67.5	147	147	0	34	32
2015	12	10	18	5	10	0.302	0.023	0.906	0.046	0.043	0	47.3	47.7	70.5	143	143	0	33	32
2015	12	10	18	15	10	0.223	-0.013	0.909	0.033	0.03	0	46.9	47.3	70.1	142	142	0	33	32
2015	12	10	18	25	10	0.305	0.079	0.909	0.033	0.03	0	46.9	46.4	71.4	142	141	0	33	33
2015	12	10	18	35	10	0.285	0.056	0.909	0.036	0.033	0	45.2	45.6	71.4	139	138	0	34	32
2015	12	10	18	45	10	0.22	-0.026	0.909	0.043	0.039	0	44.7	45.2	72.2	137	138	0	33	33
2015	12	10	18	55	10	0.243	0.049	0.909	0.039	0.036	0	46	45.6	71	140	138	0	33	32
2015	12	10	19	5	10	0.289	0.079	0.909	0.036	0.033	0	44.3	44.7	71.8	136	135	0	33	31
2015	12	10	19	15	10	0.203	0.02	0.909	0.043	0.039	0	43.4	43	73.1	134	133	0	33	33
2015	12	10	19	25	10	0.217	0.016	0.909	0.036	0.033	0	43.4	43.9	72.7	134	134	0	33	32
2015	12	10	19	35	10	0.282	0.039	0.909	0.033	0.03	0	42.6	43.4	73.5	133	133	0	34	32
2015	12	10	19	45	10	0.243	-0.013	0.909	0.033	0.03	0	42.6	43	73.5	133	133	0	34	33
2015	12	10	19	55	10	0.243	-0.016	0.909	0.036	0.033	0	43	43.4	72.7	133	134	0	33	33
2015	12	10	20	5	10	0.22	0.013	0.909	0.033	0.03	0	43.4	43.4	72.7	134	134	0	33	33
2015	12	10	20	15	10	0.285	0.059	0.909	0.039	0.036	0	43	43.4	73.1	133	133	0	33	32
2015	12	10	20	25	10	0.289	0.026	0.909	0.033	0.03	0	43	43	72.7	134	134	0	34	34
2015	12	10	20	35	10	0.164	-0.02	0.912	0.036	0.033	0	42.6	43.9	71.8	133	134	0	34	32
2015	12	10	20	45	10	0.226	0.016	0.909	0.03	0.03	0	43	43.9	72.2	134	134	0	34	32
2015	12	10	20	55	10	0.302	0.023	0.909	0.033	0.03	0	43	44.3	71.4	134	136	0	34	33
2015	12	10	21	5	10	0.22	0	0.909	0.039	0.039	0	43	44.3	72.2	133	136	0	33	33
2015	12	10	21	15	10	0.256	0	0.909	0.036	0.033	0	43.4	44.3	71.8	135	135	0	34	32
2015	12	10	21	25	10	0.272	-0.003	0.909	0.036	0.033	0	44.7	43.9	70.1	137	136	0	33	34
2015	12	10	21	35	10	0.259	-0.023	0.909	0.033	0.03	0	44.3	44.7	71	136	137	0	33	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	21	45	10	0.246	-0.003	0.909	0.036	0.033	0	44.3	46	68.4	137	139	0	34	32
2015	12	10	21	55	10	0.256	0.039	0.909	0.03	0.03	0	44.7	45.6	69.7	138	139	0	34	33
2015	12	10	22	5	10	0.262	0.036	0.909	0.033	0.03	0	46	46	68.8	140	140	0	33	33
2015	12	10	22	15	10	0.177	-0.046	0.909	0.033	0.03	0	45.6	45.6	71.4	139	139	0	33	33
2015	12	10	22	25	10	0.203	-0.069	0.909	0.036	0.033	0	44.7	46	67.9	138	139	0	34	32
2015	12	10	22	35	10	0.21	-0.039	0.909	0.036	0.033	0	45.6	46	70.5	140	140	0	34	33
2015	12	10	22	45	10	0.197	0.013	0.909	0.039	0.036	0	46	46.4	69.2	140	141	0	33	33
2015	12	10	22	55	10	0.164	0.013	0.909	0.033	0.03	0	46	47.3	67.9	141	142	0	34	32
2015	12	10	23	5	10	0.236	0.02	0.909	0.033	0.03	0	46	46.9	70.5	141	141	0	34	32
2015	12	10	23	15	10	0.2	-0.092	0.909	0.033	0.03	0	46.4	46.9	71	141	142	0	33	33
2015	12	10	23	25	10	0.24	0	0.909	0.033	0.03	0	45.6	46.4	70.1	140	141	0	34	33
2015	12	10	23	35	10	0.236	-0.023	0.909	0.043	0.043	0	46	46.4	71	140	141	0	33	33
2015	12	10	23	45	10	0.194	0.023	0.909	0.036	0.033	0	46.4	46	70.5	141	140	0	33	33
2015	12	10	23	55	10	0.262	0.033	0.909	0.033	0.03	0	45.6	46.4	71.4	139	141	0	33	33
2015	12	11	0	5	10	0.233	0.01	0.909	0.036	0.033	0	45.6	46	71.8	140	140	0	34	33
2015	12	11	0	15	10	0.246	0	0.909	0.036	0.033	0	45.6	46	71.4	139	140	0	33	33
2015	12	11	0	25	10	0.207	0.03	0.909	0.033	0.03	0	44.7	46	71.4	138	140	0	34	33
2015	12	11	0	35	10	0.19	0.026	0.909	0.03	0.03	0	44.7	46	71.8	137	140	0	33	33
2015	12	11	0	45	10	0.302	0.039	0.909	0.033	0.03	0	44.3	45.6	71	137	139	0	34	33
2015	12	11	0	55	10	0.243	-0.039	0.909	0.033	0.033	0	44.7	45.6	71.4	138	139	0	34	33
2015	12	11	1	5	10	0.233	0	0.909	0.033	0.03	0	46	46	70.5	140	140	0	33	33
2015	12	11	1	15	10	0.24	0.02	0.909	0.033	0.03	0	45.6	45.2	71	140	138	0	34	33
2015	12	11	1	25	10	0.23	0.03	0.909	0.033	0.033	0	45.2	46	71	138	139	0	33	32
2015	12	11	1	35	10	0.2	-0.013	0.909	0.033	0.033	0	45.2	46	71.8	139	140	0	34	33
2015	12	11	1	45	10	0.269	0.013	0.909	0.036	0.033	0	45.6	45.6	71.4	139	139	0	33	33
2015	12	11	1	55	10	0.22	-0.03	0.909	0.033	0.03	0	45.6	45.2	71	140	138	0	34	33
2015	12	11	2	5	10	0.177	-0.023	0.909	0.033	0.03	0	44.7	46.4	71.8	138	141	0	34	33
2015	12	11	2	15	10	0.24	-0.016	0.909	0.033	0.03	0	45.2	45.6	71.4	139	138	0	34	32
2015	12	11	2	25	10	0.233	-0.039	0.909	0.033	0.03	0	45.2	46	71.4	139	140	0	34	33
2015	12	11	2	35	10	0.233	0	0.909	0.036	0.033	0	44.7	45.6	71.8	138	139	0	34	33
2015	12	11	2	45	10	0.161	-0.023	0.906	0.039	0.036	0	44.7	46.4	71.8	138	141	0	34	33
2015	12	11	2	55	10	0.22	-0.02	0.909	0.033	0.03	0	46	46	71	140	140	0	33	33
2015	12	11	3	5	10	0.19	0.02	0.909	0.033	0.03	0	45.2	45.6	71.4	138	139	0	33	33
2015	12	11	3	15	10	0.276	-0.056	0.906	0.036	0.033	0	45.2	46	71.8	139	140	0	34	33
2015	12	11	3	25	10	0.282	-0.016	0.909	0.033	0.03	0	45.6	46.4	71.4	139	141	0	33	33
2015	12	11	3	35	10	0.246	-0.016	0.909	0.033	0.03	0	45.6	46.4	70.5	139	140	0	33	32
2015	12	11	3	45	10	0.207	0	0.909	0.033	0.03	0	44.7	46.4	71.4	138	140	0	34	32
2015	12	11	3	55	10	0.223	-0.036	0.906	0.033	0.03	0	45.6	46.4	71.4	140	140	0	34	32
2015	12	11	4	5	10	0.138	-0.02	0.909	0.033	0.03	0	44.3	46	71	137	140	0	34	33
2015	12	11	4	15	10	0.279	-0.049	0.909	0.033	0.03	0	45.2	46	71.8	139	140	0	34	33
2015	12	11	4	25	10	0.213	0.046	0.909	0.033	0.03	0	44.7	45.6	71.4	138	139	0	34	33
2015	12	11	4	35	10	0.243	-0.049	0.909	0.033	0.03	0	45.6	45.6	71.4	140	139	0	34	33
2015	12	11	4	45	10	0.322	-0.036	0.909	0.033	0.03	0	45.2	46.4	71.4	139	140	0	34	32
2015	12	11	4	55	10	0.2	-0.023	0.906	0.033	0.03	0	45.6	46	71.4	140	140	0	34	33
2015	12	11	5	5	10	0.233	-0.095	0.906	0.033	0.03	0	45.6	46.4	71	140	141	0	34	33
2015	12	11	5	15	10	0.2	-0.016	0.906	0.033	0.03	0	45.6	46.4	71	140	141	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	5	25	10	0.21	-0.03	0.906	0.033	0.03	0	45.6	46.4	71	140	141	0	34	33
2015	12	11	5	35	10	0.194	-0.023	0.906	0.033	0.03	0	45.2	46.4	70.5	139	141	0	34	33
2015	12	11	5	45	10	0.157	0	0.906	0.033	0.03	0	45.6	46.4	70.5	139	140	0	33	32
2015	12	11	5	55	10	0.194	0.007	0.906	0.033	0.03	0	45.6	46.4	71	139	140	0	33	32
2015	12	11	6	5	10	0.197	-0.02	0.906	0.033	0.03	0	45.2	46	71.4	139	140	0	34	33
2015	12	11	6	15	10	0.184	0	0.906	0.033	0.03	0	45.2	46.4	71	139	141	0	34	33
2015	12	11	6	25	10	0.217	-0.075	0.906	0.033	0.03	0	45.6	46	71	140	141	0	34	34
2015	12	11	6	35	10	0.282	0.01	0.906	0.033	0.03	0	45.6	46.4	71	139	141	0	33	33
2015	12	11	6	45	10	0.22	-0.049	0.906	0.039	0.036	0	45.2	46.4	70.5	139	141	0	34	33
2015	12	11	6	55	10	0.295	-0.033	0.906	0.039	0.036	0	45.6	46	71.4	139	140	0	33	33
2015	12	11	7	5	10	0.154	0	0.906	0.036	0.033	0	44.7	45.6	71.8	137	139	0	33	33
2015	12	11	7	15	10	0.285	-0.075	0.906	0.036	0.033	0	43.4	44.7	72.2	135	137	0	34	33
2015	12	11	7	25	10	0.233	-0.089	0.906	0.033	0.03	0	43.4	43.4	73.5	133	133	0	32	32
2015	12	11	7	35	10	0.226	-0.039	0.906	0.033	0.03	0	42.1	43.4	74	132	133	0	34	32
2015	12	11	7	45	10	0.164	-0.059	0.906	0.033	0.03	0	43	42.6	73.5	133	133	0	33	34
2015	12	11	7	55	10	0.18	-0.043	0.906	0.033	0.03	0	40.9	43.4	73.5	129	134	0	34	33
2015	12	11	8	5	10	0.256	-0.046	0.906	0.033	0.03	0	43	42.6	74	133	133	0	33	34
2015	12	11	8	15	10	0.213	-0.062	0.906	0.033	0.03	0	43	43	74	134	133	0	34	33
2015	12	11	8	25	10	0.197	-0.046	0.906	0.033	0.03	0	43.9	42.6	74.4	135	132	0	33	33
2015	12	11	8	35	10	0.148	-0.016	0.906	0.033	0.03	0	42.1	42.6	74	132	133	0	34	34
2015	12	11	8	45	10	0.2	-0.033	0.906	0.03	0.03	0	41.7	43	74.8	131	133	0	34	33
2015	12	11	8	55	10	0.164	-0.072	0.906	0.033	0.03	0	41.7	43	74.4	131	133	0	34	33
2015	12	11	9	5	10	0.233	-0.023	0.906	0.036	0.033	0	42.1	42.1	75.3	132	131	0	34	33
2015	12	11	9	15	10	0.171	-0.069	0.906	0.033	0.03	0	42.6	43	73.5	133	132	0	34	32
2015	12	11	9	25	10	0.138	-0.089	0.906	0.033	0.03	0	42.1	42.1	74	132	131	0	34	33
2015	12	11	9	35	10	0.128	-0.062	0.906	0.033	0.03	0	41.7	41.3	74	131	129	0	34	33
2015	12	11	9	45	10	0.2	-0.03	0.906	0.033	0.03	0	41.3	41.7	74.4	129	130	0	33	33
2015	12	11	9	55	10	0.194	-0.007	0.906	0.033	0.03	0	41.7	43	74.4	131	133	0	34	33
2015	12	11	10	5	10	0.246	0.013	0.906	0.03	0.026	0	42.1	41.7	75.3	132	131	0	34	34
2015	12	11	10	15	10	0.19	-0.049	0.906	0.03	0.03	0	41.7	41.7	74	130	131	0	33	34
2015	12	11	10	25	10	0.203	-0.102	0.906	0.033	0.03	0	42.1	42.1	74.8	131	130	0	33	32
2015	12	11	10	35	10	0.197	-0.085	0.906	0.033	0.03	0	41.7	42.6	74.8	130	132	0	33	33
2015	12	11	10	45	10	0.174	-0.072	0.906	0.03	0.026	0	43.4	44.3	75.3	134	135	0	33	32
2015	12	11	10	55	10	0.19	0.003	0.906	0.03	0.03	0	43.9	43.9	75.3	136	135	0	34	33
2015	12	11	11	5	10	0.171	-0.026	0.906	0.033	0.03	0	45.6	44.7	74.4	139	137	0	33	33
2015	12	11	11	15	10	0.223	-0.026	0.906	0.036	0.033	0	44.7	44.3	74.4	138	136	0	34	33
2015	12	11	11	25	10	0.19	0.049	0.906	0.033	0.03	0	44.3	44.7	73.5	137	137	0	34	33
2015	12	11	11	35	10	0.194	-0.016	0.906	0.03	0.03	0	43	44.3	75.3	134	136	0	34	33
2015	12	11	11	45	10	0.207	-0.007	0.906	0.033	0.03	0	43.4	44.3	74	134	136	0	33	33
2015	12	11	11	55	10	0.249	-0.016	0.906	0.033	0.03	0	43.4	43	75.3	134	133	0	33	33
2015	12	11	12	5	10	0.269	-0.118	0.906	0.033	0.03	0	43.4	43.9	74.4	135	135	0	34	33
2015	12	11	12	15	10	0.144	-0.03	0.906	0.036	0.033	0	41.7	42.1	75.7	131	131	0	34	33
2015	12	11	12	25	10	0.131	-0.036	0.906	0.03	0.03	0	43.4	44.3	74.8	134	135	0	33	32
2015	12	11	12	35	10	0.207	-0.056	0.906	0.03	0.03	0	43	44.3	74	134	136	0	34	33
2015	12	11	12	45	10	0.131	-0.092	0.906	0.036	0.033	0	43.9	45.2	74	135	138	0	33	33
2015	12	11	12	55	10	0.24	-0.02	0.906	0.039	0.036	0	43.9	44.7	74	136	137	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	13	5	10	0.223	-0.016	0.906	0.03	0.03	0	44.3	43.9	74.4	136	135	0	33	33
2015	12	11	13	15	10	0.177	-0.089	0.906	0.033	0.03	0	42.6	44.3	74	132	136	0	33	33
2015	12	11	13	25	10	0.24	0.01	0.899	0.039	0.036	0	58.5	56.8	49.9	169	165	0	33	33
2015	12	11	13	35	10	0.22	-0.003	0.902	0.039	0.036	0	54.6	54.2	60.2	160	158	0	33	32
2015	12	11	13	45	10	0.2	0	0.902	0.036	0.033	0	52.5	52.5	62.4	156	154	0	34	32
2015	12	11	13	55	10	0.295	-0.003	0.902	0.036	0.033	0	51.2	51.2	62.8	153	152	0	34	33
2015	12	11	14	5	10	0.194	-0.023	0.902	0.033	0.03	0	52	51.2	65.4	153	151	0	32	32
2015	12	11	14	15	10	0.22	-0.016	0.902	0.039	0.036	0	52.5	51.6	63.2	156	153	0	34	33
2015	12	11	14	25	10	0.243	-0.072	0.902	0.036	0.033	0	52.5	51.6	62.8	155	153	0	33	33
2015	12	11	14	35	10	0.151	0.059	0.902	0.03	0.03	0	52	51.6	66.7	154	153	0	33	33
2015	12	11	14	45	10	0.269	0.013	0.902	0.036	0.033	0	50.7	50.7	67.5	152	151	0	34	33
2015	12	11	14	55	10	0.19	0.039	0.902	0.033	0.03	0	50.3	51.2	68.4	151	151	0	34	32
2015	12	11	15	5	10	0.148	0.016	0.902	0.033	0.03	0	51.2	49.9	67.5	152	149	0	33	33
2015	12	11	15	15	10	0.226	0.03	0.902	0.036	0.033	0	50.3	49.9	66.2	150	149	0	33	33
2015	12	11	15	25	10	0.279	0.036	0.902	0.033	0.03	0	48.2	49.5	70.5	145	147	0	33	32
2015	12	11	15	35	10	0.233	0.03	0.902	0.033	0.03	0	47.3	47.7	67.5	144	143	0	34	32
2015	12	11	15	45	10	0.197	0.03	0.902	0.036	0.033	0	46.4	45.6	68.4	141	139	0	33	33
2015	12	11	15	55	10	0.213	0.079	0.899	0.039	0.039	0	45.2	44.3	67.5	138	136	0	33	33
2015	12	11	16	5	10	0.233	0.066	0.902	0.033	0.03	0	43.9	44.7	71.4	136	137	0	34	33
2015	12	11	16	15	10	0.243	0	0.902	0.033	0.03	0	44.3	44.3	72.2	136	135	0	33	32
2015	12	11	16	25	10	0.217	0.049	0.902	0.039	0.036	0	43.4	43	69.2	135	133	0	34	33
2015	12	11	16	35	10	0.21	0.148	0.899	0.039	0.036	0	43.9	43.4	72.2	135	133	0	33	32
2015	12	11	16	45	10	0.177	0.056	0.902	0.033	0.03	0	43	43.4	72.2	133	134	0	33	33
2015	12	11	16	55	10	0.177	0.121	0.902	0.03	0.03	0	41.7	43	74	131	132	0	34	32
2015	12	11	17	5	10	0.226	0	0.899	0.033	0.03	0	41.7	42.1	73.5	130	130	0	33	32
2015	12	11	17	15	10	0.223	0.072	0.902	0.039	0.039	0	41.3	40	73.5	130	127	0	34	34
2015	12	11	17	25	10	0.174	0.049	0.899	0.036	0.033	0	41.3	41.3	72.7	129	129	0	33	33
2015	12	11	17	35	10	0.135	0.066	0.902	0.033	0.03	0	41.3	41.7	75.3	129	129	0	33	32
2015	12	11	17	45	10	0.276	0.016	0.902	0.033	0.03	0	41.3	42.1	75.7	130	131	0	34	33
2015	12	11	17	55	10	0.236	0	0.902	0.033	0.03	0	41.3	42.1	75.7	130	130	0	34	32
2015	12	11	18	5	10	0.207	-0.01	0.899	0.033	0.03	0	41.7	41.3	74.4	130	129	0	33	33
2015	12	11	18	15	10	0.207	0.026	0.902	0.033	0.03	0	41.3	41.3	74.8	129	128	0	33	32
2015	12	11	18	25	10	0.161	-0.046	0.899	0.033	0.033	0	40.4	40.4	75.3	127	126	0	33	32
2015	12	11	18	35	10	0.171	-0.016	0.902	0.033	0.03	0	39.6	39.1	76.1	126	124	0	34	33
2015	12	11	18	45	10	0.148	-0.03	0.902	0.033	0.03	0	40	39.6	75.7	126	125	0	33	33
2015	12	11	18	55	10	0.062	-0.043	0.902	0.039	0.036	0	39.6	38.3	77.8	126	121	0	34	32
2015	12	11	19	5	10	0.144	-0.171	0.902	0.036	0.033	0	39.1	39.1	78.3	124	123	0	33	32
2015	12	11	19	15	10	0.177	-0.118	0.902	0.039	0.036	0	38.7	39.1	77.4	124	124	0	34	33
2015	12	11	19	25	10	0.148	-0.194	0.902	0.033	0.03	0	39.6	39.1	77.8	125	123	0	33	32
2015	12	11	19	35	10	0.072	-0.18	0.902	0.033	0.03	0	38.7	39.1	77.8	123	123	0	33	32
2015	12	11	19	45	10	0.082	-0.098	0.902	0.033	0.03	0	39.1	38.7	78.3	124	123	0	33	33
2015	12	11	19	55	10	0.131	-0.19	0.902	0.033	0.03	0	39.1	39.1	77.8	124	124	0	33	33
2015	12	11	20	5	10	0.052	-0.085	0.902	0.033	0.03	0	38.7	38.3	77.4	123	122	0	33	33
2015	12	11	20	15	10	0.102	-0.089	0.902	0.033	0.03	0	38.7	39.1	76.1	123	123	0	33	32
2015	12	11	20	25	10	0.118	-0.03	0.902	0.033	0.03	0	37.8	38.7	74.8	122	123	0	34	33
2015	12	11	20	35	10	0.082	-0.056	0.902	0.033	0.03	0	38.7	39.6	77	123	125	0	33	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	20	45	10	0.22	-0.089	0.902	0.039	0.036	0	39.1	39.6	77.8	124	124	0	33	32
2015	12	11	20	55	10	0.207	-0.003	0.902	0.036	0.033	0	40	40.9	76.5	127	127	0	34	32
2015	12	11	21	5	10	0.19	-0.016	0.899	0.033	0.03	0	38.7	40	77.4	123	125	0	33	32
2015	12	11	21	15	10	0.102	-0.023	0.899	0.033	0.03	0	39.1	39.6	77	124	125	0	33	33
2015	12	11	21	25	10	0.203	-0.043	0.899	0.03	0.026	0	38.7	40.4	77.4	124	126	0	34	32
2015	12	11	21	35	10	0.157	-0.056	0.899	0.03	0.03	0	38.7	40.9	77.4	123	128	0	33	33
2015	12	11	21	45	10	0.161	-0.079	0.899	0.03	0.03	0	43	42.1	75.3	133	131	0	33	33
2015	12	11	21	55	10	0.144	-0.056	0.899	0.033	0.033	0	40	41.3	76.5	127	129	0	34	33
2015	12	11	22	5	10	0.203	-0.026	0.899	0.033	0.03	0	40.4	40.9	77	127	128	0	33	33
2015	12	11	22	15	10	0.253	-0.082	0.899	0.033	0.03	0	39.6	41.3	77	126	128	0	34	32
2015	12	11	22	25	10	0.167	-0.016	0.899	0.033	0.03	0	40.9	40.9	76.1	129	128	0	34	33
2015	12	11	22	35	10	0.144	-0.046	0.899	0.036	0.033	0	39.6	41.7	76.5	126	130	0	34	33
2015	12	11	22	45	10	0.203	-0.059	0.899	0.033	0.03	0	40.4	41.7	76.5	128	129	0	34	32
2015	12	11	22	55	10	0.157	-0.046	0.899	0.033	0.03	0	40.9	41.3	75.3	128	130	0	33	34
2015	12	11	23	5	10	0.187	-0.02	0.899	0.033	0.03	0	40.9	42.1	75.7	129	132	0	34	34
2015	12	11	23	15	10	0.246	-0.069	0.899	0.033	0.03	0	40.9	41.3	75.3	129	130	0	34	34
2015	12	11	23	25	10	0.276	-0.026	0.899	0.043	0.043	0	41.3	43	75.7	129	133	0	33	33
2015	12	11	23	35	10	0.194	-0.039	0.899	0.036	0.033	0	41.3	42.1	76.1	130	131	0	34	33
2015	12	11	23	45	10	0.22	-0.059	0.899	0.036	0.033	0	40.9	42.1	75.3	129	131	0	34	33
2015	12	11	23	55	10	0.2	-0.092	0.899	0.036	0.033	0	41.7	42.6	75.3	131	132	0	34	33
2015	12	12	0	5	10	0.138	-0.01	0.899	0.03	0.03	0	41.3	43	76.1	130	133	0	34	33
2015	12	12	0	15	10	0.194	0	0.899	0.036	0.033	0	41.7	43	76.1	131	133	0	34	33
2015	12	12	0	25	10	0.2	0	0.899	0.033	0.03	0	43	42.6	75.3	134	133	0	34	34
2015	12	12	0	35	10	0.19	-0.02	0.899	0.033	0.03	0	41.7	43	75.3	130	133	0	33	33
2015	12	12	0	45	10	0.164	-0.03	0.899	0.033	0.03	0	42.6	43	75.3	132	133	0	33	33
2015	12	12	0	55	10	0.174	-0.02	0.899	0.033	0.03	0	42.6	43	74.8	133	133	0	34	33
2015	12	12	1	5	10	0.197	-0.059	0.899	0.033	0.03	0	41.7	44.3	75.3	131	135	0	34	32
2015	12	12	1	15	10	0.23	-0.072	0.899	0.033	0.03	0	42.1	43	73.1	132	134	0	34	34
2015	12	12	1	25	10	0.24	-0.062	0.899	0.036	0.033	0	42.6	43	72.7	133	134	0	34	34
2015	12	12	1	35	10	0.262	-0.066	0.896	0.033	0.03	0	42.6	43.4	74.4	133	134	0	34	33
2015	12	12	1	45	10	0.23	-0.039	0.899	0.033	0.03	0	43.9	44.3	74.8	136	136	0	34	33
2015	12	12	1	55	10	0.174	0.01	0.896	0.033	0.03	0	42.6	44.3	74	133	136	0	34	33
2015	12	12	2	5	10	0.141	-0.052	0.896	0.033	0.03	0	43.4	44.3	74.8	135	135	0	34	32
2015	12	12	2	15	10	0.22	0.007	0.896	0.033	0.03	0	43	44.3	74.4	133	136	0	33	33
2015	12	12	2	25	10	0.226	-0.003	0.896	0.033	0.03	0	42.6	44.3	74	133	136	0	34	33
2015	12	12	2	35	10	0.226	-0.013	0.896	0.039	0.036	0	43	44.3	74.4	134	136	0	34	33
2015	12	12	2	45	10	0.213	-0.007	0.896	0.033	0.03	0	42.1	44.3	74	132	136	0	34	33
2015	12	12	2	55	10	0.177	-0.03	0.896	0.03	0.03	0	43	44.3	75.3	134	136	0	34	33
2015	12	12	3	5	10	0.22	-0.102	0.896	0.033	0.03	0	43.4	43.4	74.8	134	135	0	33	34
2015	12	12	3	15	10	0.23	-0.059	0.896	0.033	0.03	0	43.9	44.7	74.4	136	137	0	34	33
2015	12	12	3	25	10	0.253	-0.043	0.896	0.033	0.03	0	50.7	49.9	68.4	152	150	0	34	34
2015	12	12	3	35	10	0.24	0.02	0.896	0.039	0.036	0	47.7	47.7	71.8	145	144	0	34	33
2015	12	12	3	45	10	0.184	-0.023	0.896	0.039	0.036	0	46	46	73.1	141	140	0	34	33
2015	12	12	3	55	10	0.174	-0.03	0.896	0.033	0.03	0	47.3	48.2	71.4	144	145	0	34	33
2015	12	12	4	5	10	0.213	-0.03	0.896	0.033	0.03	0	45.6	46.4	72.2	140	141	0	34	33
2015	12	12	4	15	10	0.226	-0.013	0.896	0.036	0.033	0	46	46.4	73.1	141	141	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	4	25	10	0.171	-0.033	0.896	0.033	0.03	0	45.6	46.4	72.7	140	141	0	34	33
2015	12	12	4	35	10	0.269	-0.013	0.896	0.036	0.033	0	52	51.2	67.9	155	152	0	34	33
2015	12	12	4	45	10	0.226	0.089	0.896	0.033	0.03	0	48.6	48.6	70.1	147	146	0	34	33
2015	12	12	4	55	10	0.157	0	0.896	0.033	0.03	0	46.9	47.3	72.2	143	143	0	34	33
2015	12	12	5	5	10	0.269	-0.039	0.896	0.046	0.043	0	48.6	48.2	70.1	147	146	0	34	34
2015	12	12	5	15	10	0.226	-0.043	0.896	0.033	0.03	0	48.6	47.3	69.7	146	144	0	33	34
2015	12	12	5	25	10	0.213	0.043	0.896	0.039	0.036	0	46	46.4	71.4	141	141	0	34	33
2015	12	12	5	35	10	0.266	-0.026	0.896	0.033	0.03	0	45.2	45.2	73.1	139	138	0	34	33
2015	12	12	5	45	10	0.246	0.016	0.896	0.033	0.03	0	43.4	44.3	74	135	137	0	34	34
2015	12	12	5	55	10	0.269	-0.023	0.896	0.033	0.03	0	44.3	44.3	73.5	136	136	0	33	33
2015	12	12	6	5	10	0.262	-0.033	0.896	0.033	0.03	0	43	43.9	74.4	134	135	0	34	33
2015	12	12	6	15	10	0.217	0.02	0.896	0.033	0.03	0	43	44.3	73.5	135	136	0	35	33
2015	12	12	6	25	10	0.154	0.007	0.896	0.033	0.03	0	43.9	44.7	74.8	135	136	0	33	32
2015	12	12	6	35	10	0.164	-0.036	0.896	0.033	0.03	0	43	43.9	74.4	134	135	0	34	33
2015	12	12	6	45	10	0.233	-0.056	0.896	0.033	0.03	0	42.1	43.9	74	132	136	0	34	34
2015	12	12	6	55	10	0.167	-0.026	0.896	0.036	0.033	0	42.6	42.6	73.1	133	132	0	34	33
2015	12	12	7	5	10	0.21	-0.043	0.896	0.033	0.03	0	40.4	42.1	74	129	131	0	35	33
2015	12	12	7	15	10	0.194	-0.013	0.896	0.033	0.03	0	40.9	41.7	74	129	130	0	34	33
2015	12	12	7	25	10	0.233	-0.085	0.896	0.033	0.03	0	40.9	40.4	74.8	128	127	0	33	33
2015	12	12	7	35	10	0.148	-0.03	0.896	0.036	0.033	0	40.9	40.9	74.8	128	129	0	33	34
2015	12	12	7	45	10	0.184	-0.105	0.896	0.033	0.03	0	40	41.3	75.3	127	129	0	34	33
2015	12	12	7	55	10	0.187	-0.033	0.896	0.033	0.03	0	40.4	40.4	74.8	128	128	0	34	34
2015	12	12	8	5	10	0.177	-0.092	0.896	0.036	0.033	0	40	41.7	77	127	130	0	34	33
2015	12	12	8	15	10	0.2	0.026	0.896	0.033	0.03	0	39.6	40	73.5	126	127	0	34	34
2015	12	12	8	25	10	0.197	-0.079	0.896	0.036	0.033	0	39.6	40.4	73.5	126	127	0	34	33
2015	12	12	8	35	10	0.148	-0.069	0.896	0.036	0.033	0	38.7	40	73.1	124	127	0	34	34
2015	12	12	8	45	10	0.177	0	0.896	0.036	0.033	0	40	41.3	74	127	129	0	34	33
2015	12	12	8	55	10	0.144	-0.007	0.896	0.033	0.033	0	40	41.3	73.5	127	129	0	34	33
2015	12	12	9	5	10	0.203	-0.059	0.896	0.033	0.03	0	40.4	40	72.7	128	128	0	34	35
2015	12	12	9	15	10	0.177	-0.066	0.896	0.036	0.033	0	40.9	40.9	71.8	129	128	0	34	33
2015	12	12	9	25	10	0.187	-0.056	0.892	0.03	0.03	0	40.9	41.7	73.1	129	130	0	34	33
2015	12	12	9	35	10	0.236	-0.016	0.892	0.033	0.03	0	41.7	42.1	70.5	131	132	0	34	34
2015	12	12	9	45	10	0.144	-0.039	0.892	0.033	0.03	0	42.1	42.6	72.7	132	132	0	34	33
2015	12	12	9	55	10	0.213	0	0.892	0.033	0.03	0	41.3	41.7	71.8	130	131	0	34	34
2015	12	12	10	5	10	0.184	0.013	0.892	0.036	0.033	0	41.7	42.1	73.1	131	131	0	34	33
2015	12	12	10	15	10	0.24	-0.03	0.892	0.033	0.03	0	43.4	42.6	72.2	134	132	0	33	33
2015	12	12	10	25	10	0.256	-0.052	0.896	0.033	0.03	0	42.1	42.1	72.7	132	132	0	34	34
2015	12	12	10	35	10	0.171	-0.02	0.892	0.033	0.03	0	43	43	72.7	134	133	0	34	33
2015	12	12	10	45	10	0.161	-0.023	0.892	0.033	0.03	0	42.1	43.9	70.5	132	135	0	34	33
2015	12	12	10	55	10	0.157	-0.03	0.892	0.039	0.036	0	43.4	44.7	70.1	135	137	0	34	33
2015	12	12	11	5	10	0.171	-0.016	0.892	0.033	0.03	0	44.7	43.9	71.8	138	136	0	34	34
2015	12	12	11	15	10	0.174	-0.052	0.896	0.033	0.03	0	44.7	44.7	71	138	137	0	34	33
2015	12	12	11	25	10	0.24	-0.052	0.896	0.046	0.043	0	45.2	45.2	72.7	139	138	0	34	33
2015	12	12	11	35	10	0.256	-0.013	0.896	0.033	0.03	0	44.7	44.7	71.4	138	137	0	34	33
2015	12	12	11	45	10	0.223	0.003	0.896	0.033	0.03	0	43.4	44.3	73.5	136	136	0	35	33
2015	12	12	11	55	10	0.187	-0.069	0.896	0.036	0.033	0	44.3	44.7	72.7	137	137	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	12	5	10	0.217	-0.059	0.896	0.033	0.03	0	44.3	44.3	72.7	138	136	0	35	33
2015	12	12	12	15	10	0.174	0	0.896	0.033	0.03	0	45.6	44.3	72.2	140	136	0	34	33
2015	12	12	12	25	10	0.131	-0.03	0.896	0.033	0.03	0	44.3	43.4	72.7	137	135	0	34	34
2015	12	12	12	35	10	0.23	0.016	0.896	0.033	0.03	0	44.3	43	75.7	137	134	0	34	34
2015	12	12	12	45	10	0.24	-0.046	0.896	0.033	0.03	0	44.3	43.4	74.8	136	134	0	33	33
2015	12	12	12	55	10	0.243	-0.039	0.896	0.033	0.03	0	44.7	43	75.3	138	134	0	34	34
2015	12	12	13	5	10	0.18	-0.085	0.896	0.039	0.036	0	44.7	43.4	74.4	137	135	0	33	34
2015	12	12	13	15	10	0.18	-0.003	0.896	0.033	0.03	0	45.6	45.2	75.3	140	138	0	34	33
2015	12	12	13	25	10	0.164	0	0.896	0.03	0.03	0	44.7	45.6	74	138	138	0	34	32
2015	12	12	13	35	10	0.187	-0.03	0.896	0.033	0.03	0	46	44.7	73.1	140	137	0	33	33
2015	12	12	13	45	10	0.223	-0.059	0.896	0.033	0.03	0	45.2	45.2	74	139	138	0	34	33
2015	12	12	13	55	10	0.187	0	0.896	0.036	0.033	0	45.2	45.6	73.1	139	139	0	34	33
2015	12	12	14	5	10	0.223	-0.02	0.896	0.033	0.03	0	46	45.6	74.8	140	139	0	33	33
2015	12	12	14	15	10	0.148	0.069	0.896	0.033	0.03	0	45.6	44.7	73.1	140	138	0	34	34
2015	12	12	14	25	10	0.105	0.01	0.896	0.033	0.03	0	45.2	45.6	74	139	139	0	34	33
2015	12	12	14	35	10	0.18	-0.059	0.896	0.039	0.039	0	44.3	44.3	75.3	137	135	0	34	32
2015	12	12	14	45	10	0.187	-0.052	0.896	0.033	0.03	0	44.3	43.4	74.8	137	134	0	34	33
2015	12	12	14	55	10	0.171	-0.059	0.896	0.033	0.03	0	41.7	42.6	76.1	131	132	0	34	33
2015	12	12	15	5	10	0.157	-0.056	0.896	0.039	0.036	0	40	40.4	77.8	127	127	0	34	33
2015	12	12	15	15	10	0.161	0.02	0.896	0.036	0.033	0	39.1	40	76.5	124	126	0	33	33
2015	12	12	15	25	10	0.18	-0.003	0.896	0.033	0.03	0	39.6	38.7	76.5	125	124	0	33	34
2015	12	12	15	35	10	0.118	-0.03	0.896	0.036	0.033	0	37.8	37.4	77.8	122	120	0	34	33
2015	12	12	15	45	10	0.174	-0.072	0.896	0.039	0.036	0	37.4	36.5	79.1	121	118	0	34	33
2015	12	12	15	55	10	0.135	-0.059	0.896	0.036	0.033	0	35.3	35.7	79.1	116	117	0	34	34
2015	12	12	16	5	10	0.148	-0.069	0.896	0.033	0.03	0	35.3	35.7	78.3	116	116	0	34	33
2015	12	12	16	15	10	0.062	-0.062	0.896	0.036	0.033	0	35.3	34.8	78.7	116	115	0	34	34
2015	12	12	16	25	10	0.144	-0.066	0.896	0.039	0.039	0	36.1	36.1	78.7	119	117	0	35	33
2015	12	12	16	35	10	0.213	-0.18	0.896	0.033	0.03	0	35.7	35.7	79.1	117	117	0	34	34
2015	12	12	16	45	10	0.151	-0.108	0.896	0.049	0.046	0	35.3	35.3	79.1	116	115	0	34	33
2015	12	12	16	55	10	0.148	-0.03	0.896	0.043	0.039	0	34.4	33.5	78.7	114	112	0	34	34
2015	12	12	17	5	10	0.131	-0.105	0.896	0.039	0.036	0	34.8	34.8	79.6	114	113	0	33	32
2015	12	12	17	15	10	0.079	-0.131	0.896	0.046	0.046	0	35.3	34	79.1	115	112	0	33	33
2015	12	12	17	25	10	0.098	-0.102	0.896	0.036	0.033	0	34.4	34	79.1	114	112	0	34	33
2015	12	12	17	35	10	0.161	-0.125	0.896	0.036	0.033	0	34.4	34	78.7	114	112	0	34	33
2015	12	12	17	45	10	0.2	-0.174	0.896	0.036	0.033	0	34.4	34.4	79.1	114	113	0	34	33
2015	12	12	17	55	10	0.203	-0.157	0.896	0.039	0.036	0	35.3	34.4	78.7	115	113	0	33	33
2015	12	12	18	5	10	0.19	-0.125	0.896	0.033	0.03	0	35.7	35.3	79.1	116	115	0	33	33
2015	12	12	18	15	10	0.197	-0.046	0.896	0.039	0.036	0	34.8	34.8	78.7	115	114	0	34	33
2015	12	12	18	25	10	0.184	-0.141	0.896	0.039	0.039	0	38.7	37.8	78.3	123	120	0	33	32
2015	12	12	18	35	10	0.2	0.007	0.896	0.036	0.033	0	37.8	37.4	77.8	122	120	0	34	33
2015	12	12	18	45	10	0.236	-0.108	0.896	0.036	0.033	0	38.3	37.4	78.7	122	120	0	33	33
2015	12	12	18	55	10	0.148	-0.121	0.896	0.039	0.036	0	37.4	37.4	78.7	121	119	0	34	32
2015	12	12	19	5	10	0.23	-0.121	0.896	0.046	0.043	0	37.4	37	78.3	121	119	0	34	33
2015	12	12	19	15	10	0.243	-0.148	0.899	0.043	0.039	0	37	36.5	78.3	120	118	0	34	33
2015	12	12	19	25	10	0.23	-0.121	0.896	0.039	0.036	0	36.1	36.5	78.3	119	118	0	35	33
2015	12	12	19	35	10	0.226	-0.072	0.899	0.033	0.03	0	36.1	36.1	78.7	118	118	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	19	45	10	0.236	-0.075	0.899	0.039	0.039	0	37	37	78.3	119	119	0	33	33
2015	12	12	19	55	10	0.213	-0.02	0.899	0.033	0.03	0	37	37	78.7	120	119	0	34	33
2015	12	12	20	5	10	0.253	-0.049	0.899	0.033	0.03	0	37	37	78.3	119	119	0	33	33
2015	12	12	20	15	10	0.177	-0.085	0.899	0.036	0.033	0	37	37.4	78.7	120	120	0	34	33
2015	12	12	20	25	10	0.194	-0.102	0.899	0.039	0.036	0	37.4	37.4	77.4	121	120	0	34	33
2015	12	12	20	35	10	0.161	-0.059	0.899	0.039	0.036	0	37.8	37.8	77.8	122	121	0	34	33
2015	12	12	20	45	10	0.177	-0.108	0.899	0.036	0.033	0	37.4	38.3	78.3	121	122	0	34	33
2015	12	12	20	55	10	0.144	-0.102	0.899	0.036	0.033	0	37.8	37.8	77.8	121	121	0	33	33
2015	12	12	21	5	10	0.21	-0.082	0.899	0.039	0.036	0	37.8	38.3	78.3	121	122	0	33	33
2015	12	12	21	15	10	0.174	-0.043	0.899	0.036	0.033	0	38.7	38.3	77.8	123	122	0	33	33
2015	12	12	21	25	10	0.151	-0.043	0.899	0.033	0.03	0	38.7	39.1	77.8	124	124	0	34	33
2015	12	12	21	35	10	0.23	-0.052	0.899	0.033	0.03	0	38.3	38.7	77.4	123	123	0	34	33
2015	12	12	21	45	10	0.161	-0.082	0.899	0.036	0.033	0	38.3	39.1	77	123	123	0	34	32
2015	12	12	21	55	10	0.157	-0.072	0.899	0.03	0.03	0	38.7	38.7	77.4	124	123	0	34	33
2015	12	12	22	5	10	0.259	-0.066	0.899	0.039	0.036	0	38.3	39.6	77.4	123	125	0	34	33
2015	12	12	22	15	10	0.223	-0.026	0.899	0.039	0.036	0	38.7	39.6	77.4	123	125	0	33	33
2015	12	12	22	25	10	0.203	-0.082	0.899	0.033	0.03	0	40	40	76.5	126	126	0	33	33
2015	12	12	22	35	10	0.217	-0.079	0.899	0.033	0.03	0	39.6	40	76.5	126	127	0	34	34
2015	12	12	22	45	10	0.236	0	0.899	0.033	0.03	0	39.1	40.4	77	125	127	0	34	33
2015	12	12	22	55	10	0.308	-0.121	0.899	0.033	0.03	0	39.1	40.9	76.5	125	128	0	34	33
2015	12	12	23	5	10	0.256	-0.03	0.899	0.033	0.033	0	39.6	40.9	76.5	126	128	0	34	33
2015	12	12	23	15	10	0.23	-0.043	0.899	0.036	0.033	0	39.6	41.3	76.5	126	129	0	34	33
2015	12	12	23	25	10	0.197	-0.003	0.899	0.036	0.033	0	39.6	40.9	76.5	126	129	0	34	34
2015	12	12	23	35	10	0.203	-0.023	0.899	0.033	0.03	0	40	40.9	76.5	127	128	0	34	33
2015	12	12	23	45	10	0.203	-0.066	0.899	0.033	0.03	0	39.6	41.3	75.7	126	129	0	34	33
2015	12	12	23	55	10	0.272	-0.023	0.899	0.033	0.03	0	40.4	40.9	76.5	128	128	0	34	33
2015	12	13	0	5	10	0.184	-0.003	0.899	0.03	0.03	0	40	42.1	75.7	127	131	0	34	33
2015	12	13	0	15	10	0.2	-0.072	0.899	0.039	0.039	0	40	41.7	75.7	127	130	0	34	33
2015	12	13	0	25	10	0.243	-0.016	0.899	0.039	0.039	0	40.4	41.7	76.1	128	130	0	34	33
2015	12	13	0	35	10	0.213	-0.03	0.899	0.036	0.033	0	41.3	42.1	76.1	130	131	0	34	33
2015	12	13	0	45	10	0.289	-0.013	0.899	0.036	0.033	0	40.9	41.7	75.3	129	130	0	34	33
2015	12	13	0	55	10	0.171	-0.059	0.899	0.039	0.036	0	40.4	42.6	75.3	129	132	0	35	33
2015	12	13	1	5	10	0.243	-0.056	0.899	0.039	0.036	0	41.3	42.6	76.1	130	132	0	34	33
2015	12	13	1	15	10	0.148	-0.01	0.899	0.039	0.036	0	40	42.1	75.3	128	131	0	35	33
2015	12	13	1	25	10	0.154	-0.049	0.899	0.033	0.03	0	41.3	42.6	75.7	129	132	0	33	33
2015	12	13	1	35	10	0.207	-0.069	0.899	0.03	0.03	0	41.3	42.1	76.1	130	132	0	34	34
2015	12	13	1	45	10	0.23	-0.043	0.899	0.036	0.033	0	41.3	40.9	75.3	130	129	0	34	34
2015	12	13	1	55	10	0.207	-0.02	0.899	0.033	0.03	0	41.3	42.6	75.7	130	132	0	34	33
2015	12	13	2	5	10	0.269	-0.066	0.899	0.033	0.03	0	40.4	41.3	74.8	128	130	0	34	34
2015	12	13	2	15	10	0.269	-0.023	0.899	0.033	0.03	0	42.1	42.1	75.7	131	132	0	33	34
2015	12	13	2	25	10	0.174	0	0.896	0.046	0.043	0	40.9	42.6	74.8	129	132	0	34	33
2015	12	13	2	35	10	0.197	-0.085	0.896	0.033	0.03	0	41.3	43	75.3	130	133	0	34	33
2015	12	13	2	45	10	0.24	-0.01	0.896	0.036	0.033	0	40	42.6	76.1	127	132	0	34	33
2015	12	13	2	55	10	0.194	-0.039	0.896	0.036	0.033	0	40.9	42.6	74.4	129	133	0	34	34
2015	12	13	3	5	10	0.21	-0.039	0.896	0.033	0.03	0	41.3	42.1	75.3	130	131	0	34	33
2015	12	13	3	15	10	0.217	-0.02	0.896	0.039	0.036	0	41.7	42.6	75.3	131	133	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	3	25	10	0.184	-0.007	0.896	0.033	0.03	0	41.7	42.6	74.8	131	133	0	34	34
2015	12	13	3	35	10	0.177	-0.033	0.896	0.033	0.03	0	41.3	42.6	74.4	130	132	0	34	33
2015	12	13	3	45	10	0.21	0	0.896	0.033	0.03	0	41.3	42.6	74.8	130	132	0	34	33
2015	12	13	3	55	10	0.2	-0.02	0.896	0.033	0.03	0	41.7	42.6	74.8	131	132	0	34	33
2015	12	13	4	5	10	0.223	-0.039	0.896	0.033	0.03	0	42.1	43.4	74.4	132	134	0	34	33
2015	12	13	4	15	10	0.226	-0.098	0.896	0.033	0.03	0	41.7	43	74.8	131	133	0	34	33
2015	12	13	4	25	10	0.217	-0.003	0.896	0.033	0.03	0	41.7	43	74.8	131	133	0	34	33
2015	12	13	4	35	10	0.249	-0.003	0.896	0.033	0.03	0	42.1	42.1	74.8	132	132	0	34	34
2015	12	13	4	45	10	0.19	-0.003	0.896	0.03	0.03	0	40.9	43.4	75.7	130	134	0	35	33
2015	12	13	4	55	10	0.236	-0.072	0.896	0.033	0.03	0	42.1	42.1	75.7	132	131	0	34	33
2015	12	13	5	5	10	0.292	-0.026	0.896	0.036	0.033	0	40.9	41.7	75.3	129	131	0	34	34
2015	12	13	5	15	10	0.177	-0.013	0.896	0.033	0.03	0	40.9	42.6	75.3	129	133	0	34	34
2015	12	13	5	25	10	0.246	-0.056	0.896	0.033	0.03	0	41.3	42.1	74.8	130	132	0	34	34
2015	12	13	5	35	10	0.197	-0.013	0.896	0.03	0.026	0	41.7	43	75.3	131	134	0	34	34
2015	12	13	5	45	10	0.266	-0.069	0.896	0.033	0.03	0	40.9	42.1	74.8	129	132	0	34	34
2015	12	13	5	55	10	0.22	-0.016	0.896	0.03	0.026	0	41.7	42.6	74.8	131	132	0	34	33
2015	12	13	6	5	10	0.217	-0.036	0.896	0.033	0.03	0	41.3	41.7	75.3	130	131	0	34	34
2015	12	13	6	15	10	0.24	-0.007	0.896	0.033	0.03	0	42.1	43.4	75.3	132	133	0	34	32
2015	12	13	6	25	10	0.213	-0.03	0.896	0.033	0.033	0	41.7	42.6	74.8	131	132	0	34	33
2015	12	13	6	35	10	0.236	-0.052	0.896	0.039	0.036	0	40.9	42.6	75.3	130	132	0	35	33
2015	12	13	6	45	10	0.236	0	0.896	0.039	0.039	0	41.3	42.1	75.3	130	132	0	34	34
2015	12	13	6	55	10	0.223	-0.02	0.896	0.033	0.03	0	40	41.3	75.3	127	129	0	34	33
2015	12	13	7	5	10	0.226	-0.072	0.896	0.033	0.03	0	39.1	40	76.1	125	127	0	34	34
2015	12	13	7	15	10	0.223	0.013	0.896	0.039	0.036	0	38.3	38.7	77	124	124	0	35	34
2015	12	13	7	25	10	0.226	-0.013	0.896	0.03	0.026	0	38.7	38.7	76.5	124	124	0	34	34
2015	12	13	7	35	10	0.249	-0.095	0.896	0.033	0.033	0	37.4	38.7	76.5	121	123	0	34	33
2015	12	13	7	45	10	0.223	-0.03	0.896	0.033	0.03	0	38.7	38.7	77	124	124	0	34	34
2015	12	13	7	55	10	0.217	0.01	0.896	0.036	0.033	0	38.3	38.7	77	123	124	0	34	34
2015	12	13	8	5	10	0.233	-0.089	0.896	0.033	0.03	0	38.7	38.7	76.5	124	123	0	34	33
2015	12	13	8	15	10	0.243	-0.052	0.896	0.033	0.03	0	37.4	39.1	76.5	122	125	0	35	34
2015	12	13	8	25	10	0.207	-0.036	0.896	0.036	0.033	0	38.7	40	76.1	124	126	0	34	33
2015	12	13	8	35	10	0.21	-0.049	0.896	0.033	0.03	0	38.7	39.6	77	124	125	0	34	33
2015	12	13	8	45	10	0.223	-0.046	0.896	0.03	0.03	0	40.4	39.6	76.5	128	126	0	34	34
2015	12	13	8	55	10	0.19	-0.026	0.896	0.033	0.033	0	39.6	40	77	126	126	0	34	33
2015	12	13	9	5	10	0.197	-0.046	0.896	0.033	0.03	0	39.6	39.6	77.4	126	125	0	34	33
2015	12	13	9	15	10	0.161	-0.039	0.896	0.033	0.03	0	39.6	39.1	77.4	126	124	0	34	33
2015	12	13	9	25	10	0.164	0.003	0.896	0.036	0.033	0	40	39.6	77.4	127	126	0	34	34
2015	12	13	9	35	10	0.18	-0.056	0.896	0.033	0.03	0	40	39.6	77	127	125	0	34	33
2015	12	13	9	45	10	0.194	-0.056	0.892	0.033	0.03	0	43	43	74.4	135	133	0	35	33
2015	12	13	9	55	10	0.246	-0.082	0.896	0.033	0.03	0	44.7	44.3	74	138	136	0	34	33
2015	12	13	10	5	10	0.233	-0.062	0.896	0.039	0.036	0	43.9	43	74.8	136	134	0	34	34
2015	12	13	10	15	10	0.203	-0.023	0.896	0.036	0.033	0	43	42.6	76.1	134	132	0	34	33
2015	12	13	10	25	10	0.236	0	0.896	0.039	0.036	0	41.3	41.7	77	130	131	0	34	34
2015	12	13	10	35	10	0.226	-0.062	0.896	0.043	0.043	0	41.3	42.6	76.5	130	132	0	34	33
2015	12	13	10	45	10	0.253	-0.092	0.896	0.033	0.03	0	41.3	42.1	76.1	131	132	0	35	34
2015	12	13	10	55	10	0.249	-0.036	0.896	0.036	0.033	0	42.6	42.1	76.1	133	131	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	11	5	10	0.21	-0.098	0.896	0.036	0.033	0	41.7	41.3	77	131	130	0	34	34
2015	12	13	11	15	10	0.272	-0.059	0.896	0.036	0.033	0	43.4	42.1	75.7	135	131	0	34	33
2015	12	13	11	25	10	0.171	0.026	0.896	0.03	0.03	0	43	43.9	75.3	134	136	0	34	34
2015	12	13	11	35	10	0.2	0.007	0.896	0.036	0.033	0	43.4	43.9	76.1	135	135	0	34	33
2015	12	13	11	45	10	0.167	0	0.896	0.039	0.036	0	44.3	43.9	75.7	137	135	0	34	33
2015	12	13	11	55	10	0.262	-0.043	0.896	0.039	0.039	0	43.4	42.6	76.5	135	132	0	34	33
2015	12	13	12	5	10	0.171	-0.046	0.896	0.033	0.03	0	43	42.6	75.7	134	132	0	34	33
2015	12	13	12	15	10	0.167	-0.049	0.896	0.039	0.036	0	42.6	42.6	75.3	133	132	0	34	33
2015	12	13	12	25	10	0.246	-0.082	0.892	0.046	0.043	0	44.3	44.3	74	137	136	0	34	33
2015	12	13	12	35	10	0.256	-0.056	0.896	0.033	0.03	0	52.5	51.6	68.4	155	153	0	33	33
2015	12	13	12	45	10	0.194	-0.039	0.892	0.039	0.039	0	52	50.7	67.9	154	151	0	33	33
2015	12	13	12	55	10	0.171	-0.03	0.896	0.036	0.033	0	49	49	71.4	147	146	0	33	32
2015	12	13	13	5	10	0.226	-0.043	0.892	0.033	0.03	0	47.7	47.3	71.8	144	143	0	33	33
2015	12	13	13	15	10	0.197	-0.052	0.892	0.039	0.036	0	45.6	45.6	73.1	140	140	0	34	34
2015	12	13	13	25	10	0.266	-0.036	0.892	0.033	0.03	0	44.7	45.6	74	138	139	0	34	33
2015	12	13	13	35	10	0.203	-0.049	0.892	0.049	0.046	0	43.9	43.9	74.8	135	135	0	33	33
2015	12	13	13	45	10	0.194	-0.023	0.892	0.033	0.03	0	43.4	43	74	136	134	0	35	34
2015	12	13	13	55	10	0.187	-0.023	0.892	0.033	0.03	0	42.1	42.6	75.7	133	132	0	35	33
2015	12	13	14	5	10	0.174	-0.036	0.892	0.039	0.036	0	43.4	43.4	74.4	135	134	0	34	33
2015	12	13	14	15	10	0.171	-0.072	0.892	0.039	0.036	0	45.2	45.6	74	139	139	0	34	33
2015	12	13	14	25	10	0.233	0.013	0.892	0.039	0.036	0	44.3	43.9	74	136	136	0	33	34
2015	12	13	14	35	10	0.259	0.069	0.892	0.036	0.033	0	46.4	46.9	73.5	142	142	0	34	33
2015	12	13	14	45	10	0.233	0.026	0.892	0.039	0.039	0	46.9	46.4	71.8	143	141	0	34	33
2015	12	13	14	55	10	0.259	0	0.892	0.033	0.03	0	47.7	48.2	70.5	145	145	0	34	33
2015	12	13	15	5	10	0.164	0.013	0.892	0.046	0.043	0	47.7	47.7	69.7	144	144	0	33	33
2015	12	13	15	15	10	0.217	0.039	0.892	0.033	0.03	0	50.3	50.7	68.8	151	151	0	34	33
2015	12	13	15	25	10	0.226	0.098	0.892	0.039	0.039	0	51.2	50.7	66.7	153	151	0	34	33
2015	12	13	15	35	10	0.295	0.21	0.892	0.036	0.033	0	51.2	51.6	68.4	153	152	0	34	32
2015	12	13	15	45	10	0.197	0.043	0.892	0.039	0.039	0	51.2	50.7	68.8	153	151	0	34	33
2015	12	13	15	55	10	0.259	0.095	0.892	0.039	0.036	0	51.6	51.6	67.1	154	153	0	34	33
2015	12	13	16	5	10	0.256	0.056	0.892	0.036	0.033	0	51.6	51.2	67.5	154	152	0	34	33
2015	12	13	16	15	10	0.233	0.072	0.892	0.039	0.039	0	51.6	50.7	67.5	154	152	0	34	34
2015	12	13	16	25	10	0.236	0.092	0.892	0.039	0.039	0	51.6	51.6	65.8	154	153	0	34	33
2015	12	13	16	35	10	0.289	0.135	0.892	0.046	0.043	0	52	51.2	67.1	154	153	0	33	34
2015	12	13	16	45	10	0.236	0.118	0.892	0.043	0.039	0	53.3	52.9	65.4	158	156	0	34	33
2015	12	13	16	55	10	0.243	0.108	0.892	0.046	0.043	0	53.8	52.9	65.8	158	156	0	33	33
2015	12	13	17	5	10	0.282	0.052	0.892	0.043	0.039	0	52.5	52	66.7	156	154	0	34	33
2015	12	13	17	15	10	0.259	0.115	0.892	0.039	0.036	0	52	51.6	66.7	155	153	0	34	33
2015	12	13	17	25	10	0.22	0.039	0.892	0.036	0.033	0	52	51.2	66.7	154	152	0	33	33
2015	12	13	17	35	10	0.23	0.131	0.892	0.046	0.043	0	52.5	51.6	66.2	156	154	0	34	34
2015	12	13	17	45	10	0.249	0.112	0.892	0.039	0.039	0	50.7	49.9	68.8	151	149	0	33	33
2015	12	13	17	55	10	0.243	0.092	0.892	0.043	0.039	0	49.5	49	70.1	149	147	0	34	33
2015	12	13	18	5	10	0.236	0.151	0.892	0.036	0.033	0	49	48.6	70.1	147	146	0	33	33
2015	12	13	18	15	10	0.259	0.128	0.892	0.039	0.036	0	48.2	47.7	71	146	144	0	34	33
2015	12	13	18	25	10	0.312	0.167	0.892	0.036	0.033	0	47.3	46.9	72.2	144	142	0	34	33
2015	12	13	18	35	10	0.256	0.085	0.892	0.039	0.039	0	46.4	46.4	72.7	142	141	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	18	45	10	0.249	0.085	0.892	0.036	0.033	0	46.4	46	72.2	142	140	0	34	33
2015	12	13	18	55	10	0.18	0.112	0.892	0.043	0.039	0	46.4	46	72.7	141	140	0	33	33
2015	12	13	19	5	10	0.203	0.085	0.892	0.039	0.039	0	45.6	45.6	73.5	140	139	0	34	33
2015	12	13	19	15	10	0.187	0.135	0.892	0.039	0.039	0	45.6	45.6	73.1	140	139	0	34	33
2015	12	13	19	25	10	0.23	0	0.892	0.043	0.039	0	45.6	45.2	73.5	140	138	0	34	33
2015	12	13	19	35	10	0.282	0.03	0.889	0.046	0.043	0	47.3	46.9	67.9	144	142	0	34	33
2015	12	13	19	45	10	0.305	0.161	0.892	0.039	0.039	0	46.4	45.6	71	141	140	0	33	34
2015	12	13	19	55	10	0.236	0.102	0.892	0.046	0.043	0	46.9	46.4	73.1	143	141	0	34	33
2015	12	13	20	5	10	0.249	0.01	0.892	0.039	0.039	0	47.3	48.2	71.8	144	144	0	34	32
2015	12	13	20	15	10	0.23	0.043	0.892	0.036	0.033	0	46.4	46.9	73.1	142	142	0	34	33
2015	12	13	20	25	10	0.23	0.052	0.892	0.039	0.036	0	46.4	46.4	72.2	142	141	0	34	33
2015	12	13	20	35	10	0.23	0.075	0.892	0.036	0.033	0	46.9	46	73.1	142	140	0	33	33
2015	12	13	20	45	10	0.249	0.121	0.892	0.039	0.036	0	46	46	73.1	141	140	0	34	33
2015	12	13	20	55	10	0.226	0.056	0.892	0.033	0.03	0	45.6	45.6	73.5	140	139	0	34	33
2015	12	13	21	5	10	0.266	0.043	0.892	0.036	0.033	0	45.2	45.2	73.1	139	139	0	34	34
2015	12	13	21	15	10	0.272	0.079	0.892	0.033	0.03	0	44.7	44.7	74.4	138	137	0	34	33
2015	12	13	21	25	10	0.302	0.043	0.892	0.036	0.033	0	44.7	44.7	74.8	138	137	0	34	33
2015	12	13	21	35	10	0.217	0.056	0.896	0.036	0.033	0	44.3	44.7	74.4	137	137	0	34	33
2015	12	13	21	45	10	0.23	-0.013	0.892	0.033	0.03	0	43.9	44.3	74.4	136	137	0	34	34
2015	12	13	21	55	10	0.256	0.046	0.896	0.036	0.033	0	43.4	44.3	74.8	135	136	0	34	33
2015	12	13	22	5	10	0.207	0.02	0.892	0.03	0.03	0	43.9	43.9	75.3	136	135	0	34	33
2015	12	13	22	15	10	0.164	0.095	0.896	0.036	0.033	0	43.4	43.9	75.3	136	135	0	35	33
2015	12	13	22	25	10	0.223	0.02	0.892	0.036	0.033	0	43.4	43.9	75.3	135	135	0	34	33
2015	12	13	22	35	10	0.167	0.026	0.892	0.033	0.03	0	43.9	43.9	75.3	136	136	0	34	34
2015	12	13	22	45	10	0.174	0.013	0.896	0.033	0.03	0	43.9	44.3	75.7	136	136	0	34	33
2015	12	13	22	55	10	0.23	0	0.896	0.033	0.03	0	43.4	43.9	74	135	135	0	34	33
2015	12	13	23	5	10	0.171	0.043	0.896	0.033	0.03	0	43.4	43.9	75.7	135	135	0	34	33
2015	12	13	23	15	10	0.2	0.046	0.896	0.033	0.03	0	43.4	43.9	75.7	135	136	0	34	34
2015	12	13	23	25	10	0.174	-0.026	0.896	0.036	0.033	0	43.4	43.9	74.8	135	136	0	34	34
2015	12	13	23	35	10	0.243	-0.003	0.892	0.03	0.03	0	43.4	43.4	75.3	134	135	0	33	34
2015	12	13	23	45	10	0.174	0.043	0.892	0.036	0.033	0	43.9	43.9	74.8	135	135	0	33	33
2015	12	13	23	55	10	0.157	-0.033	0.892	0.039	0.036	0	43.4	43.9	75.3	135	135	0	34	33
2015	12	14	0	5	10	0.203	0.016	0.896	0.033	0.03	0	43	43.9	75.3	134	135	0	34	33
2015	12	14	0	15	10	0.21	-0.013	0.896	0.033	0.03	0	43	44.3	75.3	134	136	0	34	33
2015	12	14	0	25	10	0.197	-0.026	0.892	0.039	0.036	0	43.4	44.3	75.3	135	136	0	34	33
2015	12	14	0	35	10	0.233	-0.013	0.892	0.033	0.03	0	43.9	44.3	75.7	135	136	0	33	33
2015	12	14	0	45	10	0.18	-0.003	0.892	0.033	0.03	0	43.4	44.3	74.8	135	136	0	34	33
2015	12	14	0	55	10	0.203	-0.039	0.892	0.036	0.033	0	43	43.4	73.1	134	135	0	34	34
2015	12	14	1	5	10	0.249	-0.052	0.892	0.033	0.03	0	43.9	43.9	74.4	136	136	0	34	34
2015	12	14	1	15	10	0.262	0.013	0.892	0.033	0.03	0	43.4	45.2	72.7	135	137	0	34	32
2015	12	14	1	25	10	0.213	-0.066	0.892	0.036	0.033	0	43.4	43.9	73.5	135	136	0	34	34
2015	12	14	1	35	10	0.23	-0.082	0.892	0.033	0.03	0	43	43.9	74.8	134	135	0	34	33
2015	12	14	1	45	10	0.299	0.082	0.892	0.033	0.03	0	43.9	44.3	70.1	136	136	0	34	33
2015	12	14	1	55	10	0.213	0	0.892	0.033	0.03	0	43	44.3	70.1	134	137	0	34	34
2015	12	14	2	5	10	0.18	-0.026	0.892	0.033	0.033	0	43.9	44.7	73.5	136	137	0	34	33
2015	12	14	2	15	10	0.213	-0.039	0.892	0.033	0.03	0	44.3	45.2	72.7	137	138	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	2	25	10	0.135	-0.007	0.892	0.039	0.036	0	43.9	45.6	71.8	136	139	0	34	33
2015	12	14	2	35	10	0.118	0.026	0.892	0.033	0.03	0	44.3	44.3	71.4	137	137	0	34	34
2015	12	14	2	45	10	0.141	0.01	0.892	0.033	0.03	0	44.3	45.6	71.4	137	139	0	34	33
2015	12	14	2	55	10	0.171	0.059	0.892	0.033	0.03	0	44.3	45.2	73.5	137	138	0	34	33
2015	12	14	3	5	10	0.217	-0.01	0.892	0.039	0.036	0	43.9	44.7	72.7	136	138	0	34	34
2015	12	14	3	15	10	0.22	-0.033	0.892	0.033	0.03	0	44.3	44.7	73.5	137	137	0	34	33
2015	12	14	3	25	10	0.197	-0.036	0.892	0.03	0.03	0	44.3	45.6	73.1	137	139	0	34	33
2015	12	14	3	35	10	0.164	0.036	0.892	0.036	0.033	0	43.9	45.2	74	136	138	0	34	33
2015	12	14	3	45	10	0.18	-0.036	0.892	0.033	0.03	0	43.9	44.7	73.5	136	137	0	34	33
2015	12	14	3	55	10	0.2	0.01	0.892	0.036	0.033	0	44.3	45.2	68.8	137	138	0	34	33
2015	12	14	4	5	10	0.164	-0.052	0.889	0.036	0.033	0	43.9	44.7	69.7	136	137	0	34	33
2015	12	14	4	15	10	0.151	0.056	0.889	0.039	0.039	0	44.3	45.2	68.8	138	139	0	35	34
2015	12	14	4	25	10	0.154	0	0.892	0.033	0.03	0	44.7	45.2	72.7	138	138	0	34	33
2015	12	14	4	35	10	0.154	-0.043	0.889	0.033	0.03	0	44.3	44.7	69.7	137	138	0	34	34
2015	12	14	4	45	10	0.217	-0.036	0.892	0.036	0.033	0	44.7	45.2	73.5	138	138	0	34	33
2015	12	14	4	55	10	0.223	0.007	0.892	0.033	0.03	0	44.7	44.7	74	138	138	0	34	34
2015	12	14	5	5	10	0.282	0	0.892	0.033	0.03	0	45.2	45.2	74.4	139	138	0	34	33
2015	12	14	5	15	10	0.23	0.013	0.892	0.033	0.03	0	44.3	44.7	73.5	137	138	0	34	34
2015	12	14	5	25	10	0.262	-0.013	0.892	0.033	0.03	0	43.4	45.6	73.1	135	139	0	34	33
2015	12	14	5	35	10	0.262	-0.03	0.892	0.033	0.03	0	43.9	44.3	73.5	136	137	0	34	34
2015	12	14	5	45	10	0.203	0	0.892	0.033	0.03	0	44.3	45.2	74	137	138	0	34	33
2015	12	14	5	55	10	0.21	-0.007	0.889	0.033	0.03	0	43.9	44.7	71.8	137	137	0	35	33
2015	12	14	6	5	10	0.213	-0.007	0.889	0.033	0.03	0	43	43.9	74.8	135	136	0	35	34
2015	12	14	6	15	10	0.217	0.01	0.889	0.039	0.036	0	43.4	43.9	69.7	135	136	0	34	34
2015	12	14	6	25	10	0.19	-0.052	0.889	0.039	0.036	0	43.9	43.9	71	136	136	0	34	34
2015	12	14	6	35	10	0.246	-0.059	0.892	0.033	0.03	0	44.3	44.3	73.5	137	136	0	34	33
2015	12	14	6	45	10	0.203	0.033	0.889	0.033	0.03	0	44.3	44.7	74	137	137	0	34	33
2015	12	14	6	55	10	0.184	-0.052	0.892	0.036	0.033	0	42.6	43.4	74.4	133	135	0	34	34
2015	12	14	7	5	10	0.19	0.046	0.889	0.036	0.033	0	40.9	43	74.8	130	134	0	35	34
2015	12	14	7	15	10	0.184	-0.062	0.892	0.03	0.03	0	40.4	41.7	74.4	129	130	0	35	33
2015	12	14	7	25	10	0.253	-0.02	0.889	0.039	0.036	0	40.9	40.4	74.8	129	128	0	34	34
2015	12	14	7	35	10	0.23	0.007	0.889	0.033	0.03	0	40.4	41.3	72.2	128	130	0	34	34
2015	12	14	7	45	10	0.148	-0.026	0.889	0.03	0.03	0	41.3	41.7	71.8	130	130	0	34	33
2015	12	14	7	55	10	0.2	0.003	0.889	0.033	0.03	0	41.7	41.3	71.4	131	130	0	34	34
2015	12	14	8	5	10	0.18	0.016	0.889	0.03	0.03	0	41.3	42.1	70.1	130	131	0	34	33
2015	12	14	8	15	10	0.197	0.016	0.889	0.03	0.03	0	41.7	41.7	73.5	131	131	0	34	34
2015	12	14	8	25	10	0.236	-0.003	0.889	0.033	0.03	0	42.6	42.1	71	133	132	0	34	34
2015	12	14	8	35	10	0.223	0	0.889	0.033	0.03	0	42.6	43	69.7	133	133	0	34	33
2015	12	14	8	45	10	0.18	-0.007	0.889	0.033	0.03	0	42.6	43	70.1	134	133	0	35	33
2015	12	14	8	55	10	0.187	0.026	0.889	0.033	0.03	0	43	43.4	67.9	134	135	0	34	34
2015	12	14	9	5	10	0.203	-0.039	0.889	0.036	0.033	0	44.3	44.3	66.7	136	137	0	33	34
2015	12	14	9	15	10	0.151	0.007	0.889	0.036	0.033	0	43.9	44.7	67.5	136	137	0	34	33
2015	12	14	9	25	10	0.118	-0.118	0.889	0.033	0.03	0	45.6	45.6	66.2	140	139	0	34	33
2015	12	14	9	35	10	0.18	-0.075	0.886	0.039	0.039	0	50.3	50.7	63.2	151	151	0	34	33
2015	12	14	9	45	10	0.194	0	0.886	0.043	0.039	0	49.5	49	62.4	149	148	0	34	34
2015	12	14	9	55	10	0.18	0.007	0.886	0.036	0.033	0	48.6	49	62.8	147	147	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	10	5	10	0.194	-0.072	0.886	0.043	0.043	0	47.7	47.7	63.6	146	145	0	35	34
2015	12	14	10	15	10	0.161	-0.013	0.886	0.033	0.03	0	48.2	48.6	64.1	146	146	0	34	33
2015	12	14	10	25	10	0.151	0.072	0.886	0.033	0.03	0	47.7	48.6	62.4	146	146	0	35	33
2015	12	14	10	35	10	0.141	-0.01	0.889	0.033	0.03	0	48.2	49	64.5	147	147	0	35	33
2015	12	14	10	45	10	0.154	0.049	0.886	0.036	0.033	0	48.6	48.2	62.4	147	147	0	34	35
2015	12	14	10	55	10	0.187	0.01	0.889	0.033	0.03	0	49	48.2	65.4	148	146	0	34	34
2015	12	14	11	5	10	0.203	-0.016	0.886	0.036	0.033	0	49	48.2	63.6	148	146	0	34	34
2015	12	14	11	15	10	0.226	-0.013	0.889	0.039	0.036	0	49	49	66.7	148	147	0	34	33
2015	12	14	11	25	10	0.164	0	0.889	0.033	0.03	0	49.5	49	64.9	149	147	0	34	33
2015	12	14	11	35	10	0.174	0.013	0.886	0.033	0.03	0	48.6	48.2	64.5	147	145	0	34	33
2015	12	14	11	45	10	0.223	0.02	0.889	0.033	0.03	0	49	48.2	66.2	147	146	0	33	34
2015	12	14	11	55	10	0.151	0.059	0.889	0.036	0.033	0	48.6	48.2	65.4	146	145	0	33	33
2015	12	14	12	5	10	0.223	-0.033	0.886	0.036	0.033	0	47.3	47.7	66.2	144	144	0	34	33
2015	12	14	12	15	10	0.18	0.046	0.886	0.043	0.039	0	48.2	47.7	64.1	146	145	0	34	34
2015	12	14	12	25	10	0.148	-0.026	0.886	0.039	0.036	0	47.3	48.2	65.8	144	145	0	34	33
2015	12	14	12	35	10	0.21	0.052	0.886	0.036	0.033	0	46.9	47.3	64.1	143	143	0	34	33
2015	12	14	12	45	10	0.197	0.043	0.886	0.036	0.033	0	47.3	46.9	67.5	144	142	0	34	33
2015	12	14	12	55	10	0.112	0.046	0.886	0.033	0.03	0	46	46.9	65.8	141	143	0	34	34
2015	12	14	13	5	10	0.213	0.036	0.886	0.03	0.03	0	47.3	47.7	65.4	144	143	0	34	32
2015	12	14	13	15	10	0.203	0	0.886	0.036	0.033	0	46.9	46.9	64.1	143	142	0	34	33
2015	12	14	13	25	10	0.171	0.036	0.886	0.046	0.043	0	47.7	48.6	61.9	145	146	0	34	33
2015	12	14	13	35	10	0.167	0.098	0.886	0.036	0.033	0	49.5	49.9	63.2	149	149	0	34	33
2015	12	14	13	45	10	0.171	-0.007	0.886	0.039	0.036	0	49	49.9	63.2	148	149	0	34	33
2015	12	14	13	55	10	0.19	0.039	0.889	0.036	0.033	0	48.2	48.6	66.7	146	146	0	34	33
2015	12	14	14	5	10	0.184	0.095	0.886	0.033	0.03	0	48.2	48.6	64.1	146	146	0	34	33
2015	12	14	14	15	10	0.184	0.069	0.886	0.033	0.03	0	49	49.5	64.1	148	148	0	34	33
2015	12	14	14	25	10	0.112	0.023	0.886	0.033	0.03	0	49.5	49	65.8	148	147	0	33	33
2015	12	14	14	35	10	0.23	0.016	0.889	0.033	0.03	0	48.6	48.2	64.5	147	145	0	34	33
2015	12	14	14	45	10	0.138	0.013	0.889	0.033	0.03	0	48.6	48.6	66.7	147	146	0	34	33
2015	12	14	14	55	10	0.171	0.02	0.886	0.039	0.036	0	49.5	48.2	63.2	148	146	0	33	34
2015	12	14	15	5	10	0.2	0.013	0.886	0.036	0.033	0	47.3	47.3	66.2	144	144	0	34	34
2015	12	14	15	15	10	0.128	0.066	0.883	0.036	0.033	0	48.2	48.2	63.2	146	145	0	34	33
2015	12	14	15	25	10	0.161	-0.03	0.886	0.039	0.039	0	47.3	46.9	66.7	144	142	0	34	33
2015	12	14	15	35	10	0.282	-0.059	0.889	0.033	0.03	0	46.9	46	67.9	143	140	0	34	33
2015	12	14	15	45	10	0.203	-0.033	0.886	0.036	0.033	0	45.2	44.7	67.9	139	138	0	34	34
2015	12	14	15	55	10	0.203	-0.033	0.889	0.036	0.033	0	44.7	43.9	68.4	138	135	0	34	33
2015	12	14	16	5	10	0.177	-0.007	0.889	0.033	0.03	0	45.2	43.9	68.8	138	135	0	33	33
2015	12	14	16	15	10	0.184	0.056	0.889	0.039	0.036	0	43.9	43	71.4	136	134	0	34	34
2015	12	14	16	25	10	0.184	0.072	0.889	0.043	0.043	0	43.4	42.6	72.2	135	132	0	34	33
2015	12	14	16	35	10	0.19	0.026	0.889	0.049	0.046	0	43	42.6	73.1	134	132	0	34	33
2015	12	14	16	45	10	0.154	0.095	0.889	0.033	0.03	0	42.1	42.1	71.4	132	130	0	34	32
2015	12	14	16	55	10	0.223	0.046	0.889	0.033	0.03	0	40.4	41.3	72.2	128	128	0	34	32
2015	12	14	17	5	10	0.21	0.033	0.889	0.039	0.039	0	40	39.6	74	127	126	0	34	34
2015	12	14	17	15	10	0.144	0	0.889	0.039	0.036	0	39.6	39.6	74.4	126	125	0	34	33
2015	12	14	17	25	10	0.187	-0.007	0.889	0.039	0.036	0	39.1	38.3	71	125	122	0	34	33
2015	12	14	17	35	10	0.18	-0.03	0.889	0.033	0.03	0	38.7	39.1	70.5	124	124	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	17	45	10	0.223	-0.062	0.889	0.036	0.033	0	39.6	39.1	72.2	126	125	0	34	34
2015	12	14	17	55	10	0.105	-0.085	0.889	0.033	0.03	0	40	40	69.7	127	126	0	34	33
2015	12	14	18	5	10	0.105	-0.046	0.889	0.036	0.033	0	40	39.1	72.2	127	125	0	34	34
2015	12	14	18	15	10	0.115	0	0.889	0.033	0.03	0	40	40	70.5	127	126	0	34	33
2015	12	14	18	25	10	0.167	0.016	0.889	0.039	0.036	0	40	40	72.7	127	126	0	34	33
2015	12	14	18	35	10	0.207	-0.069	0.889	0.033	0.03	0	40.4	40.4	74.8	128	128	0	34	34
2015	12	14	18	45	10	0.108	-0.013	0.889	0.033	0.03	0	40.4	40.9	71.8	128	128	0	34	33
2015	12	14	18	55	10	0.069	0.02	0.889	0.033	0.03	0	40	40	71.8	127	126	0	34	33
2015	12	14	19	5	10	0.128	-0.03	0.889	0.033	0.03	0	39.6	39.1	73.5	126	124	0	34	33
2015	12	14	19	15	10	0.138	-0.085	0.889	0.039	0.039	0	39.1	39.6	72.2	125	126	0	34	34
2015	12	14	19	25	10	0.151	-0.007	0.889	0.033	0.03	0	38.7	39.1	72.7	124	124	0	34	33
2015	12	14	19	35	10	0.22	0	0.889	0.033	0.03	0	39.1	38.7	73.1	125	123	0	34	33
2015	12	14	19	45	10	0.138	-0.062	0.889	0.033	0.03	0	39.1	39.1	73.1	125	124	0	34	33
2015	12	14	19	55	10	0.167	-0.059	0.892	0.036	0.033	0	39.1	38.7	74	125	124	0	34	34
2015	12	14	20	5	10	0.157	-0.062	0.892	0.036	0.033	0	38.3	38.3	75.7	123	122	0	34	33
2015	12	14	20	15	10	0.184	-0.036	0.892	0.033	0.03	0	39.1	38.7	75.7	125	123	0	34	33
2015	12	14	20	25	10	0.135	-0.059	0.892	0.03	0.03	0	38.3	38.3	77.4	123	122	0	34	33
2015	12	14	20	35	10	0.171	-0.102	0.889	0.033	0.03	0	38.7	38.3	74.4	124	122	0	34	33
2015	12	14	20	45	10	0.177	-0.033	0.889	0.033	0.03	0	38.3	37.8	76.1	123	121	0	34	33
2015	12	14	20	55	10	0.125	-0.161	0.889	0.033	0.03	0	37.4	37.8	75.3	122	121	0	35	33
2015	12	14	21	5	10	0.151	-0.108	0.889	0.036	0.033	0	38.3	37.4	75.7	123	120	0	34	33
2015	12	14	21	15	10	0.121	-0.121	0.889	0.033	0.03	0	37.4	36.5	74.4	121	119	0	34	34
2015	12	14	21	25	10	0.148	-0.148	0.889	0.033	0.03	0	37.8	37	74.4	122	120	0	34	34
2015	12	14	21	35	10	0.112	-0.161	0.889	0.036	0.033	0	38.3	37	75.3	122	120	0	33	34
2015	12	14	21	45	10	0.154	-0.177	0.889	0.033	0.03	0	37.4	37.4	74.8	121	121	0	34	34
2015	12	14	21	55	10	0.151	-0.207	0.889	0.033	0.03	0	37.8	37.4	74	122	120	0	34	33
2015	12	14	22	5	10	0.138	-0.223	0.889	0.036	0.033	0	37.4	37.8	75.7	121	121	0	34	33
2015	12	14	22	15	10	0.066	-0.157	0.889	0.033	0.03	0	38.3	37	77	123	120	0	34	34
2015	12	14	22	25	10	0.072	-0.148	0.889	0.036	0.033	0	37.8	37	77	122	120	0	34	34
2015	12	14	22	35	10	0.138	-0.115	0.889	0.03	0.026	0	37.4	37.8	77	121	122	0	34	34
2015	12	14	22	45	10	0.075	-0.082	0.889	0.033	0.03	0	37.8	37	77	122	120	0	34	34
2015	12	14	22	55	10	0.167	-0.046	0.889	0.033	0.03	0	37.8	37.8	77	122	121	0	34	33
2015	12	14	23	5	10	0.085	-0.171	0.889	0.033	0.03	0	37	37.4	76.5	121	121	0	35	34
2015	12	14	23	15	10	0.187	-0.102	0.889	0.033	0.03	0	37.4	37.8	76.5	122	122	0	35	34
2015	12	14	23	25	10	0.174	-0.026	0.889	0.039	0.039	0	37.8	37.4	74.8	121	120	0	33	33
2015	12	14	23	35	10	0.161	-0.056	0.889	0.033	0.03	0	37	37.8	75.7	120	122	0	34	34
2015	12	14	23	45	10	0.259	-0.056	0.889	0.033	0.03	0	37.4	38.3	75.7	121	122	0	34	33
2015	12	14	23	55	10	0.148	-0.026	0.889	0.033	0.03	0	37	37.8	75.3	121	121	0	35	33
2015	12	15	0	5	10	0.148	-0.036	0.889	0.036	0.033	0	37	37.4	76.1	120	121	0	34	34
2015	12	15	0	15	10	0.135	-0.062	0.889	0.039	0.036	0	37.4	37.4	74.4	121	121	0	34	34
2015	12	15	0	25	10	0.174	-0.056	0.889	0.033	0.03	0	37.8	38.3	74.8	122	122	0	34	33
2015	12	15	0	35	10	0.213	-0.043	0.889	0.036	0.033	0	38.7	39.1	76.1	125	124	0	35	33
2015	12	15	0	45	10	0.2	-0.105	0.889	0.036	0.033	0	38.3	37.8	75.7	123	122	0	34	34
2015	12	15	0	55	10	0.167	-0.121	0.889	0.033	0.03	0	37	37.4	76.1	121	121	0	35	34
2015	12	15	1	5	10	0.138	-0.066	0.889	0.033	0.03	0	37.4	38.3	75.7	122	123	0	35	34
2015	12	15	1	15	10	0.161	-0.075	0.889	0.033	0.03	0	37.4	37.8	77	121	122	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	1	25	10	0.144	-0.144	0.886	0.043	0.043	0	37.4	37.4	77	121	121	0	34	34
2015	12	15	1	35	10	0.213	-0.085	0.886	0.033	0.03	0	36.5	37.8	74.8	120	122	0	35	34
2015	12	15	1	45	10	0.161	-0.066	0.886	0.033	0.03	0	37.4	38.3	71.4	122	123	0	35	34
2015	12	15	1	55	10	0.167	-0.069	0.886	0.033	0.03	0	37.8	38.3	72.7	122	122	0	34	33
2015	12	15	2	5	10	0.105	-0.043	0.886	0.033	0.03	0	37.4	38.7	73.1	122	123	0	35	33
2015	12	15	2	15	10	0.135	-0.115	0.886	0.033	0.03	0	38.3	39.6	71.4	124	125	0	35	33
2015	12	15	2	25	10	0.174	-0.066	0.886	0.033	0.03	0	38.7	39.1	71.4	125	125	0	35	34
2015	12	15	2	35	10	0.125	-0.026	0.886	0.033	0.03	0	38.7	40.4	70.5	125	127	0	35	33
2015	12	15	2	45	10	0.197	0	0.886	0.033	0.03	0	40.4	40.4	71	128	127	0	34	33
2015	12	15	2	55	10	0.161	-0.039	0.886	0.033	0.03	0	40	40.4	69.7	127	128	0	34	34
2015	12	15	3	5	10	0.217	-0.036	0.886	0.033	0.03	0	40	40.9	70.5	128	129	0	35	34
2015	12	15	3	15	10	0.125	0.01	0.886	0.036	0.033	0	40	41.3	70.5	128	129	0	35	33
2015	12	15	3	25	10	0.276	-0.007	0.886	0.036	0.033	0	40.4	41.3	73.5	129	129	0	35	33
2015	12	15	3	35	10	0.161	-0.075	0.886	0.039	0.039	0	39.6	39.6	74	127	126	0	35	34
2015	12	15	3	45	10	0.21	-0.069	0.886	0.033	0.03	0	39.1	40.4	74.4	126	127	0	35	33
2015	12	15	3	55	10	0.213	-0.079	0.886	0.033	0.03	0	40.4	39.6	74	128	125	0	34	33
2015	12	15	4	5	10	0.161	0	0.886	0.036	0.033	0	38.3	39.1	74.8	124	125	0	35	34
2015	12	15	4	15	10	0.2	-0.023	0.886	0.033	0.03	0	38.7	39.1	74	125	125	0	35	34
2015	12	15	4	25	10	0.21	0.02	0.883	0.043	0.039	0	37.8	38.3	71.8	123	123	0	35	34
2015	12	15	4	35	10	0.187	-0.079	0.886	0.033	0.03	0	38.3	39.1	74.8	124	125	0	35	34
2015	12	15	4	45	10	0.194	-0.039	0.886	0.039	0.036	0	38.7	37.8	73.5	124	122	0	34	34
2015	12	15	4	55	10	0.148	-0.052	0.883	0.039	0.039	0	37.8	37.8	73.1	122	121	0	34	33
2015	12	15	5	5	10	0.141	-0.046	0.883	0.033	0.03	0	37	37.4	74.4	121	121	0	35	34
2015	12	15	5	15	10	0.184	-0.039	0.886	0.033	0.03	0	37.8	37.8	73.1	123	122	0	35	34
2015	12	15	5	25	10	0.246	-0.062	0.886	0.033	0.03	0	37.4	37.4	74.4	122	121	0	35	34
2015	12	15	5	35	10	0.207	-0.138	0.883	0.039	0.036	0	37	37	74.4	121	120	0	35	34
2015	12	15	5	45	10	0.105	-0.095	0.883	0.033	0.03	0	37.4	37.4	71.4	122	121	0	35	34
2015	12	15	5	55	10	0.148	-0.049	0.883	0.043	0.039	0	37.4	37.4	73.1	122	121	0	35	34
2015	12	15	6	5	10	0.249	-0.069	0.883	0.033	0.03	0	37.4	37	74.4	122	121	0	35	35
2015	12	15	6	15	10	0.157	-0.121	0.883	0.033	0.03	0	37.4	37.4	74.8	121	121	0	34	34
2015	12	15	6	25	10	0.213	-0.059	0.883	0.039	0.036	0	37	37	72.2	121	120	0	35	34
2015	12	15	6	35	10	0.164	-0.082	0.883	0.036	0.033	0	37.4	37	73.1	122	120	0	35	34
2015	12	15	6	45	10	0.112	-0.059	0.883	0.033	0.03	0	37.8	38.3	70.5	123	122	0	35	33
2015	12	15	6	55	10	0.167	-0.056	0.883	0.033	0.03	0	37.8	37.8	71.8	122	122	0	34	34
2015	12	15	7	5	10	0.128	-0.121	0.883	0.033	0.03	0	37	37	72.2	121	120	0	35	34
2015	12	15	7	15	10	0.203	-0.056	0.883	0.036	0.033	0	37	37	73.5	121	120	0	35	34
2015	12	15	7	25	10	0.164	-0.144	0.879	0.033	0.03	0	36.5	36.1	72.7	120	118	0	35	34
2015	12	15	7	35	10	0.167	-0.039	0.879	0.036	0.033	0	37	37	73.1	121	120	0	35	34
2015	12	15	7	45	10	0.157	-0.052	0.883	0.033	0.03	0	37.4	37	71.8	121	120	0	34	34
2015	12	15	7	55	10	0.167	-0.003	0.879	0.033	0.03	0	40.4	40	67.5	129	127	0	35	34
2015	12	15	8	5	10	0.125	0	0.879	0.046	0.043	0	38.3	38.3	71	124	123	0	35	34
2015	12	15	8	15	10	0.131	-0.036	0.879	0.036	0.033	0	37.8	37.8	72.7	123	122	0	35	34
2015	12	15	8	25	10	0.118	-0.036	0.879	0.033	0.03	0	37.8	37.4	71	123	121	0	35	34
2015	12	15	8	35	10	0.194	-0.046	0.879	0.039	0.039	0	38.3	37.8	70.1	124	122	0	35	34
2015	12	15	8	45	10	0.167	-0.062	0.879	0.033	0.03	0	38.3	37.8	68.8	124	122	0	35	34
2015	12	15	8	55	10	0.125	-0.03	0.879	0.033	0.03	0	38.3	37.8	71.8	124	122	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	9	5	10	0.223	0.013	0.879	0.036	0.033	0	38.3	38.7	72.2	124	124	0	35	34
2015	12	15	9	15	10	0.171	-0.039	0.879	0.033	0.03	0	38.7	39.1	69.2	125	124	0	35	33
2015	12	15	9	25	10	0.108	0.02	0.879	0.036	0.033	0	38.7	38.7	71	125	124	0	35	34
2015	12	15	9	35	10	0.187	-0.062	0.879	0.036	0.033	0	39.6	38.7	71.4	127	124	0	35	34
2015	12	15	9	45	10	0.108	-0.052	0.879	0.043	0.039	0	39.1	39.1	70.1	126	125	0	35	34
2015	12	15	9	55	10	0.194	0.052	0.879	0.036	0.033	0	40	40	69.7	128	127	0	35	34
2015	12	15	10	5	10	0.161	-0.092	0.879	0.036	0.033	0	42.6	41.3	67.9	134	131	0	35	35
2015	12	15	10	15	10	0.148	-0.056	0.879	0.039	0.036	0	41.7	42.6	67.1	132	133	0	35	34
2015	12	15	10	25	10	0.089	-0.066	0.879	0.036	0.033	0	43.4	43.4	66.2	136	135	0	35	34
2015	12	15	10	35	10	0.253	-0.072	0.879	0.036	0.033	0	43	43	67.1	135	134	0	35	34
2015	12	15	10	45	10	0.118	-0.092	0.876	0.039	0.036	0	48.6	48.2	61.9	148	146	0	35	34
2015	12	15	10	55	10	0.144	0.033	0.876	0.043	0.039	0	49	49	60.6	149	148	0	35	34
2015	12	15	11	5	10	0.161	-0.049	0.876	0.039	0.039	0	46.4	45.6	64.5	142	141	0	34	35
2015	12	15	11	15	10	0.177	-0.026	0.873	0.039	0.036	0	47.3	46.4	62.8	145	142	0	35	34
2015	12	15	11	25	10	0.174	-0.007	0.876	0.043	0.039	0	52	50.7	58.5	155	152	0	34	34
2015	12	15	11	35	10	0.171	-0.026	0.876	0.036	0.033	0	48.2	48.2	62.4	147	146	0	35	34
2015	12	15	11	45	10	0.174	-0.033	0.876	0.043	0.039	0	51.2	50.3	58.9	153	151	0	34	34
2015	12	15	11	55	10	0.171	0.023	0.873	0.033	0.03	0	51.6	50.7	59.8	154	152	0	34	34
2015	12	15	12	5	10	0.069	0	0.873	0.036	0.033	0	52.9	52.5	56.8	157	156	0	34	34
2015	12	15	12	15	10	0.171	-0.039	0.873	0.039	0.036	0	50.3	50.3	60.2	152	151	0	35	34
2015	12	15	12	25	10	0.213	-0.066	0.876	0.033	0.033	0	49.5	49.5	59.3	150	148	0	35	33
2015	12	15	12	35	10	0.2	0.01	0.876	0.043	0.039	0	49.9	49	61.1	151	148	0	35	34
2015	12	15	12	45	10	0.115	-0.013	0.876	0.033	0.03	0	49.5	49	62.8	150	148	0	35	34
2015	12	15	12	55	10	0.213	-0.079	0.876	0.036	0.033	0	50.3	49.9	61.9	152	150	0	35	34
2015	12	15	13	5	10	0.118	0.007	0.876	0.039	0.039	0	50.3	49.9	61.9	152	149	0	35	33
2015	12	15	13	15	10	0.154	-0.023	0.879	0.039	0.036	0	49.5	49.9	62.8	149	149	0	34	33
2015	12	15	13	25	10	0.164	-0.026	0.879	0.036	0.033	0	49.9	49.5	65.4	150	148	0	34	33
2015	12	15	13	35	10	0.203	0.016	0.879	0.036	0.033	0	49.5	49.5	66.2	150	149	0	35	34
2015	12	15	13	45	10	0.161	0.033	0.876	0.033	0.03	0	51.2	50.3	61.5	153	151	0	34	34
2015	12	15	13	55	10	0.19	0.023	0.876	0.036	0.033	0	49.9	49	62.8	150	148	0	34	34
2015	12	15	14	5	10	0.194	-0.003	0.876	0.033	0.03	0	50.3	49	61.5	151	148	0	34	34
2015	12	15	14	15	10	0.171	0.039	0.879	0.033	0.03	0	49.5	49.5	64.9	149	148	0	34	33
2015	12	15	14	25	10	0.187	0.049	0.879	0.036	0.033	0	49	48.2	65.8	148	146	0	34	34
2015	12	15	14	35	10	0.164	0.023	0.879	0.036	0.033	0	48.2	49	64.5	147	147	0	35	33
2015	12	15	14	45	10	0.161	-0.043	0.879	0.033	0.03	0	48.6	48.6	64.1	148	147	0	35	34
2015	12	15	14	55	10	0.226	0.02	0.879	0.033	0.03	0	49	48.2	63.2	148	146	0	34	34
2015	12	15	15	5	10	0.22	0.013	0.879	0.036	0.033	0	48.2	48.2	64.9	146	146	0	34	34
2015	12	15	15	15	10	0.233	-0.013	0.879	0.033	0.03	0	48.2	48.2	68.8	146	145	0	34	33
2015	12	15	15	25	10	0.19	-0.013	0.879	0.039	0.039	0	46.9	47.3	67.9	144	143	0	35	33
2015	12	15	15	35	10	0.151	0	0.879	0.039	0.036	0	46.4	46.4	69.2	142	141	0	34	33
2015	12	15	15	45	10	0.197	0.026	0.879	0.043	0.039	0	44.7	44.7	69.7	139	138	0	35	34
2015	12	15	15	55	10	0.223	-0.033	0.879	0.033	0.03	0	43.9	44.3	69.7	136	136	0	34	33
2015	12	15	16	5	10	0.19	0.003	0.879	0.039	0.036	0	43	42.6	71.8	134	133	0	34	34
2015	12	15	16	15	10	0.236	0.03	0.883	0.033	0.03	0	41.7	41.3	74	131	130	0	34	34
2015	12	15	16	25	10	0.194	0.013	0.883	0.039	0.036	0	40.9	40.4	74	130	128	0	35	34
2015	12	15	16	35	10	0.249	-0.043	0.883	0.039	0.036	0	40.4	40.4	74.4	129	127	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	16	45	10	0.207	0	0.883	0.036	0.033	0	40	39.6	75.3	128	126	0	35	34
2015	12	15	16	55	10	0.135	-0.062	0.883	0.033	0.03	0	40	39.1	74.4	127	125	0	34	34
2015	12	15	17	5	10	0.24	0.007	0.883	0.033	0.03	0	38.7	39.1	74.4	125	125	0	35	34
2015	12	15	17	15	10	0.174	0.023	0.883	0.043	0.039	0	38.7	38.3	74.4	124	123	0	34	34
2015	12	15	17	25	10	0.19	-0.023	0.883	0.036	0.033	0	38.3	37.8	75.3	124	122	0	35	34
2015	12	15	17	35	10	0.217	-0.056	0.883	0.039	0.039	0	37.8	37.8	75.7	123	122	0	35	34
2015	12	15	17	45	10	0.259	-0.046	0.883	0.036	0.033	0	37.8	38.3	75.7	123	122	0	35	33
2015	12	15	17	55	10	0.164	-0.013	0.883	0.039	0.036	0	37.4	37.4	76.1	122	121	0	35	34
2015	12	15	18	5	10	0.144	-0.066	0.883	0.039	0.036	0	37.4	37.4	75.3	122	121	0	35	34
2015	12	15	18	15	10	0.217	-0.02	0.883	0.043	0.039	0	37.8	37.4	76.5	122	120	0	34	33
2015	12	15	18	25	10	0.194	0.01	0.883	0.036	0.033	0	37.4	36.5	76.5	121	119	0	34	34
2015	12	15	18	35	10	0.171	0.066	0.883	0.039	0.036	0	36.5	37	76.1	120	119	0	35	33
2015	12	15	18	45	10	0.141	-0.046	0.883	0.036	0.033	0	35.7	35.7	76.5	118	117	0	35	34
2015	12	15	18	55	10	0.164	-0.039	0.883	0.033	0.03	0	36.1	35.7	77	119	117	0	35	34
2015	12	15	19	5	10	0.164	-0.013	0.883	0.033	0.03	0	35.7	35.7	76.5	118	117	0	35	34
2015	12	15	19	15	10	0.135	-0.023	0.883	0.046	0.043	0	35.7	35.3	75.7	118	116	0	35	34
2015	12	15	19	25	10	0.144	-0.039	0.883	0.036	0.033	0	36.1	35.7	75.7	119	116	0	35	33
2015	12	15	19	35	10	0.187	0.033	0.883	0.036	0.033	0	35.7	34.8	76.1	117	115	0	34	34
2015	12	15	19	45	10	0.128	-0.049	0.883	0.036	0.033	0	34.8	34.8	76.5	116	115	0	35	34
2015	12	15	19	55	10	0.144	-0.059	0.883	0.036	0.033	0	35.7	34.8	77	117	115	0	34	34
2015	12	15	20	5	10	0.21	-0.072	0.883	0.03	0.03	0	35.3	34.8	78.3	117	116	0	35	35
2015	12	15	20	15	10	0.098	-0.026	0.883	0.036	0.033	0	34.8	34.8	77.4	116	115	0	35	34
2015	12	15	20	25	10	0.177	0	0.883	0.036	0.033	0	34.4	34.4	77.4	115	114	0	35	34
2015	12	15	20	35	10	0.121	-0.102	0.883	0.033	0.03	0	34.8	33.5	77.4	116	113	0	35	35
2015	12	15	20	45	10	0.102	-0.039	0.883	0.033	0.03	0	34.4	34.4	76.5	115	114	0	35	34
2015	12	15	20	55	10	0.098	-0.082	0.883	0.036	0.033	0	34.4	33.5	77.4	114	112	0	34	34
2015	12	15	21	5	10	0.118	-0.075	0.883	0.043	0.039	0	34	34.4	77	114	113	0	35	33
2015	12	15	21	15	10	0.138	-0.102	0.883	0.033	0.03	0	34.4	34	77	114	113	0	34	34
2015	12	15	21	25	10	0.046	-0.095	0.883	0.036	0.033	0	34.4	34	76.1	114	113	0	34	34
2015	12	15	21	35	10	0.167	-0.056	0.883	0.033	0.03	0	34	34.4	75.7	114	113	0	35	33
2015	12	15	21	45	10	0.108	-0.072	0.883	0.033	0.03	0	34.8	33.5	75.7	116	113	0	35	35
2015	12	15	21	55	10	0.092	-0.023	0.883	0.043	0.039	0	35.3	34.8	74.8	116	115	0	34	34
2015	12	15	22	5	10	0.105	-0.167	0.883	0.033	0.03	0	34.8	34.4	75.7	116	114	0	35	34
2015	12	15	22	15	10	0.161	-0.052	0.886	0.033	0.03	0	35.3	34.4	76.5	116	115	0	34	35
2015	12	15	22	25	10	0.105	-0.125	0.886	0.039	0.036	0	34.8	34.8	77.8	116	116	0	35	35
2015	12	15	22	35	10	0.141	-0.069	0.886	0.033	0.03	0	35.7	34.8	77	118	115	0	35	34
2015	12	15	22	45	10	0.171	-0.059	0.886	0.033	0.03	0	36.1	35.3	77	118	116	0	34	34
2015	12	15	22	55	10	0.184	-0.075	0.886	0.039	0.036	0	35.7	34.4	76.1	117	115	0	34	35
2015	12	15	23	5	10	0.207	-0.144	0.886	0.033	0.03	0	35.3	34.8	75.3	116	115	0	34	34
2015	12	15	23	15	10	0.184	-0.066	0.886	0.033	0.03	0	34.8	34.4	74.8	116	114	0	35	34
2015	12	15	23	25	10	0.066	-0.052	0.886	0.036	0.033	0	34.8	34.4	75.7	116	114	0	35	34
2015	12	15	23	35	10	0.092	0.01	0.886	0.033	0.03	0	34.8	34.4	77.8	116	114	0	35	34
2015	12	15	23	45	10	0.098	-0.062	0.886	0.036	0.033	0	35.7	34.4	77	117	114	0	34	34
2015	12	15	23	55	10	0.069	0.026	0.886	0.039	0.036	0	35.7	34.8	77.4	117	115	0	34	34
2015	12	16	0	5	10	0.105	0.079	0.886	0.033	0.033	0	35.3	34.4	77.8	117	114	0	35	34
2015	12	16	0	15	10	0.115	-0.108	0.886	0.036	0.033	0	35.3	34	77.8	116	113	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	0	25	10	-0.03	-0.046	0.886	0.033	0.03	0	34.4	34.4	77.4	115	114	0	35	34
2015	12	16	0	35	10	0.131	-0.039	0.886	0.039	0.036	0	34.4	34	77.8	115	113	0	35	34
2015	12	16	0	45	10	0.066	-0.105	0.886	0.033	0.03	0	34.8	33.1	78.3	115	111	0	34	34
2015	12	16	0	55	10	0.18	-0.059	0.886	0.033	0.03	0	33.5	33.1	77.8	113	111	0	35	34
2015	12	16	1	5	10	0.148	0	0.886	0.039	0.036	0	34	32.7	77.4	113	110	0	34	34
2015	12	16	1	15	10	0.167	-0.056	0.886	0.033	0.033	0	33.5	32.7	77.4	113	111	0	35	35
2015	12	16	1	25	10	0.089	-0.062	0.886	0.03	0.03	0	33.5	33.5	73.1	113	112	0	35	34
2015	12	16	1	35	10	0.131	-0.085	0.886	0.046	0.046	0	33.1	33.1	75.3	112	111	0	35	34
2015	12	16	1	45	10	0.138	-0.043	0.886	0.033	0.03	0	33.5	33.5	75.3	113	112	0	35	34
2015	12	16	1	55	10	0.069	-0.033	0.886	0.039	0.036	0	33.5	33.1	74	112	111	0	34	34
2015	12	16	2	5	10	0.141	-0.072	0.886	0.036	0.033	0	33.5	34	75.3	113	113	0	35	34
2015	12	16	2	15	10	0.125	0.026	0.886	0.033	0.03	0	33.5	34	74.8	113	113	0	35	34
2015	12	16	2	25	10	0.128	-0.075	0.886	0.033	0.03	0	33.1	34	74.8	112	113	0	35	34
2015	12	16	2	35	10	0.089	-0.046	0.886	0.033	0.03	0	33.5	33.5	75.3	113	113	0	35	35
2015	12	16	2	45	10	0.144	-0.013	0.886	0.033	0.03	0	34	34	74.8	113	113	0	34	34
2015	12	16	2	55	10	0.118	-0.026	0.886	0.03	0.026	0	34.4	33.5	72.2	115	113	0	35	35
2015	12	16	3	5	10	0.167	-0.066	0.886	0.033	0.03	0	34	33.5	71.8	114	112	0	35	34
2015	12	16	3	15	10	0.121	-0.043	0.886	0.033	0.03	0	34	34.4	74	114	113	0	35	33
2015	12	16	3	25	10	0.144	-0.046	0.886	0.033	0.03	0	34	34	74.4	114	113	0	35	34
2015	12	16	3	35	10	0.098	-0.066	0.886	0.033	0.03	0	33.5	33.1	73.1	113	112	0	35	35
2015	12	16	3	45	10	0.171	-0.033	0.886	0.039	0.036	0	33.5	33.5	72.7	113	112	0	35	34
2015	12	16	3	55	10	0.21	0	0.886	0.033	0.03	0	34	33.5	73.1	114	112	0	35	34
2015	12	16	4	5	10	0.131	-0.049	0.886	0.046	0.043	0	33.5	33.5	74	113	112	0	35	34
2015	12	16	4	15	10	0.125	-0.013	0.886	0.03	0.026	0	33.5	33.5	75.7	113	112	0	35	34
2015	12	16	4	25	10	0.148	-0.079	0.886	0.033	0.03	0	33.5	33.5	76.1	113	112	0	35	34
2015	12	16	4	35	10	0.157	-0.075	0.886	0.033	0.03	0	33.5	33.5	77	113	112	0	35	34
2015	12	16	4	45	10	0.23	-0.036	0.886	0.033	0.03	0	34	33.5	77	114	112	0	35	34
2015	12	16	4	55	10	0.135	-0.092	0.886	0.033	0.03	0	34	33.5	76.5	114	112	0	35	34
2015	12	16	5	5	10	0.174	-0.092	0.886	0.033	0.03	0	34	32.7	77	114	111	0	35	35
2015	12	16	5	15	10	0.151	-0.062	0.886	0.033	0.03	0	34	32.7	77	113	110	0	34	34
2015	12	16	5	25	10	0.148	0	0.886	0.036	0.033	0	33.5	32.3	77	113	110	0	35	35
2015	12	16	5	35	10	0.118	-0.069	0.886	0.033	0.03	0	33.5	32.3	77.4	113	109	0	35	34
2015	12	16	5	45	10	0.125	0.003	0.886	0.03	0.026	0	33.1	32.3	77.4	112	109	0	35	34
2015	12	16	5	55	10	0.059	0	0.886	0.046	0.043	0	33.1	32.3	77	112	109	0	35	34
2015	12	16	6	5	10	0.194	-0.052	0.886	0.033	0.03	0	33.1	31.8	76.5	112	109	0	35	35
2015	12	16	6	15	10	0.105	-0.043	0.886	0.033	0.03	0	33.5	32.3	77	112	109	0	34	34
2015	12	16	6	25	10	0.164	0.007	0.886	0.033	0.03	0	32.7	31.8	77	111	108	0	35	34
2015	12	16	6	35	10	0.174	-0.013	0.886	0.039	0.039	0	32.7	31.4	77	111	108	0	35	35
2015	12	16	6	45	10	0.194	-0.066	0.886	0.036	0.033	0	33.1	31.8	77.4	112	109	0	35	35
2015	12	16	6	55	10	0.138	-0.052	0.886	0.033	0.03	0	33.5	32.3	77.4	113	109	0	35	34
2015	12	16	7	5	10	0.164	0	0.886	0.046	0.043	0	33.1	32.3	76.5	112	109	0	35	34
2015	12	16	7	15	10	0.148	0.013	0.886	0.046	0.043	0	33.1	31.8	77	112	108	0	35	34
2015	12	16	7	25	10	0.115	-0.036	0.886	0.039	0.036	0	32.7	31.4	77	111	108	0	35	35
2015	12	16	7	35	10	0.213	-0.072	0.886	0.033	0.03	0	33.1	31.8	77	112	108	0	35	34
2015	12	16	7	45	10	0.18	-0.049	0.886	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	16	7	55	10	0.138	-0.013	0.886	0.033	0.03	0	33.1	32.3	77.4	112	109	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	8	5	10	0.197	-0.033	0.886	0.036	0.033	0	33.5	32.7	77	113	110	0	35	34
2015	12	16	8	15	10	0.095	-0.033	0.886	0.039	0.036	0	33.5	32.3	77.4	114	110	0	36	35
2015	12	16	8	25	10	0.112	-0.069	0.886	0.039	0.036	0	34.4	32.7	77.4	115	110	0	35	34
2015	12	16	8	35	10	0.184	-0.039	0.886	0.033	0.03	0	34	33.1	77.4	114	111	0	35	34
2015	12	16	8	45	10	0.164	-0.016	0.886	0.033	0.03	0	34.4	33.1	77	115	111	0	35	34
2015	12	16	8	55	10	0.164	-0.033	0.886	0.033	0.03	0	35.3	33.5	77.4	117	112	0	35	34
2015	12	16	9	5	10	0.131	-0.066	0.886	0.036	0.033	0	36.1	33.5	77.4	118	112	0	34	34
2015	12	16	9	15	10	0.023	0.033	0.886	0.026	0.026	0	37	34.4	77.8	121	113	0	35	33
2015	12	16	9	25	10	-0.033	0.026	0.886	0.036	0.033	0	36.5	33.5	77.4	119	113	0	34	35
2015	12	16	9	35	10	0	-0.039	0.886	0.03	0.026	0	35.7	34.4	77.4	118	114	0	35	34
2015	12	16	9	45	10	0.056	-0.039	0.886	0.033	0.03	0	34	34	77.8	114	113	0	35	34
2015	12	16	9	55	10	0.21	-0.105	0.886	0.033	0.03	0	34	34.4	77.4	114	114	0	35	34
2015	12	16	10	5	10	0.171	-0.007	0.883	0.043	0.039	0	52.9	46.4	53.8	158	142	0	35	34
2015	12	16	10	15	10	0.187	-0.046	0.889	0.036	0.033	0	34.4	34.4	76.1	115	114	0	35	34
2015	12	16	10	25	10	0.207	-0.066	0.889	0.036	0.033	0	34.4	34.4	76.1	115	114	0	35	34
2015	12	16	10	35	10	0.203	-0.098	0.886	0.033	0.03	0	34.4	35.3	76.5	115	116	0	35	34
2015	12	16	10	45	10	0.151	-0.013	0.886	0.033	0.03	0	34.8	35.3	77.4	116	116	0	35	34
2015	12	16	10	55	10	0.148	-0.023	0.886	0.039	0.039	0	34.4	34.8	76.5	115	115	0	35	34
2015	12	16	11	5	10	0.118	-0.016	0.886	0.036	0.033	0	35.3	34.4	77.8	116	115	0	34	35
2015	12	16	11	15	10	0.105	-0.02	0.886	0.033	0.03	0	35.3	35.3	77	116	116	0	34	34
2015	12	16	11	25	10	0.121	-0.007	0.886	0.033	0.03	0	35.3	34.8	77.8	116	115	0	34	34
2015	12	16	11	35	10	0.151	-0.056	0.886	0.033	0.03	0	35.3	34.8	77.4	116	115	0	34	34
2015	12	16	11	45	10	0.24	-0.151	0.886	0.033	0.03	0	35.3	35.3	77.4	117	116	0	35	34
2015	12	16	11	55	10	0.157	-0.039	0.886	0.033	0.03	0	34.8	34.8	77.4	116	115	0	35	34
2015	12	16	12	5	10	0.226	-0.079	0.886	0.033	0.03	0	35.7	35.3	77.4	117	116	0	34	34
2015	12	16	12	15	10	0.157	-0.046	0.886	0.03	0.03	0	35.3	34.8	77.4	116	115	0	34	34
2015	12	16	12	25	10	0.174	-0.03	0.886	0.039	0.036	0	34.8	34.8	78.3	116	115	0	35	34
2015	12	16	12	35	10	0.131	-0.007	0.886	0.036	0.033	0	34.8	35.3	77.8	116	116	0	35	34
2015	12	16	12	45	10	0.148	-0.075	0.886	0.039	0.039	0	35.7	35.3	77.8	117	116	0	34	34
2015	12	16	12	55	10	0.18	-0.007	0.886	0.036	0.033	0	35.3	36.1	77.8	117	118	0	35	34
2015	12	16	13	5	10	0.154	0	0.886	0.043	0.039	0	37	37	77.4	120	120	0	34	34
2015	12	16	13	15	10	0.203	-0.121	0.886	0.036	0.033	0	37	37	77.4	120	120	0	34	34
2015	12	16	13	25	10	0.213	-0.066	0.886	0.033	0.03	0	36.5	35.3	77.8	119	117	0	34	35
2015	12	16	13	35	10	0.164	-0.121	0.886	0.033	0.03	0	36.5	36.5	77.8	120	119	0	35	34
2015	12	16	13	45	10	0.148	-0.148	0.886	0.039	0.039	0	37	37	77.4	121	120	0	35	34
2015	12	16	13	55	10	0.213	-0.105	0.886	0.043	0.039	0	37	37.4	77.4	120	120	0	34	33
2015	12	16	14	5	10	0.174	-0.105	0.886	0.039	0.039	0	37.4	37	77.4	121	120	0	34	34
2015	12	16	14	15	10	0.236	-0.131	0.886	0.039	0.036	0	37.4	37	77.8	121	120	0	34	34
2015	12	16	14	25	10	0.148	-0.066	0.886	0.033	0.03	0	37	37	77.4	120	120	0	34	34
2015	12	16	14	35	10	0.118	-0.102	0.886	0.03	0.03	0	36.5	36.1	78.3	120	119	0	35	35
2015	12	16	14	45	10	0.203	-0.148	0.886	0.036	0.033	0	37	36.5	77.8	120	119	0	34	34
2015	12	16	14	55	10	0.243	-0.052	0.886	0.039	0.039	0	37	36.5	78.3	121	119	0	35	34
2015	12	16	15	5	10	0.246	-0.003	0.886	0.033	0.03	0	37	36.5	78.3	120	118	0	34	33
2015	12	16	15	15	10	0.23	-0.112	0.886	0.036	0.033	0	36.5	36.1	77.8	119	118	0	34	34
2015	12	16	15	25	10	0.2	-0.141	0.886	0.036	0.033	0	37	36.1	77.8	120	118	0	34	34
2015	12	16	15	35	10	0.197	-0.135	0.886	0.039	0.039	0	37	36.1	78.3	120	118	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	15	45	10	0.187	-0.105	0.886	0.033	0.03	0	36.5	36.1	78.3	120	118	0	35	34
2015	12	16	15	55	10	0.262	-0.01	0.886	0.036	0.033	0	36.5	36.1	78.3	119	117	0	34	33
2015	12	16	16	5	10	0.226	-0.082	0.886	0.036	0.033	0	36.1	35.7	78.3	118	117	0	34	34
2015	12	16	16	15	10	0.23	-0.105	0.886	0.036	0.033	0	35.3	35.3	78.3	117	115	0	35	33
2015	12	16	16	25	10	0.213	-0.121	0.886	0.039	0.036	0	35.3	34.4	78.3	117	115	0	35	35
2015	12	16	16	35	10	0.23	-0.069	0.886	0.049	0.049	0	36.1	34.8	79.1	118	115	0	34	34
2015	12	16	16	45	10	0.269	-0.013	0.886	0.036	0.033	0	35.3	34.4	78.7	117	114	0	35	34
2015	12	16	16	55	10	0.171	-0.059	0.886	0.043	0.039	0	35.3	34.8	78.3	117	115	0	35	34
2015	12	16	17	5	10	0.23	-0.141	0.886	0.043	0.039	0	34.8	35.3	78.7	116	115	0	35	33
2015	12	16	17	15	10	0.213	-0.033	0.886	0.049	0.046	0	35.7	35.3	78.7	117	115	0	34	33
2015	12	16	17	25	10	0.154	-0.039	0.886	0.033	0.03	0	35.7	35.3	78.7	117	115	0	34	33
2015	12	16	17	35	10	0.131	0.056	0.886	0.033	0.03	0	35.7	35.3	78.7	118	116	0	35	34
2015	12	16	17	45	10	0.112	-0.023	0.886	0.033	0.03	0	35.7	34.8	78.7	117	115	0	34	34
2015	12	16	17	55	10	0.118	0.039	0.886	0.039	0.036	0	35.3	35.7	79.1	116	116	0	34	33
2015	12	16	18	5	10	0.177	-0.013	0.886	0.036	0.033	0	35.3	34.8	78.7	116	115	0	34	34
2015	12	16	18	15	10	0.089	-0.026	0.886	0.039	0.036	0	34.8	34.8	79.1	116	115	0	35	34
2015	12	16	18	25	10	0.161	0	0.886	0.033	0.03	0	35.3	34.8	79.1	116	115	0	34	34
2015	12	16	18	35	10	0.177	0.043	0.886	0.033	0.03	0	34.8	35.3	78.7	115	115	0	34	33
2015	12	16	18	45	10	0.151	0.01	0.886	0.033	0.03	0	35.3	34.4	79.1	116	114	0	34	34
2015	12	16	18	55	10	0.269	-0.01	0.886	0.033	0.03	0	34.8	34	79.1	115	113	0	34	34
2015	12	16	19	5	10	0.171	-0.052	0.886	0.033	0.03	0	34	33.5	78.7	113	112	0	34	34
2015	12	16	19	15	10	0.157	-0.01	0.889	0.039	0.036	0	33.5	33.5	79.1	113	112	0	35	34
2015	12	16	19	25	10	0.203	-0.108	0.889	0.033	0.03	0	33.5	33.1	79.1	112	111	0	34	34
2015	12	16	19	35	10	0.148	-0.046	0.886	0.039	0.036	0	33.1	33.5	79.1	112	111	0	35	33
2015	12	16	19	45	10	0.108	0.03	0.889	0.033	0.03	0	33.1	32.7	79.1	111	110	0	34	34
2015	12	16	19	55	10	0.203	-0.036	0.886	0.036	0.033	0	33.1	33.1	79.1	111	111	0	34	34
2015	12	16	20	5	10	0.24	-0.023	0.889	0.033	0.03	0	34.4	34	78.7	114	112	0	34	33
2015	12	16	20	15	10	0.148	-0.016	0.889	0.036	0.033	0	33.5	34.4	78.7	112	113	0	34	33
2015	12	16	20	25	10	0.24	-0.118	0.889	0.036	0.033	0	32.7	32.3	79.1	111	109	0	35	34
2015	12	16	20	35	10	0.266	-0.026	0.889	0.039	0.036	0	33.1	32.7	79.1	111	110	0	34	34
2015	12	16	20	45	10	0.24	-0.052	0.889	0.036	0.033	0	32.7	32.7	79.6	110	109	0	34	33
2015	12	16	20	55	10	0.21	-0.089	0.889	0.033	0.03	0	32.3	32.7	79.6	109	109	0	34	33
2015	12	16	21	5	10	0.197	-0.075	0.889	0.039	0.036	0	32.7	32.3	78.7	110	109	0	34	34
2015	12	16	21	15	10	0.226	-0.177	0.886	0.033	0.03	0	32.3	31.8	78.7	109	108	0	34	34
2015	12	16	21	25	10	0.246	-0.138	0.886	0.039	0.036	0	32.7	31.4	79.1	110	107	0	34	34
2015	12	16	21	35	10	0.299	-0.164	0.886	0.036	0.033	0	31.4	32.3	78.7	108	109	0	35	34
2015	12	16	21	45	10	0.269	-0.138	0.886	0.033	0.03	0	31.8	31.8	78.7	109	108	0	35	34
2015	12	16	21	55	10	0.308	-0.085	0.886	0.039	0.036	0	31.4	32.3	79.1	108	109	0	35	34
2015	12	16	22	5	10	0.24	-0.085	0.886	0.036	0.033	0	32.3	32.3	79.1	109	109	0	34	34
2015	12	16	22	15	10	0.23	-0.069	0.886	0.036	0.033	0	31.8	32.3	79.1	108	109	0	34	34
2015	12	16	22	25	10	0.213	-0.013	0.886	0.036	0.033	0	31.4	31.8	79.1	108	108	0	35	34
2015	12	16	22	35	10	0.148	0.039	0.886	0.043	0.039	0	31.4	32.3	78.3	108	109	0	35	34
2015	12	16	22	45	10	0.105	-0.056	0.886	0.039	0.039	0	32.3	31.8	79.1	109	108	0	34	34
2015	12	16	22	55	10	0.138	-0.092	0.886	0.036	0.033	0	31.8	31.4	79.1	108	107	0	34	34
2015	12	16	23	5	10	0.184	-0.046	0.886	0.033	0.03	0	31.8	31.4	79.1	108	107	0	34	34
2015	12	16	23	15	10	0.269	-0.18	0.886	0.039	0.036	0	31.4	31.8	79.1	107	108	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	23	25	10	0.207	-0.033	0.886	0.039	0.036	0	31.8	31.8	78.7	108	108	0	34	34
2015	12	16	23	35	10	0.404	-0.226	0.886	0.033	0.03	0	31.8	32.3	78.7	108	109	0	34	34
2015	12	16	23	45	10	0.351	-0.21	0.886	0.036	0.033	0	31	32.7	78.7	107	109	0	35	33
2015	12	16	23	55	10	0.243	-0.105	0.886	0.043	0.039	0	31.4	32.7	78.7	108	110	0	35	34
2015	12	17	0	5	10	0.276	-0.207	0.886	0.036	0.033	0	31.4	33.1	78.3	108	111	0	35	34
2015	12	17	0	15	10	0.187	-0.135	0.886	0.039	0.039	0	31.4	32.7	78.7	108	110	0	35	34
2015	12	17	0	25	10	0.24	-0.157	0.886	0.03	0.03	0	31.4	33.1	78.3	108	111	0	35	34
2015	12	17	0	35	10	0.036	0.105	0.886	0.039	0.036	0	31.8	33.5	78.3	109	111	0	35	33
2015	12	17	0	45	10	-0.066	0.066	0.886	0.036	0.033	0	32.7	32.7	78.3	110	110	0	34	34
2015	12	17	0	55	10	0.157	-0.056	0.886	0.036	0.033	0	31.8	33.1	78.7	109	111	0	35	34
2015	12	17	1	5	10	0.295	-0.2	0.886	0.036	0.033	0	31.8	33.1	78.3	108	110	0	34	33
2015	12	17	1	15	10	0.292	-0.112	0.886	0.033	0.03	0	32.3	33.1	78.3	109	111	0	34	34
2015	12	17	1	25	10	0.246	-0.115	0.886	0.036	0.033	0	32.7	33.1	78.3	110	111	0	34	34
2015	12	17	1	35	10	0.197	-0.135	0.886	0.036	0.033	0	31.8	33.5	78.3	109	112	0	35	34
2015	12	17	1	45	10	0.302	-0.095	0.886	0.039	0.036	0	32.3	33.1	77.8	109	111	0	34	34
2015	12	17	1	55	10	0.131	0.03	0.886	0.033	0.03	0	31.8	32.7	78.3	109	111	0	35	35
2015	12	17	2	5	10	0.21	-0.164	0.886	0.033	0.03	0	32.3	32.7	77.8	110	110	0	35	34
2015	12	17	2	15	10	0.266	-0.092	0.886	0.036	0.033	0	32.3	32.3	77.8	110	109	0	35	34
2015	12	17	2	25	10	0.144	0	0.886	0.033	0.03	0	31.8	31.8	77.8	109	109	0	35	35
2015	12	17	2	35	10	0.18	-0.033	0.886	0.03	0.03	0	31.8	32.7	78.3	109	109	0	35	33
2015	12	17	2	45	10	0.253	-0.062	0.886	0.033	0.03	0	31.8	33.1	77.8	109	110	0	35	33
2015	12	17	2	55	10	0.105	0.003	0.886	0.039	0.036	0	31.8	32.3	78.3	109	109	0	35	34
2015	12	17	3	5	10	0.144	-0.092	0.886	0.036	0.033	0	31.8	31.8	77.8	109	108	0	35	34
2015	12	17	3	15	10	0.105	0	0.886	0.033	0.03	0	31.8	33.1	77	109	111	0	35	34
2015	12	17	3	25	10	0.167	-0.062	0.886	0.039	0.036	0	32.3	32.3	78.3	109	109	0	34	34
2015	12	17	3	35	10	0.098	0.118	0.886	0.036	0.033	0	32.3	32.7	77.4	109	110	0	34	34
2015	12	17	3	45	10	0.052	0.075	0.886	0.036	0.033	0	31.8	32.7	78.3	109	110	0	35	34
2015	12	17	3	55	10	0.108	0.056	0.886	0.033	0.03	0	32.3	32.3	77.8	110	109	0	35	34
2015	12	17	4	5	10	0.144	-0.036	0.886	0.033	0.03	0	31.8	31.4	78.3	109	108	0	35	35
2015	12	17	4	15	10	0.115	0.03	0.886	0.039	0.036	0	31.8	32.3	78.3	109	109	0	35	34
2015	12	17	4	25	10	0.072	0.052	0.886	0.039	0.039	0	32.3	31.8	78.3	110	109	0	35	35
2015	12	17	4	35	10	0.118	0.013	0.886	0.033	0.03	0	31.4	31.8	78.3	108	108	0	35	34
2015	12	17	4	45	10	0.112	0	0.886	0.039	0.036	0	31.4	32.3	78.3	108	109	0	35	34
2015	12	17	4	55	10	0.128	-0.118	0.886	0.033	0.03	0	31	31.8	77.8	107	108	0	35	34
2015	12	17	5	5	10	0.089	-0.01	0.886	0.043	0.039	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	17	5	15	10	0.105	-0.095	0.886	0.033	0.03	0	31.8	31.8	77.8	109	108	0	35	34
2015	12	17	5	25	10	0.118	-0.033	0.886	0.033	0.03	0	31.8	31.4	77.8	108	107	0	34	34
2015	12	17	5	35	10	0.052	0.098	0.886	0.036	0.033	0	31.8	31.8	77.8	108	108	0	34	34
2015	12	17	5	45	10	0.138	0.105	0.886	0.033	0.03	0	31.4	31.8	78.3	108	108	0	35	34
2015	12	17	5	55	10	0.092	-0.026	0.886	0.039	0.039	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	17	6	5	10	0.121	-0.052	0.886	0.033	0.03	0	31.8	31.8	78.3	109	108	0	35	34
2015	12	17	6	15	10	0.18	0	0.886	0.039	0.036	0	31.4	31.8	77.4	108	108	0	35	34
2015	12	17	6	25	10	0.276	-0.095	0.886	0.039	0.036	0	31.4	31	78.3	108	106	0	35	34
2015	12	17	6	35	10	0.259	-0.144	0.886	0.036	0.033	0	32.3	31.8	77.8	109	108	0	34	34
2015	12	17	6	45	10	0.131	-0.075	0.886	0.039	0.039	0	31.8	31.4	77.8	109	107	0	35	34
2015	12	17	6	55	10	0.266	-0.082	0.883	0.036	0.033	0	31.4	31.4	77.8	108	107	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	7	5	10	0.249	-0.043	0.886	0.043	0.039	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	17	7	15	10	0.289	-0.105	0.886	0.039	0.039	0	31.4	31.8	77.4	108	108	0	35	34
2015	12	17	7	25	10	0.243	-0.171	0.886	0.033	0.03	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	17	7	35	10	0.269	-0.138	0.886	0.033	0.03	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	17	7	45	10	0.253	-0.075	0.883	0.033	0.03	0	31.8	31.8	78.3	109	109	0	35	35
2015	12	17	7	55	10	0.2	-0.066	0.886	0.036	0.033	0	31.8	32.3	78.3	109	109	0	35	34
2015	12	17	8	5	10	0.23	-0.197	0.886	0.033	0.03	0	32.3	32.3	77.8	110	110	0	35	35
2015	12	17	8	15	10	0.253	-0.092	0.886	0.046	0.043	0	31.8	32.3	78.3	109	109	0	35	34
2015	12	17	8	25	10	0.223	-0.082	0.886	0.046	0.043	0	32.3	32.7	78.3	109	109	0	34	33
2015	12	17	8	35	10	0.177	-0.013	0.883	0.036	0.033	0	32.7	32.3	78.3	111	109	0	35	34
2015	12	17	8	45	10	0.22	-0.036	0.883	0.036	0.033	0	32.3	32.7	78.7	111	110	0	36	34
2015	12	17	8	55	10	0.207	-0.144	0.883	0.033	0.03	0	32.7	32.3	78.7	110	109	0	34	34
2015	12	17	9	5	10	0.177	-0.062	0.883	0.033	0.03	0	32.7	32.3	78.7	110	109	0	34	34
2015	12	17	9	15	10	0.135	-0.118	0.883	0.039	0.036	0	32.7	32.7	78.3	111	110	0	35	34
2015	12	17	9	25	10	0.148	-0.092	0.883	0.039	0.039	0	32.7	32.7	78.7	111	110	0	35	34
2015	12	17	9	35	10	0.187	-0.003	0.883	0.039	0.036	0	32.7	32.7	78.3	111	110	0	35	34
2015	12	17	9	45	10	0.197	0.033	0.883	0.039	0.036	0	33.1	32.7	78.7	112	110	0	35	34
2015	12	17	9	55	10	0.157	-0.095	0.883	0.033	0.03	0	32.7	33.1	78.7	111	111	0	35	34
2015	12	17	10	5	10	0.128	0.01	0.883	0.046	0.043	0	33.1	33.1	78.7	112	111	0	35	34
2015	12	17	10	15	10	0.135	0.062	0.883	0.033	0.03	0	33.1	33.5	78.3	112	112	0	35	34
2015	12	17	10	25	10	0.102	0.026	0.883	0.036	0.033	0	33.5	34	78.7	113	112	0	35	33
2015	12	17	10	35	10	0.115	0.039	0.883	0.036	0.033	0	33.5	34	78.7	113	113	0	35	34
2015	12	17	10	45	10	0.164	0	0.883	0.036	0.033	0	33.5	33.5	78.7	113	112	0	35	34
2015	12	17	10	55	10	0.184	-0.105	0.883	0.033	0.03	0	34	34.4	78.7	114	114	0	35	34
2015	12	17	11	5	10	0.272	-0.03	0.886	0.033	0.03	0	34	34.4	78.3	114	114	0	35	34
2015	12	17	11	15	10	0.203	-0.026	0.886	0.039	0.039	0	33.5	34	78.3	113	113	0	35	34
2015	12	17	11	25	10	0.118	-0.079	0.886	0.039	0.036	0	33.5	34	78.3	113	113	0	35	34
2015	12	17	11	35	10	0.177	-0.01	0.886	0.039	0.036	0	34	33.5	78.7	113	112	0	34	34
2015	12	17	11	45	10	0.187	-0.095	0.886	0.039	0.039	0	33.5	34.4	78.7	112	114	0	34	34
2015	12	17	11	55	10	0.187	-0.039	0.886	0.036	0.033	0	34.4	34	78.7	114	113	0	34	34
2015	12	17	12	5	10	0.226	-0.03	0.886	0.039	0.036	0	33.5	34	79.1	113	113	0	35	34
2015	12	17	12	15	10	0.223	-0.108	0.886	0.033	0.03	0	34	34	78.7	114	113	0	35	34
2015	12	17	12	25	10	0.213	-0.079	0.886	0.039	0.036	0	34	34.8	79.1	113	114	0	34	33
2015	12	17	12	35	10	0.246	-0.121	0.886	0.039	0.036	0	34.8	34	78.7	115	113	0	34	34
2015	12	17	12	45	10	0.121	-0.069	0.886	0.043	0.039	0	34.8	34.4	79.1	115	114	0	34	34
2015	12	17	12	55	10	0.19	-0.056	0.886	0.033	0.03	0	34.4	34.8	78.3	114	115	0	34	34
2015	12	17	13	5	10	0.217	0	0.886	0.039	0.036	0	34.8	34.4	78.7	115	114	0	34	34
2015	12	17	13	15	10	0.144	0	0.886	0.033	0.03	0	35.3	35.3	79.1	116	115	0	34	33
2015	12	17	13	25	10	0.19	-0.066	0.886	0.036	0.033	0	35.3	35.3	79.1	116	116	0	34	34
2015	12	17	13	35	10	0.285	-0.128	0.886	0.036	0.033	0	36.1	36.5	78.7	118	118	0	34	33
2015	12	17	13	45	10	0.217	-0.095	0.886	0.036	0.033	0	36.5	36.1	78.3	119	118	0	34	34
2015	12	17	13	55	10	0.22	-0.046	0.886	0.036	0.033	0	35.7	35.3	78.7	118	116	0	35	34
2015	12	17	14	5	10	0.197	0	0.886	0.033	0.03	0	36.1	36.1	78.3	118	118	0	34	34
2015	12	17	14	15	10	0.148	-0.072	0.886	0.043	0.039	0	35.7	35.3	78.3	117	116	0	34	34
2015	12	17	14	25	10	0.19	-0.125	0.886	0.033	0.03	0	34.8	34.8	78.7	116	115	0	35	34
2015	12	17	14	35	10	0.144	-0.023	0.886	0.033	0.03	0	35.3	35.3	78.3	116	115	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	14	45	10	0.203	-0.154	0.886	0.036	0.033	0	35.3	35.7	77.8	117	116	0	35	33
2015	12	17	14	55	10	0.174	-0.131	0.886	0.036	0.033	0	35.7	35.3	77.8	117	116	0	34	34
2015	12	17	15	5	10	0.19	-0.095	0.886	0.03	0.03	0	35.3	35.3	77.8	116	116	0	34	34
2015	12	17	15	15	10	0.213	-0.095	0.886	0.036	0.033	0	34.8	34.4	77.8	115	114	0	34	34
2015	12	17	15	25	10	0.236	-0.131	0.886	0.039	0.036	0	35.3	35.3	78.3	117	115	0	35	33
2015	12	17	15	35	10	0.262	-0.095	0.886	0.036	0.033	0	35.7	35.3	77.4	117	115	0	34	33
2015	12	17	15	45	10	0.292	-0.082	0.883	0.039	0.039	0	35.3	34.4	77.4	116	114	0	34	34
2015	12	17	15	55	10	0.262	-0.082	0.883	0.036	0.033	0	34.8	34.8	77.8	116	115	0	35	34
2015	12	17	16	5	10	0.194	-0.075	0.883	0.039	0.036	0	35.7	34.8	77	117	115	0	34	34
2015	12	17	16	15	10	0.315	-0.039	0.883	0.039	0.039	0	35.7	34.8	77.4	117	115	0	34	34
2015	12	17	16	25	10	0.285	-0.131	0.883	0.033	0.03	0	34.8	34.4	77	116	114	0	35	34
2015	12	17	16	35	10	0.272	-0.138	0.883	0.039	0.039	0	34.8	34	77	115	113	0	34	34
2015	12	17	16	45	10	0.358	-0.043	0.883	0.036	0.033	0	34.8	34.4	77	116	114	0	35	34
2015	12	17	16	55	10	0.24	-0.082	0.883	0.036	0.033	0	34.8	35.3	76.5	115	115	0	34	33
2015	12	17	17	5	10	0.217	-0.095	0.883	0.036	0.033	0	34.8	34.4	77	116	114	0	35	34
2015	12	17	17	15	10	0.194	-0.102	0.883	0.036	0.033	0	35.3	34.8	76.5	116	115	0	34	34
2015	12	17	17	25	10	0.148	-0.112	0.883	0.043	0.043	0	34.8	34	77	115	113	0	34	34
2015	12	17	17	35	10	0.223	0.016	0.883	0.036	0.033	0	35.3	34.4	76.1	116	114	0	34	34
2015	12	17	17	45	10	0.249	-0.052	0.883	0.033	0.03	0	37.8	37.8	75.7	123	121	0	35	33
2015	12	17	17	55	10	0.236	-0.023	0.883	0.039	0.036	0	36.1	34.8	76.5	118	116	0	34	35
2015	12	17	18	5	10	0.177	-0.013	0.883	0.039	0.036	0	35.3	34	76.1	116	113	0	34	34
2015	12	17	18	15	10	0.151	-0.092	0.883	0.036	0.033	0	34.8	35.3	76.5	115	115	0	34	33
2015	12	17	18	25	10	0.115	-0.013	0.883	0.039	0.036	0	35.3	34.4	77	116	114	0	34	34
2015	12	17	18	35	10	0.194	0.03	0.883	0.039	0.036	0	35.7	34.8	76.5	117	114	0	34	33
2015	12	17	18	45	10	0.135	0.023	0.883	0.039	0.036	0	34.8	33.5	77	114	112	0	33	34
2015	12	17	18	55	10	0.341	-0.059	0.883	0.033	0.03	0	33.1	33.5	77	112	111	0	35	33
2015	12	17	19	5	10	0.164	-0.085	0.883	0.033	0.03	0	33.1	34	77	111	112	0	34	33
2015	12	17	19	15	10	0.18	-0.046	0.883	0.033	0.03	0	33.5	33.1	77	112	110	0	34	33
2015	12	17	19	25	10	0.233	-0.089	0.883	0.039	0.039	0	33.5	32.7	77.4	112	110	0	34	34
2015	12	17	19	35	10	0.171	-0.049	0.883	0.033	0.03	0	33.1	32.3	77.4	112	108	0	35	33
2015	12	17	19	45	10	0.328	-0.184	0.883	0.039	0.036	0	32.3	32.3	77	110	109	0	35	34
2015	12	17	19	55	10	0.292	-0.22	0.883	0.039	0.036	0	32.3	32.3	77	110	109	0	35	34
2015	12	17	20	5	10	0.161	0	0.886	0.039	0.036	0	32.7	32.7	77.4	111	109	0	35	33
2015	12	17	20	15	10	0.262	-0.138	0.883	0.033	0.03	0	33.1	33.1	77	111	110	0	34	33
2015	12	17	20	25	10	0.253	-0.036	0.883	0.039	0.036	0	32.7	32.3	77.4	110	109	0	34	34
2015	12	17	20	35	10	0.249	-0.069	0.883	0.036	0.033	0	32.7	31.8	77.4	110	108	0	34	34
2015	12	17	20	45	10	0.21	-0.062	0.886	0.039	0.036	0	32.3	31.8	77.8	110	108	0	35	34
2015	12	17	20	55	10	0.292	-0.131	0.886	0.033	0.03	0	32.7	31.8	77.8	110	108	0	34	34
2015	12	17	21	5	10	0.295	-0.105	0.886	0.036	0.033	0	32.7	32.7	77.4	110	109	0	34	33
2015	12	17	21	15	10	0.262	-0.112	0.886	0.043	0.043	0	32.7	33.5	77.8	110	111	0	34	33
2015	12	17	21	25	10	0.2	-0.125	0.886	0.033	0.033	0	32.3	32.3	77.8	110	109	0	35	34
2015	12	17	21	35	10	0.194	-0.125	0.886	0.039	0.036	0	33.1	32.7	77.8	111	110	0	34	34
2015	12	17	21	45	10	0.243	-0.108	0.886	0.036	0.033	0	32.3	32.7	77.8	109	110	0	34	34
2015	12	17	21	55	10	0.249	-0.102	0.886	0.033	0.03	0	32.3	33.5	78.3	110	111	0	35	33
2015	12	17	22	5	10	0.22	-0.069	0.886	0.033	0.03	0	33.1	32.7	78.3	111	110	0	34	34
2015	12	17	22	15	10	0.249	-0.161	0.886	0.03	0.03	0	32.7	33.5	77.4	111	111	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	22	25	10	0.171	-0.043	0.886	0.036	0.033	0	34	34	77.8	113	112	0	34	33
2015	12	17	22	35	10	0.21	-0.052	0.886	0.033	0.03	0	34.4	34	77.8	114	113	0	34	34
2015	12	17	22	45	10	0.203	-0.02	0.886	0.039	0.036	0	35.7	34.8	77.8	117	115	0	34	34
2015	12	17	22	55	10	0.157	-0.072	0.886	0.033	0.03	0	36.5	35.7	77.4	119	117	0	34	34
2015	12	17	23	5	10	0.269	-0.026	0.886	0.033	0.03	0	35.7	35.3	78.3	117	116	0	34	34
2015	12	17	23	15	10	0.19	0	0.886	0.036	0.033	0	34.4	34.4	77.8	114	114	0	34	34
2015	12	17	23	25	10	0.253	-0.072	0.886	0.033	0.03	0	34.4	34.8	77.4	114	115	0	34	34
2015	12	17	23	35	10	0.177	-0.052	0.886	0.033	0.03	0	33.5	34.4	77.8	113	113	0	35	33
2015	12	17	23	45	10	0.213	-0.085	0.886	0.033	0.03	0	34	34.4	77.8	113	113	0	34	33
2015	12	17	23	55	10	0.259	-0.049	0.886	0.033	0.03	0	33.1	34	78.3	112	113	0	35	34
2015	12	18	0	5	10	0.23	-0.102	0.883	0.036	0.033	0	33.1	32.7	78.7	111	111	0	34	35
2015	12	18	0	15	10	0.226	-0.098	0.886	0.03	0.03	0	33.5	33.5	78.7	112	112	0	34	34
2015	12	18	0	25	10	0.171	-0.023	0.886	0.033	0.03	0	32.7	33.5	78.7	110	112	0	34	34
2015	12	18	0	35	10	0.246	0	0.883	0.033	0.03	0	32.7	33.5	79.1	111	112	0	35	34
2015	12	18	0	45	10	0.18	0	0.883	0.033	0.03	0	33.5	33.5	78.7	112	111	0	34	33
2015	12	18	0	55	10	0.089	-0.003	0.886	0.033	0.03	0	32.3	33.1	78.7	110	111	0	35	34
2015	12	18	1	5	10	0.039	0.039	0.883	0.033	0.03	0	32.3	33.1	78.7	110	111	0	35	34
2015	12	18	1	15	10	0.167	0.01	0.883	0.033	0.03	0	33.1	33.1	79.1	111	111	0	34	34
2015	12	18	1	25	10	0.171	-0.033	0.883	0.039	0.036	0	32.7	33.5	78.7	111	111	0	35	33
2015	12	18	1	35	10	0.233	-0.095	0.883	0.033	0.03	0	32.3	32.3	78.3	110	110	0	35	35
2015	12	18	1	45	10	0.269	-0.128	0.883	0.043	0.039	0	32.7	32.7	79.1	110	109	0	34	33
2015	12	18	1	55	10	0.269	-0.141	0.883	0.033	0.03	0	32.7	32.7	78.3	110	110	0	34	34
2015	12	18	2	5	10	0.246	-0.148	0.883	0.033	0.03	0	32.3	33.5	78.3	110	112	0	35	34
2015	12	18	2	15	10	0.276	-0.2	0.883	0.033	0.03	0	32.3	33.1	79.1	110	111	0	35	34
2015	12	18	2	25	10	0.338	-0.207	0.883	0.033	0.03	0	31.8	33.5	78.7	109	112	0	35	34
2015	12	18	2	35	10	0.177	-0.108	0.883	0.036	0.033	0	32.7	33.5	79.1	111	112	0	35	34
2015	12	18	2	45	10	0.177	-0.174	0.883	0.033	0.03	0	32.3	32.7	78.7	109	110	0	34	34
2015	12	18	2	55	10	0.243	-0.164	0.883	0.033	0.03	0	31.8	33.5	79.1	109	112	0	35	34
2015	12	18	3	5	10	0.22	-0.135	0.883	0.036	0.033	0	32.7	32.7	79.1	110	110	0	34	34
2015	12	18	3	15	10	0.157	-0.046	0.883	0.03	0.03	0	32.7	33.1	79.1	110	110	0	34	33
2015	12	18	3	25	10	0.154	-0.075	0.883	0.03	0.03	0	32.7	33.5	78.7	111	112	0	35	34
2015	12	18	3	35	10	0.144	-0.052	0.883	0.033	0.03	0	32.7	32.7	79.1	110	110	0	34	34
2015	12	18	3	45	10	0.141	-0.095	0.883	0.036	0.033	0	32.3	33.5	78.7	110	112	0	35	34
2015	12	18	3	55	10	0.079	0.013	0.883	0.033	0.03	0	31.4	32.7	78.7	108	110	0	35	34
2015	12	18	4	5	10	0.079	-0.046	0.883	0.033	0.03	0	33.1	33.5	78.7	112	111	0	35	33
2015	12	18	4	15	10	0.161	-0.102	0.883	0.033	0.03	0	31.8	32.3	78.7	109	110	0	35	35
2015	12	18	4	25	10	0.22	-0.072	0.883	0.043	0.039	0	31.8	33.1	79.1	109	111	0	35	34
2015	12	18	4	35	10	0.171	-0.039	0.883	0.033	0.03	0	32.7	33.1	79.1	111	111	0	35	34
2015	12	18	4	45	10	0.171	-0.013	0.883	0.039	0.039	0	32.7	33.1	78.7	111	111	0	35	34
2015	12	18	4	55	10	0.118	-0.036	0.883	0.039	0.039	0	32.7	33.1	79.1	111	111	0	35	34
2015	12	18	5	5	10	0.118	-0.072	0.883	0.033	0.03	0	31.4	32.3	79.1	108	109	0	35	34
2015	12	18	5	15	10	0.095	-0.066	0.883	0.036	0.033	0	32.3	32.7	78.7	110	110	0	35	34
2015	12	18	5	25	10	0.253	-0.121	0.883	0.039	0.036	0	31.8	32.3	79.1	109	109	0	35	34
2015	12	18	5	35	10	0.144	-0.062	0.883	0.036	0.033	0	33.5	33.5	78.3	113	112	0	35	34
2015	12	18	5	45	10	0.262	-0.115	0.883	0.036	0.033	0	32.3	32.7	79.1	110	110	0	35	34
2015	12	18	5	55	10	0.249	-0.092	0.883	0.033	0.03	0	32.3	32.3	79.1	110	109	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	6	5	10	0.236	-0.089	0.883	0.039	0.039	0	32.7	32.3	79.1	110	109	0	34	34
2015	12	18	6	15	10	0.226	-0.102	0.883	0.033	0.03	0	31.4	32.3	78.7	108	109	0	35	34
2015	12	18	6	25	10	0.157	0	0.883	0.033	0.03	0	34.8	34.4	78.3	116	114	0	35	34
2015	12	18	6	35	10	0.177	-0.125	0.883	0.033	0.03	0	35.7	35.7	77.8	118	117	0	35	34
2015	12	18	6	45	10	0.171	-0.118	0.883	0.036	0.033	0	34.4	34.4	78.3	115	114	0	35	34
2015	12	18	6	55	10	0.21	-0.026	0.883	0.036	0.033	0	33.1	32.7	79.1	112	110	0	35	34
2015	12	18	7	5	10	0.167	-0.062	0.883	0.033	0.03	0	32.7	31.8	78.7	110	108	0	34	34
2015	12	18	7	15	10	0.22	-0.062	0.883	0.036	0.033	0	31.8	31.4	79.1	109	107	0	35	34
2015	12	18	7	25	10	0.194	-0.072	0.883	0.033	0.03	0	31.8	31	78.7	109	106	0	35	34
2015	12	18	7	35	10	0.115	-0.056	0.883	0.03	0.03	0	32.3	31.4	78.7	109	107	0	34	34
2015	12	18	7	45	10	0.092	-0.026	0.883	0.036	0.033	0	31.8	31.8	79.1	109	108	0	35	34
2015	12	18	7	55	10	0.118	-0.023	0.883	0.036	0.033	0	32.3	31.4	78.7	109	108	0	34	35
2015	12	18	8	5	10	0.131	0.02	0.883	0.036	0.033	0	31.8	31.8	79.1	109	108	0	35	34
2015	12	18	8	15	10	0.118	-0.046	0.883	0.033	0.03	0	31.8	32.3	79.1	109	109	0	35	34
2015	12	18	8	25	10	0.249	0.016	0.883	0.039	0.036	0	32.3	31.8	79.1	109	108	0	34	34
2015	12	18	8	35	10	0.118	-0.026	0.883	0.033	0.03	0	32.7	31.8	78.7	111	108	0	35	34
2015	12	18	8	45	10	0.108	-0.108	0.883	0.033	0.03	0	32.3	31.8	79.1	110	109	0	35	35
2015	12	18	8	55	10	0.095	0.007	0.883	0.033	0.03	0	32.3	31.8	79.6	110	108	0	35	34
2015	12	18	9	5	10	0.092	0.003	0.883	0.036	0.033	0	32.3	31.8	79.1	110	108	0	35	34
2015	12	18	9	15	10	0.039	0.056	0.883	0.033	0.03	0	32.3	31.8	79.6	110	108	0	35	34
2015	12	18	9	25	10	0.105	0.007	0.883	0.036	0.033	0	32.7	32.3	79.6	110	109	0	34	34
2015	12	18	9	35	10	0.033	0.026	0.883	0.033	0.03	0	32.3	32.3	79.1	110	109	0	35	34
2015	12	18	9	45	10	0.092	-0.003	0.883	0.033	0.03	0	32.7	32.3	79.6	110	109	0	34	34
2015	12	18	9	55	10	0.249	-0.043	0.883	0.033	0.03	0	32.7	32.3	79.1	111	109	0	35	34
2015	12	18	10	5	10	0.22	-0.125	0.883	0.036	0.033	0	33.1	32.7	79.6	111	110	0	34	34
2015	12	18	10	15	10	0.171	-0.151	0.883	0.033	0.03	0	33.1	32.7	79.1	111	110	0	34	34
2015	12	18	10	25	10	0.21	-0.082	0.883	0.036	0.033	0	33.1	32.3	79.6	111	109	0	34	34
2015	12	18	10	35	10	0.167	-0.02	0.883	0.033	0.03	0	32.7	32.7	79.1	111	110	0	35	34
2015	12	18	10	45	10	0.243	-0.075	0.883	0.036	0.033	0	33.1	33.1	79.1	112	111	0	35	34
2015	12	18	10	55	10	0.22	-0.098	0.883	0.039	0.036	0	33.5	34	79.1	113	112	0	35	33
2015	12	18	11	5	10	0.095	-0.085	0.883	0.039	0.036	0	34	34	79.1	113	113	0	34	34
2015	12	18	11	15	10	0.108	-0.089	0.883	0.036	0.033	0	33.1	33.5	79.1	112	112	0	35	34
2015	12	18	11	25	10	0.148	-0.075	0.883	0.033	0.03	0	34.4	33.5	79.1	114	112	0	34	34
2015	12	18	11	35	10	0.226	-0.095	0.883	0.033	0.03	0	34	33.5	79.1	113	112	0	34	34
2015	12	18	11	45	10	0.23	-0.184	0.883	0.033	0.03	0	34	33.5	79.1	113	112	0	34	34
2015	12	18	11	55	10	0.174	-0.098	0.883	0.043	0.043	0	34	33.5	79.1	114	112	0	35	34
2015	12	18	12	5	10	0.105	-0.043	0.883	0.039	0.036	0	34.4	34.8	78.7	114	114	0	34	33
2015	12	18	12	15	10	0.128	-0.023	0.883	0.033	0.03	0	33.5	34	78.3	113	113	0	35	34
2015	12	18	12	25	10	0.164	-0.016	0.883	0.036	0.033	0	34	34	78.3	114	113	0	35	34
2015	12	18	12	35	10	0.135	-0.043	0.883	0.043	0.039	0	34	33.5	78.7	113	112	0	34	34
2015	12	18	12	45	10	0.177	-0.118	0.883	0.039	0.039	0	34.4	34	78.3	114	113	0	34	34
2015	12	18	12	55	10	0.243	-0.03	0.883	0.039	0.036	0	34.8	34.8	77.8	115	114	0	34	33
2015	12	18	13	5	10	0.226	-0.105	0.883	0.039	0.036	0	35.3	34.4	77.4	117	115	0	35	35
2015	12	18	13	15	10	0.203	-0.062	0.883	0.039	0.036	0	35.7	35.7	77.8	117	116	0	34	33
2015	12	18	13	25	10	0.207	-0.039	0.883	0.036	0.033	0	37	36.5	77.8	120	118	0	34	33
2015	12	18	13	35	10	0.164	-0.056	0.883	0.036	0.033	0	39.1	37.8	75.7	125	122	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	13	45	10	0.213	-0.128	0.879	0.033	0.03	0	46.4	46	69.7	143	141	0	35	34
2015	12	18	13	55	10	0.177	-0.079	0.883	0.039	0.039	0	47.7	46.4	70.1	146	142	0	35	34
2015	12	18	14	5	10	0.151	-0.108	0.883	0.039	0.036	0	44.3	43.9	72.2	138	136	0	35	34
2015	12	18	14	15	10	0.276	0.023	0.883	0.039	0.036	0	43.4	42.6	73.5	135	133	0	34	34
2015	12	18	14	25	10	0.22	-0.056	0.883	0.036	0.033	0	42.6	43	73.1	134	133	0	35	33
2015	12	18	14	35	10	0.22	-0.036	0.883	0.033	0.03	0	42.6	42.1	73.5	133	131	0	34	33
2015	12	18	14	45	10	0.2	0.01	0.883	0.039	0.036	0	41.3	40.9	74	130	129	0	34	34
2015	12	18	14	55	10	0.207	0.013	0.883	0.039	0.036	0	40.9	40.4	74	129	128	0	34	34
2015	12	18	15	5	10	0.19	-0.062	0.883	0.033	0.03	0	40.4	40	74.4	128	127	0	34	34
2015	12	18	15	15	10	0.259	-0.01	0.883	0.033	0.03	0	40	39.1	74.8	127	124	0	34	33
2015	12	18	15	25	10	0.279	0	0.883	0.036	0.033	0	39.6	38.7	74.8	126	124	0	34	34
2015	12	18	15	35	10	0.194	0.059	0.883	0.033	0.03	0	38.7	38.3	74.4	124	123	0	34	34
2015	12	18	15	45	10	0.21	-0.01	0.883	0.039	0.036	0	38.3	38.3	74.8	124	122	0	35	33
2015	12	18	15	55	10	0.197	-0.069	0.883	0.036	0.033	0	37.4	37.8	74.8	122	122	0	35	34
2015	12	18	16	5	10	0.246	0	0.883	0.036	0.033	0	37.8	37.8	75.3	122	121	0	34	33
2015	12	18	16	15	10	0.131	-0.056	0.883	0.043	0.039	0	37.4	37	74.8	121	119	0	34	33
2015	12	18	16	25	10	0.167	0.007	0.883	0.039	0.036	0	37.8	36.5	75.3	122	119	0	34	34
2015	12	18	16	35	10	0.118	-0.056	0.883	0.036	0.033	0	36.5	36.1	74.8	120	118	0	35	34
2015	12	18	16	45	10	0.249	-0.069	0.883	0.036	0.033	0	37	36.5	74.8	120	118	0	34	33
2015	12	18	16	55	10	0.236	-0.062	0.883	0.033	0.03	0	37.4	36.5	74.8	121	119	0	34	34
2015	12	18	17	5	10	0.177	-0.075	0.879	0.039	0.039	0	36.5	37	75.3	120	119	0	35	33
2015	12	18	17	15	10	0.236	-0.089	0.879	0.039	0.036	0	37	36.1	74.8	120	118	0	34	34
2015	12	18	17	25	10	0.085	-0.059	0.879	0.033	0.03	0	37.8	37	74.8	122	119	0	34	33
2015	12	18	17	35	10	0.197	0	0.879	0.039	0.039	0	37.4	37.4	74.4	121	120	0	34	33
2015	12	18	17	45	10	0.23	0	0.879	0.036	0.033	0	37	36.5	74.4	121	119	0	35	34
2015	12	18	17	55	10	0.194	-0.026	0.879	0.033	0.03	0	37	36.5	74.8	120	118	0	34	33
2015	12	18	18	5	10	0.174	0.02	0.879	0.036	0.033	0	36.5	36.1	75.3	119	118	0	34	34
2015	12	18	18	15	10	0.266	-0.194	0.879	0.039	0.036	0	36.1	35.7	74.8	118	117	0	34	34
2015	12	18	18	25	10	0.164	-0.01	0.879	0.033	0.03	0	35.7	35.3	74.8	118	116	0	35	34
2015	12	18	18	35	10	0.249	-0.069	0.879	0.046	0.043	0	35.7	36.1	74.8	118	117	0	35	33
2015	12	18	18	45	10	0.167	0.026	0.879	0.036	0.033	0	35.7	35.7	75.3	117	116	0	34	33
2015	12	18	18	55	10	0.269	-0.01	0.879	0.036	0.033	0	36.1	36.1	74.8	118	117	0	34	33
2015	12	18	19	5	10	0.226	-0.056	0.879	0.046	0.043	0	35.7	35.3	74.8	117	116	0	34	34
2015	12	18	19	15	10	0.236	-0.056	0.883	0.036	0.033	0	35.7	35.3	74.8	117	115	0	34	33
2015	12	18	19	25	10	0.282	-0.069	0.879	0.033	0.03	0	35.3	34.8	75.3	116	115	0	34	34
2015	12	18	19	35	10	0.207	-0.052	0.883	0.039	0.039	0	34.8	34	75.3	115	113	0	34	34
2015	12	18	19	45	10	0.194	-0.013	0.879	0.033	0.03	0	34.4	34	75.3	114	113	0	34	34
2015	12	18	19	55	10	0.207	-0.131	0.879	0.033	0.03	0	34.4	33.5	75.3	114	112	0	34	34
2015	12	18	20	5	10	0.157	-0.089	0.883	0.046	0.043	0	34	33.1	75.7	113	111	0	34	34
2015	12	18	20	15	10	0.098	-0.121	0.883	0.039	0.039	0	33.1	33.5	74.8	112	111	0	35	33
2015	12	18	20	25	10	0.187	-0.125	0.883	0.033	0.03	0	33.5	33.5	75.7	112	112	0	34	34
2015	12	18	20	35	10	0.223	-0.141	0.883	0.033	0.03	0	33.1	33.1	75.7	111	110	0	34	33
2015	12	18	20	45	10	0.203	-0.102	0.883	0.043	0.039	0	32.7	33.1	75.3	110	110	0	34	33
2015	12	18	20	55	10	0.092	-0.112	0.883	0.036	0.033	0	32.7	32.7	76.1	111	110	0	35	34
2015	12	18	21	5	10	0.217	-0.105	0.883	0.039	0.036	0	33.1	32.7	75.7	111	110	0	34	34
2015	12	18	21	15	10	0.207	-0.069	0.883	0.036	0.033	0	33.1	32.7	76.1	111	110	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	21	25	10	0.22	-0.121	0.883	0.039	0.036	0	33.5	32.7	76.5	112	110	0	34	34
2015	12	18	21	35	10	0.207	-0.062	0.883	0.039	0.039	0	34	34	75.7	113	113	0	34	34
2015	12	18	21	45	10	0.262	-0.125	0.883	0.039	0.036	0	33.5	33.1	76.1	112	111	0	34	34
2015	12	18	21	55	10	0.213	-0.128	0.883	0.036	0.033	0	33.5	33.1	75.7	112	111	0	34	34
2015	12	18	22	5	10	0.223	-0.112	0.883	0.033	0.03	0	33.5	33.5	76.5	112	111	0	34	33
2015	12	18	22	15	10	0.197	-0.102	0.883	0.036	0.033	0	33.5	33.5	76.1	112	112	0	34	34
2015	12	18	22	25	10	0.184	-0.131	0.883	0.033	0.03	0	33.1	33.5	77	111	111	0	34	33
2015	12	18	22	35	10	0.177	-0.144	0.883	0.03	0.03	0	33.1	34	76.1	111	113	0	34	34
2015	12	18	22	45	10	0.21	-0.131	0.883	0.033	0.03	0	32.7	33.5	76.5	110	112	0	34	34
2015	12	18	22	55	10	0.19	-0.108	0.883	0.033	0.03	0	33.1	33.5	76.5	111	112	0	34	34
2015	12	18	23	5	10	0.174	-0.131	0.883	0.033	0.03	0	32.3	33.5	76.5	109	112	0	34	34
2015	12	18	23	15	10	0.121	-0.121	0.883	0.033	0.03	0	33.1	33.5	77	111	112	0	34	34
2015	12	18	23	25	10	0.22	-0.095	0.883	0.033	0.03	0	32.7	34	76.5	110	113	0	34	34
2015	12	18	23	35	10	0.174	-0.072	0.883	0.033	0.03	0	32.7	33.5	77	110	111	0	34	33
2015	12	18	23	45	10	0.177	-0.013	0.883	0.033	0.03	0	33.5	34	77	112	112	0	34	33
2015	12	18	23	55	10	0.059	0.007	0.883	0.033	0.03	0	32.7	32.7	77.4	110	110	0	34	34
2015	12	19	0	5	10	0.089	-0.026	0.883	0.033	0.03	0	33.5	33.5	77	112	112	0	34	34
2015	12	19	0	15	10	0.069	-0.056	0.883	0.033	0.03	0	33.1	32.7	77	111	110	0	34	34
2015	12	19	0	25	10	0.115	-0.003	0.883	0.036	0.033	0	32.3	34	77	110	113	0	35	34
2015	12	19	0	35	10	0.177	0	0.883	0.036	0.033	0	33.5	33.5	76.5	112	112	0	34	34
2015	12	19	0	45	10	0.148	-0.03	0.883	0.033	0.03	0	33.5	33.1	77.4	113	111	0	35	34
2015	12	19	0	55	10	0.144	-0.043	0.883	0.039	0.036	0	33.1	34.8	77	112	114	0	35	33
2015	12	19	1	5	10	0.174	-0.02	0.883	0.033	0.03	0	33.1	33.1	77	112	111	0	35	34
2015	12	19	1	15	10	0.19	-0.046	0.879	0.036	0.033	0	32.7	33.5	77.4	111	112	0	35	34
2015	12	19	1	25	10	0.167	-0.062	0.879	0.036	0.033	0	34	34.8	77.4	113	113	0	34	32
2015	12	19	1	35	10	0.243	-0.108	0.883	0.033	0.03	0	33.1	33.1	77.4	111	111	0	34	34
2015	12	19	1	45	10	0.039	-0.052	0.883	0.033	0.03	0	33.1	34	77	112	113	0	35	34
2015	12	19	1	55	10	0.184	0.003	0.879	0.033	0.03	0	33.1	33.5	77.4	111	112	0	34	34
2015	12	19	2	5	10	0.157	-0.036	0.883	0.036	0.033	0	32.7	33.5	77	111	112	0	35	34
2015	12	19	2	15	10	0.2	-0.059	0.879	0.033	0.033	0	33.1	33.5	77.4	112	111	0	35	33
2015	12	19	2	25	10	0.177	-0.03	0.879	0.036	0.033	0	34.4	33.5	77	114	113	0	34	35
2015	12	19	2	35	10	0.223	-0.085	0.879	0.033	0.03	0	34	34.8	77.8	114	115	0	35	34
2015	12	19	2	45	10	0.2	-0.082	0.879	0.033	0.03	0	34	33.5	77	113	112	0	34	34
2015	12	19	2	55	10	0.177	-0.069	0.879	0.039	0.036	0	33.5	34	77.4	113	113	0	35	34
2015	12	19	3	5	10	0.217	-0.056	0.879	0.033	0.03	0	32.7	34	77	111	113	0	35	34
2015	12	19	3	15	10	0.203	-0.108	0.879	0.033	0.03	0	33.1	34.4	77.4	112	113	0	35	33
2015	12	19	3	25	10	0.23	-0.075	0.879	0.033	0.03	0	33.5	33.5	77.8	113	112	0	35	34
2015	12	19	3	35	10	0.223	-0.135	0.879	0.033	0.03	0	33.1	34	77.8	112	113	0	35	34
2015	12	19	3	45	10	0.213	-0.069	0.879	0.033	0.03	0	34	34.4	77.8	114	114	0	35	34
2015	12	19	3	55	10	0.24	-0.164	0.879	0.033	0.03	0	32.7	33.5	77	110	112	0	34	34
2015	12	19	4	5	10	0.22	-0.131	0.879	0.033	0.03	0	32.7	33.1	77.8	111	112	0	35	35
2015	12	19	4	15	10	0.187	-0.187	0.879	0.033	0.03	0	32.7	33.5	77.4	111	112	0	35	34
2015	12	19	4	25	10	0.141	-0.062	0.879	0.03	0.03	0	32.7	33.1	77.8	111	111	0	35	34
2015	12	19	4	35	10	0.151	-0.121	0.883	0.03	0.026	0	33.1	33.1	77.8	112	111	0	35	34
2015	12	19	4	45	10	0.18	-0.043	0.879	0.033	0.03	0	33.1	34	78.3	112	113	0	35	34
2015	12	19	4	55	10	0.194	-0.052	0.879	0.033	0.03	0	32.7	34	77.8	111	113	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	5	5	10	0.118	-0.121	0.879	0.033	0.03	0	33.1	33.1	78.3	111	112	0	34	35
2015	12	19	5	15	10	0.226	-0.121	0.879	0.03	0.03	0	32.7	33.1	77.4	111	111	0	35	34
2015	12	19	5	25	10	0.161	0.043	0.879	0.039	0.036	0	32.3	33.1	77.4	110	111	0	35	34
2015	12	19	5	35	10	0.2	-0.085	0.879	0.033	0.03	0	32.7	33.1	78.3	110	111	0	34	34
2015	12	19	5	45	10	0.135	-0.115	0.879	0.033	0.03	0	32.7	33.5	77.8	111	112	0	35	34
2015	12	19	5	55	10	0.161	-0.062	0.879	0.036	0.033	0	32.7	33.5	77.8	111	111	0	35	33
2015	12	19	6	5	10	0.207	-0.118	0.879	0.033	0.03	0	32.7	32.7	77.8	111	110	0	35	34
2015	12	19	6	15	10	0.135	-0.115	0.879	0.033	0.03	0	33.5	33.1	78.3	112	111	0	34	34
2015	12	19	6	25	10	0.197	-0.079	0.879	0.033	0.03	0	33.1	33.5	78.3	112	112	0	35	34
2015	12	19	6	35	10	0.194	-0.131	0.879	0.036	0.033	0	33.1	33.5	77.8	112	112	0	35	34
2015	12	19	6	45	10	0.144	-0.131	0.879	0.036	0.033	0	32.7	33.1	77.8	111	111	0	35	34
2015	12	19	6	55	10	0.167	-0.079	0.879	0.036	0.033	0	33.5	33.1	77.4	112	111	0	34	34
2015	12	19	7	5	10	0.164	-0.171	0.879	0.036	0.033	0	32.7	32.3	78.3	111	110	0	35	35
2015	12	19	7	15	10	0.213	-0.052	0.879	0.033	0.03	0	32.3	32.3	77.8	109	109	0	34	34
2015	12	19	7	25	10	0.279	-0.095	0.879	0.033	0.03	0	31.8	32.3	78.3	109	109	0	35	34
2015	12	19	7	35	10	0.23	-0.105	0.879	0.033	0.03	0	32.3	32.3	77.8	110	109	0	35	34
2015	12	19	7	45	10	0.197	-0.075	0.879	0.033	0.033	0	31.8	31.8	77.8	109	109	0	35	35
2015	12	19	7	55	10	0.194	-0.151	0.879	0.036	0.033	0	32.7	32.7	78.7	110	110	0	34	34
2015	12	19	8	5	10	0.233	-0.049	0.879	0.046	0.046	0	32.7	32.3	78.7	111	109	0	35	34
2015	12	19	8	15	10	0.253	-0.161	0.879	0.039	0.036	0	32.3	32.3	78.3	110	109	0	35	34
2015	12	19	8	25	10	0.177	-0.079	0.879	0.033	0.03	0	32.3	31.8	78.7	109	108	0	34	34
2015	12	19	8	35	10	0.194	-0.167	0.879	0.033	0.03	0	31.8	31.4	78.3	109	107	0	35	34
2015	12	19	8	45	10	0.144	-0.079	0.879	0.033	0.03	0	31.4	31.8	78.7	108	108	0	35	34
2015	12	19	8	55	10	0.24	-0.118	0.879	0.03	0.03	0	31.8	31.8	79.1	109	108	0	35	34
2015	12	19	9	5	10	0.223	-0.184	0.879	0.033	0.03	0	31.4	31.4	78.3	108	107	0	35	34
2015	12	19	9	15	10	0.207	-0.121	0.879	0.033	0.03	0	31.8	31.4	78.3	109	107	0	35	34
2015	12	19	9	25	10	0.187	-0.135	0.879	0.036	0.033	0	31.4	31.4	77.8	108	108	0	35	35
2015	12	19	9	35	10	0.167	-0.092	0.879	0.036	0.033	0	31.4	31.8	79.1	108	108	0	35	34
2015	12	19	9	45	10	0.184	-0.092	0.879	0.033	0.03	0	31.8	31.8	77.8	109	108	0	35	34
2015	12	19	9	55	10	0.105	-0.069	0.879	0.03	0.03	0	32.3	32.3	78.7	110	109	0	35	34
2015	12	19	10	5	10	0.154	-0.118	0.879	0.039	0.039	0	32.3	32.3	78.3	110	109	0	35	34
2015	12	19	10	15	10	0.154	-0.039	0.879	0.033	0.03	0	31.8	32.3	78.3	108	109	0	34	34
2015	12	19	10	25	10	0.118	-0.092	0.879	0.033	0.03	0	32.3	32.7	78.3	110	110	0	35	34
2015	12	19	10	35	10	0.203	-0.105	0.879	0.049	0.046	0	32.7	33.1	77.4	111	111	0	35	34
2015	12	19	10	45	10	0.171	-0.079	0.879	0.033	0.03	0	32.7	32.7	77.8	110	110	0	34	34
2015	12	19	10	55	10	0.177	-0.177	0.879	0.033	0.03	0	32.3	32.7	77.4	110	110	0	35	34
2015	12	19	11	5	10	0.213	-0.108	0.879	0.039	0.036	0	33.1	33.5	77.4	111	111	0	34	33
2015	12	19	11	15	10	0.233	-0.095	0.879	0.039	0.036	0	33.1	33.5	77	111	112	0	34	34
2015	12	19	11	25	10	0.177	-0.177	0.879	0.036	0.033	0	32.7	32.7	77.8	111	111	0	35	35
2015	12	19	11	35	10	0.125	-0.098	0.879	0.039	0.039	0	33.1	33.1	77.4	111	110	0	34	33
2015	12	19	11	45	10	0.203	-0.112	0.879	0.043	0.039	0	34	33.5	76.5	113	112	0	34	34
2015	12	19	11	55	10	0.256	-0.059	0.879	0.039	0.036	0	34.4	33.5	76.5	114	112	0	34	34
2015	12	19	12	5	10	0.207	-0.026	0.879	0.039	0.036	0	33.1	33.1	77	112	111	0	35	34
2015	12	19	12	15	10	0.19	-0.046	0.879	0.033	0.03	0	34.8	34.4	77	115	113	0	34	33
2015	12	19	12	25	10	0.203	-0.069	0.879	0.039	0.039	0	33.5	33.1	77	113	111	0	35	34
2015	12	19	12	35	10	0.236	-0.141	0.879	0.036	0.033	0	33.5	33.5	77	113	112	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	12	45	10	0.233	-0.069	0.879	0.043	0.039	0	34	34	76.5	114	113	0	35	34
2015	12	19	12	55	10	0.2	-0.121	0.879	0.043	0.039	0	34	34.4	76.5	114	113	0	35	33
2015	12	19	13	5	10	0.187	-0.118	0.879	0.036	0.033	0	34.4	34	76.1	114	113	0	34	34
2015	12	19	13	15	10	0.164	-0.039	0.879	0.039	0.036	0	34	34	76.1	113	112	0	34	33
2015	12	19	13	25	10	0.144	-0.013	0.879	0.039	0.036	0	34.4	34.4	76.1	114	113	0	34	33
2015	12	19	13	35	10	0.098	0.039	0.879	0.036	0.033	0	34	33.5	75.7	113	112	0	34	34
2015	12	19	13	45	10	0.03	0.105	0.879	0.033	0.03	0	34.4	34	75.7	114	113	0	34	34
2015	12	19	13	55	10	0.072	0.072	0.879	0.039	0.036	0	34.4	34.4	74.8	114	114	0	34	34
2015	12	19	14	5	10	0.121	0.013	0.879	0.039	0.036	0	34.4	34	75.7	114	113	0	34	34
2015	12	19	14	15	10	0.144	-0.016	0.879	0.039	0.039	0	34	34	75.7	113	113	0	34	34
2015	12	19	14	25	10	0.151	-0.079	0.879	0.036	0.033	0	33.5	33.5	75.7	113	112	0	35	34
2015	12	19	14	35	10	0.102	-0.043	0.879	0.033	0.03	0	33.5	34	75.3	113	114	0	35	35
2015	12	19	14	45	10	0.177	-0.01	0.879	0.036	0.033	0	34.4	34	75.3	114	113	0	34	34
2015	12	19	14	55	10	0.171	-0.052	0.879	0.039	0.039	0	34	34	75.3	113	113	0	34	34
2015	12	19	15	5	10	0.269	-0.131	0.879	0.036	0.033	0	34.4	34.8	75.3	114	114	0	34	33
2015	12	19	15	15	10	0.246	-0.079	0.879	0.039	0.039	0	34	34.4	75.3	114	114	0	35	34
2015	12	19	15	25	10	0.295	-0.082	0.879	0.039	0.036	0	34.8	34.4	75.3	115	114	0	34	34
2015	12	19	15	35	10	0.203	-0.154	0.879	0.039	0.036	0	34.4	34	74.8	114	113	0	34	34
2015	12	19	15	45	10	0.249	-0.141	0.879	0.036	0.033	0	34	33.5	74.8	113	112	0	34	34
2015	12	19	15	55	10	0.197	-0.141	0.879	0.039	0.036	0	34	33.5	75.3	113	111	0	34	33
2015	12	19	16	5	10	0.282	-0.144	0.879	0.039	0.039	0	33.5	33.1	74.8	112	111	0	34	34
2015	12	19	16	15	10	0.266	-0.102	0.876	0.036	0.033	0	32.7	33.5	74.8	111	111	0	35	33
2015	12	19	16	25	10	0.276	-0.082	0.876	0.036	0.033	0	33.5	33.1	74.4	112	110	0	34	33
2015	12	19	16	35	10	0.246	-0.075	0.876	0.033	0.03	0	33.5	32.7	74.4	112	110	0	34	34
2015	12	19	16	45	10	0.22	-0.144	0.876	0.036	0.033	0	33.5	33.1	74.8	112	110	0	34	33
2015	12	19	16	55	10	0.213	-0.043	0.876	0.033	0.03	0	34	34	74.4	113	112	0	34	33
2015	12	19	17	5	10	0.266	-0.039	0.876	0.036	0.033	0	34	34	74.4	114	112	0	35	33
2015	12	19	17	15	10	0.22	-0.056	0.876	0.036	0.033	0	33.5	33.5	74.4	113	112	0	35	34
2015	12	19	17	25	10	0.184	-0.052	0.876	0.033	0.03	0	35.3	34.4	73.5	116	114	0	34	34
2015	12	19	17	35	10	0.23	0	0.876	0.036	0.033	0	37.8	37.4	73.1	122	121	0	34	34
2015	12	19	17	45	10	0.167	0.013	0.876	0.036	0.033	0	39.1	38.7	73.1	125	124	0	34	34
2015	12	19	17	55	10	0.203	0.013	0.876	0.033	0.03	0	38.3	38.3	73.1	123	122	0	34	33
2015	12	19	18	5	10	0.249	0.007	0.876	0.036	0.033	0	37	37.4	73.1	120	120	0	34	33
2015	12	19	18	15	10	0.184	-0.03	0.876	0.033	0.03	0	35.7	36.1	73.5	118	117	0	35	33
2015	12	19	18	25	10	0.246	-0.03	0.876	0.039	0.039	0	35.3	35.3	74.4	116	115	0	34	33
2015	12	19	18	35	10	0.253	-0.052	0.876	0.033	0.03	0	34.8	34.8	73.5	115	115	0	34	34
2015	12	19	18	45	10	0.285	-0.026	0.876	0.033	0.03	0	34.8	35.3	73.5	116	115	0	35	33
2015	12	19	18	55	10	0.302	-0.125	0.876	0.036	0.033	0	34.8	33.5	74	115	113	0	34	35
2015	12	19	19	5	10	0.207	-0.01	0.876	0.036	0.033	0	33.1	34	74	112	112	0	35	33
2015	12	19	19	15	10	0.223	-0.098	0.876	0.039	0.036	0	33.5	33.1	74	112	110	0	34	33
2015	12	19	19	25	10	0.236	-0.082	0.876	0.033	0.03	0	33.1	33.1	74	111	110	0	34	33
2015	12	19	19	35	10	0.112	0.016	0.879	0.039	0.036	0	33.1	32.3	74.8	111	109	0	34	34
2015	12	19	19	45	10	0.207	-0.079	0.879	0.039	0.039	0	32.7	32.3	74.4	110	109	0	34	34
2015	12	19	19	55	10	0.23	-0.085	0.879	0.036	0.033	0	32.7	32.3	74.8	110	109	0	34	34
2015	12	19	20	5	10	0.194	-0.043	0.879	0.033	0.03	0	32.7	31.8	74.4	110	108	0	34	34
2015	12	19	20	15	10	0.236	-0.082	0.879	0.036	0.033	0	32.3	32.3	74	109	108	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	20	25	10	0.262	-0.144	0.879	0.036	0.033	0	32.7	32.7	74.8	110	109	0	34	33
2015	12	19	20	35	10	0.269	-0.138	0.879	0.039	0.036	0	31.8	32.3	74.4	109	108	0	35	33
2015	12	19	20	45	10	0.22	-0.161	0.879	0.039	0.036	0	33.1	32.7	74.8	111	109	0	34	33
2015	12	19	20	55	10	0.223	-0.056	0.879	0.036	0.033	0	32.7	32.3	74.8	111	108	0	35	33
2015	12	19	21	5	10	0.249	-0.108	0.879	0.039	0.039	0	33.1	32.3	74.8	110	108	0	33	33
2015	12	19	21	15	10	0.23	-0.112	0.879	0.036	0.033	0	33.1	33.1	74.4	111	111	0	34	34
2015	12	19	21	25	10	0.207	-0.069	0.879	0.033	0.03	0	34.4	34	74.8	114	113	0	34	34
2015	12	19	21	35	10	0.236	-0.052	0.879	0.036	0.033	0	33.1	32.7	74.8	111	110	0	34	34
2015	12	19	21	45	10	0.2	-0.052	0.879	0.033	0.03	0	32.3	33.5	75.3	109	111	0	34	33
2015	12	19	21	55	10	0.226	-0.072	0.879	0.039	0.036	0	33.1	34	74.4	111	112	0	34	33
2015	12	19	22	5	10	0.322	-0.157	0.879	0.039	0.036	0	32.7	32.7	74.8	111	110	0	35	34
2015	12	19	22	15	10	0.279	-0.164	0.879	0.036	0.033	0	32.7	33.1	75.3	110	111	0	34	34
2015	12	19	22	25	10	0.207	-0.046	0.879	0.036	0.033	0	32.3	33.1	74.8	110	110	0	35	33
2015	12	19	22	35	10	0.236	-0.125	0.879	0.039	0.036	0	32.7	32.3	75.3	111	109	0	35	34
2015	12	19	22	45	10	0.171	-0.125	0.879	0.033	0.03	0	32.7	34	74.8	110	112	0	34	33
2015	12	19	22	55	10	0.256	-0.194	0.879	0.033	0.03	0	32.7	33.1	75.3	110	111	0	34	34
2015	12	19	23	5	10	0.259	-0.207	0.879	0.033	0.03	0	32.7	33.5	75.3	110	112	0	34	34
2015	12	19	23	15	10	0.331	-0.22	0.879	0.033	0.03	0	32.7	33.5	75.3	110	112	0	34	34
2015	12	19	23	25	10	0.299	-0.272	0.879	0.039	0.039	0	32.7	34	75.3	110	113	0	34	34
2015	12	19	23	35	10	0.253	-0.148	0.879	0.036	0.033	0	32.7	34.4	75.3	110	114	0	34	34
2015	12	19	23	45	10	0.302	-0.138	0.879	0.03	0.026	0	33.5	34.4	74.4	112	114	0	34	34
2015	12	19	23	55	10	0.22	-0.135	0.879	0.033	0.03	0	32.7	35.3	74.8	110	115	0	34	33
2015	12	20	0	5	10	0.243	-0.148	0.879	0.039	0.036	0	33.5	34.4	75.3	112	114	0	34	34
2015	12	20	0	15	10	0.23	-0.194	0.879	0.036	0.033	0	32.7	34.4	75.3	111	114	0	35	34
2015	12	20	0	25	10	0.2	-0.072	0.879	0.033	0.03	0	33.5	35.7	74.8	112	116	0	34	33
2015	12	20	0	35	10	0.151	-0.01	0.879	0.033	0.03	0	33.1	34.4	75.3	112	114	0	35	34
2015	12	20	0	45	10	0.102	0.082	0.879	0.03	0.03	0	33.5	34.4	74.8	112	114	0	34	34
2015	12	20	0	55	10	0.039	0.043	0.879	0.03	0.026	0	33.1	34.8	74.8	111	115	0	34	34
2015	12	20	1	5	10	0.062	0.036	0.879	0.039	0.039	0	34.4	35.3	75.7	114	115	0	34	33
2015	12	20	1	15	10	0.085	0.052	0.879	0.036	0.033	0	34.4	36.1	75.3	114	118	0	34	34
2015	12	20	1	25	10	0.003	0.039	0.879	0.03	0.03	0	34.4	35.7	75.7	114	116	0	34	33
2015	12	20	1	35	10	0.115	0.089	0.879	0.033	0.03	0	34	35.3	74.8	113	116	0	34	34
2015	12	20	1	45	10	0.066	0.033	0.879	0.033	0.03	0	34.8	35.3	75.3	115	115	0	34	33
2015	12	20	1	55	10	0.141	-0.062	0.879	0.033	0.03	0	34	35.7	75.3	113	116	0	34	33
2015	12	20	2	5	10	0.095	-0.043	0.879	0.039	0.036	0	34	35.7	75.3	114	117	0	35	34
2015	12	20	2	15	10	0.125	0.036	0.879	0.033	0.03	0	33.1	34.4	75.7	112	114	0	35	34
2015	12	20	2	25	10	0.167	-0.095	0.879	0.039	0.036	0	34.8	35.3	75.3	115	116	0	34	34
2015	12	20	2	35	10	0.19	-0.049	0.879	0.033	0.03	0	35.3	36.1	74.8	116	118	0	34	34
2015	12	20	2	45	10	0.249	-0.066	0.879	0.039	0.036	0	35.7	35.7	75.3	117	117	0	34	34
2015	12	20	2	55	10	0.167	-0.079	0.879	0.033	0.03	0	35.3	35.7	74.8	116	117	0	34	34
2015	12	20	3	5	10	0.154	-0.056	0.879	0.039	0.036	0	35.3	34.8	75.3	116	115	0	34	34
2015	12	20	3	15	10	0.22	-0.069	0.879	0.033	0.03	0	34	34.8	74.8	114	115	0	35	34
2015	12	20	3	25	10	0.203	-0.072	0.879	0.033	0.03	0	34.8	35.3	75.7	115	116	0	34	34
2015	12	20	3	35	10	0.223	0.007	0.879	0.036	0.033	0	34.8	35.3	75.3	116	116	0	35	34
2015	12	20	3	45	10	0.118	-0.016	0.879	0.033	0.03	0	33.5	35.7	74.8	113	117	0	35	34
2015	12	20	3	55	10	0.19	-0.066	0.879	0.036	0.033	0	34.8	35.7	74.8	115	116	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	4	5	10	0.249	-0.118	0.879	0.039	0.039	0	34.8	35.7	75.3	115	117	0	34	34
2015	12	20	4	15	10	0.262	-0.141	0.879	0.039	0.036	0	34.4	34.4	75.7	114	114	0	34	34
2015	12	20	4	25	10	0.174	-0.125	0.879	0.033	0.03	0	33.5	35.3	75.3	112	116	0	34	34
2015	12	20	4	35	10	0.24	-0.043	0.879	0.033	0.03	0	34.4	34.4	75.3	114	114	0	34	34
2015	12	20	4	45	10	0.187	-0.141	0.879	0.033	0.03	0	34.4	34.8	75.7	114	114	0	34	33
2015	12	20	4	55	10	0.246	-0.039	0.879	0.033	0.03	0	34	34.8	75.7	114	115	0	35	34
2015	12	20	5	5	10	0.217	-0.079	0.879	0.033	0.03	0	34	35.3	76.1	113	115	0	34	33
2015	12	20	5	15	10	0.23	-0.18	0.879	0.033	0.03	0	33.1	34.8	75.7	112	115	0	35	34
2015	12	20	5	25	10	0.157	-0.066	0.879	0.039	0.036	0	34	34.8	75.3	114	115	0	35	34
2015	12	20	5	35	10	0.174	-0.089	0.879	0.036	0.033	0	33.1	33.5	76.1	112	112	0	35	34
2015	12	20	5	45	10	0.167	-0.079	0.879	0.039	0.036	0	33.5	34	75.3	113	113	0	35	34
2015	12	20	5	55	10	0.187	-0.121	0.879	0.036	0.033	0	33.5	34.8	75.7	112	115	0	34	34
2015	12	20	6	5	10	0.203	-0.105	0.879	0.033	0.03	0	32.7	34	75.7	111	113	0	35	34
2015	12	20	6	15	10	0.135	-0.108	0.879	0.036	0.033	0	33.5	34	75.7	113	113	0	35	34
2015	12	20	6	25	10	0.167	-0.026	0.876	0.033	0.03	0	33.1	34.4	76.1	112	114	0	35	34
2015	12	20	6	35	10	0.213	-0.121	0.879	0.033	0.03	0	33.5	34.8	76.1	113	114	0	35	33
2015	12	20	6	45	10	0.079	-0.033	0.876	0.033	0.03	0	34.4	34.4	75.3	114	114	0	34	34
2015	12	20	6	55	10	0.098	-0.141	0.876	0.033	0.03	0	32.7	32.7	76.5	111	110	0	35	34
2015	12	20	7	5	10	0.121	-0.085	0.879	0.033	0.03	0	32.7	33.1	75.7	110	111	0	34	34
2015	12	20	7	15	10	0.049	0.016	0.876	0.039	0.036	0	32.3	32.7	75.7	110	110	0	35	34
2015	12	20	7	25	10	0.043	-0.033	0.876	0.036	0.033	0	31.4	31.8	76.1	108	108	0	35	34
2015	12	20	7	35	10	0.092	-0.026	0.876	0.033	0.03	0	31.8	31.8	76.5	109	108	0	35	34
2015	12	20	7	45	10	0.052	-0.052	0.879	0.039	0.036	0	31.8	31.8	76.1	109	108	0	35	34
2015	12	20	7	55	10	0.112	-0.161	0.876	0.036	0.033	0	32.3	32.3	77	109	108	0	34	33
2015	12	20	8	5	10	0.072	-0.098	0.879	0.039	0.036	0	32.7	31.8	76.5	110	109	0	34	35
2015	12	20	8	15	10	0.01	-0.062	0.876	0.036	0.033	0	31.8	31.8	76.5	109	108	0	35	34
2015	12	20	8	25	10	0.052	-0.062	0.879	0.033	0.03	0	31.8	31.4	76.1	108	107	0	34	34
2015	12	20	8	35	10	0.013	-0.052	0.876	0.033	0.03	0	31.8	31.4	76.5	109	107	0	35	34
2015	12	20	8	45	10	0.135	-0.203	0.876	0.03	0.03	0	31.4	32.3	76.1	108	109	0	35	34
2015	12	20	8	55	10	0.22	-0.177	0.876	0.03	0.03	0	31.8	31.8	76.1	108	108	0	34	34
2015	12	20	9	5	10	0.187	-0.121	0.879	0.036	0.033	0	32.3	31.4	76.5	109	107	0	34	34
2015	12	20	9	15	10	0.157	-0.125	0.876	0.039	0.039	0	31.8	31.8	76.1	109	109	0	35	35
2015	12	20	9	25	10	0.098	-0.026	0.876	0.039	0.036	0	31.4	31.4	76.5	108	107	0	35	34
2015	12	20	9	35	10	0.161	-0.075	0.879	0.033	0.03	0	31.4	31.4	76.5	107	107	0	34	34
2015	12	20	9	45	10	0.151	-0.125	0.876	0.036	0.033	0	32.3	32.3	76.5	110	109	0	35	34
2015	12	20	9	55	10	0.213	-0.108	0.876	0.036	0.033	0	32.7	32.3	75.7	111	108	0	35	33
2015	12	20	10	5	10	0.226	-0.072	0.879	0.036	0.033	0	32.7	32.3	76.1	110	109	0	34	34
2015	12	20	10	15	10	0.217	-0.072	0.876	0.033	0.03	0	31	32.3	76.1	107	109	0	35	34
2015	12	20	10	25	10	0.21	-0.105	0.876	0.036	0.033	0	31.8	31.4	75.7	108	107	0	34	34
2015	12	20	10	35	10	0.167	-0.089	0.876	0.039	0.036	0	31	31.8	76.1	107	107	0	35	33
2015	12	20	10	45	10	0.164	-0.105	0.876	0.039	0.039	0	32.3	32.7	75.7	109	110	0	34	34
2015	12	20	10	55	10	0.223	-0.092	0.876	0.043	0.039	0	34	33.5	76.1	113	112	0	34	34
2015	12	20	11	5	10	0.118	-0.128	0.876	0.033	0.03	0	33.1	33.1	75.7	111	111	0	34	34
2015	12	20	11	15	10	0.19	-0.03	0.876	0.033	0.03	0	33.1	33.1	76.1	111	111	0	34	34
2015	12	20	11	25	10	0.2	-0.069	0.876	0.039	0.036	0	32.7	33.5	75.3	111	112	0	35	34
2015	12	20	11	35	10	0.148	-0.046	0.876	0.043	0.039	0	32.3	32.7	75.7	110	110	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	11	45	10	0.19	-0.069	0.876	0.033	0.03	0	32.7	32.7	75.3	111	110	0	35	34
2015	12	20	11	55	10	0.164	-0.003	0.879	0.033	0.03	0	34	34.4	75.3	113	113	0	34	33
2015	12	20	12	5	10	0.177	-0.072	0.879	0.036	0.033	0	34	34.4	74.8	114	114	0	35	34
2015	12	20	12	15	10	0.095	-0.125	0.879	0.033	0.03	0	34.4	34.4	75.3	114	114	0	34	34
2015	12	20	12	25	10	0.194	-0.112	0.879	0.033	0.03	0	34.4	34.4	74.8	114	113	0	34	33
2015	12	20	12	35	10	0.148	-0.079	0.879	0.039	0.036	0	34.8	34	74.8	115	113	0	34	34
2015	12	20	12	45	10	0.157	-0.046	0.879	0.033	0.03	0	34.4	34	75.3	114	113	0	34	34
2015	12	20	12	55	10	0.184	-0.069	0.879	0.033	0.03	0	35.7	36.1	74.8	117	117	0	34	33
2015	12	20	13	5	10	0.164	-0.072	0.879	0.033	0.03	0	36.5	36.1	74.8	119	118	0	34	34
2015	12	20	13	15	10	0.164	-0.03	0.879	0.036	0.033	0	37.4	37.8	74.8	121	121	0	34	33
2015	12	20	13	25	10	0.217	-0.046	0.879	0.039	0.039	0	35.3	35.3	74.8	116	115	0	34	33
2015	12	20	13	35	10	0.276	-0.069	0.879	0.043	0.039	0	36.1	34.8	74.8	118	115	0	34	34
2015	12	20	13	45	10	0.18	-0.072	0.879	0.039	0.036	0	35.7	35.7	74.8	117	116	0	34	33
2015	12	20	13	55	10	0.223	-0.036	0.879	0.036	0.033	0	34.8	35.3	75.3	116	115	0	35	33
2015	12	20	14	5	10	0.207	-0.072	0.879	0.033	0.03	0	35.3	34.4	74.8	116	114	0	34	34
2015	12	20	14	15	10	0.24	-0.075	0.879	0.033	0.03	0	35.7	34.8	75.3	117	115	0	34	34
2015	12	20	14	25	10	0.154	-0.056	0.879	0.033	0.03	0	35.3	35.3	74.8	116	115	0	34	33
2015	12	20	14	35	10	0.154	-0.039	0.879	0.043	0.039	0	43.9	43.4	70.5	136	134	0	34	33
2015	12	20	14	45	10	0.161	-0.007	0.879	0.036	0.033	0	39.1	39.1	73.5	125	124	0	34	33
2015	12	20	14	55	10	0.171	0.026	0.879	0.033	0.03	0	37	37	74.4	120	119	0	34	33
2015	12	20	15	5	10	0.236	0.02	0.879	0.033	0.03	0	37.4	37	74.4	121	120	0	34	34
2015	12	20	15	15	10	0.154	-0.023	0.879	0.036	0.033	0	43.4	43	70.5	136	133	0	35	33
2015	12	20	15	25	10	0.138	-0.01	0.879	0.033	0.03	0	39.1	38.7	74	125	124	0	34	34
2015	12	20	15	35	10	0.157	0.036	0.883	0.046	0.043	0	37.4	37	74	121	120	0	34	34
2015	12	20	15	45	10	0.226	-0.043	0.883	0.036	0.033	0	36.1	36.5	74.4	118	118	0	34	33
2015	12	20	15	55	10	0.253	0.013	0.883	0.036	0.033	0	35.3	35.3	75.3	116	115	0	34	33
2015	12	20	16	5	10	0.187	-0.069	0.883	0.036	0.033	0	34.8	34.8	75.3	115	114	0	34	33
2015	12	20	16	15	10	0.203	-0.016	0.883	0.036	0.033	0	34.8	34.8	75.3	115	114	0	34	33
2015	12	20	16	25	10	0.184	0.023	0.883	0.036	0.033	0	34.4	34	75.3	114	113	0	34	34
2015	12	20	16	35	10	0.187	0	0.883	0.039	0.036	0	35.3	35.3	75.3	116	115	0	34	33
2015	12	20	16	45	10	0.194	0.023	0.883	0.036	0.033	0	34.8	35.3	75.7	115	116	0	34	34
2015	12	20	16	55	10	0.2	-0.01	0.883	0.036	0.033	0	34.4	34.4	75.7	114	114	0	34	34
2015	12	20	17	5	10	0.125	0.026	0.883	0.036	0.033	0	34.8	34.8	75.7	115	114	0	34	33
2015	12	20	17	15	10	0.19	0.003	0.883	0.033	0.03	0	34.8	34.4	76.1	115	113	0	34	33
2015	12	20	17	25	10	0.167	-0.016	0.883	0.036	0.033	0	34.8	34.4	76.1	115	114	0	34	34
2015	12	20	17	35	10	0.184	0.007	0.883	0.036	0.033	0	34.8	35.3	75.7	115	115	0	34	33
2015	12	20	17	45	10	0.135	-0.016	0.883	0.039	0.039	0	43	41.7	72.7	134	131	0	34	34
2015	12	20	17	55	10	0.148	0.01	0.883	0.033	0.03	0	37.8	38.3	75.3	123	122	0	35	33
2015	12	20	18	5	10	0.21	0.023	0.883	0.036	0.033	0	38.3	37.8	74.8	123	122	0	34	34
2015	12	20	18	15	10	0.194	-0.059	0.886	0.036	0.033	0	34	34.4	76.1	113	113	0	34	33
2015	12	20	18	25	10	0.223	0.052	0.886	0.033	0.03	0	33.5	33.1	76.5	112	111	0	34	34
2015	12	20	18	35	10	0.19	0.01	0.886	0.036	0.033	0	33.5	33.5	76.5	112	111	0	34	33
2015	12	20	18	45	10	0.141	-0.095	0.886	0.043	0.039	0	34	33.5	77	113	111	0	34	33
2015	12	20	18	55	10	0.21	0	0.886	0.036	0.033	0	34.8	34.8	76.5	116	115	0	35	34
2015	12	20	19	5	10	0.19	-0.056	0.886	0.036	0.033	0	32.7	32.7	77.4	110	109	0	34	33
2015	12	20	19	15	10	0.19	-0.121	0.886	0.033	0.033	0	31.4	32.3	77.8	108	108	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	19	25	10	0.105	-0.043	0.886	0.033	0.03	0	31.8	31.4	77.4	108	107	0	34	34
2015	12	20	19	35	10	0.18	-0.039	0.886	0.039	0.036	0	31.4	31	77.4	107	106	0	34	34
2015	12	20	19	45	10	0.194	-0.082	0.886	0.039	0.036	0	31.4	31.8	77.8	107	107	0	34	33
2015	12	20	19	55	10	0.223	-0.013	0.886	0.033	0.03	0	31.8	31.4	77.8	108	107	0	34	34
2015	12	20	20	5	10	0.128	-0.066	0.886	0.033	0.03	0	31.4	30.5	77.8	107	105	0	34	34
2015	12	20	20	15	10	0.151	-0.043	0.886	0.039	0.039	0	31.4	31.4	78.3	107	106	0	34	33
2015	12	20	20	25	10	0.138	0.03	0.886	0.036	0.033	0	31.8	31	78.7	108	106	0	34	34
2015	12	20	20	35	10	0.184	-0.154	0.886	0.039	0.036	0	31.8	30.5	78.3	108	105	0	34	34
2015	12	20	20	45	10	0.18	-0.043	0.889	0.033	0.03	0	31.4	31.4	78.3	107	106	0	34	33
2015	12	20	20	55	10	0.144	-0.03	0.889	0.033	0.03	0	31.4	31.4	78.7	107	107	0	34	34
2015	12	20	21	5	10	0.138	-0.056	0.889	0.033	0.033	0	31.8	32.3	78.3	108	108	0	34	33
2015	12	20	21	15	10	0.151	-0.016	0.889	0.033	0.03	0	31.8	33.1	78.7	109	110	0	35	33
2015	12	20	21	25	10	0.2	-0.115	0.889	0.036	0.033	0	35.3	34.8	77.8	116	115	0	34	34
2015	12	20	21	35	10	0.194	-0.016	0.889	0.039	0.036	0	32.3	32.7	78.7	109	110	0	34	34
2015	12	20	21	45	10	0.171	-0.043	0.889	0.036	0.033	0	31.8	32.3	78.7	108	109	0	34	34
2015	12	20	21	55	10	0.249	-0.039	0.889	0.043	0.039	0	32.3	32.7	78.7	109	109	0	34	33
2015	12	20	22	5	10	0.207	-0.062	0.889	0.033	0.03	0	31.8	32.3	79.1	107	108	0	33	33
2015	12	20	22	15	10	0.217	-0.089	0.889	0.039	0.036	0	32.3	33.1	79.1	109	110	0	34	33
2015	12	20	22	25	10	0.19	-0.112	0.889	0.039	0.036	0	32.7	33.1	78.3	110	111	0	34	34
2015	12	20	22	35	10	0.194	-0.125	0.889	0.039	0.036	0	33.1	33.1	79.1	111	110	0	34	33
2015	12	20	22	45	10	0.164	-0.098	0.889	0.036	0.033	0	31.8	32.7	79.1	109	110	0	35	34
2015	12	20	22	55	10	0.217	-0.062	0.889	0.036	0.033	0	32.3	34	78.3	110	112	0	35	33
2015	12	20	23	5	10	0.171	-0.056	0.889	0.033	0.03	0	33.1	33.5	80	111	111	0	34	33
2015	12	20	23	15	10	0.207	-0.069	0.889	0.039	0.036	0	33.5	33.5	79.6	112	112	0	34	34
2015	12	20	23	25	10	0.18	-0.016	0.889	0.043	0.039	0	33.5	34	78.3	112	112	0	34	33
2015	12	20	23	35	10	0.164	-0.154	0.889	0.036	0.033	0	33.1	34.8	78.7	111	114	0	34	33
2015	12	20	23	45	10	0.223	-0.069	0.889	0.033	0.03	0	33.5	33.1	79.1	112	111	0	34	34
2015	12	20	23	55	10	0.177	-0.052	0.889	0.033	0.03	0	34	34.8	78.7	113	115	0	34	34
2015	12	21	0	5	10	0.187	-0.059	0.889	0.033	0.03	0	34	35.7	78.7	113	116	0	34	33
2015	12	21	0	15	10	0.207	-0.082	0.889	0.033	0.03	0	33.1	34.4	78.7	111	114	0	34	34
2015	12	21	0	25	10	0.194	-0.043	0.889	0.036	0.033	0	33.5	35.7	78.3	113	116	0	35	33
2015	12	21	0	35	10	0.187	-0.102	0.889	0.03	0.03	0	33.5	34.8	78.3	113	114	0	35	33
2015	12	21	0	45	10	0.207	-0.125	0.889	0.033	0.03	0	34	34.8	78.7	113	114	0	34	33
2015	12	21	0	55	10	0.213	-0.082	0.889	0.033	0.03	0	33.5	34.4	78.3	113	114	0	35	34
2015	12	21	1	5	10	0.2	-0.036	0.889	0.033	0.03	0	33.5	33.5	79.1	112	112	0	34	34
2015	12	21	1	15	10	0.2	-0.079	0.889	0.033	0.03	0	34	35.3	78.7	113	116	0	34	34
2015	12	21	1	25	10	0.233	-0.102	0.889	0.033	0.03	0	34.4	34.8	78.7	114	114	0	34	33
2015	12	21	1	35	10	0.164	-0.046	0.889	0.033	0.03	0	33.1	34	78.7	111	113	0	34	34
2015	12	21	1	45	10	0.171	-0.082	0.889	0.033	0.03	0	34.4	34.8	78.3	114	115	0	34	34
2015	12	21	1	55	10	0.19	-0.059	0.889	0.033	0.03	0	34.4	35.7	78.7	114	117	0	34	34
2015	12	21	2	5	10	0.233	-0.098	0.889	0.036	0.033	0	34.4	34.8	78.3	115	115	0	35	34
2015	12	21	2	15	10	0.236	-0.046	0.889	0.033	0.03	0	33.5	34.8	78.3	112	115	0	34	34
2015	12	21	2	25	10	0.243	-0.164	0.889	0.033	0.03	0	34	34.8	78.7	113	115	0	34	34
2015	12	21	2	35	10	0.151	-0.079	0.889	0.036	0.033	0	34.4	34.8	78.7	114	115	0	34	34
2015	12	21	2	45	10	0.164	-0.056	0.889	0.036	0.033	0	34	34.4	78.7	113	114	0	34	34
2015	12	21	2	55	10	0.203	-0.135	0.889	0.033	0.03	0	34	34.8	78.3	113	115	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	3	5	10	0.187	-0.118	0.889	0.033	0.03	0	34	35.3	78.7	114	116	0	35	34
2015	12	21	3	15	10	0.141	-0.052	0.889	0.033	0.03	0	33.5	35.3	78.7	113	115	0	35	33
2015	12	21	3	25	10	0.233	-0.148	0.889	0.033	0.03	0	33.5	35.3	78.3	112	115	0	34	33
2015	12	21	3	35	10	0.21	-0.141	0.889	0.033	0.03	0	34	34.4	78.7	114	114	0	35	34
2015	12	21	3	45	10	0.22	-0.151	0.889	0.033	0.03	0	34	34.8	78.3	114	115	0	35	34
2015	12	21	3	55	10	0.246	-0.092	0.889	0.03	0.03	0	34	34.8	78.3	113	115	0	34	34
2015	12	21	4	5	10	0.246	-0.089	0.886	0.033	0.03	0	34	34.4	78.3	114	114	0	35	34
2015	12	21	4	15	10	0.194	-0.066	0.886	0.033	0.03	0	33.5	34.8	78.7	113	115	0	35	34
2015	12	21	4	25	10	0.177	-0.095	0.886	0.036	0.033	0	33.1	34.4	78.7	111	114	0	34	34
2015	12	21	4	35	10	0.177	-0.016	0.886	0.033	0.03	0	34.8	35.3	78.3	115	115	0	34	33
2015	12	21	4	45	10	0.246	-0.141	0.886	0.033	0.03	0	34	34	78.7	113	113	0	34	34
2015	12	21	4	55	10	0.203	-0.036	0.886	0.033	0.03	0	33.5	34.4	78.7	113	114	0	35	34
2015	12	21	5	5	10	0.253	-0.066	0.886	0.033	0.033	0	34.8	34.4	78.7	115	114	0	34	34
2015	12	21	5	15	10	0.23	-0.03	0.886	0.033	0.03	0	34	34.8	78.3	114	115	0	35	34
2015	12	21	5	25	10	0.21	-0.046	0.886	0.033	0.03	0	34	35.3	79.1	114	116	0	35	34
2015	12	21	5	35	10	0.21	-0.03	0.886	0.036	0.033	0	34	34.4	78.3	113	113	0	34	33
2015	12	21	5	45	10	0.213	-0.066	0.886	0.033	0.03	0	33.1	34.8	78.3	112	115	0	35	34
2015	12	21	5	55	10	0.213	-0.121	0.886	0.033	0.03	0	33.1	34.8	78.7	112	115	0	35	34
2015	12	21	6	5	10	0.23	-0.098	0.886	0.039	0.036	0	34.4	35.3	77.8	114	116	0	34	34
2015	12	21	6	15	10	0.246	-0.052	0.886	0.033	0.03	0	34	34.8	78.3	114	115	0	35	34
2015	12	21	6	25	10	0.151	-0.062	0.886	0.036	0.033	0	33.5	34.8	78.3	113	115	0	35	34
2015	12	21	6	35	10	0.236	-0.043	0.886	0.033	0.03	0	34.4	34.4	78.3	114	114	0	34	34
2015	12	21	6	45	10	0.21	-0.105	0.886	0.036	0.033	0	32.7	34.4	78.7	110	113	0	34	33
2015	12	21	6	55	10	0.18	-0.121	0.886	0.036	0.033	0	32.3	33.5	79.1	110	112	0	35	34
2015	12	21	7	5	10	0.256	-0.118	0.886	0.033	0.03	0	32.3	32.3	78.7	109	108	0	34	33
2015	12	21	7	15	10	0.197	-0.085	0.886	0.036	0.033	0	32.7	32.7	78.7	111	109	0	35	33
2015	12	21	7	25	10	0.213	-0.079	0.886	0.033	0.03	0	31.8	31.4	78.7	108	107	0	34	34
2015	12	21	7	35	10	0.236	-0.043	0.886	0.033	0.03	0	31	31	79.6	107	106	0	35	34
2015	12	21	7	45	10	0.243	-0.089	0.886	0.036	0.033	0	31.4	31.4	79.1	108	107	0	35	34
2015	12	21	7	55	10	0.217	-0.135	0.886	0.039	0.036	0	31	30.5	79.1	107	105	0	35	34
2015	12	21	8	5	10	0.197	-0.108	0.886	0.036	0.033	0	31	30.1	78.7	107	104	0	35	34
2015	12	21	8	15	10	0.18	-0.085	0.886	0.036	0.033	0	31.8	30.1	79.1	108	105	0	34	35
2015	12	21	8	25	10	0.213	-0.033	0.886	0.036	0.033	0	30.5	30.5	79.6	106	105	0	35	34
2015	12	21	8	35	10	0.243	-0.075	0.886	0.033	0.033	0	30.5	31	79.6	106	106	0	35	34
2015	12	21	8	45	10	0.23	-0.112	0.886	0.033	0.03	0	31.4	31	79.6	107	106	0	34	34
2015	12	21	8	55	10	0.236	-0.115	0.886	0.033	0.03	0	30.5	31	79.1	106	106	0	35	34
2015	12	21	9	5	10	0.167	-0.131	0.886	0.036	0.033	0	31.4	31.4	79.1	107	107	0	34	34
2015	12	21	9	15	10	0.246	-0.043	0.886	0.039	0.036	0	31	31.8	79.6	107	108	0	35	34
2015	12	21	9	25	10	0.223	-0.085	0.886	0.043	0.039	0	31.8	31.4	79.6	108	107	0	34	34
2015	12	21	9	35	10	0.24	-0.075	0.886	0.033	0.03	0	31.8	31.4	78.7	108	107	0	34	34
2015	12	21	9	45	10	0.187	-0.102	0.886	0.039	0.039	0	32.3	31.8	79.1	109	108	0	34	34
2015	12	21	9	55	10	0.19	-0.039	0.886	0.033	0.03	0	32.7	32.3	79.6	110	109	0	34	34
2015	12	21	10	5	10	0.226	-0.056	0.886	0.039	0.039	0	32.3	31.8	79.6	109	109	0	34	35
2015	12	21	10	15	10	0.22	-0.079	0.886	0.033	0.03	0	31.8	31.8	80	109	108	0	35	34
2015	12	21	10	25	10	0.144	-0.049	0.886	0.039	0.036	0	32.3	32.3	80	109	109	0	34	34
2015	12	21	10	35	10	0.21	-0.095	0.886	0.033	0.03	0	32.7	32.7	79.6	110	110	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	10	45	10	0.207	-0.049	0.886	0.033	0.03	0	33.1	32.7	79.1	111	110	0	34	34
2015	12	21	10	55	10	0.177	-0.098	0.886	0.036	0.033	0	32.7	33.5	79.1	110	112	0	34	34
2015	12	21	11	5	10	0.154	-0.082	0.886	0.033	0.03	0	32.7	33.1	78.7	110	109	0	34	32
2015	12	21	11	15	10	0.203	-0.023	0.886	0.039	0.036	0	32.7	34	79.6	110	112	0	34	33
2015	12	21	11	25	10	0.236	-0.115	0.886	0.036	0.033	0	32.7	32.7	79.1	111	110	0	35	34
2015	12	21	11	35	10	0.256	-0.023	0.886	0.033	0.03	0	32.3	33.1	78.7	110	111	0	35	34
2015	12	21	11	45	10	0.18	-0.082	0.886	0.039	0.039	0	34	34.4	78.7	114	113	0	35	33
2015	12	21	11	55	10	0.161	-0.023	0.886	0.033	0.03	0	34.4	34.4	79.1	114	114	0	34	34
2015	12	21	12	5	10	0.194	-0.056	0.886	0.036	0.033	0	34	33.5	78.7	113	112	0	34	34
2015	12	21	12	15	10	0.161	-0.049	0.886	0.036	0.033	0	34.4	34.4	78.3	114	114	0	34	34
2015	12	21	12	25	10	0.194	-0.013	0.886	0.039	0.036	0	34	34	78.3	114	113	0	35	34
2015	12	21	12	35	10	0.187	-0.102	0.886	0.033	0.03	0	34.4	34	78.7	114	112	0	34	33
2015	12	21	12	45	10	0.213	-0.033	0.886	0.036	0.033	0	34	34	78.3	113	113	0	34	34
2015	12	21	12	55	10	0.164	-0.043	0.886	0.036	0.033	0	34.4	34	78.3	113	113	0	33	34
2015	12	21	13	5	10	0.151	-0.089	0.886	0.036	0.033	0	34	33.1	78.3	113	111	0	34	34
2015	12	21	13	15	10	0.217	-0.089	0.886	0.043	0.039	0	33.5	33.5	78.7	113	112	0	35	34
2015	12	21	13	25	10	0.207	-0.082	0.886	0.049	0.046	0	34.4	34.4	78.3	114	114	0	34	34
2015	12	21	13	35	10	0.236	-0.085	0.886	0.039	0.036	0	33.5	34	77.8	112	113	0	34	34
2015	12	21	13	45	10	0.194	-0.148	0.886	0.039	0.039	0	34.8	34.8	77.8	115	114	0	34	33
2015	12	21	13	55	10	0.154	-0.082	0.886	0.039	0.036	0	34.8	35.7	77.8	116	116	0	35	33
2015	12	21	14	5	10	0.24	-0.043	0.886	0.043	0.043	0	36.5	37	77.8	119	119	0	34	33
2015	12	21	14	15	10	0.174	-0.036	0.886	0.039	0.036	0	37.8	38.3	77	122	122	0	34	33
2015	12	21	14	25	10	0.249	0.007	0.886	0.039	0.036	0	37.8	37.4	76.5	122	121	0	34	34
2015	12	21	14	35	10	0.174	-0.003	0.886	0.039	0.036	0	37.4	37.8	77	121	121	0	34	33
2015	12	21	14	45	10	0.22	0.039	0.886	0.036	0.033	0	37	37.4	76.5	121	120	0	35	33
2015	12	21	14	55	10	0.236	-0.003	0.886	0.033	0.03	0	37	37.8	77	120	121	0	34	33
2015	12	21	15	5	10	0.22	0.049	0.886	0.033	0.03	0	37	36.5	77	121	119	0	35	34
2015	12	21	15	15	10	0.095	-0.016	0.886	0.039	0.036	0	37.4	37	77	121	119	0	34	33
2015	12	21	15	25	10	0.19	0.072	0.886	0.036	0.033	0	38.3	38.3	76.5	123	123	0	34	34
2015	12	21	15	35	10	0.23	0.049	0.886	0.033	0.03	0	38.7	38.7	75.7	124	123	0	34	33
2015	12	21	15	45	10	0.223	0.026	0.886	0.036	0.033	0	38.7	38.3	76.5	124	122	0	34	33
2015	12	21	15	55	10	0.177	0.112	0.886	0.033	0.03	0	39.1	37.8	76.1	125	122	0	34	34
2015	12	21	16	5	10	0.18	-0.01	0.886	0.039	0.039	0	37.8	38.3	76.1	123	122	0	35	33
2015	12	21	16	15	10	0.194	0.056	0.886	0.033	0.03	0	38.3	37.8	75.7	123	122	0	34	34
2015	12	21	16	25	10	0.226	0.105	0.886	0.036	0.033	0	37.8	37.4	76.5	122	120	0	34	33
2015	12	21	16	35	10	0.2	0.036	0.886	0.033	0.03	0	37	36.1	76.5	120	118	0	34	34
2015	12	21	16	45	10	0.157	0.01	0.886	0.039	0.036	0	35.7	35.3	76.5	118	116	0	35	34
2015	12	21	16	55	10	0.131	0.013	0.886	0.036	0.033	0	35.7	35.3	76.5	117	116	0	34	34
2015	12	21	17	5	10	0.207	0.013	0.886	0.043	0.039	0	35.3	35.7	76.5	116	116	0	34	33
2015	12	21	17	15	10	0.236	0.056	0.886	0.033	0.03	0	35.7	35.7	76.5	117	116	0	34	33
2015	12	21	17	25	10	0.243	-0.026	0.886	0.033	0.03	0	36.1	36.1	75.7	119	118	0	35	34
2015	12	21	17	35	10	0.18	0.095	0.886	0.033	0.03	0	37.8	38.3	75.7	122	122	0	34	33
2015	12	21	17	45	10	0.236	0.095	0.886	0.036	0.033	0	37.4	37.4	75.7	121	120	0	34	33
2015	12	21	17	55	10	0.23	0.082	0.886	0.033	0.03	0	37.4	36.5	76.1	121	119	0	34	34
2015	12	21	18	5	10	0.24	0.092	0.886	0.043	0.039	0	37	37	75.7	120	119	0	34	33
2015	12	21	18	15	10	0.2	-0.01	0.886	0.039	0.036	0	37	36.1	75.7	120	118	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	18	25	10	0.161	0.013	0.886	0.039	0.036	0	35.7	35.7	76.1	117	116	0	34	33
2015	12	21	18	35	10	0.223	0.026	0.886	0.033	0.03	0	35.7	34.8	76.1	116	114	0	33	33
2015	12	21	18	45	10	0.203	-0.023	0.886	0.036	0.033	0	33.5	34.4	76.5	113	114	0	35	34
2015	12	21	18	55	10	0.151	-0.059	0.886	0.033	0.03	0	33.5	33.5	77	113	111	0	35	33
2015	12	21	19	5	10	0.203	0	0.883	0.039	0.039	0	33.1	33.1	76.5	111	110	0	34	33
2015	12	21	19	15	10	0.161	-0.007	0.886	0.039	0.036	0	33.1	32.7	76.5	111	109	0	34	33
2015	12	21	19	25	10	0.105	0.003	0.883	0.039	0.036	0	33.5	32.7	76.1	112	110	0	34	34
2015	12	21	19	35	10	0.157	-0.039	0.883	0.036	0.033	0	32.7	32.3	76.5	110	109	0	34	34
2015	12	21	19	45	10	0.184	-0.059	0.886	0.043	0.039	0	32.3	32.3	77	110	109	0	35	34
2015	12	21	19	55	10	0.138	-0.03	0.883	0.039	0.039	0	32.3	33.1	76.5	110	110	0	35	33
2015	12	21	20	5	10	0.095	-0.02	0.883	0.033	0.03	0	32.7	32.7	76.1	110	109	0	34	33
2015	12	21	20	15	10	0.151	-0.072	0.886	0.033	0.033	0	32.7	31.8	76.5	110	107	0	34	33
2015	12	21	20	25	10	0.197	-0.085	0.886	0.049	0.046	0	31.8	31.8	77	109	107	0	35	33
2015	12	21	20	35	10	0.151	-0.043	0.883	0.036	0.033	0	31.8	31.8	76.5	108	107	0	34	33
2015	12	21	20	45	10	0.177	-0.135	0.883	0.036	0.033	0	31.8	31.8	76.5	107	107	0	33	33
2015	12	21	20	55	10	0.164	-0.069	0.883	0.039	0.036	0	31.4	31.4	76.5	107	107	0	34	34
2015	12	21	21	5	10	0.118	-0.135	0.883	0.036	0.033	0	31.4	31.4	76.1	107	106	0	34	33
2015	12	21	21	15	10	0.125	-0.092	0.883	0.039	0.039	0	31.8	31.8	77	108	108	0	34	34
2015	12	21	21	25	10	0.203	-0.056	0.883	0.033	0.03	0	31.8	31.8	76.1	108	108	0	34	34
2015	12	21	21	35	10	0.256	-0.085	0.883	0.036	0.033	0	30.1	31.4	76.5	105	107	0	35	34
2015	12	21	21	45	10	0.167	-0.069	0.883	0.039	0.036	0	31.8	31.8	76.1	108	108	0	34	34
2015	12	21	21	55	10	0.194	-0.105	0.883	0.03	0.03	0	31.8	31.8	76.5	109	108	0	35	34
2015	12	21	22	5	10	0.213	-0.056	0.883	0.036	0.033	0	31.8	31.8	76.1	108	107	0	34	33
2015	12	21	22	15	10	0.2	-0.18	0.883	0.039	0.036	0	32.7	32.7	77	110	109	0	34	33
2015	12	21	22	25	10	0.23	0	0.883	0.033	0.03	0	32.7	31.8	75.7	110	107	0	34	33
2015	12	21	22	35	10	0.095	-0.036	0.883	0.036	0.033	0	33.1	32.7	75.7	111	109	0	34	33
2015	12	21	22	45	10	0.213	-0.098	0.883	0.039	0.039	0	33.1	32.3	75.7	111	109	0	34	34
2015	12	21	22	55	10	0.217	-0.131	0.883	0.033	0.03	0	32.3	32.7	75.3	109	110	0	34	34
2015	12	21	23	5	10	0.207	-0.098	0.883	0.036	0.033	0	32.7	33.5	75.7	111	112	0	35	34
2015	12	21	23	15	10	0.187	-0.098	0.883	0.036	0.033	0	33.5	34.8	75.3	113	114	0	35	33
2015	12	21	23	25	10	0.24	-0.092	0.883	0.033	0.03	0	33.1	34	76.1	111	112	0	34	33
2015	12	21	23	35	10	0.187	-0.03	0.883	0.03	0.03	0	33.1	34	75.3	111	113	0	34	34
2015	12	21	23	45	10	0.128	0.026	0.883	0.036	0.033	0	33.5	34	75.7	112	113	0	34	34
2015	12	21	23	55	10	0.207	-0.128	0.883	0.036	0.033	0	33.5	32.7	76.1	112	110	0	34	34
2015	12	22	0	5	10	0.187	-0.092	0.883	0.039	0.036	0	33.1	34.8	75.3	111	114	0	34	33
2015	12	22	0	15	10	0.161	-0.056	0.879	0.039	0.036	0	34.8	35.3	75.3	115	115	0	34	33
2015	12	22	0	25	10	0.167	-0.052	0.883	0.036	0.033	0	34	34.8	74.4	114	115	0	35	34
2015	12	22	0	35	10	0.19	-0.069	0.879	0.036	0.033	0	34	35.3	74.8	113	115	0	34	33
2015	12	22	0	45	10	0.167	-0.095	0.879	0.036	0.033	0	34.4	34.4	75.3	114	114	0	34	34
2015	12	22	0	55	10	0.207	-0.056	0.879	0.033	0.03	0	34.4	35.7	74.8	114	117	0	34	34
2015	12	22	1	5	10	0.154	-0.069	0.879	0.033	0.03	0	34	35.3	74.8	114	116	0	35	34
2015	12	22	1	15	10	0.184	-0.089	0.879	0.033	0.03	0	34.4	34.8	74.4	114	115	0	34	34
2015	12	22	1	25	10	0.249	-0.036	0.879	0.039	0.036	0	34.4	35.7	75.3	114	117	0	34	34
2015	12	22	1	35	10	0.203	-0.085	0.879	0.033	0.03	0	35.3	35.7	74.8	116	117	0	34	34
2015	12	22	1	45	10	0.184	-0.089	0.879	0.039	0.036	0	34.4	35.3	75.7	114	116	0	34	34
2015	12	22	1	55	10	0.223	-0.016	0.879	0.033	0.03	0	34.8	35.3	74.8	116	116	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	2	5	10	0.177	-0.056	0.879	0.039	0.036	0	34.8	35.7	74.8	115	117	0	34	34
2015	12	22	2	15	10	0.174	-0.072	0.879	0.033	0.03	0	34.4	35.3	74.8	115	115	0	35	33
2015	12	22	2	25	10	0.236	-0.069	0.879	0.033	0.03	0	34.8	36.1	74	115	117	0	34	33
2015	12	22	2	35	10	0.138	-0.112	0.879	0.033	0.03	0	35.3	36.5	74.4	116	118	0	34	33
2015	12	22	2	45	10	0.171	-0.043	0.879	0.036	0.033	0	34.4	36.1	74.4	114	118	0	34	34
2015	12	22	2	55	10	0.194	-0.062	0.879	0.036	0.033	0	34.8	36.1	74.4	116	118	0	35	34
2015	12	22	3	5	10	0.203	-0.112	0.879	0.036	0.033	0	35.3	36.1	74	116	118	0	34	34
2015	12	22	3	15	10	0.187	-0.102	0.879	0.033	0.03	0	36.1	37	73.5	118	119	0	34	33
2015	12	22	3	25	10	0.131	-0.062	0.879	0.033	0.03	0	35.7	37	74	117	119	0	34	33
2015	12	22	3	35	10	0.184	-0.128	0.879	0.039	0.036	0	35.7	38.3	73.1	117	122	0	34	33
2015	12	22	3	45	10	0.177	-0.059	0.876	0.033	0.03	0	37	37.8	72.2	120	121	0	34	33
2015	12	22	3	55	10	0.125	-0.098	0.879	0.033	0.03	0	38.3	39.1	74.4	123	125	0	34	34
2015	12	22	4	5	10	0.233	-0.062	0.879	0.033	0.03	0	38.3	39.1	73.1	123	125	0	34	34
2015	12	22	4	15	10	0.131	0.01	0.876	0.03	0.03	0	40	40.4	73.1	127	128	0	34	34
2015	12	22	4	25	10	0.19	-0.062	0.873	0.033	0.03	0	39.6	40	72.7	126	127	0	34	34
2015	12	22	4	35	10	0.177	-0.052	0.879	0.033	0.03	0	39.6	40.4	73.1	126	128	0	34	34
2015	12	22	4	45	10	0.266	-0.082	0.876	0.033	0.03	0	39.6	40	72.7	126	127	0	34	34
2015	12	22	4	55	10	0.18	-0.03	0.876	0.033	0.03	0	38.3	39.6	73.1	123	126	0	34	34
2015	12	22	5	5	10	0.207	-0.043	0.876	0.033	0.03	0	39.1	40.4	72.7	125	127	0	34	33
2015	12	22	5	15	10	0.19	-0.02	0.876	0.03	0.03	0	39.6	39.6	73.1	125	126	0	33	34
2015	12	22	5	25	10	0.236	0	0.876	0.033	0.03	0	37.4	39.1	73.1	122	125	0	35	34
2015	12	22	5	35	10	0.19	-0.036	0.876	0.036	0.033	0	38.7	39.1	73.5	124	125	0	34	34
2015	12	22	5	45	10	0.23	-0.066	0.876	0.043	0.039	0	37.8	38.7	73.1	122	124	0	34	34
2015	12	22	5	55	10	0.21	-0.036	0.876	0.033	0.03	0	38.7	39.1	73.1	124	125	0	34	34
2015	12	22	6	5	10	0.184	-0.056	0.876	0.033	0.03	0	38.3	39.1	73.5	122	125	0	33	34
2015	12	22	6	15	10	0.138	-0.03	0.873	0.036	0.033	0	38.3	40	73.5	123	127	0	34	34
2015	12	22	6	25	10	0.177	-0.033	0.876	0.033	0.03	0	38.7	39.1	73.1	124	125	0	34	34
2015	12	22	6	35	10	0.253	-0.052	0.876	0.03	0.03	0	38.7	39.1	72.7	124	125	0	34	34
2015	12	22	6	45	10	0.167	-0.013	0.873	0.033	0.03	0	37.4	39.1	72.7	121	125	0	34	34
2015	12	22	6	55	10	0.253	-0.079	0.873	0.033	0.03	0	37.4	38.7	73.5	121	123	0	34	33
2015	12	22	7	5	10	0.236	-0.095	0.876	0.036	0.033	0	36.5	36.5	73.5	118	119	0	33	34
2015	12	22	7	15	10	0.197	-0.007	0.873	0.033	0.03	0	35.3	36.5	73.5	116	118	0	34	33
2015	12	22	7	25	10	0.164	-0.043	0.873	0.033	0.03	0	35.3	36.1	73.5	116	117	0	34	33
2015	12	22	7	35	10	0.19	-0.026	0.876	0.036	0.033	0	36.1	35.7	73.1	118	117	0	34	34
2015	12	22	7	45	10	0.223	-0.013	0.873	0.03	0.03	0	34.8	36.5	74	116	118	0	35	33
2015	12	22	7	55	10	0.138	-0.03	0.873	0.033	0.03	0	35.3	34.8	73.1	117	116	0	35	35
2015	12	22	8	5	10	0.157	-0.098	0.869	0.039	0.039	0	35.7	36.1	72.7	117	117	0	34	33
2015	12	22	8	15	10	0.138	-0.092	0.869	0.033	0.03	0	35.3	36.1	73.5	116	117	0	34	33
2015	12	22	8	25	10	0.164	-0.079	0.869	0.033	0.03	0	35.7	36.5	73.5	117	118	0	34	33
2015	12	22	8	35	10	0.177	0	0.873	0.033	0.03	0	35.3	35.3	73.1	116	115	0	34	33
2015	12	22	8	45	10	0.164	-0.056	0.869	0.033	0.03	0	35.3	35.7	73.5	116	116	0	34	33
2015	12	22	8	55	10	0.21	-0.072	0.873	0.033	0.03	0	34.4	34.4	74	114	114	0	34	34
2015	12	22	9	5	10	0.151	-0.098	0.869	0.033	0.03	0	33.5	34.8	74.4	113	115	0	35	34
2015	12	22	9	15	10	0.161	-0.03	0.866	0.033	0.03	0	39.6	39.1	73.1	126	125	0	34	34
2015	12	22	9	25	10	0.194	-0.049	0.866	0.033	0.03	0	38.7	39.6	73.1	124	125	0	34	33
2015	12	22	9	35	10	0.18	-0.082	0.866	0.033	0.03	0	36.1	36.5	73.5	118	118	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	9	45	10	0.161	-0.007	0.866	0.039	0.036	0	35.3	35.7	74.4	116	116	0	34	33
2015	12	22	9	55	10	0.223	-0.056	0.866	0.036	0.033	0	34.8	35.7	74.8	115	116	0	34	33
2015	12	22	10	5	10	0.253	-0.092	0.866	0.033	0.03	0	34	34.8	74.8	114	115	0	35	34
2015	12	22	10	15	10	0.207	-0.079	0.866	0.039	0.039	0	36.1	36.1	74.8	118	118	0	34	34
2015	12	22	10	25	10	0.223	-0.02	0.866	0.039	0.036	0	35.3	36.1	75.3	116	118	0	34	34
2015	12	22	10	35	10	0.157	-0.069	0.866	0.039	0.036	0	34.4	35.7	75.3	115	117	0	35	34
2015	12	22	10	45	10	0.18	-0.056	0.863	0.039	0.036	0	36.1	37.8	74.4	119	121	0	35	33
2015	12	22	10	55	10	0.23	-0.039	0.863	0.036	0.033	0	37	37.4	75.3	120	121	0	34	34
2015	12	22	11	5	10	0.174	-0.01	0.866	0.043	0.039	0	36.1	37	74.8	118	119	0	34	33
2015	12	22	11	15	10	0.171	-0.046	0.866	0.039	0.036	0	36.5	36.5	75.3	119	119	0	34	34
2015	12	22	11	25	10	0.187	0	0.866	0.039	0.036	0	36.1	37	76.1	118	119	0	34	33
2015	12	22	11	35	10	0.154	-0.007	0.866	0.033	0.03	0	39.1	39.6	75.7	125	126	0	34	34
2015	12	22	11	45	10	0.2	-0.003	0.863	0.036	0.033	0	38.7	38.7	75.7	124	123	0	34	33
2015	12	22	11	55	10	0.144	0.052	0.863	0.033	0.03	0	38.3	37.8	75.7	123	122	0	34	34
2015	12	22	12	5	10	0.184	-0.036	0.863	0.039	0.039	0	37.8	37.4	76.1	122	120	0	34	33
2015	12	22	12	15	10	0.141	-0.01	0.863	0.036	0.033	0	40.9	40	74.4	129	126	0	34	33
2015	12	22	12	25	10	0.164	0.003	0.863	0.043	0.039	0	41.3	40.4	74.8	130	127	0	34	33
2015	12	22	12	35	10	0.213	0.105	0.863	0.036	0.033	0	39.1	40	75.7	125	126	0	34	33
2015	12	22	12	45	10	0.2	0.105	0.863	0.039	0.036	0	40	40.4	74.8	127	127	0	34	33
2015	12	22	12	55	10	0.128	0.059	0.863	0.03	0.03	0	40	40.9	75.3	127	128	0	34	33
2015	12	22	13	5	10	0.105	0.079	0.863	0.033	0.03	0	40.9	41.3	74.8	130	129	0	35	33
2015	12	22	13	15	10	0.167	0.039	0.863	0.036	0.033	0	45.6	44.3	72.7	139	136	0	33	33
2015	12	22	13	25	10	0.197	0.046	0.866	0.036	0.033	0	49.9	47.7	71.4	149	144	0	33	33
2015	12	22	13	35	10	0.138	0.043	0.86	0.043	0.039	0	43.4	43	70.1	135	134	0	34	34
2015	12	22	13	45	10	0.217	-0.01	0.86	0.036	0.033	0	46.9	46	69.7	143	139	0	34	32
2015	12	22	13	55	10	0.187	0.013	0.86	0.039	0.036	0	49	47.7	65.8	147	145	0	33	34
2015	12	22	14	5	10	0.194	-0.089	0.863	0.033	0.03	0	49.9	48.6	65.8	150	147	0	34	34
2015	12	22	14	15	10	0.075	0.066	0.863	0.036	0.033	0	49.5	49	67.9	149	147	0	34	33
2015	12	22	14	25	10	0.262	-0.013	0.86	0.039	0.036	0	51.2	50.7	64.5	153	151	0	34	33
2015	12	22	14	35	10	0.174	0.003	0.86	0.043	0.039	0	52.9	52.5	60.2	157	154	0	34	32
2015	12	22	14	45	10	0.184	0.016	0.86	0.039	0.036	0	52.9	52	61.1	157	155	0	34	34
2015	12	22	14	55	10	0.187	-0.01	0.863	0.036	0.033	0	52	51.6	64.9	155	154	0	34	34
2015	12	22	15	5	10	0.144	0.026	0.86	0.039	0.039	0	52.5	52.5	64.1	156	155	0	34	33
2015	12	22	15	15	10	0.226	0.082	0.86	0.033	0.03	0	52	51.6	64.9	154	153	0	33	33
2015	12	22	15	25	10	0.21	0.066	0.86	0.039	0.036	0	49.9	49.5	67.5	150	148	0	34	33
2015	12	22	15	35	10	0.223	-0.016	0.86	0.043	0.039	0	49.5	48.6	69.2	148	146	0	33	33
2015	12	22	15	45	10	0.226	0.039	0.86	0.033	0.03	0	48.6	48.2	69.7	147	145	0	34	33
2015	12	22	15	55	10	0.177	0.075	0.86	0.036	0.033	0	48.2	47.7	71	146	143	0	34	32
2015	12	22	16	5	10	0.121	0.02	0.86	0.033	0.03	0	47.3	46.9	71.4	144	142	0	34	33
2015	12	22	16	15	10	0.085	0.046	0.863	0.039	0.036	0	46	45.6	71.8	141	140	0	34	34
2015	12	22	16	25	10	0.233	0.059	0.863	0.033	0.03	0	47.3	46.9	71.4	144	142	0	34	33
2015	12	22	16	35	10	0.203	0.026	0.863	0.039	0.036	0	45.6	44.7	73.5	139	137	0	33	33
2015	12	22	16	45	10	0.131	0.079	0.86	0.039	0.036	0	43.9	43.9	74	136	135	0	34	33
2015	12	22	16	55	10	0.115	0.075	0.863	0.052	0.052	0	43.9	43	74	135	134	0	33	34
2015	12	22	17	5	10	0.18	0.03	0.863	0.039	0.036	0	43.9	44.3	74	136	136	0	34	33
2015	12	22	17	15	10	0.148	0.01	0.863	0.036	0.033	0	45.2	45.2	73.1	139	138	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	17	25	10	0.174	0.102	0.863	0.043	0.039	0	44.3	43.9	73.5	137	135	0	34	33
2015	12	22	17	35	10	0.19	0.128	0.863	0.033	0.03	0	43.4	43	74.4	134	133	0	33	33
2015	12	22	17	45	10	0.148	0.069	0.86	0.033	0.03	0	51.6	50.7	67.5	154	152	0	34	34
2015	12	22	17	55	10	0.157	0.095	0.86	0.033	0.03	0	49	47.7	70.5	147	145	0	33	34
2015	12	22	18	5	10	0.197	0.085	0.863	0.049	0.046	0	46	45.6	73.1	140	139	0	33	33
2015	12	22	18	15	10	0.2	0.092	0.863	0.039	0.039	0	44.3	43.9	74	137	135	0	34	33
2015	12	22	18	25	10	0.187	0.161	0.863	0.036	0.033	0	43.4	42.6	74.8	135	132	0	34	33
2015	12	22	18	35	10	0.2	0.118	0.863	0.039	0.036	0	42.1	41.7	75.7	131	130	0	33	33
2015	12	22	18	45	10	0.217	0.079	0.863	0.033	0.03	0	40.4	40.4	76.1	128	127	0	34	33
2015	12	22	18	55	10	0.184	0.115	0.863	0.036	0.033	0	39.6	40	76.5	125	125	0	33	32
2015	12	22	19	5	10	0.171	0.171	0.863	0.036	0.033	0	43.4	43	74.8	135	134	0	34	34
2015	12	22	19	15	10	0.171	0.072	0.863	0.033	0.03	0	41.7	41.7	76.1	131	130	0	34	33
2015	12	22	19	25	10	0.157	0.046	0.863	0.036	0.033	0	40	39.6	76.5	127	125	0	34	33
2015	12	22	19	35	10	0.148	0.013	0.863	0.039	0.039	0	43	42.6	74.4	133	132	0	33	33
2015	12	22	19	45	10	0.161	0.023	0.863	0.033	0.03	0	40	40.4	76.1	127	128	0	34	34
2015	12	22	19	55	10	0.144	0.082	0.863	0.033	0.03	0	38.3	39.6	77	123	123	0	34	31
2015	12	22	20	5	10	0.131	0.026	0.863	0.033	0.03	0	39.6	40	76.1	126	126	0	34	33
2015	12	22	20	15	10	0.194	0.059	0.863	0.039	0.036	0	37.4	37.8	77.4	121	121	0	34	33
2015	12	22	20	25	10	0.115	0.01	0.863	0.033	0.03	0	37	37	77.8	120	118	0	34	32
2015	12	22	20	35	10	0.164	-0.02	0.863	0.033	0.03	0	36.5	36.5	77.4	118	118	0	33	33
2015	12	22	20	45	10	0.164	-0.01	0.863	0.033	0.03	0	37	37.4	77	119	119	0	33	32
2015	12	22	20	55	10	0.18	0.062	0.863	0.039	0.039	0	36.1	36.1	77.8	117	117	0	33	33
2015	12	22	21	5	10	0.18	0.01	0.863	0.033	0.03	0	36.5	37	77	119	119	0	34	33
2015	12	22	21	15	10	0.174	0.066	0.863	0.036	0.033	0	36.5	37.4	77.4	119	120	0	34	33
2015	12	22	21	25	10	0.197	0.013	0.863	0.036	0.033	0	37	37	77	120	119	0	34	33
2015	12	22	21	35	10	0.171	0.026	0.863	0.033	0.03	0	36.5	37.8	77.4	120	121	0	35	33
2015	12	22	21	45	10	0.226	0.013	0.863	0.036	0.033	0	37	37	76.1	120	119	0	34	33
2015	12	22	21	55	10	0.154	0.01	0.863	0.033	0.03	0	37	37	77	120	120	0	34	34
2015	12	22	22	5	10	0.115	-0.03	0.863	0.033	0.03	0	36.5	37	77	119	119	0	34	33
2015	12	22	22	15	10	0.194	-0.039	0.863	0.036	0.033	0	36.1	37.4	77	118	119	0	34	32
2015	12	22	22	25	10	0.203	-0.049	0.863	0.033	0.03	0	36.1	37.8	77	118	121	0	34	33
2015	12	22	22	35	10	0.171	-0.098	0.863	0.033	0.03	0	37.4	38.3	77	120	121	0	33	32
2015	12	22	22	45	10	0.141	0.007	0.863	0.039	0.036	0	36.1	37.4	77	118	120	0	34	33
2015	12	22	22	55	10	0.141	-0.059	0.863	0.033	0.03	0	37	38.3	76.1	120	122	0	34	33
2015	12	22	23	5	10	0.154	-0.043	0.863	0.033	0.03	0	37.4	39.1	76.5	121	123	0	34	32
2015	12	22	23	15	10	0.108	-0.059	0.863	0.03	0.03	0	37.8	38.3	76.1	121	122	0	33	33
2015	12	22	23	25	10	0.144	-0.039	0.863	0.033	0.03	0	37	38.7	75.3	120	123	0	34	33
2015	12	22	23	35	10	0.18	-0.043	0.863	0.039	0.036	0	37.8	38.7	75.7	122	122	0	34	32
2015	12	22	23	45	10	0.18	-0.089	0.863	0.033	0.03	0	37.8	38.7	75.7	122	123	0	34	33
2015	12	22	23	55	10	0.236	-0.007	0.863	0.033	0.03	0	37.8	39.6	75.7	122	125	0	34	33
2015	12	23	0	5	10	0.167	0.016	0.863	0.033	0.03	0	38.7	40	75.3	124	125	0	34	32
2015	12	23	0	15	10	0.108	-0.049	0.863	0.033	0.03	0	38.3	40	75.3	123	126	0	34	33
2015	12	23	0	25	10	0.112	-0.056	0.863	0.033	0.03	0	38.7	39.6	76.5	124	125	0	34	33
2015	12	23	0	35	10	0.177	-0.016	0.863	0.033	0.03	0	37.8	40.4	75.7	122	127	0	34	33
2015	12	23	0	45	10	0.2	-0.013	0.863	0.033	0.03	0	37.8	40.4	76.1	122	127	0	34	33
2015	12	23	0	55	10	0.217	-0.02	0.863	0.033	0.03	0	38.7	40	75.3	124	127	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	1	5	10	0.161	-0.059	0.863	0.033	0.03	0	39.1	40.9	75.3	125	128	0	34	33
2015	12	23	1	15	10	0.19	-0.115	0.863	0.036	0.033	0	39.1	40.4	74.8	126	127	0	35	33
2015	12	23	1	25	10	0.194	-0.03	0.863	0.036	0.033	0	39.6	41.3	74.4	125	129	0	33	33
2015	12	23	1	35	10	0.157	-0.072	0.863	0.033	0.03	0	39.1	41.3	75.3	125	129	0	34	33
2015	12	23	1	45	10	0.171	-0.052	0.863	0.039	0.036	0	39.6	41.7	74.8	126	130	0	34	33
2015	12	23	1	55	10	0.171	-0.108	0.863	0.033	0.03	0	40	40.9	75.7	127	128	0	34	33
2015	12	23	2	5	10	0.138	-0.056	0.863	0.03	0.03	0	40	40.4	74.4	126	128	0	33	34
2015	12	23	2	15	10	0.171	-0.056	0.863	0.033	0.03	0	40.4	41.7	74.8	127	130	0	33	33
2015	12	23	2	25	10	0.194	-0.075	0.863	0.033	0.03	0	38.7	40.9	75.3	125	128	0	35	33
2015	12	23	2	35	10	0.21	0.016	0.863	0.033	0.03	0	39.6	40.9	75.3	126	128	0	34	33
2015	12	23	2	45	10	0.141	-0.046	0.863	0.033	0.03	0	40.4	42.1	74.4	128	131	0	34	33
2015	12	23	2	55	10	0.141	0.013	0.863	0.033	0.03	0	40.9	41.3	74.4	128	130	0	33	34
2015	12	23	3	5	10	0.135	-0.125	0.863	0.033	0.03	0	40	42.1	74.4	127	132	0	34	34
2015	12	23	3	15	10	0.138	-0.059	0.863	0.033	0.03	0	40	42.1	74.4	127	131	0	34	33
2015	12	23	3	25	10	0.197	-0.036	0.863	0.033	0.03	0	40.9	41.3	74.4	129	129	0	34	33
2015	12	23	3	35	10	0.151	-0.033	0.863	0.033	0.03	0	40.4	41.7	74.8	128	130	0	34	33
2015	12	23	3	45	10	0.167	-0.052	0.86	0.03	0.03	0	40	42.1	74	128	131	0	35	33
2015	12	23	3	55	10	0.125	-0.039	0.863	0.036	0.033	0	39.1	41.7	74	125	131	0	34	34
2015	12	23	4	5	10	0.194	-0.016	0.863	0.033	0.03	0	39.6	41.7	74.8	126	130	0	34	33
2015	12	23	4	15	10	0.2	-0.03	0.86	0.03	0.026	0	40.4	41.3	74	128	130	0	34	34
2015	12	23	4	25	10	0.069	-0.036	0.86	0.03	0.03	0	40.4	41.3	74.4	128	130	0	34	34
2015	12	23	4	35	10	0.154	-0.003	0.86	0.033	0.03	0	40	42.1	74	128	131	0	35	33
2015	12	23	4	45	10	0.148	-0.062	0.86	0.033	0.03	0	40	42.1	74.4	127	131	0	34	33
2015	12	23	4	55	10	0.174	-0.062	0.86	0.036	0.033	0	41.7	42.6	74	131	133	0	34	34
2015	12	23	5	5	10	0.174	0.072	0.86	0.033	0.03	0	41.7	41.7	74.4	130	130	0	33	33
2015	12	23	5	15	10	0.167	-0.056	0.86	0.033	0.03	0	40	41.3	74.4	127	130	0	34	34
2015	12	23	5	25	10	0.194	-0.03	0.86	0.03	0.03	0	39.6	41.7	74	127	130	0	35	33
2015	12	23	5	35	10	0.141	-0.052	0.86	0.033	0.03	0	40.4	42.1	74	128	131	0	34	33
2015	12	23	5	45	10	0.167	-0.043	0.86	0.033	0.03	0	40	40.9	74.8	127	129	0	34	34
2015	12	23	5	55	10	0.141	-0.095	0.86	0.033	0.03	0	40.9	41.7	74.4	129	130	0	34	33
2015	12	23	6	5	10	0.131	-0.052	0.86	0.033	0.03	0	40	41.3	74	127	129	0	34	33
2015	12	23	6	15	10	0.164	-0.112	0.86	0.033	0.03	0	40.4	41.7	74	128	130	0	34	33
2015	12	23	6	25	10	0.171	-0.066	0.86	0.033	0.03	0	40	41.7	74	127	130	0	34	33
2015	12	23	6	35	10	0.18	0.013	0.86	0.033	0.03	0	40	42.1	73.5	127	131	0	34	33
2015	12	23	6	45	10	0.171	-0.039	0.86	0.036	0.033	0	40.4	41.7	74.4	128	130	0	34	33
2015	12	23	6	55	10	0.167	-0.043	0.86	0.03	0.03	0	39.1	40	74.4	125	127	0	34	34
2015	12	23	7	5	10	0.154	-0.049	0.86	0.033	0.03	0	37.8	38.7	74.8	123	124	0	35	34
2015	12	23	7	15	10	0.167	-0.056	0.86	0.033	0.03	0	41.3	41.3	73.5	130	130	0	34	34
2015	12	23	7	25	10	0.154	-0.085	0.86	0.03	0.03	0	37	36.5	75.3	120	118	0	34	33
2015	12	23	7	35	10	0.233	-0.03	0.86	0.033	0.03	0	35.3	35.7	75.7	116	117	0	34	34
2015	12	23	7	45	10	0.184	-0.121	0.86	0.03	0.03	0	35.3	36.5	75.3	117	118	0	35	33
2015	12	23	7	55	10	0.174	-0.01	0.86	0.039	0.036	0	35.7	35.7	75.7	117	117	0	34	34
2015	12	23	8	5	10	0.19	-0.052	0.86	0.039	0.036	0	36.1	37	75.7	118	119	0	34	33
2015	12	23	8	15	10	0.164	-0.062	0.86	0.033	0.033	0	35.7	36.5	75.3	117	118	0	34	33
2015	12	23	8	25	10	0.197	-0.049	0.86	0.033	0.03	0	35.7	36.5	75.3	117	118	0	34	33
2015	12	23	8	35	10	0.177	-0.056	0.86	0.033	0.03	0	35.7	37	75.7	118	119	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	8	45	10	0.164	-0.085	0.86	0.036	0.033	0	35.7	37	75.7	117	119	0	34	33
2015	12	23	8	55	10	0.177	-0.043	0.86	0.03	0.026	0	36.1	36.1	76.1	118	117	0	34	33
2015	12	23	9	5	10	0.164	-0.033	0.86	0.033	0.03	0	36.5	37	75.3	119	120	0	34	34
2015	12	23	9	15	10	0.2	0.013	0.86	0.039	0.036	0	36.5	37	75.3	119	120	0	34	34
2015	12	23	9	25	10	0.233	-0.095	0.86	0.033	0.03	0	37	38.3	76.1	120	122	0	34	33
2015	12	23	9	35	10	0.148	0.02	0.86	0.036	0.033	0	37	37.8	75.3	121	121	0	35	33
2015	12	23	9	45	10	0.174	-0.095	0.86	0.033	0.03	0	36.5	36.5	76.1	119	119	0	34	34
2015	12	23	9	55	10	0.177	-0.043	0.86	0.033	0.03	0	36.5	36.5	75.3	119	119	0	34	34
2015	12	23	10	5	10	0.187	-0.039	0.86	0.033	0.03	0	36.5	37	76.5	119	120	0	34	34
2015	12	23	10	15	10	0.095	-0.043	0.86	0.036	0.033	0	36.5	36.5	76.1	120	119	0	35	34
2015	12	23	10	25	10	0.171	-0.075	0.86	0.03	0.026	0	37	37.4	75.7	120	120	0	34	33
2015	12	23	10	35	10	0.194	-0.013	0.86	0.033	0.03	0	36.5	37.4	74.8	119	121	0	34	34
2015	12	23	10	45	10	0.21	-0.105	0.86	0.036	0.033	0	41.7	42.1	74.8	131	131	0	34	33
2015	12	23	10	55	10	0.167	-0.066	0.86	0.036	0.033	0	43.9	43.4	72.2	136	135	0	34	34
2015	12	23	11	5	10	0.095	-0.098	0.86	0.036	0.033	0	42.6	42.1	73.5	133	132	0	34	34
2015	12	23	11	15	10	0.154	-0.085	0.86	0.033	0.03	0	41.7	41.7	74	131	130	0	34	33
2015	12	23	11	25	10	0.148	-0.098	0.86	0.036	0.033	0	41.7	40.9	74.8	130	129	0	33	34
2015	12	23	11	35	10	0.171	-0.03	0.86	0.036	0.033	0	42.1	41.3	74	132	131	0	34	35
2015	12	23	11	45	10	0.118	-0.072	0.86	0.036	0.033	0	41.3	42.1	74.4	131	131	0	35	33
2015	12	23	11	55	10	0.144	-0.092	0.86	0.039	0.036	0	42.1	41.3	74.8	131	129	0	33	33
2015	12	23	12	5	10	0.187	-0.075	0.86	0.036	0.033	0	40.9	40.9	75.3	130	128	0	35	33
2015	12	23	12	15	10	0.18	0.013	0.86	0.036	0.033	0	40.4	40	74.4	128	127	0	34	34
2015	12	23	12	25	10	0.213	-0.069	0.86	0.033	0.03	0	40.4	40	75.7	128	126	0	34	33
2015	12	23	12	35	10	0.2	-0.085	0.86	0.036	0.033	0	40.9	40.4	75.7	129	127	0	34	33
2015	12	23	12	45	10	0.157	0	0.86	0.039	0.036	0	39.6	40	76.1	125	125	0	33	32
2015	12	23	12	55	10	0.141	-0.033	0.86	0.039	0.036	0	40.9	40.4	75.7	129	127	0	34	33
2015	12	23	13	5	10	0.184	-0.115	0.86	0.033	0.03	0	41.3	41.3	75.3	130	129	0	34	33
2015	12	23	13	15	10	0.167	0.016	0.86	0.03	0.026	0	41.3	41.3	75.7	130	129	0	34	33
2015	12	23	13	25	10	0.141	-0.102	0.86	0.036	0.033	0	39.1	39.1	76.1	125	124	0	34	33
2015	12	23	13	35	10	0.098	-0.089	0.86	0.043	0.039	0	38.3	38.3	77	123	123	0	34	34
2015	12	23	13	45	10	0.217	-0.046	0.86	0.036	0.033	0	38.7	38.3	77	123	122	0	33	33
2015	12	23	13	55	10	0.213	-0.052	0.86	0.039	0.036	0	38.7	38.7	76.5	124	123	0	34	33
2015	12	23	14	5	10	0.161	-0.072	0.86	0.039	0.036	0	37.8	37.4	77.4	122	121	0	34	34
2015	12	23	14	15	10	0.19	-0.072	0.86	0.039	0.039	0	44.7	44.3	72.7	138	136	0	34	33
2015	12	23	14	25	10	0.226	-0.066	0.86	0.039	0.036	0	46	44.3	73.1	141	137	0	34	34
2015	12	23	14	35	10	0.157	-0.039	0.86	0.043	0.039	0	40.9	40.9	75.7	129	128	0	34	33
2015	12	23	14	45	10	0.213	-0.003	0.86	0.036	0.033	0	39.1	38.3	77.4	125	122	0	34	33
2015	12	23	14	55	10	0.118	-0.039	0.86	0.033	0.03	0	40.4	40	77	127	126	0	33	33
2015	12	23	15	5	10	0.131	-0.069	0.86	0.033	0.03	0	40	40.4	77	126	126	0	33	32
2015	12	23	15	15	10	0.164	0.003	0.86	0.036	0.033	0	39.6	38.7	77	125	123	0	33	33
2015	12	23	15	25	10	0.125	-0.016	0.86	0.036	0.033	0	37.8	38.3	77.8	122	122	0	34	33
2015	12	23	15	35	10	0.144	0.013	0.86	0.03	0.03	0	37.8	37.4	77.8	121	120	0	33	33
2015	12	23	15	45	10	0.259	-0.072	0.86	0.033	0.03	0	37	37	78.7	120	118	0	34	32
2015	12	23	15	55	10	0.154	0.003	0.86	0.033	0.03	0	36.5	36.1	77.8	119	117	0	34	33
2015	12	23	16	5	10	0.102	-0.056	0.86	0.039	0.039	0	36.5	36.5	78.7	119	118	0	34	33
2015	12	23	16	15	10	0.151	-0.092	0.86	0.043	0.039	0	37.4	37.4	78.7	121	120	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	16	25	10	0.154	-0.072	0.86	0.033	0.03	0	35.7	36.1	78.3	117	117	0	34	33
2015	12	23	16	35	10	0.2	0.043	0.86	0.036	0.033	0	35.3	35.3	79.1	116	115	0	34	33
2015	12	23	16	45	10	0.18	-0.046	0.86	0.036	0.033	0	35.7	35.3	78.7	117	115	0	34	33
2015	12	23	16	55	10	0.174	0	0.86	0.036	0.033	0	40.4	38.7	77.4	128	123	0	34	33
2015	12	23	17	5	10	0.161	-0.075	0.86	0.039	0.039	0	36.1	35.3	78.7	117	115	0	33	33
2015	12	23	17	15	10	0.18	-0.059	0.86	0.039	0.036	0	35.3	34.8	79.1	116	114	0	34	33
2015	12	23	17	25	10	0.161	-0.039	0.86	0.033	0.03	0	34.8	34.8	78.7	115	114	0	34	33
2015	12	23	17	35	10	0.144	-0.013	0.86	0.039	0.036	0	34.8	35.7	78.7	115	116	0	34	33
2015	12	23	17	45	10	0.194	-0.039	0.86	0.039	0.036	0	36.1	36.1	78.7	117	117	0	33	33
2015	12	23	17	55	10	0.157	0	0.86	0.039	0.036	0	37.4	37.4	77.8	120	120	0	33	33
2015	12	23	18	5	10	0.144	-0.026	0.86	0.036	0.033	0	37.4	36.5	78.7	121	118	0	34	33
2015	12	23	18	15	10	0.151	-0.007	0.86	0.039	0.036	0	37	37.4	78.3	119	119	0	33	32
2015	12	23	18	25	10	0.154	-0.013	0.86	0.033	0.03	0	38.3	37	77.8	122	119	0	33	33
2015	12	23	18	35	10	0.203	-0.039	0.86	0.036	0.033	0	35.7	36.5	78.3	117	118	0	34	33
2015	12	23	18	45	10	0.112	0.036	0.86	0.039	0.036	0	36.5	36.1	78.3	119	118	0	34	34
2015	12	23	18	55	10	0.217	0.023	0.86	0.036	0.033	0	37	37	78.7	120	119	0	34	33
2015	12	23	19	5	10	0.164	0.069	0.86	0.036	0.033	0	36.5	37.4	78.3	119	120	0	34	33
2015	12	23	19	15	10	0.144	-0.036	0.86	0.039	0.039	0	36.5	37	77.8	118	119	0	33	33
2015	12	23	19	25	10	0.213	-0.003	0.86	0.036	0.033	0	36.5	37.4	77.8	119	120	0	34	33
2015	12	23	19	35	10	0.164	0.052	0.86	0.033	0.03	0	37	37.4	77.4	120	120	0	34	33
2015	12	23	19	45	10	0.171	0.026	0.86	0.033	0.03	0	37	36.5	77.8	120	118	0	34	33
2015	12	23	19	55	10	0.197	0.026	0.86	0.036	0.033	0	36.1	35.7	78.3	117	116	0	33	33
2015	12	23	20	5	10	0.161	0.013	0.86	0.039	0.036	0	35.3	34	78.3	116	113	0	34	34
2015	12	23	20	15	10	0.2	-0.007	0.86	0.033	0.03	0	34.4	34.8	78.3	114	114	0	34	33
2015	12	23	20	25	10	0.157	0	0.86	0.033	0.03	0	34.4	34.8	77	114	114	0	34	33
2015	12	23	20	35	10	0.174	-0.069	0.86	0.033	0.03	0	34.8	34.4	78.3	114	114	0	33	34
2015	12	23	20	45	10	0.141	-0.039	0.86	0.033	0.03	0	35.3	34.8	77.8	115	114	0	33	33
2015	12	23	20	55	10	0.184	-0.039	0.86	0.039	0.036	0	35.7	35.3	77.4	117	115	0	34	33
2015	12	23	21	5	10	0.167	-0.082	0.86	0.036	0.033	0	36.1	35.7	76.5	118	116	0	34	33
2015	12	23	21	15	10	0.213	-0.043	0.86	0.033	0.03	0	35.7	36.5	77.4	117	118	0	34	33
2015	12	23	21	25	10	0.203	-0.049	0.86	0.036	0.033	0	36.1	36.1	77	117	117	0	33	33
2015	12	23	21	35	10	0.161	-0.049	0.86	0.033	0.03	0	35.7	36.5	77	117	119	0	34	34
2015	12	23	21	45	10	0.171	-0.056	0.86	0.039	0.036	0	37.4	36.1	75.7	120	118	0	33	34
2015	12	23	21	55	10	0.167	-0.059	0.86	0.039	0.036	0	36.1	37	76.1	118	120	0	34	34
2015	12	23	22	5	10	0.164	-0.069	0.86	0.033	0.03	0	37.4	37	76.1	120	120	0	33	34
2015	12	23	22	15	10	0.141	-0.01	0.86	0.033	0.033	0	37	37.8	76.1	120	121	0	34	33
2015	12	23	22	25	10	0.151	-0.03	0.86	0.033	0.03	0	37	38.3	76.1	120	122	0	34	33
2015	12	23	22	35	10	0.187	-0.089	0.86	0.039	0.036	0	37	38.3	77	120	122	0	34	33
2015	12	23	22	45	10	0.174	-0.069	0.86	0.036	0.033	0	37.8	37.4	77	122	121	0	34	34
2015	12	23	22	55	10	0.157	-0.085	0.86	0.033	0.03	0	37.4	37.8	77	121	122	0	34	34
2015	12	23	23	5	10	0.184	0	0.86	0.033	0.03	0	36.5	37.8	77.4	119	121	0	34	33
2015	12	23	23	15	10	0.157	-0.013	0.86	0.033	0.03	0	37	38.3	77	120	122	0	34	33
2015	12	23	23	25	10	0.2	-0.03	0.86	0.03	0.026	0	37	38.3	77	120	122	0	34	33
2015	12	23	23	35	10	0.138	-0.059	0.86	0.033	0.03	0	37.4	38.7	76.5	120	123	0	33	33
2015	12	23	23	45	10	0.167	-0.033	0.86	0.033	0.03	0	37.4	38.3	76.5	121	122	0	34	33
2015	12	23	23	55	10	0.217	-0.03	0.86	0.039	0.039	0	37.8	38.7	76.1	122	123	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	0	5	10	0.171	-0.007	0.86	0.036	0.033	0	37.4	38.7	77	121	123	0	34	33
2015	12	24	0	15	10	0.171	-0.059	0.86	0.033	0.03	0	37.8	39.6	77	122	124	0	34	32
2015	12	24	0	25	10	0.154	-0.072	0.86	0.033	0.03	0	38.7	39.6	76.5	124	125	0	34	33
2015	12	24	0	35	10	0.171	-0.075	0.86	0.033	0.03	0	37.8	39.6	76.5	122	125	0	34	33
2015	12	24	0	45	10	0.151	-0.039	0.86	0.033	0.03	0	38.3	39.1	76.5	123	125	0	34	34
2015	12	24	0	55	10	0.177	0	0.86	0.033	0.03	0	37.8	38.7	76.5	122	123	0	34	33
2015	12	24	1	5	10	0.19	0.013	0.86	0.033	0.03	0	37.4	39.1	76.1	121	124	0	34	33
2015	12	24	1	15	10	0.174	-0.03	0.86	0.036	0.033	0	38.7	40	75.7	124	126	0	34	33
2015	12	24	1	25	10	0.21	-0.03	0.86	0.033	0.03	0	38.7	39.1	76.1	124	125	0	34	34
2015	12	24	1	35	10	0.226	-0.02	0.86	0.033	0.03	0	39.1	40	76.1	125	126	0	34	33
2015	12	24	1	45	10	0.141	-0.043	0.86	0.033	0.03	0	38.3	39.6	76.1	124	125	0	35	33
2015	12	24	1	55	10	0.164	-0.026	0.86	0.033	0.03	0	38.3	40	75.3	123	126	0	34	33
2015	12	24	2	5	10	0.197	-0.023	0.86	0.03	0.03	0	39.1	40.4	75.3	125	127	0	34	33
2015	12	24	2	15	10	0.125	-0.007	0.86	0.033	0.03	0	39.1	39.6	75.3	125	126	0	34	34
2015	12	24	2	25	10	0.102	-0.059	0.86	0.036	0.033	0	38.7	40.4	75.3	124	127	0	34	33
2015	12	24	2	35	10	0.194	-0.112	0.86	0.033	0.03	0	38.7	40	74.8	124	126	0	34	33
2015	12	24	2	45	10	0.174	0.013	0.86	0.033	0.03	0	39.1	40.4	75.3	126	127	0	35	33
2015	12	24	2	55	10	0.203	-0.033	0.86	0.036	0.033	0	38.7	40	75.3	124	127	0	34	34
2015	12	24	3	5	10	0.095	-0.079	0.86	0.033	0.03	0	37.4	39.6	75.3	122	125	0	35	33
2015	12	24	3	15	10	0.151	-0.013	0.86	0.033	0.03	0	38.7	39.6	74.8	124	126	0	34	34
2015	12	24	3	25	10	0.194	-0.007	0.86	0.033	0.03	0	39.1	40	75.7	125	126	0	34	33
2015	12	24	3	35	10	0.125	0.007	0.86	0.033	0.03	0	39.1	40	75.3	125	126	0	34	33
2015	12	24	3	45	10	0.164	-0.036	0.86	0.03	0.03	0	38.7	40.4	74.8	124	128	0	34	34
2015	12	24	3	55	10	0.138	-0.003	0.86	0.033	0.03	0	38.7	40	76.1	124	127	0	34	34
2015	12	24	4	5	10	0.171	-0.066	0.86	0.033	0.03	0	39.6	40	75.3	126	127	0	34	34
2015	12	24	4	15	10	0.23	-0.082	0.86	0.033	0.03	0	38.3	39.6	74.8	123	126	0	34	34
2015	12	24	4	25	10	0.21	0	0.86	0.033	0.03	0	38.7	40	75.3	124	126	0	34	33
2015	12	24	4	35	10	0.138	-0.013	0.86	0.033	0.03	0	39.6	40.4	75.7	126	127	0	34	33
2015	12	24	4	45	10	0.138	-0.039	0.86	0.033	0.03	0	38.3	40	74.8	124	127	0	35	34
2015	12	24	4	55	10	0.194	-0.069	0.86	0.033	0.03	0	39.1	40	74.8	125	126	0	34	33
2015	12	24	5	5	10	0.233	-0.059	0.86	0.036	0.033	0	37.8	40.4	74.8	123	127	0	35	33
2015	12	24	5	15	10	0.131	-0.105	0.86	0.039	0.036	0	38.3	39.1	74.8	123	125	0	34	34
2015	12	24	5	25	10	0.171	-0.066	0.86	0.033	0.03	0	38.3	39.1	74.4	123	125	0	34	34
2015	12	24	5	35	10	0.138	-0.049	0.86	0.039	0.036	0	37.8	39.6	75.3	122	125	0	34	33
2015	12	24	5	45	10	0.18	-0.03	0.86	0.036	0.033	0	38.3	39.1	74.4	123	124	0	34	33
2015	12	24	5	55	10	0.171	-0.092	0.86	0.03	0.03	0	38.7	39.1	74.4	124	125	0	34	34
2015	12	24	6	5	10	0.207	-0.036	0.86	0.036	0.033	0	37.4	38.7	74.4	121	124	0	34	34
2015	12	24	6	15	10	0.105	-0.03	0.86	0.039	0.039	0	40.9	40.9	74	129	129	0	34	34
2015	12	24	6	25	10	0.108	-0.043	0.86	0.033	0.03	0	37.8	38.7	75.3	123	123	0	35	33
2015	12	24	6	35	10	0.171	-0.026	0.86	0.033	0.03	0	38.3	39.6	74.4	123	126	0	34	34
2015	12	24	6	45	10	0.187	-0.095	0.86	0.033	0.03	0	37.8	38.7	74.8	122	124	0	34	34
2015	12	24	6	55	10	0.184	-0.069	0.86	0.033	0.03	0	37.8	37.8	74.8	122	122	0	34	34
2015	12	24	7	5	10	0.167	-0.062	0.86	0.033	0.03	0	36.1	35.3	75.3	119	116	0	35	34
2015	12	24	7	15	10	0.144	-0.052	0.86	0.03	0.03	0	35.3	35.7	75.7	116	117	0	34	34
2015	12	24	7	25	10	0.236	-0.121	0.86	0.033	0.03	0	34.4	35.3	75.7	115	115	0	35	33
2015	12	24	7	35	10	0.161	-0.075	0.86	0.033	0.03	0	33.5	34.8	75.3	113	114	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	7	45	10	0.194	-0.03	0.86	0.033	0.03	0	34.8	34.8	75.7	116	115	0	35	34
2015	12	24	7	55	10	0.144	-0.082	0.86	0.033	0.03	0	34	34.8	75.7	113	114	0	34	33
2015	12	24	8	5	10	0.233	-0.082	0.86	0.033	0.03	0	34.8	34.4	75.7	115	113	0	34	33
2015	12	24	8	15	10	0.19	-0.066	0.86	0.036	0.033	0	34.8	34.8	74.8	115	114	0	34	33
2015	12	24	8	25	10	0.151	-0.154	0.86	0.043	0.043	0	34	34	74.8	113	113	0	34	34
2015	12	24	8	35	10	0.187	-0.102	0.86	0.03	0.03	0	34.4	34.8	75.3	114	115	0	34	34
2015	12	24	8	45	10	0.184	-0.062	0.86	0.039	0.036	0	34	35.3	75.7	113	116	0	34	34
2015	12	24	8	55	10	0.184	-0.03	0.86	0.033	0.03	0	33.5	34	75.7	113	113	0	35	34
2015	12	24	9	5	10	0.131	-0.072	0.86	0.036	0.033	0	34	34.4	75.3	114	114	0	35	34
2015	12	24	9	15	10	0.246	-0.069	0.86	0.039	0.039	0	34.4	33.5	75.7	114	112	0	34	34
2015	12	24	9	25	10	0.148	-0.052	0.86	0.033	0.03	0	34.4	33.5	75.7	114	112	0	34	34
2015	12	24	9	35	10	0.207	-0.098	0.86	0.033	0.03	0	34.4	34.4	76.1	115	113	0	35	33
2015	12	24	9	45	10	0.19	-0.112	0.86	0.033	0.03	0	34.4	34.8	75.7	114	115	0	34	34
2015	12	24	9	55	10	0.177	-0.108	0.86	0.033	0.03	0	34.8	35.3	75.7	115	115	0	34	33
2015	12	24	10	5	10	0.217	-0.003	0.86	0.033	0.03	0	34.4	34.8	75.7	114	115	0	34	34
2015	12	24	10	15	10	0.154	-0.066	0.86	0.039	0.036	0	34.8	34.8	75.7	116	116	0	35	35
2015	12	24	10	25	10	0.22	-0.112	0.86	0.039	0.036	0	34.8	34.8	75.7	115	115	0	34	34
2015	12	24	10	35	10	0.194	-0.043	0.86	0.039	0.036	0	35.3	35.7	76.1	117	116	0	35	33
2015	12	24	10	45	10	0.135	-0.128	0.86	0.033	0.03	0	35.3	34.8	75.3	116	115	0	34	34
2015	12	24	10	55	10	0.128	-0.066	0.86	0.039	0.039	0	35.7	35.7	75.7	117	117	0	34	34
2015	12	24	11	5	10	0.19	-0.069	0.86	0.033	0.03	0	37	37.8	74.8	120	122	0	34	34
2015	12	24	11	15	10	0.131	-0.072	0.86	0.039	0.036	0	42.6	42.1	72.2	133	131	0	34	33
2015	12	24	11	25	10	0.23	-0.03	0.86	0.033	0.03	0	39.1	39.6	74.8	125	126	0	34	34
2015	12	24	11	35	10	0.187	-0.108	0.86	0.036	0.033	0	40.4	40	74.4	128	127	0	34	34
2015	12	24	11	45	10	0.131	-0.036	0.86	0.039	0.036	0	41.3	40.4	73.5	130	128	0	34	34
2015	12	24	11	55	10	0.141	-0.02	0.856	0.033	0.03	0	46	45.6	69.7	142	140	0	35	34
2015	12	24	12	5	10	0.194	-0.069	0.86	0.046	0.043	0	49.5	48.2	67.5	149	146	0	34	34
2015	12	24	12	15	10	0.171	-0.098	0.86	0.039	0.039	0	47.7	47.3	69.2	145	143	0	34	33
2015	12	24	12	25	10	0.194	-0.085	0.86	0.036	0.033	0	45.2	44.3	71.4	139	136	0	34	33
2015	12	24	12	35	10	0.167	-0.049	0.86	0.043	0.039	0	44.7	43.4	71	138	135	0	34	34
2015	12	24	12	45	10	0.187	-0.059	0.86	0.039	0.036	0	45.2	44.3	71.4	139	137	0	34	34
2015	12	24	12	55	10	0.203	-0.033	0.86	0.039	0.036	0	44.7	44.3	71	138	137	0	34	34
2015	12	24	13	5	10	0.207	0.036	0.86	0.043	0.043	0	44.3	43	72.2	137	134	0	34	34
2015	12	24	13	15	10	0.23	-0.007	0.86	0.033	0.03	0	43	42.1	73.1	134	131	0	34	33
2015	12	24	13	25	10	0.115	-0.046	0.86	0.033	0.03	0	42.6	42.6	73.5	134	133	0	35	34
2015	12	24	13	35	10	0.167	-0.082	0.86	0.039	0.036	0	40.9	41.3	74.8	129	129	0	34	33
2015	12	24	13	45	10	0.161	-0.033	0.86	0.039	0.036	0	40.4	40.4	74.4	128	127	0	34	33
2015	12	24	13	55	10	0.141	-0.033	0.86	0.036	0.033	0	41.7	41.7	74.4	131	130	0	34	33
2015	12	24	14	5	10	0.079	-0.013	0.86	0.036	0.033	0	43	42.6	73.1	134	133	0	34	34
2015	12	24	14	15	10	0.187	-0.102	0.86	0.036	0.033	0	40.9	40.4	74	129	128	0	34	34
2015	12	24	14	25	10	0.125	-0.062	0.86	0.036	0.033	0	40.9	40.9	73.5	129	128	0	34	33
2015	12	24	14	35	10	0.203	-0.056	0.86	0.033	0.03	0	40.9	40.9	74.8	129	129	0	34	34
2015	12	24	14	45	10	0.194	0.007	0.86	0.043	0.039	0	41.3	40.9	74	130	128	0	34	33
2015	12	24	14	55	10	0.141	-0.026	0.863	0.036	0.033	0	40.9	40	74.8	129	127	0	34	34
2015	12	24	15	5	10	0.112	0.007	0.86	0.039	0.036	0	40	39.6	74.8	127	125	0	34	33
2015	12	24	15	15	10	0.131	-0.043	0.86	0.036	0.033	0	40	39.1	75.7	127	125	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	15	25	10	0.171	0	0.86	0.033	0.03	0	39.1	39.6	75.7	125	125	0	34	33
2015	12	24	15	35	10	0.213	-0.033	0.86	0.036	0.033	0	38.7	38.3	76.1	124	122	0	34	33
2015	12	24	15	45	10	0.131	0.03	0.86	0.039	0.036	0	38.3	38.3	75.7	123	122	0	34	33
2015	12	24	15	55	10	0.151	-0.023	0.86	0.033	0.03	0	37.4	37	76.1	121	120	0	34	34
2015	12	24	16	5	10	0.203	-0.026	0.86	0.039	0.039	0	37.4	37	75.7	120	120	0	33	34
2015	12	24	16	15	10	0.148	-0.03	0.86	0.039	0.036	0	37.4	37.4	74.8	121	120	0	34	33
2015	12	24	16	25	10	0.141	-0.033	0.86	0.039	0.036	0	38.3	38.7	75.7	123	123	0	34	33
2015	12	24	16	35	10	0.19	-0.03	0.86	0.036	0.033	0	37.4	37.4	76.5	121	120	0	34	33
2015	12	24	16	45	10	0.23	0.013	0.86	0.033	0.03	0	37.8	36.5	76.5	122	119	0	34	34
2015	12	24	16	55	10	0.164	0.02	0.863	0.036	0.033	0	37	36.5	77	120	118	0	34	33
2015	12	24	17	5	10	0.164	-0.056	0.86	0.033	0.03	0	37	37.4	76.5	120	120	0	34	33
2015	12	24	17	15	10	0.171	-0.072	0.863	0.033	0.03	0	37	36.1	77	120	118	0	34	34
2015	12	24	17	25	10	0.21	0.01	0.863	0.033	0.03	0	36.5	37	76.5	119	119	0	34	33
2015	12	24	17	35	10	0.197	0.003	0.863	0.046	0.043	0	36.5	36.5	76.1	119	118	0	34	33
2015	12	24	17	45	10	0.187	-0.023	0.863	0.039	0.036	0	37	37.4	76.1	121	120	0	35	33
2015	12	24	17	55	10	0.184	0.026	0.863	0.033	0.03	0	37.4	38.3	76.5	121	122	0	34	33
2015	12	24	18	5	10	0.151	0.007	0.86	0.043	0.039	0	38.7	38.7	76.1	124	123	0	34	33
2015	12	24	18	15	10	0.194	0	0.863	0.033	0.03	0	38.7	38.3	76.1	124	123	0	34	34
2015	12	24	18	25	10	0.18	-0.026	0.86	0.039	0.036	0	41.3	40.9	74.8	130	129	0	34	34
2015	12	24	18	35	10	0.128	0.069	0.86	0.036	0.033	0	41.3	41.3	74.8	129	129	0	33	33
2015	12	24	18	45	10	0.197	0.01	0.86	0.036	0.033	0	43.9	43.9	73.5	136	135	0	34	33
2015	12	24	18	55	10	0.233	0.069	0.86	0.039	0.036	0	43.9	43.4	73.5	136	135	0	34	34
2015	12	24	19	5	10	0.115	-0.01	0.86	0.043	0.039	0	46.4	46.4	72.7	143	142	0	35	34
2015	12	24	19	15	10	0.098	-0.03	0.86	0.036	0.033	0	47.3	48.2	68.8	144	145	0	34	33
2015	12	24	19	25	10	0.138	0.056	0.86	0.039	0.036	0	49	48.2	67.1	148	146	0	34	34
2015	12	24	19	35	10	0.157	-0.026	0.86	0.039	0.036	0	49	49	67.5	148	147	0	34	33
2015	12	24	19	45	10	0.18	0.046	0.86	0.036	0.033	0	49	49	67.1	148	147	0	34	33
2015	12	24	19	55	10	0.184	0.052	0.86	0.036	0.033	0	48.6	47.7	67.5	147	145	0	34	34
2015	12	24	20	5	10	0.161	0.056	0.86	0.039	0.039	0	48.2	48.6	69.2	146	146	0	34	33
2015	12	24	20	15	10	0.184	0.013	0.863	0.036	0.033	0	47.3	47.7	70.1	144	144	0	34	33
2015	12	24	20	25	10	0.207	0.069	0.863	0.036	0.033	0	46.9	46	70.5	143	141	0	34	34
2015	12	24	20	35	10	0.259	0.046	0.863	0.036	0.033	0	46	45.6	71	141	140	0	34	34
2015	12	24	20	45	10	0.164	0.026	0.863	0.033	0.033	0	44.7	44.7	71.8	138	137	0	34	33
2015	12	24	20	55	10	0.121	0.043	0.863	0.036	0.033	0	44.3	44.3	71.8	137	136	0	34	33
2015	12	24	21	5	10	0.2	0.089	0.863	0.036	0.033	0	43.4	43.4	72.7	135	135	0	34	34
2015	12	24	21	15	10	0.19	0	0.863	0.03	0.03	0	42.6	42.6	73.1	133	132	0	34	33
2015	12	24	21	25	10	0.23	0.082	0.863	0.043	0.039	0	41.7	41.7	73.1	131	130	0	34	33
2015	12	24	21	35	10	0.203	-0.049	0.863	0.033	0.03	0	41.3	42.1	73.5	130	131	0	34	33
2015	12	24	21	45	10	0.21	0.016	0.863	0.033	0.03	0	40.9	41.3	74.4	129	129	0	34	33
2015	12	24	21	55	10	0.167	0.066	0.863	0.036	0.033	0	40.9	40.4	74	129	127	0	34	33
2015	12	24	22	5	10	0.194	0.049	0.863	0.036	0.033	0	40.4	40.4	73.1	128	128	0	34	34
2015	12	24	22	15	10	0.131	0.03	0.863	0.033	0.03	0	40	40.9	73.5	127	128	0	34	33
2015	12	24	22	25	10	0.2	-0.01	0.863	0.036	0.033	0	40	40.4	74.4	127	127	0	34	33
2015	12	24	22	35	10	0.21	0.013	0.863	0.039	0.036	0	40	40.4	73.5	127	127	0	34	33
2015	12	24	22	45	10	0.164	0.026	0.863	0.036	0.033	0	40.4	40	73.5	127	127	0	33	34
2015	12	24	22	55	10	0.226	0.049	0.863	0.036	0.033	0	40	40	74	127	126	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	23	5	10	0.233	0.043	0.863	0.033	0.03	0	40	39.6	73.5	127	126	0	34	34
2015	12	24	23	15	10	0.21	0.082	0.863	0.036	0.033	0	40.4	40.4	73.5	127	127	0	33	33
2015	12	24	23	25	10	0.154	0.069	0.863	0.033	0.03	0	39.6	40	71.8	126	127	0	34	34
2015	12	24	23	35	10	0.138	0.026	0.863	0.036	0.033	0	40.4	40.9	71.8	128	128	0	34	33
2015	12	24	23	45	10	0.217	0.026	0.863	0.033	0.03	0	40.4	40.4	74	128	127	0	34	33
2015	12	24	23	55	10	0.18	-0.01	0.863	0.036	0.033	0	40	40	74	127	126	0	34	33
2015	12	25	0	5	10	0.187	0.066	0.863	0.039	0.039	0	39.6	40.4	74	126	128	0	34	34
2015	12	25	0	15	10	0.171	0	0.863	0.033	0.03	0	39.6	40.4	73.5	127	127	0	35	33
2015	12	25	0	25	10	0.18	0.043	0.863	0.039	0.036	0	39.6	39.6	74	126	126	0	34	34
2015	12	25	0	35	10	0.253	0.059	0.863	0.033	0.03	0	40	40.4	74	127	127	0	34	33
2015	12	25	0	45	10	0.223	0.039	0.863	0.033	0.03	0	40	39.6	74.4	127	126	0	34	34
2015	12	25	0	55	10	0.154	0	0.863	0.033	0.033	0	39.1	39.6	74	125	126	0	34	34
2015	12	25	1	5	10	0.2	-0.026	0.863	0.033	0.03	0	39.6	39.1	74	126	125	0	34	34
2015	12	25	1	15	10	0.161	0.043	0.863	0.033	0.03	0	38.7	39.1	74	124	125	0	34	34
2015	12	25	1	25	10	0.233	0.02	0.863	0.033	0.03	0	38.3	38.7	74.4	123	124	0	34	34
2015	12	25	1	35	10	0.164	0.003	0.863	0.039	0.036	0	38.3	39.1	74	123	125	0	34	34
2015	12	25	1	45	10	0.226	-0.036	0.863	0.033	0.033	0	38.3	39.6	74.4	124	126	0	35	34
2015	12	25	1	55	10	0.161	-0.092	0.863	0.033	0.03	0	37.4	39.1	74	121	124	0	34	33
2015	12	25	2	5	10	0.121	-0.069	0.863	0.033	0.03	0	37.8	39.1	73.5	122	125	0	34	34
2015	12	25	2	15	10	0.167	-0.046	0.863	0.033	0.03	0	37.8	38.7	74.4	122	124	0	34	34
2015	12	25	2	25	10	0.21	-0.056	0.863	0.033	0.03	0	38.3	39.6	74	123	125	0	34	33
2015	12	25	2	35	10	0.18	-0.03	0.863	0.033	0.03	0	37.8	39.1	74	122	125	0	34	34
2015	12	25	2	45	10	0.177	-0.033	0.863	0.033	0.03	0	37.4	39.1	74.4	121	124	0	34	33
2015	12	25	2	55	10	0.177	0	0.863	0.036	0.033	0	37.4	38.3	73.5	121	123	0	34	34
2015	12	25	3	5	10	0.177	-0.03	0.863	0.033	0.03	0	37.8	38.7	74.4	122	124	0	34	34
2015	12	25	3	15	10	0.157	-0.098	0.863	0.033	0.03	0	37	39.6	74	121	125	0	35	33
2015	12	25	3	25	10	0.18	-0.033	0.863	0.033	0.03	0	37.4	39.1	74	121	125	0	34	34
2015	12	25	3	35	10	0.203	-0.066	0.863	0.033	0.03	0	37	38.3	74	120	123	0	34	34
2015	12	25	3	45	10	0.233	-0.026	0.863	0.033	0.03	0	37.4	37.4	74.4	121	121	0	34	34
2015	12	25	3	55	10	0.19	-0.046	0.863	0.03	0.026	0	37	38.3	74	121	123	0	35	34
2015	12	25	4	5	10	0.194	-0.033	0.863	0.033	0.03	0	37	37.8	74.4	120	122	0	34	34
2015	12	25	4	15	10	0.131	0.01	0.863	0.033	0.03	0	37.8	38.7	73.5	122	123	0	34	33
2015	12	25	4	25	10	0.187	-0.049	0.863	0.033	0.03	0	37.4	38.7	74	121	124	0	34	34
2015	12	25	4	35	10	0.184	-0.089	0.863	0.033	0.03	0	37.4	39.1	73.5	121	124	0	34	33
2015	12	25	4	45	10	0.19	-0.023	0.863	0.033	0.03	0	37.4	37.8	74	121	122	0	34	34
2015	12	25	4	55	10	0.207	-0.098	0.863	0.03	0.03	0	37	38.3	73.1	120	123	0	34	34
2015	12	25	5	5	10	0.233	-0.026	0.86	0.036	0.033	0	37	37.4	74.8	120	120	0	34	33
2015	12	25	5	15	10	0.144	-0.026	0.863	0.033	0.03	0	37	38.3	74	120	123	0	34	34
2015	12	25	5	25	10	0.171	-0.075	0.863	0.033	0.03	0	36.1	37.4	74	119	121	0	35	34
2015	12	25	5	35	10	0.22	-0.003	0.863	0.033	0.03	0	36.5	39.1	73.5	120	124	0	35	33
2015	12	25	5	45	10	0.154	-0.056	0.86	0.036	0.033	0	37.4	38.3	73.5	121	122	0	34	33
2015	12	25	5	55	10	0.131	-0.105	0.86	0.033	0.03	0	37.4	37.8	74	121	122	0	34	34
2015	12	25	6	5	10	0.21	-0.052	0.86	0.03	0.03	0	36.5	37	74	119	120	0	34	34
2015	12	25	6	15	10	0.177	-0.102	0.86	0.033	0.03	0	36.5	38.3	73.5	119	122	0	34	33
2015	12	25	6	25	10	0.207	-0.066	0.86	0.03	0.03	0	35.7	37.4	73.5	118	121	0	35	34
2015	12	25	6	35	10	0.138	-0.056	0.86	0.033	0.03	0	35.7	37	74	118	120	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	6	45	10	0.128	-0.128	0.86	0.033	0.03	0	36.5	37.8	74.4	120	121	0	35	33
2015	12	25	6	55	10	0.233	-0.039	0.86	0.043	0.043	0	35.7	37	74	118	120	0	35	34
2015	12	25	7	5	10	0.217	-0.075	0.86	0.039	0.039	0	34.4	35.7	74	115	117	0	35	34
2015	12	25	7	15	10	0.18	-0.023	0.863	0.033	0.03	0	33.5	34.4	73.5	113	114	0	35	34
2015	12	25	7	25	10	0.177	-0.066	0.863	0.033	0.03	0	34	34.8	74.4	113	114	0	34	33
2015	12	25	7	35	10	0.108	-0.098	0.86	0.033	0.03	0	33.5	34	74	112	113	0	34	34
2015	12	25	7	45	10	0.18	-0.039	0.86	0.03	0.03	0	34	34.4	74.4	113	113	0	34	33
2015	12	25	7	55	10	0.161	-0.052	0.86	0.033	0.03	0	33.5	34.4	74.8	113	113	0	35	33
2015	12	25	8	5	10	0.177	-0.023	0.86	0.036	0.033	0	34.4	34	74.8	114	113	0	34	34
2015	12	25	8	15	10	0.18	-0.154	0.86	0.033	0.03	0	33.5	34	74.4	113	112	0	35	33
2015	12	25	8	25	10	0.197	-0.161	0.86	0.039	0.036	0	33.1	33.1	74.8	111	111	0	34	34
2015	12	25	8	35	10	0.167	-0.069	0.86	0.049	0.046	0	33.5	34.8	74.4	112	114	0	34	33
2015	12	25	8	45	10	0.157	-0.056	0.863	0.036	0.033	0	34	33.5	74	113	112	0	34	34
2015	12	25	8	55	10	0.161	-0.062	0.86	0.033	0.03	0	33.5	33.5	74.4	112	113	0	34	35
2015	12	25	9	5	10	0.141	-0.089	0.86	0.039	0.036	0	33.1	33.1	74.4	112	111	0	35	34
2015	12	25	9	15	10	0.174	-0.056	0.86	0.036	0.033	0	33.5	33.1	74.8	112	111	0	34	34
2015	12	25	9	25	10	0.118	-0.164	0.86	0.036	0.033	0	33.1	34	74.8	111	112	0	34	33
2015	12	25	9	35	10	0.236	-0.141	0.86	0.033	0.03	0	34	33.5	74.4	113	112	0	34	34
2015	12	25	9	45	10	0.148	-0.089	0.86	0.033	0.03	0	33.5	33.1	74.4	112	111	0	34	34
2015	12	25	9	55	10	0.177	-0.115	0.86	0.036	0.033	0	33.5	33.5	74.8	112	112	0	34	34
2015	12	25	10	5	10	0.259	-0.075	0.86	0.039	0.036	0	33.5	34	74.4	113	113	0	35	34
2015	12	25	10	15	10	0.144	-0.039	0.86	0.036	0.033	0	34.4	34	74.8	114	113	0	34	34
2015	12	25	10	25	10	0.135	-0.115	0.86	0.033	0.03	0	34.4	34.8	74.4	115	115	0	35	34
2015	12	25	10	35	10	0.135	-0.118	0.86	0.03	0.03	0	35.3	34.8	74.4	116	115	0	34	34
2015	12	25	10	45	10	0.161	-0.066	0.86	0.033	0.03	0	35.3	34.8	74.4	116	115	0	34	34
2015	12	25	10	55	10	0.138	-0.066	0.86	0.039	0.036	0	36.5	37	74	120	120	0	35	34
2015	12	25	11	5	10	0.095	-0.098	0.86	0.033	0.03	0	37.8	37.8	73.5	122	121	0	34	33
2015	12	25	11	15	10	0.121	-0.062	0.86	0.039	0.036	0	40	39.6	73.5	127	125	0	34	33
2015	12	25	11	25	10	0.138	-0.131	0.86	0.036	0.033	0	38.7	37.4	74	124	122	0	34	35
2015	12	25	11	35	10	0.194	-0.105	0.86	0.039	0.039	0	37.8	38.3	74.4	123	123	0	35	34
2015	12	25	11	45	10	0.19	-0.128	0.86	0.036	0.033	0	37.8	37.4	74.4	122	121	0	34	34
2015	12	25	11	55	10	0.187	-0.016	0.86	0.039	0.039	0	38.3	38.3	73.5	123	124	0	34	35
2015	12	25	12	5	10	0.138	-0.108	0.86	0.033	0.03	0	38.7	37.8	74.4	125	122	0	35	34
2015	12	25	12	15	10	0.282	-0.066	0.86	0.039	0.039	0	38.7	38.3	74	125	123	0	35	34
2015	12	25	12	25	10	0.22	0.016	0.86	0.043	0.039	0	38.7	39.1	73.5	124	124	0	34	33
2015	12	25	12	35	10	0.177	-0.131	0.86	0.039	0.036	0	38.7	38.3	74.4	124	122	0	34	33
2015	12	25	12	45	10	0.135	0	0.86	0.036	0.033	0	38.3	37.8	75.3	124	122	0	35	34
2015	12	25	12	55	10	0.128	-0.069	0.86	0.036	0.033	0	38.7	39.1	73.5	124	124	0	34	33
2015	12	25	13	5	10	0.115	-0.128	0.86	0.036	0.033	0	42.6	41.7	72.7	133	131	0	34	34
2015	12	25	13	15	10	0.174	-0.089	0.86	0.033	0.03	0	41.3	40	74	129	127	0	33	34
2015	12	25	13	25	10	0.18	-0.03	0.86	0.036	0.033	0	40.9	40	73.5	129	127	0	34	34
2015	12	25	13	35	10	0.174	-0.115	0.86	0.036	0.033	0	40	39.1	74	127	125	0	34	34
2015	12	25	13	45	10	0.194	-0.039	0.86	0.043	0.039	0	39.6	38.7	74.8	126	124	0	34	34
2015	12	25	13	55	10	0.187	-0.069	0.856	0.039	0.036	0	42.1	41.3	71	132	130	0	34	34
2015	12	25	14	5	10	0.138	-0.062	0.856	0.033	0.03	0	42.6	41.7	72.2	133	131	0	34	34
2015	12	25	14	15	10	0.203	-0.085	0.856	0.039	0.036	0	43	42.1	72.2	133	131	0	33	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	14	25	10	0.154	-0.016	0.856	0.039	0.039	0	41.3	41.3	70.1	130	129	0	34	33
2015	12	25	14	35	10	0.164	-0.003	0.86	0.036	0.033	0	40.9	40.4	74.4	129	128	0	34	34
2015	12	25	14	45	10	0.154	-0.039	0.86	0.033	0.03	0	40	39.1	74.8	127	125	0	34	34
2015	12	25	14	55	10	0.112	-0.056	0.86	0.039	0.039	0	39.6	38.7	75.3	126	124	0	34	34
2015	12	25	15	5	10	0.167	-0.039	0.86	0.033	0.03	0	39.1	38.3	75.3	125	123	0	34	34
2015	12	25	15	15	10	0.138	-0.046	0.86	0.043	0.039	0	39.1	38.3	76.1	125	123	0	34	34
2015	12	25	15	25	10	0.236	-0.056	0.86	0.036	0.033	0	38.3	37.4	76.1	122	121	0	33	34
2015	12	25	15	35	10	0.157	-0.01	0.86	0.036	0.033	0	37.4	37	76.5	121	120	0	34	34
2015	12	25	15	45	10	0.236	-0.085	0.86	0.036	0.033	0	36.5	36.1	77	119	117	0	34	33
2015	12	25	15	55	10	0.177	-0.118	0.86	0.033	0.03	0	36.1	35.3	77	118	116	0	34	34
2015	12	25	16	5	10	0.128	-0.056	0.856	0.039	0.036	0	35.7	35.3	76.5	117	115	0	34	33
2015	12	25	16	15	10	0.141	-0.02	0.856	0.033	0.03	0	35.3	35.3	76.1	116	115	0	34	33
2015	12	25	16	25	10	0.112	-0.056	0.856	0.036	0.033	0	35.7	35.3	77	117	115	0	34	33
2015	12	25	16	35	10	0.207	-0.056	0.86	0.033	0.03	0	35.7	34.8	77	117	115	0	34	34
2015	12	25	16	45	10	0.135	-0.039	0.86	0.039	0.039	0	34.8	34.4	77.8	115	114	0	34	34
2015	12	25	16	55	10	0.194	-0.121	0.86	0.033	0.03	0	35.3	34	77.4	116	113	0	34	34
2015	12	25	17	5	10	0.148	-0.069	0.86	0.036	0.033	0	34.8	34.8	77.4	115	114	0	34	33
2015	12	25	17	15	10	0.157	-0.036	0.86	0.036	0.033	0	34.8	34.8	77.4	115	115	0	34	34
2015	12	25	17	25	10	0.154	-0.102	0.86	0.033	0.03	0	34.8	34.8	77	115	114	0	34	33
2015	12	25	17	35	10	0.18	-0.112	0.856	0.036	0.033	0	34.8	34	77	114	113	0	33	34
2015	12	25	17	45	10	0.272	0.016	0.86	0.039	0.036	0	34.8	34.8	76.5	115	114	0	34	33
2015	12	25	17	55	10	0.18	-0.023	0.856	0.039	0.036	0	34.4	34.8	75.7	115	115	0	35	34
2015	12	25	18	5	10	0.128	0.049	0.86	0.039	0.036	0	35.3	34.4	75.7	116	114	0	34	34
2015	12	25	18	15	10	0.177	-0.059	0.86	0.039	0.039	0	35.3	34.4	75.7	116	114	0	34	34
2015	12	25	18	25	10	0.184	0.003	0.856	0.033	0.03	0	37.8	37	73.5	122	120	0	34	34
2015	12	25	18	35	10	0.167	-0.098	0.856	0.046	0.043	0	42.6	41.7	70.5	133	131	0	34	34
2015	12	25	18	45	10	0.157	-0.036	0.856	0.036	0.033	0	45.2	44.7	67.5	139	138	0	34	34
2015	12	25	18	55	10	0.18	-0.026	0.856	0.039	0.036	0	48.6	47.7	65.4	147	145	0	34	34
2015	12	25	19	5	10	0.171	0.026	0.856	0.039	0.036	0	47.7	47.3	64.1	145	143	0	34	33
2015	12	25	19	15	10	0.121	-0.026	0.856	0.043	0.039	0	47.7	46.9	64.5	145	142	0	34	33
2015	12	25	19	25	10	0.138	-0.03	0.856	0.033	0.03	0	44.3	43	71.8	137	134	0	34	34
2015	12	25	19	35	10	0.157	-0.069	0.856	0.036	0.033	0	42.1	41.7	71	133	130	0	35	33
2015	12	25	19	45	10	0.115	-0.056	0.856	0.033	0.03	0	41.3	40.4	72.7	130	128	0	34	34
2015	12	25	19	55	10	0.154	-0.062	0.856	0.039	0.036	0	41.3	40.9	72.2	129	129	0	33	34
2015	12	25	20	5	10	0.115	0.003	0.856	0.036	0.033	0	44.7	45.2	65.8	139	138	0	35	33
2015	12	25	20	15	10	0.135	0.075	0.856	0.039	0.036	0	43.4	43.4	69.2	135	134	0	34	33
2015	12	25	20	25	10	0.167	-0.03	0.856	0.039	0.036	0	41.7	40.9	69.7	131	130	0	34	35
2015	12	25	20	35	10	0.135	-0.007	0.86	0.033	0.03	0	40.9	40.9	71.8	129	128	0	34	33
2015	12	25	20	45	10	0.131	0.013	0.856	0.036	0.033	0	39.1	39.6	73.1	126	125	0	35	33
2015	12	25	20	55	10	0.164	-0.003	0.856	0.036	0.033	0	38.7	39.6	72.2	124	125	0	34	33
2015	12	25	21	5	10	0.2	-0.026	0.86	0.033	0.03	0	39.1	39.1	74	125	124	0	34	33
2015	12	25	21	15	10	0.21	-0.01	0.86	0.039	0.039	0	38.3	38.7	72.7	123	124	0	34	34
2015	12	25	21	25	10	0.197	-0.075	0.856	0.036	0.033	0	38.7	38.3	70.5	124	123	0	34	34
2015	12	25	21	35	10	0.138	-0.023	0.856	0.036	0.033	0	37.8	38.3	72.2	122	123	0	34	34
2015	12	25	21	45	10	0.197	0.016	0.86	0.039	0.036	0	37.8	38.3	74.4	122	122	0	34	33
2015	12	25	21	55	10	0.151	-0.043	0.86	0.033	0.03	0	37.4	37	73.5	121	120	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	22	5	10	0.19	-0.098	0.86	0.033	0.03	0	37	36.5	74.8	120	119	0	34	34
2015	12	25	22	15	10	0.24	0	0.86	0.036	0.033	0	36.5	36.5	73.5	119	119	0	34	34
2015	12	25	22	25	10	0.141	-0.052	0.86	0.036	0.033	0	36.5	36.1	74	120	118	0	35	34
2015	12	25	22	35	10	0.2	-0.003	0.86	0.039	0.036	0	36.1	36.1	73.5	118	118	0	34	34
2015	12	25	22	45	10	0.171	0.049	0.86	0.033	0.03	0	36.1	36.1	74.8	118	118	0	34	34
2015	12	25	22	55	10	0.171	-0.082	0.86	0.033	0.03	0	35.7	35.7	74	117	117	0	34	34
2015	12	25	23	5	10	0.138	-0.056	0.86	0.036	0.033	0	35.7	35.7	74.8	117	117	0	34	34
2015	12	25	23	15	10	0.174	-0.043	0.86	0.039	0.036	0	35.3	35.7	73.1	117	117	0	35	34
2015	12	25	23	25	10	0.135	-0.013	0.86	0.033	0.03	0	35.3	36.1	74.8	117	117	0	35	33
2015	12	25	23	35	10	0.157	-0.039	0.86	0.033	0.03	0	34.8	35.7	75.3	115	117	0	34	34
2015	12	25	23	45	10	0.18	-0.049	0.86	0.033	0.03	0	35.7	35.3	74.4	118	116	0	35	34
2015	12	25	23	55	10	0.135	-0.082	0.86	0.033	0.03	0	35.7	35.7	74	118	116	0	35	33
2015	12	26	0	5	10	0.135	-0.062	0.86	0.033	0.03	0	35.3	35.7	73.5	116	117	0	34	34
2015	12	26	0	15	10	0.167	-0.115	0.86	0.033	0.03	0	35.3	35.7	73.5	116	117	0	34	34
2015	12	26	0	25	10	0.151	0.023	0.86	0.033	0.03	0	35.3	36.1	74	117	118	0	35	34
2015	12	26	0	35	10	0.131	-0.026	0.86	0.033	0.03	0	35.7	35.7	74.8	117	117	0	34	34
2015	12	26	0	45	10	0.161	-0.062	0.86	0.036	0.033	0	35.7	35.3	74.4	117	116	0	34	34
2015	12	26	0	55	10	0.253	-0.052	0.86	0.03	0.03	0	34.4	34.8	74.4	115	115	0	35	34
2015	12	26	1	5	10	0.144	-0.007	0.86	0.033	0.03	0	34.8	35.3	74.4	115	115	0	34	33
2015	12	26	1	15	10	0.131	-0.02	0.86	0.033	0.03	0	34.8	34.4	74.8	115	114	0	34	34
2015	12	26	1	25	10	0.194	-0.112	0.86	0.03	0.03	0	34	34.4	74.8	113	114	0	34	34
2015	12	26	1	35	10	0.174	-0.098	0.86	0.033	0.03	0	33.5	34	74	112	113	0	34	34
2015	12	26	1	45	10	0.121	-0.062	0.86	0.033	0.03	0	34	35.3	73.5	113	115	0	34	33
2015	12	26	1	55	10	0.118	-0.092	0.86	0.033	0.03	0	34.8	34.4	73.1	115	114	0	34	34
2015	12	26	2	5	10	0.151	-0.046	0.86	0.033	0.03	0	34	34.4	74	113	115	0	34	35
2015	12	26	2	15	10	0.135	-0.003	0.86	0.033	0.03	0	34.8	35.7	73.1	114	117	0	33	34
2015	12	26	2	25	10	0.141	-0.095	0.86	0.033	0.03	0	34.8	34.8	73.5	115	115	0	34	34
2015	12	26	2	35	10	0.135	-0.062	0.86	0.033	0.03	0	34	34.4	74.4	114	114	0	35	34
2015	12	26	2	45	10	0.171	-0.059	0.86	0.033	0.03	0	33.5	34.4	73.5	113	114	0	35	34
2015	12	26	2	55	10	0.171	-0.085	0.86	0.033	0.03	0	34.4	34.8	73.1	115	115	0	35	34
2015	12	26	3	5	10	0.21	-0.046	0.86	0.039	0.036	0	34	34.8	73.5	114	115	0	35	34
2015	12	26	3	15	10	0.141	-0.105	0.86	0.033	0.03	0	34.4	34.4	74	115	115	0	35	35
2015	12	26	3	25	10	0.184	-0.079	0.86	0.033	0.03	0	34.8	34.8	73.5	115	114	0	34	33
2015	12	26	3	35	10	0.197	-0.066	0.863	0.036	0.033	0	34.4	35.3	73.5	114	116	0	34	34
2015	12	26	3	45	10	0.197	-0.066	0.86	0.036	0.033	0	35.3	34.8	73.5	116	115	0	34	34
2015	12	26	3	55	10	0.207	-0.069	0.86	0.033	0.03	0	33.5	34.4	73.5	113	114	0	35	34
2015	12	26	4	5	10	0.174	-0.056	0.86	0.036	0.033	0	33.5	34.4	73.5	113	114	0	35	34
2015	12	26	4	15	10	0.174	-0.079	0.86	0.039	0.036	0	34	34	74	114	113	0	35	34
2015	12	26	4	25	10	0.174	-0.036	0.86	0.033	0.033	0	33.5	34	74	113	113	0	35	34
2015	12	26	4	35	10	0.197	-0.066	0.86	0.039	0.039	0	33.5	34	74	113	113	0	35	34
2015	12	26	4	45	10	0.148	-0.154	0.86	0.033	0.03	0	33.5	33.5	72.7	113	112	0	35	34
2015	12	26	4	55	10	0.194	-0.082	0.86	0.033	0.03	0	33.5	34.8	73.5	112	114	0	34	33
2015	12	26	5	5	10	0.2	-0.052	0.86	0.036	0.033	0	33.1	33.5	72.7	112	112	0	35	34
2015	12	26	5	15	10	0.197	-0.085	0.863	0.033	0.03	0	34	34.4	72.2	113	113	0	34	33
2015	12	26	5	25	10	0.141	-0.089	0.866	0.033	0.03	0	33.1	34	72.7	112	113	0	35	34
2015	12	26	5	35	10	0.226	-0.066	0.863	0.039	0.036	0	33.5	33.5	71.8	113	112	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	5	45	10	0.177	-0.157	0.863	0.046	0.043	0	34	34.4	71.4	113	114	0	34	34
2015	12	26	5	55	10	0.135	-0.174	0.863	0.033	0.03	0	34	35.3	71.4	114	116	0	35	34
2015	12	26	6	5	10	0.112	-0.049	0.863	0.036	0.033	0	34	35.3	72.2	114	116	0	35	34
2015	12	26	6	15	10	0.194	-0.072	0.863	0.033	0.03	0	34.4	34	72.7	115	114	0	35	35
2015	12	26	6	25	10	0.24	-0.082	0.863	0.033	0.03	0	34.8	34.8	72.2	115	115	0	34	34
2015	12	26	6	35	10	0.2	-0.079	0.863	0.033	0.03	0	34.4	34.8	72.7	115	115	0	35	34
2015	12	26	6	45	10	0.18	-0.118	0.863	0.033	0.03	0	34	34.8	72.7	114	115	0	35	34
2015	12	26	6	55	10	0.144	-0.121	0.863	0.033	0.03	0	33.5	34.4	72.7	113	114	0	35	34
2015	12	26	7	5	10	0.174	-0.052	0.863	0.036	0.033	0	33.1	34	73.1	112	113	0	35	34
2015	12	26	7	15	10	0.19	-0.082	0.863	0.043	0.039	0	34.4	34	72.2	114	113	0	34	34
2015	12	26	7	25	10	0.24	-0.066	0.863	0.033	0.03	0	33.5	34	72.7	113	113	0	35	34
2015	12	26	7	35	10	0.125	-0.082	0.863	0.033	0.03	0	34	34	72.7	113	113	0	34	34
2015	12	26	7	45	10	0.174	-0.007	0.863	0.039	0.039	0	33.5	33.5	71.8	113	112	0	35	34
2015	12	26	7	55	10	0.151	-0.148	0.866	0.036	0.033	0	34	33.5	73.1	113	112	0	34	34
2015	12	26	8	5	10	0.148	-0.157	0.863	0.03	0.03	0	34	33.5	72.7	113	112	0	34	34
2015	12	26	8	15	10	0.177	-0.082	0.866	0.033	0.03	0	34	33.5	73.1	114	112	0	35	34
2015	12	26	8	25	10	0.177	-0.079	0.863	0.039	0.036	0	33.5	33.1	73.1	113	111	0	35	34
2015	12	26	8	35	10	0.256	-0.092	0.866	0.039	0.036	0	34.4	34	72.2	114	113	0	34	34
2015	12	26	8	45	10	0.223	-0.095	0.86	0.039	0.036	0	33.5	33.1	72.7	113	111	0	35	34
2015	12	26	8	55	10	0.128	-0.082	0.86	0.039	0.036	0	34	34.4	72.7	113	113	0	34	33
2015	12	26	9	5	10	0.217	-0.161	0.863	0.033	0.03	0	33.5	33.1	71.8	112	111	0	34	34
2015	12	26	9	15	10	0.131	-0.082	0.86	0.033	0.03	0	33.5	33.5	69.2	112	112	0	34	34
2015	12	26	9	25	10	0.174	-0.092	0.86	0.036	0.033	0	34	33.5	71	114	112	0	35	34
2015	12	26	9	35	10	0.118	-0.115	0.863	0.039	0.036	0	34	33.5	71.8	114	112	0	35	34
2015	12	26	9	45	10	0.203	-0.098	0.86	0.039	0.036	0	34	33.5	71.4	114	112	0	35	34
2015	12	26	9	55	10	0.171	-0.141	0.86	0.036	0.033	0	34.8	34	69.7	115	113	0	34	34
2015	12	26	10	5	10	0.138	-0.102	0.86	0.033	0.03	0	40	39.1	67.5	128	126	0	35	35
2015	12	26	10	15	10	0.148	-0.085	0.86	0.033	0.03	0	38.3	37.4	67.9	124	121	0	35	34
2015	12	26	10	25	10	0.128	-0.066	0.86	0.036	0.033	0	39.6	39.6	67.5	127	126	0	35	34
2015	12	26	10	35	10	0.167	-0.046	0.86	0.036	0.033	0	40	39.6	68.8	128	126	0	35	34
2015	12	26	10	45	10	0.187	0	0.86	0.043	0.043	0	39.1	39.1	69.2	126	126	0	35	35
2015	12	26	10	55	10	0.144	-0.052	0.86	0.036	0.033	0	40	39.6	68.8	127	126	0	34	34
2015	12	26	11	5	10	0.138	-0.069	0.86	0.036	0.033	0	40.9	40.9	68.4	130	129	0	35	34
2015	12	26	11	15	10	0.197	-0.108	0.856	0.039	0.036	0	40	40.4	69.2	128	128	0	35	34
2015	12	26	11	25	10	0.164	-0.121	0.86	0.033	0.03	0	40	40.4	68.8	128	128	0	35	34
2015	12	26	11	35	10	0.2	-0.125	0.86	0.039	0.036	0	40.4	40.4	68.8	129	128	0	35	34
2015	12	26	11	45	10	0.138	-0.085	0.86	0.036	0.033	0	40.9	40.4	70.1	129	128	0	34	34
2015	12	26	11	55	10	0.2	-0.079	0.86	0.036	0.033	0	41.3	40	68.4	130	127	0	34	34
2015	12	26	12	5	10	0.207	-0.108	0.86	0.036	0.033	0	40.4	40	69.7	129	127	0	35	34
2015	12	26	12	15	10	0.243	-0.052	0.86	0.043	0.039	0	41.3	40.4	69.2	130	128	0	34	34
2015	12	26	12	25	10	0.2	-0.069	0.856	0.033	0.03	0	40.4	40.4	69.7	129	128	0	35	34
2015	12	26	12	35	10	0.19	-0.075	0.86	0.036	0.033	0	41.3	40.4	69.2	131	128	0	35	34
2015	12	26	12	45	10	0.131	0.02	0.856	0.033	0.03	0	40.9	40	70.1	130	127	0	35	34
2015	12	26	12	55	10	0.256	-0.069	0.86	0.039	0.036	0	40.9	40.9	71	129	129	0	34	34
2015	12	26	13	5	10	0.203	-0.089	0.856	0.039	0.036	0	41.3	40.9	69.2	131	129	0	35	34
2015	12	26	13	15	10	0.177	-0.03	0.86	0.036	0.033	0	40.9	40.9	69.7	129	128	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	13	25	10	0.19	-0.02	0.856	0.033	0.03	0	40.9	41.3	70.5	129	130	0	34	34
2015	12	26	13	35	10	0.243	-0.19	0.856	0.036	0.033	0	41.7	40.4	69.7	131	129	0	34	35
2015	12	26	13	45	10	0.138	-0.102	0.856	0.039	0.036	0	42.1	41.3	70.1	132	130	0	34	34
2015	12	26	13	55	10	0.194	-0.003	0.856	0.039	0.036	0	41.3	41.7	69.2	131	130	0	35	33
2015	12	26	14	5	10	0.171	-0.092	0.856	0.033	0.03	0	40.9	40.9	70.1	130	129	0	35	34
2015	12	26	14	15	10	0.177	-0.049	0.856	0.039	0.036	0	41.3	40.9	70.1	130	129	0	34	34
2015	12	26	14	25	10	0.167	-0.046	0.856	0.036	0.033	0	41.3	40.9	71	131	128	0	35	33
2015	12	26	14	35	10	0.184	-0.056	0.856	0.039	0.039	0	40.9	41.3	71	130	129	0	35	33
2015	12	26	14	45	10	0.184	0.02	0.856	0.039	0.036	0	41.3	40.4	71.8	130	128	0	34	34
2015	12	26	14	55	10	0.148	-0.036	0.856	0.039	0.036	0	41.3	40	71.4	130	128	0	34	35
2015	12	26	15	5	10	0.217	-0.046	0.856	0.033	0.03	0	41.3	40.4	70.5	131	128	0	35	34
2015	12	26	15	15	10	0.161	-0.026	0.856	0.039	0.036	0	41.3	40	71.8	130	127	0	34	34
2015	12	26	15	25	10	0.19	-0.01	0.856	0.039	0.036	0	40.4	40.4	71.8	129	127	0	35	33
2015	12	26	15	35	10	0.217	0.033	0.856	0.039	0.036	0	41.3	40.9	72.2	131	129	0	35	34
2015	12	26	15	45	10	0.223	-0.007	0.856	0.039	0.039	0	40.9	39.6	73.1	129	126	0	34	34
2015	12	26	15	55	10	0.223	-0.039	0.856	0.039	0.039	0	39.6	39.1	74	126	124	0	34	33
2015	12	26	16	5	10	0.154	-0.033	0.856	0.036	0.033	0	38.7	38.7	74	124	123	0	34	33
2015	12	26	16	15	10	0.138	-0.039	0.856	0.03	0.03	0	37.8	38.3	75.7	123	122	0	35	33
2015	12	26	16	25	10	0.177	-0.105	0.856	0.043	0.039	0	38.3	37.4	76.1	123	121	0	34	34
2015	12	26	16	35	10	0.262	-0.082	0.856	0.039	0.036	0	37.4	36.5	75.7	121	119	0	34	34
2015	12	26	16	45	10	0.217	-0.026	0.856	0.033	0.03	0	37	36.5	75.7	121	119	0	35	34
2015	12	26	16	55	10	0.167	-0.036	0.856	0.036	0.033	0	36.5	36.1	76.5	119	118	0	34	34
2015	12	26	17	5	10	0.151	-0.125	0.856	0.039	0.036	0	35.7	35.7	75.7	118	117	0	35	34
2015	12	26	17	15	10	0.2	-0.003	0.856	0.043	0.043	0	35.7	35.7	75.3	118	116	0	35	33
2015	12	26	17	25	10	0.19	-0.039	0.856	0.036	0.033	0	35.7	35.3	75.7	117	116	0	34	34
2015	12	26	17	35	10	0.151	-0.098	0.856	0.036	0.033	0	35.3	34.8	74.8	117	115	0	35	34
2015	12	26	17	45	10	0.141	-0.089	0.856	0.036	0.033	0	34.8	35.3	74.4	116	115	0	35	33
2015	12	26	17	55	10	0.141	-0.115	0.856	0.039	0.036	0	35.7	34.4	74.8	117	114	0	34	34
2015	12	26	18	5	10	0.223	-0.075	0.856	0.036	0.033	0	34.8	34.8	74.8	116	115	0	35	34
2015	12	26	18	15	10	0.194	-0.003	0.856	0.039	0.036	0	35.3	34.4	75.3	117	114	0	35	34
2015	12	26	18	25	10	0.138	0.007	0.856	0.033	0.03	0	34.8	34.4	75.3	115	114	0	34	34
2015	12	26	18	35	10	0.135	-0.01	0.856	0.036	0.033	0	35.7	35.7	73.5	118	116	0	35	33
2015	12	26	18	45	10	0.128	-0.007	0.856	0.033	0.03	0	35.7	35.7	74.4	117	117	0	34	34
2015	12	26	18	55	10	0.24	-0.085	0.856	0.039	0.039	0	35.7	34.8	74.8	117	115	0	34	34
2015	12	26	19	5	10	0.148	0	0.856	0.036	0.033	0	35.3	34.4	74.8	116	114	0	34	34
2015	12	26	19	15	10	0.226	-0.062	0.856	0.036	0.033	0	35.3	34.4	74.4	116	114	0	34	34
2015	12	26	19	25	10	0.112	0.013	0.856	0.033	0.033	0	35.3	34.4	73.5	117	114	0	35	34
2015	12	26	19	35	10	0.243	-0.049	0.856	0.039	0.039	0	35.7	35.3	72.2	118	116	0	35	34
2015	12	26	19	45	10	0.161	0	0.856	0.039	0.036	0	35.7	35.3	73.1	118	116	0	35	34
2015	12	26	19	55	10	0.148	0.036	0.856	0.039	0.036	0	35.7	35.3	74.8	117	116	0	34	34
2015	12	26	20	5	10	0.207	-0.013	0.856	0.039	0.036	0	35.3	35.3	72.7	117	116	0	35	34
2015	12	26	20	15	10	0.246	-0.062	0.856	0.033	0.03	0	35.3	35.7	73.5	116	116	0	34	33
2015	12	26	20	25	10	0.24	-0.039	0.856	0.043	0.039	0	36.1	35.7	73.1	118	117	0	34	34
2015	12	26	20	35	10	0.233	-0.007	0.856	0.039	0.036	0	35.7	35.3	74.4	117	115	0	34	33
2015	12	26	20	45	10	0.085	-0.108	0.856	0.036	0.033	0	36.1	35.7	70.1	118	117	0	34	34
2015	12	26	20	55	10	0.138	-0.112	0.853	0.033	0.03	0	37	36.1	70.5	120	118	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	21	5	10	0.174	-0.03	0.856	0.036	0.033	0	37	37	71	121	120	0	35	34
2015	12	26	21	15	10	0.141	-0.105	0.853	0.039	0.039	0	48.2	48.6	63.2	147	146	0	35	33
2015	12	26	21	25	10	0.128	-0.059	0.853	0.043	0.043	0	50.3	48.6	60.6	151	147	0	34	34
2015	12	26	21	35	10	0.21	-0.056	0.853	0.036	0.033	0	49.9	48.6	63.6	151	147	0	35	34
2015	12	26	21	45	10	0.207	-0.013	0.853	0.036	0.033	0	42.6	42.6	68.4	134	133	0	35	34
2015	12	26	21	55	10	0.085	-0.023	0.856	0.036	0.033	0	40.9	41.3	67.5	130	130	0	35	34
2015	12	26	22	5	10	0.105	-0.075	0.853	0.036	0.033	0	43	42.6	67.5	134	133	0	34	34
2015	12	26	22	15	10	0.121	-0.095	0.853	0.039	0.036	0	43.4	43.4	65.8	135	135	0	34	34
2015	12	26	22	25	10	0.138	-0.049	0.856	0.043	0.039	0	44.3	43.4	65.8	138	135	0	35	34
2015	12	26	22	35	10	0.21	-0.062	0.853	0.033	0.03	0	44.7	43.9	67.1	138	136	0	34	34
2015	12	26	22	45	10	0.21	-0.013	0.856	0.033	0.03	0	43	42.6	66.2	135	133	0	35	34
2015	12	26	22	55	10	0.112	-0.023	0.853	0.039	0.036	0	47.3	46.9	64.1	145	143	0	35	34
2015	12	26	23	5	10	0.138	-0.043	0.856	0.036	0.033	0	43.9	43.9	66.2	137	136	0	35	34
2015	12	26	23	15	10	0.148	-0.095	0.853	0.036	0.033	0	45.2	45.2	65.8	140	139	0	35	34
2015	12	26	23	25	10	0.187	-0.026	0.853	0.033	0.03	0	49.5	48.2	62.8	149	146	0	34	34
2015	12	26	23	35	10	0.131	-0.039	0.853	0.039	0.039	0	44.3	43.4	64.9	137	135	0	34	34
2015	12	26	23	45	10	0.22	-0.013	0.853	0.039	0.036	0	43.9	43.9	67.5	137	136	0	35	34
2015	12	26	23	55	10	0.174	0	0.853	0.036	0.033	0	43.9	42.6	68.4	136	133	0	34	34
2015	12	27	0	5	10	0.217	-0.016	0.853	0.033	0.03	0	42.6	42.6	67.1	134	133	0	35	34
2015	12	27	0	15	10	0.144	0.016	0.853	0.033	0.03	0	42.1	42.1	67.5	133	133	0	35	35
2015	12	27	0	25	10	0.128	-0.069	0.856	0.033	0.03	0	41.3	41.7	70.5	131	131	0	35	34
2015	12	27	0	35	10	0.171	-0.108	0.856	0.033	0.03	0	40.9	40.9	72.2	130	129	0	35	34
2015	12	27	0	45	10	0.151	0.003	0.856	0.036	0.033	0	40.9	40.4	72.7	129	128	0	34	34
2015	12	27	0	55	10	0.151	-0.013	0.856	0.039	0.036	0	40.4	39.6	73.1	128	126	0	34	34
2015	12	27	1	5	10	0.213	-0.033	0.856	0.033	0.03	0	39.1	39.1	72.7	125	125	0	34	34
2015	12	27	1	15	10	0.157	0.016	0.856	0.03	0.03	0	38.3	38.7	74	124	123	0	35	33
2015	12	27	1	25	10	0.174	-0.062	0.856	0.039	0.036	0	37.8	37.4	74	122	121	0	34	34
2015	12	27	1	35	10	0.21	-0.079	0.856	0.039	0.036	0	36.1	35.7	74.4	119	118	0	35	35
2015	12	27	1	45	10	0.144	-0.026	0.856	0.039	0.036	0	36.5	36.5	74.4	120	119	0	35	34
2015	12	27	1	55	10	0.121	0	0.856	0.033	0.03	0	36.1	35.3	74.4	118	116	0	34	34
2015	12	27	2	5	10	0.184	-0.052	0.856	0.043	0.039	0	35.7	35.3	74.4	117	116	0	34	34
2015	12	27	2	15	10	0.187	-0.115	0.856	0.036	0.033	0	35.7	35.3	74.8	117	116	0	34	34
2015	12	27	2	25	10	0.148	-0.092	0.856	0.036	0.033	0	34.8	34.8	74	116	115	0	35	34
2015	12	27	2	35	10	0.131	-0.108	0.856	0.036	0.033	0	34.4	34.8	74.4	115	115	0	35	34
2015	12	27	2	45	10	0.125	-0.026	0.856	0.036	0.033	0	34.4	34.8	74.4	115	115	0	35	34
2015	12	27	2	55	10	0.144	-0.039	0.856	0.036	0.033	0	34.8	35.3	74	116	116	0	35	34
2015	12	27	3	5	10	0.131	-0.092	0.856	0.033	0.03	0	35.3	34.4	73.5	117	114	0	35	34
2015	12	27	3	15	10	0.164	-0.075	0.856	0.036	0.033	0	34.8	34.4	74	115	114	0	34	34
2015	12	27	3	25	10	0.118	-0.118	0.856	0.036	0.033	0	34.8	34.8	74.4	115	115	0	34	34
2015	12	27	3	35	10	0.144	-0.052	0.856	0.033	0.03	0	34.8	34.8	74	115	116	0	34	35
2015	12	27	3	45	10	0.207	-0.059	0.856	0.033	0.03	0	34.8	34.8	74.4	117	115	0	36	34
2015	12	27	3	55	10	0.21	-0.059	0.856	0.033	0.03	0	34.4	34.4	73.5	115	114	0	35	34
2015	12	27	4	5	10	0.197	-0.115	0.856	0.039	0.036	0	34.8	34.8	73.5	115	115	0	34	34
2015	12	27	4	15	10	0.171	-0.066	0.856	0.036	0.033	0	34.8	34.4	74	115	114	0	34	34
2015	12	27	4	25	10	0.213	-0.082	0.856	0.033	0.03	0	35.3	34	74	117	114	0	35	35
2015	12	27	4	35	10	0.213	-0.144	0.856	0.033	0.03	0	34	34	73.5	114	113	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	4	45	10	0.203	-0.118	0.856	0.033	0.03	0	34.4	34.4	73.1	115	114	0	35	34
2015	12	27	4	55	10	0.217	-0.102	0.856	0.036	0.033	0	33.5	34	73.5	113	113	0	35	34
2015	12	27	5	5	10	0.18	-0.049	0.856	0.046	0.043	0	33.5	34.4	73.5	113	114	0	35	34
2015	12	27	5	15	10	0.223	-0.089	0.856	0.039	0.036	0	34	33.5	74	114	112	0	35	34
2015	12	27	5	25	10	0.144	-0.072	0.856	0.036	0.033	0	33.5	33.5	73.5	113	112	0	35	34
2015	12	27	5	35	10	0.18	-0.164	0.856	0.033	0.03	0	34	33.5	74	113	112	0	34	34
2015	12	27	5	45	10	0.141	-0.098	0.856	0.039	0.036	0	33.5	33.1	74	112	111	0	34	34
2015	12	27	5	55	10	0.2	-0.079	0.856	0.033	0.03	0	33.5	33.1	74	113	111	0	35	34
2015	12	27	6	5	10	0.259	-0.059	0.856	0.033	0.03	0	32.7	32.7	73.5	111	111	0	35	35
2015	12	27	6	15	10	0.223	-0.118	0.856	0.039	0.036	0	33.1	32.3	74	112	110	0	35	35
2015	12	27	6	25	10	0.167	-0.128	0.856	0.039	0.036	0	32.3	33.1	74	110	110	0	35	33
2015	12	27	6	35	10	0.174	-0.066	0.856	0.036	0.033	0	32.7	32.3	74	111	109	0	35	34
2015	12	27	6	45	10	0.203	-0.105	0.856	0.039	0.036	0	32.3	32.3	74	110	109	0	35	34
2015	12	27	6	55	10	0.148	-0.131	0.856	0.036	0.033	0	32.7	32.3	73.5	111	109	0	35	34
2015	12	27	7	5	10	0.226	-0.102	0.856	0.046	0.043	0	32.3	31.8	73.5	110	108	0	35	34
2015	12	27	7	15	10	0.151	-0.115	0.856	0.043	0.039	0	32.3	31.8	74	109	108	0	34	34
2015	12	27	7	25	10	0.249	-0.128	0.86	0.033	0.03	0	31.8	31.8	73.5	109	108	0	35	34
2015	12	27	7	35	10	0.236	-0.069	0.856	0.036	0.033	0	32.3	31.8	74	110	108	0	35	34
2015	12	27	7	45	10	0.164	-0.154	0.856	0.033	0.03	0	32.3	32.3	74	110	109	0	35	34
2015	12	27	7	55	10	0.18	-0.079	0.856	0.033	0.03	0	32.7	32.3	74.4	110	109	0	34	34
2015	12	27	8	5	10	0.167	-0.118	0.856	0.033	0.033	0	33.1	32.7	74.4	112	110	0	35	34
2015	12	27	8	15	10	0.207	-0.118	0.856	0.033	0.03	0	32.7	32.7	74.4	111	110	0	35	34
2015	12	27	8	25	10	0.171	-0.095	0.856	0.036	0.033	0	32.7	32.7	74.4	111	110	0	35	34
2015	12	27	8	35	10	0.259	-0.131	0.856	0.036	0.033	0	33.1	32.7	74.4	111	110	0	34	34
2015	12	27	8	45	10	0.154	-0.102	0.856	0.036	0.033	0	32.7	32.3	74.4	112	110	0	36	35
2015	12	27	8	55	10	0.148	-0.052	0.856	0.039	0.036	0	33.1	31.8	74	111	109	0	34	35
2015	12	27	9	5	10	0.23	-0.046	0.856	0.056	0.052	0	34.8	33.1	74.4	116	111	0	35	34
2015	12	27	9	15	10	0.062	-0.262	0.856	0.039	0.036	0	36.5	33.1	74.4	120	111	0	35	34
2015	12	27	9	25	10	0.01	-0.253	0.856	0.052	0.049	0	37.4	32.7	74.8	122	111	0	35	35
2015	12	27	9	35	10	-0.276	-0.591	0.856	0.062	0.062	0	39.1	32.3	74.4	125	110	0	34	35
2015	12	27	9	45	10	0.384	0.19	0.856	0.092	0.092	0	38.3	33.1	74.4	124	111	0	35	34
2015	12	27	9	55	10	-0.266	-0.564	0.869	0.043	0.043	0	39.1	33.1	80.8	126	111	0	35	34
2015	12	27	10	5	10	-0.515	-0.869	0.863	0.039	0.039	0	39.1	33.5	76.1	125	112	0	34	34
2015	12	27	10	15	10	-0.476	-0.807	0.876	0.066	0.066	0	39.1	33.5	82.6	125	113	0	34	35
2015	12	27	10	25	10	0.436	0.089	0.886	0.049	0.046	0	39.6	33.5	87.7	127	112	0	35	34
2015	12	27	10	35	10	0.144	-0.18	0.866	0.046	0.043	0	37.8	34.4	78.7	123	114	0	35	34
2015	12	27	10	45	10	-0.83	-1.175	0.873	0.059	0.059	0	39.1	35.3	86	126	117	0	35	35
2015	12	27	10	55	10	-0.279	-0.482	0.876	0.066	0.066	0	39.6	35.3	87.3	127	116	0	35	34
2015	12	27	11	5	10	2.549	2.398	0.873	0.089	0.085	0	39.6	34.8	86	127	115	0	35	34
2015	12	27	11	15	10	-0.65	-0.886	0.873	0.052	0.049	0	40	36.5	81.3	128	119	0	35	34
2015	12	27	11	25	10	0.108	-0.125	0.873	0.052	0.049	0	40.4	35.3	82.6	128	116	0	34	34
2015	12	27	11	35	10	-1.02	-1.115	0.856	0.046	0.046	0	40.4	34.8	74.8	128	115	0	34	34
2015	12	27	11	45	10	0.049	-0.141	0.856	0.075	0.075	0	40	34.8	74.8	128	116	0	35	35
2015	12	27	11	55	10	0.308	0.141	0.856	0.062	0.062	0	39.6	34.8	74.8	127	115	0	35	34
2015	12	27	12	5	10	0.272	0.036	0.856	0.043	0.039	0	39.1	34	74.4	125	113	0	34	34
2015	12	27	12	15	10	0.213	-0.144	0.856	0.049	0.049	0	38.3	34.8	74.4	124	115	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	12	25	10	0.174	-0.108	0.856	0.046	0.046	0	37	34.8	74.4	120	115	0	34	34
2015	12	27	12	35	10	0.184	-0.105	0.856	0.039	0.039	0	35.7	35.3	74.4	118	115	0	35	33
2015	12	27	12	45	10	0.2	-0.144	0.856	0.039	0.039	0	35.3	34.8	74.8	117	115	0	35	34
2015	12	27	12	55	10	0.161	-0.092	0.856	0.036	0.033	0	35.7	35.3	74.4	118	116	0	35	34
2015	12	27	13	5	10	0.217	-0.056	0.856	0.039	0.036	0	35.7	35.7	74.8	118	117	0	35	34
2015	12	27	13	15	10	0.246	-0.03	0.856	0.039	0.036	0	36.5	35.7	74	119	117	0	34	34
2015	12	27	13	25	10	0.187	-0.092	0.856	0.036	0.033	0	36.1	35.3	74.8	119	116	0	35	34
2015	12	27	13	35	10	0.138	-0.095	0.856	0.043	0.043	0	36.1	36.1	74	119	118	0	35	34
2015	12	27	13	45	10	0.105	-0.092	0.856	0.033	0.033	0	36.5	36.1	74.8	120	118	0	35	34
2015	12	27	13	55	10	0.21	-0.072	0.856	0.036	0.033	0	37.8	36.5	74.4	122	119	0	34	34
2015	12	27	14	5	10	0.167	0.003	0.856	0.039	0.036	0	36.5	36.1	74.8	120	118	0	35	34
2015	12	27	14	15	10	0.154	-0.092	0.856	0.033	0.03	0	37.8	36.5	74.8	122	119	0	34	34
2015	12	27	14	25	10	0.194	-0.01	0.856	0.039	0.039	0	37.4	37	74.4	122	120	0	35	34
2015	12	27	14	35	10	0.2	-0.052	0.856	0.036	0.033	0	37.8	37.4	73.5	123	121	0	35	34
2015	12	27	14	45	10	0.2	-0.095	0.856	0.039	0.036	0	37.8	37	73.5	123	120	0	35	34
2015	12	27	14	55	10	0.194	-0.072	0.856	0.039	0.039	0	38.3	37.8	73.5	124	121	0	35	33
2015	12	27	15	5	10	0.236	-0.082	0.856	0.039	0.036	0	38.3	37.8	74.4	124	122	0	35	34
2015	12	27	15	15	10	0.21	-0.039	0.856	0.036	0.033	0	38.7	38.3	73.5	125	123	0	35	34
2015	12	27	15	25	10	0.171	-0.052	0.856	0.039	0.036	0	39.1	37.8	74	125	122	0	34	34
2015	12	27	15	35	10	0.144	-0.059	0.856	0.043	0.039	0	37.8	37.8	74	123	121	0	35	33
2015	12	27	15	45	10	0.164	-0.026	0.856	0.036	0.033	0	37.8	37	74.4	122	120	0	34	34
2015	12	27	15	55	10	0.125	-0.02	0.856	0.036	0.033	0	37.8	37	74.4	123	120	0	35	34
2015	12	27	16	5	10	0.21	-0.062	0.853	0.036	0.033	0	37.4	37	74.4	122	120	0	35	34
2015	12	27	16	15	10	0.167	-0.056	0.853	0.039	0.039	0	37.4	36.5	74.8	122	120	0	35	35
2015	12	27	16	25	10	0.171	-0.125	0.853	0.033	0.03	0	37.4	36.5	74.8	122	120	0	35	35
2015	12	27	16	35	10	0.144	0.013	0.853	0.046	0.043	0	37.4	37	75.3	122	120	0	35	34
2015	12	27	16	45	10	0.194	-0.036	0.853	0.043	0.039	0	36.5	36.5	75.7	120	119	0	35	34
2015	12	27	16	55	10	0.174	-0.039	0.853	0.039	0.039	0	36.5	36.1	75.3	120	118	0	35	34
2015	12	27	17	5	10	0.187	0.066	0.853	0.043	0.039	0	36.5	36.1	75.3	120	118	0	35	34
2015	12	27	17	15	10	0.085	-0.026	0.853	0.033	0.03	0	37	36.5	75.3	120	118	0	34	33
2015	12	27	17	25	10	0.131	-0.069	0.853	0.033	0.03	0	36.5	35.7	75.3	120	117	0	35	34
2015	12	27	17	35	10	0.118	-0.115	0.853	0.039	0.036	0	36.1	35.7	75.3	119	117	0	35	34
2015	12	27	17	45	10	0.243	0	0.853	0.039	0.036	0	36.1	35.7	75.7	119	117	0	35	34
2015	12	27	17	55	10	0.223	-0.082	0.853	0.043	0.039	0	36.5	35.7	75.3	120	117	0	35	34
2015	12	27	18	5	10	0.079	-0.046	0.853	0.039	0.036	0	37	36.5	75.3	120	118	0	34	33
2015	12	27	18	15	10	0.144	-0.092	0.853	0.039	0.036	0	36.1	35.7	75.3	119	117	0	35	34
2015	12	27	18	25	10	0.125	-0.066	0.853	0.036	0.033	0	36.5	35.3	75.3	119	116	0	34	34
2015	12	27	18	35	10	0.18	-0.069	0.853	0.046	0.043	0	36.1	35.3	75.7	119	116	0	35	34
2015	12	27	18	45	10	0.164	-0.102	0.853	0.039	0.036	0	35.3	34.8	75.7	117	115	0	35	34
2015	12	27	18	55	10	0.223	0.023	0.853	0.039	0.039	0	35.3	34.8	76.5	117	115	0	35	34
2015	12	27	19	5	10	0.174	-0.023	0.853	0.039	0.036	0	35.3	34.4	76.1	117	114	0	35	34
2015	12	27	19	15	10	0.164	-0.007	0.853	0.039	0.039	0	34.4	34	76.1	115	113	0	35	34
2015	12	27	19	25	10	0.161	-0.066	0.856	0.039	0.036	0	34.8	34	76.1	116	113	0	35	34
2015	12	27	19	35	10	0.19	-0.013	0.853	0.036	0.033	0	35.3	34	76.5	116	113	0	34	34
2015	12	27	19	45	10	0.187	-0.098	0.856	0.033	0.03	0	34.4	34	77	115	113	0	35	34
2015	12	27	19	55	10	0.161	-0.013	0.853	0.036	0.033	0	34.8	33.5	77	116	112	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	20	5	10	0.118	-0.02	0.856	0.043	0.039	0	34	33.5	76.5	114	111	0	35	33
2015	12	27	20	15	10	0.157	-0.079	0.856	0.039	0.039	0	33.5	33.5	77	113	111	0	35	33
2015	12	27	20	25	10	0.161	-0.095	0.856	0.036	0.033	0	33.1	33.1	77	113	111	0	36	34
2015	12	27	20	35	10	0.2	-0.062	0.853	0.039	0.036	0	33.5	32.7	76.5	112	110	0	34	34
2015	12	27	20	45	10	0.115	-0.043	0.853	0.039	0.036	0	33.1	33.1	77	112	110	0	35	33
2015	12	27	20	55	10	0.151	-0.115	0.856	0.033	0.03	0	33.1	32.3	77	112	109	0	35	34
2015	12	27	21	5	10	0.135	-0.036	0.856	0.033	0.03	0	32.7	32.3	77	111	109	0	35	34
2015	12	27	21	15	10	0.141	-0.098	0.856	0.039	0.036	0	33.1	32.3	76.5	111	109	0	34	34
2015	12	27	21	25	10	0.177	-0.036	0.856	0.036	0.033	0	33.1	31.8	77	111	108	0	34	34
2015	12	27	21	35	10	0.125	-0.105	0.853	0.036	0.033	0	32.3	31.8	77	110	108	0	35	34
2015	12	27	21	45	10	0.148	-0.072	0.856	0.039	0.036	0	32.3	31.8	77	110	108	0	35	34
2015	12	27	21	55	10	0.161	-0.066	0.856	0.039	0.036	0	31.8	31.4	77	109	107	0	35	34
2015	12	27	22	5	10	0.184	-0.072	0.853	0.039	0.036	0	31.8	31.4	77	109	107	0	35	34
2015	12	27	22	15	10	0.161	-0.098	0.856	0.036	0.033	0	32.3	31	76.5	109	106	0	34	34
2015	12	27	22	25	10	0.148	-0.069	0.853	0.039	0.036	0	31.4	31	77	108	106	0	35	34
2015	12	27	22	35	10	0.177	-0.062	0.856	0.039	0.036	0	31.8	31	77	108	106	0	34	34
2015	12	27	22	45	10	0.171	-0.069	0.853	0.039	0.036	0	31.8	30.5	77	108	105	0	34	34
2015	12	27	22	55	10	0.174	-0.121	0.856	0.039	0.036	0	31.8	31	77.4	108	106	0	34	34
2015	12	27	23	5	10	0.174	-0.046	0.853	0.039	0.036	0	31.8	30.5	76.5	108	105	0	34	34
2015	12	27	23	15	10	0.141	-0.052	0.853	0.039	0.036	0	31	31	77	106	105	0	34	33
2015	12	27	23	25	10	0.207	-0.085	0.853	0.039	0.036	0	31.4	30.5	76.5	107	105	0	34	34
2015	12	27	23	35	10	0.187	-0.033	0.853	0.046	0.043	0	31	30.1	76.5	107	104	0	35	34
2015	12	27	23	45	10	0.092	-0.072	0.853	0.033	0.03	0	31.4	30.5	76.5	107	105	0	34	34
2015	12	27	23	55	10	0.187	-0.026	0.853	0.033	0.03	0	31	30.5	76.5	107	105	0	35	34
2015	12	28	0	5	10	0.095	-0.085	0.853	0.039	0.036	0	31	29.7	76.5	107	104	0	35	35
2015	12	28	0	15	10	0.112	-0.039	0.853	0.039	0.036	0	31	30.5	76.5	107	105	0	35	34
2015	12	28	0	25	10	0.148	-0.075	0.853	0.033	0.03	0	31	30.5	76.5	107	105	0	35	34
2015	12	28	0	35	10	0.151	-0.115	0.853	0.046	0.043	0	31	30.5	76.5	107	105	0	35	34
2015	12	28	0	45	10	0.098	-0.082	0.853	0.039	0.036	0	30.5	30.5	76.5	106	104	0	35	33
2015	12	28	0	55	10	0.112	-0.066	0.853	0.036	0.033	0	31	30.1	77	107	104	0	35	34
2015	12	28	1	5	10	0.161	-0.148	0.853	0.039	0.036	0	31.4	30.5	76.1	107	105	0	34	34
2015	12	28	1	15	10	0.177	-0.039	0.853	0.033	0.03	0	30.5	29.7	77	106	103	0	35	34
2015	12	28	1	25	10	0.203	-0.062	0.853	0.039	0.036	0	30.5	29.7	77	105	104	0	34	35
2015	12	28	1	35	10	0.128	-0.095	0.853	0.043	0.043	0	30.1	30.5	76.1	105	104	0	35	33
2015	12	28	1	45	10	0.174	-0.144	0.853	0.036	0.033	0	31	30.1	76.1	106	104	0	34	34
2015	12	28	1	55	10	0.157	-0.066	0.853	0.039	0.039	0	30.5	30.1	76.1	106	104	0	35	34
2015	12	28	2	5	10	0.174	-0.075	0.853	0.039	0.036	0	30.5	30.5	76.5	106	105	0	35	34
2015	12	28	2	15	10	0.144	-0.052	0.853	0.036	0.033	0	30.1	29.7	76.5	105	103	0	35	34
2015	12	28	2	25	10	0.131	-0.108	0.853	0.036	0.033	0	30.1	29.7	76.1	105	103	0	35	34
2015	12	28	2	35	10	0.131	-0.115	0.853	0.036	0.033	0	31.4	30.5	76.1	107	105	0	34	34
2015	12	28	2	45	10	0.131	-0.102	0.853	0.039	0.036	0	31	31	76.1	106	106	0	34	34
2015	12	28	2	55	10	0.22	-0.026	0.853	0.033	0.03	0	31.8	31	76.1	108	106	0	34	34
2015	12	28	3	5	10	0.177	-0.039	0.853	0.039	0.036	0	31.4	30.1	76.1	108	105	0	35	35
2015	12	28	3	15	10	0.19	-0.085	0.853	0.039	0.036	0	31	31	76.1	108	106	0	36	34
2015	12	28	3	25	10	0.151	-0.072	0.853	0.033	0.03	0	31.8	31.8	76.5	109	108	0	35	34
2015	12	28	3	35	10	0.184	-0.131	0.853	0.036	0.033	0	32.7	31.8	75.7	111	108	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	3	45	10	0.121	-0.148	0.853	0.036	0.033	0	32.3	31.4	76.1	110	108	0	35	35
2015	12	28	3	55	10	0.148	-0.105	0.853	0.036	0.033	0	31.8	32.3	75.7	109	109	0	35	34
2015	12	28	4	5	10	0.203	-0.046	0.853	0.039	0.039	0	31.8	31.8	75.7	109	108	0	35	34
2015	12	28	4	15	10	0.144	-0.036	0.853	0.033	0.03	0	32.3	32.3	75.7	110	109	0	35	34
2015	12	28	4	25	10	0.141	-0.062	0.853	0.033	0.03	0	31.8	31.8	76.5	109	108	0	35	34
2015	12	28	4	35	10	0.115	-0.095	0.853	0.039	0.036	0	32.7	32.3	75.7	110	109	0	34	34
2015	12	28	4	45	10	0.184	-0.043	0.853	0.033	0.03	0	31.8	32.3	76.1	109	109	0	35	34
2015	12	28	4	55	10	0.167	-0.089	0.853	0.039	0.036	0	32.3	31.8	75.7	110	109	0	35	35
2015	12	28	5	5	10	0.171	-0.026	0.853	0.033	0.03	0	32.3	31.8	76.5	110	108	0	35	34
2015	12	28	5	15	10	0.161	-0.062	0.853	0.036	0.033	0	32.3	32.3	75.7	110	109	0	35	34
2015	12	28	5	25	10	0.171	-0.112	0.853	0.033	0.03	0	32.3	31.4	75.7	110	107	0	35	34
2015	12	28	5	35	10	0.161	-0.157	0.853	0.033	0.03	0	32.3	32.3	76.1	110	109	0	35	34
2015	12	28	5	45	10	0.223	-0.131	0.853	0.033	0.03	0	31.8	32.3	76.1	109	108	0	35	33
2015	12	28	5	55	10	0.171	-0.187	0.853	0.036	0.033	0	31.4	31	76.5	108	107	0	35	35
2015	12	28	6	5	10	0.184	-0.115	0.853	0.033	0.03	0	31.4	31.4	76.1	108	107	0	35	34
2015	12	28	6	15	10	0.154	-0.105	0.853	0.039	0.036	0	31.4	31.4	76.1	108	108	0	35	35
2015	12	28	6	25	10	0.121	-0.092	0.853	0.033	0.03	0	31.8	31.4	76.1	109	108	0	35	35
2015	12	28	6	35	10	0.207	-0.085	0.853	0.039	0.036	0	31.8	31.4	75.7	109	108	0	35	35
2015	12	28	6	45	10	0.171	-0.115	0.853	0.036	0.033	0	31.4	31.4	75.7	108	107	0	35	34
2015	12	28	6	55	10	0.249	-0.082	0.853	0.039	0.039	0	31	31	75.7	107	106	0	35	34
2015	12	28	7	5	10	0.167	-0.125	0.853	0.033	0.03	0	32.3	31	76.1	109	106	0	34	34
2015	12	28	7	15	10	0.138	-0.131	0.853	0.039	0.036	0	31.4	31	76.1	108	106	0	35	34
2015	12	28	7	25	10	0.131	-0.131	0.853	0.033	0.033	0	31.4	31	76.1	108	106	0	35	34
2015	12	28	7	35	10	0.161	-0.066	0.853	0.036	0.033	0	31	31	76.1	107	106	0	35	34
2015	12	28	7	45	10	0.141	-0.089	0.853	0.039	0.036	0	31.4	31.4	76.5	108	107	0	35	34
2015	12	28	7	55	10	0.187	-0.046	0.853	0.036	0.033	0	31.8	31.8	76.1	109	108	0	35	34
2015	12	28	8	5	10	0.154	-0.069	0.853	0.039	0.036	0	31.8	31.8	76.1	109	108	0	35	34
2015	12	28	8	15	10	0.157	-0.026	0.853	0.036	0.033	0	32.3	31.4	76.1	110	107	0	35	34
2015	12	28	8	25	10	0.138	-0.066	0.853	0.039	0.039	0	31.8	31.4	76.5	109	107	0	35	34
2015	12	28	8	35	10	0.135	-0.118	0.853	0.033	0.03	0	32.3	32.3	76.5	110	109	0	35	34
2015	12	28	8	45	10	0.144	-0.148	0.853	0.049	0.046	0	32.7	31.8	76.5	110	108	0	34	34
2015	12	28	8	55	10	0.184	-0.108	0.853	0.039	0.036	0	32.3	31.8	77	110	108	0	35	34
2015	12	28	9	5	10	0.112	-0.026	0.853	0.036	0.033	0	32.7	31.4	76.5	111	108	0	35	35
2015	12	28	9	15	10	0.21	-0.066	0.853	0.033	0.03	0	32.3	31.8	76.5	110	108	0	35	34
2015	12	28	9	25	10	0.157	-0.082	0.853	0.039	0.039	0	32.7	31.8	76.5	111	108	0	35	34
2015	12	28	9	35	10	0.118	-0.062	0.853	0.039	0.036	0	31.8	31.4	76.5	110	108	0	36	35
2015	12	28	9	45	10	0.118	-0.112	0.853	0.033	0.03	0	32.7	32.3	77	111	109	0	35	34
2015	12	28	9	55	10	0.161	-0.066	0.853	0.039	0.036	0	32.3	31.8	76.5	110	108	0	35	34
2015	12	28	10	5	10	0.19	-0.112	0.853	0.036	0.033	0	32.7	32.3	76.5	111	109	0	35	34
2015	12	28	10	15	10	0.118	-0.105	0.853	0.033	0.03	0	32.7	31.8	76.5	111	109	0	35	35
2015	12	28	10	25	10	0.095	-0.085	0.853	0.036	0.033	0	33.1	32.7	77	112	110	0	35	34
2015	12	28	10	35	10	0.144	-0.128	0.853	0.033	0.03	0	33.5	32.7	77.4	112	110	0	34	34
2015	12	28	10	45	10	0.161	-0.108	0.853	0.036	0.033	0	32.7	33.1	77.4	111	111	0	35	34
2015	12	28	10	55	10	0.197	-0.105	0.853	0.039	0.039	0	33.1	32.7	77	112	110	0	35	34
2015	12	28	11	5	10	0.154	-0.082	0.853	0.033	0.03	0	33.1	32.3	76.5	112	109	0	35	34
2015	12	28	11	15	10	0.157	-0.121	0.853	0.033	0.03	0	33.1	32.7	76.5	112	110	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	11	25	10	0.2	-0.095	0.853	0.033	0.03	0	34	33.1	77.4	114	111	0	35	34
2015	12	28	11	35	10	0.259	-0.112	0.853	0.036	0.033	0	33.1	32.7	77	112	110	0	35	34
2015	12	28	11	45	10	0.167	-0.01	0.853	0.039	0.036	0	33.5	32.3	77	113	109	0	35	34
2015	12	28	11	55	10	0.072	-0.079	0.853	0.036	0.033	0	33.5	32.7	77	113	110	0	35	34
2015	12	28	12	5	10	0.167	-0.069	0.853	0.039	0.039	0	32.7	32.7	77.4	111	110	0	35	34
2015	12	28	12	15	10	0.174	-0.03	0.853	0.039	0.036	0	33.1	32.3	77.4	112	109	0	35	34
2015	12	28	12	25	10	0.213	-0.092	0.853	0.039	0.039	0	32.7	32.3	77.4	111	109	0	35	34
2015	12	28	12	35	10	0.102	-0.092	0.853	0.039	0.036	0	33.1	32.3	77	112	109	0	35	34
2015	12	28	12	45	10	0.161	-0.141	0.853	0.052	0.049	0	34	32.3	77.4	114	109	0	35	34
2015	12	28	12	55	10	0.187	-0.118	0.853	0.036	0.033	0	34	32.7	77	114	110	0	35	34
2015	12	28	13	5	10	0.157	-0.144	0.853	0.036	0.033	0	33.5	32.3	77	113	110	0	35	35
2015	12	28	13	15	10	0.174	-0.135	0.853	0.046	0.043	0	34	32.7	77.8	114	110	0	35	34
2015	12	28	13	25	10	0.135	-0.148	0.853	0.043	0.043	0	33.1	32.3	77	112	109	0	35	34
2015	12	28	13	35	10	0.164	-0.082	0.853	0.036	0.033	0	33.5	32.3	77.4	112	109	0	34	34
2015	12	28	13	45	10	0.213	-0.033	0.85	0.039	0.036	0	33.5	32.7	77	112	110	0	34	34
2015	12	28	13	55	10	0.151	-0.151	0.853	0.039	0.039	0	33.1	33.1	77.4	112	111	0	35	34
2015	12	28	14	5	10	0.157	-0.108	0.853	0.039	0.036	0	33.5	32.7	77	112	110	0	34	34
2015	12	28	14	15	10	0.144	-0.144	0.85	0.039	0.036	0	33.1	32.7	77.4	112	110	0	35	34
2015	12	28	14	25	10	0.154	-0.075	0.85	0.039	0.036	0	34	32.7	77.8	114	110	0	35	34
2015	12	28	14	35	10	0.177	-0.115	0.85	0.039	0.039	0	36.1	35.3	73.1	119	116	0	35	34
2015	12	28	14	45	10	0.148	-0.069	0.85	0.036	0.033	0	34.4	33.1	75.3	114	112	0	34	35
2015	12	28	14	55	10	0.131	-0.121	0.85	0.039	0.036	0	35.3	34	75.3	116	113	0	34	34
2015	12	28	15	5	10	0.138	-0.105	0.85	0.039	0.036	0	34.8	34	75.3	115	113	0	34	34
2015	12	28	15	15	10	0.085	-0.069	0.85	0.039	0.039	0	36.1	35.7	77	118	117	0	34	34
2015	12	28	15	25	10	0.161	-0.161	0.846	0.049	0.049	0	39.1	38.7	78.7	126	124	0	35	34
2015	12	28	15	35	10	0.135	-0.036	0.85	0.046	0.043	0	38.7	38.7	78.3	125	124	0	35	34
2015	12	28	15	45	10	0.164	-0.102	0.85	0.043	0.039	0	40.4	40	77	129	127	0	35	34
2015	12	28	15	55	10	0.105	-0.085	0.85	0.039	0.039	0	42.1	43	76.5	133	134	0	35	34
2015	12	28	16	5	10	0.148	0	0.846	0.043	0.039	0	44.3	44.7	74.8	138	138	0	35	34
2015	12	28	16	15	10	0.18	0.013	0.846	0.043	0.039	0	45.6	45.6	74	140	141	0	34	35
2015	12	28	16	25	10	0.138	0.016	0.846	0.039	0.036	0	46.9	46.9	72.7	144	143	0	35	34
2015	12	28	16	35	10	0.18	0.059	0.85	0.033	0.03	0	48.2	47.7	70.1	147	145	0	35	34
2015	12	28	16	45	10	0.148	0.036	0.846	0.033	0.03	0	49.5	49.5	69.2	149	149	0	34	34
2015	12	28	16	55	10	0.19	0.069	0.85	0.043	0.039	0	50.3	49.5	68.4	151	150	0	34	35
2015	12	28	17	5	10	0.148	0.056	0.85	0.036	0.033	0	49	49.5	68.8	149	149	0	35	34
2015	12	28	17	15	10	0.161	0.059	0.85	0.043	0.039	0	49.5	49	68.8	149	148	0	34	34
2015	12	28	17	25	10	0.226	0	0.85	0.033	0.03	0	49	48.6	69.2	149	147	0	35	34
2015	12	28	17	35	10	0.135	0.098	0.85	0.043	0.039	0	49	47.7	69.7	148	145	0	34	34
2015	12	28	17	45	10	0.161	0.069	0.85	0.046	0.043	0	48.2	47.7	70.1	146	145	0	34	34
2015	12	28	17	55	10	0.194	0.098	0.85	0.036	0.033	0	47.7	47.3	70.1	146	144	0	35	34
2015	12	28	18	5	10	0.21	0.046	0.85	0.033	0.03	0	47.7	46.4	71	145	142	0	34	34
2015	12	28	18	15	10	0.18	0.095	0.85	0.049	0.046	0	46	45.6	71.4	142	140	0	35	34
2015	12	28	18	25	10	0.167	0.046	0.85	0.033	0.03	0	45.6	45.2	72.7	141	139	0	35	34
2015	12	28	18	35	10	0.177	0.115	0.85	0.039	0.039	0	45.2	44.7	72.2	140	138	0	35	34
2015	12	28	18	45	10	0.213	0.148	0.85	0.039	0.039	0	44.7	44.3	72.2	139	137	0	35	34
2015	12	28	18	55	10	0.151	0.108	0.85	0.036	0.033	0	44.3	43.9	73.5	138	136	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	19	5	10	0.135	0.121	0.85	0.039	0.036	0	44.3	43.4	73.1	138	135	0	35	34
2015	12	28	19	15	10	0.2	0.135	0.85	0.033	0.03	0	44.3	43.4	73.1	138	135	0	35	34
2015	12	28	19	25	10	0.174	0.131	0.85	0.036	0.033	0	43.9	43	73.1	137	134	0	35	34
2015	12	28	19	35	10	0.2	0.121	0.85	0.036	0.033	0	43.9	43	73.1	137	134	0	35	34
2015	12	28	19	45	10	0.141	0.21	0.85	0.036	0.033	0	43.9	42.6	73.5	136	133	0	34	34
2015	12	28	19	55	10	0.128	0.128	0.85	0.043	0.039	0	43	42.1	74	135	132	0	35	34
2015	12	28	20	5	10	0.23	0.118	0.85	0.039	0.036	0	42.6	42.6	74	134	132	0	35	33
2015	12	28	20	15	10	0.279	0.167	0.85	0.036	0.033	0	42.6	41.7	74.4	134	131	0	35	34
2015	12	28	20	25	10	0.161	0.108	0.85	0.039	0.039	0	42.1	41.7	73.5	133	131	0	35	34
2015	12	28	20	35	10	0.184	0.177	0.85	0.036	0.033	0	42.6	41.7	74.4	133	131	0	34	34
2015	12	28	20	45	10	0.279	0.141	0.85	0.033	0.03	0	42.6	42.1	74	133	131	0	34	33
2015	12	28	20	55	10	0.19	0.144	0.85	0.039	0.036	0	41.7	41.3	74.4	132	130	0	35	34
2015	12	28	21	5	10	0.207	0.154	0.85	0.039	0.039	0	41.7	40.9	74.4	132	129	0	35	34
2015	12	28	21	15	10	0.174	0.112	0.85	0.036	0.033	0	41.7	41.3	74.8	132	129	0	35	33
2015	12	28	21	25	10	0.174	0.164	0.85	0.039	0.039	0	41.7	40.9	73.5	131	129	0	34	34
2015	12	28	21	35	10	0.18	0.164	0.853	0.039	0.036	0	40.9	40.4	74.4	130	128	0	35	34
2015	12	28	21	45	10	0.249	0.112	0.853	0.039	0.036	0	40.9	40	74.8	130	127	0	35	34
2015	12	28	21	55	10	0.187	0.171	0.85	0.036	0.033	0	40.4	40	75.3	129	127	0	35	34
2015	12	28	22	5	10	0.236	0.177	0.853	0.036	0.033	0	40	38.7	75.3	128	125	0	35	35
2015	12	28	22	15	10	0.223	0.197	0.853	0.033	0.03	0	39.6	39.1	74.8	127	125	0	35	34
2015	12	28	22	25	10	0.23	0.144	0.853	0.039	0.039	0	38.7	38.7	75.7	125	123	0	35	33
2015	12	28	22	35	10	0.118	0.036	0.853	0.043	0.043	0	38.7	38.3	75.7	124	122	0	34	33
2015	12	28	22	45	10	0.154	0.085	0.85	0.036	0.033	0	37.8	37.8	76.1	123	122	0	35	34
2015	12	28	22	55	10	0.115	0.161	0.853	0.039	0.036	0	37.8	37.4	75.3	122	121	0	34	34
2015	12	28	23	5	10	0.121	0.121	0.85	0.043	0.039	0	37.8	36.5	75.3	122	119	0	34	34
2015	12	28	23	15	10	0.049	0.128	0.85	0.033	0.03	0	36.5	36.1	74.8	120	118	0	35	34
2015	12	28	23	25	10	0.144	-0.023	0.853	0.039	0.036	0	36.1	36.1	75.3	118	118	0	34	34
2015	12	28	23	35	10	0.135	0.066	0.853	0.036	0.033	0	36.1	36.1	74	119	118	0	35	34
2015	12	28	23	45	10	0.18	0.007	0.853	0.033	0.033	0	35.7	36.1	74.4	118	118	0	35	34
2015	12	28	23	55	10	0.131	0.039	0.853	0.033	0.03	0	36.1	35.3	74.8	119	116	0	35	34
2015	12	29	0	5	10	0.157	0	0.853	0.036	0.033	0	36.1	35.3	76.5	118	116	0	34	34
2015	12	29	0	15	10	0.131	0.023	0.853	0.036	0.033	0	35.3	35.7	76.1	117	117	0	35	34
2015	12	29	0	25	10	0.138	0.023	0.853	0.033	0.03	0	35.3	35.3	75.7	117	115	0	35	33
2015	12	29	0	35	10	0.207	0	0.853	0.036	0.033	0	35.7	34.8	76.5	117	115	0	34	34
2015	12	29	0	45	10	0.174	-0.039	0.85	0.033	0.03	0	34.8	34.8	75.3	116	115	0	35	34
2015	12	29	0	55	10	0.131	0	0.85	0.039	0.036	0	34.4	34.4	76.5	115	114	0	35	34
2015	12	29	1	5	10	0.226	-0.036	0.85	0.036	0.033	0	34	34.4	75.3	114	114	0	35	34
2015	12	29	1	15	10	0.148	0.03	0.85	0.039	0.036	0	34.4	34.4	75.7	115	114	0	35	34
2015	12	29	1	25	10	0.157	0.01	0.853	0.039	0.039	0	34	34.4	76.5	114	114	0	35	34
2015	12	29	1	35	10	0.233	-0.026	0.85	0.033	0.03	0	34	33.5	75.7	113	112	0	34	34
2015	12	29	1	45	10	0.197	-0.062	0.853	0.043	0.039	0	33.5	33.5	75.7	113	112	0	35	34
2015	12	29	1	55	10	0.148	-0.039	0.85	0.033	0.03	0	33.1	33.1	76.1	112	111	0	35	34
2015	12	29	2	5	10	0.135	-0.072	0.85	0.033	0.03	0	33.1	33.5	74	112	112	0	35	34
2015	12	29	2	15	10	0.184	-0.039	0.85	0.039	0.036	0	33.1	32.7	75.3	112	110	0	35	34
2015	12	29	2	25	10	0.18	-0.066	0.85	0.036	0.033	0	33.1	32.7	76.1	111	110	0	34	34
2015	12	29	2	35	10	0.171	-0.036	0.85	0.039	0.036	0	32.7	32.7	76.5	111	110	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	2	45	10	0.184	0.046	0.85	0.033	0.03	0	32.3	32.7	75.3	110	110	0	35	34
2015	12	29	2	55	10	0.154	-0.026	0.85	0.033	0.03	0	32.7	32.3	74.4	111	109	0	35	34
2015	12	29	3	5	10	0.141	-0.148	0.85	0.039	0.036	0	32.3	32.3	76.1	110	109	0	35	34
2015	12	29	3	15	10	0.144	-0.046	0.85	0.033	0.03	0	32.7	32.3	74.8	111	109	0	35	34
2015	12	29	3	25	10	0.161	-0.056	0.85	0.036	0.033	0	32.3	32.3	76.1	110	109	0	35	34
2015	12	29	3	35	10	0.085	-0.059	0.85	0.036	0.033	0	31.8	32.3	75.3	109	109	0	35	34
2015	12	29	3	45	10	0.21	-0.056	0.85	0.039	0.036	0	31.8	32.3	75.7	109	109	0	35	34
2015	12	29	3	55	10	0.194	-0.046	0.85	0.033	0.03	0	32.3	32.3	76.1	110	108	0	35	33
2015	12	29	4	5	10	0.184	-0.036	0.85	0.033	0.03	0	32.3	33.1	74.4	109	110	0	34	33
2015	12	29	4	15	10	0.157	-0.036	0.85	0.036	0.033	0	32.3	31.8	74.8	110	108	0	35	34
2015	12	29	4	25	10	0.148	-0.075	0.85	0.033	0.03	0	31.8	32.7	74.4	109	110	0	35	34
2015	12	29	4	35	10	0.194	-0.062	0.85	0.033	0.03	0	33.1	32.3	73.1	111	109	0	34	34
2015	12	29	4	45	10	0.233	-0.092	0.85	0.036	0.033	0	31.8	32.3	74	109	109	0	35	34
2015	12	29	4	55	10	0.207	-0.066	0.85	0.039	0.036	0	31.8	31.8	75.7	109	108	0	35	34
2015	12	29	5	5	10	0.138	-0.039	0.85	0.033	0.03	0	32.3	31.8	74.8	110	108	0	35	34
2015	12	29	5	15	10	0.131	-0.135	0.85	0.033	0.03	0	32.3	31.8	76.1	110	109	0	35	35
2015	12	29	5	25	10	0.194	-0.082	0.85	0.036	0.033	0	32.3	31.8	74.8	110	108	0	35	34
2015	12	29	5	35	10	0.141	-0.082	0.85	0.033	0.03	0	31.8	32.3	76.1	109	109	0	35	34
2015	12	29	5	45	10	0.161	-0.046	0.85	0.033	0.03	0	31.8	31.8	74.4	109	108	0	35	34
2015	12	29	5	55	10	0.167	-0.131	0.85	0.033	0.03	0	31.4	31.4	72.2	108	108	0	35	35
2015	12	29	6	5	10	0.118	-0.039	0.85	0.043	0.039	0	31.8	31.8	75.3	109	108	0	35	34
2015	12	29	6	15	10	0.105	-0.089	0.85	0.036	0.033	0	31.8	31.4	73.5	109	107	0	35	34
2015	12	29	6	25	10	0.148	-0.095	0.85	0.033	0.03	0	32.3	31.4	74.4	110	108	0	35	35
2015	12	29	6	35	10	0.151	0.013	0.85	0.039	0.036	0	31.8	31.8	75.3	109	108	0	35	34
2015	12	29	6	45	10	0.236	-0.115	0.85	0.039	0.036	0	32.3	31.4	76.5	109	107	0	34	34
2015	12	29	6	55	10	0.194	-0.105	0.85	0.033	0.03	0	31.4	31.4	76.1	108	107	0	35	34
2015	12	29	7	5	10	0.157	-0.082	0.85	0.033	0.03	0	32.3	31.8	75.7	110	108	0	35	34
2015	12	29	7	15	10	0.154	-0.052	0.85	0.036	0.033	0	31.8	31.4	75.7	109	107	0	35	34
2015	12	29	7	25	10	0.121	-0.052	0.85	0.033	0.03	0	31.8	31.4	74.8	109	107	0	35	34
2015	12	29	7	35	10	0.131	-0.039	0.85	0.036	0.033	0	31.8	31.8	75.7	109	108	0	35	34
2015	12	29	7	45	10	0.154	-0.092	0.85	0.036	0.033	0	32.3	31.8	76.5	110	108	0	35	34
2015	12	29	7	55	10	0.154	-0.069	0.85	0.039	0.036	0	32.3	31.4	75.7	110	108	0	35	35
2015	12	29	8	5	10	0.223	0	0.85	0.036	0.033	0	32.7	32.3	75.3	111	109	0	35	34
2015	12	29	8	15	10	0.112	-0.112	0.85	0.036	0.033	0	32.3	31.8	75.3	110	108	0	35	34
2015	12	29	8	25	10	0.108	-0.108	0.85	0.039	0.036	0	33.1	32.3	74.4	111	109	0	34	34
2015	12	29	8	35	10	0.131	-0.023	0.85	0.039	0.039	0	33.5	32.3	71.8	112	110	0	34	35
2015	12	29	8	45	10	0.144	-0.052	0.85	0.039	0.036	0	32.7	32.3	73.1	111	109	0	35	34
2015	12	29	8	55	10	0.085	-0.092	0.85	0.033	0.03	0	33.1	32.7	72.2	112	110	0	35	34
2015	12	29	9	5	10	0.177	-0.118	0.85	0.036	0.033	0	33.1	32.7	74.4	112	110	0	35	34
2015	12	29	9	15	10	0.144	-0.079	0.85	0.033	0.03	0	33.1	32.7	74.4	112	110	0	35	34
2015	12	29	9	25	10	0.197	-0.03	0.85	0.033	0.03	0	32.7	33.1	74.4	111	111	0	35	34
2015	12	29	9	35	10	0.157	-0.075	0.85	0.033	0.03	0	33.1	32.7	74.4	112	111	0	35	35
2015	12	29	9	45	10	0.167	-0.089	0.85	0.036	0.033	0	33.1	33.1	74.4	112	111	0	35	34
2015	12	29	9	55	10	0.105	-0.082	0.85	0.036	0.033	0	33.5	32.7	73.5	113	111	0	35	35
2015	12	29	10	5	10	0.079	0.01	0.85	0.036	0.033	0	34	33.5	72.7	113	112	0	34	34
2015	12	29	10	15	10	0.118	-0.089	0.85	0.039	0.036	0	34.4	34.4	72.7	115	114	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	10	25	10	0.154	-0.075	0.85	0.033	0.03	0	34.4	34.4	73.5	115	114	0	35	34
2015	12	29	10	35	10	0.128	-0.049	0.85	0.036	0.033	0	34.4	34.4	75.7	115	114	0	35	34
2015	12	29	10	45	10	0.174	-0.059	0.85	0.033	0.03	0	35.3	34.8	76.1	117	115	0	35	34
2015	12	29	10	55	10	0.118	-0.039	0.85	0.039	0.036	0	34.8	35.3	74	116	116	0	35	34
2015	12	29	11	5	10	0.253	-0.026	0.85	0.036	0.033	0	36.1	35.7	73.5	118	117	0	34	34
2015	12	29	11	15	10	0.151	-0.125	0.85	0.036	0.033	0	36.5	36.1	75.3	119	118	0	34	34
2015	12	29	11	25	10	0.177	0.003	0.85	0.033	0.03	0	37.4	36.5	73.5	121	119	0	34	34
2015	12	29	11	35	10	0.138	-0.138	0.85	0.036	0.033	0	36.1	36.1	75.7	119	118	0	35	34
2015	12	29	11	45	10	0.131	-0.066	0.85	0.039	0.036	0	36.5	37	75.3	120	119	0	35	33
2015	12	29	11	55	10	0.154	-0.016	0.85	0.039	0.036	0	37	36.5	74.8	121	119	0	35	34
2015	12	29	12	5	10	0.184	-0.036	0.85	0.039	0.036	0	37.4	37	75.3	122	120	0	35	34
2015	12	29	12	15	10	0.174	0.016	0.85	0.036	0.033	0	37.4	37.4	74.8	122	121	0	35	34
2015	12	29	12	25	10	0.174	-0.066	0.85	0.033	0.03	0	38.7	37.8	75.3	125	122	0	35	34
2015	12	29	12	35	10	0.194	-0.105	0.85	0.039	0.036	0	37.8	37.8	77	123	122	0	35	34
2015	12	29	12	45	10	0.167	-0.079	0.85	0.039	0.036	0	38.3	37.8	76.1	124	122	0	35	34
2015	12	29	12	55	10	0.135	-0.066	0.85	0.033	0.03	0	38.7	37.8	77	124	122	0	34	34
2015	12	29	13	5	10	0.184	-0.043	0.85	0.036	0.033	0	37.8	37.4	77	123	121	0	35	34
2015	12	29	13	15	10	0.144	-0.033	0.85	0.033	0.03	0	38.7	37.4	76.5	124	121	0	34	34
2015	12	29	13	25	10	0.243	-0.082	0.85	0.036	0.033	0	38.3	37.4	76.1	124	121	0	35	34
2015	12	29	13	35	10	0.2	-0.089	0.85	0.033	0.03	0	38.7	37.8	77.4	124	122	0	34	34
2015	12	29	13	45	10	0.098	-0.046	0.85	0.039	0.036	0	38.3	37.4	77	124	121	0	35	34
2015	12	29	13	55	10	0.144	-0.026	0.85	0.036	0.033	0	38.7	37.8	76.5	125	121	0	35	33
2015	12	29	14	5	10	0.138	-0.043	0.85	0.043	0.039	0	38.3	38.3	77	124	122	0	35	33
2015	12	29	14	15	10	0.177	-0.03	0.85	0.036	0.033	0	38.3	38.3	77.4	124	123	0	35	34
2015	12	29	14	25	10	0.167	-0.036	0.85	0.033	0.03	0	39.1	38.3	77	125	122	0	34	33
2015	12	29	14	35	10	0.151	-0.079	0.85	0.036	0.033	0	39.1	39.1	77	126	124	0	35	33
2015	12	29	14	45	10	0.118	-0.075	0.85	0.036	0.033	0	39.1	37.8	77.4	126	123	0	35	35
2015	12	29	14	55	10	0.151	-0.082	0.85	0.039	0.039	0	40.4	39.6	77.4	128	125	0	34	33
2015	12	29	15	5	10	0.148	-0.098	0.85	0.036	0.033	0	40	39.6	77.4	128	125	0	35	33
2015	12	29	15	15	10	0.128	0.052	0.85	0.033	0.03	0	39.6	39.6	77.4	126	125	0	34	33
2015	12	29	15	25	10	0.187	-0.007	0.85	0.039	0.039	0	39.1	38.3	77	125	123	0	34	34
2015	12	29	15	35	10	0.144	0	0.85	0.033	0.03	0	39.6	38.7	77.4	126	123	0	34	33
2015	12	29	15	45	10	0.197	0	0.85	0.033	0.03	0	38.7	38.3	77.4	124	123	0	34	34
2015	12	29	15	55	10	0.121	-0.033	0.85	0.039	0.036	0	38.3	37.8	77.8	123	122	0	34	34
2015	12	29	16	5	10	0.131	-0.043	0.85	0.036	0.033	0	38.3	37.4	77.8	123	121	0	34	34
2015	12	29	16	15	10	0.167	-0.02	0.85	0.039	0.036	0	38.7	38.3	77.4	124	122	0	34	33
2015	12	29	16	25	10	0.154	-0.026	0.85	0.033	0.03	0	38.7	37.8	77.8	124	122	0	34	34
2015	12	29	16	35	10	0.164	0.016	0.85	0.033	0.03	0	39.1	37.8	77.8	125	122	0	34	34
2015	12	29	16	45	10	0.138	0.033	0.85	0.039	0.039	0	39.1	38.3	77.4	125	123	0	34	34
2015	12	29	16	55	10	0.177	-0.026	0.85	0.039	0.039	0	39.1	38.7	77.8	126	124	0	35	34
2015	12	29	17	5	10	0.174	0.079	0.85	0.033	0.03	0	39.6	38.3	77.8	127	124	0	35	35
2015	12	29	17	15	10	0.105	-0.01	0.85	0.039	0.036	0	39.1	38.7	77.4	125	124	0	34	34
2015	12	29	17	25	10	0.131	-0.01	0.85	0.039	0.036	0	38.7	38.3	77.8	125	123	0	35	34
2015	12	29	17	35	10	0.161	0.092	0.85	0.039	0.036	0	39.6	38.7	77.8	126	124	0	34	34
2015	12	29	17	45	10	0.187	-0.059	0.85	0.033	0.03	0	38.7	38.3	77.8	124	123	0	34	34
2015	12	29	17	55	10	0.157	0.046	0.85	0.046	0.046	0	38.3	38.3	77.4	124	122	0	35	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	18	5	10	0.177	0.052	0.85	0.036	0.033	0	37.8	38.3	77.8	123	122	0	35	33
2015	12	29	18	15	10	0.115	-0.003	0.85	0.036	0.033	0	38.7	37.8	77.8	124	122	0	34	34
2015	12	29	18	25	10	0.203	-0.013	0.85	0.036	0.033	0	37.8	36.5	78.3	122	119	0	34	34
2015	12	29	18	35	10	0.18	0.059	0.85	0.039	0.036	0	37.8	36.5	78.3	122	119	0	34	34
2015	12	29	18	45	10	0.151	0.026	0.85	0.033	0.03	0	37	36.1	77.4	121	118	0	35	34
2015	12	29	18	55	10	0.121	-0.02	0.85	0.039	0.039	0	37	36.1	78.3	121	118	0	35	34
2015	12	29	19	5	10	0.187	-0.092	0.85	0.036	0.033	0	36.5	35.3	78.7	119	116	0	34	34
2015	12	29	19	15	10	0.121	-0.033	0.85	0.039	0.039	0	36.1	34.8	78.7	119	115	0	35	34
2015	12	29	19	25	10	0.19	-0.039	0.85	0.039	0.039	0	35.7	34.4	78.7	117	114	0	34	34
2015	12	29	19	35	10	0.102	-0.075	0.85	0.033	0.03	0	35.7	35.3	79.1	118	115	0	35	33
2015	12	29	19	45	10	0.217	-0.066	0.85	0.036	0.033	0	35.3	34.4	78.7	117	113	0	35	33
2015	12	29	19	55	10	0.121	-0.02	0.85	0.039	0.036	0	35.7	34.4	79.1	117	114	0	34	34
2015	12	29	20	5	10	0.118	0	0.85	0.036	0.033	0	35.7	34	79.1	117	113	0	34	34
2015	12	29	20	15	10	0.203	-0.039	0.85	0.039	0.036	0	35.3	33.5	78.7	116	112	0	34	34
2015	12	29	20	25	10	0.167	0	0.85	0.036	0.033	0	34.8	33.5	79.1	115	112	0	34	34
2015	12	29	20	35	10	0.115	-0.03	0.85	0.049	0.049	0	36.1	36.1	78.3	119	118	0	35	34
2015	12	29	20	45	10	0.141	-0.03	0.85	0.039	0.036	0	35.3	34.4	79.1	116	113	0	34	33
2015	12	29	20	55	10	0.174	-0.02	0.85	0.033	0.03	0	34.4	33.1	79.6	115	111	0	35	34
2015	12	29	21	5	10	0.138	-0.039	0.85	0.036	0.033	0	34.4	32.7	79.1	114	110	0	34	34
2015	12	29	21	15	10	0.18	-0.023	0.85	0.033	0.033	0	33.5	31.8	79.6	113	108	0	35	34
2015	12	29	21	25	10	0.157	-0.039	0.85	0.033	0.03	0	33.5	31.8	79.1	113	108	0	35	34
2015	12	29	21	35	10	0.18	-0.049	0.85	0.033	0.03	0	33.1	31.8	80	112	108	0	35	34
2015	12	29	21	45	10	0.108	-0.043	0.85	0.033	0.03	0	33.5	31.4	79.1	112	107	0	34	34
2015	12	29	21	55	10	0.128	-0.085	0.85	0.036	0.033	0	33.1	31	78.7	111	107	0	34	35
2015	12	29	22	5	10	0.151	-0.098	0.85	0.036	0.033	0	32.3	31	78.7	110	106	0	35	34
2015	12	29	22	15	10	0.174	-0.151	0.85	0.039	0.039	0	32.3	31	78.7	110	106	0	35	34
2015	12	29	22	25	10	0.112	-0.052	0.85	0.036	0.033	0	32.3	30.5	78.7	110	105	0	35	34
2015	12	29	22	35	10	0.108	-0.161	0.85	0.036	0.033	0	31.8	30.5	78.7	109	105	0	35	34
2015	12	29	22	45	10	0.171	-0.118	0.85	0.033	0.03	0	31.8	31	78.7	108	106	0	34	34
2015	12	29	22	55	10	0.128	-0.049	0.85	0.039	0.036	0	31.4	30.5	79.1	108	105	0	35	34
2015	12	29	23	5	10	0.095	-0.066	0.85	0.036	0.033	0	31	30.5	79.1	107	105	0	35	34
2015	12	29	23	15	10	0.174	-0.075	0.85	0.033	0.03	0	30.5	30.5	78.7	106	105	0	35	34
2015	12	29	23	25	10	0.194	-0.052	0.85	0.036	0.033	0	30.1	30.5	79.1	105	105	0	35	34
2015	12	29	23	35	10	0.157	-0.02	0.85	0.033	0.03	0	30.5	30.1	79.1	105	103	0	34	33
2015	12	29	23	45	10	0.148	-0.052	0.85	0.033	0.03	0	30.5	30.1	78.7	106	104	0	35	34
2015	12	29	23	55	10	0.161	-0.039	0.85	0.039	0.036	0	31	31	78.7	106	105	0	34	33
2015	12	30	0	5	10	0.19	-0.112	0.85	0.033	0.03	0	30.1	30.1	78.7	105	104	0	35	34
2015	12	30	0	15	10	0.161	-0.059	0.85	0.033	0.033	0	30.5	31	78.3	105	105	0	34	33
2015	12	30	0	25	10	0.2	-0.059	0.85	0.033	0.033	0	31	30.1	78.3	106	104	0	34	34
2015	12	30	0	35	10	0.118	-0.082	0.85	0.039	0.036	0	30.5	30.5	78.3	106	105	0	35	34
2015	12	30	0	45	10	0.21	-0.098	0.85	0.039	0.036	0	31.4	30.5	78.3	107	105	0	34	34
2015	12	30	0	55	10	0.203	-0.079	0.85	0.039	0.036	0	31.4	30.5	78.7	107	105	0	34	34
2015	12	30	1	5	10	0.177	-0.098	0.85	0.039	0.036	0	31	31	78.3	107	106	0	35	34
2015	12	30	1	15	10	0.197	0	0.85	0.036	0.033	0	31	30.5	78.7	107	105	0	35	34
2015	12	30	1	25	10	0.144	-0.069	0.85	0.046	0.043	0	30.5	31	79.1	106	105	0	35	33
2015	12	30	1	35	10	0.184	-0.013	0.85	0.036	0.033	0	31	29.7	78.3	107	104	0	35	35

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	1	45	10	0.161	-0.121	0.85	0.036	0.033	0	31.8	29.7	78.3	108	104	0	34	35
2015	12	30	1	55	10	0.2	-0.003	0.85	0.036	0.033	0	31.4	31	78.7	107	105	0	34	33
2015	12	30	2	5	10	0.131	-0.052	0.85	0.039	0.036	0	31.4	30.1	78.3	107	105	0	34	35
2015	12	30	2	15	10	0.121	-0.118	0.85	0.033	0.03	0	30.5	31.4	77.8	106	107	0	35	34
2015	12	30	2	25	10	0.164	-0.043	0.85	0.039	0.036	0	31.8	30.1	78.3	108	105	0	34	35
2015	12	30	2	35	10	0.089	-0.082	0.85	0.033	0.03	0	31	31	78.3	107	106	0	35	34
2015	12	30	2	45	10	0.144	-0.046	0.85	0.033	0.03	0	31.4	32.3	78.3	107	108	0	34	33
2015	12	30	2	55	10	0.154	-0.118	0.85	0.039	0.036	0	31.8	31.4	77.8	109	107	0	35	34
2015	12	30	3	5	10	0.157	-0.03	0.85	0.036	0.033	0	31.4	31	77.8	108	106	0	35	34
2015	12	30	3	15	10	0.121	-0.121	0.85	0.033	0.03	0	31.8	30.5	77.8	108	106	0	34	35
2015	12	30	3	25	10	0.18	-0.085	0.85	0.036	0.033	0	31.4	31	78.3	108	106	0	35	34
2015	12	30	3	35	10	0.184	-0.108	0.85	0.033	0.03	0	31.4	31.4	77.8	108	106	0	35	33
2015	12	30	3	45	10	0.253	-0.052	0.85	0.036	0.033	0	31.4	31	78.3	107	106	0	34	34
2015	12	30	3	55	10	0.121	-0.118	0.85	0.033	0.03	0	32.3	31.8	77.8	109	108	0	34	34
2015	12	30	4	5	10	0.171	-0.131	0.85	0.033	0.03	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	30	4	15	10	0.161	-0.092	0.85	0.039	0.036	0	31	31	77.8	107	106	0	35	34
2015	12	30	4	25	10	0.21	-0.154	0.85	0.046	0.043	0	31	31.4	78.3	107	106	0	35	33
2015	12	30	4	35	10	0.131	-0.082	0.85	0.033	0.03	0	31.8	30.5	77.8	108	105	0	34	34
2015	12	30	4	45	10	0.174	-0.085	0.85	0.036	0.033	0	31	30.5	77.8	107	105	0	35	34
2015	12	30	4	55	10	0.213	-0.056	0.85	0.033	0.03	0	31	31.8	77.8	107	107	0	35	33
2015	12	30	5	5	10	0.125	-0.108	0.85	0.033	0.03	0	31	31.4	77.8	107	107	0	35	34
2015	12	30	5	15	10	0.177	0.03	0.85	0.036	0.033	0	30.5	30.1	77.4	106	105	0	35	35
2015	12	30	5	25	10	0.207	-0.026	0.85	0.036	0.033	0	31	31	77.8	107	106	0	35	34
2015	12	30	5	35	10	0.102	-0.026	0.85	0.039	0.036	0	31	30.1	77.8	107	104	0	35	34
2015	12	30	5	45	10	0.131	-0.056	0.846	0.033	0.03	0	31.4	30.1	77.8	107	104	0	34	34
2015	12	30	5	55	10	0.157	-0.069	0.85	0.036	0.033	0	30.5	30.5	77.8	106	105	0	35	34
2015	12	30	6	5	10	0.167	-0.026	0.85	0.033	0.03	0	30.1	30.1	77.8	105	104	0	35	34
2015	12	30	6	15	10	0.144	-0.043	0.85	0.033	0.03	0	30.5	29.7	77.4	106	104	0	35	35
2015	12	30	6	25	10	0.105	-0.013	0.85	0.043	0.039	0	30.1	29.7	77.8	105	103	0	35	34
2015	12	30	6	35	10	0.131	-0.013	0.846	0.036	0.033	0	29.7	29.2	77.8	104	102	0	35	34
2015	12	30	6	45	10	0.118	-0.026	0.85	0.033	0.03	0	29.7	29.2	78.3	104	103	0	35	35
2015	12	30	6	55	10	0.171	-0.075	0.846	0.033	0.03	0	30.5	29.7	77.8	106	104	0	35	35
2015	12	30	7	5	10	0.151	-0.03	0.846	0.033	0.03	0	30.5	30.1	77.8	105	104	0	34	34
2015	12	30	7	15	10	0.098	-0.125	0.85	0.039	0.036	0	30.5	30.1	77.8	106	105	0	35	35
2015	12	30	7	25	10	0.128	-0.079	0.85	0.036	0.033	0	30.1	29.7	78.3	105	104	0	35	35
2015	12	30	7	35	10	0.125	-0.072	0.85	0.033	0.03	0	30.1	29.2	77.8	105	102	0	35	34
2015	12	30	7	45	10	0.118	-0.026	0.85	0.033	0.03	0	31	30.1	77.8	106	104	0	34	34
2015	12	30	7	55	10	0.043	-0.059	0.85	0.043	0.039	0	30.5	30.5	78.3	105	105	0	34	34
2015	12	30	8	5	10	0.115	-0.066	0.85	0.036	0.033	0	31	30.1	77.8	106	105	0	34	35
2015	12	30	8	15	10	0.075	-0.056	0.85	0.036	0.033	0	31	29.7	78.3	106	104	0	34	35
2015	12	30	8	25	10	0.135	-0.108	0.85	0.033	0.03	0	31	31	78.3	107	106	0	35	34
2015	12	30	8	35	10	0.125	-0.131	0.846	0.039	0.036	0	31	30.5	78.3	107	105	0	35	34
2015	12	30	8	45	10	0.161	-0.026	0.846	0.039	0.039	0	31	31	77.8	107	106	0	35	34
2015	12	30	8	55	10	0.207	-0.079	0.846	0.036	0.033	0	31.4	31	78.3	108	106	0	35	34
2015	12	30	9	5	10	0.213	-0.092	0.846	0.036	0.033	0	31.8	31	78.3	108	106	0	34	34
2015	12	30	9	15	10	0.112	-0.066	0.85	0.036	0.033	0	31	31	77.8	107	106	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	9	25	10	0.075	-0.043	0.846	0.033	0.03	0	31.4	31	78.3	108	107	0	35	35
2015	12	30	9	35	10	0.098	-0.089	0.846	0.039	0.036	0	31.4	31	78.3	108	106	0	35	34
2015	12	30	9	45	10	0.075	-0.01	0.846	0.033	0.03	0	31.4	31.4	78.3	108	106	0	35	33
2015	12	30	9	55	10	0.138	-0.059	0.846	0.039	0.039	0	32.3	31.4	79.1	110	107	0	35	34
2015	12	30	10	5	10	0.105	-0.079	0.846	0.039	0.036	0	32.3	31.4	78.3	111	107	0	36	34
2015	12	30	10	15	10	0.131	-0.062	0.846	0.033	0.03	0	33.1	32.7	78.3	112	110	0	35	34
2015	12	30	10	25	10	0.148	-0.013	0.846	0.036	0.033	0	32.7	31.4	79.1	111	108	0	35	35
2015	12	30	10	35	10	0.118	-0.02	0.846	0.033	0.03	0	32.3	31.4	78.3	110	108	0	35	35
2015	12	30	10	45	10	0.095	-0.026	0.846	0.043	0.039	0	32.7	32.7	78.3	111	110	0	35	34
2015	12	30	10	55	10	0.154	-0.043	0.846	0.033	0.03	0	32.3	32.7	78.3	110	111	0	35	35
2015	12	30	11	5	10	0.157	-0.039	0.85	0.039	0.039	0	33.5	33.1	78.3	113	110	0	35	33
2015	12	30	11	15	10	0.174	-0.069	0.85	0.046	0.043	0	34	33.1	78.3	114	111	0	35	34
2015	12	30	11	25	10	0.148	-0.049	0.85	0.043	0.039	0	34	32.7	78.3	114	110	0	35	34
2015	12	30	11	35	10	0.2	-0.079	0.85	0.039	0.039	0	34	32.3	78.7	114	109	0	35	34
2015	12	30	11	45	10	0.098	-0.046	0.85	0.033	0.03	0	34	32.3	78.7	114	109	0	35	34
2015	12	30	11	55	10	0.161	-0.059	0.85	0.033	0.03	0	33.5	32.7	78.7	113	110	0	35	34
2015	12	30	12	5	10	0.164	-0.056	0.85	0.043	0.043	0	33.5	32.7	78.7	112	110	0	34	34
2015	12	30	12	15	10	0.085	-0.085	0.85	0.039	0.039	0	33.1	32.7	78.7	112	110	0	35	34
2015	12	30	12	25	10	0.197	-0.059	0.85	0.043	0.039	0	33.5	33.5	78.7	113	111	0	35	33
2015	12	30	12	35	10	0.105	-0.112	0.85	0.033	0.03	0	33.5	34	78.3	113	113	0	35	34
2015	12	30	12	45	10	0.19	-0.085	0.85	0.033	0.03	0	34.4	33.1	79.1	114	111	0	34	34
2015	12	30	12	55	10	0.174	0.003	0.85	0.036	0.033	0	34.4	33.5	78.3	114	112	0	34	34
2015	12	30	13	5	10	0.148	-0.02	0.85	0.036	0.033	0	34	33.5	78.7	114	112	0	35	34
2015	12	30	13	15	10	0.194	-0.135	0.85	0.043	0.039	0	35.3	34.4	78.7	116	113	0	34	33
2015	12	30	13	25	10	0.157	0.013	0.85	0.043	0.039	0	35.3	34.4	78.7	116	114	0	34	34
2015	12	30	13	35	10	0.177	-0.026	0.85	0.033	0.03	0	36.1	34.4	79.1	119	114	0	35	34
2015	12	30	13	45	10	0.128	0.01	0.85	0.039	0.036	0	35.7	34.8	78.3	117	115	0	34	34
2015	12	30	13	55	10	0.184	-0.089	0.85	0.039	0.039	0	36.1	34.8	78.7	118	115	0	34	34
2015	12	30	14	5	10	0.154	-0.112	0.85	0.033	0.03	0	35.7	34.8	78.7	118	115	0	35	34
2015	12	30	14	15	10	0.18	-0.075	0.846	0.036	0.033	0	36.5	34.8	78.7	120	115	0	35	34
2015	12	30	14	25	10	0.197	-0.023	0.85	0.036	0.033	0	36.1	34.8	78.7	119	115	0	35	34
2015	12	30	14	35	10	0.164	-0.056	0.85	0.033	0.03	0	35.7	34.8	78.7	118	115	0	35	34
2015	12	30	14	45	10	0.121	-0.095	0.85	0.036	0.033	0	36.5	35.7	78.3	119	117	0	34	34
2015	12	30	14	55	10	0.177	-0.098	0.85	0.039	0.036	0	36.5	36.1	78.3	119	118	0	34	34
2015	12	30	15	5	10	0.135	-0.016	0.85	0.033	0.03	0	37	36.1	78.7	120	117	0	34	33
2015	12	30	15	15	10	0.105	-0.105	0.85	0.046	0.043	0	35.7	35.7	78.7	117	116	0	34	33
2015	12	30	15	25	10	0.171	-0.079	0.85	0.039	0.039	0	35.3	34.8	78.7	117	115	0	35	34
2015	12	30	15	35	10	0.161	-0.052	0.85	0.039	0.036	0	36.1	35.3	78.7	118	116	0	34	34
2015	12	30	15	45	10	0.075	-0.052	0.85	0.033	0.03	0	36.5	35.3	78.3	119	116	0	34	34
2015	12	30	15	55	10	0.135	-0.062	0.85	0.033	0.03	0	36.5	35.7	78.7	120	117	0	35	34
2015	12	30	16	5	10	0.112	-0.066	0.85	0.036	0.033	0	36.5	35.7	78.7	120	117	0	35	34
2015	12	30	16	15	10	0.21	-0.108	0.85	0.036	0.033	0	36.1	34.4	78.3	118	115	0	34	35
2015	12	30	16	36	20	0.21	-0.046	0.85	0.039	0.039	0	34.8	34.4	79.1	116	114	0	35	34
2015	12	30	16	46	20	0.121	-0.082	0.846	0.033	0.03	0	35.3	34.4	79.1	117	114	0	35	34
2015	12	30	16	56	20	0.18	-0.121	0.85	0.033	0.03	0	34.8	34	78.7	116	113	0	35	34
2015	12	30	17	6	20	0.135	-0.036	0.85	0.036	0.033	0	35.3	34	78.7	116	113	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	17	16	20	0.184	-0.043	0.85	0.039	0.039	0	35.3	34	78.7	116	113	0	34	34
2015	12	30	17	26	20	0.115	-0.056	0.85	0.043	0.039	0	34	34.4	79.1	114	113	0	35	33
2015	12	30	17	36	20	0.151	-0.164	0.85	0.039	0.036	0	35.3	34.4	79.1	116	114	0	34	34
2015	12	30	17	46	20	0.203	-0.069	0.85	0.033	0.03	0	34.8	34.4	79.1	116	114	0	35	34
2015	12	30	17	56	20	0.144	-0.108	0.85	0.036	0.033	0	35.3	34.8	78.3	117	114	0	35	33
2015	12	30	18	6	20	0.171	-0.085	0.85	0.039	0.036	0	34.8	34	78.7	116	113	0	35	34
2015	12	30	18	16	20	0.177	-0.069	0.85	0.036	0.033	0	35.3	34	79.1	117	113	0	35	34
2015	12	30	18	26	20	0.128	-0.056	0.85	0.039	0.036	0	34.4	33.5	79.1	115	112	0	35	34
2015	12	30	18	36	20	0.135	-0.066	0.85	0.039	0.039	0	34.4	33.5	79.1	115	112	0	35	34
2015	12	30	18	46	20	0.108	-0.036	0.85	0.039	0.036	0	34.4	33.5	78.7	114	111	0	34	33
2015	12	30	18	56	20	0.157	-0.098	0.85	0.039	0.039	0	34	32.7	79.6	114	110	0	35	34
2015	12	30	19	6	20	0.161	-0.112	0.85	0.033	0.03	0	34	32.7	79.1	114	111	0	35	35
2015	12	30	19	16	20	0.125	-0.062	0.85	0.039	0.039	0	33.5	32.3	79.6	113	109	0	35	34
2015	12	30	19	26	20	0.157	-0.131	0.85	0.039	0.039	0	33.1	32.3	79.1	112	109	0	35	34
2015	12	30	19	36	20	0.22	-0.03	0.85	0.033	0.03	0	33.1	31.8	79.1	112	108	0	35	34
2015	12	30	19	46	20	0.125	-0.082	0.85	0.039	0.036	0	33.5	32.3	78.7	112	108	0	34	33
2015	12	30	19	56	20	0.131	-0.157	0.85	0.043	0.043	0	34	31.4	79.1	113	107	0	34	34
2015	12	30	20	6	20	0.151	-0.131	0.85	0.036	0.033	0	34	33.1	79.6	114	111	0	35	34
2015	12	30	20	16	20	0.102	-0.095	0.85	0.039	0.036	0	34	32.7	78.7	114	110	0	35	34
2015	12	30	20	26	20	0.187	-0.059	0.85	0.036	0.033	0	33.1	31.8	79.6	112	108	0	35	34
2015	12	30	20	36	20	0.095	-0.082	0.85	0.039	0.036	0	33.5	31.4	79.1	112	107	0	34	34
2015	12	30	20	46	20	0.102	-0.102	0.85	0.039	0.036	0	33.1	31	79.6	111	106	0	34	34
2015	12	30	20	56	20	0.167	-0.141	0.85	0.039	0.036	0	32.7	31	78.7	110	106	0	34	34
2015	12	30	21	6	20	0.138	-0.056	0.85	0.033	0.03	0	31.8	31	78.3	109	106	0	35	34
2015	12	30	21	16	20	0.112	-0.069	0.85	0.036	0.033	0	32.3	31.8	79.1	110	107	0	35	33
2015	12	30	21	26	20	0.177	-0.016	0.85	0.039	0.036	0	32.3	31	78.3	109	106	0	34	34
2015	12	30	21	36	20	0.138	-0.02	0.85	0.039	0.036	0	32.7	31.8	78.7	110	108	0	34	34
2015	12	30	21	46	20	0.174	-0.079	0.85	0.039	0.036	0	33.1	31.8	78.7	111	108	0	34	34
2015	12	30	21	56	20	0.174	-0.095	0.85	0.033	0.03	0	32.3	31.8	79.1	110	107	0	35	33
2015	12	30	22	6	20	0.144	-0.112	0.85	0.039	0.036	0	32.7	31.8	78.7	111	108	0	35	34
2015	12	30	22	16	20	0.112	-0.023	0.85	0.039	0.036	0	33.5	32.3	78.7	112	108	0	34	33
2015	12	30	22	26	20	0.105	-0.072	0.85	0.033	0.03	0	33.5	32.3	78.7	112	109	0	34	34
2015	12	30	22	36	20	0.121	-0.089	0.85	0.039	0.039	0	33.1	32.3	77.4	111	109	0	34	34
2015	12	30	22	46	20	0.157	-0.056	0.85	0.039	0.036	0	33.1	31.8	78.3	111	108	0	34	34
2015	12	30	22	56	20	0.203	-0.105	0.85	0.039	0.036	0	33.1	32.3	77.4	112	109	0	35	34
2015	12	30	23	6	20	0.121	-0.059	0.85	0.039	0.036	0	33.5	32.7	77	112	110	0	34	34
2015	12	30	23	16	20	0.187	-0.049	0.85	0.039	0.036	0	33.5	32.7	76.5	112	110	0	34	34
2015	12	30	23	26	20	0.164	-0.059	0.85	0.033	0.03	0	34	34	75.3	114	113	0	35	34
2015	12	30	23	36	20	0.151	-0.154	0.85	0.043	0.039	0	33.5	34	77	113	112	0	35	33
2015	12	30	23	46	20	0.121	-0.069	0.85	0.033	0.03	0	34	33.5	77	113	112	0	34	34
2015	12	30	23	56	20	0.151	-0.026	0.85	0.036	0.033	0	34.4	34	77.8	114	113	0	34	34
2015	12	31	0	6	20	0.217	-0.135	0.85	0.036	0.033	0	34.4	34	76.1	115	113	0	35	34
2015	12	31	0	16	20	0.167	-0.046	0.85	0.039	0.039	0	34.4	34	76.1	115	113	0	35	34
2015	12	31	0	26	20	0.203	-0.013	0.85	0.036	0.033	0	34.4	34	76.5	115	113	0	35	34
2015	12	31	0	36	20	0.121	-0.062	0.85	0.039	0.039	0	34.4	34	77	114	113	0	34	34
2015	12	31	0	46	20	0.167	-0.062	0.85	0.046	0.043	0	34	33.1	77.4	114	111	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	0	56	20	0.121	-0.082	0.85	0.033	0.03	0	34.4	33.5	76.5	114	112	0	34	34
2015	12	31	1	6	20	0.148	-0.056	0.85	0.036	0.033	0	34	34	77	113	113	0	34	34
2015	12	31	1	16	20	0.148	-0.056	0.85	0.036	0.033	0	34	33.5	77	114	112	0	35	34
2015	12	31	1	26	20	0.184	-0.03	0.85	0.036	0.033	0	34	33.5	77	114	112	0	35	34
2015	12	31	1	36	20	0.154	-0.092	0.85	0.036	0.033	0	33.1	33.5	77	112	112	0	35	34
2015	12	31	1	46	20	0.167	-0.098	0.85	0.033	0.03	0	33.5	33.1	77	111	111	0	33	34
2015	12	31	1	56	20	0.079	-0.016	0.85	0.039	0.036	0	32.7	32.7	77	111	110	0	35	34
2015	12	31	2	6	20	0.148	-0.075	0.85	0.036	0.033	0	32.7	32.3	77.8	111	109	0	35	34
2015	12	31	2	16	20	0.19	-0.066	0.85	0.039	0.039	0	34.4	34	77.8	115	113	0	35	34
2015	12	31	2	26	20	0.164	-0.095	0.85	0.033	0.03	0	34	33.5	76.5	114	112	0	35	34
2015	12	31	2	36	20	0.121	-0.066	0.85	0.033	0.03	0	33.5	33.1	77	112	111	0	34	34
2015	12	31	2	46	20	0.144	-0.102	0.85	0.033	0.03	0	32.7	33.1	77.8	111	110	0	35	33
2015	12	31	2	56	20	0.21	-0.062	0.85	0.036	0.033	0	32.7	31.4	77.8	110	108	0	34	35
2015	12	31	3	6	20	0.151	-0.082	0.85	0.039	0.036	0	31.8	32.3	77	108	108	0	34	33
2015	12	31	3	16	20	0.098	-0.026	0.85	0.046	0.043	0	31.8	31.4	77.4	109	107	0	35	34
2015	12	31	3	26	20	0.213	-0.046	0.85	0.033	0.03	0	33.1	31.4	77.8	111	107	0	34	34
2015	12	31	3	36	20	0.131	-0.03	0.85	0.036	0.033	0	31.8	32.3	77.4	109	109	0	35	34
2015	12	31	3	46	20	0.167	-0.082	0.85	0.033	0.03	0	31.4	31	77.4	109	106	0	36	34
2015	12	31	3	56	20	0.079	-0.085	0.85	0.033	0.03	0	31.4	31.8	77.8	108	108	0	35	34
2015	12	31	4	6	20	0.174	-0.01	0.85	0.033	0.03	0	31.4	31.4	77.8	108	107	0	35	34
2015	12	31	4	16	20	0.187	-0.089	0.85	0.033	0.03	0	31.8	31.8	77.8	108	108	0	34	34
2015	12	31	4	26	20	0.161	-0.115	0.85	0.033	0.03	0	32.3	31	77.8	109	106	0	34	34
2015	12	31	4	36	20	0.174	-0.01	0.85	0.033	0.03	0	31	31.4	77.8	107	107	0	35	34
2015	12	31	4	46	20	0.2	-0.016	0.85	0.033	0.03	0	31.4	31	77.8	108	106	0	35	34
2015	12	31	4	56	20	0.131	-0.046	0.85	0.036	0.033	0	32.7	32.7	77.4	111	110	0	35	34
2015	12	31	5	6	20	0.187	-0.092	0.85	0.033	0.03	0	34	34	77.4	114	113	0	35	34
2015	12	31	5	16	20	0.131	-0.013	0.85	0.033	0.03	0	32.3	31.4	76.5	109	108	0	34	35
2015	12	31	5	26	20	0.118	-0.075	0.85	0.033	0.03	0	31.4	31.4	77.4	107	107	0	34	34
2015	12	31	5	36	20	0.141	-0.079	0.85	0.036	0.033	0	31	31.4	76.5	107	106	0	35	33
2015	12	31	5	46	20	0.128	-0.112	0.85	0.036	0.033	0	31.8	31	76.5	109	106	0	35	34
2015	12	31	5	56	20	0.171	-0.052	0.85	0.033	0.03	0	30.5	30.5	77.4	106	105	0	35	34
2015	12	31	6	6	20	0.24	-0.03	0.85	0.036	0.033	0	31.4	30.5	77.8	107	105	0	34	34
2015	12	31	6	16	20	0.157	-0.062	0.85	0.039	0.036	0	31.4	30.5	77.4	107	105	0	34	34
2015	12	31	6	26	20	0.18	-0.075	0.85	0.046	0.043	0	31.4	30.5	77	108	105	0	35	34
2015	12	31	6	36	20	0.154	-0.059	0.85	0.033	0.03	0	31.4	31	77.8	107	106	0	34	34
2015	12	31	6	46	20	0.112	-0.033	0.85	0.036	0.033	0	31	31	77.4	106	106	0	34	34
2015	12	31	6	56	20	0.151	-0.092	0.85	0.033	0.03	0	31.4	31	77.4	107	105	0	34	33
2015	12	31	7	6	20	0.19	-0.043	0.85	0.033	0.03	0	31.4	30.5	77.4	107	105	0	34	34
2015	12	31	7	16	20	0.157	-0.066	0.85	0.039	0.036	0	31	30.1	77.4	107	104	0	35	34
2015	12	31	7	26	20	0.177	-0.082	0.85	0.033	0.03	0	30.5	30.5	77.8	106	105	0	35	34
2015	12	31	7	36	20	0.154	-0.161	0.85	0.036	0.033	0	31	31	77	106	106	0	34	34
2015	12	31	7	46	20	0.187	-0.066	0.85	0.039	0.036	0	31	30.1	77.4	107	105	0	35	35
2015	12	31	7	56	20	0.125	-0.108	0.85	0.036	0.033	0	31.4	31.4	77	108	106	0	35	33
2015	12	31	8	6	20	0.207	-0.069	0.85	0.039	0.039	0	31.4	31	77	107	106	0	34	34
2015	12	31	8	16	20	0.148	-0.144	0.85	0.039	0.036	0	32.3	31	75.7	109	107	0	34	35
2015	12	31	8	26	20	0.131	-0.079	0.85	0.036	0.033	0	31.4	31.4	76.1	108	107	0	35	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	8	36	20	0.187	-0.02	0.85	0.039	0.036	0	31.8	31.4	75.7	109	107	0	35	34
2015	12	31	8	46	20	0.167	-0.02	0.85	0.043	0.039	0	31.8	31.4	76.1	109	107	0	35	34
2015	12	31	8	56	20	0.128	-0.049	0.85	0.039	0.039	0	32.7	32.7	75.3	111	110	0	35	34
2015	12	31	9	6	20	0.174	-0.092	0.85	0.036	0.033	0	32.7	33.5	74.4	111	112	0	35	34
2015	12	31	9	16	20	0.079	-0.105	0.85	0.049	0.046	0	34	34.4	74.8	114	114	0	35	34
2015	12	31	9	26	20	0.108	-0.082	0.85	0.036	0.033	0	33.5	34.4	77	113	113	0	35	33
2015	12	31	9	36	20	0.105	-0.059	0.846	0.039	0.039	0	34.8	34.4	74.8	116	114	0	35	34
2015	12	31	9	46	20	0.128	-0.095	0.846	0.036	0.033	0	36.5	36.1	75.3	119	118	0	34	34
2015	12	31	9	56	20	0.098	-0.01	0.85	0.036	0.033	0	34.8	33.5	76.1	115	112	0	34	34
2015	12	31	10	6	20	0.125	-0.052	0.846	0.039	0.039	0	35.7	34.8	76.5	117	115	0	34	34
2015	12	31	10	16	20	0.138	-0.102	0.85	0.036	0.033	0	36.1	35.3	76.5	118	116	0	34	34
2015	12	31	10	26	20	0.157	-0.052	0.85	0.039	0.036	0	35.3	35.3	77	117	116	0	35	34
2015	12	31	10	36	20	0.115	-0.062	0.846	0.039	0.036	0	35.7	36.1	76.1	118	118	0	35	34
2015	12	31	10	46	20	0.148	-0.112	0.846	0.043	0.039	0	37	37	75.7	121	120	0	35	34
2015	12	31	10	56	20	0.2	-0.079	0.846	0.033	0.03	0	37.4	37	76.1	122	120	0	35	34
2015	12	31	11	6	20	0.18	0	0.85	0.039	0.036	0	37.4	37	75.7	122	121	0	35	35
2015	12	31	11	16	20	0.141	-0.108	0.85	0.046	0.043	0	38.3	38.3	74.8	124	123	0	35	34
2015	12	31	11	26	20	0.128	-0.023	0.85	0.036	0.033	0	37.8	37.8	75.7	123	122	0	35	34
2015	12	31	11	36	20	0.135	-0.082	0.85	0.036	0.033	0	38.3	37	77	123	120	0	34	34
2015	12	31	11	46	20	0.207	-0.102	0.85	0.043	0.039	0	38.3	37.8	77	123	122	0	34	34
2015	12	31	11	56	20	0.105	-0.026	0.85	0.033	0.03	0	38.3	37	76.1	123	120	0	34	34
2015	12	31	12	6	20	0.184	-0.062	0.85	0.039	0.039	0	37.4	37.4	77.4	122	121	0	35	34
2015	12	31	12	16	20	0.157	-0.098	0.85	0.033	0.03	0	38.3	38.3	77	124	122	0	35	33
2015	12	31	12	26	20	0.157	-0.056	0.85	0.036	0.033	0	39.1	37.8	77.8	125	122	0	34	34
2015	12	31	12	36	20	0.18	-0.016	0.85	0.036	0.033	0	38.3	37.8	77.4	124	122	0	35	34
2015	12	31	12	46	20	0.177	-0.052	0.85	0.039	0.036	0	38.7	37.4	77.8	124	121	0	34	34
2015	12	31	12	56	20	0.157	-0.056	0.85	0.046	0.043	0	38.7	37.8	77.4	124	121	0	34	33
2015	12	31	13	6	20	0.105	-0.089	0.85	0.039	0.039	0	38.7	38.3	77.8	124	122	0	34	33
2015	12	31	13	16	20	0.174	-0.03	0.85	0.039	0.039	0	37.8	37	77.8	122	120	0	34	34
2015	12	31	13	26	20	0.213	-0.007	0.85	0.036	0.033	0	37.4	37.8	78.3	122	120	0	35	32
2015	12	31	13	36	20	0.167	-0.069	0.85	0.033	0.03	0	38.3	37	78.3	123	120	0	34	34
2015	12	31	13	46	20	0.157	0.013	0.85	0.039	0.036	0	37.8	37.4	77.8	123	120	0	35	33
2015	12	31	13	56	20	0.135	-0.007	0.85	0.036	0.033	0	38.3	36.5	78.7	123	119	0	34	34
2015	12	31	14	6	20	0.197	-0.092	0.85	0.033	0.03	0	38.7	37.4	77.8	124	121	0	34	34
2015	12	31	14	16	20	0.121	-0.092	0.85	0.036	0.033	0	44.3	42.6	74.4	137	133	0	34	34
2015	12	31	14	26	20	0.154	-0.066	0.85	0.039	0.036	0	46	45.2	73.1	142	138	0	35	33
2015	12	31	14	36	20	0.194	0.013	0.85	0.039	0.036	0	45.2	43.9	73.5	139	136	0	34	34
2015	12	31	14	46	20	0.157	0.02	0.85	0.039	0.039	0	46.4	46	72.2	142	140	0	34	33
2015	12	31	14	56	20	0.213	0.138	0.85	0.036	0.033	0	45.2	44.3	73.5	140	137	0	35	34
2015	12	31	15	6	20	0.187	0.118	0.85	0.039	0.039	0	46.4	44.3	73.1	142	137	0	34	34
2015	12	31	15	16	20	0.2	0.108	0.85	0.036	0.033	0	46.4	45.2	73.1	143	138	0	35	33
2015	12	31	15	26	20	0.121	0.026	0.85	0.039	0.036	0	46	44.7	72.7	141	138	0	34	34
2015	12	31	15	36	20	0.22	0.19	0.85	0.039	0.036	0	45.6	44.3	73.5	141	137	0	35	34
2015	12	31	15	46	20	0.164	0.174	0.85	0.039	0.036	0	44.7	43.9	73.1	138	136	0	34	34
2015	12	31	15	56	20	0.262	0.059	0.85	0.039	0.036	0	44.7	43.4	73.5	138	135	0	34	34
2015	12	31	16	6	20	0.125	0.036	0.85	0.036	0.033	0	44.3	43.4	73.1	137	134	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	16	16	20	0.141	0.03	0.85	0.039	0.036	0	43	42.1	74.8	134	131	0	34	33
2015	12	31	16	26	20	0.118	0.112	0.85	0.033	0.03	0	42.1	41.3	75.7	133	130	0	35	34
2015	12	31	16	36	20	0.167	0.013	0.85	0.039	0.036	0	41.7	40.4	75.7	131	128	0	34	34
2015	12	31	16	46	20	0.184	-0.062	0.85	0.039	0.036	0	41.3	40.9	75.7	131	128	0	35	33
2015	12	31	16	56	20	0.138	-0.01	0.85	0.039	0.036	0	42.1	40.9	75.7	132	129	0	34	34
2015	12	31	17	6	20	0.167	0.01	0.85	0.033	0.03	0	42.6	41.3	75.3	133	129	0	34	33
2015	12	31	17	16	20	0.069	0.075	0.85	0.033	0.03	0	41.7	40	76.1	131	127	0	34	34
2015	12	31	17	26	20	0.161	0.039	0.85	0.039	0.036	0	40.4	39.6	76.1	128	126	0	34	34
2015	12	31	17	36	20	0.075	-0.023	0.85	0.039	0.036	0	39.6	39.1	76.5	126	124	0	34	33
2015	12	31	17	46	20	0.141	0.036	0.85	0.033	0.03	0	39.1	38.7	77	125	124	0	34	34
2015	12	31	17	56	20	0.184	0.046	0.846	0.036	0.033	0	40.4	40.4	75.3	128	128	0	34	34
2015	12	31	18	6	20	0.144	0.092	0.846	0.036	0.033	0	40	39.6	76.1	128	126	0	35	34
2015	12	31	18	16	20	0.095	-0.03	0.85	0.036	0.033	0	39.1	39.6	76.1	126	125	0	35	33
2015	12	31	18	26	20	0.105	0.098	0.85	0.039	0.039	0	38.7	38.3	77	124	123	0	34	34
2015	12	31	18	36	20	0.177	0	0.85	0.033	0.03	0	37.8	37.4	77.4	123	121	0	35	34
2015	12	31	18	46	20	0.112	0.049	0.85	0.036	0.033	0	37.8	37	76.5	122	120	0	34	34
2015	12	31	18	56	20	0.223	-0.016	0.85	0.036	0.033	0	37	37.4	77.4	120	120	0	34	33
2015	12	31	19	6	20	0.121	-0.043	0.85	0.033	0.03	0	37.4	36.5	77.8	122	119	0	35	34
2015	12	31	19	16	20	0.121	0.026	0.85	0.033	0.03	0	36.5	36.5	77.4	120	119	0	35	34
2015	12	31	19	26	20	0.249	-0.016	0.85	0.036	0.033	0	36.5	35.7	77.8	119	117	0	34	34
2015	12	31	19	36	20	0.141	-0.003	0.85	0.036	0.033	0	36.1	35.7	77.8	118	117	0	34	34
2015	12	31	19	46	20	0.174	-0.003	0.85	0.033	0.03	0	35.3	35.3	78.3	117	115	0	35	33
2015	12	31	19	56	20	0.135	-0.056	0.85	0.033	0.03	0	34.8	34.8	78.3	116	115	0	35	34
2015	12	31	20	6	20	0.098	0.01	0.85	0.036	0.033	0	34.8	34.8	77.8	115	114	0	34	33
2015	12	31	20	16	20	0.164	0.013	0.85	0.039	0.036	0	34.8	34.8	78.3	116	114	0	35	33
2015	12	31	20	26	20	0.125	-0.072	0.85	0.033	0.03	0	34	34	78.7	114	113	0	35	34
2015	12	31	20	36	20	0.207	-0.003	0.85	0.033	0.03	0	33.5	34	78.7	113	113	0	35	34
2015	12	31	20	46	20	0.128	-0.075	0.85	0.033	0.03	0	33.5	32.7	78.7	112	110	0	34	34
2015	12	31	20	56	20	0.125	-0.089	0.85	0.033	0.03	0	33.5	32.3	78.3	112	109	0	34	34
2015	12	31	21	6	20	0.105	-0.056	0.85	0.033	0.03	0	33.1	32.7	79.1	111	110	0	34	34
2015	12	31	21	16	20	0.141	0.003	0.85	0.033	0.03	0	33.1	32.3	78.7	111	109	0	34	34
2015	12	31	21	26	20	0.105	-0.03	0.85	0.033	0.03	0	32.7	32.3	78.7	110	108	0	34	33
2015	12	31	21	36	20	0.164	-0.092	0.85	0.036	0.033	0	32.3	32.3	78.7	109	108	0	34	33
2015	12	31	21	46	20	0.171	-0.023	0.85	0.039	0.039	0	31.8	31.4	78.7	109	107	0	35	34
2015	12	31	21	56	20	0.131	-0.089	0.85	0.033	0.03	0	32.3	32.3	79.1	110	109	0	35	34
2015	12	31	22	6	20	0.095	-0.043	0.85	0.033	0.03	0	32.7	32.3	78.7	110	108	0	34	33
2015	12	31	22	16	20	0.144	-0.043	0.85	0.039	0.036	0	33.1	32.3	78.7	111	109	0	34	34
2015	12	31	22	26	20	0.177	-0.079	0.85	0.033	0.03	0	32.3	32.3	78.3	109	108	0	34	33
2015	12	31	22	36	20	0.18	-0.043	0.85	0.033	0.03	0	32.7	32.3	79.1	110	108	0	34	33
2015	12	31	22	46	20	0.108	-0.026	0.85	0.039	0.036	0	32.7	31.4	79.1	110	107	0	34	34
2015	12	31	22	56	20	0.187	-0.121	0.85	0.036	0.033	0	32.3	31.4	79.1	109	107	0	34	34
2015	12	31	23	6	20	0.151	-0.161	0.85	0.033	0.03	0	32.7	32.3	79.1	111	109	0	35	34
2015	12	31	23	16	20	0.154	-0.121	0.85	0.046	0.043	0	32.3	31	78.7	109	106	0	34	34
2015	12	31	23	26	20	0.108	-0.069	0.85	0.033	0.03	0	31.4	30.5	79.6	108	105	0	35	34
2015	12	31	23	36	20	0.105	-0.003	0.85	0.039	0.039	0	33.5	33.1	78.7	112	111	0	34	34
2015	12	31	23	46	20	0.095	-0.095	0.85	0.033	0.03	0	32.7	31	79.1	110	106	0	34	34

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	23	56	20	0.108	-0.01	0.85	0.036	0.033	0	32.7	31.4	79.6	110	106	0	34	33

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	0	5	10	35	0	0	0	0	0	0	0	36.82	0	0	11.8
2015	12	1	0	15	10	35	0	0	0	0	0	0	0	36.72	0	0	11.8
2015	12	1	0	25	10	35	0	0	0	0	0	0	0	36.61	0	0	11.8
2015	12	1	0	35	10	35	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	1	0	45	10	36	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	1	0	55	10	35	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	1	1	5	10	36	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	1	1	15	10	36	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	1	1	25	10	36	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	1	1	35	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	1	1	45	10	35	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	1	1	55	10	36	0	0	0	0	0	0	0	35.69	0	0	11.8
2015	12	1	2	5	10	36	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	1	2	15	10	35	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	1	2	25	10	35	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	1	2	35	10	35	0	0	0	0	0	0	0	35.31	0	0	11.8
2015	12	1	2	45	10	35	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	1	2	55	10	36	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	1	3	5	10	36	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	1	3	15	10	36	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	1	3	25	10	35	0	0	0	0	0	0	0	34.92	0	0	11.8
2015	12	1	3	35	10	35	0	0	0	0	0	0	0	34.84	0	0	11.8
2015	12	1	3	45	10	36	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	1	3	55	10	36	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	1	4	5	10	36	0	0	0	0	0	0	0	34.65	0	0	11.8
2015	12	1	4	15	10	35	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	1	4	25	10	36	0	0	0	0	0	0	0	34.52	0	0	11.6
2015	12	1	4	35	10	35	0	0	0	0	0	0	0	34.47	0	0	11.6
2015	12	1	4	45	10	36	0	0	0	0	0	0	0	34.39	0	0	11.6
2015	12	1	4	55	10	36	0	0	0	0	0	0	0	34.34	0	0	11.6
2015	12	1	5	5	10	35	0	0	0	0	0	0	0	34.29	0	0	11.6
2015	12	1	5	15	10	36	0	0	0	0	0	0	0	34.23	0	0	11.6
2015	12	1	5	25	10	35	0	0	0	0	0	0	0	34.18	0	0	11.6
2015	12	1	5	35	10	35	0	0	0	0	0	0	0	34.14	0	0	11.6
2015	12	1	5	45	10	36	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	1	5	55	10	36	0	0	0	0	0	0	0	34.03	0	0	11.6
2015	12	1	6	5	10	36	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	1	6	15	10	35	0	0	0	0	0	0	0	33.93	0	0	11.6
2015	12	1	6	25	10	36	0	0	0	0	0	0	0	33.89	0	0	11.6
2015	12	1	6	35	10	35	0	0	0	0	0	0	0	33.84	0	0	11.6
2015	12	1	6	45	10	35	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	1	6	55	10	36	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	1	7	5	10	35	0	0	0	0	0	0	0	33.75	0	0	11.6
2015	12	1	7	15	10	36	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	1	7	25	10	35	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	1	7	35	10	36	0	0	0	0	0	0	0	33.69	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	7	45	10	36	0	0	0	0	0	0	0	33.67	0	0	12.8
2015	12	1	7	55	10	36	0	0	0	0	0	0	0	33.67	0	0	13.2
2015	12	1	8	5	10	36	0	0	0	0	0	0	0	33.67	0	0	13.4
2015	12	1	8	15	10	36	0	0	0	0	0	0	0	33.66	0	0	13.4
2015	12	1	8	25	10	36	0	0	0	0	0	0	0	33.66	0	0	13.4
2015	12	1	8	35	10	35	0	0	0	0	0	0	0	33.66	0	0	13.4
2015	12	1	8	45	10	36	0	0	0	0	0	0	0	33.64	0	0	13.4
2015	12	1	8	55	10	36	0	0	0	0	0	0	0	33.66	0	0	13.6
2015	12	1	9	5	10	36	0	0	0	0	0	0	0	33.67	0	0	13.6
2015	12	1	9	15	10	36	0	0	0	0	0	0	0	33.71	0	0	13.6
2015	12	1	9	25	10	36	0	0	0	0	0	0	0	33.73	0	0	13.6
2015	12	1	9	35	10	36	0	0	0	0	0	0	0	33.78	0	0	13.6
2015	12	1	9	45	10	35	0	0	0	0	0	0	0	33.84	0	0	13.6
2015	12	1	9	55	10	35	0	0	0	0	0	0	0	33.89	0	0	13.6
2015	12	1	10	5	10	36	0	0	0	0	0	0	0	33.98	0	0	13.4
2015	12	1	10	15	10	36	0	0	0	0	0	0	0	34.07	0	0	13.4
2015	12	1	10	25	10	36	0	0	0	0	0	0	0	34.16	0	0	13.4
2015	12	1	10	35	10	35	0	0	0	0	0	0	0	34.48	0	0	13.6
2015	12	1	10	45	10	35	0	0	0	0	0	0	0	34.81	0	0	13.6
2015	12	1	10	55	10	35	0	0	0	0	0	0	0	35.01	0	0	13.6
2015	12	1	11	5	10	36	0	0	0	0	0	0	0	35.11	0	0	13.6
2015	12	1	11	15	10	36	0	0	0	0	0	0	0	35.29	0	0	13.6
2015	12	1	11	25	10	36	0	0	0	0	0	0	0	35.42	0	0	13.6
2015	12	1	11	35	10	36	0	0	0	0	0	0	0	35.6	0	0	13.6
2015	12	1	11	45	10	36	0	0	0	0	0	0	0	35.71	0	0	13.6
2015	12	1	11	55	10	35	0	0	0	0	0	0	0	35.87	0	0	13.6
2015	12	1	12	5	10	35	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	1	12	15	10	35	0	0	0	0	0	0	0	36.16	0	0	13.4
2015	12	1	12	25	10	35	0	0	0	0	0	0	0	36.3	0	0	13.6
2015	12	1	12	35	10	36	0	0	0	0	0	0	0	36.54	0	0	13.6
2015	12	1	12	45	10	35	0	0	0	0	0	0	0	36.68	0	0	13.6
2015	12	1	12	55	10	35	0	0	0	0	0	0	0	36.9	0	0	13.6
2015	12	1	13	5	10	35	0	0	0	0	0	0	0	37.06	0	0	13.6
2015	12	1	13	15	10	35	0	0	0	0	0	0	0	37.24	0	0	13.6
2015	12	1	13	25	10	35	0	0	0	0	0	0	0	37.42	0	0	13.6
2015	12	1	13	35	10	36	0	0	0	0	0	0	0	37.62	0	0	13.6
2015	12	1	13	45	10	36	0	0	0	0	0	0	0	37.76	0	0	13.6
2015	12	1	13	55	10	36	0	0	0	0	0	0	0	37.92	0	0	13.6
2015	12	1	14	5	10	35	0	0	0	0	0	0	0	38.08	0	0	13.4
2015	12	1	14	15	10	35	0	0	0	0	0	0	0	38.25	0	0	13.4
2015	12	1	14	25	10	35	0	0	0	0	0	0	0	38.43	0	0	13.2
2015	12	1	14	35	10	35	0	0	0	0	0	0	0	38.57	0	0	13
2015	12	1	14	45	10	35	0	0	0	0	0	0	0	38.7	0	0	12.8
2015	12	1	14	55	10	35	0	0	0	0	0	0	0	38.82	0	0	12.8
2015	12	1	15	5	10	35	0	0	0	0	0	0	0	38.93	0	0	12.6
2015	12	1	15	15	10	35	0	0	0	0	0	0	0	39.04	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	15	25	10	35	0	0	0	0	0	0	0	39.13	0	0	12.4
2015	12	1	15	35	10	35	0	0	0	0	0	0	0	39.2	0	0	12.4
2015	12	1	15	45	10	35	0	0	0	0	0	0	0	39.25	0	0	12.2
2015	12	1	15	55	10	35	0	0	0	0	0	0	0	39.31	0	0	12.2
2015	12	1	16	5	10	35	0	0	0	0	0	0	0	39.36	0	0	12.2
2015	12	1	16	15	10	35	0	0	0	0	0	0	0	39.4	0	0	12.2
2015	12	1	16	25	10	35	0	0	0	0	0	0	0	39.45	0	0	12.2
2015	12	1	16	35	10	35	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	1	16	45	10	35	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	1	16	55	10	35	0	0	0	0	0	0	0	39.54	0	0	12
2015	12	1	17	5	10	35	0	0	0	0	0	0	0	39.56	0	0	12
2015	12	1	17	15	10	34	0	0	0	0	0	0	0	39.58	0	0	12
2015	12	1	17	25	10	35	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	1	17	35	10	35	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	1	17	45	10	35	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	1	17	55	10	35	0	0	0	0	0	0	0	39.65	0	0	12
2015	12	1	18	5	10	35	0	0	0	0	0	0	0	39.65	0	0	12
2015	12	1	18	15	10	35	0	0	0	0	0	0	0	39.67	0	0	12
2015	12	1	18	25	10	35	0	0	0	0	0	0	0	39.69	0	0	12
2015	12	1	18	35	10	35	0	0	0	0	0	0	0	39.69	0	0	12
2015	12	1	18	45	10	35	0	0	0	0	0	0	0	39.7	0	0	12
2015	12	1	18	55	10	35	0	0	0	0	0	0	0	39.72	0	0	12
2015	12	1	19	5	10	35	0	0	0	0	0	0	0	39.72	0	0	12
2015	12	1	19	15	10	36	0	0	0	0	0	0	0	39.72	0	0	12
2015	12	1	19	25	10	34	0	0	0	0	0	0	0	39.72	0	0	12
2015	12	1	19	35	10	35	0	0	0	0	0	0	0	39.7	0	0	12
2015	12	1	19	45	10	35	0	0	0	0	0	0	0	39.69	0	0	12
2015	12	1	19	55	10	35	0	0	0	0	0	0	0	39.65	0	0	12
2015	12	1	20	5	10	35	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	1	20	15	10	35	0	0	0	0	0	0	0	39.56	0	0	12
2015	12	1	20	25	10	35	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	1	20	35	10	35	0	0	0	0	0	0	0	39.45	0	0	12
2015	12	1	20	45	10	35	0	0	0	0	0	0	0	39.38	0	0	12
2015	12	1	20	55	10	35	0	0	0	0	0	0	0	39.33	0	0	12
2015	12	1	21	5	10	35	0	0	0	0	0	0	0	39.25	0	0	12
2015	12	1	21	15	10	36	0	0	0	0	0	0	0	39.18	0	0	12
2015	12	1	21	25	10	35	0	0	0	0	0	0	0	39.11	0	0	11.8
2015	12	1	21	35	10	35	0	0	0	0	0	0	0	39.04	0	0	11.8
2015	12	1	21	45	10	35	0	0	0	0	0	0	0	38.97	0	0	11.8
2015	12	1	21	55	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	1	22	5	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	1	22	15	10	35	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	1	22	25	10	35	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	1	22	35	10	35	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	1	22	45	10	35	0	0	0	0	0	0	0	38.46	0	0	11.8
2015	12	1	22	55	10	35	0	0	0	0	0	0	0	38.35	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	23	5	10	35	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	1	23	15	10	35	0	0	0	0	0	0	0	38.16	0	0	11.8
2015	12	1	23	25	10	36	0	0	0	0	0	0	0	38.07	0	0	11.8
2015	12	1	23	35	10	35	0	0	0	0	0	0	0	37.98	0	0	11.8
2015	12	1	23	45	10	35	0	0	0	0	0	0	0	37.87	0	0	11.8
2015	12	1	23	55	10	35	0	0	0	0	0	0	0	37.78	0	0	11.8
2015	12	2	0	5	10	35	0	0	0	0	0	0	0	37.67	0	0	11.8
2015	12	2	0	15	10	35	0	0	0	0	0	0	0	37.58	0	0	11.8
2015	12	2	0	25	10	34	0	0	0	0	0	0	0	37.47	0	0	11.8
2015	12	2	0	35	10	35	0	0	0	0	0	0	0	37.38	0	0	11.8
2015	12	2	0	45	10	35	0	0	0	0	0	0	0	37.27	0	0	11.8
2015	12	2	0	55	10	35	0	0	0	0	0	0	0	37.18	0	0	11.8
2015	12	2	1	5	10	35	0	0	0	0	0	0	0	37.09	0	0	11.8
2015	12	2	1	15	10	36	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	2	1	25	10	35	0	0	0	0	0	0	0	36.88	0	0	11.8
2015	12	2	1	35	10	35	0	0	0	0	0	0	0	36.79	0	0	11.8
2015	12	2	1	45	10	34	0	0	0	0	0	0	0	36.7	0	0	11.8
2015	12	2	1	55	10	35	0	0	0	0	0	0	0	36.61	0	0	11.8
2015	12	2	2	5	10	35	0	0	0	0	0	0	0	36.52	0	0	11.8
2015	12	2	2	15	10	35	0	0	0	0	0	0	0	36.43	0	0	11.8
2015	12	2	2	25	10	35	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	2	2	35	10	35	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	2	2	45	10	35	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	2	2	55	10	36	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	2	3	5	10	35	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	2	3	15	10	36	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	2	3	25	10	35	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	2	3	35	10	35	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	2	3	45	10	35	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	2	3	55	10	36	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	2	4	5	10	35	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	2	4	15	10	35	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	2	4	25	10	35	0	0	0	0	0	0	0	35.56	0	0	11.8
2015	12	2	4	35	10	36	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	2	4	45	10	35	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	2	4	55	10	34	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	2	5	5	10	35	0	0	0	0	0	0	0	35.35	0	0	11.6
2015	12	2	5	15	10	35	0	0	0	0	0	0	0	35.29	0	0	11.6
2015	12	2	5	25	10	35	0	0	0	0	0	0	0	35.26	0	0	11.6
2015	12	2	5	35	10	36	0	0	0	0	0	0	0	35.22	0	0	11.6
2015	12	2	5	45	10	36	0	0	0	0	0	0	0	35.19	0	0	11.6
2015	12	2	5	55	10	36	0	0	0	0	0	0	0	35.13	0	0	11.6
2015	12	2	6	5	10	35	0	0	0	0	0	0	0	35.1	0	0	11.6
2015	12	2	6	15	10	36	0	0	0	0	0	0	0	35.06	0	0	11.6
2015	12	2	6	25	10	36	0	0	0	0	0	0	0	35.02	0	0	11.6
2015	12	2	6	35	10	36	0	0	0	0	0	0	0	34.99	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	6	45	10	35	0	0	0	0	0	0	0	34.97	0	0	11.6
2015	12	2	6	55	10	36	0	0	0	0	0	0	0	34.95	0	0	11.6
2015	12	2	7	5	10	35	0	0	0	0	0	0	0	34.92	0	0	11.6
2015	12	2	7	15	10	35	0	0	0	0	0	0	0	34.92	0	0	11.6
2015	12	2	7	25	10	35	0	0	0	0	0	0	0	34.9	0	0	11.6
2015	12	2	7	35	10	35	0	0	0	0	0	0	0	34.9	0	0	12.4
2015	12	2	7	45	10	36	0	0	0	0	0	0	0	34.9	0	0	12.8
2015	12	2	7	55	10	36	0	0	0	0	0	0	0	34.88	0	0	13.2
2015	12	2	8	5	10	35	0	0	0	0	0	0	0	34.88	0	0	13
2015	12	2	8	15	10	35	0	0	0	0	0	0	0	34.88	0	0	13.2
2015	12	2	8	25	10	35	0	0	0	0	0	0	0	34.88	0	0	13.4
2015	12	2	8	35	10	35	0	0	0	0	0	0	0	34.88	0	0	13.4
2015	12	2	8	45	10	36	0	0	0	0	0	0	0	34.92	0	0	13.4
2015	12	2	8	55	10	35	0	0	0	0	0	0	0	34.93	0	0	13.4
2015	12	2	9	5	10	35	0	0	0	0	0	0	0	34.97	0	0	13.6
2015	12	2	9	15	10	36	0	0	0	0	0	0	0	35.02	0	0	13.6
2015	12	2	9	25	10	36	0	0	0	0	0	0	0	35.06	0	0	13.6
2015	12	2	9	35	10	35	0	0	0	0	0	0	0	35.13	0	0	13.6
2015	12	2	9	45	10	36	0	0	0	0	0	0	0	35.24	0	0	13.8
2015	12	2	9	55	10	36	0	0	0	0	0	0	0	35.47	0	0	13.6
2015	12	2	10	5	10	36	0	0	0	0	0	0	0	35.55	0	0	13.4
2015	12	2	10	15	10	36	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	2	10	25	10	36	0	0	0	0	0	0	0	35.74	0	0	13.8
2015	12	2	10	35	10	36	0	0	0	0	0	0	0	36.05	0	0	13.8
2015	12	2	10	45	10	36	0	0	0	0	0	0	0	36.36	0	0	13.8
2015	12	2	10	55	10	36	0	0	0	0	0	0	0	36.45	0	0	13.2
2015	12	2	11	5	10	36	0	0	0	0	0	0	0	36.64	0	0	13.2
2015	12	2	11	15	10	35	0	0	0	0	0	0	0	36.99	0	0	13.8
2015	12	2	11	25	10	35	0	0	0	0	0	0	0	36.99	0	0	13.2
2015	12	2	11	35	10	35	0	0	0	0	0	0	0	37.26	0	0	13.8
2015	12	2	11	45	10	35	0	0	0	0	0	0	0	37.4	0	0	13.4
2015	12	2	11	55	10	35	0	0	0	0	0	0	0	37.44	0	0	13
2015	12	2	12	5	10	35	0	0	0	0	0	0	0	37.65	0	0	13.6
2015	12	2	12	15	10	35	0	0	0	0	0	0	0	37.83	0	0	13.6
2015	12	2	12	25	10	36	0	0	0	0	0	0	0	38.01	0	0	13.6
2015	12	2	12	35	10	35	0	0	0	0	0	0	0	38.17	0	0	13.2
2015	12	2	12	45	10	35	0	0	0	0	0	0	0	38.32	0	0	13
2015	12	2	12	55	10	35	0	0	0	0	0	0	0	38.46	0	0	13
2015	12	2	13	5	10	35	0	0	0	0	0	0	0	38.62	0	0	13.2
2015	12	2	13	15	10	35	0	0	0	0	0	0	0	38.73	0	0	13.2
2015	12	2	13	25	10	35	0	0	0	0	0	0	0	38.79	0	0	12.8
2015	12	2	13	35	10	35	0	0	0	0	0	0	0	38.89	0	0	12.6
2015	12	2	13	45	10	35	0	0	0	0	0	0	0	39.02	0	0	12.6
2015	12	2	13	55	10	35	0	0	0	0	0	0	0	39.15	0	0	12.4
2015	12	2	14	5	10	35	0	0	0	0	0	0	0	39.27	0	0	12.4
2015	12	2	14	15	10	35	0	0	0	0	0	0	0	39.36	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	14	25	10	35	0	0	0	0	0	0	0	39.51	0	0	12.6
2015	12	2	14	35	10	35	0	0	0	0	0	0	0	39.56	0	0	12.4
2015	12	2	14	45	10	35	0	0	0	0	0	0	0	39.63	0	0	12.4
2015	12	2	14	55	10	35	0	0	0	0	0	0	0	39.7	0	0	12.4
2015	12	2	15	5	10	35	0	0	0	0	0	0	0	39.79	0	0	12.4
2015	12	2	15	15	10	35	0	0	0	0	0	0	0	39.83	0	0	12.2
2015	12	2	15	25	10	35	0	0	0	0	0	0	0	39.88	0	0	12.4
2015	12	2	15	35	10	35	0	0	0	0	0	0	0	39.96	0	0	12.4
2015	12	2	15	45	10	35	0	0	0	0	0	0	0	40.01	0	0	12.2
2015	12	2	15	55	10	35	0	0	0	0	0	0	0	40.08	0	0	12.2
2015	12	2	16	5	10	35	0	0	0	0	0	0	0	40.1	0	0	12.2
2015	12	2	16	15	10	35	0	0	0	0	0	0	0	40.14	0	0	12.2
2015	12	2	16	25	10	35	0	0	0	0	0	0	0	40.15	0	0	12
2015	12	2	16	35	10	35	0	0	0	0	0	0	0	40.21	0	0	12
2015	12	2	16	45	10	35	0	0	0	0	0	0	0	40.21	0	0	12
2015	12	2	16	55	10	35	0	0	0	0	0	0	0	40.23	0	0	12
2015	12	2	17	5	10	35	0	0	0	0	0	0	0	40.24	0	0	12
2015	12	2	17	15	10	35	0	0	0	0	0	0	0	40.26	0	0	12
2015	12	2	17	25	10	35	0	0	0	0	0	0	0	40.28	0	0	12
2015	12	2	17	35	10	36	0	0	0	0	0	0	0	40.32	0	0	12
2015	12	2	17	45	10	35	0	0	0	0	0	0	0	40.32	0	0	12
2015	12	2	17	55	10	35	0	0	0	0	0	0	0	40.33	0	0	12
2015	12	2	18	5	10	35	0	0	0	0	0	0	0	40.35	0	0	12
2015	12	2	18	15	10	35	0	0	0	0	0	0	0	40.37	0	0	12
2015	12	2	18	25	10	34	0	0	0	0	0	0	0	40.39	0	0	12
2015	12	2	18	35	10	35	0	0	0	0	0	0	0	40.42	0	0	12
2015	12	2	18	45	10	35	0	0	0	0	0	0	0	40.44	0	0	12
2015	12	2	18	55	10	35	0	0	0	0	0	0	0	40.46	0	0	12
2015	12	2	19	5	10	35	0	0	0	0	0	0	0	40.5	0	0	12
2015	12	2	19	15	10	35	0	0	0	0	0	0	0	40.51	0	0	12
2015	12	2	19	25	10	35	0	0	0	0	0	0	0	40.51	0	0	12
2015	12	2	19	35	10	35	0	0	0	0	0	0	0	40.5	0	0	12
2015	12	2	19	45	10	35	0	0	0	0	0	0	0	40.5	0	0	12
2015	12	2	19	55	10	35	0	0	0	0	0	0	0	40.5	0	0	12
2015	12	2	20	5	10	35	0	0	0	0	0	0	0	40.46	0	0	12
2015	12	2	20	15	10	35	0	0	0	0	0	0	0	40.42	0	0	12
2015	12	2	20	25	10	34	0	0	0	0	0	0	0	40.41	0	0	12
2015	12	2	20	35	10	36	0	0	0	0	0	0	0	40.35	0	0	12
2015	12	2	20	45	10	35	0	0	0	0	0	0	0	40.3	0	0	12
2015	12	2	20	55	10	35	0	0	0	0	0	0	0	40.26	0	0	12
2015	12	2	21	5	10	35	0	0	0	0	0	0	0	40.19	0	0	12
2015	12	2	21	15	10	35	0	0	0	0	0	0	0	40.14	0	0	11.8
2015	12	2	21	25	10	35	0	0	0	0	0	0	0	40.06	0	0	11.8
2015	12	2	21	35	10	35	0	0	0	0	0	0	0	39.99	0	0	11.8
2015	12	2	21	45	10	35	0	0	0	0	0	0	0	39.94	0	0	11.8
2015	12	2	21	55	10	35	0	0	0	0	0	0	0	39.85	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	22	5	10	35	0	0	0	0	0	0	0	39.76	0	0	11.8
2015	12	2	22	15	10	35	0	0	0	0	0	0	0	39.69	0	0	11.8
2015	12	2	22	25	10	35	0	0	0	0	0	0	0	39.61	0	0	11.8
2015	12	2	22	35	10	35	0	0	0	0	0	0	0	39.52	0	0	11.8
2015	12	2	22	45	10	36	0	0	0	0	0	0	0	39.43	0	0	11.8
2015	12	2	22	55	10	35	0	0	0	0	0	0	0	39.36	0	0	11.8
2015	12	2	23	5	10	35	0	0	0	0	0	0	0	39.27	0	0	11.8
2015	12	2	23	15	10	35	0	0	0	0	0	0	0	39.18	0	0	11.8
2015	12	2	23	25	10	36	0	0	0	0	0	0	0	39.11	0	0	11.8
2015	12	2	23	35	10	35	0	0	0	0	0	0	0	39.02	0	0	11.8
2015	12	2	23	45	10	34	0	0	0	0	0	0	0	38.95	0	0	11.8
2015	12	2	23	55	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	3	0	5	10	35	0	0	0	0	0	0	0	38.79	0	0	11.8
2015	12	3	0	15	10	35	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	3	0	25	10	34	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	3	0	35	10	35	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	3	0	45	10	35	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	3	0	55	10	35	0	0	0	0	0	0	0	38.41	0	0	11.8
2015	12	3	1	5	10	36	0	0	0	0	0	0	0	38.32	0	0	11.8
2015	12	3	1	15	10	35	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	3	1	25	10	35	0	0	0	0	0	0	0	38.17	0	0	11.8
2015	12	3	1	35	10	36	0	0	0	0	0	0	0	38.1	0	0	11.8
2015	12	3	1	45	10	35	0	0	0	0	0	0	0	38.03	0	0	11.8
2015	12	3	1	55	10	35	0	0	0	0	0	0	0	37.96	0	0	11.8
2015	12	3	2	5	10	35	0	0	0	0	0	0	0	37.89	0	0	11.8
2015	12	3	2	15	10	35	0	0	0	0	0	0	0	37.81	0	0	11.8
2015	12	3	2	25	10	36	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	3	2	35	10	35	0	0	0	0	0	0	0	37.67	0	0	11.8
2015	12	3	2	45	10	36	0	0	0	0	0	0	0	37.6	0	0	11.8
2015	12	3	2	55	10	36	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	3	3	5	10	35	0	0	0	0	0	0	0	37.47	0	0	11.8
2015	12	3	3	15	10	35	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	3	3	25	10	35	0	0	0	0	0	0	0	37.35	0	0	11.8
2015	12	3	3	35	10	35	0	0	0	0	0	0	0	37.29	0	0	11.6
2015	12	3	3	45	10	35	0	0	0	0	0	0	0	37.22	0	0	11.6
2015	12	3	3	55	10	35	0	0	0	0	0	0	0	37.17	0	0	11.6
2015	12	3	4	5	10	35	0	0	0	0	0	0	0	37.09	0	0	11.6
2015	12	3	4	15	10	35	0	0	0	0	0	0	0	37.04	0	0	11.6
2015	12	3	4	25	10	35	0	0	0	0	0	0	0	36.99	0	0	11.6
2015	12	3	4	35	10	35	0	0	0	0	0	0	0	36.93	0	0	11.6
2015	12	3	4	45	10	36	0	0	0	0	0	0	0	36.88	0	0	11.6
2015	12	3	4	55	10	35	0	0	0	0	0	0	0	36.81	0	0	11.6
2015	12	3	5	5	10	35	0	0	0	0	0	0	0	36.75	0	0	11.6
2015	12	3	5	15	10	35	0	0	0	0	0	0	0	36.7	0	0	11.6
2015	12	3	5	25	10	35	0	0	0	0	0	0	0	36.64	0	0	11.6
2015	12	3	5	35	10	35	0	0	0	0	0	0	0	36.59	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	5	45	10	35	0	0	0	0	0	0	0	36.55	0	0	11.6
2015	12	3	5	55	10	36	0	0	0	0	0	0	0	36.5	0	0	11.6
2015	12	3	6	5	10	35	0	0	0	0	0	0	0	36.43	0	0	11.6
2015	12	3	6	15	10	35	0	0	0	0	0	0	0	36.39	0	0	11.6
2015	12	3	6	25	10	35	0	0	0	0	0	0	0	36.36	0	0	11.6
2015	12	3	6	35	10	36	0	0	0	0	0	0	0	36.3	0	0	11.6
2015	12	3	6	45	10	36	0	0	0	0	0	0	0	36.25	0	0	11.6
2015	12	3	6	55	10	35	0	0	0	0	0	0	0	36.23	0	0	11.6
2015	12	3	7	5	10	35	0	0	0	0	0	0	0	36.19	0	0	11.6
2015	12	3	7	15	10	35	0	0	0	0	0	0	0	36.14	0	0	11.6
2015	12	3	7	25	10	36	0	0	0	0	0	0	0	36.14	0	0	11.6
2015	12	3	7	35	10	36	0	0	0	0	0	0	0	36.12	0	0	12.2
2015	12	3	7	45	10	36	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	3	7	55	10	35	0	0	0	0	0	0	0	36.07	0	0	12.4
2015	12	3	8	5	10	36	0	0	0	0	0	0	0	36.05	0	0	12.6
2015	12	3	8	15	10	35	0	0	0	0	0	0	0	36.07	0	0	12.6
2015	12	3	8	25	10	35	0	0	0	0	0	0	0	36.07	0	0	13
2015	12	3	8	35	10	35	0	0	0	0	0	0	0	36.03	0	0	13
2015	12	3	8	45	10	36	0	0	0	0	0	0	0	36.05	0	0	13.4
2015	12	3	8	55	10	36	0	0	0	0	0	0	0	36.07	0	0	13.2
2015	12	3	9	5	10	35	0	0	0	0	0	0	0	36.1	0	0	13.4
2015	12	3	9	15	10	35	0	0	0	0	0	0	0	36.14	0	0	13.4
2015	12	3	9	25	10	36	0	0	0	0	0	0	0	36.19	0	0	13.2
2015	12	3	9	35	10	36	0	0	0	0	0	0	0	36.21	0	0	13.2
2015	12	3	9	45	10	35	0	0	0	0	0	0	0	36.32	0	0	13.6
2015	12	3	9	55	10	36	0	0	0	0	0	0	0	36.45	0	0	13
2015	12	3	10	5	10	35	0	0	0	0	0	0	0	36.5	0	0	13.4
2015	12	3	10	15	10	35	0	0	0	0	0	0	0	36.57	0	0	13.4
2015	12	3	10	25	10	35	0	0	0	0	0	0	0	36.73	0	0	13
2015	12	3	10	35	10	36	0	0	0	0	0	0	0	36.84	0	0	13.2
2015	12	3	10	45	10	36	0	0	0	0	0	0	0	37.22	0	0	13.2
2015	12	3	10	55	10	35	0	0	0	0	0	0	0	37.11	0	0	13.2
2015	12	3	11	5	10	35	0	0	0	0	0	0	0	37.56	0	0	13.4
2015	12	3	11	15	10	35	0	0	0	0	0	0	0	37.62	0	0	13.2
2015	12	3	11	25	10	35	0	0	0	0	0	0	0	37.85	0	0	13.4
2015	12	3	11	35	10	35	0	0	0	0	0	0	0	38.03	0	0	13.4
2015	12	3	11	45	10	35	0	0	0	0	0	0	0	38.16	0	0	13.6
2015	12	3	11	55	10	35	0	0	0	0	0	0	0	38.35	0	0	13.6
2015	12	3	12	5	10	36	0	0	0	0	0	0	0	38.5	0	0	13.6
2015	12	3	12	15	10	35	0	0	0	0	0	0	0	38.66	0	0	13.6
2015	12	3	12	25	10	35	0	0	0	0	0	0	0	38.8	0	0	13.6
2015	12	3	12	35	10	35	0	0	0	0	0	0	0	38.95	0	0	13.2
2015	12	3	12	45	10	35	0	0	0	0	0	0	0	39.06	0	0	12.8
2015	12	3	12	55	10	35	0	0	0	0	0	0	0	39.2	0	0	13.2
2015	12	3	13	5	10	35	0	0	0	0	0	0	0	39.4	0	0	13.4
2015	12	3	13	15	10	35	0	0	0	0	0	0	0	39.47	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	13	25	10	35	0	0	0	0	0	0	0	39.58	0	0	13
2015	12	3	13	35	10	35	0	0	0	0	0	0	0	39.78	0	0	13.6
2015	12	3	13	45	10	35	0	0	0	0	0	0	0	39.9	0	0	13.4
2015	12	3	13	55	10	35	0	0	0	0	0	0	0	40.03	0	0	13.2
2015	12	3	14	5	10	35	0	0	0	0	0	0	0	40.15	0	0	13.2
2015	12	3	14	15	10	35	0	0	0	0	0	0	0	40.23	0	0	13
2015	12	3	14	25	10	35	0	0	0	0	0	0	0	40.32	0	0	12.8
2015	12	3	14	35	10	35	0	0	0	0	0	0	0	40.44	0	0	12.8
2015	12	3	14	45	10	35	0	0	0	0	0	0	0	40.55	0	0	12.6
2015	12	3	14	55	10	35	0	0	0	0	0	0	0	40.62	0	0	12.4
2015	12	3	15	5	10	35	0	0	0	0	0	0	0	40.68	0	0	12.4
2015	12	3	15	15	10	35	0	0	0	0	0	0	0	40.77	0	0	12.2
2015	12	3	15	25	10	35	0	0	0	0	0	0	0	40.8	0	0	12.2
2015	12	3	15	35	10	35	0	0	0	0	0	0	0	40.91	0	0	12.2
2015	12	3	15	45	10	35	0	0	0	0	0	0	0	40.96	0	0	12.2
2015	12	3	15	55	10	35	0	0	0	0	0	0	0	40.98	0	0	12.2
2015	12	3	16	5	10	35	0	0	0	0	0	0	0	41	0	0	12
2015	12	3	16	15	10	34	0	0	0	0	0	0	0	41.02	0	0	12
2015	12	3	16	25	10	34	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	16	35	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	16	45	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	16	55	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	17	5	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	17	15	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	17	25	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	17	35	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	17	45	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	17	55	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	18	5	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	18	15	10	34	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	18	25	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	18	35	10	35	0	0	0	0	0	0	0	41.09	0	0	12
2015	12	3	18	45	10	35	0	0	0	0	0	0	0	41.09	0	0	12
2015	12	3	18	55	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	19	5	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	19	15	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	19	25	10	35	0	0	0	0	0	0	0	41.07	0	0	12
2015	12	3	19	35	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	19	45	10	34	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	19	55	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	20	5	10	35	0	0	0	0	0	0	0	41.05	0	0	12
2015	12	3	20	15	10	35	0	0	0	0	0	0	0	41.04	0	0	12
2015	12	3	20	25	10	35	0	0	0	0	0	0	0	41.02	0	0	12
2015	12	3	20	35	10	35	0	0	0	0	0	0	0	41.02	0	0	12
2015	12	3	20	45	10	35	0	0	0	0	0	0	0	40.98	0	0	12
2015	12	3	20	55	10	35	0	0	0	0	0	0	0	40.96	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	21	5	10	34	0	0	0	0	0	0	0	40.95	0	0	11.8
2015	12	3	21	15	10	34	0	0	0	0	0	0	0	40.91	0	0	11.8
2015	12	3	21	25	10	34	0	0	0	0	0	0	0	40.87	0	0	11.8
2015	12	3	21	35	10	35	0	0	0	0	0	0	0	40.84	0	0	11.8
2015	12	3	21	45	10	35	0	0	0	0	0	0	0	40.8	0	0	11.8
2015	12	3	21	55	10	35	0	0	0	0	0	0	0	40.78	0	0	11.8
2015	12	3	22	5	10	35	0	0	0	0	0	0	0	40.75	0	0	11.8
2015	12	3	22	15	10	36	0	0	0	0	0	0	0	40.71	0	0	11.8
2015	12	3	22	25	10	35	0	0	0	0	0	0	0	40.68	0	0	11.8
2015	12	3	22	35	10	35	0	0	0	0	0	0	0	40.64	0	0	11.8
2015	12	3	22	45	10	35	0	0	0	0	0	0	0	40.6	0	0	11.8
2015	12	3	22	55	10	35	0	0	0	0	0	0	0	40.57	0	0	11.8
2015	12	3	23	5	10	35	0	0	0	0	0	0	0	40.51	0	0	11.8
2015	12	3	23	15	10	35	0	0	0	0	0	0	0	40.46	0	0	11.8
2015	12	3	23	25	10	34	0	0	0	0	0	0	0	40.41	0	0	11.8
2015	12	3	23	35	10	36	0	0	0	0	0	0	0	40.35	0	0	11.8
2015	12	3	23	45	10	35	0	0	0	0	0	0	0	40.3	0	0	11.8
2015	12	3	23	55	10	36	0	0	0	0	0	0	0	40.24	0	0	11.8
2015	12	4	0	5	10	35	0	0	0	0	0	0	0	40.19	0	0	11.8
2015	12	4	0	15	10	35	0	0	0	0	0	0	0	40.14	0	0	11.8
2015	12	4	0	25	10	35	0	0	0	0	0	0	0	40.08	0	0	11.8
2015	12	4	0	35	10	35	0	0	0	0	0	0	0	40.03	0	0	11.8
2015	12	4	0	45	10	35	0	0	0	0	0	0	0	39.97	0	0	11.8
2015	12	4	0	55	10	35	0	0	0	0	0	0	0	39.92	0	0	11.8
2015	12	4	1	5	10	35	0	0	0	0	0	0	0	39.88	0	0	11.8
2015	12	4	1	15	10	35	0	0	0	0	0	0	0	39.81	0	0	11.8
2015	12	4	1	25	10	35	0	0	0	0	0	0	0	39.78	0	0	11.8
2015	12	4	1	35	10	35	0	0	0	0	0	0	0	39.72	0	0	11.8
2015	12	4	1	45	10	35	0	0	0	0	0	0	0	39.69	0	0	11.8
2015	12	4	1	55	10	35	0	0	0	0	0	0	0	39.63	0	0	11.8
2015	12	4	2	5	10	35	0	0	0	0	0	0	0	39.6	0	0	11.8
2015	12	4	2	15	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	4	2	25	10	35	0	0	0	0	0	0	0	39.51	0	0	11.8
2015	12	4	2	35	10	34	0	0	0	0	0	0	0	39.47	0	0	11.8
2015	12	4	2	45	10	35	0	0	0	0	0	0	0	39.43	0	0	11.8
2015	12	4	2	55	10	35	0	0	0	0	0	0	0	39.4	0	0	11.8
2015	12	4	3	5	10	36	0	0	0	0	0	0	0	39.36	0	0	11.8
2015	12	4	3	15	10	35	0	0	0	0	0	0	0	39.33	0	0	11.8
2015	12	4	3	25	10	35	0	0	0	0	0	0	0	39.29	0	0	11.8
2015	12	4	3	35	10	34	0	0	0	0	0	0	0	39.27	0	0	11.8
2015	12	4	3	45	10	35	0	0	0	0	0	0	0	39.22	0	0	11.8
2015	12	4	3	55	10	35	0	0	0	0	0	0	0	39.2	0	0	11.8
2015	12	4	4	5	10	35	0	0	0	0	0	0	0	39.18	0	0	11.8
2015	12	4	4	15	10	34	0	0	0	0	0	0	0	39.16	0	0	11.8
2015	12	4	4	25	10	35	0	0	0	0	0	0	0	39.13	0	0	11.8
2015	12	4	4	35	10	35	0	0	0	0	0	0	0	39.11	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	4	45	10	36	0	0	0	0	0	0	0	39.09	0	0	11.8
2015	12	4	4	55	10	35	0	0	0	0	0	0	0	39.07	0	0	11.8
2015	12	4	5	5	10	35	0	0	0	0	0	0	0	39.06	0	0	11.8
2015	12	4	5	15	10	35	0	0	0	0	0	0	0	39.04	0	0	11.6
2015	12	4	5	25	10	35	0	0	0	0	0	0	0	39.04	0	0	11.6
2015	12	4	5	35	10	35	0	0	0	0	0	0	0	39.02	0	0	11.6
2015	12	4	5	45	10	35	0	0	0	0	0	0	0	39	0	0	11.6
2015	12	4	5	55	10	35	0	0	0	0	0	0	0	38.98	0	0	11.6
2015	12	4	6	5	10	35	0	0	0	0	0	0	0	38.97	0	0	11.6
2015	12	4	6	15	10	35	0	0	0	0	0	0	0	38.95	0	0	11.6
2015	12	4	6	25	10	35	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	4	6	35	10	35	0	0	0	0	0	0	0	38.91	0	0	11.6
2015	12	4	6	45	10	34	0	0	0	0	0	0	0	38.91	0	0	11.6
2015	12	4	6	55	10	35	0	0	0	0	0	0	0	38.91	0	0	11.6
2015	12	4	7	5	10	35	0	0	0	0	0	0	0	38.91	0	0	11.6
2015	12	4	7	15	10	35	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	4	7	25	10	35	0	0	0	0	0	0	0	38.93	0	0	11.8
2015	12	4	7	35	10	34	0	0	0	0	0	0	0	38.95	0	0	12.4
2015	12	4	7	45	10	35	0	0	0	0	0	0	0	38.97	0	0	12.8
2015	12	4	7	55	10	35	0	0	0	0	0	0	0	38.98	0	0	13
2015	12	4	8	5	10	35	0	0	0	0	0	0	0	38.98	0	0	13
2015	12	4	8	15	10	35	0	0	0	0	0	0	0	39	0	0	13.2
2015	12	4	8	25	10	35	0	0	0	0	0	0	0	39.02	0	0	13.2
2015	12	4	8	35	10	35	0	0	0	0	0	0	0	39.04	0	0	13.2
2015	12	4	8	45	10	35	0	0	0	0	0	0	0	39.06	0	0	13.2
2015	12	4	8	55	10	35	0	0	0	0	0	0	0	39.07	0	0	13.2
2015	12	4	9	5	10	35	0	0	0	0	0	0	0	39.13	0	0	13.2
2015	12	4	9	15	10	35	0	0	0	0	0	0	0	39.16	0	0	13.4
2015	12	4	9	25	10	35	0	0	0	0	0	0	0	39.24	0	0	13.4
2015	12	4	9	35	10	35	0	0	0	0	0	0	0	39.31	0	0	13.4
2015	12	4	9	45	10	35	0	0	0	0	0	0	0	39.38	0	0	13.4
2015	12	4	9	55	10	35	0	0	0	0	0	0	0	39.47	0	0	13.4
2015	12	4	10	5	10	34	0	0	0	0	0	0	0	39.58	0	0	13.4
2015	12	4	10	15	10	35	0	0	0	0	0	0	0	39.67	0	0	13.4
2015	12	4	10	25	10	35	0	0	0	0	0	0	0	39.79	0	0	13.6
2015	12	4	10	35	10	35	0	0	0	0	0	0	0	39.96	0	0	13.6
2015	12	4	10	45	10	35	0	0	0	0	0	0	0	40.37	0	0	13.6
2015	12	4	10	55	10	35	0	0	0	0	0	0	0	40.55	0	0	13.8
2015	12	4	11	5	10	35	0	0	0	0	0	0	0	40.73	0	0	13.8
2015	12	4	11	15	10	35	0	0	0	0	0	0	0	40.89	0	0	13.8
2015	12	4	11	25	10	35	0	0	0	0	0	0	0	41.07	0	0	13.8
2015	12	4	11	35	10	34	0	0	0	0	0	0	0	41.22	0	0	13.8
2015	12	4	11	45	10	35	0	0	0	0	0	0	0	41.36	0	0	13.8
2015	12	4	11	55	10	35	0	0	0	0	0	0	0	41.54	0	0	13.6
2015	12	4	12	5	10	35	0	0	0	0	0	0	0	41.68	0	0	13.6
2015	12	4	12	15	10	35	0	0	0	0	0	0	0	41.86	0	0	13.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	12	25	10	34	0	0	0	0	0	0	0	42.01	0	0	13.6
2015	12	4	12	35	10	35	0	0	0	0	0	0	0	42.19	0	0	13.6
2015	12	4	12	45	10	34	0	0	0	0	0	0	0	42.35	0	0	13.6
2015	12	4	12	55	10	34	0	0	0	0	0	0	0	42.53	0	0	13.4
2015	12	4	13	5	10	35	0	0	0	0	0	0	0	42.69	0	0	13.4
2015	12	4	13	15	10	36	0	0	0	0	0	0	0	42.85	0	0	13.4
2015	12	4	13	25	10	35	0	0	0	0	0	0	0	43.02	0	0	13.4
2015	12	4	13	35	10	35	0	0	0	0	0	0	0	43.14	0	0	13.4
2015	12	4	13	45	10	35	0	0	0	0	0	0	0	43.3	0	0	13.4
2015	12	4	13	55	10	34	0	0	0	0	0	0	0	43.45	0	0	13.4
2015	12	4	14	5	10	35	0	0	0	0	0	0	0	43.57	0	0	13.2
2015	12	4	14	15	10	34	0	0	0	0	0	0	0	43.7	0	0	13
2015	12	4	14	25	10	35	0	0	0	0	0	0	0	43.81	0	0	13
2015	12	4	14	35	10	35	0	0	0	0	0	0	0	43.92	0	0	12.8
2015	12	4	14	45	10	35	0	0	0	0	0	0	0	44.01	0	0	12.8
2015	12	4	14	55	10	34	0	0	0	0	0	0	0	44.08	0	0	12.6
2015	12	4	15	5	10	34	0	0	0	0	0	0	0	44.15	0	0	12.6
2015	12	4	15	15	10	34	0	0	0	0	0	0	0	44.2	0	0	12.4
2015	12	4	15	25	10	35	0	0	0	0	0	0	0	44.22	0	0	12.4
2015	12	4	15	35	10	34	0	0	0	0	0	0	0	44.24	0	0	12.4
2015	12	4	15	45	10	34	0	0	0	0	0	0	0	44.26	0	0	12.2
2015	12	4	15	55	10	34	0	0	0	0	0	0	0	44.26	0	0	12.2
2015	12	4	16	5	10	34	0	0	0	0	0	0	0	44.26	0	0	12.2
2015	12	4	16	15	10	35	0	0	0	0	0	0	0	44.26	0	0	12.2
2015	12	4	16	25	10	34	0	0	0	0	0	0	0	44.26	0	0	12
2015	12	4	16	35	10	34	0	0	0	0	0	0	0	44.24	0	0	12
2015	12	4	16	45	10	34	0	0	0	0	0	0	0	44.2	0	0	12
2015	12	4	16	55	10	34	0	0	0	0	0	0	0	44.2	0	0	12
2015	12	4	17	5	10	34	0	0	0	0	0	0	0	44.19	0	0	12
2015	12	4	17	15	10	35	0	0	0	0	0	0	0	44.19	0	0	12
2015	12	4	17	25	10	35	0	0	0	0	0	0	0	44.19	0	0	12
2015	12	4	17	35	10	34	0	0	0	0	0	0	0	44.17	0	0	12
2015	12	4	17	45	10	34	0	0	0	0	0	0	0	44.15	0	0	12
2015	12	4	17	55	10	35	0	0	0	0	0	0	0	44.11	0	0	12
2015	12	4	18	5	10	34	0	0	0	0	0	0	0	44.11	0	0	12
2015	12	4	18	15	10	34	0	0	0	0	0	0	0	44.08	0	0	12
2015	12	4	18	25	10	35	0	0	0	0	0	0	0	44.06	0	0	12
2015	12	4	18	35	10	34	0	0	0	0	0	0	0	44.02	0	0	12
2015	12	4	18	45	10	36	0	0	0	0	0	0	0	44.01	0	0	12
2015	12	4	18	55	10	34	0	0	0	0	0	0	0	43.97	0	0	12
2015	12	4	19	5	10	35	0	0	0	0	0	0	0	43.93	0	0	12
2015	12	4	19	15	10	34	0	0	0	0	0	0	0	43.9	0	0	12
2015	12	4	19	25	10	35	0	0	0	0	0	0	0	43.84	0	0	12
2015	12	4	19	35	10	34	0	0	0	0	0	0	0	43.79	0	0	12
2015	12	4	19	45	10	34	0	0	0	0	0	0	0	43.74	0	0	12
2015	12	4	19	55	10	34	0	0	0	0	0	0	0	43.68	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	20	5	10	33	0	0	0	0	0	0	0	43.61	0	0	12
2015	12	4	20	15	10	35	0	0	0	0	0	0	0	43.52	0	0	12
2015	12	4	20	25	10	35	0	0	0	0	0	0	0	43.45	0	0	12
2015	12	4	20	35	10	34	0	0	0	0	0	0	0	43.36	0	0	12
2015	12	4	20	45	10	34	0	0	0	0	0	0	0	43.27	0	0	12
2015	12	4	20	55	10	35	0	0	0	0	0	0	0	43.2	0	0	12
2015	12	4	21	5	10	34	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	4	21	15	10	35	0	0	0	0	0	0	0	43.02	0	0	11.8
2015	12	4	21	25	10	34	0	0	0	0	0	0	0	42.93	0	0	11.8
2015	12	4	21	35	10	34	0	0	0	0	0	0	0	42.82	0	0	11.8
2015	12	4	21	45	10	35	0	0	0	0	0	0	0	42.73	0	0	11.8
2015	12	4	21	55	10	34	0	0	0	0	0	0	0	42.62	0	0	11.8
2015	12	4	22	5	10	35	0	0	0	0	0	0	0	42.51	0	0	11.8
2015	12	4	22	15	10	35	0	0	0	0	0	0	0	42.39	0	0	11.8
2015	12	4	22	25	10	35	0	0	0	0	0	0	0	42.28	0	0	11.8
2015	12	4	22	35	10	35	0	0	0	0	0	0	0	42.19	0	0	11.8
2015	12	4	22	45	10	35	0	0	0	0	0	0	0	42.06	0	0	11.8
2015	12	4	22	55	10	35	0	0	0	0	0	0	0	41.95	0	0	11.8
2015	12	4	23	5	10	35	0	0	0	0	0	0	0	41.85	0	0	11.8
2015	12	4	23	15	10	35	0	0	0	0	0	0	0	41.74	0	0	11.8
2015	12	4	23	25	10	34	0	0	0	0	0	0	0	41.63	0	0	11.8
2015	12	4	23	35	10	35	0	0	0	0	0	0	0	41.56	0	0	11.8
2015	12	4	23	45	10	35	0	0	0	0	0	0	0	41.45	0	0	11.8
2015	12	4	23	55	10	35	0	0	0	0	0	0	0	41.34	0	0	11.8
2015	12	5	0	5	10	35	0	0	0	0	0	0	0	41.27	0	0	11.8
2015	12	5	0	15	10	35	0	0	0	0	0	0	0	41.14	0	0	11.8
2015	12	5	0	25	10	35	0	0	0	0	0	0	0	41.05	0	0	11.8
2015	12	5	0	35	10	35	0	0	0	0	0	0	0	40.96	0	0	11.8
2015	12	5	0	45	10	35	0	0	0	0	0	0	0	40.89	0	0	11.8
2015	12	5	0	55	10	34	0	0	0	0	0	0	0	40.77	0	0	11.8
2015	12	5	1	5	10	35	0	0	0	0	0	0	0	40.68	0	0	11.8
2015	12	5	1	15	10	35	0	0	0	0	0	0	0	40.6	0	0	11.8
2015	12	5	1	25	10	35	0	0	0	0	0	0	0	40.51	0	0	11.8
2015	12	5	1	35	10	35	0	0	0	0	0	0	0	40.42	0	0	11.8
2015	12	5	1	45	10	35	0	0	0	0	0	0	0	40.32	0	0	11.8
2015	12	5	1	55	10	35	0	0	0	0	0	0	0	40.24	0	0	11.8
2015	12	5	2	5	10	35	0	0	0	0	0	0	0	40.17	0	0	11.8
2015	12	5	2	15	10	35	0	0	0	0	0	0	0	40.08	0	0	11.8
2015	12	5	2	25	10	35	0	0	0	0	0	0	0	40.01	0	0	11.8
2015	12	5	2	35	10	35	0	0	0	0	0	0	0	39.92	0	0	11.8
2015	12	5	2	45	10	35	0	0	0	0	0	0	0	39.85	0	0	11.8
2015	12	5	2	55	10	35	0	0	0	0	0	0	0	39.76	0	0	11.8
2015	12	5	3	5	10	35	0	0	0	0	0	0	0	39.69	0	0	11.8
2015	12	5	3	15	10	34	0	0	0	0	0	0	0	39.61	0	0	11.8
2015	12	5	3	25	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	5	3	35	10	35	0	0	0	0	0	0	0	39.45	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	3	45	10	35	0	0	0	0	0	0	0	39.38	0	0	11.8
2015	12	5	3	55	10	35	0	0	0	0	0	0	0	39.31	0	0	11.8
2015	12	5	4	5	10	36	0	0	0	0	0	0	0	39.24	0	0	11.8
2015	12	5	4	15	10	35	0	0	0	0	0	0	0	39.16	0	0	11.8
2015	12	5	4	25	10	35	0	0	0	0	0	0	0	39.09	0	0	11.8
2015	12	5	4	35	10	35	0	0	0	0	0	0	0	39.02	0	0	11.8
2015	12	5	4	45	10	35	0	0	0	0	0	0	0	38.95	0	0	11.8
2015	12	5	4	55	10	35	0	0	0	0	0	0	0	38.89	0	0	11.8
2015	12	5	5	5	10	35	0	0	0	0	0	0	0	38.82	0	0	11.6
2015	12	5	5	15	10	35	0	0	0	0	0	0	0	38.77	0	0	11.6
2015	12	5	5	25	10	35	0	0	0	0	0	0	0	38.7	0	0	11.6
2015	12	5	5	35	10	36	0	0	0	0	0	0	0	38.64	0	0	11.6
2015	12	5	5	45	10	35	0	0	0	0	0	0	0	38.57	0	0	11.6
2015	12	5	5	55	10	35	0	0	0	0	0	0	0	38.52	0	0	11.6
2015	12	5	6	5	10	35	0	0	0	0	0	0	0	38.46	0	0	11.6
2015	12	5	6	15	10	36	0	0	0	0	0	0	0	38.41	0	0	11.6
2015	12	5	6	25	10	35	0	0	0	0	0	0	0	38.34	0	0	11.6
2015	12	5	6	35	10	35	0	0	0	0	0	0	0	38.28	0	0	11.6
2015	12	5	6	45	10	35	0	0	0	0	0	0	0	38.23	0	0	11.6
2015	12	5	6	55	10	35	0	0	0	0	0	0	0	38.19	0	0	11.6
2015	12	5	7	5	10	36	0	0	0	0	0	0	0	38.16	0	0	11.6
2015	12	5	7	15	10	35	0	0	0	0	0	0	0	38.12	0	0	11.6
2015	12	5	7	25	10	36	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	5	7	35	10	35	0	0	0	0	0	0	0	38.07	0	0	12.4
2015	12	5	7	45	10	35	0	0	0	0	0	0	0	38.03	0	0	12.4
2015	12	5	7	55	10	35	0	0	0	0	0	0	0	38.01	0	0	12.8
2015	12	5	8	5	10	35	0	0	0	0	0	0	0	37.99	0	0	13
2015	12	5	8	15	10	35	0	0	0	0	0	0	0	37.98	0	0	13.2
2015	12	5	8	25	10	35	0	0	0	0	0	0	0	37.98	0	0	13.2
2015	12	5	8	35	10	36	0	0	0	0	0	0	0	37.98	0	0	13.4
2015	12	5	8	45	10	35	0	0	0	0	0	0	0	37.99	0	0	13.4
2015	12	5	8	55	10	35	0	0	0	0	0	0	0	38.03	0	0	13
2015	12	5	9	5	10	34	0	0	0	0	0	0	0	38.14	0	0	13.6
2015	12	5	9	15	10	36	0	0	0	0	0	0	0	38.19	0	0	13.2
2015	12	5	9	25	10	35	0	0	0	0	0	0	0	38.21	0	0	12.6
2015	12	5	9	35	10	35	0	0	0	0	0	0	0	38.26	0	0	13.2
2015	12	5	9	45	10	35	0	0	0	0	0	0	0	38.32	0	0	13.8
2015	12	5	9	55	10	35	0	0	0	0	0	0	0	38.39	0	0	13.6
2015	12	5	10	5	10	35	0	0	0	0	0	0	0	38.55	0	0	13.8
2015	12	5	10	15	10	35	0	0	0	0	0	0	0	38.71	0	0	13.4
2015	12	5	10	25	10	35	0	0	0	0	0	0	0	38.84	0	0	13.4
2015	12	5	10	35	10	35	0	0	0	0	0	0	0	38.95	0	0	13.8
2015	12	5	10	45	10	35	0	0	0	0	0	0	0	39.4	0	0	13.6
2015	12	5	10	55	10	35	0	0	0	0	0	0	0	39.45	0	0	13
2015	12	5	11	5	10	35	0	0	0	0	0	0	0	39.56	0	0	13.6
2015	12	5	11	15	10	35	0	0	0	0	0	0	0	39.69	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	11	25	10	35	0	0	0	0	0	0	0	40.05	0	0	13.6
2015	12	5	11	35	10	35	0	0	0	0	0	0	0	40.17	0	0	13.2
2015	12	5	11	45	10	35	0	0	0	0	0	0	0	40.32	0	0	13.6
2015	12	5	11	55	10	35	0	0	0	0	0	0	0	40.44	0	0	13.2
2015	12	5	12	5	10	35	0	0	0	0	0	0	0	40.66	0	0	13.6
2015	12	5	12	15	10	34	0	0	0	0	0	0	0	40.77	0	0	13.4
2015	12	5	12	25	10	35	0	0	0	0	0	0	0	40.91	0	0	13.2
2015	12	5	12	35	10	35	0	0	0	0	0	0	0	41.05	0	0	13.2
2015	12	5	12	45	10	35	0	0	0	0	0	0	0	41.18	0	0	12.8
2015	12	5	12	55	10	35	0	0	0	0	0	0	0	41.27	0	0	12.8
2015	12	5	13	5	10	35	0	0	0	0	0	0	0	41.47	0	0	13
2015	12	5	13	15	10	35	0	0	0	0	0	0	0	41.63	0	0	13.4
2015	12	5	13	25	10	35	0	0	0	0	0	0	0	41.76	0	0	13.4
2015	12	5	13	35	10	34	0	0	0	0	0	0	0	41.86	0	0	13.4
2015	12	5	13	45	10	35	0	0	0	0	0	0	0	42.01	0	0	13.4
2015	12	5	13	55	10	34	0	0	0	0	0	0	0	42.13	0	0	13.2
2015	12	5	14	5	10	35	0	0	0	0	0	0	0	42.26	0	0	13.2
2015	12	5	14	15	10	34	0	0	0	0	0	0	0	42.39	0	0	13
2015	12	5	14	25	10	35	0	0	0	0	0	0	0	42.51	0	0	13
2015	12	5	14	35	10	35	0	0	0	0	0	0	0	42.6	0	0	12.8
2015	12	5	14	45	10	35	0	0	0	0	0	0	0	42.71	0	0	12.6
2015	12	5	14	55	10	35	0	0	0	0	0	0	0	42.8	0	0	12.6
2015	12	5	15	5	10	34	0	0	0	0	0	0	0	42.89	0	0	12.6
2015	12	5	15	15	10	34	0	0	0	0	0	0	0	42.96	0	0	12.4
2015	12	5	15	25	10	35	0	0	0	0	0	0	0	43.03	0	0	12.4
2015	12	5	15	35	10	35	0	0	0	0	0	0	0	43.07	0	0	12.2
2015	12	5	15	45	10	35	0	0	0	0	0	0	0	43.11	0	0	12.2
2015	12	5	15	55	10	35	0	0	0	0	0	0	0	43.12	0	0	12.2
2015	12	5	16	5	10	35	0	0	0	0	0	0	0	43.14	0	0	12.2
2015	12	5	16	15	10	35	0	0	0	0	0	0	0	43.14	0	0	12.2
2015	12	5	16	25	10	36	0	0	0	0	0	0	0	43.14	0	0	12
2015	12	5	16	35	10	35	0	0	0	0	0	0	0	43.14	0	0	12
2015	12	5	16	45	10	35	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	5	16	55	10	34	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	5	17	5	10	33	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	5	17	15	10	35	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	5	17	25	10	34	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	5	17	35	10	35	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	5	17	45	10	34	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	5	17	55	10	35	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	5	18	5	10	35	0	0	0	0	0	0	0	43.09	0	0	12
2015	12	5	18	15	10	35	0	0	0	0	0	0	0	43.07	0	0	12
2015	12	5	18	25	10	34	0	0	0	0	0	0	0	43.05	0	0	12
2015	12	5	18	35	10	35	0	0	0	0	0	0	0	43.05	0	0	12
2015	12	5	18	45	10	35	0	0	0	0	0	0	0	43.03	0	0	12
2015	12	5	18	55	10	35	0	0	0	0	0	0	0	43.02	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	19	5	10	35	0	0	0	0	0	0	0	42.98	0	0	12
2015	12	5	19	15	10	35	0	0	0	0	0	0	0	42.96	0	0	12
2015	12	5	19	25	10	34	0	0	0	0	0	0	0	42.93	0	0	12
2015	12	5	19	35	10	35	0	0	0	0	0	0	0	42.91	0	0	12
2015	12	5	19	45	10	34	0	0	0	0	0	0	0	42.85	0	0	12
2015	12	5	19	55	10	34	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	5	20	5	10	34	0	0	0	0	0	0	0	42.76	0	0	12
2015	12	5	20	15	10	35	0	0	0	0	0	0	0	42.69	0	0	12
2015	12	5	20	25	10	35	0	0	0	0	0	0	0	42.64	0	0	12
2015	12	5	20	35	10	35	0	0	0	0	0	0	0	42.57	0	0	12
2015	12	5	20	45	10	35	0	0	0	0	0	0	0	42.49	0	0	12
2015	12	5	20	55	10	35	0	0	0	0	0	0	0	42.42	0	0	11.8
2015	12	5	21	5	10	35	0	0	0	0	0	0	0	42.33	0	0	11.8
2015	12	5	21	15	10	34	0	0	0	0	0	0	0	42.26	0	0	11.8
2015	12	5	21	25	10	35	0	0	0	0	0	0	0	42.19	0	0	11.8
2015	12	5	21	35	10	34	0	0	0	0	0	0	0	42.1	0	0	11.8
2015	12	5	21	45	10	35	0	0	0	0	0	0	0	42.01	0	0	11.8
2015	12	5	21	55	10	35	0	0	0	0	0	0	0	41.92	0	0	11.8
2015	12	5	22	5	10	34	0	0	0	0	0	0	0	41.81	0	0	11.8
2015	12	5	22	15	10	35	0	0	0	0	0	0	0	41.72	0	0	11.8
2015	12	5	22	25	10	34	0	0	0	0	0	0	0	41.63	0	0	11.8
2015	12	5	22	35	10	35	0	0	0	0	0	0	0	41.52	0	0	11.8
2015	12	5	22	45	10	35	0	0	0	0	0	0	0	41.43	0	0	11.8
2015	12	5	22	55	10	36	0	0	0	0	0	0	0	41.34	0	0	11.8
2015	12	5	23	5	10	35	0	0	0	0	0	0	0	41.25	0	0	11.8
2015	12	5	23	15	10	34	0	0	0	0	0	0	0	41.16	0	0	11.8
2015	12	5	23	25	10	35	0	0	0	0	0	0	0	41.07	0	0	11.8
2015	12	5	23	35	10	35	0	0	0	0	0	0	0	41	0	0	11.8
2015	12	5	23	45	10	34	0	0	0	0	0	0	0	40.91	0	0	11.8
2015	12	5	23	55	10	35	0	0	0	0	0	0	0	40.8	0	0	11.8
2015	12	6	0	5	10	35	0	0	0	0	0	0	0	40.71	0	0	11.8
2015	12	6	0	15	10	34	0	0	0	0	0	0	0	40.62	0	0	11.8
2015	12	6	0	25	10	35	0	0	0	0	0	0	0	40.55	0	0	11.8
2015	12	6	0	35	10	35	0	0	0	0	0	0	0	40.46	0	0	11.8
2015	12	6	0	45	10	35	0	0	0	0	0	0	0	40.37	0	0	11.8
2015	12	6	0	55	10	35	0	0	0	0	0	0	0	40.28	0	0	11.8
2015	12	6	1	5	10	35	0	0	0	0	0	0	0	40.21	0	0	11.8
2015	12	6	1	15	10	35	0	0	0	0	0	0	0	40.14	0	0	11.8
2015	12	6	1	25	10	35	0	0	0	0	0	0	0	40.05	0	0	11.8
2015	12	6	1	35	10	35	0	0	0	0	0	0	0	39.99	0	0	11.8
2015	12	6	1	45	10	34	0	0	0	0	0	0	0	39.92	0	0	11.8
2015	12	6	1	55	10	35	0	0	0	0	0	0	0	39.85	0	0	11.8
2015	12	6	2	5	10	35	0	0	0	0	0	0	0	39.79	0	0	11.8
2015	12	6	2	15	10	35	0	0	0	0	0	0	0	39.74	0	0	11.8
2015	12	6	2	25	10	35	0	0	0	0	0	0	0	39.67	0	0	11.8
2015	12	6	2	35	10	35	0	0	0	0	0	0	0	39.63	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	2	45	10	35	0	0	0	0	0	0	0	39.58	0	0	11.8
2015	12	6	2	55	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	6	3	5	10	34	0	0	0	0	0	0	0	39.51	0	0	11.8
2015	12	6	3	15	10	35	0	0	0	0	0	0	0	39.47	0	0	11.8
2015	12	6	3	25	10	34	0	0	0	0	0	0	0	39.43	0	0	11.8
2015	12	6	3	35	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	6	3	45	10	35	0	0	0	0	0	0	0	39.36	0	0	11.6
2015	12	6	3	55	10	35	0	0	0	0	0	0	0	39.33	0	0	11.6
2015	12	6	4	5	10	36	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	6	4	15	10	35	0	0	0	0	0	0	0	39.27	0	0	11.6
2015	12	6	4	25	10	36	0	0	0	0	0	0	0	39.25	0	0	11.6
2015	12	6	4	35	10	34	0	0	0	0	0	0	0	39.24	0	0	11.6
2015	12	6	4	45	10	35	0	0	0	0	0	0	0	39.22	0	0	11.6
2015	12	6	4	55	10	34	0	0	0	0	0	0	0	39.2	0	0	11.6
2015	12	6	5	5	10	35	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	6	5	15	10	35	0	0	0	0	0	0	0	39.16	0	0	11.6
2015	12	6	5	25	10	35	0	0	0	0	0	0	0	39.13	0	0	11.6
2015	12	6	5	35	10	35	0	0	0	0	0	0	0	39.11	0	0	11.6
2015	12	6	5	45	10	34	0	0	0	0	0	0	0	39.09	0	0	11.6
2015	12	6	5	55	10	35	0	0	0	0	0	0	0	39.07	0	0	11.6
2015	12	6	6	5	10	35	0	0	0	0	0	0	0	39.04	0	0	11.6
2015	12	6	6	15	10	34	0	0	0	0	0	0	0	39.02	0	0	11.6
2015	12	6	6	25	10	35	0	0	0	0	0	0	0	38.98	0	0	11.6
2015	12	6	6	35	10	35	0	0	0	0	0	0	0	38.95	0	0	11.6
2015	12	6	6	45	10	35	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	6	6	55	10	35	0	0	0	0	0	0	0	38.89	0	0	11.6
2015	12	6	7	5	10	35	0	0	0	0	0	0	0	38.88	0	0	11.6
2015	12	6	7	15	10	35	0	0	0	0	0	0	0	38.84	0	0	11.6
2015	12	6	7	25	10	35	0	0	0	0	0	0	0	38.82	0	0	11.6
2015	12	6	7	35	10	35	0	0	0	0	0	0	0	38.8	0	0	12
2015	12	6	7	45	10	36	0	0	0	0	0	0	0	38.77	0	0	12.2
2015	12	6	7	55	10	34	0	0	0	0	0	0	0	38.75	0	0	12.2
2015	12	6	8	5	10	35	0	0	0	0	0	0	0	38.71	0	0	12
2015	12	6	8	15	10	35	0	0	0	0	0	0	0	38.71	0	0	12.4
2015	12	6	8	25	10	35	0	0	0	0	0	0	0	38.7	0	0	12.8
2015	12	6	8	35	10	35	0	0	0	0	0	0	0	38.7	0	0	13
2015	12	6	8	45	10	35	0	0	0	0	0	0	0	38.68	0	0	12.8
2015	12	6	8	55	10	35	0	0	0	0	0	0	0	38.7	0	0	13.2
2015	12	6	9	5	10	35	0	0	0	0	0	0	0	38.73	0	0	13.4
2015	12	6	9	15	10	35	0	0	0	0	0	0	0	38.77	0	0	13.4
2015	12	6	9	25	10	36	0	0	0	0	0	0	0	38.8	0	0	13.4
2015	12	6	9	35	10	34	0	0	0	0	0	0	0	38.86	0	0	13.2
2015	12	6	9	45	10	34	0	0	0	0	0	0	0	39.02	0	0	13.2
2015	12	6	9	55	10	35	0	0	0	0	0	0	0	39.13	0	0	13
2015	12	6	10	5	10	35	0	0	0	0	0	0	0	39.13	0	0	12.4
2015	12	6	10	15	10	35	0	0	0	0	0	0	0	39.18	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	10	25	10	36	0	0	0	0	0	0	0	39.27	0	0	12.4
2015	12	6	10	35	10	36	0	0	0	0	0	0	0	39.45	0	0	12.8
2015	12	6	10	45	10	35	0	0	0	0	0	0	0	39.63	0	0	13
2015	12	6	10	55	10	35	0	0	0	0	0	0	0	39.67	0	0	12.6
2015	12	6	11	5	10	35	0	0	0	0	0	0	0	39.74	0	0	12.6
2015	12	6	11	15	10	35	0	0	0	0	0	0	0	39.79	0	0	12.6
2015	12	6	11	25	10	36	0	0	0	0	0	0	0	39.88	0	0	12.6
2015	12	6	11	35	10	35	0	0	0	0	0	0	0	40.01	0	0	12.8
2015	12	6	11	45	10	35	0	0	0	0	0	0	0	40.12	0	0	13.2
2015	12	6	11	55	10	35	0	0	0	0	0	0	0	40.26	0	0	13.2
2015	12	6	12	5	10	34	0	0	0	0	0	0	0	40.41	0	0	13.2
2015	12	6	12	15	10	34	0	0	0	0	0	0	0	40.51	0	0	13
2015	12	6	12	25	10	35	0	0	0	0	0	0	0	40.62	0	0	13
2015	12	6	12	35	10	35	0	0	0	0	0	0	0	40.82	0	0	13.2
2015	12	6	12	45	10	35	0	0	0	0	0	0	0	40.95	0	0	13.2
2015	12	6	12	55	10	35	0	0	0	0	0	0	0	41.11	0	0	13.4
2015	12	6	13	5	10	35	0	0	0	0	0	0	0	41.27	0	0	13.4
2015	12	6	13	15	10	35	0	0	0	0	0	0	0	41.4	0	0	13.2
2015	12	6	13	25	10	34	0	0	0	0	0	0	0	41.54	0	0	13.2
2015	12	6	13	35	10	35	0	0	0	0	0	0	0	41.68	0	0	13.2
2015	12	6	13	45	10	35	0	0	0	0	0	0	0	41.83	0	0	13
2015	12	6	13	55	10	35	0	0	0	0	0	0	0	41.97	0	0	13
2015	12	6	14	5	10	35	0	0	0	0	0	0	0	42.12	0	0	13
2015	12	6	14	15	10	35	0	0	0	0	0	0	0	42.24	0	0	13
2015	12	6	14	25	10	36	0	0	0	0	0	0	0	42.35	0	0	12.8
2015	12	6	14	35	10	34	0	0	0	0	0	0	0	42.44	0	0	12.8
2015	12	6	14	45	10	35	0	0	0	0	0	0	0	42.53	0	0	12.6
2015	12	6	14	55	10	34	0	0	0	0	0	0	0	42.6	0	0	12.6
2015	12	6	15	5	10	35	0	0	0	0	0	0	0	42.66	0	0	12.4
2015	12	6	15	15	10	35	0	0	0	0	0	0	0	42.67	0	0	12.2
2015	12	6	15	25	10	35	0	0	0	0	0	0	0	42.71	0	0	12.2
2015	12	6	15	35	10	35	0	0	0	0	0	0	0	42.73	0	0	12.2
2015	12	6	15	45	10	34	0	0	0	0	0	0	0	42.76	0	0	12.2
2015	12	6	15	55	10	34	0	0	0	0	0	0	0	42.8	0	0	12.2
2015	12	6	16	5	10	34	0	0	0	0	0	0	0	42.8	0	0	12.2
2015	12	6	16	15	10	35	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	16	25	10	35	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	16	35	10	34	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	16	45	10	35	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	16	55	10	34	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	17	5	10	34	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	17	15	10	35	0	0	0	0	0	0	0	42.82	0	0	12
2015	12	6	17	25	10	35	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	6	17	35	10	34	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	6	17	45	10	34	0	0	0	0	0	0	0	42.76	0	0	12
2015	12	6	17	55	10	34	0	0	0	0	0	0	0	42.75	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	18	5	10	35	0	0	0	0	0	0	0	42.71	0	0	12
2015	12	6	18	15	10	34	0	0	0	0	0	0	0	42.67	0	0	12
2015	12	6	18	25	10	34	0	0	0	0	0	0	0	42.62	0	0	12
2015	12	6	18	35	10	35	0	0	0	0	0	0	0	42.58	0	0	12
2015	12	6	18	45	10	34	0	0	0	0	0	0	0	42.53	0	0	12
2015	12	6	18	55	10	35	0	0	0	0	0	0	0	42.48	0	0	12
2015	12	6	19	5	10	34	0	0	0	0	0	0	0	42.42	0	0	12
2015	12	6	19	15	10	35	0	0	0	0	0	0	0	42.37	0	0	12
2015	12	6	19	25	10	35	0	0	0	0	0	0	0	42.3	0	0	12
2015	12	6	19	35	10	34	0	0	0	0	0	0	0	42.22	0	0	12
2015	12	6	19	45	10	34	0	0	0	0	0	0	0	42.17	0	0	11.8
2015	12	6	19	55	10	35	0	0	0	0	0	0	0	42.1	0	0	11.8
2015	12	6	20	5	10	35	0	0	0	0	0	0	0	42.03	0	0	11.8
2015	12	6	20	15	10	35	0	0	0	0	0	0	0	41.95	0	0	11.8
2015	12	6	20	25	10	35	0	0	0	0	0	0	0	41.88	0	0	11.8
2015	12	6	20	35	10	35	0	0	0	0	0	0	0	41.79	0	0	11.8
2015	12	6	20	45	10	34	0	0	0	0	0	0	0	41.72	0	0	11.8
2015	12	6	20	55	10	35	0	0	0	0	0	0	0	41.63	0	0	11.8
2015	12	6	21	5	10	35	0	0	0	0	0	0	0	41.54	0	0	11.8
2015	12	6	21	15	10	35	0	0	0	0	0	0	0	41.47	0	0	11.8
2015	12	6	21	25	10	35	0	0	0	0	0	0	0	41.38	0	0	11.8
2015	12	6	21	35	10	35	0	0	0	0	0	0	0	41.29	0	0	11.8
2015	12	6	21	45	10	35	0	0	0	0	0	0	0	41.2	0	0	11.8
2015	12	6	21	55	10	35	0	0	0	0	0	0	0	41.09	0	0	11.8
2015	12	6	22	5	10	35	0	0	0	0	0	0	0	41	0	0	11.8
2015	12	6	22	15	10	35	0	0	0	0	0	0	0	40.89	0	0	11.8
2015	12	6	22	25	10	35	0	0	0	0	0	0	0	40.78	0	0	11.8
2015	12	6	22	35	10	35	0	0	0	0	0	0	0	40.69	0	0	11.8
2015	12	6	22	45	10	35	0	0	0	0	0	0	0	40.59	0	0	11.8
2015	12	6	22	55	10	35	0	0	0	0	0	0	0	40.51	0	0	11.8
2015	12	6	23	5	10	35	0	0	0	0	0	0	0	40.42	0	0	11.8
2015	12	6	23	15	10	34	0	0	0	0	0	0	0	40.33	0	0	11.8
2015	12	6	23	25	10	35	0	0	0	0	0	0	0	40.26	0	0	11.8
2015	12	6	23	35	10	35	0	0	0	0	0	0	0	40.19	0	0	11.8
2015	12	6	23	45	10	35	0	0	0	0	0	0	0	40.14	0	0	11.8
2015	12	6	23	55	10	35	0	0	0	0	0	0	0	40.06	0	0	11.8
2015	12	7	0	5	10	35	0	0	0	0	0	0	0	40.01	0	0	11.8
2015	12	7	0	15	10	34	0	0	0	0	0	0	0	39.97	0	0	11.8
2015	12	7	0	25	10	35	0	0	0	0	0	0	0	39.92	0	0	11.8
2015	12	7	0	35	10	35	0	0	0	0	0	0	0	39.87	0	0	11.8
2015	12	7	0	45	10	35	0	0	0	0	0	0	0	39.83	0	0	11.8
2015	12	7	0	55	10	34	0	0	0	0	0	0	0	39.78	0	0	11.8
2015	12	7	1	5	10	35	0	0	0	0	0	0	0	39.74	0	0	11.8
2015	12	7	1	15	10	34	0	0	0	0	0	0	0	39.7	0	0	11.8
2015	12	7	1	25	10	35	0	0	0	0	0	0	0	39.67	0	0	11.6
2015	12	7	1	35	10	36	0	0	0	0	0	0	0	39.65	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	1	45	10	35	0	0	0	0	0	0	0	39.61	0	0	11.6
2015	12	7	1	55	10	36	0	0	0	0	0	0	0	39.58	0	0	11.6
2015	12	7	2	5	10	35	0	0	0	0	0	0	0	39.56	0	0	11.6
2015	12	7	2	15	10	35	0	0	0	0	0	0	0	39.54	0	0	11.6
2015	12	7	2	25	10	35	0	0	0	0	0	0	0	39.54	0	0	11.6
2015	12	7	2	35	10	34	0	0	0	0	0	0	0	39.52	0	0	11.6
2015	12	7	2	45	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	2	55	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	3	5	10	35	0	0	0	0	0	0	0	39.49	0	0	11.6
2015	12	7	3	15	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	3	25	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	3	35	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	3	45	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	3	55	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	4	5	10	35	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	4	15	10	34	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	7	4	25	10	35	0	0	0	0	0	0	0	39.49	0	0	11.6
2015	12	7	4	35	10	36	0	0	0	0	0	0	0	39.49	0	0	11.6
2015	12	7	4	45	10	36	0	0	0	0	0	0	0	39.49	0	0	11.6
2015	12	7	4	55	10	35	0	0	0	0	0	0	0	39.47	0	0	11.6
2015	12	7	5	5	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	7	5	15	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	7	5	25	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	7	5	35	10	34	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	7	5	45	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	7	5	55	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	7	6	5	10	36	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	7	6	15	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	7	6	25	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	7	6	35	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	7	6	45	10	35	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	7	6	55	10	35	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	7	7	5	10	35	0	0	0	0	0	0	0	39.36	0	0	11.6
2015	12	7	7	15	10	35	0	0	0	0	0	0	0	39.36	0	0	11.6
2015	12	7	7	25	10	35	0	0	0	0	0	0	0	39.34	0	0	11.6
2015	12	7	7	35	10	35	0	0	0	0	0	0	0	39.33	0	0	12
2015	12	7	7	45	10	35	0	0	0	0	0	0	0	39.33	0	0	12.2
2015	12	7	7	55	10	35	0	0	0	0	0	0	0	39.33	0	0	12.6
2015	12	7	8	5	10	35	0	0	0	0	0	0	0	39.33	0	0	13.2
2015	12	7	8	15	10	35	0	0	0	0	0	0	0	39.34	0	0	13.4
2015	12	7	8	25	10	36	0	0	0	0	0	0	0	39.33	0	0	13.2
2015	12	7	8	35	10	35	0	0	0	0	0	0	0	39.33	0	0	13.2
2015	12	7	8	45	10	35	0	0	0	0	0	0	0	39.31	0	0	13
2015	12	7	8	55	10	35	0	0	0	0	0	0	0	39.34	0	0	13
2015	12	7	9	5	10	34	0	0	0	0	0	0	0	39.36	0	0	13.4
2015	12	7	9	15	10	35	0	0	0	0	0	0	0	39.4	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	9	25	10	35	0	0	0	0	0	0	0	39.47	0	0	13.4
2015	12	7	9	35	10	36	0	0	0	0	0	0	0	39.54	0	0	13.4
2015	12	7	9	45	10	35	0	0	0	0	0	0	0	39.63	0	0	13.2
2015	12	7	9	55	10	35	0	0	0	0	0	0	0	39.7	0	0	13.2
2015	12	7	10	5	10	35	0	0	0	0	0	0	0	39.78	0	0	13
2015	12	7	10	15	10	34	0	0	0	0	0	0	0	39.87	0	0	13.2
2015	12	7	10	25	10	35	0	0	0	0	0	0	0	39.99	0	0	13.4
2015	12	7	10	35	10	35	0	0	0	0	0	0	0	40.06	0	0	13
2015	12	7	10	45	10	35	0	0	0	0	0	0	0	40.41	0	0	13.6
2015	12	7	10	55	10	35	0	0	0	0	0	0	0	40.59	0	0	13.2
2015	12	7	11	5	10	35	0	0	0	0	0	0	0	40.77	0	0	13.2
2015	12	7	11	15	10	35	0	0	0	0	0	0	0	40.89	0	0	13
2015	12	7	11	25	10	35	0	0	0	0	0	0	0	41.05	0	0	13
2015	12	7	11	35	10	35	0	0	0	0	0	0	0	41.22	0	0	13
2015	12	7	11	45	10	35	0	0	0	0	0	0	0	41.27	0	0	12.6
2015	12	7	11	55	10	35	0	0	0	0	0	0	0	41.36	0	0	12.8
2015	12	7	12	5	10	35	0	0	0	0	0	0	0	41.59	0	0	13.4
2015	12	7	12	15	10	34	0	0	0	0	0	0	0	41.76	0	0	13.4
2015	12	7	12	25	10	35	0	0	0	0	0	0	0	41.95	0	0	13.2
2015	12	7	12	35	10	35	0	0	0	0	0	0	0	42.08	0	0	12.8
2015	12	7	12	45	10	35	0	0	0	0	0	0	0	42.19	0	0	12.8
2015	12	7	12	55	10	34	0	0	0	0	0	0	0	42.35	0	0	13.2
2015	12	7	13	5	10	35	0	0	0	0	0	0	0	42.53	0	0	13
2015	12	7	13	15	10	35	0	0	0	0	0	0	0	42.67	0	0	13
2015	12	7	13	25	10	35	0	0	0	0	0	0	0	42.82	0	0	13
2015	12	7	13	35	10	35	0	0	0	0	0	0	0	42.93	0	0	12.8
2015	12	7	13	45	10	35	0	0	0	0	0	0	0	43.05	0	0	12.6
2015	12	7	13	55	10	35	0	0	0	0	0	0	0	43.2	0	0	12.8
2015	12	7	14	5	10	35	0	0	0	0	0	0	0	43.32	0	0	12.6
2015	12	7	14	15	10	35	0	0	0	0	0	0	0	43.43	0	0	12.4
2015	12	7	14	25	10	35	0	0	0	0	0	0	0	43.5	0	0	12.4
2015	12	7	14	35	10	35	0	0	0	0	0	0	0	43.59	0	0	12.4
2015	12	7	14	45	10	35	0	0	0	0	0	0	0	43.65	0	0	12.4
2015	12	7	14	55	10	35	0	0	0	0	0	0	0	43.72	0	0	12.4
2015	12	7	15	5	10	34	0	0	0	0	0	0	0	43.79	0	0	12.4
2015	12	7	15	15	10	35	0	0	0	0	0	0	0	43.84	0	0	12.2
2015	12	7	15	25	10	35	0	0	0	0	0	0	0	43.88	0	0	12.2
2015	12	7	15	35	10	34	0	0	0	0	0	0	0	43.93	0	0	12.2
2015	12	7	15	45	10	34	0	0	0	0	0	0	0	43.97	0	0	12.2
2015	12	7	15	55	10	34	0	0	0	0	0	0	0	44.01	0	0	12.2
2015	12	7	16	5	10	35	0	0	0	0	0	0	0	44.04	0	0	12
2015	12	7	16	15	10	34	0	0	0	0	0	0	0	44.06	0	0	12
2015	12	7	16	25	10	34	0	0	0	0	0	0	0	44.1	0	0	12
2015	12	7	16	35	10	35	0	0	0	0	0	0	0	44.1	0	0	12
2015	12	7	16	45	10	34	0	0	0	0	0	0	0	44.11	0	0	12
2015	12	7	16	55	10	34	0	0	0	0	0	0	0	44.13	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	17	5	10	35	0	0	0	0	0	0	0	44.13	0	0	12
2015	12	7	17	15	10	34	0	0	0	0	0	0	0	44.15	0	0	12
2015	12	7	17	25	10	35	0	0	0	0	0	0	0	44.15	0	0	12
2015	12	7	17	35	10	35	0	0	0	0	0	0	0	44.15	0	0	12
2015	12	7	17	45	10	35	0	0	0	0	0	0	0	44.13	0	0	12
2015	12	7	17	55	10	34	0	0	0	0	0	0	0	44.13	0	0	12
2015	12	7	18	5	10	34	0	0	0	0	0	0	0	44.11	0	0	12
2015	12	7	18	15	10	35	0	0	0	0	0	0	0	44.1	0	0	12
2015	12	7	18	25	10	34	0	0	0	0	0	0	0	44.06	0	0	12
2015	12	7	18	35	10	34	0	0	0	0	0	0	0	44.04	0	0	12
2015	12	7	18	45	10	35	0	0	0	0	0	0	0	43.99	0	0	12
2015	12	7	18	55	10	34	0	0	0	0	0	0	0	43.95	0	0	12
2015	12	7	19	5	10	35	0	0	0	0	0	0	0	43.9	0	0	12
2015	12	7	19	15	10	35	0	0	0	0	0	0	0	43.84	0	0	12
2015	12	7	19	25	10	35	0	0	0	0	0	0	0	43.77	0	0	12
2015	12	7	19	35	10	34	0	0	0	0	0	0	0	43.72	0	0	12
2015	12	7	19	45	10	34	0	0	0	0	0	0	0	43.65	0	0	12
2015	12	7	19	55	10	35	0	0	0	0	0	0	0	43.59	0	0	12
2015	12	7	20	5	10	35	0	0	0	0	0	0	0	43.52	0	0	11.8
2015	12	7	20	15	10	34	0	0	0	0	0	0	0	43.45	0	0	11.8
2015	12	7	20	25	10	34	0	0	0	0	0	0	0	43.36	0	0	11.8
2015	12	7	20	35	10	34	0	0	0	0	0	0	0	43.29	0	0	11.8
2015	12	7	20	45	10	35	0	0	0	0	0	0	0	43.2	0	0	11.8
2015	12	7	20	55	10	34	0	0	0	0	0	0	0	43.11	0	0	11.8
2015	12	7	21	5	10	35	0	0	0	0	0	0	0	43.03	0	0	11.8
2015	12	7	21	15	10	35	0	0	0	0	0	0	0	42.94	0	0	11.8
2015	12	7	21	25	10	34	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	7	21	35	10	34	0	0	0	0	0	0	0	42.78	0	0	11.8
2015	12	7	21	45	10	34	0	0	0	0	0	0	0	42.71	0	0	11.8
2015	12	7	21	55	10	35	0	0	0	0	0	0	0	42.64	0	0	11.8
2015	12	7	22	5	10	35	0	0	0	0	0	0	0	42.55	0	0	11.8
2015	12	7	22	15	10	34	0	0	0	0	0	0	0	42.46	0	0	11.8
2015	12	7	22	25	10	35	0	0	0	0	0	0	0	42.39	0	0	11.8
2015	12	7	22	35	10	35	0	0	0	0	0	0	0	42.3	0	0	11.8
2015	12	7	22	45	10	35	0	0	0	0	0	0	0	42.21	0	0	11.8
2015	12	7	22	55	10	34	0	0	0	0	0	0	0	42.13	0	0	11.8
2015	12	7	23	5	10	35	0	0	0	0	0	0	0	42.06	0	0	11.8
2015	12	7	23	15	10	35	0	0	0	0	0	0	0	41.97	0	0	11.8
2015	12	7	23	25	10	34	0	0	0	0	0	0	0	41.9	0	0	11.8
2015	12	7	23	35	10	35	0	0	0	0	0	0	0	41.81	0	0	11.8
2015	12	7	23	45	10	35	0	0	0	0	0	0	0	41.74	0	0	11.8
2015	12	7	23	55	10	35	0	0	0	0	0	0	0	41.67	0	0	11.8
2015	12	8	0	5	10	35	0	0	0	0	0	0	0	41.59	0	0	11.8
2015	12	8	0	15	10	35	0	0	0	0	0	0	0	41.54	0	0	11.8
2015	12	8	0	25	10	35	0	0	0	0	0	0	0	41.47	0	0	11.8
2015	12	8	0	35	10	34	0	0	0	0	0	0	0	41.41	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	0	45	10	35	0	0	0	0	0	0	0	41.36	0	0	11.8
2015	12	8	0	55	10	35	0	0	0	0	0	0	0	41.29	0	0	11.8
2015	12	8	1	5	10	35	0	0	0	0	0	0	0	41.23	0	0	11.8
2015	12	8	1	15	10	35	0	0	0	0	0	0	0	41.18	0	0	11.8
2015	12	8	1	25	10	35	0	0	0	0	0	0	0	41.13	0	0	11.8
2015	12	8	1	35	10	35	0	0	0	0	0	0	0	41.09	0	0	11.8
2015	12	8	1	45	10	35	0	0	0	0	0	0	0	41.04	0	0	11.8
2015	12	8	1	55	10	34	0	0	0	0	0	0	0	41	0	0	11.8
2015	12	8	2	5	10	35	0	0	0	0	0	0	0	40.96	0	0	11.8
2015	12	8	2	15	10	34	0	0	0	0	0	0	0	40.93	0	0	11.8
2015	12	8	2	25	10	35	0	0	0	0	0	0	0	40.89	0	0	11.8
2015	12	8	2	35	10	35	0	0	0	0	0	0	0	40.87	0	0	11.6
2015	12	8	2	45	10	35	0	0	0	0	0	0	0	40.84	0	0	11.6
2015	12	8	2	55	10	35	0	0	0	0	0	0	0	40.8	0	0	11.6
2015	12	8	3	5	10	35	0	0	0	0	0	0	0	40.78	0	0	11.6
2015	12	8	3	15	10	34	0	0	0	0	0	0	0	40.77	0	0	11.6
2015	12	8	3	25	10	35	0	0	0	0	0	0	0	40.75	0	0	11.6
2015	12	8	3	35	10	34	0	0	0	0	0	0	0	40.73	0	0	11.6
2015	12	8	3	45	10	34	0	0	0	0	0	0	0	40.71	0	0	11.6
2015	12	8	3	55	10	35	0	0	0	0	0	0	0	40.68	0	0	11.6
2015	12	8	4	5	10	35	0	0	0	0	0	0	0	40.66	0	0	11.6
2015	12	8	4	15	10	35	0	0	0	0	0	0	0	40.64	0	0	11.6
2015	12	8	4	25	10	35	0	0	0	0	0	0	0	40.64	0	0	11.6
2015	12	8	4	35	10	35	0	0	0	0	0	0	0	40.6	0	0	11.6
2015	12	8	4	45	10	35	0	0	0	0	0	0	0	40.6	0	0	11.6
2015	12	8	4	55	10	35	0	0	0	0	0	0	0	40.59	0	0	11.6
2015	12	8	5	5	10	34	0	0	0	0	0	0	0	40.57	0	0	11.6
2015	12	8	5	15	10	35	0	0	0	0	0	0	0	40.57	0	0	11.6
2015	12	8	5	25	10	35	0	0	0	0	0	0	0	40.55	0	0	11.6
2015	12	8	5	35	10	35	0	0	0	0	0	0	0	40.53	0	0	11.6
2015	12	8	5	45	10	35	0	0	0	0	0	0	0	40.51	0	0	11.6
2015	12	8	5	55	10	35	0	0	0	0	0	0	0	40.5	0	0	11.6
2015	12	8	6	5	10	35	0	0	0	0	0	0	0	40.48	0	0	11.6
2015	12	8	6	15	10	35	0	0	0	0	0	0	0	40.46	0	0	11.6
2015	12	8	6	25	10	35	0	0	0	0	0	0	0	40.44	0	0	11.6
2015	12	8	6	35	10	35	0	0	0	0	0	0	0	40.42	0	0	11.6
2015	12	8	6	45	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	8	6	55	10	35	0	0	0	0	0	0	0	40.39	0	0	11.6
2015	12	8	7	5	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	8	7	15	10	35	0	0	0	0	0	0	0	40.39	0	0	11.6
2015	12	8	7	25	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	8	7	35	10	35	0	0	0	0	0	0	0	40.41	0	0	11.8
2015	12	8	7	45	10	35	0	0	0	0	0	0	0	40.41	0	0	12.2
2015	12	8	7	55	10	34	0	0	0	0	0	0	0	40.41	0	0	12.4
2015	12	8	8	5	10	35	0	0	0	0	0	0	0	40.44	0	0	12.4
2015	12	8	8	15	10	35	0	0	0	0	0	0	0	40.48	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	8	25	10	35	0	0	0	0	0	0	0	40.5	0	0	12.8
2015	12	8	8	35	10	35	0	0	0	0	0	0	0	40.53	0	0	12.8
2015	12	8	8	45	10	35	0	0	0	0	0	0	0	40.59	0	0	12.8
2015	12	8	8	55	10	35	0	0	0	0	0	0	0	40.64	0	0	13
2015	12	8	9	5	10	35	0	0	0	0	0	0	0	40.69	0	0	13
2015	12	8	9	15	10	35	0	0	0	0	0	0	0	40.73	0	0	13
2015	12	8	9	25	10	35	0	0	0	0	0	0	0	40.78	0	0	12.8
2015	12	8	9	35	10	35	0	0	0	0	0	0	0	40.86	0	0	13
2015	12	8	9	45	10	35	0	0	0	0	0	0	0	40.91	0	0	13
2015	12	8	9	55	10	35	0	0	0	0	0	0	0	40.98	0	0	13
2015	12	8	10	5	10	35	0	0	0	0	0	0	0	41.05	0	0	13
2015	12	8	10	15	10	35	0	0	0	0	0	0	0	41.13	0	0	13
2015	12	8	10	25	10	35	0	0	0	0	0	0	0	41.22	0	0	13.2
2015	12	8	10	35	10	35	0	0	0	0	0	0	0	41.29	0	0	13.2
2015	12	8	10	45	10	34	0	0	0	0	0	0	0	41.59	0	0	13.4
2015	12	8	10	55	10	36	0	0	0	0	0	0	0	41.77	0	0	13.4
2015	12	8	11	5	10	35	0	0	0	0	0	0	0	41.95	0	0	13.2
2015	12	8	11	15	10	35	0	0	0	0	0	0	0	42.15	0	0	13.2
2015	12	8	11	25	10	35	0	0	0	0	0	0	0	42.26	0	0	12.8
2015	12	8	11	35	10	34	0	0	0	0	0	0	0	42.33	0	0	12.6
2015	12	8	11	45	10	35	0	0	0	0	0	0	0	42.48	0	0	12.6
2015	12	8	11	55	10	35	0	0	0	0	0	0	0	42.62	0	0	12.6
2015	12	8	12	5	10	35	0	0	0	0	0	0	0	42.8	0	0	12.8
2015	12	8	12	15	10	35	0	0	0	0	0	0	0	42.94	0	0	12.8
2015	12	8	12	25	10	35	0	0	0	0	0	0	0	43.07	0	0	12.8
2015	12	8	12	35	10	35	0	0	0	0	0	0	0	43.23	0	0	12.8
2015	12	8	12	45	10	35	0	0	0	0	0	0	0	43.32	0	0	12.8
2015	12	8	12	55	10	35	0	0	0	0	0	0	0	43.43	0	0	12.8
2015	12	8	13	5	10	34	0	0	0	0	0	0	0	43.52	0	0	12.8
2015	12	8	13	15	10	34	0	0	0	0	0	0	0	43.66	0	0	12.8
2015	12	8	13	25	10	34	0	0	0	0	0	0	0	43.81	0	0	12.8
2015	12	8	13	35	10	34	0	0	0	0	0	0	0	43.95	0	0	12.6
2015	12	8	13	45	10	34	0	0	0	0	0	0	0	44.04	0	0	12.6
2015	12	8	13	55	10	35	0	0	0	0	0	0	0	44.15	0	0	12.4
2015	12	8	14	5	10	34	0	0	0	0	0	0	0	44.24	0	0	12.4
2015	12	8	14	15	10	34	0	0	0	0	0	0	0	44.33	0	0	12.4
2015	12	8	14	25	10	35	0	0	0	0	0	0	0	44.38	0	0	12.2
2015	12	8	14	35	10	34	0	0	0	0	0	0	0	44.47	0	0	12.2
2015	12	8	14	45	10	34	0	0	0	0	0	0	0	44.53	0	0	12.2
2015	12	8	14	55	10	34	0	0	0	0	0	0	0	44.6	0	0	12.2
2015	12	8	15	5	10	35	0	0	0	0	0	0	0	44.65	0	0	12.2
2015	12	8	15	15	10	35	0	0	0	0	0	0	0	44.71	0	0	12.2
2015	12	8	15	25	10	34	0	0	0	0	0	0	0	44.74	0	0	12.2
2015	12	8	15	35	10	34	0	0	0	0	0	0	0	44.8	0	0	12.2
2015	12	8	15	45	10	34	0	0	0	0	0	0	0	44.83	0	0	12
2015	12	8	15	55	10	35	0	0	0	0	0	0	0	44.87	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	16	5	10	35	0	0	0	0	0	0	0	44.91	0	0	12
2015	12	8	16	15	10	35	0	0	0	0	0	0	0	44.94	0	0	12
2015	12	8	16	25	10	34	0	0	0	0	0	0	0	44.96	0	0	12
2015	12	8	16	35	10	35	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	16	45	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	16	55	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	17	5	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	17	15	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	17	25	10	35	0	0	0	0	0	0	0	45	0	0	12
2015	12	8	17	35	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	17	45	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	17	55	10	34	0	0	0	0	0	0	0	44.98	0	0	12
2015	12	8	18	5	10	34	0	0	0	0	0	0	0	44.96	0	0	12
2015	12	8	18	15	10	34	0	0	0	0	0	0	0	44.96	0	0	12
2015	12	8	18	25	10	34	0	0	0	0	0	0	0	44.94	0	0	12
2015	12	8	18	35	10	34	0	0	0	0	0	0	0	44.91	0	0	12
2015	12	8	18	45	10	34	0	0	0	0	0	0	0	44.87	0	0	11.8
2015	12	8	18	55	10	34	0	0	0	0	0	0	0	44.83	0	0	11.8
2015	12	8	19	5	10	35	0	0	0	0	0	0	0	44.78	0	0	11.8
2015	12	8	19	15	10	34	0	0	0	0	0	0	0	44.73	0	0	11.8
2015	12	8	19	25	10	35	0	0	0	0	0	0	0	44.67	0	0	11.8
2015	12	8	19	35	10	34	0	0	0	0	0	0	0	44.6	0	0	11.8
2015	12	8	19	45	10	34	0	0	0	0	0	0	0	44.53	0	0	11.8
2015	12	8	19	55	10	34	0	0	0	0	0	0	0	44.46	0	0	11.8
2015	12	8	20	5	10	35	0	0	0	0	0	0	0	44.4	0	0	11.8
2015	12	8	20	15	10	35	0	0	0	0	0	0	0	44.31	0	0	11.8
2015	12	8	20	25	10	35	0	0	0	0	0	0	0	44.24	0	0	11.8
2015	12	8	20	35	10	35	0	0	0	0	0	0	0	44.17	0	0	11.8
2015	12	8	20	45	10	35	0	0	0	0	0	0	0	44.1	0	0	11.8
2015	12	8	20	55	10	35	0	0	0	0	0	0	0	44.02	0	0	11.8
2015	12	8	21	5	10	34	0	0	0	0	0	0	0	43.93	0	0	11.8
2015	12	8	21	15	10	35	0	0	0	0	0	0	0	43.84	0	0	11.8
2015	12	8	21	25	10	35	0	0	0	0	0	0	0	43.75	0	0	11.8
2015	12	8	21	35	10	35	0	0	0	0	0	0	0	43.68	0	0	11.8
2015	12	8	21	45	10	35	0	0	0	0	0	0	0	43.59	0	0	11.8
2015	12	8	21	55	10	35	0	0	0	0	0	0	0	43.52	0	0	11.8
2015	12	8	22	5	10	34	0	0	0	0	0	0	0	43.45	0	0	11.8
2015	12	8	22	15	10	35	0	0	0	0	0	0	0	43.36	0	0	11.8
2015	12	8	22	25	10	34	0	0	0	0	0	0	0	43.29	0	0	11.8
2015	12	8	22	35	10	34	0	0	0	0	0	0	0	43.2	0	0	11.8
2015	12	8	22	45	10	35	0	0	0	0	0	0	0	43.11	0	0	11.8
2015	12	8	22	55	10	35	0	0	0	0	0	0	0	43.05	0	0	11.8
2015	12	8	23	5	10	34	0	0	0	0	0	0	0	42.96	0	0	11.8
2015	12	8	23	15	10	35	0	0	0	0	0	0	0	42.89	0	0	11.8
2015	12	8	23	25	10	34	0	0	0	0	0	0	0	42.8	0	0	11.8
2015	12	8	23	35	10	35	0	0	0	0	0	0	0	42.73	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	23	45	10	35	0	0	0	0	0	0	0	42.66	0	0	11.6
2015	12	8	23	55	10	35	0	0	0	0	0	0	0	42.58	0	0	11.6
2015	12	9	0	5	10	35	0	0	0	0	0	0	0	42.51	0	0	11.6
2015	12	9	0	15	10	35	0	0	0	0	0	0	0	42.46	0	0	11.6
2015	12	9	0	25	10	34	0	0	0	0	0	0	0	42.39	0	0	11.6
2015	12	9	0	35	10	35	0	0	0	0	0	0	0	42.33	0	0	11.6
2015	12	9	0	45	10	34	0	0	0	0	0	0	0	42.3	0	0	11.6
2015	12	9	0	55	10	35	0	0	0	0	0	0	0	42.24	0	0	11.6
2015	12	9	1	5	10	35	0	0	0	0	0	0	0	42.19	0	0	11.6
2015	12	9	1	15	10	35	0	0	0	0	0	0	0	42.15	0	0	11.6
2015	12	9	1	25	10	35	0	0	0	0	0	0	0	42.1	0	0	11.6
2015	12	9	1	35	10	34	0	0	0	0	0	0	0	42.06	0	0	11.6
2015	12	9	1	45	10	35	0	0	0	0	0	0	0	42.03	0	0	11.6
2015	12	9	1	55	10	35	0	0	0	0	0	0	0	42.01	0	0	11.6
2015	12	9	2	5	10	35	0	0	0	0	0	0	0	41.97	0	0	11.6
2015	12	9	2	15	10	34	0	0	0	0	0	0	0	41.94	0	0	11.6
2015	12	9	2	25	10	34	0	0	0	0	0	0	0	41.92	0	0	11.6
2015	12	9	2	35	10	34	0	0	0	0	0	0	0	41.9	0	0	11.6
2015	12	9	2	45	10	35	0	0	0	0	0	0	0	41.9	0	0	11.6
2015	12	9	2	55	10	35	0	0	0	0	0	0	0	41.88	0	0	11.6
2015	12	9	3	5	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	3	15	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	3	25	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	3	35	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	3	45	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	3	55	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	4	5	10	34	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	4	15	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	4	25	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	4	35	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	4	45	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	4	55	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	5	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	15	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	25	10	34	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	35	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	45	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	5	55	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	6	5	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	6	15	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	6	25	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	6	35	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	9	6	45	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	6	55	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	9	7	5	10	34	0	0	0	0	0	0	0	41.83	0	0	11.6
2015	12	9	7	15	10	34	0	0	0	0	0	0	0	41.83	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	7	25	10	35	0	0	0	0	0	0	0	41.83	0	0	11.6
2015	12	9	7	35	10	35	0	0	0	0	0	0	0	41.83	0	0	11.6
2015	12	9	7	45	10	34	0	0	0	0	0	0	0	41.81	0	0	11.6
2015	12	9	7	55	10	35	0	0	0	0	0	0	0	41.83	0	0	11.8
2015	12	9	8	5	10	35	0	0	0	0	0	0	0	41.85	0	0	11.8
2015	12	9	8	15	10	35	0	0	0	0	0	0	0	41.81	0	0	11.8
2015	12	9	8	25	10	34	0	0	0	0	0	0	0	41.81	0	0	11.8
2015	12	9	8	35	10	35	0	0	0	0	0	0	0	41.81	0	0	12
2015	12	9	8	45	10	35	0	0	0	0	0	0	0	41.83	0	0	12.2
2015	12	9	8	55	10	35	0	0	0	0	0	0	0	41.85	0	0	12.4
2015	12	9	9	5	10	35	0	0	0	0	0	0	0	41.83	0	0	12.8
2015	12	9	9	15	10	35	0	0	0	0	0	0	0	41.86	0	0	13.4
2015	12	9	9	25	10	35	0	0	0	0	0	0	0	41.9	0	0	13.4
2015	12	9	9	35	10	34	0	0	0	0	0	0	0	41.95	0	0	13.6
2015	12	9	9	45	10	34	0	0	0	0	0	0	0	41.99	0	0	13.2
2015	12	9	9	55	10	34	0	0	0	0	0	0	0	42.04	0	0	13.2
2015	12	9	10	5	10	35	0	0	0	0	0	0	0	42.13	0	0	13
2015	12	9	10	15	10	35	0	0	0	0	0	0	0	42.17	0	0	13
2015	12	9	10	25	10	35	0	0	0	0	0	0	0	42.28	0	0	13
2015	12	9	10	35	10	35	0	0	0	0	0	0	0	42.37	0	0	12.8
2015	12	9	10	45	10	35	0	0	0	0	0	0	0	42.44	0	0	12.6
2015	12	9	10	55	10	35	0	0	0	0	0	0	0	42.57	0	0	12.6
2015	12	9	11	5	10	35	0	0	0	0	0	0	0	42.66	0	0	12.8
2015	12	9	11	15	10	34	0	0	0	0	0	0	0	42.75	0	0	12.8
2015	12	9	11	25	10	35	0	0	0	0	0	0	0	42.8	0	0	12.6
2015	12	9	11	35	10	35	0	0	0	0	0	0	0	42.87	0	0	12.6
2015	12	9	11	45	10	35	0	0	0	0	0	0	0	43.02	0	0	12.8
2015	12	9	11	55	10	34	0	0	0	0	0	0	0	43.11	0	0	12.8
2015	12	9	12	5	10	35	0	0	0	0	0	0	0	43.18	0	0	12.8
2015	12	9	12	15	10	34	0	0	0	0	0	0	0	43.29	0	0	13
2015	12	9	12	25	10	35	0	0	0	0	0	0	0	43.41	0	0	13
2015	12	9	12	35	10	34	0	0	0	0	0	0	0	43.54	0	0	13
2015	12	9	12	45	10	35	0	0	0	0	0	0	0	43.75	0	0	13.4
2015	12	9	12	55	10	34	0	0	0	0	0	0	0	43.92	0	0	13.2
2015	12	9	13	5	10	35	0	0	0	0	0	0	0	44.11	0	0	13.2
2015	12	9	13	15	10	35	0	0	0	0	0	0	0	44.26	0	0	13.2
2015	12	9	13	25	10	34	0	0	0	0	0	0	0	44.46	0	0	13.2
2015	12	9	13	35	10	34	0	0	0	0	0	0	0	44.62	0	0	13
2015	12	9	13	45	10	35	0	0	0	0	0	0	0	44.78	0	0	13
2015	12	9	13	55	10	35	0	0	0	0	0	0	0	44.96	0	0	13
2015	12	9	14	5	10	34	0	0	0	0	0	0	0	45.12	0	0	13
2015	12	9	14	15	10	35	0	0	0	0	0	0	0	45.28	0	0	12.8
2015	12	9	14	25	10	34	0	0	0	0	0	0	0	45.43	0	0	12.8
2015	12	9	14	35	10	34	0	0	0	0	0	0	0	45.55	0	0	12.6
2015	12	9	14	45	10	34	0	0	0	0	0	0	0	45.66	0	0	12.6
2015	12	9	14	55	10	34	0	0	0	0	0	0	0	45.75	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	15	5	10	35	0	0	0	0	0	0	0	45.82	0	0	12.4
2015	12	9	15	15	10	34	0	0	0	0	0	0	0	45.9	0	0	12.4
2015	12	9	15	25	10	34	0	0	0	0	0	0	0	45.93	0	0	12.2
2015	12	9	15	35	10	34	0	0	0	0	0	0	0	45.97	0	0	12.2
2015	12	9	15	45	10	35	0	0	0	0	0	0	0	45.99	0	0	12.2
2015	12	9	15	55	10	34	0	0	0	0	0	0	0	46.02	0	0	12
2015	12	9	16	5	10	34	0	0	0	0	0	0	0	46.04	0	0	12
2015	12	9	16	15	10	35	0	0	0	0	0	0	0	46.06	0	0	12
2015	12	9	16	25	10	34	0	0	0	0	0	0	0	46.08	0	0	12
2015	12	9	16	35	10	35	0	0	0	0	0	0	0	46.09	0	0	12
2015	12	9	16	45	10	34	0	0	0	0	0	0	0	46.11	0	0	12
2015	12	9	16	55	10	35	0	0	0	0	0	0	0	46.11	0	0	12
2015	12	9	17	5	10	34	0	0	0	0	0	0	0	46.13	0	0	12
2015	12	9	17	15	10	34	0	0	0	0	0	0	0	46.13	0	0	12
2015	12	9	17	25	10	34	0	0	0	0	0	0	0	46.11	0	0	12
2015	12	9	17	35	10	34	0	0	0	0	0	0	0	46.11	0	0	12
2015	12	9	17	45	10	35	0	0	0	0	0	0	0	46.09	0	0	12
2015	12	9	17	55	10	34	0	0	0	0	0	0	0	46.08	0	0	12
2015	12	9	18	5	10	34	0	0	0	0	0	0	0	46.04	0	0	12
2015	12	9	18	15	10	35	0	0	0	0	0	0	0	46	0	0	12
2015	12	9	18	25	10	35	0	0	0	0	0	0	0	45.97	0	0	12
2015	12	9	18	35	10	34	0	0	0	0	0	0	0	45.91	0	0	12
2015	12	9	18	45	10	34	0	0	0	0	0	0	0	45.86	0	0	12
2015	12	9	18	55	10	35	0	0	0	0	0	0	0	45.79	0	0	12
2015	12	9	19	5	10	34	0	0	0	0	0	0	0	45.75	0	0	11.8
2015	12	9	19	15	10	34	0	0	0	0	0	0	0	45.7	0	0	11.8
2015	12	9	19	25	10	34	0	0	0	0	0	0	0	45.64	0	0	11.8
2015	12	9	19	35	10	34	0	0	0	0	0	0	0	45.57	0	0	11.8
2015	12	9	19	45	10	34	0	0	0	0	0	0	0	45.52	0	0	11.8
2015	12	9	19	55	10	34	0	0	0	0	0	0	0	45.46	0	0	11.8
2015	12	9	20	5	10	34	0	0	0	0	0	0	0	45.39	0	0	11.8
2015	12	9	20	15	10	34	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	9	20	25	10	35	0	0	0	0	0	0	0	45.28	0	0	11.8
2015	12	9	20	35	10	34	0	0	0	0	0	0	0	45.21	0	0	11.8
2015	12	9	20	45	10	34	0	0	0	0	0	0	0	45.14	0	0	11.8
2015	12	9	20	55	10	35	0	0	0	0	0	0	0	45.07	0	0	11.8
2015	12	9	21	5	10	35	0	0	0	0	0	0	0	44.98	0	0	11.8
2015	12	9	21	15	10	35	0	0	0	0	0	0	0	44.89	0	0	11.8
2015	12	9	21	25	10	35	0	0	0	0	0	0	0	44.78	0	0	11.8
2015	12	9	21	35	10	35	0	0	0	0	0	0	0	44.67	0	0	11.8
2015	12	9	21	45	10	35	0	0	0	0	0	0	0	44.58	0	0	11.8
2015	12	9	21	55	10	34	0	0	0	0	0	0	0	44.47	0	0	11.8
2015	12	9	22	5	10	35	0	0	0	0	0	0	0	44.37	0	0	11.8
2015	12	9	22	15	10	34	0	0	0	0	0	0	0	44.26	0	0	11.8
2015	12	9	22	25	10	34	0	0	0	0	0	0	0	44.15	0	0	11.8
2015	12	9	22	35	10	35	0	0	0	0	0	0	0	44.04	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	22	45	10	35	0	0	0	0	0	0	0	43.93	0	0	11.8
2015	12	9	22	55	10	35	0	0	0	0	0	0	0	43.83	0	0	11.8
2015	12	9	23	5	10	35	0	0	0	0	0	0	0	43.74	0	0	11.8
2015	12	9	23	15	10	34	0	0	0	0	0	0	0	43.63	0	0	11.8
2015	12	9	23	25	10	34	0	0	0	0	0	0	0	43.54	0	0	11.8
2015	12	9	23	35	10	35	0	0	0	0	0	0	0	43.43	0	0	11.8
2015	12	9	23	45	10	34	0	0	0	0	0	0	0	43.34	0	0	11.8
2015	12	9	23	55	10	35	0	0	0	0	0	0	0	43.25	0	0	11.8
2015	12	10	0	5	10	35	0	0	0	0	0	0	0	43.16	0	0	11.8
2015	12	10	0	15	10	35	0	0	0	0	0	0	0	43.07	0	0	11.8
2015	12	10	0	25	10	35	0	0	0	0	0	0	0	43	0	0	11.6
2015	12	10	0	35	10	35	0	0	0	0	0	0	0	42.93	0	0	11.6
2015	12	10	0	45	10	34	0	0	0	0	0	0	0	42.85	0	0	11.6
2015	12	10	0	55	10	35	0	0	0	0	0	0	0	42.78	0	0	11.6
2015	12	10	1	5	10	35	0	0	0	0	0	0	0	42.71	0	0	11.6
2015	12	10	1	15	10	34	0	0	0	0	0	0	0	42.66	0	0	11.6
2015	12	10	1	25	10	34	0	0	0	0	0	0	0	42.6	0	0	11.6
2015	12	10	1	35	10	34	0	0	0	0	0	0	0	42.53	0	0	11.6
2015	12	10	1	45	10	34	0	0	0	0	0	0	0	42.48	0	0	11.6
2015	12	10	1	55	10	35	0	0	0	0	0	0	0	42.42	0	0	11.6
2015	12	10	2	5	10	34	0	0	0	0	0	0	0	42.39	0	0	11.6
2015	12	10	2	15	10	36	0	0	0	0	0	0	0	42.35	0	0	11.6
2015	12	10	2	25	10	34	0	0	0	0	0	0	0	42.3	0	0	11.6
2015	12	10	2	35	10	35	0	0	0	0	0	0	0	42.28	0	0	11.6
2015	12	10	2	45	10	34	0	0	0	0	0	0	0	42.24	0	0	11.6
2015	12	10	2	55	10	35	0	0	0	0	0	0	0	42.21	0	0	11.6
2015	12	10	3	5	10	35	0	0	0	0	0	0	0	42.19	0	0	11.6
2015	12	10	3	15	10	34	0	0	0	0	0	0	0	42.15	0	0	11.6
2015	12	10	3	25	10	35	0	0	0	0	0	0	0	42.12	0	0	11.6
2015	12	10	3	35	10	35	0	0	0	0	0	0	0	42.08	0	0	11.6
2015	12	10	3	45	10	35	0	0	0	0	0	0	0	42.06	0	0	11.6
2015	12	10	3	55	10	35	0	0	0	0	0	0	0	42.04	0	0	11.6
2015	12	10	4	5	10	35	0	0	0	0	0	0	0	42.01	0	0	11.6
2015	12	10	4	15	10	35	0	0	0	0	0	0	0	41.99	0	0	11.6
2015	12	10	4	25	10	34	0	0	0	0	0	0	0	41.97	0	0	11.6
2015	12	10	4	35	10	36	0	0	0	0	0	0	0	41.95	0	0	11.6
2015	12	10	4	45	10	34	0	0	0	0	0	0	0	41.94	0	0	11.6
2015	12	10	4	55	10	34	0	0	0	0	0	0	0	41.92	0	0	11.6
2015	12	10	5	5	10	35	0	0	0	0	0	0	0	41.9	0	0	11.6
2015	12	10	5	15	10	35	0	0	0	0	0	0	0	41.88	0	0	11.6
2015	12	10	5	25	10	35	0	0	0	0	0	0	0	41.88	0	0	11.6
2015	12	10	5	35	10	35	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	10	5	45	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	10	5	55	10	34	0	0	0	0	0	0	0	41.83	0	0	11.6
2015	12	10	6	5	10	35	0	0	0	0	0	0	0	41.81	0	0	11.6
2015	12	10	6	15	10	34	0	0	0	0	0	0	0	41.79	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	6	25	10	35	0	0	0	0	0	0	0	41.79	0	0	11.6
2015	12	10	6	35	10	35	0	0	0	0	0	0	0	41.77	0	0	11.6
2015	12	10	6	45	10	35	0	0	0	0	0	0	0	41.77	0	0	11.6
2015	12	10	6	55	10	35	0	0	0	0	0	0	0	41.77	0	0	11.6
2015	12	10	7	5	10	35	0	0	0	0	0	0	0	41.77	0	0	11.6
2015	12	10	7	15	10	35	0	0	0	0	0	0	0	41.79	0	0	11.6
2015	12	10	7	25	10	35	0	0	0	0	0	0	0	41.85	0	0	11.6
2015	12	10	7	35	10	35	0	0	0	0	0	0	0	41.88	0	0	11.8
2015	12	10	7	45	10	35	0	0	0	0	0	0	0	41.92	0	0	11.8
2015	12	10	7	55	10	35	0	0	0	0	0	0	0	41.97	0	0	11.8
2015	12	10	8	5	10	35	0	0	0	0	0	0	0	42.04	0	0	11.8
2015	12	10	8	15	10	35	0	0	0	0	0	0	0	42.1	0	0	11.8
2015	12	10	8	25	10	34	0	0	0	0	0	0	0	42.19	0	0	11.8
2015	12	10	8	35	10	35	0	0	0	0	0	0	0	42.28	0	0	11.8
2015	12	10	8	45	10	35	0	0	0	0	0	0	0	42.35	0	0	11.8
2015	12	10	8	55	10	35	0	0	0	0	0	0	0	42.4	0	0	11.8
2015	12	10	9	5	10	35	0	0	0	0	0	0	0	42.48	0	0	11.8
2015	12	10	9	15	10	35	0	0	0	0	0	0	0	42.57	0	0	11.8
2015	12	10	9	25	10	35	0	0	0	0	0	0	0	42.64	0	0	11.8
2015	12	10	9	35	10	35	0	0	0	0	0	0	0	42.73	0	0	11.8
2015	12	10	9	45	10	34	0	0	0	0	0	0	0	42.82	0	0	11.8
2015	12	10	9	55	10	34	0	0	0	0	0	0	0	42.91	0	0	11.8
2015	12	10	10	5	10	35	0	0	0	0	0	0	0	42.98	0	0	11.8
2015	12	10	10	15	10	35	0	0	0	0	0	0	0	43.05	0	0	11.8
2015	12	10	10	25	10	35	0	0	0	0	0	0	0	43.12	0	0	11.8
2015	12	10	10	35	10	35	0	0	0	0	0	0	0	43.21	0	0	11.8
2015	12	10	10	45	10	34	0	0	0	0	0	0	0	43.36	0	0	11.8
2015	12	10	10	55	10	35	0	0	0	0	0	0	0	43.43	0	0	11.8
2015	12	10	11	5	10	35	0	0	0	0	0	0	0	43.54	0	0	11.8
2015	12	10	11	15	10	36	0	0	0	0	0	0	0	43.65	0	0	11.8
2015	12	10	11	25	10	35	0	0	0	0	0	0	0	43.72	0	0	11.8
2015	12	10	11	35	10	34	0	0	0	0	0	0	0	43.81	0	0	11.8
2015	12	10	11	45	10	35	0	0	0	0	0	0	0	43.83	0	0	11.8
2015	12	10	11	55	10	34	0	0	0	0	0	0	0	43.97	0	0	11.8
2015	12	10	12	5	10	35	0	0	0	0	0	0	0	44.08	0	0	11.8
2015	12	10	12	15	10	35	0	0	0	0	0	0	0	44.13	0	0	11.8
2015	12	10	12	25	10	35	0	0	0	0	0	0	0	44.22	0	0	11.8
2015	12	10	12	35	10	35	0	0	0	0	0	0	0	44.24	0	0	11.8
2015	12	10	12	45	10	35	0	0	0	0	0	0	0	44.29	0	0	11.8
2015	12	10	12	55	10	35	0	0	0	0	0	0	0	44.4	0	0	11.8
2015	12	10	13	5	10	34	0	0	0	0	0	0	0	44.47	0	0	11.8
2015	12	10	13	15	10	35	0	0	0	0	0	0	0	44.53	0	0	11.8
2015	12	10	13	25	10	34	0	0	0	0	0	0	0	44.56	0	0	11.8
2015	12	10	13	35	10	34	0	0	0	0	0	0	0	44.62	0	0	11.8
2015	12	10	13	45	10	34	0	0	0	0	0	0	0	44.73	0	0	11.8
2015	12	10	13	55	10	35	0	0	0	0	0	0	0	44.8	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	14	5	10	35	0	0	0	0	0	0	0	44.82	0	0	11.8
2015	12	10	14	15	10	35	0	0	0	0	0	0	0	44.89	0	0	11.8
2015	12	10	14	25	10	35	0	0	0	0	0	0	0	44.92	0	0	11.8
2015	12	10	14	35	10	35	0	0	0	0	0	0	0	44.94	0	0	11.8
2015	12	10	14	45	10	34	0	0	0	0	0	0	0	45	0	0	11.8
2015	12	10	14	55	10	34	0	0	0	0	0	0	0	45.05	0	0	11.8
2015	12	10	15	5	10	35	0	0	0	0	0	0	0	45.07	0	0	11.8
2015	12	10	15	15	10	35	0	0	0	0	0	0	0	45.14	0	0	11.8
2015	12	10	15	25	10	34	0	0	0	0	0	0	0	45.16	0	0	11.8
2015	12	10	15	35	10	33	0	0	0	0	0	0	0	45.18	0	0	11.8
2015	12	10	15	45	10	35	0	0	0	0	0	0	0	45.19	0	0	11.8
2015	12	10	15	55	10	34	0	0	0	0	0	0	0	45.23	0	0	11.8
2015	12	10	16	5	10	34	0	0	0	0	0	0	0	45.25	0	0	11.8
2015	12	10	16	15	10	35	0	0	0	0	0	0	0	45.27	0	0	11.8
2015	12	10	16	25	10	35	0	0	0	0	0	0	0	45.28	0	0	11.8
2015	12	10	16	35	10	34	0	0	0	0	0	0	0	45.3	0	0	11.8
2015	12	10	16	45	10	34	0	0	0	0	0	0	0	45.32	0	0	11.8
2015	12	10	16	55	10	34	0	0	0	0	0	0	0	45.34	0	0	11.8
2015	12	10	17	5	10	34	0	0	0	0	0	0	0	45.34	0	0	11.8
2015	12	10	17	15	10	34	0	0	0	0	0	0	0	45.34	0	0	11.8
2015	12	10	17	25	10	34	0	0	0	0	0	0	0	45.34	0	0	11.8
2015	12	10	17	35	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	17	45	10	34	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	17	55	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	5	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	15	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	25	10	34	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	35	10	34	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	45	10	34	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	18	55	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	10	19	5	10	35	0	0	0	0	0	0	0	45.34	0	0	11.8
2015	12	10	19	15	10	34	0	0	0	0	0	0	0	45.32	0	0	11.8
2015	12	10	19	25	10	35	0	0	0	0	0	0	0	45.3	0	0	11.8
2015	12	10	19	35	10	34	0	0	0	0	0	0	0	45.28	0	0	11.8
2015	12	10	19	45	10	33	0	0	0	0	0	0	0	45.27	0	0	11.6
2015	12	10	19	55	10	34	0	0	0	0	0	0	0	45.25	0	0	11.6
2015	12	10	20	5	10	34	0	0	0	0	0	0	0	45.23	0	0	11.6
2015	12	10	20	15	10	34	0	0	0	0	0	0	0	45.19	0	0	11.6
2015	12	10	20	25	10	34	0	0	0	0	0	0	0	45.18	0	0	11.6
2015	12	10	20	35	10	34	0	0	0	0	0	0	0	45.14	0	0	11.6
2015	12	10	20	45	10	35	0	0	0	0	0	0	0	45.1	0	0	11.6
2015	12	10	20	55	10	34	0	0	0	0	0	0	0	45.09	0	0	11.6
2015	12	10	21	5	10	34	0	0	0	0	0	0	0	45.03	0	0	11.6
2015	12	10	21	15	10	34	0	0	0	0	0	0	0	45	0	0	11.6
2015	12	10	21	25	10	35	0	0	0	0	0	0	0	44.96	0	0	11.6
2015	12	10	21	35	10	35	0	0	0	0	0	0	0	44.92	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	21	45	10	35	0	0	0	0	0	0	0	44.87	0	0	11.6
2015	12	10	21	55	10	34	0	0	0	0	0	0	0	44.83	0	0	11.6
2015	12	10	22	5	10	34	0	0	0	0	0	0	0	44.78	0	0	11.6
2015	12	10	22	15	10	34	0	0	0	0	0	0	0	44.73	0	0	11.6
2015	12	10	22	25	10	34	0	0	0	0	0	0	0	44.69	0	0	11.6
2015	12	10	22	35	10	34	0	0	0	0	0	0	0	44.64	0	0	11.6
2015	12	10	22	45	10	35	0	0	0	0	0	0	0	44.56	0	0	11.6
2015	12	10	22	55	10	35	0	0	0	0	0	0	0	44.51	0	0	11.6
2015	12	10	23	5	10	34	0	0	0	0	0	0	0	44.46	0	0	11.6
2015	12	10	23	15	10	34	0	0	0	0	0	0	0	44.4	0	0	11.6
2015	12	10	23	25	10	35	0	0	0	0	0	0	0	44.35	0	0	11.6
2015	12	10	23	35	10	34	0	0	0	0	0	0	0	44.31	0	0	11.6
2015	12	10	23	45	10	35	0	0	0	0	0	0	0	44.26	0	0	11.6
2015	12	10	23	55	10	35	0	0	0	0	0	0	0	44.2	0	0	11.6
2015	12	11	0	5	10	34	0	0	0	0	0	0	0	44.17	0	0	11.6
2015	12	11	0	15	10	34	0	0	0	0	0	0	0	44.11	0	0	11.6
2015	12	11	0	25	10	34	0	0	0	0	0	0	0	44.08	0	0	11.6
2015	12	11	0	35	10	34	0	0	0	0	0	0	0	44.06	0	0	11.6
2015	12	11	0	45	10	35	0	0	0	0	0	0	0	44.02	0	0	11.6
2015	12	11	0	55	10	34	0	0	0	0	0	0	0	43.99	0	0	11.6
2015	12	11	1	5	10	35	0	0	0	0	0	0	0	43.97	0	0	11.6
2015	12	11	1	15	10	35	0	0	0	0	0	0	0	43.93	0	0	11.6
2015	12	11	1	25	10	34	0	0	0	0	0	0	0	43.92	0	0	11.6
2015	12	11	1	35	10	35	0	0	0	0	0	0	0	43.9	0	0	11.6
2015	12	11	1	45	10	35	0	0	0	0	0	0	0	43.88	0	0	11.6
2015	12	11	1	55	10	35	0	0	0	0	0	0	0	43.84	0	0	11.6
2015	12	11	2	5	10	34	0	0	0	0	0	0	0	43.83	0	0	11.6
2015	12	11	2	15	10	35	0	0	0	0	0	0	0	43.81	0	0	11.6
2015	12	11	2	25	10	34	0	0	0	0	0	0	0	43.77	0	0	11.6
2015	12	11	2	35	10	34	0	0	0	0	0	0	0	43.74	0	0	11.6
2015	12	11	2	45	10	34	0	0	0	0	0	0	0	43.72	0	0	11.6
2015	12	11	2	55	10	35	0	0	0	0	0	0	0	43.7	0	0	11.6
2015	12	11	3	5	10	34	0	0	0	0	0	0	0	43.68	0	0	11.6
2015	12	11	3	15	10	35	0	0	0	0	0	0	0	43.66	0	0	11.6
2015	12	11	3	25	10	35	0	0	0	0	0	0	0	43.65	0	0	11.6
2015	12	11	3	35	10	34	0	0	0	0	0	0	0	43.63	0	0	11.6
2015	12	11	3	45	10	34	0	0	0	0	0	0	0	43.61	0	0	11.6
2015	12	11	3	55	10	35	0	0	0	0	0	0	0	43.59	0	0	11.6
2015	12	11	4	5	10	35	0	0	0	0	0	0	0	43.56	0	0	11.6
2015	12	11	4	15	10	34	0	0	0	0	0	0	0	43.54	0	0	11.6
2015	12	11	4	25	10	35	0	0	0	0	0	0	0	43.5	0	0	11.6
2015	12	11	4	35	10	35	0	0	0	0	0	0	0	43.48	0	0	11.6
2015	12	11	4	45	10	35	0	0	0	0	0	0	0	43.45	0	0	11.6
2015	12	11	4	55	10	34	0	0	0	0	0	0	0	43.43	0	0	11.6
2015	12	11	5	5	10	35	0	0	0	0	0	0	0	43.39	0	0	11.6
2015	12	11	5	15	10	35	0	0	0	0	0	0	0	43.38	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	5	25	10	35	0	0	0	0	0	0	0	43.36	0	0	11.6
2015	12	11	5	35	10	35	0	0	0	0	0	0	0	43.32	0	0	11.6
2015	12	11	5	45	10	34	0	0	0	0	0	0	0	43.29	0	0	11.6
2015	12	11	5	55	10	35	0	0	0	0	0	0	0	43.25	0	0	11.6
2015	12	11	6	5	10	34	0	0	0	0	0	0	0	43.21	0	0	11.6
2015	12	11	6	15	10	35	0	0	0	0	0	0	0	43.16	0	0	11.6
2015	12	11	6	25	10	34	0	0	0	0	0	0	0	43.12	0	0	11.6
2015	12	11	6	35	10	34	0	0	0	0	0	0	0	43.09	0	0	11.6
2015	12	11	6	45	10	35	0	0	0	0	0	0	0	43.05	0	0	11.6
2015	12	11	6	55	10	34	0	0	0	0	0	0	0	43.03	0	0	11.6
2015	12	11	7	5	10	35	0	0	0	0	0	0	0	43.02	0	0	11.6
2015	12	11	7	15	10	35	0	0	0	0	0	0	0	43.02	0	0	11.6
2015	12	11	7	25	10	35	0	0	0	0	0	0	0	43.03	0	0	11.6
2015	12	11	7	35	10	34	0	0	0	0	0	0	0	43.03	0	0	11.6
2015	12	11	7	45	10	35	0	0	0	0	0	0	0	43.03	0	0	11.6
2015	12	11	7	55	10	35	0	0	0	0	0	0	0	43.05	0	0	11.8
2015	12	11	8	5	10	35	0	0	0	0	0	0	0	43.14	0	0	12.4
2015	12	11	8	15	10	34	0	0	0	0	0	0	0	43.09	0	0	11.8
2015	12	11	8	25	10	34	0	0	0	0	0	0	0	43.07	0	0	12.2
2015	12	11	8	35	10	34	0	0	0	0	0	0	0	43.09	0	0	12.8
2015	12	11	8	45	10	35	0	0	0	0	0	0	0	43.07	0	0	13
2015	12	11	8	55	10	35	0	0	0	0	0	0	0	43.05	0	0	13
2015	12	11	9	5	10	34	0	0	0	0	0	0	0	43.09	0	0	13
2015	12	11	9	15	10	35	0	0	0	0	0	0	0	43.09	0	0	13.2
2015	12	11	9	25	10	35	0	0	0	0	0	0	0	43.09	0	0	13.2
2015	12	11	9	35	10	35	0	0	0	0	0	0	0	43.12	0	0	13.2
2015	12	11	9	45	10	35	0	0	0	0	0	0	0	43.14	0	0	13.2
2015	12	11	9	55	10	35	0	0	0	0	0	0	0	43.21	0	0	13.2
2015	12	11	10	5	10	35	0	0	0	0	0	0	0	43.29	0	0	13.2
2015	12	11	10	15	10	35	0	0	0	0	0	0	0	43.36	0	0	13
2015	12	11	10	25	10	35	0	0	0	0	0	0	0	43.45	0	0	12.4
2015	12	11	10	35	10	35	0	0	0	0	0	0	0	43.56	0	0	13
2015	12	11	10	45	10	34	0	0	0	0	0	0	0	43.84	0	0	13
2015	12	11	10	55	10	34	0	0	0	0	0	0	0	44.13	0	0	13
2015	12	11	11	5	10	34	0	0	0	0	0	0	0	44.33	0	0	13
2015	12	11	11	15	10	35	0	0	0	0	0	0	0	44.47	0	0	13
2015	12	11	11	25	10	34	0	0	0	0	0	0	0	44.64	0	0	13
2015	12	11	11	35	10	34	0	0	0	0	0	0	0	44.74	0	0	13
2015	12	11	11	45	10	35	0	0	0	0	0	0	0	44.87	0	0	13
2015	12	11	11	55	10	34	0	0	0	0	0	0	0	45.03	0	0	13
2015	12	11	12	5	10	35	0	0	0	0	0	0	0	45.21	0	0	13
2015	12	11	12	15	10	34	0	0	0	0	0	0	0	45.25	0	0	12.6
2015	12	11	12	25	10	34	0	0	0	0	0	0	0	45.45	0	0	12.6
2015	12	11	12	35	10	35	0	0	0	0	0	0	0	45.61	0	0	13
2015	12	11	12	45	10	35	0	0	0	0	0	0	0	45.73	0	0	13
2015	12	11	12	55	10	34	0	0	0	0	0	0	0	45.84	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	13	5	10	35	0	0	0	0	0	0	0	45.93	0	0	12.8
2015	12	11	13	15	10	35	0	0	0	0	0	0	0	46.06	0	0	13
2015	12	11	13	25	10	34	0	0	0	0	0	0	0	46.22	0	0	12.8
2015	12	11	13	35	10	33	0	0	0	0	0	0	0	46.36	0	0	12.8
2015	12	11	13	45	10	34	0	0	0	0	0	0	0	46.36	0	0	12.2
2015	12	11	13	55	10	34	0	0	0	0	0	0	0	46.35	0	0	12.2
2015	12	11	14	5	10	35	0	0	0	0	0	0	0	46.4	0	0	12.2
2015	12	11	14	15	10	35	0	0	0	0	0	0	0	46.42	0	0	12.2
2015	12	11	14	25	10	35	0	0	0	0	0	0	0	46.45	0	0	12.2
2015	12	11	14	35	10	34	0	0	0	0	0	0	0	46.44	0	0	12.2
2015	12	11	14	45	10	34	0	0	0	0	0	0	0	46.42	0	0	12.2
2015	12	11	14	55	10	35	0	0	0	0	0	0	0	46.42	0	0	12.2
2015	12	11	15	5	10	34	0	0	0	0	0	0	0	46.44	0	0	12.4
2015	12	11	15	15	10	34	0	0	0	0	0	0	0	46.42	0	0	12.4
2015	12	11	15	25	10	34	0	0	0	0	0	0	0	46.4	0	0	12.2
2015	12	11	15	35	10	34	0	0	0	0	0	0	0	46.36	0	0	12.2
2015	12	11	15	45	10	34	0	0	0	0	0	0	0	46.35	0	0	12
2015	12	11	15	55	10	34	0	0	0	0	0	0	0	46.29	0	0	12
2015	12	11	16	5	10	34	0	0	0	0	0	0	0	46.26	0	0	12
2015	12	11	16	15	10	33	0	0	0	0	0	0	0	46.2	0	0	12
2015	12	11	16	25	10	34	0	0	0	0	0	0	0	46.15	0	0	12
2015	12	11	16	35	10	34	0	0	0	0	0	0	0	46.08	0	0	12
2015	12	11	16	45	10	34	0	0	0	0	0	0	0	46.02	0	0	12
2015	12	11	16	55	10	34	0	0	0	0	0	0	0	45.95	0	0	11.8
2015	12	11	17	5	10	34	0	0	0	0	0	0	0	45.86	0	0	11.8
2015	12	11	17	15	10	35	0	0	0	0	0	0	0	45.79	0	0	11.8
2015	12	11	17	25	10	35	0	0	0	0	0	0	0	45.73	0	0	11.8
2015	12	11	17	35	10	34	0	0	0	0	0	0	0	45.66	0	0	11.8
2015	12	11	17	45	10	34	0	0	0	0	0	0	0	45.59	0	0	11.8
2015	12	11	17	55	10	34	0	0	0	0	0	0	0	45.54	0	0	11.8
2015	12	11	18	5	10	34	0	0	0	0	0	0	0	45.48	0	0	11.8
2015	12	11	18	15	10	34	0	0	0	0	0	0	0	45.41	0	0	11.8
2015	12	11	18	25	10	35	0	0	0	0	0	0	0	45.36	0	0	11.8
2015	12	11	18	35	10	35	0	0	0	0	0	0	0	45.3	0	0	11.8
2015	12	11	18	45	10	34	0	0	0	0	0	0	0	45.23	0	0	11.8
2015	12	11	18	55	10	35	0	0	0	0	0	0	0	45.16	0	0	11.8
2015	12	11	19	5	10	34	0	0	0	0	0	0	0	45.09	0	0	11.8
2015	12	11	19	15	10	34	0	0	0	0	0	0	0	45.03	0	0	11.8
2015	12	11	19	25	10	34	0	0	0	0	0	0	0	44.94	0	0	11.8
2015	12	11	19	35	10	34	0	0	0	0	0	0	0	44.87	0	0	11.8
2015	12	11	19	45	10	34	0	0	0	0	0	0	0	44.8	0	0	11.8
2015	12	11	19	55	10	35	0	0	0	0	0	0	0	44.71	0	0	11.8
2015	12	11	20	5	10	34	0	0	0	0	0	0	0	44.64	0	0	11.8
2015	12	11	20	15	10	35	0	0	0	0	0	0	0	44.55	0	0	11.8
2015	12	11	20	25	10	35	0	0	0	0	0	0	0	44.46	0	0	11.8
2015	12	11	20	35	10	35	0	0	0	0	0	0	0	44.37	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	20	45	10	34	0	0	0	0	0	0	0	44.26	0	0	11.8
2015	12	11	20	55	10	35	0	0	0	0	0	0	0	44.17	0	0	11.8
2015	12	11	21	5	10	34	0	0	0	0	0	0	0	44.06	0	0	11.8
2015	12	11	21	15	10	35	0	0	0	0	0	0	0	43.95	0	0	11.8
2015	12	11	21	25	10	34	0	0	0	0	0	0	0	43.83	0	0	11.8
2015	12	11	21	35	10	34	0	0	0	0	0	0	0	43.74	0	0	11.8
2015	12	11	21	45	10	35	0	0	0	0	0	0	0	43.63	0	0	11.8
2015	12	11	21	55	10	34	0	0	0	0	0	0	0	43.52	0	0	11.8
2015	12	11	22	5	10	34	0	0	0	0	0	0	0	43.43	0	0	11.8
2015	12	11	22	15	10	34	0	0	0	0	0	0	0	43.34	0	0	11.8
2015	12	11	22	25	10	35	0	0	0	0	0	0	0	43.23	0	0	11.8
2015	12	11	22	35	10	34	0	0	0	0	0	0	0	43.14	0	0	11.8
2015	12	11	22	45	10	34	0	0	0	0	0	0	0	43.05	0	0	11.8
2015	12	11	22	55	10	35	0	0	0	0	0	0	0	42.96	0	0	11.8
2015	12	11	23	5	10	35	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	11	23	15	10	35	0	0	0	0	0	0	0	42.78	0	0	11.8
2015	12	11	23	25	10	35	0	0	0	0	0	0	0	42.69	0	0	11.8
2015	12	11	23	35	10	35	0	0	0	0	0	0	0	42.6	0	0	11.6
2015	12	11	23	45	10	35	0	0	0	0	0	0	0	42.49	0	0	11.6
2015	12	11	23	55	10	34	0	0	0	0	0	0	0	42.4	0	0	11.6
2015	12	12	0	5	10	34	0	0	0	0	0	0	0	42.31	0	0	11.6
2015	12	12	0	15	10	34	0	0	0	0	0	0	0	42.22	0	0	11.6
2015	12	12	0	25	10	35	0	0	0	0	0	0	0	42.13	0	0	11.6
2015	12	12	0	35	10	35	0	0	0	0	0	0	0	42.04	0	0	11.6
2015	12	12	0	45	10	35	0	0	0	0	0	0	0	41.95	0	0	11.6
2015	12	12	0	55	10	34	0	0	0	0	0	0	0	41.86	0	0	11.6
2015	12	12	1	5	10	34	0	0	0	0	0	0	0	41.77	0	0	11.6
2015	12	12	1	15	10	35	0	0	0	0	0	0	0	41.7	0	0	11.6
2015	12	12	1	25	10	35	0	0	0	0	0	0	0	41.61	0	0	11.6
2015	12	12	1	35	10	36	0	0	0	0	0	0	0	41.54	0	0	11.6
2015	12	12	1	45	10	34	0	0	0	0	0	0	0	41.45	0	0	11.6
2015	12	12	1	55	10	35	0	0	0	0	0	0	0	41.4	0	0	11.6
2015	12	12	2	5	10	35	0	0	0	0	0	0	0	41.31	0	0	11.6
2015	12	12	2	15	10	35	0	0	0	0	0	0	0	41.23	0	0	11.6
2015	12	12	2	25	10	35	0	0	0	0	0	0	0	41.18	0	0	11.6
2015	12	12	2	35	10	35	0	0	0	0	0	0	0	41.11	0	0	11.6
2015	12	12	2	45	10	35	0	0	0	0	0	0	0	41.05	0	0	11.6
2015	12	12	2	55	10	34	0	0	0	0	0	0	0	40.98	0	0	11.6
2015	12	12	3	5	10	35	0	0	0	0	0	0	0	40.93	0	0	11.6
2015	12	12	3	15	10	34	0	0	0	0	0	0	0	40.87	0	0	11.6
2015	12	12	3	25	10	34	0	0	0	0	0	0	0	40.82	0	0	11.6
2015	12	12	3	35	10	35	0	0	0	0	0	0	0	40.77	0	0	11.6
2015	12	12	3	45	10	35	0	0	0	0	0	0	0	40.71	0	0	11.6
2015	12	12	3	55	10	35	0	0	0	0	0	0	0	40.66	0	0	11.6
2015	12	12	4	5	10	35	0	0	0	0	0	0	0	40.6	0	0	11.6
2015	12	12	4	15	10	34	0	0	0	0	0	0	0	40.57	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	4	25	10	35	0	0	0	0	0	0	0	40.5	0	0	11.6
2015	12	12	4	35	10	34	0	0	0	0	0	0	0	40.48	0	0	11.6
2015	12	12	4	45	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	12	4	55	10	35	0	0	0	0	0	0	0	40.39	0	0	11.6
2015	12	12	5	5	10	35	0	0	0	0	0	0	0	40.35	0	0	11.6
2015	12	12	5	15	10	36	0	0	0	0	0	0	0	40.32	0	0	11.6
2015	12	12	5	25	10	36	0	0	0	0	0	0	0	40.26	0	0	11.6
2015	12	12	5	35	10	35	0	0	0	0	0	0	0	40.23	0	0	11.6
2015	12	12	5	45	10	35	0	0	0	0	0	0	0	40.19	0	0	11.6
2015	12	12	5	55	10	35	0	0	0	0	0	0	0	40.15	0	0	11.6
2015	12	12	6	5	10	34	0	0	0	0	0	0	0	40.12	0	0	11.6
2015	12	12	6	15	10	35	0	0	0	0	0	0	0	40.1	0	0	11.6
2015	12	12	6	25	10	34	0	0	0	0	0	0	0	40.06	0	0	11.6
2015	12	12	6	35	10	35	0	0	0	0	0	0	0	40.03	0	0	11.6
2015	12	12	6	45	10	35	0	0	0	0	0	0	0	39.99	0	0	11.6
2015	12	12	6	55	10	35	0	0	0	0	0	0	0	39.96	0	0	11.6
2015	12	12	7	5	10	35	0	0	0	0	0	0	0	39.94	0	0	11.6
2015	12	12	7	15	10	35	0	0	0	0	0	0	0	39.9	0	0	11.6
2015	12	12	7	25	10	35	0	0	0	0	0	0	0	39.88	0	0	11.6
2015	12	12	7	35	10	35	0	0	0	0	0	0	0	39.85	0	0	12
2015	12	12	7	45	10	35	0	0	0	0	0	0	0	39.83	0	0	12.4
2015	12	12	7	55	10	35	0	0	0	0	0	0	0	39.79	0	0	12.6
2015	12	12	8	5	10	35	0	0	0	0	0	0	0	39.78	0	0	12.8
2015	12	12	8	15	10	35	0	0	0	0	0	0	0	39.74	0	0	13
2015	12	12	8	25	10	35	0	0	0	0	0	0	0	39.7	0	0	13
2015	12	12	8	35	10	35	0	0	0	0	0	0	0	39.7	0	0	13
2015	12	12	8	45	10	35	0	0	0	0	0	0	0	39.67	0	0	13
2015	12	12	8	55	10	35	0	0	0	0	0	0	0	39.67	0	0	13.2
2015	12	12	9	5	10	35	0	0	0	0	0	0	0	39.65	0	0	13.2
2015	12	12	9	15	10	36	0	0	0	0	0	0	0	39.67	0	0	13.2
2015	12	12	9	25	10	35	0	0	0	0	0	0	0	39.65	0	0	13.2
2015	12	12	9	35	10	36	0	0	0	0	0	0	0	39.69	0	0	13.2
2015	12	12	9	45	10	35	0	0	0	0	0	0	0	39.7	0	0	13.2
2015	12	12	9	55	10	35	0	0	0	0	0	0	0	39.76	0	0	13.2
2015	12	12	10	5	10	34	0	0	0	0	0	0	0	39.81	0	0	13.2
2015	12	12	10	15	10	35	0	0	0	0	0	0	0	39.87	0	0	13.2
2015	12	12	10	25	10	35	0	0	0	0	0	0	0	39.94	0	0	13.2
2015	12	12	10	35	10	35	0	0	0	0	0	0	0	40.05	0	0	13.2
2015	12	12	10	45	10	34	0	0	0	0	0	0	0	40.24	0	0	13.2
2015	12	12	10	55	10	35	0	0	0	0	0	0	0	40.57	0	0	13.2
2015	12	12	11	5	10	35	0	0	0	0	0	0	0	40.77	0	0	13.2
2015	12	12	11	15	10	35	0	0	0	0	0	0	0	40.91	0	0	13.2
2015	12	12	11	25	10	35	0	0	0	0	0	0	0	41.04	0	0	13.2
2015	12	12	11	35	10	35	0	0	0	0	0	0	0	41.18	0	0	13.2
2015	12	12	11	45	10	35	0	0	0	0	0	0	0	41.29	0	0	13.2
2015	12	12	11	55	10	35	0	0	0	0	0	0	0	41.45	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	12	5	10	35	0	0	0	0	0	0	0	41.56	0	0	13.2
2015	12	12	12	15	10	35	0	0	0	0	0	0	0	41.72	0	0	13.2
2015	12	12	12	25	10	35	0	0	0	0	0	0	0	41.81	0	0	13.2
2015	12	12	12	35	10	35	0	0	0	0	0	0	0	41.97	0	0	13.2
2015	12	12	12	45	10	35	0	0	0	0	0	0	0	42.08	0	0	13
2015	12	12	12	55	10	34	0	0	0	0	0	0	0	42.21	0	0	13
2015	12	12	13	5	10	35	0	0	0	0	0	0	0	42.33	0	0	13
2015	12	12	13	15	10	34	0	0	0	0	0	0	0	42.46	0	0	13
2015	12	12	13	25	10	35	0	0	0	0	0	0	0	42.57	0	0	13
2015	12	12	13	35	10	35	0	0	0	0	0	0	0	42.67	0	0	13
2015	12	12	13	45	10	35	0	0	0	0	0	0	0	42.78	0	0	12.8
2015	12	12	13	55	10	35	0	0	0	0	0	0	0	42.91	0	0	12.8
2015	12	12	14	5	10	34	0	0	0	0	0	0	0	42.96	0	0	12.8
2015	12	12	14	15	10	34	0	0	0	0	0	0	0	43.07	0	0	12.8
2015	12	12	14	25	10	35	0	0	0	0	0	0	0	43.12	0	0	12.6
2015	12	12	14	35	10	34	0	0	0	0	0	0	0	43.18	0	0	12.6
2015	12	12	14	45	10	35	0	0	0	0	0	0	0	43.23	0	0	12.4
2015	12	12	14	55	10	34	0	0	0	0	0	0	0	43.25	0	0	12.4
2015	12	12	15	5	10	34	0	0	0	0	0	0	0	43.25	0	0	12.4
2015	12	12	15	15	10	35	0	0	0	0	0	0	0	43.27	0	0	12.2
2015	12	12	15	25	10	35	0	0	0	0	0	0	0	43.25	0	0	12.2
2015	12	12	15	35	10	34	0	0	0	0	0	0	0	43.23	0	0	12
2015	12	12	15	45	10	34	0	0	0	0	0	0	0	43.21	0	0	12.2
2015	12	12	15	55	10	34	0	0	0	0	0	0	0	43.2	0	0	12
2015	12	12	16	5	10	35	0	0	0	0	0	0	0	43.18	0	0	12
2015	12	12	16	15	10	35	0	0	0	0	0	0	0	43.16	0	0	12
2015	12	12	16	25	10	34	0	0	0	0	0	0	0	43.14	0	0	12
2015	12	12	16	35	10	34	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	12	16	45	10	35	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	12	16	55	10	35	0	0	0	0	0	0	0	43.09	0	0	12
2015	12	12	17	5	10	34	0	0	0	0	0	0	0	43.11	0	0	12
2015	12	12	17	15	10	35	0	0	0	0	0	0	0	43.12	0	0	12
2015	12	12	17	25	10	34	0	0	0	0	0	0	0	43.14	0	0	12
2015	12	12	17	35	10	35	0	0	0	0	0	0	0	43.16	0	0	12
2015	12	12	17	45	10	35	0	0	0	0	0	0	0	43.18	0	0	12
2015	12	12	17	55	10	35	0	0	0	0	0	0	0	43.2	0	0	12
2015	12	12	18	5	10	34	0	0	0	0	0	0	0	43.23	0	0	12
2015	12	12	18	15	10	35	0	0	0	0	0	0	0	43.23	0	0	12
2015	12	12	18	25	10	34	0	0	0	0	0	0	0	43.23	0	0	12
2015	12	12	18	35	10	35	0	0	0	0	0	0	0	43.21	0	0	11.8
2015	12	12	18	45	10	35	0	0	0	0	0	0	0	43.21	0	0	11.8
2015	12	12	18	55	10	34	0	0	0	0	0	0	0	43.2	0	0	11.8
2015	12	12	19	5	10	35	0	0	0	0	0	0	0	43.18	0	0	11.8
2015	12	12	19	15	10	35	0	0	0	0	0	0	0	43.14	0	0	11.8
2015	12	12	19	25	10	35	0	0	0	0	0	0	0	43.11	0	0	11.8
2015	12	12	19	35	10	34	0	0	0	0	0	0	0	43.07	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	19	45	10	35	0	0	0	0	0	0	0	43.02	0	0	11.8
2015	12	12	19	55	10	34	0	0	0	0	0	0	0	42.98	0	0	11.8
2015	12	12	20	5	10	35	0	0	0	0	0	0	0	42.93	0	0	11.8
2015	12	12	20	15	10	34	0	0	0	0	0	0	0	42.89	0	0	11.8
2015	12	12	20	25	10	35	0	0	0	0	0	0	0	42.82	0	0	11.8
2015	12	12	20	35	10	35	0	0	0	0	0	0	0	42.76	0	0	11.8
2015	12	12	20	45	10	35	0	0	0	0	0	0	0	42.69	0	0	11.8
2015	12	12	20	55	10	35	0	0	0	0	0	0	0	42.62	0	0	11.8
2015	12	12	21	5	10	34	0	0	0	0	0	0	0	42.55	0	0	11.8
2015	12	12	21	15	10	35	0	0	0	0	0	0	0	42.48	0	0	11.8
2015	12	12	21	25	10	35	0	0	0	0	0	0	0	42.4	0	0	11.8
2015	12	12	21	35	10	35	0	0	0	0	0	0	0	42.31	0	0	11.8
2015	12	12	21	45	10	35	0	0	0	0	0	0	0	42.24	0	0	11.8
2015	12	12	21	55	10	35	0	0	0	0	0	0	0	42.15	0	0	11.8
2015	12	12	22	5	10	35	0	0	0	0	0	0	0	42.08	0	0	11.8
2015	12	12	22	15	10	35	0	0	0	0	0	0	0	41.97	0	0	11.8
2015	12	12	22	25	10	35	0	0	0	0	0	0	0	41.88	0	0	11.8
2015	12	12	22	35	10	35	0	0	0	0	0	0	0	41.77	0	0	11.8
2015	12	12	22	45	10	35	0	0	0	0	0	0	0	41.68	0	0	11.8
2015	12	12	22	55	10	35	0	0	0	0	0	0	0	41.59	0	0	11.8
2015	12	12	23	5	10	35	0	0	0	0	0	0	0	41.49	0	0	11.8
2015	12	12	23	15	10	35	0	0	0	0	0	0	0	41.4	0	0	11.8
2015	12	12	23	25	10	35	0	0	0	0	0	0	0	41.29	0	0	11.8
2015	12	12	23	35	10	34	0	0	0	0	0	0	0	41.2	0	0	11.8
2015	12	12	23	45	10	35	0	0	0	0	0	0	0	41.09	0	0	11.8
2015	12	12	23	55	10	35	0	0	0	0	0	0	0	41.02	0	0	11.8
2015	12	13	0	5	10	35	0	0	0	0	0	0	0	40.93	0	0	11.8
2015	12	13	0	15	10	35	0	0	0	0	0	0	0	40.84	0	0	11.8
2015	12	13	0	25	10	34	0	0	0	0	0	0	0	40.77	0	0	11.8
2015	12	13	0	35	10	35	0	0	0	0	0	0	0	40.69	0	0	11.8
2015	12	13	0	45	10	35	0	0	0	0	0	0	0	40.64	0	0	11.8
2015	12	13	0	55	10	35	0	0	0	0	0	0	0	40.55	0	0	11.8
2015	12	13	1	5	10	35	0	0	0	0	0	0	0	40.5	0	0	11.8
2015	12	13	1	15	10	35	0	0	0	0	0	0	0	40.44	0	0	11.8
2015	12	13	1	25	10	35	0	0	0	0	0	0	0	40.37	0	0	11.8
2015	12	13	1	35	10	35	0	0	0	0	0	0	0	40.32	0	0	11.6
2015	12	13	1	45	10	35	0	0	0	0	0	0	0	40.24	0	0	11.6
2015	12	13	1	55	10	35	0	0	0	0	0	0	0	40.19	0	0	11.6
2015	12	13	2	5	10	35	0	0	0	0	0	0	0	40.14	0	0	11.6
2015	12	13	2	15	10	35	0	0	0	0	0	0	0	40.06	0	0	11.6
2015	12	13	2	25	10	36	0	0	0	0	0	0	0	40.01	0	0	11.6
2015	12	13	2	35	10	35	0	0	0	0	0	0	0	39.96	0	0	11.6
2015	12	13	2	45	10	34	0	0	0	0	0	0	0	39.9	0	0	11.6
2015	12	13	2	55	10	36	0	0	0	0	0	0	0	39.87	0	0	11.6
2015	12	13	3	5	10	35	0	0	0	0	0	0	0	39.81	0	0	11.6
2015	12	13	3	15	10	34	0	0	0	0	0	0	0	39.78	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	3	25	10	35	0	0	0	0	0	0	0	39.72	0	0	11.6
2015	12	13	3	35	10	35	0	0	0	0	0	0	0	39.67	0	0	11.6
2015	12	13	3	45	10	35	0	0	0	0	0	0	0	39.63	0	0	11.6
2015	12	13	3	55	10	35	0	0	0	0	0	0	0	39.6	0	0	11.6
2015	12	13	4	5	10	35	0	0	0	0	0	0	0	39.54	0	0	11.6
2015	12	13	4	15	10	34	0	0	0	0	0	0	0	39.51	0	0	11.6
2015	12	13	4	25	10	35	0	0	0	0	0	0	0	39.47	0	0	11.6
2015	12	13	4	35	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	13	4	45	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	13	4	55	10	34	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	13	5	5	10	35	0	0	0	0	0	0	0	39.34	0	0	11.6
2015	12	13	5	15	10	35	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	13	5	25	10	35	0	0	0	0	0	0	0	39.27	0	0	11.6
2015	12	13	5	35	10	35	0	0	0	0	0	0	0	39.24	0	0	11.6
2015	12	13	5	45	10	35	0	0	0	0	0	0	0	39.22	0	0	11.6
2015	12	13	5	55	10	35	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	13	6	5	10	35	0	0	0	0	0	0	0	39.16	0	0	11.6
2015	12	13	6	15	10	35	0	0	0	0	0	0	0	39.13	0	0	11.6
2015	12	13	6	25	10	35	0	0	0	0	0	0	0	39.11	0	0	11.6
2015	12	13	6	35	10	35	0	0	0	0	0	0	0	39.07	0	0	11.6
2015	12	13	6	45	10	35	0	0	0	0	0	0	0	39.06	0	0	11.6
2015	12	13	6	55	10	35	0	0	0	0	0	0	0	39.04	0	0	11.6
2015	12	13	7	5	10	35	0	0	0	0	0	0	0	39.02	0	0	11.6
2015	12	13	7	15	10	35	0	0	0	0	0	0	0	39	0	0	11.6
2015	12	13	7	25	10	35	0	0	0	0	0	0	0	38.98	0	0	11.6
2015	12	13	7	35	10	35	0	0	0	0	0	0	0	38.97	0	0	11.8
2015	12	13	7	45	10	35	0	0	0	0	0	0	0	38.97	0	0	12.4
2015	12	13	7	55	10	35	0	0	0	0	0	0	0	38.95	0	0	12.8
2015	12	13	8	5	10	36	0	0	0	0	0	0	0	38.93	0	0	12.8
2015	12	13	8	15	10	35	0	0	0	0	0	0	0	38.91	0	0	13
2015	12	13	8	25	10	35	0	0	0	0	0	0	0	38.89	0	0	13
2015	12	13	8	35	10	35	0	0	0	0	0	0	0	38.91	0	0	13.2
2015	12	13	8	45	10	35	0	0	0	0	0	0	0	38.89	0	0	13.2
2015	12	13	8	55	10	35	0	0	0	0	0	0	0	38.91	0	0	13.2
2015	12	13	9	5	10	35	0	0	0	0	0	0	0	38.95	0	0	13.2
2015	12	13	9	15	10	35	0	0	0	0	0	0	0	38.98	0	0	13.2
2015	12	13	9	25	10	35	0	0	0	0	0	0	0	39	0	0	13.2
2015	12	13	9	35	10	35	0	0	0	0	0	0	0	39.04	0	0	13
2015	12	13	9	45	10	35	0	0	0	0	0	0	0	39.11	0	0	13.2
2015	12	13	9	55	10	35	0	0	0	0	0	0	0	39.22	0	0	13.2
2015	12	13	10	5	10	35	0	0	0	0	0	0	0	39.34	0	0	13.2
2015	12	13	10	15	10	35	0	0	0	0	0	0	0	39.4	0	0	13
2015	12	13	10	25	10	35	0	0	0	0	0	0	0	39.49	0	0	13.4
2015	12	13	10	35	10	35	0	0	0	0	0	0	0	39.61	0	0	13.4
2015	12	13	10	45	10	35	0	0	0	0	0	0	0	39.83	0	0	13.4
2015	12	13	10	55	10	35	0	0	0	0	0	0	0	40.23	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	11	5	10	35	0	0	0	0	0	0	0	40.23	0	0	12.6
2015	12	13	11	15	10	36	0	0	0	0	0	0	0	40.46	0	0	13
2015	12	13	11	25	10	35	0	0	0	0	0	0	0	40.64	0	0	13.2
2015	12	13	11	35	10	34	0	0	0	0	0	0	0	40.84	0	0	13.2
2015	12	13	11	45	10	35	0	0	0	0	0	0	0	40.98	0	0	13
2015	12	13	11	55	10	35	0	0	0	0	0	0	0	40.98	0	0	12.6
2015	12	13	12	5	10	35	0	0	0	0	0	0	0	41.05	0	0	12.6
2015	12	13	12	15	10	35	0	0	0	0	0	0	0	41.14	0	0	12.4
2015	12	13	12	25	10	35	0	0	0	0	0	0	0	41.2	0	0	12.4
2015	12	13	12	35	10	35	0	0	0	0	0	0	0	41.27	0	0	12.2
2015	12	13	12	45	10	35	0	0	0	0	0	0	0	41.38	0	0	12.2
2015	12	13	12	55	10	35	0	0	0	0	0	0	0	41.41	0	0	12.2
2015	12	13	13	5	10	35	0	0	0	0	0	0	0	41.5	0	0	12.2
2015	12	13	13	15	10	35	0	0	0	0	0	0	0	41.49	0	0	12
2015	12	13	13	25	10	35	0	0	0	0	0	0	0	41.5	0	0	12
2015	12	13	13	35	10	35	0	0	0	0	0	0	0	41.52	0	0	12
2015	12	13	13	45	10	35	0	0	0	0	0	0	0	41.54	0	0	12
2015	12	13	13	55	10	35	0	0	0	0	0	0	0	41.58	0	0	12
2015	12	13	14	5	10	35	0	0	0	0	0	0	0	41.63	0	0	12
2015	12	13	14	15	10	34	0	0	0	0	0	0	0	41.67	0	0	12
2015	12	13	14	25	10	35	0	0	0	0	0	0	0	41.7	0	0	12
2015	12	13	14	35	10	35	0	0	0	0	0	0	0	41.72	0	0	12
2015	12	13	14	45	10	35	0	0	0	0	0	0	0	41.76	0	0	12
2015	12	13	14	55	10	35	0	0	0	0	0	0	0	41.79	0	0	12
2015	12	13	15	5	10	35	0	0	0	0	0	0	0	41.83	0	0	12
2015	12	13	15	15	10	35	0	0	0	0	0	0	0	41.85	0	0	12
2015	12	13	15	25	10	35	0	0	0	0	0	0	0	41.9	0	0	12
2015	12	13	15	35	10	35	0	0	0	0	0	0	0	41.92	0	0	12
2015	12	13	15	45	10	34	0	0	0	0	0	0	0	41.95	0	0	12
2015	12	13	15	55	10	35	0	0	0	0	0	0	0	41.99	0	0	11.8
2015	12	13	16	5	10	34	0	0	0	0	0	0	0	42.03	0	0	11.8
2015	12	13	16	15	10	35	0	0	0	0	0	0	0	42.06	0	0	11.8
2015	12	13	16	25	10	35	0	0	0	0	0	0	0	42.1	0	0	11.8
2015	12	13	16	35	10	35	0	0	0	0	0	0	0	42.13	0	0	11.8
2015	12	13	16	45	10	35	0	0	0	0	0	0	0	42.17	0	0	11.8
2015	12	13	16	55	10	35	0	0	0	0	0	0	0	42.21	0	0	11.8
2015	12	13	17	5	10	35	0	0	0	0	0	0	0	42.24	0	0	11.8
2015	12	13	17	15	10	34	0	0	0	0	0	0	0	42.28	0	0	11.8
2015	12	13	17	25	10	35	0	0	0	0	0	0	0	42.3	0	0	11.8
2015	12	13	17	35	10	35	0	0	0	0	0	0	0	42.31	0	0	11.8
2015	12	13	17	45	10	34	0	0	0	0	0	0	0	42.33	0	0	11.8
2015	12	13	17	55	10	34	0	0	0	0	0	0	0	42.35	0	0	11.8
2015	12	13	18	5	10	35	0	0	0	0	0	0	0	42.37	0	0	11.8
2015	12	13	18	15	10	35	0	0	0	0	0	0	0	42.37	0	0	11.8
2015	12	13	18	25	10	34	0	0	0	0	0	0	0	42.35	0	0	11.8
2015	12	13	18	35	10	35	0	0	0	0	0	0	0	42.35	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	18	45	10	35	0	0	0	0	0	0	0	42.33	0	0	11.8
2015	12	13	18	55	10	35	0	0	0	0	0	0	0	42.33	0	0	11.8
2015	12	13	19	5	10	35	0	0	0	0	0	0	0	42.3	0	0	11.8
2015	12	13	19	15	10	35	0	0	0	0	0	0	0	42.3	0	0	11.8
2015	12	13	19	25	10	34	0	0	0	0	0	0	0	42.28	0	0	11.8
2015	12	13	19	35	10	35	0	0	0	0	0	0	0	42.24	0	0	11.8
2015	12	13	19	45	10	35	0	0	0	0	0	0	0	42.21	0	0	11.8
2015	12	13	19	55	10	35	0	0	0	0	0	0	0	42.17	0	0	11.8
2015	12	13	20	5	10	35	0	0	0	0	0	0	0	42.13	0	0	11.8
2015	12	13	20	15	10	34	0	0	0	0	0	0	0	42.08	0	0	11.8
2015	12	13	20	25	10	35	0	0	0	0	0	0	0	42.03	0	0	11.8
2015	12	13	20	35	10	35	0	0	0	0	0	0	0	41.99	0	0	11.8
2015	12	13	20	45	10	35	0	0	0	0	0	0	0	41.92	0	0	11.8
2015	12	13	20	55	10	35	0	0	0	0	0	0	0	41.86	0	0	11.8
2015	12	13	21	5	10	35	0	0	0	0	0	0	0	41.81	0	0	11.6
2015	12	13	21	15	10	35	0	0	0	0	0	0	0	41.76	0	0	11.6
2015	12	13	21	25	10	34	0	0	0	0	0	0	0	41.7	0	0	11.6
2015	12	13	21	35	10	35	0	0	0	0	0	0	0	41.63	0	0	11.6
2015	12	13	21	45	10	35	0	0	0	0	0	0	0	41.58	0	0	11.6
2015	12	13	21	55	10	35	0	0	0	0	0	0	0	41.5	0	0	11.6
2015	12	13	22	5	10	35	0	0	0	0	0	0	0	41.45	0	0	11.6
2015	12	13	22	15	10	35	0	0	0	0	0	0	0	41.4	0	0	11.6
2015	12	13	22	25	10	35	0	0	0	0	0	0	0	41.34	0	0	11.6
2015	12	13	22	35	10	35	0	0	0	0	0	0	0	41.29	0	0	11.6
2015	12	13	22	45	10	35	0	0	0	0	0	0	0	41.25	0	0	11.6
2015	12	13	22	55	10	35	0	0	0	0	0	0	0	41.2	0	0	11.6
2015	12	13	23	5	10	35	0	0	0	0	0	0	0	41.14	0	0	11.6
2015	12	13	23	15	10	35	0	0	0	0	0	0	0	41.09	0	0	11.6
2015	12	13	23	25	10	35	0	0	0	0	0	0	0	41.04	0	0	11.6
2015	12	13	23	35	10	35	0	0	0	0	0	0	0	40.98	0	0	11.6
2015	12	13	23	45	10	36	0	0	0	0	0	0	0	40.95	0	0	11.6
2015	12	13	23	55	10	35	0	0	0	0	0	0	0	40.91	0	0	11.6
2015	12	14	0	5	10	35	0	0	0	0	0	0	0	40.87	0	0	11.6
2015	12	14	0	15	10	35	0	0	0	0	0	0	0	40.82	0	0	11.6
2015	12	14	0	25	10	35	0	0	0	0	0	0	0	40.8	0	0	11.6
2015	12	14	0	35	10	34	0	0	0	0	0	0	0	40.77	0	0	11.6
2015	12	14	0	45	10	35	0	0	0	0	0	0	0	40.73	0	0	11.6
2015	12	14	0	55	10	35	0	0	0	0	0	0	0	40.68	0	0	11.6
2015	12	14	1	5	10	35	0	0	0	0	0	0	0	40.62	0	0	11.6
2015	12	14	1	15	10	35	0	0	0	0	0	0	0	40.55	0	0	11.6
2015	12	14	1	25	10	35	0	0	0	0	0	0	0	40.5	0	0	11.6
2015	12	14	1	35	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	14	1	45	10	34	0	0	0	0	0	0	0	40.37	0	0	11.6
2015	12	14	1	55	10	35	0	0	0	0	0	0	0	40.3	0	0	11.6
2015	12	14	2	5	10	35	0	0	0	0	0	0	0	40.24	0	0	11.6
2015	12	14	2	15	10	35	0	0	0	0	0	0	0	40.17	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	2	25	10	35	0	0	0	0	0	0	0	40.1	0	0	11.6
2015	12	14	2	35	10	36	0	0	0	0	0	0	0	40.05	0	0	11.6
2015	12	14	2	45	10	35	0	0	0	0	0	0	0	39.97	0	0	11.6
2015	12	14	2	55	10	35	0	0	0	0	0	0	0	39.92	0	0	11.6
2015	12	14	3	5	10	35	0	0	0	0	0	0	0	39.87	0	0	11.6
2015	12	14	3	15	10	35	0	0	0	0	0	0	0	39.81	0	0	11.6
2015	12	14	3	25	10	34	0	0	0	0	0	0	0	39.74	0	0	11.6
2015	12	14	3	35	10	36	0	0	0	0	0	0	0	39.69	0	0	11.6
2015	12	14	3	45	10	35	0	0	0	0	0	0	0	39.63	0	0	11.6
2015	12	14	3	55	10	35	0	0	0	0	0	0	0	39.58	0	0	11.6
2015	12	14	4	5	10	35	0	0	0	0	0	0	0	39.52	0	0	11.6
2015	12	14	4	15	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	14	4	25	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	14	4	35	10	36	0	0	0	0	0	0	0	39.36	0	0	11.6
2015	12	14	4	45	10	36	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	14	4	55	10	35	0	0	0	0	0	0	0	39.27	0	0	11.6
2015	12	14	5	5	10	35	0	0	0	0	0	0	0	39.22	0	0	11.6
2015	12	14	5	15	10	35	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	14	5	25	10	35	0	0	0	0	0	0	0	39.13	0	0	11.6
2015	12	14	5	35	10	36	0	0	0	0	0	0	0	39.09	0	0	11.6
2015	12	14	5	45	10	35	0	0	0	0	0	0	0	39.02	0	0	11.6
2015	12	14	5	55	10	35	0	0	0	0	0	0	0	38.98	0	0	11.6
2015	12	14	6	5	10	34	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	14	6	15	10	35	0	0	0	0	0	0	0	38.89	0	0	11.6
2015	12	14	6	25	10	35	0	0	0	0	0	0	0	38.84	0	0	11.6
2015	12	14	6	35	10	35	0	0	0	0	0	0	0	38.8	0	0	11.6
2015	12	14	6	45	10	35	0	0	0	0	0	0	0	38.75	0	0	11.6
2015	12	14	6	55	10	35	0	0	0	0	0	0	0	38.71	0	0	11.6
2015	12	14	7	5	10	36	0	0	0	0	0	0	0	38.68	0	0	11.6
2015	12	14	7	15	10	35	0	0	0	0	0	0	0	38.64	0	0	11.6
2015	12	14	7	25	10	35	0	0	0	0	0	0	0	38.61	0	0	11.6
2015	12	14	7	35	10	36	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	14	7	45	10	36	0	0	0	0	0	0	0	38.53	0	0	12.4
2015	12	14	7	55	10	36	0	0	0	0	0	0	0	38.5	0	0	12.6
2015	12	14	8	5	10	36	0	0	0	0	0	0	0	38.46	0	0	12.8
2015	12	14	8	15	10	35	0	0	0	0	0	0	0	38.43	0	0	13
2015	12	14	8	25	10	35	0	0	0	0	0	0	0	38.37	0	0	13
2015	12	14	8	35	10	36	0	0	0	0	0	0	0	38.35	0	0	13
2015	12	14	8	45	10	35	0	0	0	0	0	0	0	38.32	0	0	13.2
2015	12	14	8	55	10	35	0	0	0	0	0	0	0	38.28	0	0	13.2
2015	12	14	9	5	10	35	0	0	0	0	0	0	0	38.26	0	0	13.2
2015	12	14	9	15	10	35	0	0	0	0	0	0	0	38.23	0	0	13.2
2015	12	14	9	25	10	36	0	0	0	0	0	0	0	38.25	0	0	13.2
2015	12	14	9	35	10	36	0	0	0	0	0	0	0	38.23	0	0	13.2
2015	12	14	9	45	10	35	0	0	0	0	0	0	0	38.25	0	0	13.2
2015	12	14	9	55	10	35	0	0	0	0	0	0	0	38.26	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	10	5	10	35	0	0	0	0	0	0	0	38.28	0	0	13.2
2015	12	14	10	15	10	35	0	0	0	0	0	0	0	38.34	0	0	13.2
2015	12	14	10	25	10	36	0	0	0	0	0	0	0	38.37	0	0	13.2
2015	12	14	10	35	10	35	0	0	0	0	0	0	0	38.44	0	0	13.4
2015	12	14	10	45	10	35	0	0	0	0	0	0	0	38.55	0	0	13.4
2015	12	14	10	55	10	35	0	0	0	0	0	0	0	38.91	0	0	13.4
2015	12	14	11	5	10	35	0	0	0	0	0	0	0	39.15	0	0	13.4
2015	12	14	11	15	10	35	0	0	0	0	0	0	0	39.29	0	0	13.4
2015	12	14	11	25	10	35	0	0	0	0	0	0	0	39.47	0	0	13.4
2015	12	14	11	35	10	35	0	0	0	0	0	0	0	39.52	0	0	13.2
2015	12	14	11	45	10	35	0	0	0	0	0	0	0	39.63	0	0	13.2
2015	12	14	11	55	10	35	0	0	0	0	0	0	0	39.78	0	0	13.2
2015	12	14	12	5	10	35	0	0	0	0	0	0	0	39.88	0	0	13.2
2015	12	14	12	15	10	34	0	0	0	0	0	0	0	40.01	0	0	13.2
2015	12	14	12	25	10	35	0	0	0	0	0	0	0	40.08	0	0	13.2
2015	12	14	12	35	10	36	0	0	0	0	0	0	0	40.15	0	0	13.2
2015	12	14	12	45	10	34	0	0	0	0	0	0	0	40.28	0	0	13.2
2015	12	14	12	55	10	35	0	0	0	0	0	0	0	40.33	0	0	13.2
2015	12	14	13	5	10	36	0	0	0	0	0	0	0	40.46	0	0	13.2
2015	12	14	13	15	10	35	0	0	0	0	0	0	0	40.55	0	0	13
2015	12	14	13	25	10	35	0	0	0	0	0	0	0	40.62	0	0	13
2015	12	14	13	35	10	35	0	0	0	0	0	0	0	40.69	0	0	13
2015	12	14	13	45	10	35	0	0	0	0	0	0	0	40.78	0	0	13
2015	12	14	13	55	10	35	0	0	0	0	0	0	0	40.84	0	0	13
2015	12	14	14	5	10	35	0	0	0	0	0	0	0	40.87	0	0	12.8
2015	12	14	14	15	10	35	0	0	0	0	0	0	0	40.93	0	0	12.8
2015	12	14	14	25	10	35	0	0	0	0	0	0	0	40.96	0	0	12.8
2015	12	14	14	35	10	35	0	0	0	0	0	0	0	40.98	0	0	12.6
2015	12	14	14	45	10	34	0	0	0	0	0	0	0	40.98	0	0	12.6
2015	12	14	14	55	10	35	0	0	0	0	0	0	0	41	0	0	12.6
2015	12	14	15	5	10	35	0	0	0	0	0	0	0	40.96	0	0	12.4
2015	12	14	15	15	10	35	0	0	0	0	0	0	0	40.93	0	0	12.4
2015	12	14	15	25	10	35	0	0	0	0	0	0	0	40.87	0	0	12.4
2015	12	14	15	35	10	36	0	0	0	0	0	0	0	40.8	0	0	12.2
2015	12	14	15	45	10	35	0	0	0	0	0	0	0	40.73	0	0	12
2015	12	14	15	55	10	35	0	0	0	0	0	0	0	40.66	0	0	12
2015	12	14	16	5	10	35	0	0	0	0	0	0	0	40.59	0	0	12
2015	12	14	16	15	10	35	0	0	0	0	0	0	0	40.51	0	0	12
2015	12	14	16	25	10	35	0	0	0	0	0	0	0	40.44	0	0	12
2015	12	14	16	35	10	35	0	0	0	0	0	0	0	40.35	0	0	12
2015	12	14	16	45	10	36	0	0	0	0	0	0	0	40.28	0	0	12
2015	12	14	16	55	10	35	0	0	0	0	0	0	0	40.21	0	0	12
2015	12	14	17	5	10	35	0	0	0	0	0	0	0	40.14	0	0	12
2015	12	14	17	15	10	34	0	0	0	0	0	0	0	40.06	0	0	12
2015	12	14	17	25	10	35	0	0	0	0	0	0	0	40.01	0	0	12
2015	12	14	17	35	10	35	0	0	0	0	0	0	0	39.94	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	17	45	10	35	0	0	0	0	0	0	0	39.88	0	0	11.8
2015	12	14	17	55	10	35	0	0	0	0	0	0	0	39.81	0	0	11.8
2015	12	14	18	5	10	35	0	0	0	0	0	0	0	39.74	0	0	11.8
2015	12	14	18	15	10	35	0	0	0	0	0	0	0	39.67	0	0	11.8
2015	12	14	18	25	10	35	0	0	0	0	0	0	0	39.61	0	0	11.8
2015	12	14	18	35	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	14	18	45	10	35	0	0	0	0	0	0	0	39.47	0	0	11.8
2015	12	14	18	55	10	35	0	0	0	0	0	0	0	39.42	0	0	11.8
2015	12	14	19	5	10	35	0	0	0	0	0	0	0	39.34	0	0	11.8
2015	12	14	19	15	10	34	0	0	0	0	0	0	0	39.27	0	0	11.8
2015	12	14	19	25	10	35	0	0	0	0	0	0	0	39.2	0	0	11.8
2015	12	14	19	35	10	35	0	0	0	0	0	0	0	39.13	0	0	11.8
2015	12	14	19	45	10	35	0	0	0	0	0	0	0	39.06	0	0	11.8
2015	12	14	19	55	10	35	0	0	0	0	0	0	0	38.97	0	0	11.8
2015	12	14	20	5	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	14	20	15	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	14	20	25	10	35	0	0	0	0	0	0	0	38.73	0	0	11.8
2015	12	14	20	35	10	34	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	14	20	45	10	35	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	14	20	55	10	36	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	14	21	5	10	35	0	0	0	0	0	0	0	38.37	0	0	11.8
2015	12	14	21	15	10	35	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	14	21	25	10	35	0	0	0	0	0	0	0	38.21	0	0	11.8
2015	12	14	21	35	10	34	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	14	21	45	10	35	0	0	0	0	0	0	0	38.03	0	0	11.8
2015	12	14	21	55	10	35	0	0	0	0	0	0	0	37.92	0	0	11.8
2015	12	14	22	5	10	35	0	0	0	0	0	0	0	37.83	0	0	11.8
2015	12	14	22	15	10	35	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	14	22	25	10	35	0	0	0	0	0	0	0	37.63	0	0	11.8
2015	12	14	22	35	10	35	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	14	22	45	10	35	0	0	0	0	0	0	0	37.45	0	0	11.8
2015	12	14	22	55	10	35	0	0	0	0	0	0	0	37.35	0	0	11.8
2015	12	14	23	5	10	35	0	0	0	0	0	0	0	37.26	0	0	11.8
2015	12	14	23	15	10	36	0	0	0	0	0	0	0	37.15	0	0	11.8
2015	12	14	23	25	10	35	0	0	0	0	0	0	0	37.04	0	0	11.8
2015	12	14	23	35	10	35	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	14	23	45	10	35	0	0	0	0	0	0	0	36.82	0	0	11.8
2015	12	14	23	55	10	36	0	0	0	0	0	0	0	36.73	0	0	11.8
2015	12	15	0	5	10	35	0	0	0	0	0	0	0	36.63	0	0	11.8
2015	12	15	0	15	10	35	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	15	0	25	10	36	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	15	0	35	10	35	0	0	0	0	0	0	0	36.36	0	0	11.8
2015	12	15	0	45	10	35	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	15	0	55	10	36	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	15	1	5	10	36	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	15	1	15	10	35	0	0	0	0	0	0	0	36.01	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	1	25	10	35	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	15	1	35	10	35	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	15	1	45	10	36	0	0	0	0	0	0	0	35.78	0	0	11.6
2015	12	15	1	55	10	35	0	0	0	0	0	0	0	35.69	0	0	11.6
2015	12	15	2	5	10	35	0	0	0	0	0	0	0	35.6	0	0	11.6
2015	12	15	2	15	10	35	0	0	0	0	0	0	0	35.53	0	0	11.6
2015	12	15	2	25	10	35	0	0	0	0	0	0	0	35.44	0	0	11.6
2015	12	15	2	35	10	35	0	0	0	0	0	0	0	35.35	0	0	11.6
2015	12	15	2	45	10	35	0	0	0	0	0	0	0	35.26	0	0	11.6
2015	12	15	2	55	10	35	0	0	0	0	0	0	0	35.19	0	0	11.6
2015	12	15	3	5	10	35	0	0	0	0	0	0	0	35.11	0	0	11.6
2015	12	15	3	15	10	36	0	0	0	0	0	0	0	35.04	0	0	11.6
2015	12	15	3	25	10	35	0	0	0	0	0	0	0	34.95	0	0	11.6
2015	12	15	3	35	10	35	0	0	0	0	0	0	0	34.9	0	0	11.6
2015	12	15	3	45	10	35	0	0	0	0	0	0	0	34.84	0	0	11.6
2015	12	15	3	55	10	36	0	0	0	0	0	0	0	34.79	0	0	11.6
2015	12	15	4	5	10	36	0	0	0	0	0	0	0	34.72	0	0	11.6
2015	12	15	4	15	10	35	0	0	0	0	0	0	0	34.66	0	0	11.6
2015	12	15	4	25	10	35	0	0	0	0	0	0	0	34.61	0	0	11.6
2015	12	15	4	35	10	35	0	0	0	0	0	0	0	34.54	0	0	11.6
2015	12	15	4	45	10	36	0	0	0	0	0	0	0	34.48	0	0	11.6
2015	12	15	4	55	10	37	0	0	0	0	0	0	0	34.43	0	0	11.6
2015	12	15	5	5	10	36	0	0	0	0	0	0	0	34.39	0	0	11.6
2015	12	15	5	15	10	36	0	0	0	0	0	0	0	34.34	0	0	11.6
2015	12	15	5	25	10	35	0	0	0	0	0	0	0	34.29	0	0	11.6
2015	12	15	5	35	10	36	0	0	0	0	0	0	0	34.23	0	0	11.6
2015	12	15	5	45	10	36	0	0	0	0	0	0	0	34.18	0	0	11.6
2015	12	15	5	55	10	36	0	0	0	0	0	0	0	34.14	0	0	11.6
2015	12	15	6	5	10	35	0	0	0	0	0	0	0	34.09	0	0	11.6
2015	12	15	6	15	10	37	0	0	0	0	0	0	0	34.02	0	0	11.6
2015	12	15	6	25	10	36	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	15	6	35	10	35	0	0	0	0	0	0	0	33.93	0	0	11.6
2015	12	15	6	45	10	36	0	0	0	0	0	0	0	33.89	0	0	11.6
2015	12	15	6	55	10	36	0	0	0	0	0	0	0	33.84	0	0	11.6
2015	12	15	7	5	10	36	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	15	7	15	10	35	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	15	7	25	10	36	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	15	7	35	10	36	0	0	0	0	0	0	0	33.71	0	0	11.8
2015	12	15	7	45	10	36	0	0	0	0	0	0	0	33.67	0	0	12.4
2015	12	15	7	55	10	36	0	0	0	0	0	0	0	33.66	0	0	12.6
2015	12	15	8	5	10	36	0	0	0	0	0	0	0	33.64	0	0	12.8
2015	12	15	8	15	10	36	0	0	0	0	0	0	0	33.6	0	0	13
2015	12	15	8	25	10	35	0	0	0	0	0	0	0	33.58	0	0	13
2015	12	15	8	35	10	36	0	0	0	0	0	0	0	33.57	0	0	13
2015	12	15	8	45	10	36	0	0	0	0	0	0	0	33.55	0	0	13.2
2015	12	15	8	55	10	35	0	0	0	0	0	0	0	33.53	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	9	5	10	36	0	0	0	0	0	0	0	33.53	0	0	13.2
2015	12	15	9	15	10	36	0	0	0	0	0	0	0	33.53	0	0	13.2
2015	12	15	9	25	10	35	0	0	0	0	0	0	0	33.51	0	0	13.4
2015	12	15	9	35	10	36	0	0	0	0	0	0	0	33.55	0	0	13.4
2015	12	15	9	45	10	36	0	0	0	0	0	0	0	33.57	0	0	13.4
2015	12	15	9	55	10	35	0	0	0	0	0	0	0	33.58	0	0	13.4
2015	12	15	10	5	10	36	0	0	0	0	0	0	0	33.6	0	0	13.4
2015	12	15	10	15	10	36	0	0	0	0	0	0	0	33.62	0	0	13.4
2015	12	15	10	25	10	36	0	0	0	0	0	0	0	33.67	0	0	13.6
2015	12	15	10	35	10	36	0	0	0	0	0	0	0	33.73	0	0	13.6
2015	12	15	10	45	10	36	0	0	0	0	0	0	0	33.82	0	0	13.6
2015	12	15	10	55	10	36	0	0	0	0	0	0	0	34.2	0	0	13.6
2015	12	15	11	5	10	36	0	0	0	0	0	0	0	34.47	0	0	13.6
2015	12	15	11	15	10	36	0	0	0	0	0	0	0	34.61	0	0	13.6
2015	12	15	11	25	10	36	0	0	0	0	0	0	0	34.65	0	0	13.6
2015	12	15	11	35	10	36	0	0	0	0	0	0	0	34.79	0	0	13.6
2015	12	15	11	45	10	36	0	0	0	0	0	0	0	34.88	0	0	13.6
2015	12	15	11	55	10	35	0	0	0	0	0	0	0	34.9	0	0	13.4
2015	12	15	12	5	10	36	0	0	0	0	0	0	0	34.93	0	0	13.4
2015	12	15	12	15	10	35	0	0	0	0	0	0	0	35.04	0	0	13.4
2015	12	15	12	25	10	36	0	0	0	0	0	0	0	35.15	0	0	13.4
2015	12	15	12	35	10	36	0	0	0	0	0	0	0	35.29	0	0	13.4
2015	12	15	12	45	10	36	0	0	0	0	0	0	0	35.42	0	0	13.4
2015	12	15	12	55	10	35	0	0	0	0	0	0	0	35.55	0	0	13.2
2015	12	15	13	5	10	35	0	0	0	0	0	0	0	35.62	0	0	13.2
2015	12	15	13	15	10	35	0	0	0	0	0	0	0	35.74	0	0	13.2
2015	12	15	13	25	10	35	0	0	0	0	0	0	0	35.8	0	0	13.2
2015	12	15	13	35	10	36	0	0	0	0	0	0	0	35.91	0	0	13
2015	12	15	13	45	10	36	0	0	0	0	0	0	0	36.01	0	0	13
2015	12	15	13	55	10	36	0	0	0	0	0	0	0	36.05	0	0	13
2015	12	15	14	5	10	35	0	0	0	0	0	0	0	36.12	0	0	13
2015	12	15	14	15	10	35	0	0	0	0	0	0	0	36.18	0	0	12.8
2015	12	15	14	25	10	35	0	0	0	0	0	0	0	36.21	0	0	12.8
2015	12	15	14	35	10	35	0	0	0	0	0	0	0	36.27	0	0	12.8
2015	12	15	14	45	10	36	0	0	0	0	0	0	0	36.27	0	0	12.6
2015	12	15	14	55	10	36	0	0	0	0	0	0	0	36.3	0	0	12.6
2015	12	15	15	5	10	35	0	0	0	0	0	0	0	36.3	0	0	12.6
2015	12	15	15	15	10	36	0	0	0	0	0	0	0	36.27	0	0	12.4
2015	12	15	15	25	10	35	0	0	0	0	0	0	0	36.27	0	0	12.4
2015	12	15	15	35	10	35	0	0	0	0	0	0	0	36.23	0	0	12.2
2015	12	15	15	45	10	35	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	15	15	55	10	35	0	0	0	0	0	0	0	36.16	0	0	12
2015	12	15	16	5	10	35	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	15	16	15	10	35	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	15	16	25	10	35	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	15	16	35	10	35	0	0	0	0	0	0	0	35.98	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	16	45	10	35	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	15	16	55	10	35	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	15	17	5	10	35	0	0	0	0	0	0	0	35.87	0	0	12
2015	12	15	17	15	10	35	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	15	17	25	10	36	0	0	0	0	0	0	0	35.82	0	0	12
2015	12	15	17	35	10	35	0	0	0	0	0	0	0	35.78	0	0	12
2015	12	15	17	45	10	35	0	0	0	0	0	0	0	35.76	0	0	12
2015	12	15	17	55	10	36	0	0	0	0	0	0	0	35.74	0	0	12
2015	12	15	18	5	10	36	0	0	0	0	0	0	0	35.73	0	0	12
2015	12	15	18	15	10	35	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	18	25	10	35	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	18	35	10	36	0	0	0	0	0	0	0	35.65	0	0	12
2015	12	15	18	45	10	35	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	15	18	55	10	35	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	15	19	5	10	35	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	15	19	15	10	35	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	15	19	25	10	35	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	15	19	35	10	36	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	15	19	45	10	36	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	15	19	55	10	35	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	15	20	5	10	35	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	15	20	15	10	35	0	0	0	0	0	0	0	35.38	0	0	11.8
2015	12	15	20	25	10	35	0	0	0	0	0	0	0	35.37	0	0	11.8
2015	12	15	20	35	10	36	0	0	0	0	0	0	0	35.31	0	0	11.8
2015	12	15	20	45	10	36	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	15	20	55	10	35	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	15	21	5	10	36	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	15	21	15	10	36	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	15	21	25	10	35	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	15	21	35	10	36	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	15	21	45	10	35	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	15	21	55	10	35	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	15	22	5	10	36	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	15	22	15	10	36	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	15	22	25	10	35	0	0	0	0	0	0	0	34.7	0	0	11.8
2015	12	15	22	35	10	35	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	15	22	45	10	36	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	15	22	55	10	35	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	15	23	5	10	36	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	15	23	15	10	35	0	0	0	0	0	0	0	34.34	0	0	11.8
2015	12	15	23	25	10	36	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	15	23	35	10	35	0	0	0	0	0	0	0	34.2	0	0	11.8
2015	12	15	23	45	10	36	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	15	23	55	10	36	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	16	0	5	10	35	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	16	0	15	10	36	0	0	0	0	0	0	0	33.89	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	0	25	10	36	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	16	0	35	10	36	0	0	0	0	0	0	0	33.75	0	0	11.8
2015	12	16	0	45	10	35	0	0	0	0	0	0	0	33.69	0	0	11.8
2015	12	16	0	55	10	36	0	0	0	0	0	0	0	33.62	0	0	11.8
2015	12	16	1	5	10	35	0	0	0	0	0	0	0	33.55	0	0	11.8
2015	12	16	1	15	10	36	0	0	0	0	0	0	0	33.49	0	0	11.8
2015	12	16	1	25	10	35	0	0	0	0	0	0	0	33.44	0	0	11.8
2015	12	16	1	35	10	35	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	16	1	45	10	35	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	16	1	55	10	35	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	16	2	5	10	36	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	16	2	15	10	35	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	16	2	25	10	36	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	16	2	35	10	35	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	16	2	45	10	36	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	16	2	55	10	36	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	16	3	5	10	35	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	16	3	15	10	36	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	16	3	25	10	36	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	16	3	35	10	36	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	16	3	45	10	36	0	0	0	0	0	0	0	32.81	0	0	11.8
2015	12	16	3	55	10	36	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	16	4	5	10	36	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	16	4	15	10	35	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	16	4	25	10	36	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	16	4	35	10	35	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	16	4	45	10	35	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	16	4	55	10	36	0	0	0	0	0	0	0	32.63	0	0	11.6
2015	12	16	5	5	10	36	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	16	5	15	10	36	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	16	5	25	10	36	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	16	5	35	10	36	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	16	5	45	10	36	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	16	5	55	10	36	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	16	6	5	10	37	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	16	6	15	10	36	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	16	6	25	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	16	6	35	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	16	6	45	10	35	0	0	0	0	0	0	0	32.43	0	0	11.6
2015	12	16	6	55	10	35	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	16	7	5	10	36	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	16	7	15	10	35	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	16	7	25	10	36	0	0	0	0	0	0	0	32.43	0	0	11.6
2015	12	16	7	35	10	36	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	16	7	45	10	36	0	0	0	0	0	0	0	32.43	0	0	12
2015	12	16	7	55	10	35	0	0	0	0	0	0	0	32.43	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	8	5	10	36	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	16	8	15	10	36	0	0	0	0	0	0	0	32.47	0	0	13
2015	12	16	8	25	10	36	0	0	0	0	0	0	0	32.49	0	0	13
2015	12	16	8	35	10	36	0	0	0	0	0	0	0	32.49	0	0	13.2
2015	12	16	8	45	10	37	0	0	0	0	0	0	0	32.5	0	0	13.2
2015	12	16	8	55	10	36	0	0	0	0	0	0	0	32.52	0	0	13.2
2015	12	16	9	5	10	36	0	0	0	0	0	0	0	32.56	0	0	13.4
2015	12	16	9	15	10	35	0	0	0	0	0	0	0	32.58	0	0	13.4
2015	12	16	9	25	10	36	0	0	0	0	0	0	0	32.59	0	0	13.4
2015	12	16	9	35	10	36	0	0	0	0	0	0	0	32.63	0	0	13.4
2015	12	16	9	45	10	36	0	0	0	0	0	0	0	32.67	0	0	13.4
2015	12	16	9	55	10	36	0	0	0	0	0	0	0	32.7	0	0	13.6
2015	12	16	10	5	10	35	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	16	10	15	10	36	0	0	0	0	0	0	0	32.74	0	0	13.6
2015	12	16	10	25	10	36	0	0	0	0	0	0	0	32.79	0	0	13.6
2015	12	16	10	35	10	36	0	0	0	0	0	0	0	32.85	0	0	13.6
2015	12	16	10	45	10	35	0	0	0	0	0	0	0	32.92	0	0	13.6
2015	12	16	10	55	10	36	0	0	0	0	0	0	0	33.31	0	0	13.6
2015	12	16	11	5	10	35	0	0	0	0	0	0	0	33.44	0	0	13.6
2015	12	16	11	15	10	36	0	0	0	0	0	0	0	33.58	0	0	13.6
2015	12	16	11	25	10	35	0	0	0	0	0	0	0	33.66	0	0	13.6
2015	12	16	11	35	10	36	0	0	0	0	0	0	0	33.8	0	0	13.4
2015	12	16	11	45	10	35	0	0	0	0	0	0	0	33.82	0	0	13.4
2015	12	16	11	55	10	36	0	0	0	0	0	0	0	33.91	0	0	13.4
2015	12	16	12	5	10	36	0	0	0	0	0	0	0	33.94	0	0	13.4
2015	12	16	12	15	10	36	0	0	0	0	0	0	0	34.02	0	0	13.4
2015	12	16	12	25	10	35	0	0	0	0	0	0	0	34.12	0	0	13.4
2015	12	16	12	35	10	35	0	0	0	0	0	0	0	34.2	0	0	13.2
2015	12	16	12	45	10	35	0	0	0	0	0	0	0	34.27	0	0	13.2
2015	12	16	12	55	10	36	0	0	0	0	0	0	0	34.32	0	0	13
2015	12	16	13	5	10	36	0	0	0	0	0	0	0	34.39	0	0	13.2
2015	12	16	13	15	10	36	0	0	0	0	0	0	0	34.47	0	0	13.2
2015	12	16	13	25	10	35	0	0	0	0	0	0	0	34.57	0	0	13.2
2015	12	16	13	35	10	35	0	0	0	0	0	0	0	34.66	0	0	13
2015	12	16	13	45	10	36	0	0	0	0	0	0	0	34.74	0	0	13
2015	12	16	13	55	10	36	0	0	0	0	0	0	0	34.81	0	0	13
2015	12	16	14	5	10	36	0	0	0	0	0	0	0	34.92	0	0	12.8
2015	12	16	14	15	10	35	0	0	0	0	0	0	0	34.99	0	0	12.8
2015	12	16	14	25	10	36	0	0	0	0	0	0	0	35.1	0	0	12.8
2015	12	16	14	35	10	35	0	0	0	0	0	0	0	35.2	0	0	12.8
2015	12	16	14	45	10	36	0	0	0	0	0	0	0	35.29	0	0	12.6
2015	12	16	14	55	10	35	0	0	0	0	0	0	0	35.38	0	0	12.6
2015	12	16	15	5	10	35	0	0	0	0	0	0	0	35.49	0	0	12.4
2015	12	16	15	15	10	36	0	0	0	0	0	0	0	35.56	0	0	12.4
2015	12	16	15	25	10	36	0	0	0	0	0	0	0	35.64	0	0	12.4
2015	12	16	15	35	10	35	0	0	0	0	0	0	0	35.71	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	15	45	10	35	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	16	15	55	10	36	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	16	16	5	10	36	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	16	16	15	10	35	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	16	16	25	10	36	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	16	16	35	10	35	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	16	16	45	10	36	0	0	0	0	0	0	0	36.12	0	0	12
2015	12	16	16	55	10	36	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	16	17	5	10	35	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	16	17	15	10	36	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	16	17	25	10	35	0	0	0	0	0	0	0	36.36	0	0	12
2015	12	16	17	35	10	35	0	0	0	0	0	0	0	36.39	0	0	12
2015	12	16	17	45	10	36	0	0	0	0	0	0	0	36.45	0	0	12
2015	12	16	17	55	10	35	0	0	0	0	0	0	0	36.48	0	0	12
2015	12	16	18	5	10	35	0	0	0	0	0	0	0	36.52	0	0	12
2015	12	16	18	15	10	35	0	0	0	0	0	0	0	36.55	0	0	12
2015	12	16	18	25	10	35	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	16	18	35	10	36	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	16	18	45	10	35	0	0	0	0	0	0	0	36.64	0	0	12
2015	12	16	18	55	10	35	0	0	0	0	0	0	0	36.66	0	0	11.8
2015	12	16	19	5	10	36	0	0	0	0	0	0	0	36.64	0	0	11.8
2015	12	16	19	15	10	35	0	0	0	0	0	0	0	36.66	0	0	11.8
2015	12	16	19	25	10	36	0	0	0	0	0	0	0	36.64	0	0	11.8
2015	12	16	19	35	10	35	0	0	0	0	0	0	0	36.63	0	0	11.8
2015	12	16	19	45	10	35	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	16	19	55	10	35	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	16	20	5	10	35	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	16	20	15	10	35	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	16	20	25	10	35	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	16	20	35	10	35	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	16	20	45	10	35	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	16	20	55	10	35	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	16	21	5	10	36	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	16	21	15	10	36	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	16	21	25	10	35	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	16	21	35	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	16	21	45	10	35	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	16	21	55	10	35	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	16	22	5	10	35	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	16	22	15	10	35	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	16	22	25	10	35	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	16	22	35	10	36	0	0	0	0	0	0	0	35.37	0	0	11.8
2015	12	16	22	45	10	35	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	16	22	55	10	35	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	16	23	5	10	35	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	16	23	15	10	35	0	0	0	0	0	0	0	34.99	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	23	25	10	35	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	16	23	35	10	35	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	16	23	45	10	35	0	0	0	0	0	0	0	34.7	0	0	11.8
2015	12	16	23	55	10	35	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	17	0	5	10	36	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	17	0	15	10	35	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	17	0	25	10	36	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	17	0	35	10	35	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	17	0	45	10	36	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	17	0	55	10	35	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	17	1	5	10	36	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	17	1	15	10	35	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	17	1	25	10	35	0	0	0	0	0	0	0	33.84	0	0	11.6
2015	12	17	1	35	10	35	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	17	1	45	10	36	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	17	1	55	10	35	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	17	2	5	10	36	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	17	2	15	10	36	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	17	2	25	10	36	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	17	2	35	10	35	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	17	2	45	10	36	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	17	2	55	10	35	0	0	0	0	0	0	0	33.37	0	0	11.6
2015	12	17	3	5	10	36	0	0	0	0	0	0	0	33.33	0	0	11.6
2015	12	17	3	15	10	37	0	0	0	0	0	0	0	33.3	0	0	11.6
2015	12	17	3	25	10	35	0	0	0	0	0	0	0	33.28	0	0	11.6
2015	12	17	3	35	10	36	0	0	0	0	0	0	0	33.24	0	0	11.6
2015	12	17	3	45	10	35	0	0	0	0	0	0	0	33.21	0	0	11.6
2015	12	17	3	55	10	36	0	0	0	0	0	0	0	33.17	0	0	11.6
2015	12	17	4	5	10	35	0	0	0	0	0	0	0	33.13	0	0	11.6
2015	12	17	4	15	10	35	0	0	0	0	0	0	0	33.12	0	0	11.6
2015	12	17	4	25	10	35	0	0	0	0	0	0	0	33.1	0	0	11.6
2015	12	17	4	35	10	35	0	0	0	0	0	0	0	33.06	0	0	11.6
2015	12	17	4	45	10	35	0	0	0	0	0	0	0	33.04	0	0	11.6
2015	12	17	4	55	10	36	0	0	0	0	0	0	0	33.03	0	0	11.6
2015	12	17	5	5	10	36	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	17	5	15	10	36	0	0	0	0	0	0	0	32.99	0	0	11.6
2015	12	17	5	25	10	36	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	17	5	35	10	36	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	17	5	45	10	35	0	0	0	0	0	0	0	32.94	0	0	11.6
2015	12	17	5	55	10	36	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	17	6	5	10	35	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	17	6	15	10	36	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	17	6	25	10	35	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	17	6	35	10	36	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	17	6	45	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	17	6	55	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	7	5	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	17	7	15	10	37	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	17	7	25	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	17	7	35	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	17	7	45	10	35	0	0	0	0	0	0	0	32.86	0	0	12.4
2015	12	17	7	55	10	35	0	0	0	0	0	0	0	32.86	0	0	12.8
2015	12	17	8	5	10	36	0	0	0	0	0	0	0	32.85	0	0	13
2015	12	17	8	15	10	36	0	0	0	0	0	0	0	32.88	0	0	13.2
2015	12	17	8	25	10	36	0	0	0	0	0	0	0	32.88	0	0	13.2
2015	12	17	8	35	10	36	0	0	0	0	0	0	0	32.88	0	0	13.2
2015	12	17	8	45	10	35	0	0	0	0	0	0	0	32.9	0	0	13.4
2015	12	17	8	55	10	35	0	0	0	0	0	0	0	32.9	0	0	13.4
2015	12	17	9	5	10	35	0	0	0	0	0	0	0	32.92	0	0	13.4
2015	12	17	9	15	10	36	0	0	0	0	0	0	0	32.95	0	0	13.4
2015	12	17	9	25	10	35	0	0	0	0	0	0	0	32.99	0	0	13.4
2015	12	17	9	35	10	36	0	0	0	0	0	0	0	33.01	0	0	13.4
2015	12	17	9	45	10	35	0	0	0	0	0	0	0	33.04	0	0	13.4
2015	12	17	9	55	10	35	0	0	0	0	0	0	0	33.1	0	0	13.4
2015	12	17	10	5	10	35	0	0	0	0	0	0	0	33.15	0	0	13.4
2015	12	17	10	15	10	36	0	0	0	0	0	0	0	33.21	0	0	13.4
2015	12	17	10	25	10	35	0	0	0	0	0	0	0	33.3	0	0	13.4
2015	12	17	10	35	10	35	0	0	0	0	0	0	0	33.4	0	0	13.4
2015	12	17	10	45	10	35	0	0	0	0	0	0	0	33.55	0	0	13.2
2015	12	17	10	55	10	35	0	0	0	0	0	0	0	33.82	0	0	13.4
2015	12	17	11	5	10	36	0	0	0	0	0	0	0	34.05	0	0	13.6
2015	12	17	11	15	10	36	0	0	0	0	0	0	0	34.2	0	0	13.4
2015	12	17	11	25	10	36	0	0	0	0	0	0	0	34.36	0	0	13.4
2015	12	17	11	35	10	36	0	0	0	0	0	0	0	34.29	0	0	13
2015	12	17	11	45	10	36	0	0	0	0	0	0	0	34.5	0	0	13.6
2015	12	17	11	55	10	36	0	0	0	0	0	0	0	34.66	0	0	13.4
2015	12	17	12	5	10	35	0	0	0	0	0	0	0	34.79	0	0	13.2
2015	12	17	12	15	10	36	0	0	0	0	0	0	0	34.92	0	0	13.4
2015	12	17	12	25	10	36	0	0	0	0	0	0	0	35.08	0	0	13.4
2015	12	17	12	35	10	36	0	0	0	0	0	0	0	35.2	0	0	13.2
2015	12	17	12	45	10	35	0	0	0	0	0	0	0	35.37	0	0	13.2
2015	12	17	12	55	10	36	0	0	0	0	0	0	0	35.53	0	0	13.2
2015	12	17	13	5	10	36	0	0	0	0	0	0	0	35.69	0	0	13.2
2015	12	17	13	15	10	35	0	0	0	0	0	0	0	35.83	0	0	13
2015	12	17	13	25	10	35	0	0	0	0	0	0	0	36.01	0	0	13
2015	12	17	13	35	10	35	0	0	0	0	0	0	0	36.14	0	0	13
2015	12	17	13	45	10	36	0	0	0	0	0	0	0	36.3	0	0	13
2015	12	17	13	55	10	35	0	0	0	0	0	0	0	36.52	0	0	13
2015	12	17	14	5	10	36	0	0	0	0	0	0	0	36.66	0	0	13
2015	12	17	14	15	10	36	0	0	0	0	0	0	0	36.79	0	0	12.8
2015	12	17	14	25	10	35	0	0	0	0	0	0	0	36.93	0	0	12.8
2015	12	17	14	35	10	35	0	0	0	0	0	0	0	37.04	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	14	45	10	35	0	0	0	0	0	0	0	37.17	0	0	12.6
2015	12	17	14	55	10	35	0	0	0	0	0	0	0	37.29	0	0	12.6
2015	12	17	15	5	10	35	0	0	0	0	0	0	0	37.35	0	0	12.2
2015	12	17	15	15	10	35	0	0	0	0	0	0	0	37.44	0	0	12.2
2015	12	17	15	25	10	34	0	0	0	0	0	0	0	37.54	0	0	12.4
2015	12	17	15	35	10	35	0	0	0	0	0	0	0	37.62	0	0	12.2
2015	12	17	15	45	10	35	0	0	0	0	0	0	0	37.65	0	0	12.2
2015	12	17	15	55	10	35	0	0	0	0	0	0	0	37.72	0	0	12
2015	12	17	16	5	10	35	0	0	0	0	0	0	0	37.78	0	0	12
2015	12	17	16	15	10	35	0	0	0	0	0	0	0	37.83	0	0	12
2015	12	17	16	25	10	35	0	0	0	0	0	0	0	37.87	0	0	12
2015	12	17	16	35	10	35	0	0	0	0	0	0	0	37.9	0	0	12
2015	12	17	16	45	10	35	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	17	16	55	10	35	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	17	17	5	10	35	0	0	0	0	0	0	0	38.01	0	0	12
2015	12	17	17	15	10	35	0	0	0	0	0	0	0	38.07	0	0	12
2015	12	17	17	25	10	34	0	0	0	0	0	0	0	38.1	0	0	12
2015	12	17	17	35	10	36	0	0	0	0	0	0	0	38.14	0	0	12
2015	12	17	17	45	10	35	0	0	0	0	0	0	0	38.16	0	0	12
2015	12	17	17	55	10	35	0	0	0	0	0	0	0	38.19	0	0	12
2015	12	17	18	5	10	36	0	0	0	0	0	0	0	38.23	0	0	12
2015	12	17	18	15	10	35	0	0	0	0	0	0	0	38.25	0	0	12
2015	12	17	18	25	10	34	0	0	0	0	0	0	0	38.26	0	0	12
2015	12	17	18	35	10	35	0	0	0	0	0	0	0	38.28	0	0	12
2015	12	17	18	45	10	35	0	0	0	0	0	0	0	38.3	0	0	12
2015	12	17	18	55	10	35	0	0	0	0	0	0	0	38.3	0	0	12
2015	12	17	19	5	10	35	0	0	0	0	0	0	0	38.3	0	0	12
2015	12	17	19	15	10	35	0	0	0	0	0	0	0	38.28	0	0	11.8
2015	12	17	19	25	10	34	0	0	0	0	0	0	0	38.28	0	0	11.8
2015	12	17	19	35	10	35	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	17	19	45	10	35	0	0	0	0	0	0	0	38.19	0	0	11.8
2015	12	17	19	55	10	35	0	0	0	0	0	0	0	38.17	0	0	11.8
2015	12	17	20	5	10	35	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	17	20	15	10	35	0	0	0	0	0	0	0	38.07	0	0	11.8
2015	12	17	20	25	10	35	0	0	0	0	0	0	0	37.99	0	0	11.8
2015	12	17	20	35	10	35	0	0	0	0	0	0	0	37.94	0	0	11.8
2015	12	17	20	45	10	35	0	0	0	0	0	0	0	37.89	0	0	11.8
2015	12	17	20	55	10	35	0	0	0	0	0	0	0	37.81	0	0	11.8
2015	12	17	21	5	10	35	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	17	21	15	10	35	0	0	0	0	0	0	0	37.65	0	0	11.8
2015	12	17	21	25	10	35	0	0	0	0	0	0	0	37.56	0	0	11.8
2015	12	17	21	35	10	35	0	0	0	0	0	0	0	37.49	0	0	11.8
2015	12	17	21	45	10	35	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	17	21	55	10	35	0	0	0	0	0	0	0	37.31	0	0	11.8
2015	12	17	22	5	10	35	0	0	0	0	0	0	0	37.2	0	0	11.8
2015	12	17	22	15	10	36	0	0	0	0	0	0	0	37.11	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	22	25	10	35	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	17	22	35	10	36	0	0	0	0	0	0	0	36.91	0	0	11.8
2015	12	17	22	45	10	35	0	0	0	0	0	0	0	36.81	0	0	11.8
2015	12	17	22	55	10	35	0	0	0	0	0	0	0	36.7	0	0	11.8
2015	12	17	23	5	10	35	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	17	23	15	10	35	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	17	23	25	10	36	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	17	23	35	10	36	0	0	0	0	0	0	0	36.28	0	0	11.8
2015	12	17	23	45	10	36	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	17	23	55	10	35	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	18	0	5	10	35	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	18	0	15	10	35	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	18	0	25	10	35	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	18	0	35	10	34	0	0	0	0	0	0	0	35.65	0	0	11.8
2015	12	18	0	45	10	35	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	18	0	55	10	36	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	18	1	5	10	36	0	0	0	0	0	0	0	35.35	0	0	11.8
2015	12	18	1	15	10	35	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	18	1	25	10	35	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	18	1	35	10	36	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	18	1	45	10	35	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	18	1	55	10	36	0	0	0	0	0	0	0	34.9	0	0	11.6
2015	12	18	2	5	10	36	0	0	0	0	0	0	0	34.83	0	0	11.6
2015	12	18	2	15	10	35	0	0	0	0	0	0	0	34.75	0	0	11.6
2015	12	18	2	25	10	36	0	0	0	0	0	0	0	34.66	0	0	11.6
2015	12	18	2	35	10	35	0	0	0	0	0	0	0	34.61	0	0	11.6
2015	12	18	2	45	10	36	0	0	0	0	0	0	0	34.56	0	0	11.6
2015	12	18	2	55	10	35	0	0	0	0	0	0	0	34.5	0	0	11.6
2015	12	18	3	5	10	35	0	0	0	0	0	0	0	34.45	0	0	11.6
2015	12	18	3	15	10	35	0	0	0	0	0	0	0	34.39	0	0	11.6
2015	12	18	3	25	10	35	0	0	0	0	0	0	0	34.34	0	0	11.6
2015	12	18	3	35	10	35	0	0	0	0	0	0	0	34.3	0	0	11.6
2015	12	18	3	45	10	36	0	0	0	0	0	0	0	34.25	0	0	11.6
2015	12	18	3	55	10	35	0	0	0	0	0	0	0	34.21	0	0	11.6
2015	12	18	4	5	10	36	0	0	0	0	0	0	0	34.18	0	0	11.6
2015	12	18	4	15	10	35	0	0	0	0	0	0	0	34.12	0	0	11.6
2015	12	18	4	25	10	35	0	0	0	0	0	0	0	34.09	0	0	11.6
2015	12	18	4	35	10	35	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	18	4	45	10	36	0	0	0	0	0	0	0	34	0	0	11.6
2015	12	18	4	55	10	35	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	18	5	5	10	35	0	0	0	0	0	0	0	33.91	0	0	11.6
2015	12	18	5	15	10	35	0	0	0	0	0	0	0	33.87	0	0	11.6
2015	12	18	5	25	10	35	0	0	0	0	0	0	0	33.85	0	0	11.6
2015	12	18	5	35	10	36	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	18	5	45	10	35	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	18	5	55	10	35	0	0	0	0	0	0	0	33.73	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	6	5	10	35	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	18	6	15	10	36	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	18	6	25	10	36	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	18	6	35	10	36	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	18	6	45	10	36	0	0	0	0	0	0	0	33.58	0	0	11.6
2015	12	18	6	55	10	35	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	18	7	5	10	36	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	18	7	15	10	35	0	0	0	0	0	0	0	33.53	0	0	11.6
2015	12	18	7	25	10	36	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	18	7	35	10	36	0	0	0	0	0	0	0	33.48	0	0	11.6
2015	12	18	7	45	10	35	0	0	0	0	0	0	0	33.48	0	0	12.4
2015	12	18	7	55	10	36	0	0	0	0	0	0	0	33.48	0	0	12.8
2015	12	18	8	5	10	35	0	0	0	0	0	0	0	33.46	0	0	13
2015	12	18	8	15	10	35	0	0	0	0	0	0	0	33.44	0	0	13
2015	12	18	8	25	10	36	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	18	8	35	10	36	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	18	8	45	10	36	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	18	8	55	10	35	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	18	9	5	10	36	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	18	9	15	10	35	0	0	0	0	0	0	0	33.46	0	0	13.4
2015	12	18	9	25	10	35	0	0	0	0	0	0	0	33.48	0	0	13.4
2015	12	18	9	35	10	36	0	0	0	0	0	0	0	33.49	0	0	13.2
2015	12	18	9	45	10	35	0	0	0	0	0	0	0	33.55	0	0	13.4
2015	12	18	9	55	10	36	0	0	0	0	0	0	0	33.58	0	0	13.4
2015	12	18	10	5	10	35	0	0	0	0	0	0	0	33.62	0	0	13.4
2015	12	18	10	15	10	36	0	0	0	0	0	0	0	33.69	0	0	13.4
2015	12	18	10	25	10	35	0	0	0	0	0	0	0	33.78	0	0	13.4
2015	12	18	10	35	10	36	0	0	0	0	0	0	0	33.85	0	0	13.4
2015	12	18	10	45	10	35	0	0	0	0	0	0	0	33.96	0	0	13.4
2015	12	18	10	55	10	36	0	0	0	0	0	0	0	34.34	0	0	13.4
2015	12	18	11	5	10	36	0	0	0	0	0	0	0	34.57	0	0	13.4
2015	12	18	11	15	10	36	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	18	11	25	10	35	0	0	0	0	0	0	0	34.92	0	0	13.4
2015	12	18	11	35	10	35	0	0	0	0	0	0	0	35.08	0	0	13.4
2015	12	18	11	45	10	35	0	0	0	0	0	0	0	35.22	0	0	13.4
2015	12	18	11	55	10	35	0	0	0	0	0	0	0	35.35	0	0	13.4
2015	12	18	12	5	10	35	0	0	0	0	0	0	0	35.51	0	0	13.2
2015	12	18	12	15	10	36	0	0	0	0	0	0	0	35.67	0	0	13.4
2015	12	18	12	25	10	35	0	0	0	0	0	0	0	35.85	0	0	13.2
2015	12	18	12	35	10	35	0	0	0	0	0	0	0	36.03	0	0	13.2
2015	12	18	12	45	10	35	0	0	0	0	0	0	0	36.14	0	0	13.2
2015	12	18	12	55	10	36	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	18	13	5	10	35	0	0	0	0	0	0	0	36.48	0	0	13.2
2015	12	18	13	15	10	35	0	0	0	0	0	0	0	36.61	0	0	13.2
2015	12	18	13	25	10	35	0	0	0	0	0	0	0	36.81	0	0	13.2
2015	12	18	13	35	10	35	0	0	0	0	0	0	0	36.97	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	13	45	10	35	0	0	0	0	0	0	0	37.09	0	0	13
2015	12	18	13	55	10	35	0	0	0	0	0	0	0	37.24	0	0	13
2015	12	18	14	5	10	35	0	0	0	0	0	0	0	37.38	0	0	13
2015	12	18	14	15	10	34	0	0	0	0	0	0	0	37.51	0	0	12.8
2015	12	18	14	25	10	36	0	0	0	0	0	0	0	37.65	0	0	12.8
2015	12	18	14	35	10	35	0	0	0	0	0	0	0	37.76	0	0	12.8
2015	12	18	14	45	10	35	0	0	0	0	0	0	0	37.89	0	0	12.6
2015	12	18	14	55	10	36	0	0	0	0	0	0	0	37.96	0	0	12.6
2015	12	18	15	5	10	35	0	0	0	0	0	0	0	38.07	0	0	12.6
2015	12	18	15	15	10	35	0	0	0	0	0	0	0	38.14	0	0	12.4
2015	12	18	15	25	10	35	0	0	0	0	0	0	0	38.21	0	0	12.4
2015	12	18	15	35	10	35	0	0	0	0	0	0	0	38.26	0	0	12.2
2015	12	18	15	45	10	35	0	0	0	0	0	0	0	38.32	0	0	12.2
2015	12	18	15	55	10	35	0	0	0	0	0	0	0	38.35	0	0	12
2015	12	18	16	5	10	35	0	0	0	0	0	0	0	38.41	0	0	12
2015	12	18	16	15	10	35	0	0	0	0	0	0	0	38.43	0	0	12
2015	12	18	16	25	10	35	0	0	0	0	0	0	0	38.44	0	0	12
2015	12	18	16	35	10	35	0	0	0	0	0	0	0	38.46	0	0	12
2015	12	18	16	45	10	35	0	0	0	0	0	0	0	38.48	0	0	12
2015	12	18	16	55	10	35	0	0	0	0	0	0	0	38.52	0	0	12
2015	12	18	17	5	10	35	0	0	0	0	0	0	0	38.53	0	0	12
2015	12	18	17	15	10	35	0	0	0	0	0	0	0	38.55	0	0	12
2015	12	18	17	25	10	35	0	0	0	0	0	0	0	38.59	0	0	12
2015	12	18	17	35	10	35	0	0	0	0	0	0	0	38.61	0	0	12
2015	12	18	17	45	10	35	0	0	0	0	0	0	0	38.64	0	0	12
2015	12	18	17	55	10	35	0	0	0	0	0	0	0	38.66	0	0	12
2015	12	18	18	5	10	34	0	0	0	0	0	0	0	38.68	0	0	12
2015	12	18	18	15	10	35	0	0	0	0	0	0	0	38.71	0	0	12
2015	12	18	18	25	10	35	0	0	0	0	0	0	0	38.71	0	0	12
2015	12	18	18	35	10	35	0	0	0	0	0	0	0	38.73	0	0	12
2015	12	18	18	45	10	35	0	0	0	0	0	0	0	38.75	0	0	12
2015	12	18	18	55	10	35	0	0	0	0	0	0	0	38.75	0	0	12
2015	12	18	19	5	10	35	0	0	0	0	0	0	0	38.77	0	0	12
2015	12	18	19	15	10	35	0	0	0	0	0	0	0	38.75	0	0	11.8
2015	12	18	19	25	10	35	0	0	0	0	0	0	0	38.73	0	0	11.8
2015	12	18	19	35	10	35	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	18	19	45	10	35	0	0	0	0	0	0	0	38.68	0	0	11.8
2015	12	18	19	55	10	35	0	0	0	0	0	0	0	38.66	0	0	11.8
2015	12	18	20	5	10	35	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	18	20	15	10	36	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	18	20	25	10	35	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	18	20	35	10	35	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	18	20	45	10	36	0	0	0	0	0	0	0	38.41	0	0	11.8
2015	12	18	20	55	10	35	0	0	0	0	0	0	0	38.35	0	0	11.8
2015	12	18	21	5	10	35	0	0	0	0	0	0	0	38.26	0	0	11.8
2015	12	18	21	15	10	35	0	0	0	0	0	0	0	38.21	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	21	25	10	34	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	18	21	35	10	35	0	0	0	0	0	0	0	38.05	0	0	11.8
2015	12	18	21	45	10	35	0	0	0	0	0	0	0	37.96	0	0	11.8
2015	12	18	21	55	10	36	0	0	0	0	0	0	0	37.87	0	0	11.8
2015	12	18	22	5	10	35	0	0	0	0	0	0	0	37.78	0	0	11.8
2015	12	18	22	15	10	35	0	0	0	0	0	0	0	37.69	0	0	11.8
2015	12	18	22	25	10	35	0	0	0	0	0	0	0	37.6	0	0	11.8
2015	12	18	22	35	10	35	0	0	0	0	0	0	0	37.51	0	0	11.8
2015	12	18	22	45	10	35	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	18	22	55	10	35	0	0	0	0	0	0	0	37.31	0	0	11.8
2015	12	18	23	5	10	35	0	0	0	0	0	0	0	37.18	0	0	11.8
2015	12	18	23	15	10	35	0	0	0	0	0	0	0	37.09	0	0	11.8
2015	12	18	23	25	10	35	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	18	23	35	10	35	0	0	0	0	0	0	0	36.88	0	0	11.8
2015	12	18	23	45	10	35	0	0	0	0	0	0	0	36.77	0	0	11.8
2015	12	18	23	55	10	35	0	0	0	0	0	0	0	36.66	0	0	11.8
2015	12	19	0	5	10	35	0	0	0	0	0	0	0	36.55	0	0	11.8
2015	12	19	0	15	10	35	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	19	0	25	10	35	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	19	0	35	10	36	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	19	0	45	10	35	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	19	0	55	10	35	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	19	1	5	10	36	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	19	1	15	10	35	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	19	1	25	10	35	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	19	1	35	10	36	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	19	1	45	10	36	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	19	1	55	10	35	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	19	2	5	10	36	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	19	2	15	10	35	0	0	0	0	0	0	0	35.33	0	0	11.8
2015	12	19	2	25	10	35	0	0	0	0	0	0	0	35.24	0	0	11.6
2015	12	19	2	35	10	35	0	0	0	0	0	0	0	35.17	0	0	11.6
2015	12	19	2	45	10	36	0	0	0	0	0	0	0	35.1	0	0	11.6
2015	12	19	2	55	10	35	0	0	0	0	0	0	0	35.01	0	0	11.6
2015	12	19	3	5	10	36	0	0	0	0	0	0	0	34.93	0	0	11.6
2015	12	19	3	15	10	35	0	0	0	0	0	0	0	34.88	0	0	11.6
2015	12	19	3	25	10	35	0	0	0	0	0	0	0	34.81	0	0	11.6
2015	12	19	3	35	10	35	0	0	0	0	0	0	0	34.74	0	0	11.6
2015	12	19	3	45	10	35	0	0	0	0	0	0	0	34.68	0	0	11.6
2015	12	19	3	55	10	36	0	0	0	0	0	0	0	34.61	0	0	11.6
2015	12	19	4	5	10	35	0	0	0	0	0	0	0	34.56	0	0	11.6
2015	12	19	4	15	10	36	0	0	0	0	0	0	0	34.5	0	0	11.6
2015	12	19	4	25	10	35	0	0	0	0	0	0	0	34.47	0	0	11.6
2015	12	19	4	35	10	36	0	0	0	0	0	0	0	34.41	0	0	11.6
2015	12	19	4	45	10	35	0	0	0	0	0	0	0	34.36	0	0	11.6
2015	12	19	4	55	10	35	0	0	0	0	0	0	0	34.3	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	5	5	10	35	0	0	0	0	0	0	0	34.27	0	0	11.6
2015	12	19	5	15	10	36	0	0	0	0	0	0	0	34.21	0	0	11.6
2015	12	19	5	25	10	36	0	0	0	0	0	0	0	34.18	0	0	11.6
2015	12	19	5	35	10	35	0	0	0	0	0	0	0	34.14	0	0	11.6
2015	12	19	5	45	10	36	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	19	5	55	10	36	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	19	6	5	10	36	0	0	0	0	0	0	0	34.03	0	0	11.6
2015	12	19	6	15	10	35	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	19	6	25	10	35	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	19	6	35	10	35	0	0	0	0	0	0	0	33.91	0	0	11.6
2015	12	19	6	45	10	36	0	0	0	0	0	0	0	33.87	0	0	11.6
2015	12	19	6	55	10	36	0	0	0	0	0	0	0	33.85	0	0	11.6
2015	12	19	7	5	10	35	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	19	7	15	10	36	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	19	7	25	10	35	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	19	7	35	10	36	0	0	0	0	0	0	0	33.75	0	0	11.6
2015	12	19	7	45	10	37	0	0	0	0	0	0	0	33.75	0	0	12.4
2015	12	19	7	55	10	35	0	0	0	0	0	0	0	33.73	0	0	12.6
2015	12	19	8	5	10	35	0	0	0	0	0	0	0	33.73	0	0	13
2015	12	19	8	15	10	36	0	0	0	0	0	0	0	33.71	0	0	13
2015	12	19	8	25	10	35	0	0	0	0	0	0	0	33.71	0	0	13.2
2015	12	19	8	35	10	36	0	0	0	0	0	0	0	33.71	0	0	13.4
2015	12	19	8	45	10	35	0	0	0	0	0	0	0	33.71	0	0	13.4
2015	12	19	8	55	10	35	0	0	0	0	0	0	0	33.69	0	0	13.2
2015	12	19	9	5	10	36	0	0	0	0	0	0	0	33.71	0	0	13.4
2015	12	19	9	15	10	36	0	0	0	0	0	0	0	33.73	0	0	13.6
2015	12	19	9	25	10	36	0	0	0	0	0	0	0	33.75	0	0	13.6
2015	12	19	9	35	10	35	0	0	0	0	0	0	0	33.76	0	0	13.6
2015	12	19	9	45	10	36	0	0	0	0	0	0	0	33.82	0	0	13.6
2015	12	19	9	55	10	35	0	0	0	0	0	0	0	33.85	0	0	13.6
2015	12	19	10	5	10	36	0	0	0	0	0	0	0	33.91	0	0	13.6
2015	12	19	10	15	10	35	0	0	0	0	0	0	0	34	0	0	13.4
2015	12	19	10	25	10	35	0	0	0	0	0	0	0	34.07	0	0	14
2015	12	19	10	35	10	36	0	0	0	0	0	0	0	34.18	0	0	14
2015	12	19	10	45	10	36	0	0	0	0	0	0	0	34.3	0	0	13.6
2015	12	19	10	55	10	36	0	0	0	0	0	0	0	34.59	0	0	13.6
2015	12	19	11	5	10	35	0	0	0	0	0	0	0	34.83	0	0	13.4
2015	12	19	11	15	10	36	0	0	0	0	0	0	0	35.04	0	0	13.8
2015	12	19	11	25	10	35	0	0	0	0	0	0	0	35.26	0	0	13.8
2015	12	19	11	35	10	35	0	0	0	0	0	0	0	35.33	0	0	13
2015	12	19	11	45	10	36	0	0	0	0	0	0	0	35.42	0	0	12.8
2015	12	19	11	55	10	36	0	0	0	0	0	0	0	35.6	0	0	13
2015	12	19	12	5	10	35	0	0	0	0	0	0	0	35.67	0	0	12.6
2015	12	19	12	15	10	35	0	0	0	0	0	0	0	35.76	0	0	12.8
2015	12	19	12	25	10	35	0	0	0	0	0	0	0	35.89	0	0	12.8
2015	12	19	12	35	10	35	0	0	0	0	0	0	0	35.92	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	12	45	10	35	0	0	0	0	0	0	0	36.03	0	0	12.6
2015	12	19	12	55	10	35	0	0	0	0	0	0	0	36.12	0	0	12.8
2015	12	19	13	5	10	36	0	0	0	0	0	0	0	36.3	0	0	13
2015	12	19	13	15	10	35	0	0	0	0	0	0	0	36.39	0	0	12.6
2015	12	19	13	25	10	35	0	0	0	0	0	0	0	36.54	0	0	12.4
2015	12	19	13	35	10	36	0	0	0	0	0	0	0	36.66	0	0	12.4
2015	12	19	13	45	10	35	0	0	0	0	0	0	0	36.77	0	0	12.4
2015	12	19	13	55	10	36	0	0	0	0	0	0	0	36.88	0	0	12.4
2015	12	19	14	5	10	35	0	0	0	0	0	0	0	36.95	0	0	12.2
2015	12	19	14	15	10	35	0	0	0	0	0	0	0	37.04	0	0	12.2
2015	12	19	14	25	10	35	0	0	0	0	0	0	0	37.13	0	0	12.2
2015	12	19	14	35	10	36	0	0	0	0	0	0	0	37.26	0	0	12.2
2015	12	19	14	45	10	35	0	0	0	0	0	0	0	37.36	0	0	12.2
2015	12	19	14	55	10	35	0	0	0	0	0	0	0	37.36	0	0	12.2
2015	12	19	15	5	10	35	0	0	0	0	0	0	0	37.42	0	0	12
2015	12	19	15	15	10	35	0	0	0	0	0	0	0	37.53	0	0	12.2
2015	12	19	15	25	10	35	0	0	0	0	0	0	0	37.65	0	0	12.2
2015	12	19	15	35	10	35	0	0	0	0	0	0	0	37.67	0	0	12
2015	12	19	15	45	10	36	0	0	0	0	0	0	0	37.72	0	0	12
2015	12	19	15	55	10	35	0	0	0	0	0	0	0	37.78	0	0	12
2015	12	19	16	5	10	35	0	0	0	0	0	0	0	37.83	0	0	12
2015	12	19	16	15	10	35	0	0	0	0	0	0	0	37.87	0	0	12
2015	12	19	16	25	10	35	0	0	0	0	0	0	0	37.92	0	0	12
2015	12	19	16	35	10	36	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	19	16	45	10	35	0	0	0	0	0	0	0	38.03	0	0	12
2015	12	19	16	55	10	35	0	0	0	0	0	0	0	38.08	0	0	12
2015	12	19	17	5	10	35	0	0	0	0	0	0	0	38.14	0	0	12
2015	12	19	17	15	10	35	0	0	0	0	0	0	0	38.19	0	0	12
2015	12	19	17	25	10	36	0	0	0	0	0	0	0	38.25	0	0	12
2015	12	19	17	35	10	35	0	0	0	0	0	0	0	38.3	0	0	12
2015	12	19	17	45	10	35	0	0	0	0	0	0	0	38.35	0	0	12
2015	12	19	17	55	10	35	0	0	0	0	0	0	0	38.39	0	0	12
2015	12	19	18	5	10	35	0	0	0	0	0	0	0	38.43	0	0	12
2015	12	19	18	15	10	35	0	0	0	0	0	0	0	38.46	0	0	12
2015	12	19	18	25	10	34	0	0	0	0	0	0	0	38.52	0	0	12
2015	12	19	18	35	10	35	0	0	0	0	0	0	0	38.57	0	0	12
2015	12	19	18	45	10	35	0	0	0	0	0	0	0	38.62	0	0	12
2015	12	19	18	55	10	35	0	0	0	0	0	0	0	38.66	0	0	11.8
2015	12	19	19	5	10	35	0	0	0	0	0	0	0	38.7	0	0	11.8
2015	12	19	19	15	10	35	0	0	0	0	0	0	0	38.73	0	0	11.8
2015	12	19	19	25	10	36	0	0	0	0	0	0	0	38.77	0	0	11.8
2015	12	19	19	35	10	34	0	0	0	0	0	0	0	38.79	0	0	11.8
2015	12	19	19	45	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	19	19	55	10	34	0	0	0	0	0	0	0	38.82	0	0	11.8
2015	12	19	20	5	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	19	20	15	10	36	0	0	0	0	0	0	0	38.79	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	20	25	10	35	0	0	0	0	0	0	0	38.75	0	0	11.8
2015	12	19	20	35	10	35	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	19	20	45	10	35	0	0	0	0	0	0	0	38.68	0	0	11.8
2015	12	19	20	55	10	35	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	19	21	5	10	35	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	19	21	15	10	35	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	19	21	25	10	35	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	19	21	35	10	35	0	0	0	0	0	0	0	38.44	0	0	11.8
2015	12	19	21	45	10	34	0	0	0	0	0	0	0	38.39	0	0	11.8
2015	12	19	21	55	10	36	0	0	0	0	0	0	0	38.35	0	0	11.8
2015	12	19	22	5	10	36	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	19	22	15	10	35	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	19	22	25	10	36	0	0	0	0	0	0	0	38.19	0	0	11.8
2015	12	19	22	35	10	35	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	19	22	45	10	36	0	0	0	0	0	0	0	38.07	0	0	11.8
2015	12	19	22	55	10	35	0	0	0	0	0	0	0	38.01	0	0	11.8
2015	12	19	23	5	10	35	0	0	0	0	0	0	0	37.94	0	0	11.8
2015	12	19	23	15	10	35	0	0	0	0	0	0	0	37.87	0	0	11.8
2015	12	19	23	25	10	35	0	0	0	0	0	0	0	37.8	0	0	11.8
2015	12	19	23	35	10	35	0	0	0	0	0	0	0	37.72	0	0	11.8
2015	12	19	23	45	10	36	0	0	0	0	0	0	0	37.67	0	0	11.8
2015	12	19	23	55	10	35	0	0	0	0	0	0	0	37.6	0	0	11.8
2015	12	20	0	5	10	35	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	20	0	15	10	35	0	0	0	0	0	0	0	37.45	0	0	11.8
2015	12	20	0	25	10	35	0	0	0	0	0	0	0	37.38	0	0	11.8
2015	12	20	0	35	10	35	0	0	0	0	0	0	0	37.31	0	0	11.8
2015	12	20	0	45	10	36	0	0	0	0	0	0	0	37.24	0	0	11.8
2015	12	20	0	55	10	36	0	0	0	0	0	0	0	37.17	0	0	11.8
2015	12	20	1	5	10	35	0	0	0	0	0	0	0	37.09	0	0	11.6
2015	12	20	1	15	10	35	0	0	0	0	0	0	0	37.02	0	0	11.6
2015	12	20	1	25	10	35	0	0	0	0	0	0	0	36.95	0	0	11.6
2015	12	20	1	35	10	35	0	0	0	0	0	0	0	36.88	0	0	11.6
2015	12	20	1	45	10	35	0	0	0	0	0	0	0	36.81	0	0	11.6
2015	12	20	1	55	10	35	0	0	0	0	0	0	0	36.75	0	0	11.6
2015	12	20	2	5	10	35	0	0	0	0	0	0	0	36.68	0	0	11.6
2015	12	20	2	15	10	35	0	0	0	0	0	0	0	36.63	0	0	11.6
2015	12	20	2	25	10	35	0	0	0	0	0	0	0	36.55	0	0	11.6
2015	12	20	2	35	10	35	0	0	0	0	0	0	0	36.5	0	0	11.6
2015	12	20	2	45	10	35	0	0	0	0	0	0	0	36.45	0	0	11.6
2015	12	20	2	55	10	35	0	0	0	0	0	0	0	36.39	0	0	11.6
2015	12	20	3	5	10	35	0	0	0	0	0	0	0	36.36	0	0	11.6
2015	12	20	3	15	10	35	0	0	0	0	0	0	0	36.3	0	0	11.6
2015	12	20	3	25	10	35	0	0	0	0	0	0	0	36.27	0	0	11.6
2015	12	20	3	35	10	35	0	0	0	0	0	0	0	36.21	0	0	11.6
2015	12	20	3	45	10	36	0	0	0	0	0	0	0	36.16	0	0	11.6
2015	12	20	3	55	10	36	0	0	0	0	0	0	0	36.12	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	4	5	10	35	0	0	0	0	0	0	0	36.07	0	0	11.6
2015	12	20	4	15	10	35	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	20	4	25	10	36	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	20	4	35	10	35	0	0	0	0	0	0	0	35.94	0	0	11.6
2015	12	20	4	45	10	35	0	0	0	0	0	0	0	35.89	0	0	11.6
2015	12	20	4	55	10	35	0	0	0	0	0	0	0	35.85	0	0	11.6
2015	12	20	5	5	10	35	0	0	0	0	0	0	0	35.82	0	0	11.6
2015	12	20	5	15	10	36	0	0	0	0	0	0	0	35.78	0	0	11.6
2015	12	20	5	25	10	36	0	0	0	0	0	0	0	35.73	0	0	11.6
2015	12	20	5	35	10	35	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	20	5	45	10	36	0	0	0	0	0	0	0	35.65	0	0	11.6
2015	12	20	5	55	10	35	0	0	0	0	0	0	0	35.62	0	0	11.6
2015	12	20	6	5	10	35	0	0	0	0	0	0	0	35.56	0	0	11.6
2015	12	20	6	15	10	35	0	0	0	0	0	0	0	35.53	0	0	11.6
2015	12	20	6	25	10	35	0	0	0	0	0	0	0	35.49	0	0	11.6
2015	12	20	6	35	10	35	0	0	0	0	0	0	0	35.46	0	0	11.6
2015	12	20	6	45	10	36	0	0	0	0	0	0	0	35.42	0	0	11.6
2015	12	20	6	55	10	35	0	0	0	0	0	0	0	35.38	0	0	11.6
2015	12	20	7	5	10	36	0	0	0	0	0	0	0	35.35	0	0	11.6
2015	12	20	7	15	10	36	0	0	0	0	0	0	0	35.31	0	0	11.6
2015	12	20	7	25	10	35	0	0	0	0	0	0	0	35.29	0	0	11.6
2015	12	20	7	35	10	35	0	0	0	0	0	0	0	35.28	0	0	11.6
2015	12	20	7	45	10	36	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	20	7	55	10	35	0	0	0	0	0	0	0	35.26	0	0	12.6
2015	12	20	8	5	10	35	0	0	0	0	0	0	0	35.26	0	0	12.6
2015	12	20	8	15	10	35	0	0	0	0	0	0	0	35.24	0	0	12.8
2015	12	20	8	25	10	36	0	0	0	0	0	0	0	35.2	0	0	12.8
2015	12	20	8	35	10	35	0	0	0	0	0	0	0	35.24	0	0	12.6
2015	12	20	8	45	10	36	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	20	8	55	10	36	0	0	0	0	0	0	0	35.35	0	0	13
2015	12	20	9	5	10	35	0	0	0	0	0	0	0	35.44	0	0	13.2
2015	12	20	9	15	10	36	0	0	0	0	0	0	0	35.51	0	0	12.6
2015	12	20	9	25	10	35	0	0	0	0	0	0	0	35.51	0	0	12.4
2015	12	20	9	35	10	35	0	0	0	0	0	0	0	35.58	0	0	12.4
2015	12	20	9	45	10	35	0	0	0	0	0	0	0	35.6	0	0	12.8
2015	12	20	9	55	10	36	0	0	0	0	0	0	0	35.74	0	0	13.2
2015	12	20	10	5	10	35	0	0	0	0	0	0	0	35.87	0	0	12.8
2015	12	20	10	15	10	35	0	0	0	0	0	0	0	35.87	0	0	12.4
2015	12	20	10	25	10	36	0	0	0	0	0	0	0	35.89	0	0	12.2
2015	12	20	10	35	10	35	0	0	0	0	0	0	0	36.01	0	0	12.2
2015	12	20	10	45	10	36	0	0	0	0	0	0	0	36.16	0	0	12.6
2015	12	20	10	55	10	35	0	0	0	0	0	0	0	36.27	0	0	13
2015	12	20	11	5	10	35	0	0	0	0	0	0	0	36.59	0	0	13.4
2015	12	20	11	15	10	35	0	0	0	0	0	0	0	36.68	0	0	12.8
2015	12	20	11	25	10	36	0	0	0	0	0	0	0	36.91	0	0	13
2015	12	20	11	35	10	35	0	0	0	0	0	0	0	36.75	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	11	45	10	36	0	0	0	0	0	0	0	36.93	0	0	13.2
2015	12	20	11	55	10	35	0	0	0	0	0	0	0	37.11	0	0	13.4
2015	12	20	12	5	10	35	0	0	0	0	0	0	0	37.35	0	0	13.2
2015	12	20	12	15	10	35	0	0	0	0	0	0	0	37.54	0	0	13.4
2015	12	20	12	25	10	36	0	0	0	0	0	0	0	37.65	0	0	13
2015	12	20	12	35	10	35	0	0	0	0	0	0	0	37.71	0	0	12.6
2015	12	20	12	45	10	35	0	0	0	0	0	0	0	37.78	0	0	12.8
2015	12	20	12	55	10	35	0	0	0	0	0	0	0	37.96	0	0	12.8
2015	12	20	13	5	10	35	0	0	0	0	0	0	0	38.14	0	0	13
2015	12	20	13	15	10	35	0	0	0	0	0	0	0	38.23	0	0	13
2015	12	20	13	25	10	35	0	0	0	0	0	0	0	38.39	0	0	13
2015	12	20	13	35	10	35	0	0	0	0	0	0	0	38.52	0	0	13
2015	12	20	13	45	10	35	0	0	0	0	0	0	0	38.66	0	0	12.8
2015	12	20	13	55	10	35	0	0	0	0	0	0	0	38.8	0	0	12.8
2015	12	20	14	5	10	35	0	0	0	0	0	0	0	38.91	0	0	12.8
2015	12	20	14	15	10	35	0	0	0	0	0	0	0	39	0	0	12.8
2015	12	20	14	25	10	35	0	0	0	0	0	0	0	39.07	0	0	12.4
2015	12	20	14	35	10	35	0	0	0	0	0	0	0	39.15	0	0	12.2
2015	12	20	14	45	10	35	0	0	0	0	0	0	0	39.2	0	0	12.2
2015	12	20	14	55	10	35	0	0	0	0	0	0	0	39.27	0	0	12.2
2015	12	20	15	5	10	35	0	0	0	0	0	0	0	39.34	0	0	12.4
2015	12	20	15	15	10	36	0	0	0	0	0	0	0	39.4	0	0	12.2
2015	12	20	15	25	10	35	0	0	0	0	0	0	0	39.42	0	0	12
2015	12	20	15	35	10	35	0	0	0	0	0	0	0	39.43	0	0	12
2015	12	20	15	45	10	35	0	0	0	0	0	0	0	39.47	0	0	12
2015	12	20	15	55	10	35	0	0	0	0	0	0	0	39.47	0	0	12
2015	12	20	16	5	10	35	0	0	0	0	0	0	0	39.47	0	0	12
2015	12	20	16	15	10	35	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	20	16	25	10	35	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	20	16	35	10	35	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	20	16	45	10	35	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	20	16	55	10	35	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	20	17	5	10	35	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	20	17	15	10	34	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	20	17	25	10	34	0	0	0	0	0	0	0	39.52	0	0	11.8
2015	12	20	17	35	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	20	17	45	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	20	17	55	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	20	18	5	10	35	0	0	0	0	0	0	0	39.54	0	0	11.8
2015	12	20	18	15	10	35	0	0	0	0	0	0	0	39.52	0	0	11.8
2015	12	20	18	25	10	35	0	0	0	0	0	0	0	39.52	0	0	11.8
2015	12	20	18	35	10	35	0	0	0	0	0	0	0	39.52	0	0	11.8
2015	12	20	18	45	10	35	0	0	0	0	0	0	0	39.51	0	0	11.8
2015	12	20	18	55	10	35	0	0	0	0	0	0	0	39.49	0	0	11.8
2015	12	20	19	5	10	35	0	0	0	0	0	0	0	39.49	0	0	11.8
2015	12	20	19	15	10	34	0	0	0	0	0	0	0	39.47	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	19	25	10	35	0	0	0	0	0	0	0	39.43	0	0	11.8
2015	12	20	19	35	10	35	0	0	0	0	0	0	0	39.42	0	0	11.8
2015	12	20	19	45	10	35	0	0	0	0	0	0	0	39.38	0	0	11.8
2015	12	20	19	55	10	35	0	0	0	0	0	0	0	39.34	0	0	11.8
2015	12	20	20	5	10	35	0	0	0	0	0	0	0	39.29	0	0	11.8
2015	12	20	20	15	10	35	0	0	0	0	0	0	0	39.24	0	0	11.8
2015	12	20	20	25	10	34	0	0	0	0	0	0	0	39.18	0	0	11.8
2015	12	20	20	35	10	35	0	0	0	0	0	0	0	39.13	0	0	11.8
2015	12	20	20	45	10	35	0	0	0	0	0	0	0	39.07	0	0	11.8
2015	12	20	20	55	10	35	0	0	0	0	0	0	0	39	0	0	11.8
2015	12	20	21	5	10	35	0	0	0	0	0	0	0	38.93	0	0	11.8
2015	12	20	21	15	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	20	21	25	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	20	21	35	10	35	0	0	0	0	0	0	0	38.73	0	0	11.8
2015	12	20	21	45	10	35	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	20	21	55	10	35	0	0	0	0	0	0	0	38.57	0	0	11.6
2015	12	20	22	5	10	35	0	0	0	0	0	0	0	38.48	0	0	11.6
2015	12	20	22	15	10	35	0	0	0	0	0	0	0	38.37	0	0	11.6
2015	12	20	22	25	10	36	0	0	0	0	0	0	0	38.28	0	0	11.6
2015	12	20	22	35	10	35	0	0	0	0	0	0	0	38.19	0	0	11.6
2015	12	20	22	45	10	35	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	20	22	55	10	36	0	0	0	0	0	0	0	38.01	0	0	11.6
2015	12	20	23	5	10	34	0	0	0	0	0	0	0	37.92	0	0	11.6
2015	12	20	23	15	10	35	0	0	0	0	0	0	0	37.81	0	0	11.6
2015	12	20	23	25	10	36	0	0	0	0	0	0	0	37.74	0	0	11.6
2015	12	20	23	35	10	35	0	0	0	0	0	0	0	37.63	0	0	11.6
2015	12	20	23	45	10	35	0	0	0	0	0	0	0	37.56	0	0	11.6
2015	12	20	23	55	10	35	0	0	0	0	0	0	0	37.47	0	0	11.6
2015	12	21	0	5	10	35	0	0	0	0	0	0	0	37.38	0	0	11.6
2015	12	21	0	15	10	35	0	0	0	0	0	0	0	37.31	0	0	11.6
2015	12	21	0	25	10	35	0	0	0	0	0	0	0	37.22	0	0	11.6
2015	12	21	0	35	10	35	0	0	0	0	0	0	0	37.15	0	0	11.6
2015	12	21	0	45	10	35	0	0	0	0	0	0	0	37.06	0	0	11.6
2015	12	21	0	55	10	36	0	0	0	0	0	0	0	36.99	0	0	11.6
2015	12	21	1	5	10	35	0	0	0	0	0	0	0	36.91	0	0	11.6
2015	12	21	1	15	10	35	0	0	0	0	0	0	0	36.84	0	0	11.6
2015	12	21	1	25	10	35	0	0	0	0	0	0	0	36.77	0	0	11.6
2015	12	21	1	35	10	35	0	0	0	0	0	0	0	36.7	0	0	11.6
2015	12	21	1	45	10	35	0	0	0	0	0	0	0	36.64	0	0	11.6
2015	12	21	1	55	10	35	0	0	0	0	0	0	0	36.57	0	0	11.6
2015	12	21	2	5	10	35	0	0	0	0	0	0	0	36.52	0	0	11.6
2015	12	21	2	15	10	36	0	0	0	0	0	0	0	36.46	0	0	11.6
2015	12	21	2	25	10	35	0	0	0	0	0	0	0	36.43	0	0	11.6
2015	12	21	2	35	10	35	0	0	0	0	0	0	0	36.37	0	0	11.6
2015	12	21	2	45	10	35	0	0	0	0	0	0	0	36.34	0	0	11.6
2015	12	21	2	55	10	35	0	0	0	0	0	0	0	36.3	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	3	5	10	35	0	0	0	0	0	0	0	36.27	0	0	11.6
2015	12	21	3	15	10	35	0	0	0	0	0	0	0	36.23	0	0	11.6
2015	12	21	3	25	10	36	0	0	0	0	0	0	0	36.19	0	0	11.6
2015	12	21	3	35	10	35	0	0	0	0	0	0	0	36.16	0	0	11.6
2015	12	21	3	45	10	35	0	0	0	0	0	0	0	36.12	0	0	11.6
2015	12	21	3	55	10	35	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	21	4	5	10	35	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	21	4	15	10	35	0	0	0	0	0	0	0	36.01	0	0	11.6
2015	12	21	4	25	10	35	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	21	4	35	10	36	0	0	0	0	0	0	0	35.96	0	0	11.6
2015	12	21	4	45	10	35	0	0	0	0	0	0	0	35.92	0	0	11.6
2015	12	21	4	55	10	35	0	0	0	0	0	0	0	35.89	0	0	11.6
2015	12	21	5	5	10	35	0	0	0	0	0	0	0	35.87	0	0	11.6
2015	12	21	5	15	10	35	0	0	0	0	0	0	0	35.83	0	0	11.6
2015	12	21	5	25	10	35	0	0	0	0	0	0	0	35.82	0	0	11.6
2015	12	21	5	35	10	36	0	0	0	0	0	0	0	35.8	0	0	11.6
2015	12	21	5	45	10	35	0	0	0	0	0	0	0	35.78	0	0	11.6
2015	12	21	5	55	10	35	0	0	0	0	0	0	0	35.76	0	0	11.6
2015	12	21	6	5	10	36	0	0	0	0	0	0	0	35.73	0	0	11.6
2015	12	21	6	15	10	36	0	0	0	0	0	0	0	35.73	0	0	11.6
2015	12	21	6	25	10	36	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	21	6	35	10	35	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	21	6	45	10	35	0	0	0	0	0	0	0	35.69	0	0	11.6
2015	12	21	6	55	10	35	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	7	5	10	36	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	7	15	10	36	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	7	25	10	36	0	0	0	0	0	0	0	35.65	0	0	11.6
2015	12	21	7	35	10	35	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	7	45	10	35	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	7	55	10	35	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	21	8	5	10	36	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	21	8	15	10	36	0	0	0	0	0	0	0	35.73	0	0	11.6
2015	12	21	8	25	10	35	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	21	8	35	10	35	0	0	0	0	0	0	0	35.74	0	0	11.6
2015	12	21	8	45	10	35	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	21	8	55	10	36	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	21	9	5	10	36	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	21	9	15	10	35	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	21	9	25	10	35	0	0	0	0	0	0	0	36	0	0	12
2015	12	21	9	35	10	36	0	0	0	0	0	0	0	36.07	0	0	12.2
2015	12	21	9	45	10	36	0	0	0	0	0	0	0	36.19	0	0	12.8
2015	12	21	9	55	10	35	0	0	0	0	0	0	0	36.23	0	0	12.4
2015	12	21	10	5	10	35	0	0	0	0	0	0	0	36.32	0	0	12.6
2015	12	21	10	15	10	35	0	0	0	0	0	0	0	36.41	0	0	12.6
2015	12	21	10	25	10	35	0	0	0	0	0	0	0	36.5	0	0	12.4
2015	12	21	10	35	10	35	0	0	0	0	0	0	0	36.59	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	10	45	10	35	0	0	0	0	0	0	0	36.7	0	0	12.6
2015	12	21	10	55	10	35	0	0	0	0	0	0	0	36.93	0	0	12.8
2015	12	21	11	5	10	36	0	0	0	0	0	0	0	36.91	0	0	12.4
2015	12	21	11	15	10	35	0	0	0	0	0	0	0	37.13	0	0	12.6
2015	12	21	11	25	10	35	0	0	0	0	0	0	0	37.18	0	0	12.4
2015	12	21	11	35	10	35	0	0	0	0	0	0	0	37.27	0	0	12.4
2015	12	21	11	45	10	35	0	0	0	0	0	0	0	37.35	0	0	12.4
2015	12	21	11	55	10	35	0	0	0	0	0	0	0	37.45	0	0	12.4
2015	12	21	12	5	10	35	0	0	0	0	0	0	0	37.53	0	0	12.2
2015	12	21	12	15	10	35	0	0	0	0	0	0	0	37.6	0	0	12.2
2015	12	21	12	25	10	35	0	0	0	0	0	0	0	37.67	0	0	12.2
2015	12	21	12	35	10	35	0	0	0	0	0	0	0	37.71	0	0	12
2015	12	21	12	45	10	35	0	0	0	0	0	0	0	37.8	0	0	12.2
2015	12	21	12	55	10	35	0	0	0	0	0	0	0	37.92	0	0	12
2015	12	21	13	5	10	35	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	21	13	15	10	35	0	0	0	0	0	0	0	38.07	0	0	12
2015	12	21	13	25	10	35	0	0	0	0	0	0	0	38.1	0	0	12
2015	12	21	13	35	10	35	0	0	0	0	0	0	0	38.16	0	0	12
2015	12	21	13	45	10	35	0	0	0	0	0	0	0	38.23	0	0	12
2015	12	21	13	55	10	35	0	0	0	0	0	0	0	38.35	0	0	12
2015	12	21	14	5	10	35	0	0	0	0	0	0	0	38.43	0	0	12
2015	12	21	14	15	10	35	0	0	0	0	0	0	0	38.52	0	0	12
2015	12	21	14	25	10	35	0	0	0	0	0	0	0	38.59	0	0	12
2015	12	21	14	35	10	35	0	0	0	0	0	0	0	38.66	0	0	11.8
2015	12	21	14	45	10	35	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	21	14	55	10	35	0	0	0	0	0	0	0	38.77	0	0	11.8
2015	12	21	15	5	10	35	0	0	0	0	0	0	0	38.82	0	0	11.8
2015	12	21	15	15	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	21	15	25	10	35	0	0	0	0	0	0	0	38.93	0	0	11.8
2015	12	21	15	35	10	36	0	0	0	0	0	0	0	38.98	0	0	11.8
2015	12	21	15	45	10	35	0	0	0	0	0	0	0	39.04	0	0	11.8
2015	12	21	15	55	10	35	0	0	0	0	0	0	0	39.07	0	0	11.8
2015	12	21	16	5	10	35	0	0	0	0	0	0	0	39.13	0	0	11.6
2015	12	21	16	15	10	36	0	0	0	0	0	0	0	39.15	0	0	11.6
2015	12	21	16	25	10	34	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	21	16	35	10	35	0	0	0	0	0	0	0	39.2	0	0	11.6
2015	12	21	16	45	10	35	0	0	0	0	0	0	0	39.24	0	0	11.6
2015	12	21	16	55	10	35	0	0	0	0	0	0	0	39.27	0	0	11.6
2015	12	21	17	5	10	35	0	0	0	0	0	0	0	39.29	0	0	11.6
2015	12	21	17	15	10	35	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	21	17	25	10	36	0	0	0	0	0	0	0	39.34	0	0	11.6
2015	12	21	17	35	10	35	0	0	0	0	0	0	0	39.36	0	0	11.6
2015	12	21	17	45	10	35	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	21	17	55	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	21	18	5	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	21	18	15	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	18	25	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	21	18	35	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	21	18	45	10	34	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	21	18	55	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	21	19	5	10	35	0	0	0	0	0	0	0	39.47	0	0	11.6
2015	12	21	19	15	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	21	19	25	10	35	0	0	0	0	0	0	0	39.45	0	0	11.6
2015	12	21	19	35	10	35	0	0	0	0	0	0	0	39.43	0	0	11.6
2015	12	21	19	45	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	21	19	55	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	21	20	5	10	35	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	21	20	15	10	35	0	0	0	0	0	0	0	39.34	0	0	11.6
2015	12	21	20	25	10	35	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	21	20	35	10	35	0	0	0	0	0	0	0	39.29	0	0	11.6
2015	12	21	20	45	10	35	0	0	0	0	0	0	0	39.25	0	0	11.6
2015	12	21	20	55	10	35	0	0	0	0	0	0	0	39.22	0	0	11.6
2015	12	21	21	5	10	36	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	21	21	15	10	35	0	0	0	0	0	0	0	39.15	0	0	11.6
2015	12	21	21	25	10	35	0	0	0	0	0	0	0	39.11	0	0	11.6
2015	12	21	21	35	10	35	0	0	0	0	0	0	0	39.06	0	0	11.6
2015	12	21	21	45	10	35	0	0	0	0	0	0	0	39.02	0	0	11.6
2015	12	21	21	55	10	35	0	0	0	0	0	0	0	38.98	0	0	11.6
2015	12	21	22	5	10	35	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	21	22	15	10	34	0	0	0	0	0	0	0	38.89	0	0	11.6
2015	12	21	22	25	10	36	0	0	0	0	0	0	0	38.86	0	0	11.6
2015	12	21	22	35	10	35	0	0	0	0	0	0	0	38.82	0	0	11.6
2015	12	21	22	45	10	35	0	0	0	0	0	0	0	38.79	0	0	11.6
2015	12	21	22	55	10	35	0	0	0	0	0	0	0	38.75	0	0	11.6
2015	12	21	23	5	10	35	0	0	0	0	0	0	0	38.71	0	0	11.6
2015	12	21	23	15	10	36	0	0	0	0	0	0	0	38.68	0	0	11.6
2015	12	21	23	25	10	34	0	0	0	0	0	0	0	38.66	0	0	11.6
2015	12	21	23	35	10	35	0	0	0	0	0	0	0	38.61	0	0	11.6
2015	12	21	23	45	10	35	0	0	0	0	0	0	0	38.59	0	0	11.6
2015	12	21	23	55	10	34	0	0	0	0	0	0	0	38.55	0	0	11.6
2015	12	22	0	5	10	35	0	0	0	0	0	0	0	38.5	0	0	11.6
2015	12	22	0	15	10	35	0	0	0	0	0	0	0	38.48	0	0	11.6
2015	12	22	0	25	10	35	0	0	0	0	0	0	0	38.44	0	0	11.6
2015	12	22	0	35	10	36	0	0	0	0	0	0	0	38.41	0	0	11.6
2015	12	22	0	45	10	35	0	0	0	0	0	0	0	38.37	0	0	11.6
2015	12	22	0	55	10	35	0	0	0	0	0	0	0	38.35	0	0	11.6
2015	12	22	1	5	10	36	0	0	0	0	0	0	0	38.32	0	0	11.6
2015	12	22	1	15	10	36	0	0	0	0	0	0	0	38.28	0	0	11.6
2015	12	22	1	25	10	34	0	0	0	0	0	0	0	38.25	0	0	11.6
2015	12	22	1	35	10	35	0	0	0	0	0	0	0	38.23	0	0	11.6
2015	12	22	1	45	10	35	0	0	0	0	0	0	0	38.23	0	0	11.6
2015	12	22	1	55	10	36	0	0	0	0	0	0	0	38.19	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	2	5	10	35	0	0	0	0	0	0	0	38.19	0	0	11.6
2015	12	22	2	15	10	36	0	0	0	0	0	0	0	38.17	0	0	11.6
2015	12	22	2	25	10	36	0	0	0	0	0	0	0	38.16	0	0	11.6
2015	12	22	2	35	10	35	0	0	0	0	0	0	0	38.14	0	0	11.6
2015	12	22	2	45	10	36	0	0	0	0	0	0	0	38.14	0	0	11.6
2015	12	22	2	55	10	35	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	22	3	5	10	35	0	0	0	0	0	0	0	38.12	0	0	11.6
2015	12	22	3	15	10	35	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	22	3	25	10	34	0	0	0	0	0	0	0	38.08	0	0	11.6
2015	12	22	3	35	10	36	0	0	0	0	0	0	0	38.07	0	0	11.6
2015	12	22	3	45	10	35	0	0	0	0	0	0	0	38.07	0	0	11.6
2015	12	22	3	55	10	34	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	4	5	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	4	15	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	4	25	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	4	35	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	4	45	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	4	55	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	5	5	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	5	15	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	5	25	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	5	35	10	35	0	0	0	0	0	0	0	38.03	0	0	11.6
2015	12	22	5	45	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	5	55	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	6	5	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	22	6	15	10	35	0	0	0	0	0	0	0	38.07	0	0	11.6
2015	12	22	6	25	10	35	0	0	0	0	0	0	0	38.07	0	0	11.6
2015	12	22	6	35	10	36	0	0	0	0	0	0	0	38.07	0	0	11.6
2015	12	22	6	45	10	35	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	22	6	55	10	35	0	0	0	0	0	0	0	38.1	0	0	11.6
2015	12	22	7	5	10	35	0	0	0	0	0	0	0	38.12	0	0	11.6
2015	12	22	7	15	10	35	0	0	0	0	0	0	0	38.14	0	0	11.6
2015	12	22	7	25	10	36	0	0	0	0	0	0	0	38.16	0	0	11.6
2015	12	22	7	35	10	36	0	0	0	0	0	0	0	38.21	0	0	11.6
2015	12	22	7	45	10	35	0	0	0	0	0	0	0	38.26	0	0	11.8
2015	12	22	7	55	10	35	0	0	0	0	0	0	0	38.35	0	0	11.8
2015	12	22	8	5	10	35	0	0	0	0	0	0	0	38.39	0	0	12
2015	12	22	8	15	10	35	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	22	8	25	10	35	0	0	0	0	0	0	0	38.46	0	0	11.8
2015	12	22	8	35	10	35	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	22	8	45	10	35	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	22	8	55	10	35	0	0	0	0	0	0	0	38.61	0	0	12.2
2015	12	22	9	5	10	35	0	0	0	0	0	0	0	38.66	0	0	12.6
2015	12	22	9	15	10	35	0	0	0	0	0	0	0	38.71	0	0	12.8
2015	12	22	9	25	10	35	0	0	0	0	0	0	0	38.86	0	0	12.8
2015	12	22	9	35	10	35	0	0	0	0	0	0	0	38.93	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	9	45	10	36	0	0	0	0	0	0	0	38.93	0	0	12.4
2015	12	22	9	55	10	35	0	0	0	0	0	0	0	39.04	0	0	13
2015	12	22	10	5	10	35	0	0	0	0	0	0	0	39.13	0	0	12.8
2015	12	22	10	15	10	35	0	0	0	0	0	0	0	39.16	0	0	12.8
2015	12	22	10	25	10	35	0	0	0	0	0	0	0	39.24	0	0	13.2
2015	12	22	10	35	10	35	0	0	0	0	0	0	0	39.33	0	0	13.2
2015	12	22	10	45	10	35	0	0	0	0	0	0	0	39.42	0	0	13.2
2015	12	22	10	55	10	35	0	0	0	0	0	0	0	39.79	0	0	13.2
2015	12	22	11	5	10	35	0	0	0	0	0	0	0	40.03	0	0	13.2
2015	12	22	11	15	10	36	0	0	0	0	0	0	0	40.21	0	0	13
2015	12	22	11	25	10	35	0	0	0	0	0	0	0	40.37	0	0	13
2015	12	22	11	35	10	34	0	0	0	0	0	0	0	40.48	0	0	13
2015	12	22	11	45	10	35	0	0	0	0	0	0	0	40.66	0	0	13
2015	12	22	11	55	10	35	0	0	0	0	0	0	0	40.82	0	0	13
2015	12	22	12	5	10	35	0	0	0	0	0	0	0	40.93	0	0	12.8
2015	12	22	12	15	10	35	0	0	0	0	0	0	0	41.04	0	0	12.6
2015	12	22	12	25	10	34	0	0	0	0	0	0	0	41.16	0	0	12.8
2015	12	22	12	35	10	34	0	0	0	0	0	0	0	41.32	0	0	12.6
2015	12	22	12	45	10	36	0	0	0	0	0	0	0	41.5	0	0	12.8
2015	12	22	12	55	10	35	0	0	0	0	0	0	0	41.65	0	0	12.8
2015	12	22	13	5	10	35	0	0	0	0	0	0	0	41.7	0	0	12.4
2015	12	22	13	15	10	35	0	0	0	0	0	0	0	41.79	0	0	12.4
2015	12	22	13	25	10	34	0	0	0	0	0	0	0	41.97	0	0	12.6
2015	12	22	13	35	10	35	0	0	0	0	0	0	0	42.13	0	0	12.4
2015	12	22	13	45	10	34	0	0	0	0	0	0	0	42.21	0	0	12.4
2015	12	22	13	55	10	34	0	0	0	0	0	0	0	42.35	0	0	12.2
2015	12	22	14	5	10	35	0	0	0	0	0	0	0	42.48	0	0	12.4
2015	12	22	14	15	10	35	0	0	0	0	0	0	0	42.48	0	0	12.2
2015	12	22	14	25	10	35	0	0	0	0	0	0	0	42.49	0	0	12
2015	12	22	14	35	10	35	0	0	0	0	0	0	0	42.53	0	0	12
2015	12	22	14	45	10	35	0	0	0	0	0	0	0	42.62	0	0	12.2
2015	12	22	14	55	10	35	0	0	0	0	0	0	0	42.75	0	0	12.2
2015	12	22	15	5	10	35	0	0	0	0	0	0	0	42.78	0	0	12.2
2015	12	22	15	15	10	35	0	0	0	0	0	0	0	42.75	0	0	12
2015	12	22	15	25	10	34	0	0	0	0	0	0	0	42.76	0	0	12
2015	12	22	15	35	10	34	0	0	0	0	0	0	0	42.78	0	0	12
2015	12	22	15	45	10	34	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	22	15	55	10	34	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	22	16	5	10	35	0	0	0	0	0	0	0	42.8	0	0	12
2015	12	22	16	15	10	35	0	0	0	0	0	0	0	42.82	0	0	11.8
2015	12	22	16	25	10	35	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	16	35	10	34	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	16	45	10	34	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	16	55	10	34	0	0	0	0	0	0	0	42.85	0	0	11.8
2015	12	22	17	5	10	34	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	22	17	15	10	35	0	0	0	0	0	0	0	42.85	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	17	25	10	35	0	0	0	0	0	0	0	42.85	0	0	11.8
2015	12	22	17	35	10	34	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	22	17	45	10	35	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	22	17	55	10	34	0	0	0	0	0	0	0	42.87	0	0	11.8
2015	12	22	18	5	10	34	0	0	0	0	0	0	0	42.85	0	0	11.8
2015	12	22	18	15	10	35	0	0	0	0	0	0	0	42.85	0	0	11.8
2015	12	22	18	25	10	34	0	0	0	0	0	0	0	42.85	0	0	11.8
2015	12	22	18	35	10	34	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	18	45	10	34	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	18	55	10	34	0	0	0	0	0	0	0	42.84	0	0	11.8
2015	12	22	19	5	10	34	0	0	0	0	0	0	0	42.82	0	0	11.8
2015	12	22	19	15	10	34	0	0	0	0	0	0	0	42.8	0	0	11.8
2015	12	22	19	25	10	35	0	0	0	0	0	0	0	42.8	0	0	11.8
2015	12	22	19	35	10	34	0	0	0	0	0	0	0	42.78	0	0	11.8
2015	12	22	19	45	10	35	0	0	0	0	0	0	0	42.76	0	0	11.8
2015	12	22	19	55	10	34	0	0	0	0	0	0	0	42.76	0	0	11.8
2015	12	22	20	5	10	35	0	0	0	0	0	0	0	42.75	0	0	11.8
2015	12	22	20	15	10	34	0	0	0	0	0	0	0	42.73	0	0	11.8
2015	12	22	20	25	10	34	0	0	0	0	0	0	0	42.71	0	0	11.8
2015	12	22	20	35	10	34	0	0	0	0	0	0	0	42.69	0	0	11.8
2015	12	22	20	45	10	35	0	0	0	0	0	0	0	42.66	0	0	11.8
2015	12	22	20	55	10	34	0	0	0	0	0	0	0	42.62	0	0	11.8
2015	12	22	21	5	10	34	0	0	0	0	0	0	0	42.57	0	0	11.8
2015	12	22	21	15	10	34	0	0	0	0	0	0	0	42.51	0	0	11.6
2015	12	22	21	25	10	34	0	0	0	0	0	0	0	42.46	0	0	11.6
2015	12	22	21	35	10	34	0	0	0	0	0	0	0	42.4	0	0	11.6
2015	12	22	21	45	10	35	0	0	0	0	0	0	0	42.35	0	0	11.6
2015	12	22	21	55	10	34	0	0	0	0	0	0	0	42.28	0	0	11.6
2015	12	22	22	5	10	34	0	0	0	0	0	0	0	42.21	0	0	11.6
2015	12	22	22	15	10	35	0	0	0	0	0	0	0	42.13	0	0	11.6
2015	12	22	22	25	10	35	0	0	0	0	0	0	0	42.06	0	0	11.6
2015	12	22	22	35	10	35	0	0	0	0	0	0	0	41.99	0	0	11.6
2015	12	22	22	45	10	35	0	0	0	0	0	0	0	41.92	0	0	11.6
2015	12	22	22	55	10	35	0	0	0	0	0	0	0	41.83	0	0	11.6
2015	12	22	23	5	10	34	0	0	0	0	0	0	0	41.76	0	0	11.6
2015	12	22	23	15	10	35	0	0	0	0	0	0	0	41.68	0	0	11.6
2015	12	22	23	25	10	35	0	0	0	0	0	0	0	41.59	0	0	11.6
2015	12	22	23	35	10	35	0	0	0	0	0	0	0	41.5	0	0	11.6
2015	12	22	23	45	10	35	0	0	0	0	0	0	0	41.43	0	0	11.6
2015	12	22	23	55	10	35	0	0	0	0	0	0	0	41.34	0	0	11.6
2015	12	23	0	5	10	35	0	0	0	0	0	0	0	41.25	0	0	11.6
2015	12	23	0	15	10	35	0	0	0	0	0	0	0	41.14	0	0	11.6
2015	12	23	0	25	10	34	0	0	0	0	0	0	0	41.07	0	0	11.6
2015	12	23	0	35	10	34	0	0	0	0	0	0	0	40.98	0	0	11.6
2015	12	23	0	45	10	35	0	0	0	0	0	0	0	40.89	0	0	11.6
2015	12	23	0	55	10	34	0	0	0	0	0	0	0	40.8	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	1	5	10	35	0	0	0	0	0	0	0	40.69	0	0	11.6
2015	12	23	1	15	10	35	0	0	0	0	0	0	0	40.62	0	0	11.6
2015	12	23	1	25	10	35	0	0	0	0	0	0	0	40.53	0	0	11.6
2015	12	23	1	35	10	34	0	0	0	0	0	0	0	40.44	0	0	11.6
2015	12	23	1	45	10	35	0	0	0	0	0	0	0	40.35	0	0	11.6
2015	12	23	1	55	10	35	0	0	0	0	0	0	0	40.26	0	0	11.6
2015	12	23	2	5	10	35	0	0	0	0	0	0	0	40.17	0	0	11.6
2015	12	23	2	15	10	35	0	0	0	0	0	0	0	40.08	0	0	11.6
2015	12	23	2	25	10	34	0	0	0	0	0	0	0	39.99	0	0	11.6
2015	12	23	2	35	10	34	0	0	0	0	0	0	0	39.9	0	0	11.6
2015	12	23	2	45	10	35	0	0	0	0	0	0	0	39.83	0	0	11.6
2015	12	23	2	55	10	35	0	0	0	0	0	0	0	39.76	0	0	11.6
2015	12	23	3	5	10	35	0	0	0	0	0	0	0	39.67	0	0	11.6
2015	12	23	3	15	10	34	0	0	0	0	0	0	0	39.6	0	0	11.6
2015	12	23	3	25	10	35	0	0	0	0	0	0	0	39.54	0	0	11.6
2015	12	23	3	35	10	35	0	0	0	0	0	0	0	39.47	0	0	11.6
2015	12	23	3	45	10	35	0	0	0	0	0	0	0	39.4	0	0	11.6
2015	12	23	3	55	10	35	0	0	0	0	0	0	0	39.33	0	0	11.6
2015	12	23	4	5	10	35	0	0	0	0	0	0	0	39.25	0	0	11.6
2015	12	23	4	15	10	35	0	0	0	0	0	0	0	39.18	0	0	11.6
2015	12	23	4	25	10	35	0	0	0	0	0	0	0	39.13	0	0	11.6
2015	12	23	4	35	10	35	0	0	0	0	0	0	0	39.06	0	0	11.4
2015	12	23	4	45	10	34	0	0	0	0	0	0	0	38.97	0	0	11.4
2015	12	23	4	55	10	35	0	0	0	0	0	0	0	38.91	0	0	11.4
2015	12	23	5	5	10	35	0	0	0	0	0	0	0	38.84	0	0	11.4
2015	12	23	5	15	10	35	0	0	0	0	0	0	0	38.77	0	0	11.4
2015	12	23	5	25	10	35	0	0	0	0	0	0	0	38.7	0	0	11.4
2015	12	23	5	35	10	35	0	0	0	0	0	0	0	38.64	0	0	11.4
2015	12	23	5	45	10	35	0	0	0	0	0	0	0	38.59	0	0	11.4
2015	12	23	5	55	10	34	0	0	0	0	0	0	0	38.52	0	0	11.4
2015	12	23	6	5	10	35	0	0	0	0	0	0	0	38.46	0	0	11.4
2015	12	23	6	15	10	35	0	0	0	0	0	0	0	38.41	0	0	11.4
2015	12	23	6	25	10	35	0	0	0	0	0	0	0	38.34	0	0	11.4
2015	12	23	6	35	10	35	0	0	0	0	0	0	0	38.3	0	0	11.4
2015	12	23	6	45	10	35	0	0	0	0	0	0	0	38.25	0	0	11.4
2015	12	23	6	55	10	36	0	0	0	0	0	0	0	38.19	0	0	11.4
2015	12	23	7	5	10	35	0	0	0	0	0	0	0	38.16	0	0	11.4
2015	12	23	7	15	10	35	0	0	0	0	0	0	0	38.12	0	0	11.4
2015	12	23	7	25	10	35	0	0	0	0	0	0	0	38.08	0	0	11.4
2015	12	23	7	35	10	35	0	0	0	0	0	0	0	38.07	0	0	11.4
2015	12	23	7	45	10	36	0	0	0	0	0	0	0	38.05	0	0	12.2
2015	12	23	7	55	10	35	0	0	0	0	0	0	0	38.05	0	0	12.6
2015	12	23	8	5	10	35	0	0	0	0	0	0	0	38.03	0	0	12.8
2015	12	23	8	15	10	35	0	0	0	0	0	0	0	38.01	0	0	12.8
2015	12	23	8	25	10	36	0	0	0	0	0	0	0	38.01	0	0	13
2015	12	23	8	35	10	35	0	0	0	0	0	0	0	37.99	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	8	45	10	35	0	0	0	0	0	0	0	38.01	0	0	13
2015	12	23	8	55	10	35	0	0	0	0	0	0	0	38.01	0	0	13
2015	12	23	9	5	10	35	0	0	0	0	0	0	0	38.03	0	0	13
2015	12	23	9	15	10	35	0	0	0	0	0	0	0	38.05	0	0	13.2
2015	12	23	9	25	10	35	0	0	0	0	0	0	0	38.08	0	0	13.2
2015	12	23	9	35	10	36	0	0	0	0	0	0	0	38.12	0	0	13.2
2015	12	23	9	45	10	35	0	0	0	0	0	0	0	38.19	0	0	13.2
2015	12	23	9	55	10	35	0	0	0	0	0	0	0	38.23	0	0	13.2
2015	12	23	10	5	10	35	0	0	0	0	0	0	0	38.32	0	0	13.2
2015	12	23	10	15	10	35	0	0	0	0	0	0	0	38.41	0	0	13.2
2015	12	23	10	25	10	35	0	0	0	0	0	0	0	38.52	0	0	13.2
2015	12	23	10	35	10	36	0	0	0	0	0	0	0	38.64	0	0	13.2
2015	12	23	10	45	10	34	0	0	0	0	0	0	0	38.79	0	0	13.2
2015	12	23	10	55	10	35	0	0	0	0	0	0	0	39.13	0	0	13.2
2015	12	23	11	5	10	36	0	0	0	0	0	0	0	39.47	0	0	13.2
2015	12	23	11	15	10	35	0	0	0	0	0	0	0	39.67	0	0	13
2015	12	23	11	25	10	35	0	0	0	0	0	0	0	39.85	0	0	13
2015	12	23	11	35	10	35	0	0	0	0	0	0	0	40.03	0	0	13
2015	12	23	11	45	10	35	0	0	0	0	0	0	0	40.17	0	0	13.2
2015	12	23	11	55	10	34	0	0	0	0	0	0	0	40.32	0	0	13
2015	12	23	12	5	10	35	0	0	0	0	0	0	0	40.48	0	0	13
2015	12	23	12	15	10	35	0	0	0	0	0	0	0	40.66	0	0	13
2015	12	23	12	25	10	35	0	0	0	0	0	0	0	40.78	0	0	13
2015	12	23	12	35	10	35	0	0	0	0	0	0	0	40.96	0	0	13
2015	12	23	12	45	10	35	0	0	0	0	0	0	0	41.11	0	0	13
2015	12	23	12	55	10	34	0	0	0	0	0	0	0	41.27	0	0	13
2015	12	23	13	5	10	35	0	0	0	0	0	0	0	41.43	0	0	13
2015	12	23	13	15	10	35	0	0	0	0	0	0	0	41.61	0	0	12.8
2015	12	23	13	25	10	35	0	0	0	0	0	0	0	41.7	0	0	12.8
2015	12	23	13	35	10	35	0	0	0	0	0	0	0	41.86	0	0	12.8
2015	12	23	13	45	10	35	0	0	0	0	0	0	0	41.94	0	0	12.6
2015	12	23	13	55	10	35	0	0	0	0	0	0	0	42.1	0	0	12.6
2015	12	23	14	5	10	34	0	0	0	0	0	0	0	42.22	0	0	12.6
2015	12	23	14	15	10	35	0	0	0	0	0	0	0	42.35	0	0	12.6
2015	12	23	14	25	10	34	0	0	0	0	0	0	0	42.39	0	0	12.4
2015	12	23	14	35	10	35	0	0	0	0	0	0	0	42.46	0	0	12.4
2015	12	23	14	45	10	34	0	0	0	0	0	0	0	42.55	0	0	12.4
2015	12	23	14	55	10	34	0	0	0	0	0	0	0	42.58	0	0	12.2
2015	12	23	15	5	10	35	0	0	0	0	0	0	0	42.58	0	0	12.2
2015	12	23	15	15	10	34	0	0	0	0	0	0	0	42.66	0	0	12.2
2015	12	23	15	25	10	34	0	0	0	0	0	0	0	42.67	0	0	12
2015	12	23	15	35	10	35	0	0	0	0	0	0	0	42.67	0	0	12
2015	12	23	15	45	10	34	0	0	0	0	0	0	0	42.67	0	0	12
2015	12	23	15	55	10	35	0	0	0	0	0	0	0	42.67	0	0	12
2015	12	23	16	5	10	35	0	0	0	0	0	0	0	42.66	0	0	12
2015	12	23	16	15	10	34	0	0	0	0	0	0	0	42.64	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	16	25	10	35	0	0	0	0	0	0	0	42.62	0	0	12
2015	12	23	16	35	10	34	0	0	0	0	0	0	0	42.6	0	0	12
2015	12	23	16	45	10	35	0	0	0	0	0	0	0	42.57	0	0	11.8
2015	12	23	16	55	10	35	0	0	0	0	0	0	0	42.55	0	0	11.8
2015	12	23	17	5	10	34	0	0	0	0	0	0	0	42.51	0	0	11.8
2015	12	23	17	15	10	34	0	0	0	0	0	0	0	42.49	0	0	11.8
2015	12	23	17	25	10	35	0	0	0	0	0	0	0	42.46	0	0	11.8
2015	12	23	17	35	10	35	0	0	0	0	0	0	0	42.44	0	0	11.8
2015	12	23	17	45	10	34	0	0	0	0	0	0	0	42.42	0	0	11.8
2015	12	23	17	55	10	35	0	0	0	0	0	0	0	42.39	0	0	11.8
2015	12	23	18	5	10	34	0	0	0	0	0	0	0	42.37	0	0	11.8
2015	12	23	18	15	10	35	0	0	0	0	0	0	0	42.35	0	0	11.8
2015	12	23	18	25	10	35	0	0	0	0	0	0	0	42.33	0	0	11.8
2015	12	23	18	35	10	35	0	0	0	0	0	0	0	42.31	0	0	11.8
2015	12	23	18	45	10	34	0	0	0	0	0	0	0	42.3	0	0	11.8
2015	12	23	18	55	10	34	0	0	0	0	0	0	0	42.26	0	0	11.8
2015	12	23	19	5	10	34	0	0	0	0	0	0	0	42.24	0	0	11.8
2015	12	23	19	15	10	35	0	0	0	0	0	0	0	42.22	0	0	11.8
2015	12	23	19	25	10	34	0	0	0	0	0	0	0	42.19	0	0	11.8
2015	12	23	19	35	10	35	0	0	0	0	0	0	0	42.17	0	0	11.8
2015	12	23	19	45	10	35	0	0	0	0	0	0	0	42.13	0	0	11.8
2015	12	23	19	55	10	35	0	0	0	0	0	0	0	42.12	0	0	11.8
2015	12	23	20	5	10	35	0	0	0	0	0	0	0	42.06	0	0	11.8
2015	12	23	20	15	10	34	0	0	0	0	0	0	0	42.03	0	0	11.8
2015	12	23	20	25	10	34	0	0	0	0	0	0	0	41.97	0	0	11.8
2015	12	23	20	35	10	34	0	0	0	0	0	0	0	41.92	0	0	11.8
2015	12	23	20	45	10	35	0	0	0	0	0	0	0	41.85	0	0	11.8
2015	12	23	20	55	10	35	0	0	0	0	0	0	0	41.81	0	0	11.8
2015	12	23	21	5	10	35	0	0	0	0	0	0	0	41.76	0	0	11.8
2015	12	23	21	15	10	34	0	0	0	0	0	0	0	41.68	0	0	11.8
2015	12	23	21	25	10	35	0	0	0	0	0	0	0	41.63	0	0	11.8
2015	12	23	21	35	10	35	0	0	0	0	0	0	0	41.56	0	0	11.8
2015	12	23	21	45	10	35	0	0	0	0	0	0	0	41.5	0	0	11.8
2015	12	23	21	55	10	35	0	0	0	0	0	0	0	41.43	0	0	11.8
2015	12	23	22	5	10	35	0	0	0	0	0	0	0	41.38	0	0	11.8
2015	12	23	22	15	10	35	0	0	0	0	0	0	0	41.29	0	0	11.8
2015	12	23	22	25	10	35	0	0	0	0	0	0	0	41.22	0	0	11.8
2015	12	23	22	35	10	34	0	0	0	0	0	0	0	41.16	0	0	11.8
2015	12	23	22	45	10	35	0	0	0	0	0	0	0	41.07	0	0	11.8
2015	12	23	22	55	10	35	0	0	0	0	0	0	0	41.02	0	0	11.8
2015	12	23	23	5	10	35	0	0	0	0	0	0	0	40.93	0	0	11.8
2015	12	23	23	15	10	35	0	0	0	0	0	0	0	40.86	0	0	11.8
2015	12	23	23	25	10	35	0	0	0	0	0	0	0	40.77	0	0	11.8
2015	12	23	23	35	10	35	0	0	0	0	0	0	0	40.68	0	0	11.8
2015	12	23	23	45	10	35	0	0	0	0	0	0	0	40.59	0	0	11.8
2015	12	23	23	55	10	35	0	0	0	0	0	0	0	40.5	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	0	5	10	35	0	0	0	0	0	0	0	40.41	0	0	11.6
2015	12	24	0	15	10	35	0	0	0	0	0	0	0	40.32	0	0	11.6
2015	12	24	0	25	10	35	0	0	0	0	0	0	0	40.23	0	0	11.6
2015	12	24	0	35	10	35	0	0	0	0	0	0	0	40.12	0	0	11.6
2015	12	24	0	45	10	35	0	0	0	0	0	0	0	40.03	0	0	11.6
2015	12	24	0	55	10	35	0	0	0	0	0	0	0	39.92	0	0	11.6
2015	12	24	1	5	10	34	0	0	0	0	0	0	0	39.83	0	0	11.6
2015	12	24	1	15	10	35	0	0	0	0	0	0	0	39.72	0	0	11.6
2015	12	24	1	25	10	35	0	0	0	0	0	0	0	39.61	0	0	11.6
2015	12	24	1	35	10	35	0	0	0	0	0	0	0	39.52	0	0	11.6
2015	12	24	1	45	10	35	0	0	0	0	0	0	0	39.42	0	0	11.6
2015	12	24	1	55	10	35	0	0	0	0	0	0	0	39.33	0	0	11.6
2015	12	24	2	5	10	36	0	0	0	0	0	0	0	39.24	0	0	11.6
2015	12	24	2	15	10	35	0	0	0	0	0	0	0	39.15	0	0	11.6
2015	12	24	2	25	10	35	0	0	0	0	0	0	0	39.04	0	0	11.6
2015	12	24	2	35	10	35	0	0	0	0	0	0	0	38.95	0	0	11.6
2015	12	24	2	45	10	35	0	0	0	0	0	0	0	38.86	0	0	11.6
2015	12	24	2	55	10	35	0	0	0	0	0	0	0	38.77	0	0	11.6
2015	12	24	3	5	10	35	0	0	0	0	0	0	0	38.66	0	0	11.6
2015	12	24	3	15	10	35	0	0	0	0	0	0	0	38.59	0	0	11.6
2015	12	24	3	25	10	35	0	0	0	0	0	0	0	38.5	0	0	11.6
2015	12	24	3	35	10	35	0	0	0	0	0	0	0	38.41	0	0	11.6
2015	12	24	3	45	10	35	0	0	0	0	0	0	0	38.32	0	0	11.6
2015	12	24	3	55	10	34	0	0	0	0	0	0	0	38.23	0	0	11.6
2015	12	24	4	5	10	35	0	0	0	0	0	0	0	38.16	0	0	11.6
2015	12	24	4	15	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	24	4	25	10	35	0	0	0	0	0	0	0	37.96	0	0	11.6
2015	12	24	4	35	10	35	0	0	0	0	0	0	0	37.87	0	0	11.6
2015	12	24	4	45	10	35	0	0	0	0	0	0	0	37.8	0	0	11.6
2015	12	24	4	55	10	35	0	0	0	0	0	0	0	37.71	0	0	11.6
2015	12	24	5	5	10	35	0	0	0	0	0	0	0	37.62	0	0	11.6
2015	12	24	5	15	10	35	0	0	0	0	0	0	0	37.53	0	0	11.6
2015	12	24	5	25	10	35	0	0	0	0	0	0	0	37.47	0	0	11.6
2015	12	24	5	35	10	35	0	0	0	0	0	0	0	37.38	0	0	11.6
2015	12	24	5	45	10	36	0	0	0	0	0	0	0	37.31	0	0	11.6
2015	12	24	5	55	10	35	0	0	0	0	0	0	0	37.22	0	0	11.6
2015	12	24	6	5	10	35	0	0	0	0	0	0	0	37.17	0	0	11.6
2015	12	24	6	15	10	35	0	0	0	0	0	0	0	37.08	0	0	11.6
2015	12	24	6	25	10	35	0	0	0	0	0	0	0	37	0	0	11.6
2015	12	24	6	35	10	36	0	0	0	0	0	0	0	36.95	0	0	11.6
2015	12	24	6	45	10	34	0	0	0	0	0	0	0	36.86	0	0	11.6
2015	12	24	6	55	10	35	0	0	0	0	0	0	0	36.79	0	0	11.6
2015	12	24	7	5	10	35	0	0	0	0	0	0	0	36.73	0	0	11.6
2015	12	24	7	15	10	35	0	0	0	0	0	0	0	36.7	0	0	11.6
2015	12	24	7	25	10	35	0	0	0	0	0	0	0	36.63	0	0	11.6
2015	12	24	7	35	10	35	0	0	0	0	0	0	0	36.57	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	7	45	10	35	0	0	0	0	0	0	0	36.54	0	0	12.2
2015	12	24	7	55	10	35	0	0	0	0	0	0	0	36.48	0	0	12.6
2015	12	24	8	5	10	35	0	0	0	0	0	0	0	36.46	0	0	12.8
2015	12	24	8	15	10	36	0	0	0	0	0	0	0	36.43	0	0	12.8
2015	12	24	8	25	10	36	0	0	0	0	0	0	0	36.37	0	0	13
2015	12	24	8	35	10	35	0	0	0	0	0	0	0	36.34	0	0	13
2015	12	24	8	45	10	35	0	0	0	0	0	0	0	36.32	0	0	13.2
2015	12	24	8	55	10	35	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	24	9	5	10	36	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	24	9	15	10	35	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	24	9	25	10	35	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	24	9	35	10	35	0	0	0	0	0	0	0	36.34	0	0	13.2
2015	12	24	9	45	10	35	0	0	0	0	0	0	0	36.36	0	0	13.2
2015	12	24	9	55	10	36	0	0	0	0	0	0	0	36.39	0	0	13.2
2015	12	24	10	5	10	35	0	0	0	0	0	0	0	36.45	0	0	13.2
2015	12	24	10	15	10	35	0	0	0	0	0	0	0	36.54	0	0	13.2
2015	12	24	10	25	10	35	0	0	0	0	0	0	0	36.63	0	0	13.2
2015	12	24	10	35	10	35	0	0	0	0	0	0	0	36.72	0	0	13.2
2015	12	24	10	45	10	36	0	0	0	0	0	0	0	36.84	0	0	13.2
2015	12	24	10	55	10	35	0	0	0	0	0	0	0	37.18	0	0	13.2
2015	12	24	11	5	10	35	0	0	0	0	0	0	0	37.56	0	0	13
2015	12	24	11	15	10	35	0	0	0	0	0	0	0	37.69	0	0	13
2015	12	24	11	25	10	35	0	0	0	0	0	0	0	37.94	0	0	13
2015	12	24	11	35	10	35	0	0	0	0	0	0	0	38.19	0	0	13.2
2015	12	24	11	45	10	35	0	0	0	0	0	0	0	38.16	0	0	12.8
2015	12	24	11	55	10	36	0	0	0	0	0	0	0	38.25	0	0	12.6
2015	12	24	12	5	10	36	0	0	0	0	0	0	0	38.37	0	0	12.8
2015	12	24	12	15	10	35	0	0	0	0	0	0	0	38.52	0	0	12.6
2015	12	24	12	25	10	36	0	0	0	0	0	0	0	38.68	0	0	12.8
2015	12	24	12	35	10	35	0	0	0	0	0	0	0	38.75	0	0	12.4
2015	12	24	12	45	10	35	0	0	0	0	0	0	0	38.82	0	0	12.4
2015	12	24	12	55	10	36	0	0	0	0	0	0	0	38.97	0	0	12.4
2015	12	24	13	5	10	35	0	0	0	0	0	0	0	39	0	0	12.2
2015	12	24	13	15	10	35	0	0	0	0	0	0	0	39.11	0	0	12.2
2015	12	24	13	25	10	34	0	0	0	0	0	0	0	39.2	0	0	12.2
2015	12	24	13	35	10	35	0	0	0	0	0	0	0	39.31	0	0	12.2
2015	12	24	13	45	10	35	0	0	0	0	0	0	0	39.4	0	0	12.2
2015	12	24	13	55	10	34	0	0	0	0	0	0	0	39.43	0	0	12.2
2015	12	24	14	5	10	35	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	24	14	15	10	35	0	0	0	0	0	0	0	39.56	0	0	12
2015	12	24	14	25	10	36	0	0	0	0	0	0	0	39.58	0	0	12
2015	12	24	14	35	10	35	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	24	14	45	10	35	0	0	0	0	0	0	0	39.65	0	0	12
2015	12	24	14	55	10	35	0	0	0	0	0	0	0	39.69	0	0	12
2015	12	24	15	5	10	35	0	0	0	0	0	0	0	39.74	0	0	12
2015	12	24	15	15	10	35	0	0	0	0	0	0	0	39.79	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	15	25	10	35	0	0	0	0	0	0	0	39.83	0	0	12
2015	12	24	15	35	10	35	0	0	0	0	0	0	0	39.87	0	0	12
2015	12	24	15	45	10	35	0	0	0	0	0	0	0	39.88	0	0	12
2015	12	24	15	55	10	35	0	0	0	0	0	0	0	39.9	0	0	12
2015	12	24	16	5	10	35	0	0	0	0	0	0	0	39.94	0	0	11.8
2015	12	24	16	15	10	35	0	0	0	0	0	0	0	39.96	0	0	11.8
2015	12	24	16	25	10	35	0	0	0	0	0	0	0	39.97	0	0	11.8
2015	12	24	16	35	10	35	0	0	0	0	0	0	0	39.99	0	0	11.8
2015	12	24	16	45	10	35	0	0	0	0	0	0	0	40.01	0	0	11.8
2015	12	24	16	55	10	34	0	0	0	0	0	0	0	40.03	0	0	11.8
2015	12	24	17	5	10	35	0	0	0	0	0	0	0	40.05	0	0	11.8
2015	12	24	17	15	10	34	0	0	0	0	0	0	0	40.06	0	0	11.8
2015	12	24	17	25	10	35	0	0	0	0	0	0	0	40.08	0	0	11.8
2015	12	24	17	35	10	35	0	0	0	0	0	0	0	40.12	0	0	11.8
2015	12	24	17	45	10	35	0	0	0	0	0	0	0	40.14	0	0	11.8
2015	12	24	17	55	10	35	0	0	0	0	0	0	0	40.17	0	0	11.8
2015	12	24	18	5	10	35	0	0	0	0	0	0	0	40.19	0	0	11.8
2015	12	24	18	15	10	35	0	0	0	0	0	0	0	40.21	0	0	11.8
2015	12	24	18	25	10	35	0	0	0	0	0	0	0	40.24	0	0	11.8
2015	12	24	18	35	10	35	0	0	0	0	0	0	0	40.28	0	0	11.8
2015	12	24	18	45	10	35	0	0	0	0	0	0	0	40.28	0	0	11.8
2015	12	24	18	55	10	35	0	0	0	0	0	0	0	40.32	0	0	11.8
2015	12	24	19	5	10	35	0	0	0	0	0	0	0	40.33	0	0	11.8
2015	12	24	19	15	10	34	0	0	0	0	0	0	0	40.35	0	0	11.8
2015	12	24	19	25	10	35	0	0	0	0	0	0	0	40.35	0	0	11.8
2015	12	24	19	35	10	34	0	0	0	0	0	0	0	40.37	0	0	11.8
2015	12	24	19	45	10	35	0	0	0	0	0	0	0	40.37	0	0	11.8
2015	12	24	19	55	10	35	0	0	0	0	0	0	0	40.37	0	0	11.8
2015	12	24	20	5	10	35	0	0	0	0	0	0	0	40.35	0	0	11.8
2015	12	24	20	15	10	35	0	0	0	0	0	0	0	40.35	0	0	11.8
2015	12	24	20	25	10	35	0	0	0	0	0	0	0	40.33	0	0	11.8
2015	12	24	20	35	10	35	0	0	0	0	0	0	0	40.32	0	0	11.8
2015	12	24	20	45	10	35	0	0	0	0	0	0	0	40.32	0	0	11.8
2015	12	24	20	55	10	36	0	0	0	0	0	0	0	40.3	0	0	11.8
2015	12	24	21	5	10	35	0	0	0	0	0	0	0	40.26	0	0	11.8
2015	12	24	21	15	10	35	0	0	0	0	0	0	0	40.24	0	0	11.8
2015	12	24	21	25	10	35	0	0	0	0	0	0	0	40.23	0	0	11.8
2015	12	24	21	35	10	35	0	0	0	0	0	0	0	40.21	0	0	11.8
2015	12	24	21	45	10	35	0	0	0	0	0	0	0	40.17	0	0	11.8
2015	12	24	21	55	10	35	0	0	0	0	0	0	0	40.15	0	0	11.6
2015	12	24	22	5	10	36	0	0	0	0	0	0	0	40.1	0	0	11.6
2015	12	24	22	15	10	35	0	0	0	0	0	0	0	40.06	0	0	11.6
2015	12	24	22	25	10	35	0	0	0	0	0	0	0	40.01	0	0	11.6
2015	12	24	22	35	10	35	0	0	0	0	0	0	0	39.94	0	0	11.6
2015	12	24	22	45	10	35	0	0	0	0	0	0	0	39.87	0	0	11.6
2015	12	24	22	55	10	35	0	0	0	0	0	0	0	39.79	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	23	5	10	35	0	0	0	0	0	0	0	39.72	0	0	11.6
2015	12	24	23	15	10	35	0	0	0	0	0	0	0	39.63	0	0	11.6
2015	12	24	23	25	10	34	0	0	0	0	0	0	0	39.56	0	0	11.6
2015	12	24	23	35	10	35	0	0	0	0	0	0	0	39.47	0	0	11.6
2015	12	24	23	45	10	35	0	0	0	0	0	0	0	39.38	0	0	11.6
2015	12	24	23	55	10	34	0	0	0	0	0	0	0	39.31	0	0	11.6
2015	12	25	0	5	10	35	0	0	0	0	0	0	0	39.24	0	0	11.6
2015	12	25	0	15	10	36	0	0	0	0	0	0	0	39.15	0	0	11.6
2015	12	25	0	25	10	35	0	0	0	0	0	0	0	39.07	0	0	11.6
2015	12	25	0	35	10	35	0	0	0	0	0	0	0	39	0	0	11.6
2015	12	25	0	45	10	34	0	0	0	0	0	0	0	38.93	0	0	11.6
2015	12	25	0	55	10	35	0	0	0	0	0	0	0	38.86	0	0	11.6
2015	12	25	1	5	10	35	0	0	0	0	0	0	0	38.79	0	0	11.6
2015	12	25	1	15	10	35	0	0	0	0	0	0	0	38.71	0	0	11.6
2015	12	25	1	25	10	35	0	0	0	0	0	0	0	38.64	0	0	11.6
2015	12	25	1	35	10	35	0	0	0	0	0	0	0	38.57	0	0	11.6
2015	12	25	1	45	10	35	0	0	0	0	0	0	0	38.5	0	0	11.6
2015	12	25	1	55	10	35	0	0	0	0	0	0	0	38.43	0	0	11.6
2015	12	25	2	5	10	35	0	0	0	0	0	0	0	38.35	0	0	11.6
2015	12	25	2	15	10	35	0	0	0	0	0	0	0	38.26	0	0	11.6
2015	12	25	2	25	10	35	0	0	0	0	0	0	0	38.21	0	0	11.6
2015	12	25	2	35	10	35	0	0	0	0	0	0	0	38.12	0	0	11.6
2015	12	25	2	45	10	35	0	0	0	0	0	0	0	38.05	0	0	11.6
2015	12	25	2	55	10	35	0	0	0	0	0	0	0	37.98	0	0	11.6
2015	12	25	3	5	10	35	0	0	0	0	0	0	0	37.9	0	0	11.6
2015	12	25	3	15	10	35	0	0	0	0	0	0	0	37.83	0	0	11.6
2015	12	25	3	25	10	35	0	0	0	0	0	0	0	37.76	0	0	11.6
2015	12	25	3	35	10	35	0	0	0	0	0	0	0	37.69	0	0	11.6
2015	12	25	3	45	10	35	0	0	0	0	0	0	0	37.62	0	0	11.4
2015	12	25	3	55	10	36	0	0	0	0	0	0	0	37.54	0	0	11.4
2015	12	25	4	5	10	35	0	0	0	0	0	0	0	37.47	0	0	11.4
2015	12	25	4	15	10	36	0	0	0	0	0	0	0	37.4	0	0	11.4
2015	12	25	4	25	10	35	0	0	0	0	0	0	0	37.33	0	0	11.4
2015	12	25	4	35	10	35	0	0	0	0	0	0	0	37.26	0	0	11.4
2015	12	25	4	45	10	35	0	0	0	0	0	0	0	37.18	0	0	11.4
2015	12	25	4	55	10	35	0	0	0	0	0	0	0	37.11	0	0	11.4
2015	12	25	5	5	10	34	0	0	0	0	0	0	0	37.04	0	0	11.4
2015	12	25	5	15	10	35	0	0	0	0	0	0	0	36.97	0	0	11.4
2015	12	25	5	25	10	35	0	0	0	0	0	0	0	36.9	0	0	11.4
2015	12	25	5	35	10	35	0	0	0	0	0	0	0	36.84	0	0	11.4
2015	12	25	5	45	10	35	0	0	0	0	0	0	0	36.77	0	0	11.4
2015	12	25	5	55	10	35	0	0	0	0	0	0	0	36.7	0	0	11.4
2015	12	25	6	5	10	35	0	0	0	0	0	0	0	36.64	0	0	11.4
2015	12	25	6	15	10	36	0	0	0	0	0	0	0	36.59	0	0	11.4
2015	12	25	6	25	10	35	0	0	0	0	0	0	0	36.5	0	0	11.4
2015	12	25	6	35	10	35	0	0	0	0	0	0	0	36.43	0	0	11.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	6	45	10	34	0	0	0	0	0	0	0	36.37	0	0	11.4
2015	12	25	6	55	10	35	0	0	0	0	0	0	0	36.3	0	0	11.4
2015	12	25	7	5	10	36	0	0	0	0	0	0	0	36.25	0	0	11.4
2015	12	25	7	15	10	36	0	0	0	0	0	0	0	36.19	0	0	11.4
2015	12	25	7	25	10	35	0	0	0	0	0	0	0	36.14	0	0	11.4
2015	12	25	7	35	10	36	0	0	0	0	0	0	0	36.07	0	0	11.4
2015	12	25	7	45	10	35	0	0	0	0	0	0	0	36.03	0	0	12.2
2015	12	25	7	55	10	35	0	0	0	0	0	0	0	36	0	0	12.6
2015	12	25	8	5	10	35	0	0	0	0	0	0	0	35.96	0	0	12.8
2015	12	25	8	15	10	35	0	0	0	0	0	0	0	35.91	0	0	13
2015	12	25	8	25	10	35	0	0	0	0	0	0	0	35.85	0	0	13
2015	12	25	8	35	10	35	0	0	0	0	0	0	0	35.82	0	0	13.2
2015	12	25	8	45	10	36	0	0	0	0	0	0	0	35.8	0	0	13.2
2015	12	25	8	55	10	36	0	0	0	0	0	0	0	35.76	0	0	13.2
2015	12	25	9	5	10	36	0	0	0	0	0	0	0	35.74	0	0	13.2
2015	12	25	9	15	10	35	0	0	0	0	0	0	0	35.73	0	0	13.2
2015	12	25	9	25	10	35	0	0	0	0	0	0	0	35.74	0	0	13.2
2015	12	25	9	35	10	35	0	0	0	0	0	0	0	35.74	0	0	13.2
2015	12	25	9	45	10	36	0	0	0	0	0	0	0	35.76	0	0	13.2
2015	12	25	9	55	10	35	0	0	0	0	0	0	0	35.76	0	0	13.2
2015	12	25	10	5	10	36	0	0	0	0	0	0	0	35.82	0	0	13.2
2015	12	25	10	15	10	35	0	0	0	0	0	0	0	35.85	0	0	13.2
2015	12	25	10	25	10	35	0	0	0	0	0	0	0	35.91	0	0	13.2
2015	12	25	10	35	10	35	0	0	0	0	0	0	0	35.96	0	0	13.2
2015	12	25	10	45	10	36	0	0	0	0	0	0	0	36.03	0	0	13.2
2015	12	25	10	55	10	35	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	25	11	5	10	35	0	0	0	0	0	0	0	36.7	0	0	13.2
2015	12	25	11	15	10	35	0	0	0	0	0	0	0	36.91	0	0	13.2
2015	12	25	11	25	10	35	0	0	0	0	0	0	0	37.06	0	0	13.2
2015	12	25	11	35	10	35	0	0	0	0	0	0	0	37.13	0	0	13.2
2015	12	25	11	45	10	35	0	0	0	0	0	0	0	37.27	0	0	13.2
2015	12	25	11	55	10	35	0	0	0	0	0	0	0	37.4	0	0	13.2
2015	12	25	12	5	10	35	0	0	0	0	0	0	0	37.49	0	0	13.2
2015	12	25	12	15	10	36	0	0	0	0	0	0	0	37.67	0	0	13.2
2015	12	25	12	25	10	35	0	0	0	0	0	0	0	37.8	0	0	13.2
2015	12	25	12	35	10	35	0	0	0	0	0	0	0	38.07	0	0	13.2
2015	12	25	12	45	10	35	0	0	0	0	0	0	0	38.21	0	0	13.2
2015	12	25	12	55	10	35	0	0	0	0	0	0	0	38.32	0	0	13.2
2015	12	25	13	5	10	36	0	0	0	0	0	0	0	38.5	0	0	13.2
2015	12	25	13	15	10	35	0	0	0	0	0	0	0	38.55	0	0	12.8
2015	12	25	13	25	10	35	0	0	0	0	0	0	0	38.66	0	0	13
2015	12	25	13	35	10	35	0	0	0	0	0	0	0	38.93	0	0	13
2015	12	25	13	45	10	35	0	0	0	0	0	0	0	39.06	0	0	12.8
2015	12	25	13	55	10	35	0	0	0	0	0	0	0	38.95	0	0	12.4
2015	12	25	14	5	10	35	0	0	0	0	0	0	0	38.89	0	0	12.2
2015	12	25	14	15	10	35	0	0	0	0	0	0	0	38.95	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	14	25	10	35	0	0	0	0	0	0	0	38.97	0	0	12.2
2015	12	25	14	35	10	35	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	25	14	45	10	35	0	0	0	0	0	0	0	38.98	0	0	12
2015	12	25	14	55	10	35	0	0	0	0	0	0	0	39.02	0	0	12.2
2015	12	25	15	5	10	35	0	0	0	0	0	0	0	39.07	0	0	12.2
2015	12	25	15	15	10	35	0	0	0	0	0	0	0	39.06	0	0	12
2015	12	25	15	25	10	36	0	0	0	0	0	0	0	39.02	0	0	12
2015	12	25	15	35	10	36	0	0	0	0	0	0	0	39	0	0	12
2015	12	25	15	45	10	35	0	0	0	0	0	0	0	39	0	0	12
2015	12	25	15	55	10	35	0	0	0	0	0	0	0	39	0	0	12
2015	12	25	16	5	10	35	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	25	16	15	10	36	0	0	0	0	0	0	0	38.93	0	0	12
2015	12	25	16	25	10	34	0	0	0	0	0	0	0	38.91	0	0	12
2015	12	25	16	35	10	35	0	0	0	0	0	0	0	38.89	0	0	11.8
2015	12	25	16	45	10	35	0	0	0	0	0	0	0	38.88	0	0	11.8
2015	12	25	16	55	10	35	0	0	0	0	0	0	0	38.86	0	0	11.8
2015	12	25	17	5	10	35	0	0	0	0	0	0	0	38.82	0	0	11.8
2015	12	25	17	15	10	35	0	0	0	0	0	0	0	38.82	0	0	11.8
2015	12	25	17	25	10	35	0	0	0	0	0	0	0	38.8	0	0	11.8
2015	12	25	17	35	10	35	0	0	0	0	0	0	0	38.79	0	0	11.8
2015	12	25	17	45	10	35	0	0	0	0	0	0	0	38.77	0	0	11.8
2015	12	25	17	55	10	35	0	0	0	0	0	0	0	38.75	0	0	11.8
2015	12	25	18	5	10	36	0	0	0	0	0	0	0	38.73	0	0	11.8
2015	12	25	18	15	10	35	0	0	0	0	0	0	0	38.7	0	0	11.8
2015	12	25	18	25	10	35	0	0	0	0	0	0	0	38.68	0	0	11.8
2015	12	25	18	35	10	35	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	25	18	45	10	35	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	25	18	55	10	35	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	25	19	5	10	35	0	0	0	0	0	0	0	38.52	0	0	11.8
2015	12	25	19	15	10	36	0	0	0	0	0	0	0	38.46	0	0	11.8
2015	12	25	19	25	10	35	0	0	0	0	0	0	0	38.44	0	0	11.8
2015	12	25	19	35	10	35	0	0	0	0	0	0	0	38.39	0	0	11.8
2015	12	25	19	45	10	35	0	0	0	0	0	0	0	38.34	0	0	11.8
2015	12	25	19	55	10	35	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	25	20	5	10	35	0	0	0	0	0	0	0	38.26	0	0	11.8
2015	12	25	20	15	10	35	0	0	0	0	0	0	0	38.19	0	0	11.8
2015	12	25	20	25	10	36	0	0	0	0	0	0	0	38.16	0	0	11.8
2015	12	25	20	35	10	36	0	0	0	0	0	0	0	38.1	0	0	11.8
2015	12	25	20	45	10	36	0	0	0	0	0	0	0	38.07	0	0	11.8
2015	12	25	20	55	10	35	0	0	0	0	0	0	0	37.99	0	0	11.8
2015	12	25	21	5	10	35	0	0	0	0	0	0	0	37.96	0	0	11.8
2015	12	25	21	15	10	35	0	0	0	0	0	0	0	37.89	0	0	11.8
2015	12	25	21	25	10	36	0	0	0	0	0	0	0	37.85	0	0	11.8
2015	12	25	21	35	10	35	0	0	0	0	0	0	0	37.78	0	0	11.8
2015	12	25	21	45	10	35	0	0	0	0	0	0	0	37.72	0	0	11.8
2015	12	25	21	55	10	35	0	0	0	0	0	0	0	37.65	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	22	5	10	35	0	0	0	0	0	0	0	37.58	0	0	11.8
2015	12	25	22	15	10	35	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	25	22	25	10	35	0	0	0	0	0	0	0	37.45	0	0	11.8
2015	12	25	22	35	10	35	0	0	0	0	0	0	0	37.38	0	0	11.8
2015	12	25	22	45	10	35	0	0	0	0	0	0	0	37.31	0	0	11.8
2015	12	25	22	55	10	36	0	0	0	0	0	0	0	37.22	0	0	11.8
2015	12	25	23	5	10	35	0	0	0	0	0	0	0	37.13	0	0	11.8
2015	12	25	23	15	10	35	0	0	0	0	0	0	0	37.04	0	0	11.8
2015	12	25	23	25	10	35	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	25	23	35	10	35	0	0	0	0	0	0	0	36.86	0	0	11.8
2015	12	25	23	45	10	35	0	0	0	0	0	0	0	36.75	0	0	11.8
2015	12	25	23	55	10	35	0	0	0	0	0	0	0	36.68	0	0	11.6
2015	12	26	0	5	10	35	0	0	0	0	0	0	0	36.59	0	0	11.6
2015	12	26	0	15	10	36	0	0	0	0	0	0	0	36.48	0	0	11.6
2015	12	26	0	25	10	36	0	0	0	0	0	0	0	36.41	0	0	11.6
2015	12	26	0	35	10	35	0	0	0	0	0	0	0	36.32	0	0	11.6
2015	12	26	0	45	10	35	0	0	0	0	0	0	0	36.25	0	0	11.6
2015	12	26	0	55	10	36	0	0	0	0	0	0	0	36.16	0	0	11.6
2015	12	26	1	5	10	35	0	0	0	0	0	0	0	36.07	0	0	11.6
2015	12	26	1	15	10	35	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	26	1	25	10	35	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	26	1	35	10	36	0	0	0	0	0	0	0	35.83	0	0	11.6
2015	12	26	1	45	10	35	0	0	0	0	0	0	0	35.74	0	0	11.6
2015	12	26	1	55	10	36	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	26	2	5	10	35	0	0	0	0	0	0	0	35.6	0	0	11.6
2015	12	26	2	15	10	36	0	0	0	0	0	0	0	35.51	0	0	11.6
2015	12	26	2	25	10	36	0	0	0	0	0	0	0	35.44	0	0	11.6
2015	12	26	2	35	10	35	0	0	0	0	0	0	0	35.37	0	0	11.6
2015	12	26	2	45	10	35	0	0	0	0	0	0	0	35.29	0	0	11.6
2015	12	26	2	55	10	35	0	0	0	0	0	0	0	35.22	0	0	11.6
2015	12	26	3	5	10	35	0	0	0	0	0	0	0	35.15	0	0	11.6
2015	12	26	3	15	10	35	0	0	0	0	0	0	0	35.1	0	0	11.6
2015	12	26	3	25	10	35	0	0	0	0	0	0	0	35.02	0	0	11.6
2015	12	26	3	35	10	35	0	0	0	0	0	0	0	34.95	0	0	11.6
2015	12	26	3	45	10	35	0	0	0	0	0	0	0	34.86	0	0	11.6
2015	12	26	3	55	10	36	0	0	0	0	0	0	0	34.83	0	0	11.6
2015	12	26	4	5	10	35	0	0	0	0	0	0	0	34.75	0	0	11.6
2015	12	26	4	15	10	35	0	0	0	0	0	0	0	34.7	0	0	11.6
2015	12	26	4	25	10	35	0	0	0	0	0	0	0	34.63	0	0	11.6
2015	12	26	4	35	10	35	0	0	0	0	0	0	0	34.57	0	0	11.6
2015	12	26	4	45	10	36	0	0	0	0	0	0	0	34.5	0	0	11.6
2015	12	26	4	55	10	36	0	0	0	0	0	0	0	34.45	0	0	11.6
2015	12	26	5	5	10	36	0	0	0	0	0	0	0	34.38	0	0	11.6
2015	12	26	5	15	10	36	0	0	0	0	0	0	0	34.34	0	0	11.6
2015	12	26	5	25	10	35	0	0	0	0	0	0	0	34.29	0	0	11.6
2015	12	26	5	35	10	35	0	0	0	0	0	0	0	34.21	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	5	45	10	36	0	0	0	0	0	0	0	34.16	0	0	11.6
2015	12	26	5	55	10	35	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	26	6	5	10	35	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	26	6	15	10	35	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	26	6	25	10	36	0	0	0	0	0	0	0	33.93	0	0	11.6
2015	12	26	6	35	10	35	0	0	0	0	0	0	0	33.87	0	0	11.6
2015	12	26	6	45	10	35	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	26	6	55	10	36	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	26	7	5	10	35	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	26	7	15	10	36	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	26	7	25	10	35	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	26	7	35	10	35	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	26	7	45	10	36	0	0	0	0	0	0	0	33.6	0	0	12.2
2015	12	26	7	55	10	36	0	0	0	0	0	0	0	33.57	0	0	12.6
2015	12	26	8	5	10	36	0	0	0	0	0	0	0	33.55	0	0	12.8
2015	12	26	8	15	10	36	0	0	0	0	0	0	0	33.53	0	0	12.8
2015	12	26	8	25	10	36	0	0	0	0	0	0	0	33.51	0	0	13
2015	12	26	8	35	10	36	0	0	0	0	0	0	0	33.48	0	0	13
2015	12	26	8	45	10	36	0	0	0	0	0	0	0	33.46	0	0	13
2015	12	26	8	55	10	35	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	26	9	5	10	36	0	0	0	0	0	0	0	33.42	0	0	13.2
2015	12	26	9	15	10	36	0	0	0	0	0	0	0	33.42	0	0	13.2
2015	12	26	9	25	10	35	0	0	0	0	0	0	0	33.42	0	0	13.2
2015	12	26	9	35	10	35	0	0	0	0	0	0	0	33.42	0	0	13.2
2015	12	26	9	45	10	35	0	0	0	0	0	0	0	33.44	0	0	13.2
2015	12	26	9	55	10	36	0	0	0	0	0	0	0	33.46	0	0	13.4
2015	12	26	10	5	10	36	0	0	0	0	0	0	0	33.48	0	0	13.4
2015	12	26	10	15	10	36	0	0	0	0	0	0	0	33.49	0	0	13.4
2015	12	26	10	25	10	35	0	0	0	0	0	0	0	33.55	0	0	13.4
2015	12	26	10	35	10	35	0	0	0	0	0	0	0	33.58	0	0	13.4
2015	12	26	10	45	10	36	0	0	0	0	0	0	0	33.62	0	0	13.4
2015	12	26	10	55	10	35	0	0	0	0	0	0	0	33.87	0	0	13.4
2015	12	26	11	5	10	35	0	0	0	0	0	0	0	34.27	0	0	13.4
2015	12	26	11	15	10	36	0	0	0	0	0	0	0	34.41	0	0	13.4
2015	12	26	11	25	10	36	0	0	0	0	0	0	0	34.59	0	0	13.4
2015	12	26	11	35	10	35	0	0	0	0	0	0	0	34.72	0	0	13.4
2015	12	26	11	45	10	36	0	0	0	0	0	0	0	34.83	0	0	13.4
2015	12	26	11	55	10	35	0	0	0	0	0	0	0	34.92	0	0	13.4
2015	12	26	12	5	10	35	0	0	0	0	0	0	0	34.95	0	0	13.4
2015	12	26	12	15	10	35	0	0	0	0	0	0	0	35.06	0	0	13.2
2015	12	26	12	25	10	35	0	0	0	0	0	0	0	35.13	0	0	13.2
2015	12	26	12	35	10	36	0	0	0	0	0	0	0	35.15	0	0	13.2
2015	12	26	12	45	10	36	0	0	0	0	0	0	0	35.24	0	0	13.2
2015	12	26	12	55	10	35	0	0	0	0	0	0	0	35.35	0	0	13.2
2015	12	26	13	5	10	36	0	0	0	0	0	0	0	35.42	0	0	13.2
2015	12	26	13	15	10	35	0	0	0	0	0	0	0	35.51	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	13	25	10	35	0	0	0	0	0	0	0	35.6	0	0	13
2015	12	26	13	35	10	35	0	0	0	0	0	0	0	35.64	0	0	13
2015	12	26	13	45	10	35	0	0	0	0	0	0	0	35.74	0	0	13
2015	12	26	13	55	10	35	0	0	0	0	0	0	0	35.8	0	0	13
2015	12	26	14	5	10	35	0	0	0	0	0	0	0	35.89	0	0	12.8
2015	12	26	14	15	10	36	0	0	0	0	0	0	0	35.94	0	0	12.8
2015	12	26	14	25	10	35	0	0	0	0	0	0	0	36	0	0	12.8
2015	12	26	14	35	10	35	0	0	0	0	0	0	0	36.03	0	0	12.6
2015	12	26	14	45	10	35	0	0	0	0	0	0	0	36.09	0	0	12.6
2015	12	26	14	55	10	35	0	0	0	0	0	0	0	36.09	0	0	12.6
2015	12	26	15	5	10	36	0	0	0	0	0	0	0	36.1	0	0	12.4
2015	12	26	15	15	10	36	0	0	0	0	0	0	0	36.14	0	0	12.4
2015	12	26	15	25	10	35	0	0	0	0	0	0	0	36.12	0	0	12.4
2015	12	26	15	35	10	35	0	0	0	0	0	0	0	36.12	0	0	12.2
2015	12	26	15	45	10	35	0	0	0	0	0	0	0	36.12	0	0	12.2
2015	12	26	15	55	10	35	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	26	16	5	10	36	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	26	16	15	10	35	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	26	16	25	10	35	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	26	16	35	10	36	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	26	16	45	10	35	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	26	16	55	10	35	0	0	0	0	0	0	0	36	0	0	12
2015	12	26	17	5	10	35	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	26	17	15	10	35	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	26	17	25	10	36	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	26	17	35	10	36	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	26	17	45	10	35	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	26	17	55	10	36	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	26	18	5	10	35	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	26	18	15	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	26	18	25	10	35	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	26	18	35	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	26	18	45	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	26	18	55	10	36	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	26	19	5	10	36	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	26	19	15	10	36	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	26	19	25	10	36	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	26	19	35	10	36	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	26	19	45	10	36	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	26	19	55	10	35	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	26	20	5	10	35	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	26	20	15	10	36	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	26	20	25	10	35	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	26	20	35	10	36	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	26	20	45	10	35	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	26	20	55	10	36	0	0	0	0	0	0	0	35.6	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	21	5	10	36	0	0	0	0	0	0	0	35.56	0	0	11.8
2015	12	26	21	15	10	35	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	26	21	25	10	35	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	26	21	35	10	35	0	0	0	0	0	0	0	35.38	0	0	11.8
2015	12	26	21	45	10	35	0	0	0	0	0	0	0	35.35	0	0	11.8
2015	12	26	21	55	10	36	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	26	22	5	10	35	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	26	22	15	10	35	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	26	22	25	10	35	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	26	22	35	10	35	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	26	22	45	10	36	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	26	22	55	10	35	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	26	23	5	10	35	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	26	23	15	10	35	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	26	23	25	10	35	0	0	0	0	0	0	0	34.66	0	0	11.8
2015	12	26	23	35	10	35	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	26	23	45	10	35	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	26	23	55	10	36	0	0	0	0	0	0	0	34.43	0	0	11.8
2015	12	27	0	5	10	35	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	27	0	15	10	35	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	27	0	25	10	36	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	27	0	35	10	36	0	0	0	0	0	0	0	34.14	0	0	11.8
2015	12	27	0	45	10	36	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	27	0	55	10	36	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	27	1	5	10	37	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	27	1	15	10	36	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	27	1	25	10	35	0	0	0	0	0	0	0	33.76	0	0	11.8
2015	12	27	1	35	10	36	0	0	0	0	0	0	0	33.71	0	0	11.8
2015	12	27	1	45	10	36	0	0	0	0	0	0	0	33.66	0	0	11.8
2015	12	27	1	55	10	36	0	0	0	0	0	0	0	33.58	0	0	11.8
2015	12	27	2	5	10	35	0	0	0	0	0	0	0	33.53	0	0	11.8
2015	12	27	2	15	10	35	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	27	2	25	10	36	0	0	0	0	0	0	0	33.4	0	0	11.6
2015	12	27	2	35	10	35	0	0	0	0	0	0	0	33.35	0	0	11.6
2015	12	27	2	45	10	35	0	0	0	0	0	0	0	33.3	0	0	11.6
2015	12	27	2	55	10	36	0	0	0	0	0	0	0	33.22	0	0	11.6
2015	12	27	3	5	10	36	0	0	0	0	0	0	0	33.17	0	0	11.6
2015	12	27	3	15	10	35	0	0	0	0	0	0	0	33.12	0	0	11.6
2015	12	27	3	25	10	35	0	0	0	0	0	0	0	33.06	0	0	11.6
2015	12	27	3	35	10	36	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	27	3	45	10	35	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	27	3	55	10	36	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	27	4	5	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	27	4	15	10	35	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	27	4	25	10	35	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	27	4	35	10	36	0	0	0	0	0	0	0	32.76	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	4	45	10	37	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	27	4	55	10	36	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	27	5	5	10	36	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	27	5	15	10	35	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	27	5	25	10	36	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	27	5	35	10	36	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	27	5	45	10	36	0	0	0	0	0	0	0	32.54	0	0	11.6
2015	12	27	5	55	10	35	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	27	6	5	10	36	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	27	6	15	10	36	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	27	6	25	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	27	6	35	10	36	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	27	6	45	10	35	0	0	0	0	0	0	0	32.4	0	0	11.6
2015	12	27	6	55	10	37	0	0	0	0	0	0	0	32.38	0	0	11.6
2015	12	27	7	5	10	36	0	0	0	0	0	0	0	32.38	0	0	11.6
2015	12	27	7	15	10	36	0	0	0	0	0	0	0	32.36	0	0	11.6
2015	12	27	7	25	10	36	0	0	0	0	0	0	0	32.36	0	0	11.6
2015	12	27	7	35	10	36	0	0	0	0	0	0	0	32.34	0	0	11.6
2015	12	27	7	45	10	36	0	0	0	0	0	0	0	32.36	0	0	12.2
2015	12	27	7	55	10	35	0	0	0	0	0	0	0	32.34	0	0	12.6
2015	12	27	8	5	10	35	0	0	0	0	0	0	0	32.36	0	0	12.8
2015	12	27	8	15	10	36	0	0	0	0	0	0	0	32.36	0	0	13
2015	12	27	8	25	10	36	0	0	0	0	0	0	0	32.34	0	0	13
2015	12	27	8	35	10	36	0	0	0	0	0	0	0	32.36	0	0	13.2
2015	12	27	8	45	10	36	0	0	0	0	0	0	0	32.36	0	0	13.2
2015	12	27	8	55	10	36	0	0	0	0	0	0	0	32.36	0	0	13.2
2015	12	27	9	5	10	36	0	0	0	0	0	0	0	32.38	0	0	13.4
2015	12	27	9	15	10	36	0	0	0	0	0	0	0	32.4	0	0	13.4
2015	12	27	9	25	10	35	0	0	0	0	0	0	0	32.41	0	0	13.4
2015	12	27	9	35	10	36	0	0	0	0	0	0	0	32.43	0	0	13.4
2015	12	27	9	45	10	36	0	0	0	0	0	0	0	32.47	0	0	13.4
2015	12	27	9	55	10	35	0	0	0	0	0	0	0	32.5	0	0	13.4
2015	12	27	10	5	10	36	0	0	0	0	0	0	0	32.56	0	0	13.4
2015	12	27	10	15	10	36	0	0	0	0	0	0	0	32.67	0	0	13.2
2015	12	27	10	25	10	37	0	0	0	0	0	0	0	32.76	0	0	13.4
2015	12	27	10	35	10	35	0	0	0	0	0	0	0	32.74	0	0	12.8
2015	12	27	10	45	10	35	0	0	0	0	0	0	0	32.83	0	0	13
2015	12	27	10	55	10	36	0	0	0	0	0	0	0	33.04	0	0	13
2015	12	27	11	5	10	36	0	0	0	0	0	0	0	33.26	0	0	13.4
2015	12	27	11	15	10	36	0	0	0	0	0	0	0	33.55	0	0	13.4
2015	12	27	11	25	10	36	0	0	0	0	0	0	0	33.66	0	0	13.4
2015	12	27	11	35	10	35	0	0	0	0	0	0	0	33.78	0	0	13.4
2015	12	27	11	45	10	36	0	0	0	0	0	0	0	33.89	0	0	13.4
2015	12	27	11	55	10	36	0	0	0	0	0	0	0	33.89	0	0	13.2
2015	12	27	12	5	10	36	0	0	0	0	0	0	0	33.98	0	0	13.4
2015	12	27	12	15	10	36	0	0	0	0	0	0	0	34.02	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	12	25	10	35	0	0	0	0	0	0	0	34.03	0	0	13.2
2015	12	27	12	35	10	35	0	0	0	0	0	0	0	34.09	0	0	13.2
2015	12	27	12	45	10	35	0	0	0	0	0	0	0	34.12	0	0	13.2
2015	12	27	12	55	10	36	0	0	0	0	0	0	0	34.23	0	0	13.2
2015	12	27	13	5	10	35	0	0	0	0	0	0	0	34.12	0	0	12.8
2015	12	27	13	15	10	36	0	0	0	0	0	0	0	34.12	0	0	13.2
2015	12	27	13	25	10	35	0	0	0	0	0	0	0	34.2	0	0	12.6
2015	12	27	13	35	10	36	0	0	0	0	0	0	0	34.09	0	0	13
2015	12	27	13	45	10	35	0	0	0	0	0	0	0	34.12	0	0	12.8
2015	12	27	13	55	10	36	0	0	0	0	0	0	0	34.14	0	0	13
2015	12	27	14	5	10	35	0	0	0	0	0	0	0	34.25	0	0	12.8
2015	12	27	14	15	10	35	0	0	0	0	0	0	0	34.3	0	0	13
2015	12	27	14	25	10	35	0	0	0	0	0	0	0	34.3	0	0	12.8
2015	12	27	14	35	10	36	0	0	0	0	0	0	0	34.21	0	0	12.8
2015	12	27	14	45	10	36	0	0	0	0	0	0	0	34.21	0	0	12.6
2015	12	27	14	55	10	36	0	0	0	0	0	0	0	34.18	0	0	12.6
2015	12	27	15	5	10	35	0	0	0	0	0	0	0	34.2	0	0	12.6
2015	12	27	15	15	10	36	0	0	0	0	0	0	0	34.11	0	0	12.4
2015	12	27	15	25	10	36	0	0	0	0	0	0	0	34.07	0	0	12.4
2015	12	27	15	35	10	35	0	0	0	0	0	0	0	34.03	0	0	12.2
2015	12	27	15	45	10	35	0	0	0	0	0	0	0	34	0	0	12.2
2015	12	27	15	55	10	36	0	0	0	0	0	0	0	33.98	0	0	12
2015	12	27	16	5	10	36	0	0	0	0	0	0	0	33.96	0	0	12
2015	12	27	16	15	10	36	0	0	0	0	0	0	0	33.96	0	0	12
2015	12	27	16	25	10	36	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	27	16	35	10	35	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	27	16	45	10	35	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	27	16	55	10	36	0	0	0	0	0	0	0	33.98	0	0	12
2015	12	27	17	5	10	36	0	0	0	0	0	0	0	34	0	0	12
2015	12	27	17	15	10	35	0	0	0	0	0	0	0	34.03	0	0	12
2015	12	27	17	25	10	36	0	0	0	0	0	0	0	34.07	0	0	12
2015	12	27	17	35	10	36	0	0	0	0	0	0	0	34.12	0	0	12
2015	12	27	17	45	10	36	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	27	17	55	10	36	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	27	18	5	10	36	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	27	18	15	10	36	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	27	18	25	10	36	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	27	18	35	10	36	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	27	18	45	10	36	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	27	18	55	10	35	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	27	19	5	10	35	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	27	19	15	10	36	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	27	19	25	10	36	0	0	0	0	0	0	0	34.92	0	0	11.8
2015	12	27	19	35	10	35	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	27	19	45	10	35	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	27	19	55	10	35	0	0	0	0	0	0	0	35.08	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	20	5	10	36	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	27	20	15	10	35	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	27	20	25	10	35	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	27	20	35	10	36	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	27	20	45	10	35	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	27	20	55	10	35	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	27	21	5	10	36	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	27	21	15	10	36	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	27	21	25	10	36	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	27	21	35	10	35	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	27	21	45	10	35	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	27	21	55	10	36	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	27	22	5	10	36	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	27	22	15	10	36	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	27	22	25	10	35	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	27	22	35	10	35	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	27	22	45	10	36	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	27	22	55	10	35	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	27	23	5	10	36	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	27	23	15	10	36	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	27	23	25	10	36	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	27	23	35	10	36	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	27	23	45	10	36	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	27	23	55	10	36	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	28	0	5	10	36	0	0	0	0	0	0	0	34.43	0	0	11.6
2015	12	28	0	15	10	36	0	0	0	0	0	0	0	34.36	0	0	11.6
2015	12	28	0	25	10	36	0	0	0	0	0	0	0	34.29	0	0	11.6
2015	12	28	0	35	10	36	0	0	0	0	0	0	0	34.21	0	0	11.6
2015	12	28	0	45	10	36	0	0	0	0	0	0	0	34.14	0	0	11.6
2015	12	28	0	55	10	35	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	28	1	5	10	36	0	0	0	0	0	0	0	34	0	0	11.6
2015	12	28	1	15	10	35	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	28	1	25	10	35	0	0	0	0	0	0	0	33.85	0	0	11.6
2015	12	28	1	35	10	36	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	28	1	45	10	36	0	0	0	0	0	0	0	33.75	0	0	11.6
2015	12	28	1	55	10	36	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	28	2	5	10	35	0	0	0	0	0	0	0	33.62	0	0	11.6
2015	12	28	2	15	10	35	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	28	2	25	10	36	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	28	2	35	10	36	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	28	2	45	10	36	0	0	0	0	0	0	0	33.39	0	0	11.6
2015	12	28	2	55	10	36	0	0	0	0	0	0	0	33.35	0	0	11.6
2015	12	28	3	5	10	36	0	0	0	0	0	0	0	33.3	0	0	11.6
2015	12	28	3	15	10	36	0	0	0	0	0	0	0	33.22	0	0	11.6
2015	12	28	3	25	10	35	0	0	0	0	0	0	0	33.19	0	0	11.6
2015	12	28	3	35	10	36	0	0	0	0	0	0	0	33.13	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	3	45	10	36	0	0	0	0	0	0	0	33.1	0	0	11.6
2015	12	28	3	55	10	36	0	0	0	0	0	0	0	33.04	0	0	11.6
2015	12	28	4	5	10	36	0	0	0	0	0	0	0	33.03	0	0	11.6
2015	12	28	4	15	10	36	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	28	4	25	10	35	0	0	0	0	0	0	0	32.94	0	0	11.6
2015	12	28	4	35	10	36	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	28	4	45	10	35	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	28	4	55	10	36	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	28	5	5	10	35	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	28	5	15	10	36	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	28	5	25	10	36	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	28	5	35	10	36	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	28	5	45	10	36	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	28	5	55	10	35	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	28	6	5	10	36	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	28	6	15	10	36	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	28	6	25	10	35	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	28	6	35	10	36	0	0	0	0	0	0	0	32.63	0	0	11.6
2015	12	28	6	45	10	36	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	28	6	55	10	36	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	28	7	5	10	36	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	28	7	15	10	36	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	28	7	25	10	36	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	28	7	35	10	36	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	28	7	45	10	35	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	28	7	55	10	36	0	0	0	0	0	0	0	32.61	0	0	12.6
2015	12	28	8	5	10	36	0	0	0	0	0	0	0	32.61	0	0	12.8
2015	12	28	8	15	10	37	0	0	0	0	0	0	0	32.61	0	0	13
2015	12	28	8	25	10	35	0	0	0	0	0	0	0	32.61	0	0	13.2
2015	12	28	8	35	10	36	0	0	0	0	0	0	0	32.63	0	0	13.2
2015	12	28	8	45	10	36	0	0	0	0	0	0	0	32.63	0	0	13.2
2015	12	28	8	55	10	35	0	0	0	0	0	0	0	32.63	0	0	13.4
2015	12	28	9	5	10	35	0	0	0	0	0	0	0	32.65	0	0	13.4
2015	12	28	9	15	10	35	0	0	0	0	0	0	0	32.67	0	0	13.4
2015	12	28	9	25	10	36	0	0	0	0	0	0	0	32.67	0	0	13.6
2015	12	28	9	35	10	36	0	0	0	0	0	0	0	32.7	0	0	13.6
2015	12	28	9	45	10	36	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	28	9	55	10	36	0	0	0	0	0	0	0	32.76	0	0	13.6
2015	12	28	10	5	10	36	0	0	0	0	0	0	0	32.79	0	0	13.8
2015	12	28	10	15	10	36	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	28	10	25	10	35	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	28	10	35	10	35	0	0	0	0	0	0	0	32.92	0	0	13.8
2015	12	28	10	45	10	35	0	0	0	0	0	0	0	32.99	0	0	13.8
2015	12	28	10	55	10	36	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	28	11	5	10	36	0	0	0	0	0	0	0	33.75	0	0	13.4
2015	12	28	11	15	10	36	0	0	0	0	0	0	0	33.46	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	11	25	10	35	0	0	0	0	0	0	0	33.66	0	0	13.2
2015	12	28	11	35	10	36	0	0	0	0	0	0	0	33.94	0	0	13
2015	12	28	11	45	10	36	0	0	0	0	0	0	0	33.82	0	0	12.4
2015	12	28	11	55	10	36	0	0	0	0	0	0	0	33.82	0	0	12.4
2015	12	28	12	5	10	35	0	0	0	0	0	0	0	33.84	0	0	12.4
2015	12	28	12	15	10	35	0	0	0	0	0	0	0	33.8	0	0	12.4
2015	12	28	12	25	10	35	0	0	0	0	0	0	0	33.76	0	0	12.4
2015	12	28	12	35	10	36	0	0	0	0	0	0	0	33.84	0	0	12.2
2015	12	28	12	45	10	35	0	0	0	0	0	0	0	33.8	0	0	12.2
2015	12	28	12	55	10	36	0	0	0	0	0	0	0	33.75	0	0	12.2
2015	12	28	13	5	10	36	0	0	0	0	0	0	0	33.76	0	0	12.2
2015	12	28	13	15	10	35	0	0	0	0	0	0	0	33.8	0	0	12.2
2015	12	28	13	25	10	36	0	0	0	0	0	0	0	33.85	0	0	12.2
2015	12	28	13	35	10	36	0	0	0	0	0	0	0	33.94	0	0	12.2
2015	12	28	13	45	10	36	0	0	0	0	0	0	0	33.94	0	0	12.2
2015	12	28	13	55	10	36	0	0	0	0	0	0	0	33.93	0	0	12.2
2015	12	28	14	5	10	36	0	0	0	0	0	0	0	33.89	0	0	12.2
2015	12	28	14	15	10	35	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	28	14	25	10	35	0	0	0	0	0	0	0	33.93	0	0	12.2
2015	12	28	14	35	10	36	0	0	0	0	0	0	0	34	0	0	12.2
2015	12	28	14	45	10	35	0	0	0	0	0	0	0	34.05	0	0	12.2
2015	12	28	14	55	10	36	0	0	0	0	0	0	0	34	0	0	12
2015	12	28	15	5	10	36	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	28	15	15	10	35	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	28	15	25	10	36	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	28	15	35	10	35	0	0	0	0	0	0	0	34	0	0	12
2015	12	28	15	45	10	35	0	0	0	0	0	0	0	34.05	0	0	12
2015	12	28	15	55	10	35	0	0	0	0	0	0	0	34.11	0	0	12
2015	12	28	16	5	10	35	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	28	16	15	10	35	0	0	0	0	0	0	0	34.2	0	0	11.8
2015	12	28	16	25	10	35	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	28	16	35	10	35	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	28	16	45	10	35	0	0	0	0	0	0	0	34.34	0	0	11.8
2015	12	28	16	55	10	35	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	28	17	5	10	35	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	28	17	15	10	36	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	28	17	25	10	35	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	28	17	35	10	36	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	28	17	45	10	35	0	0	0	0	0	0	0	34.7	0	0	11.8
2015	12	28	17	55	10	36	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	28	18	5	10	36	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	28	18	15	10	35	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	28	18	25	10	35	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	28	18	35	10	36	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	28	18	45	10	36	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	28	18	55	10	35	0	0	0	0	0	0	0	35.06	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	19	5	10	35	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	28	19	15	10	35	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	28	19	25	10	36	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	28	19	35	10	36	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	28	19	45	10	36	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	28	19	55	10	35	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	28	20	5	10	36	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	28	20	15	10	35	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	28	20	25	10	36	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	28	20	35	10	35	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	28	20	45	10	36	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	28	20	55	10	35	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	28	21	5	10	35	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	28	21	15	10	35	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	28	21	25	10	36	0	0	0	0	0	0	0	35.24	0	0	11.6
2015	12	28	21	35	10	36	0	0	0	0	0	0	0	35.2	0	0	11.6
2015	12	28	21	45	10	36	0	0	0	0	0	0	0	35.19	0	0	11.6
2015	12	28	21	55	10	35	0	0	0	0	0	0	0	35.13	0	0	11.6
2015	12	28	22	5	10	35	0	0	0	0	0	0	0	35.1	0	0	11.6
2015	12	28	22	15	10	35	0	0	0	0	0	0	0	35.06	0	0	11.6
2015	12	28	22	25	10	35	0	0	0	0	0	0	0	35.02	0	0	11.6
2015	12	28	22	35	10	35	0	0	0	0	0	0	0	34.97	0	0	11.6
2015	12	28	22	45	10	35	0	0	0	0	0	0	0	34.93	0	0	11.6
2015	12	28	22	55	10	36	0	0	0	0	0	0	0	34.9	0	0	11.6
2015	12	28	23	5	10	35	0	0	0	0	0	0	0	34.84	0	0	11.6
2015	12	28	23	15	10	35	0	0	0	0	0	0	0	34.79	0	0	11.6
2015	12	28	23	25	10	35	0	0	0	0	0	0	0	34.74	0	0	11.6
2015	12	28	23	35	10	35	0	0	0	0	0	0	0	34.7	0	0	11.6
2015	12	28	23	45	10	36	0	0	0	0	0	0	0	34.63	0	0	11.6
2015	12	28	23	55	10	36	0	0	0	0	0	0	0	34.57	0	0	11.6
2015	12	29	0	5	10	36	0	0	0	0	0	0	0	34.52	0	0	11.6
2015	12	29	0	15	10	36	0	0	0	0	0	0	0	34.47	0	0	11.6
2015	12	29	0	25	10	36	0	0	0	0	0	0	0	34.39	0	0	11.6
2015	12	29	0	35	10	35	0	0	0	0	0	0	0	34.34	0	0	11.6
2015	12	29	0	45	10	36	0	0	0	0	0	0	0	34.29	0	0	11.6
2015	12	29	0	55	10	35	0	0	0	0	0	0	0	34.21	0	0	11.6
2015	12	29	1	5	10	36	0	0	0	0	0	0	0	34.16	0	0	11.6
2015	12	29	1	15	10	35	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	29	1	25	10	35	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	29	1	35	10	36	0	0	0	0	0	0	0	34	0	0	11.6
2015	12	29	1	45	10	35	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	29	1	55	10	35	0	0	0	0	0	0	0	33.89	0	0	11.6
2015	12	29	2	5	10	35	0	0	0	0	0	0	0	33.84	0	0	11.6
2015	12	29	2	15	10	36	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	29	2	25	10	36	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	29	2	35	10	36	0	0	0	0	0	0	0	33.71	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	2	45	10	36	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	29	2	55	10	36	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	29	3	5	10	35	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	29	3	15	10	36	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	29	3	25	10	35	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	29	3	35	10	36	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	29	3	45	10	35	0	0	0	0	0	0	0	33.39	0	0	11.6
2015	12	29	3	55	10	36	0	0	0	0	0	0	0	33.33	0	0	11.6
2015	12	29	4	5	10	35	0	0	0	0	0	0	0	33.28	0	0	11.6
2015	12	29	4	15	10	36	0	0	0	0	0	0	0	33.26	0	0	11.6
2015	12	29	4	25	10	35	0	0	0	0	0	0	0	33.22	0	0	11.6
2015	12	29	4	35	10	37	0	0	0	0	0	0	0	33.17	0	0	11.6
2015	12	29	4	45	10	36	0	0	0	0	0	0	0	33.13	0	0	11.6
2015	12	29	4	55	10	36	0	0	0	0	0	0	0	33.12	0	0	11.6
2015	12	29	5	5	10	35	0	0	0	0	0	0	0	33.08	0	0	11.6
2015	12	29	5	15	10	35	0	0	0	0	0	0	0	33.06	0	0	11.6
2015	12	29	5	25	10	36	0	0	0	0	0	0	0	33.03	0	0	11.6
2015	12	29	5	35	10	35	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	29	5	45	10	35	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	29	5	55	10	35	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	29	6	5	10	35	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	29	6	15	10	36	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	29	6	25	10	36	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	29	6	35	10	36	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	29	6	45	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	29	6	55	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	29	7	5	10	36	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	29	7	15	10	36	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	29	7	25	10	36	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	29	7	35	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	29	7	45	10	36	0	0	0	0	0	0	0	32.86	0	0	12
2015	12	29	7	55	10	36	0	0	0	0	0	0	0	32.88	0	0	12.4
2015	12	29	8	5	10	36	0	0	0	0	0	0	0	32.88	0	0	12.6
2015	12	29	8	15	10	36	0	0	0	0	0	0	0	32.88	0	0	12.8
2015	12	29	8	25	10	36	0	0	0	0	0	0	0	32.88	0	0	12.8
2015	12	29	8	35	10	35	0	0	0	0	0	0	0	32.9	0	0	13
2015	12	29	8	45	10	35	0	0	0	0	0	0	0	32.9	0	0	13
2015	12	29	8	55	10	36	0	0	0	0	0	0	0	32.92	0	0	13
2015	12	29	9	5	10	36	0	0	0	0	0	0	0	32.92	0	0	13
2015	12	29	9	15	10	36	0	0	0	0	0	0	0	32.95	0	0	13
2015	12	29	9	25	10	36	0	0	0	0	0	0	0	32.97	0	0	13.2
2015	12	29	9	35	10	36	0	0	0	0	0	0	0	33.01	0	0	13.2
2015	12	29	9	45	10	36	0	0	0	0	0	0	0	33.03	0	0	13.2
2015	12	29	9	55	10	37	0	0	0	0	0	0	0	33.06	0	0	13.2
2015	12	29	10	5	10	36	0	0	0	0	0	0	0	33.12	0	0	13.2
2015	12	29	10	15	10	36	0	0	0	0	0	0	0	33.15	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	10	25	10	35	0	0	0	0	0	0	0	33.22	0	0	13.2
2015	12	29	10	35	10	36	0	0	0	0	0	0	0	33.28	0	0	13.2
2015	12	29	10	45	10	35	0	0	0	0	0	0	0	33.35	0	0	13.2
2015	12	29	10	55	10	36	0	0	0	0	0	0	0	33.57	0	0	13.2
2015	12	29	11	5	10	36	0	0	0	0	0	0	0	34.03	0	0	13.2
2015	12	29	11	15	10	35	0	0	0	0	0	0	0	34.25	0	0	13.2
2015	12	29	11	25	10	36	0	0	0	0	0	0	0	34.39	0	0	13.2
2015	12	29	11	35	10	35	0	0	0	0	0	0	0	34.48	0	0	13.2
2015	12	29	11	45	10	36	0	0	0	0	0	0	0	34.63	0	0	13.2
2015	12	29	11	55	10	36	0	0	0	0	0	0	0	34.74	0	0	13.2
2015	12	29	12	5	10	36	0	0	0	0	0	0	0	34.84	0	0	13.2
2015	12	29	12	15	10	35	0	0	0	0	0	0	0	34.97	0	0	13.2
2015	12	29	12	25	10	36	0	0	0	0	0	0	0	35.04	0	0	13.2
2015	12	29	12	35	10	35	0	0	0	0	0	0	0	35.11	0	0	13
2015	12	29	12	45	10	36	0	0	0	0	0	0	0	35.26	0	0	13.2
2015	12	29	12	55	10	35	0	0	0	0	0	0	0	35.37	0	0	13.2
2015	12	29	13	5	10	35	0	0	0	0	0	0	0	35.51	0	0	13.2
2015	12	29	13	15	10	36	0	0	0	0	0	0	0	35.6	0	0	13
2015	12	29	13	25	10	36	0	0	0	0	0	0	0	35.69	0	0	13
2015	12	29	13	35	10	35	0	0	0	0	0	0	0	35.78	0	0	13
2015	12	29	13	45	10	35	0	0	0	0	0	0	0	35.89	0	0	13
2015	12	29	13	55	10	35	0	0	0	0	0	0	0	35.96	0	0	12.8
2015	12	29	14	5	10	35	0	0	0	0	0	0	0	36.03	0	0	12.8
2015	12	29	14	15	10	35	0	0	0	0	0	0	0	36.12	0	0	12.8
2015	12	29	14	25	10	35	0	0	0	0	0	0	0	36.23	0	0	12.8
2015	12	29	14	35	10	36	0	0	0	0	0	0	0	36.3	0	0	12.6
2015	12	29	14	45	10	35	0	0	0	0	0	0	0	36.37	0	0	12.6
2015	12	29	14	55	10	35	0	0	0	0	0	0	0	36.43	0	0	12.6
2015	12	29	15	5	10	35	0	0	0	0	0	0	0	36.48	0	0	12.4
2015	12	29	15	15	10	35	0	0	0	0	0	0	0	36.5	0	0	12.4
2015	12	29	15	25	10	36	0	0	0	0	0	0	0	36.55	0	0	12.4
2015	12	29	15	35	10	35	0	0	0	0	0	0	0	36.55	0	0	12.2
2015	12	29	15	45	10	36	0	0	0	0	0	0	0	36.57	0	0	12.2
2015	12	29	15	55	10	35	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	29	16	5	10	36	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	29	16	15	10	35	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	29	16	25	10	35	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	29	16	35	10	35	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	29	16	45	10	35	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	29	16	55	10	35	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	29	17	5	10	35	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	29	17	15	10	36	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	29	17	25	10	35	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	29	17	35	10	35	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	29	17	45	10	35	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	29	17	55	10	35	0	0	0	0	0	0	0	36.57	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	18	5	10	35	0	0	0	0	0	0	0	36.55	0	0	11.8
2015	12	29	18	15	10	35	0	0	0	0	0	0	0	36.55	0	0	11.8
2015	12	29	18	25	10	36	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	29	18	35	10	35	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	29	18	45	10	36	0	0	0	0	0	0	0	36.52	0	0	11.8
2015	12	29	18	55	10	36	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	29	19	5	10	35	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	29	19	15	10	35	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	29	19	25	10	35	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	29	19	35	10	35	0	0	0	0	0	0	0	36.46	0	0	11.8
2015	12	29	19	45	10	35	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	29	19	55	10	35	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	29	20	5	10	35	0	0	0	0	0	0	0	36.43	0	0	11.8
2015	12	29	20	15	10	35	0	0	0	0	0	0	0	36.41	0	0	11.8
2015	12	29	20	25	10	35	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	29	20	35	10	36	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	29	20	45	10	35	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	29	20	55	10	34	0	0	0	0	0	0	0	36.28	0	0	11.8
2015	12	29	21	5	10	35	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	29	21	15	10	35	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	29	21	25	10	35	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	29	21	35	10	34	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	29	21	45	10	35	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	29	21	55	10	36	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	29	22	5	10	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	29	22	15	10	36	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	29	22	25	10	36	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	29	22	35	10	36	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	29	22	45	10	35	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	29	22	55	10	35	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	29	23	5	10	35	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	29	23	15	10	36	0	0	0	0	0	0	0	35.37	0	0	11.6
2015	12	29	23	25	10	35	0	0	0	0	0	0	0	35.29	0	0	11.6
2015	12	29	23	35	10	35	0	0	0	0	0	0	0	35.2	0	0	11.6
2015	12	29	23	45	10	36	0	0	0	0	0	0	0	35.11	0	0	11.6
2015	12	29	23	55	10	35	0	0	0	0	0	0	0	35.02	0	0	11.6
2015	12	30	0	5	10	35	0	0	0	0	0	0	0	34.95	0	0	11.6
2015	12	30	0	15	10	36	0	0	0	0	0	0	0	34.86	0	0	11.6
2015	12	30	0	25	10	36	0	0	0	0	0	0	0	34.77	0	0	11.6
2015	12	30	0	35	10	36	0	0	0	0	0	0	0	34.68	0	0	11.6
2015	12	30	0	45	10	36	0	0	0	0	0	0	0	34.59	0	0	11.6
2015	12	30	0	55	10	36	0	0	0	0	0	0	0	34.5	0	0	11.6
2015	12	30	1	5	10	36	0	0	0	0	0	0	0	34.41	0	0	11.6
2015	12	30	1	15	10	35	0	0	0	0	0	0	0	34.32	0	0	11.6
2015	12	30	1	25	10	35	0	0	0	0	0	0	0	34.23	0	0	11.6
2015	12	30	1	35	10	36	0	0	0	0	0	0	0	34.14	0	0	11.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	1	45	10	35	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	30	1	55	10	36	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	30	2	5	10	36	0	0	0	0	0	0	0	33.89	0	0	11.6
2015	12	30	2	15	10	36	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	30	2	25	10	36	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	30	2	35	10	35	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	30	2	45	10	35	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	30	2	55	10	36	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	30	3	5	10	36	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	30	3	15	10	36	0	0	0	0	0	0	0	33.35	0	0	11.6
2015	12	30	3	25	10	35	0	0	0	0	0	0	0	33.3	0	0	11.6
2015	12	30	3	35	10	36	0	0	0	0	0	0	0	33.22	0	0	11.6
2015	12	30	3	45	10	35	0	0	0	0	0	0	0	33.15	0	0	11.6
2015	12	30	3	55	10	36	0	0	0	0	0	0	0	33.1	0	0	11.6
2015	12	30	4	5	10	36	0	0	0	0	0	0	0	33.06	0	0	11.6
2015	12	30	4	15	10	36	0	0	0	0	0	0	0	32.99	0	0	11.6
2015	12	30	4	25	10	35	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	30	4	35	10	36	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	30	4	45	10	36	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	30	4	55	10	36	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	30	5	5	10	36	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	30	5	15	10	36	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	30	5	25	10	36	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	30	5	35	10	36	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	30	5	45	10	36	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	30	5	55	10	36	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	30	6	5	10	35	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	30	6	15	10	37	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	30	6	25	10	36	0	0	0	0	0	0	0	32.54	0	0	11.6
2015	12	30	6	35	10	36	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	30	6	45	10	35	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	30	6	55	10	36	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	30	7	5	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	30	7	15	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	30	7	25	10	35	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	30	7	35	10	36	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	30	7	45	10	36	0	0	0	0	0	0	0	32.45	0	0	12.2
2015	12	30	7	55	10	35	0	0	0	0	0	0	0	32.49	0	0	12.6
2015	12	30	8	5	10	36	0	0	0	0	0	0	0	32.47	0	0	12.8
2015	12	30	8	15	10	36	0	0	0	0	0	0	0	32.49	0	0	13
2015	12	30	8	25	10	36	0	0	0	0	0	0	0	32.49	0	0	13.2
2015	12	30	8	35	10	36	0	0	0	0	0	0	0	32.5	0	0	13.2
2015	12	30	8	45	10	36	0	0	0	0	0	0	0	32.5	0	0	13.2
2015	12	30	8	55	10	36	0	0	0	0	0	0	0	32.52	0	0	13.4
2015	12	30	9	5	10	36	0	0	0	0	0	0	0	32.54	0	0	13.4
2015	12	30	9	15	10	36	0	0	0	0	0	0	0	32.56	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	9	25	10	36	0	0	0	0	0	0	0	32.58	0	0	13.4
2015	12	30	9	35	10	36	0	0	0	0	0	0	0	32.61	0	0	13.4
2015	12	30	9	45	10	36	0	0	0	0	0	0	0	32.63	0	0	13.6
2015	12	30	9	55	10	35	0	0	0	0	0	0	0	32.67	0	0	13.6
2015	12	30	10	5	10	36	0	0	0	0	0	0	0	32.68	0	0	13.6
2015	12	30	10	15	10	36	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	30	10	25	10	34	0	0	0	0	0	0	0	32.79	0	0	13.6
2015	12	30	10	35	10	36	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	30	10	45	10	35	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	30	10	55	10	36	0	0	0	0	0	0	0	33.13	0	0	13.8
2015	12	30	11	5	10	36	0	0	0	0	0	0	0	33.58	0	0	13.8
2015	12	30	11	15	10	36	0	0	0	0	0	0	0	33.82	0	0	13.8
2015	12	30	11	25	10	36	0	0	0	0	0	0	0	33.94	0	0	13.6
2015	12	30	11	35	10	35	0	0	0	0	0	0	0	34.05	0	0	13.6
2015	12	30	11	45	10	35	0	0	0	0	0	0	0	34.07	0	0	13.6
2015	12	30	11	55	10	36	0	0	0	0	0	0	0	34.16	0	0	13.6
2015	12	30	12	5	10	35	0	0	0	0	0	0	0	34.27	0	0	13.4
2015	12	30	12	15	10	35	0	0	0	0	0	0	0	34.25	0	0	13.4
2015	12	30	12	25	10	36	0	0	0	0	0	0	0	34.32	0	0	13.4
2015	12	30	12	35	10	36	0	0	0	0	0	0	0	34.38	0	0	13.4
2015	12	30	12	45	10	35	0	0	0	0	0	0	0	34.39	0	0	13.4
2015	12	30	12	55	10	36	0	0	0	0	0	0	0	34.45	0	0	13.2
2015	12	30	13	5	10	36	0	0	0	0	0	0	0	34.5	0	0	13.2
2015	12	30	13	15	10	36	0	0	0	0	0	0	0	34.56	0	0	13.2
2015	12	30	13	25	10	36	0	0	0	0	0	0	0	34.56	0	0	13.2
2015	12	30	13	35	10	35	0	0	0	0	0	0	0	34.63	0	0	13
2015	12	30	13	45	10	35	0	0	0	0	0	0	0	34.68	0	0	13
2015	12	30	13	55	10	35	0	0	0	0	0	0	0	34.72	0	0	13
2015	12	30	14	5	10	35	0	0	0	0	0	0	0	34.75	0	0	12.8
2015	12	30	14	15	10	35	0	0	0	0	0	0	0	34.79	0	0	12.8
2015	12	30	14	25	10	35	0	0	0	0	0	0	0	34.83	0	0	12.8
2015	12	30	14	35	10	35	0	0	0	0	0	0	0	34.88	0	0	12.8
2015	12	30	14	45	10	36	0	0	0	0	0	0	0	34.95	0	0	12.6
2015	12	30	14	55	10	36	0	0	0	0	0	0	0	34.99	0	0	12.6
2015	12	30	15	5	10	35	0	0	0	0	0	0	0	35.02	0	0	12.4
2015	12	30	15	15	10	35	0	0	0	0	0	0	0	35.1	0	0	12.4
2015	12	30	15	25	10	35	0	0	0	0	0	0	0	35.13	0	0	12.4
2015	12	30	15	35	10	35	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	30	15	45	10	36	0	0	0	0	0	0	0	35.22	0	0	12.2
2015	12	30	15	55	10	35	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	30	16	5	10	35	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	30	16	15	10	36	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	30	16	36	20	35	0	0	0	0	0	0	0	35.55	0	0	12
2015	12	30	16	46	20	35	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	30	16	56	20	36	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	30	17	6	20	36	0	0	0	0	0	0	0	35.74	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	17	16	20	36	0	0	0	0	0	0	0	35.8	0	0	12
2015	12	30	17	26	20	35	0	0	0	0	0	0	0	35.87	0	0	12
2015	12	30	17	36	20	35	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	30	17	46	20	35	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	30	17	56	20	36	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	30	18	6	20	36	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	30	18	16	20	35	0	0	0	0	0	0	0	36.14	0	0	12
2015	12	30	18	26	20	35	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	30	18	36	20	35	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	30	18	46	20	36	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	30	18	56	20	35	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	30	19	6	20	35	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	30	19	16	20	35	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	30	19	26	20	36	0	0	0	0	0	0	0	36.43	0	0	11.8
2015	12	30	19	36	20	36	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	30	19	46	20	36	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	30	19	56	20	36	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	30	20	6	20	35	0	0	0	0	0	0	0	36.52	0	0	11.8
2015	12	30	20	16	20	36	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	30	20	26	20	35	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	30	20	36	20	36	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	30	20	46	20	35	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	30	20	56	20	36	0	0	0	0	0	0	0	36.52	0	0	11.8
2015	12	30	21	6	20	36	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	30	21	16	20	35	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	30	21	26	20	36	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	30	21	36	20	35	0	0	0	0	0	0	0	36.41	0	0	11.8
2015	12	30	21	46	20	35	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	30	21	56	20	35	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	30	22	6	20	35	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	30	22	16	20	35	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	30	22	26	20	35	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	30	22	36	20	35	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	30	22	46	20	35	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	30	22	56	20	35	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	30	23	6	20	35	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	30	23	16	20	36	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	30	23	26	20	35	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	30	23	36	20	35	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	30	23	46	20	35	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	30	23	56	20	35	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	31	0	6	20	36	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	31	0	16	20	35	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	31	0	26	20	35	0	0	0	0	0	0	0	35.37	0	0	11.8
2015	12	31	0	36	20	35	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	31	0	46	20	35	0	0	0	0	0	0	0	35.2	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	0	56	20	36	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	31	1	6	20	35	0	0	0	0	0	0	0	35.04	0	0	11.8
2015	12	31	1	16	20	35	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	31	1	26	20	35	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	31	1	36	20	36	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	31	1	46	20	36	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	31	1	56	20	36	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	31	2	6	20	35	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	31	2	16	20	35	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	31	2	26	20	36	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	31	2	36	20	36	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	31	2	46	20	35	0	0	0	0	0	0	0	34.34	0	0	11.8
2015	12	31	2	56	20	35	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	31	3	6	20	36	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	31	3	16	20	36	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	31	3	26	20	35	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	31	3	36	20	36	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	31	3	46	20	36	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	31	3	56	20	35	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	31	4	6	20	35	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	31	4	16	20	35	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	31	4	26	20	35	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	31	4	36	20	35	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	31	4	46	20	36	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	31	4	56	20	36	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	31	5	6	20	35	0	0	0	0	0	0	0	33.75	0	0	11.8
2015	12	31	5	16	20	36	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	31	5	26	20	35	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	31	5	36	20	35	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	31	5	46	20	35	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	31	5	56	20	35	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	31	6	6	20	35	0	0	0	0	0	0	0	33.62	0	0	11.6
2015	12	31	6	16	20	35	0	0	0	0	0	0	0	33.58	0	0	11.6
2015	12	31	6	26	20	36	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	31	6	36	20	35	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	31	6	46	20	36	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	31	6	56	20	36	0	0	0	0	0	0	0	33.53	0	0	11.6
2015	12	31	7	6	20	35	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	31	7	16	20	35	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	31	7	26	20	35	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	31	7	36	20	35	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	31	7	46	20	36	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	31	7	56	20	36	0	0	0	0	0	0	0	33.51	0	0	12.4
2015	12	31	8	6	20	35	0	0	0	0	0	0	0	33.51	0	0	12.6
2015	12	31	8	16	20	36	0	0	0	0	0	0	0	33.51	0	0	12.8
2015	12	31	8	26	20	36	0	0	0	0	0	0	0	33.51	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	8	36	20	36	0	0	0	0	0	0	0	33.53	0	0	13
2015	12	31	8	46	20	35	0	0	0	0	0	0	0	33.53	0	0	13
2015	12	31	8	56	20	36	0	0	0	0	0	0	0	33.55	0	0	13
2015	12	31	9	6	20	36	0	0	0	0	0	0	0	33.53	0	0	13
2015	12	31	9	16	20	36	0	0	0	0	0	0	0	33.57	0	0	13.2
2015	12	31	9	26	20	35	0	0	0	0	0	0	0	33.58	0	0	13.2
2015	12	31	9	36	20	35	0	0	0	0	0	0	0	33.6	0	0	13.2
2015	12	31	9	46	20	35	0	0	0	0	0	0	0	33.62	0	0	13.2
2015	12	31	9	56	20	36	0	0	0	0	0	0	0	33.66	0	0	13.2
2015	12	31	10	6	20	36	0	0	0	0	0	0	0	33.71	0	0	13.4
2015	12	31	10	16	20	35	0	0	0	0	0	0	0	33.76	0	0	13.4
2015	12	31	10	26	20	35	0	0	0	0	0	0	0	33.82	0	0	13.4
2015	12	31	10	36	20	36	0	0	0	0	0	0	0	33.87	0	0	13.4
2015	12	31	10	46	20	36	0	0	0	0	0	0	0	33.96	0	0	13.6
2015	12	31	10	56	20	35	0	0	0	0	0	0	0	34.09	0	0	13.6
2015	12	31	11	6	20	36	0	0	0	0	0	0	0	34.63	0	0	13.6
2015	12	31	11	16	20	36	0	0	0	0	0	0	0	34.92	0	0	13.6
2015	12	31	11	26	20	36	0	0	0	0	0	0	0	35.13	0	0	13.6
2015	12	31	11	36	20	35	0	0	0	0	0	0	0	35.26	0	0	13.6
2015	12	31	11	46	20	36	0	0	0	0	0	0	0	35.47	0	0	13.6
2015	12	31	11	56	20	36	0	0	0	0	0	0	0	35.56	0	0	13.6
2015	12	31	12	6	20	35	0	0	0	0	0	0	0	35.67	0	0	13.6
2015	12	31	12	16	20	35	0	0	0	0	0	0	0	35.8	0	0	13.6
2015	12	31	12	26	20	35	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	31	12	36	20	36	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	31	12	46	20	35	0	0	0	0	0	0	0	36.21	0	0	13.4
2015	12	31	12	56	20	36	0	0	0	0	0	0	0	36.32	0	0	13.4
2015	12	31	13	6	20	35	0	0	0	0	0	0	0	36.41	0	0	13.4
2015	12	31	13	16	20	36	0	0	0	0	0	0	0	36.54	0	0	13.2
2015	12	31	13	26	20	35	0	0	0	0	0	0	0	36.68	0	0	13.2
2015	12	31	13	36	20	35	0	0	0	0	0	0	0	36.81	0	0	13.2
2015	12	31	13	46	20	36	0	0	0	0	0	0	0	36.88	0	0	13
2015	12	31	13	56	20	34	0	0	0	0	0	0	0	37	0	0	13
2015	12	31	14	6	20	35	0	0	0	0	0	0	0	37.06	0	0	13
2015	12	31	14	16	20	36	0	0	0	0	0	0	0	37.15	0	0	13
2015	12	31	14	26	20	35	0	0	0	0	0	0	0	37.27	0	0	12.8
2015	12	31	14	36	20	35	0	0	0	0	0	0	0	37.33	0	0	12.8
2015	12	31	14	46	20	36	0	0	0	0	0	0	0	37.38	0	0	12.6
2015	12	31	14	56	20	35	0	0	0	0	0	0	0	37.44	0	0	12.6
2015	12	31	15	6	20	35	0	0	0	0	0	0	0	37.47	0	0	12.6
2015	12	31	15	16	20	35	0	0	0	0	0	0	0	37.53	0	0	12.4
2015	12	31	15	26	20	35	0	0	0	0	0	0	0	37.54	0	0	12.4
2015	12	31	15	36	20	35	0	0	0	0	0	0	0	37.56	0	0	12.4
2015	12	31	15	46	20	36	0	0	0	0	0	0	0	37.56	0	0	12.2
2015	12	31	15	56	20	35	0	0	0	0	0	0	0	37.56	0	0	12.2
2015	12	31	16	6	20	36	0	0	0	0	0	0	0	37.58	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	16	16	20	35	0	0	0	0	0	0	0	37.56	0	0	12
2015	12	31	16	26	20	35	0	0	0	0	0	0	0	37.56	0	0	12
2015	12	31	16	36	20	35	0	0	0	0	0	0	0	37.58	0	0	12
2015	12	31	16	46	20	35	0	0	0	0	0	0	0	37.56	0	0	12
2015	12	31	16	56	20	35	0	0	0	0	0	0	0	37.54	0	0	12
2015	12	31	17	6	20	35	0	0	0	0	0	0	0	37.53	0	0	12
2015	12	31	17	16	20	35	0	0	0	0	0	0	0	37.51	0	0	12
2015	12	31	17	26	20	35	0	0	0	0	0	0	0	37.51	0	0	12
2015	12	31	17	36	20	34	0	0	0	0	0	0	0	37.49	0	0	12
2015	12	31	17	46	20	35	0	0	0	0	0	0	0	37.47	0	0	12
2015	12	31	17	56	20	36	0	0	0	0	0	0	0	37.45	0	0	12
2015	12	31	18	6	20	35	0	0	0	0	0	0	0	37.44	0	0	12
2015	12	31	18	16	20	35	0	0	0	0	0	0	0	37.42	0	0	12
2015	12	31	18	26	20	35	0	0	0	0	0	0	0	37.4	0	0	12
2015	12	31	18	36	20	35	0	0	0	0	0	0	0	37.38	0	0	12
2015	12	31	18	46	20	36	0	0	0	0	0	0	0	37.38	0	0	12
2015	12	31	18	56	20	35	0	0	0	0	0	0	0	37.36	0	0	11.8
2015	12	31	19	6	20	35	0	0	0	0	0	0	0	37.35	0	0	11.8
2015	12	31	19	16	20	35	0	0	0	0	0	0	0	37.33	0	0	11.8
2015	12	31	19	26	20	35	0	0	0	0	0	0	0	37.31	0	0	11.8
2015	12	31	19	36	20	35	0	0	0	0	0	0	0	37.29	0	0	11.8
2015	12	31	19	46	20	35	0	0	0	0	0	0	0	37.27	0	0	11.8
2015	12	31	19	56	20	35	0	0	0	0	0	0	0	37.26	0	0	11.8
2015	12	31	20	6	20	36	0	0	0	0	0	0	0	37.24	0	0	11.8
2015	12	31	20	16	20	35	0	0	0	0	0	0	0	37.2	0	0	11.8
2015	12	31	20	26	20	35	0	0	0	0	0	0	0	37.17	0	0	11.8
2015	12	31	20	36	20	35	0	0	0	0	0	0	0	37.13	0	0	11.8
2015	12	31	20	46	20	35	0	0	0	0	0	0	0	37.09	0	0	11.8
2015	12	31	20	56	20	35	0	0	0	0	0	0	0	37.06	0	0	11.8
2015	12	31	21	6	20	34	0	0	0	0	0	0	0	37.02	0	0	11.8
2015	12	31	21	16	20	35	0	0	0	0	0	0	0	36.97	0	0	11.8
2015	12	31	21	26	20	36	0	0	0	0	0	0	0	36.9	0	0	11.8
2015	12	31	21	36	20	35	0	0	0	0	0	0	0	36.86	0	0	11.8
2015	12	31	21	46	20	35	0	0	0	0	0	0	0	36.81	0	0	11.8
2015	12	31	21	56	20	35	0	0	0	0	0	0	0	36.73	0	0	11.8
2015	12	31	22	6	20	35	0	0	0	0	0	0	0	36.68	0	0	11.8
2015	12	31	22	16	20	35	0	0	0	0	0	0	0	36.63	0	0	11.8
2015	12	31	22	26	20	36	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	31	22	36	20	35	0	0	0	0	0	0	0	36.46	0	0	11.8
2015	12	31	22	46	20	35	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	31	22	56	20	35	0	0	0	0	0	0	0	36.32	0	0	11.8
2015	12	31	23	6	20	35	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	31	23	16	20	36	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	31	23	26	20	35	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	31	23	36	20	36	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	31	23	46	20	35	0	0	0	0	0	0	0	35.92	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	23	56	20	35	0	0	0	0	0	0	0	35.83	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	0	5	10	0.3	1	0.1	180	6.4284	0
2015	12	1	0	15	10	0.3	1	0.13	153.4	6.4284	0.3358
2015	12	1	0	25	10	0.3	1	0.18	149.2	6.4284	0.5224
2015	12	1	0	35	10	0.3	1	0.17	138.9	6.4284	0.6343
2015	12	1	0	45	10	0.3	1	0.13	143.4	6.4284	0.4291
2015	12	1	0	55	10	0.3	1	0.27	146.7	6.4284	0.8582
2015	12	1	1	5	10	0.3	1	0.26	139.2	6.4284	0.9514
2015	12	1	1	15	10	0.3	1	0.11	158.8	6.4284	0.2239
2015	12	1	1	25	10	0.3	1	0.35	140.7	6.4284	1.2499
2015	12	1	1	35	10	0.3	1	0.1	132.3	6.4284	0.4104
2015	12	1	1	45	10	0.3	1	0.35	134.2	6.4284	1.4365
2015	12	1	1	55	10	0.3	1	0.17	135	6.4284	0.6903
2015	12	1	2	5	10	0.3	1	0.13	141.1	6.4284	0.4664
2015	12	1	2	15	10	0.3	1	0.09	146.9	6.4284	0.2798
2015	12	1	2	25	10	0.3	1	0.09	123.1	6.4284	0.4291
2015	12	1	2	35	10	0.3	1	0.05	327.3	6.4284	-0.1679
2015	12	1	2	45	10	0.3	1	0.05	82.9	6.4284	0.2985
2015	12	1	2	55	10	0.3	1	0.1	336.8	6.409	-0.2231
2015	12	1	3	5	10	0.3	1	0.16	104.3	6.4284	0.8768
2015	12	1	3	15	10	0.3	1	0.1	90	6.4284	0.5783
2015	12	1	3	25	10	0.3	1	0.08	0	6.4284	0
2015	12	1	3	35	10	0.3	1	0.25	111.1	6.4284	1.3059
2015	12	1	3	45	10	0.3	1	0.17	61.9	6.4284	0.8395
2015	12	1	3	55	10	0.3	1	0.28	120.7	6.4284	1.3806
2015	12	1	4	5	10	0.3	1	0.17	90	6.409	0.967
2015	12	1	4	15	10	0.3	1	0.2	41	6.409	0.7438
2015	12	1	4	25	10	0.3	1	0.25	102	6.4284	1.3992
2015	12	1	4	35	10	0.3	1	0.23	97.3	6.4284	1.3059
2015	12	1	4	45	10	0.3	1	0.24	93.9	6.4284	1.3806
2015	12	1	4	55	10	0.3	1	0.29	97.8	6.4284	1.6417
2015	12	1	5	5	10	0.3	1	0.2	70.7	6.4284	1.0634
2015	12	1	5	15	10	0.3	1	0.31	88.2	6.409	1.748
2015	12	1	5	25	10	0.3	1	0.15	46.7	6.409	0.6323
2015	12	1	5	35	10	0.3	1	0.21	102.9	6.409	1.1344
2015	12	1	5	45	10	0.3	1	0.2	66.3	6.409	1.06
2015	12	1	5	55	10	0.3	1	0.2	74.8	6.409	1.0972
2015	12	1	6	5	10	0.3	1	0.26	98.6	6.4284	1.4739
2015	12	1	6	15	10	0.3	1	0.06	51.3	6.409	0.2789
2015	12	1	6	25	10	0.3	1	0.14	351.7	6.409	-0.1116
2015	12	1	6	35	10	0.3	1	0.13	78.4	6.409	0.7252
2015	12	1	6	45	10	0.3	1	0.09	45	6.409	0.3719
2015	12	1	6	55	10	0.3	1	0.16	92.3	6.409	0.9298
2015	12	1	7	5	10	0.3	1	0.04	76	6.409	0.2232
2015	12	1	7	15	10	0.3	1	0.16	90	6.409	0.8926
2015	12	1	7	25	10	0.3	1	0.13	69.8	6.409	0.7067
2015	12	1	7	35	10	0.3	1	0.14	92.6	6.409	0.8182

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	7	45	10	0.3	1	0.12	97.9	6.409	0.6695
2015	12	1	7	55	10	0.3	1	0.17	94.5	6.409	0.9484
2015	12	1	8	5	10	0.3	1	0.17	129.5	6.409	0.7438
2015	12	1	8	15	10	0.3	1	0.16	101.8	6.409	0.8926
2015	12	1	8	25	10	0.3	1	0.21	140.8	6.409	0.7438
2015	12	1	8	35	10	0.3	1	0.14	95.2	6.409	0.8182
2015	12	1	8	45	10	0.3	1	0.11	133.8	6.409	0.4649
2015	12	1	8	55	10	0.3	1	0.12	115.1	6.409	0.5951
2015	12	1	9	5	10	0.3	1	0.24	129.4	6.409	1.0414
2015	12	1	9	15	10	0.3	1	0.24	111.9	6.409	1.2459
2015	12	1	9	25	10	0.3	1	0.16	123.4	6.409	0.7624
2015	12	1	9	35	10	0.3	1	0.07	133.2	6.409	0.2975
2015	12	1	9	45	10	0.3	1	0.11	356.4	6.409	-0.0372
2015	12	1	9	55	10	0.3	1	0.13	88.6	6.409	0.7624
2015	12	1	10	5	10	0.3	1	0.31	117.4	6.409	1.5435
2015	12	1	10	15	10	0.3	1	0.22	101.8	6.409	1.2459
2015	12	1	10	25	10	0.3	1	0.12	36.3	6.409	0.4091
2015	12	1	10	35	10	0.3	1	0.12	25.9	6.409	0.2975
2015	12	1	10	45	10	0.3	1	0.23	76.6	6.409	1.2459
2015	12	1	10	55	10	0.3	1	0.19	72.5	6.409	1.0042
2015	12	1	11	5	10	0.3	1	0.13	67.9	6.409	0.688
2015	12	1	11	15	10	0.3	1	0.11	72.6	6.409	0.5951
2015	12	1	11	25	10	0.3	1	0.16	130.7	6.409	0.6694
2015	12	1	11	35	10	0.3	1	0.07	103.4	6.409	0.3905
2015	12	1	11	45	10	0.3	1	0.1	116.6	6.409	0.5207
2015	12	1	11	55	10	0.3	1	0.21	145.6	6.409	0.688
2015	12	1	12	5	10	0.3	1	0.26	135	6.409	1.0413
2015	12	1	12	15	10	0.3	1	0.23	135.6	6.409	0.9112
2015	12	1	12	25	10	0.3	1	0.16	136.6	6.409	0.6322
2015	12	1	12	35	10	0.3	1	0.13	163.9	6.409	0.2045
2015	12	1	12	45	10	0.3	1	0.11	152.7	6.409	0.2975
2015	12	1	12	55	10	0.3	1	0.1	157.8	6.409	0.2045
2015	12	1	13	5	10	0.3	1	0.15	156.2	6.409	0.3533
2015	12	1	13	15	10	0.3	1	0.12	97.9	6.409	0.6694
2015	12	1	13	25	10	0.3	1	0.25	112.8	6.409	1.283
2015	12	1	13	35	10	0.3	1	0.16	112.9	6.409	0.8368
2015	12	1	13	45	10	0.3	1	0.25	127.6	6.409	1.1343
2015	12	1	13	55	10	0.3	1	0.17	124	6.409	0.7996
2015	12	1	14	5	10	0.3	1	0.08	113.5	6.409	0.4277
2015	12	1	14	15	10	0.3	1	0.17	85.6	6.409	0.9669
2015	12	1	14	25	10	0.3	1	0.17	114.5	6.409	0.8553
2015	12	1	14	35	10	0.3	1	0.11	101.6	6.409	0.6322
2015	12	1	14	45	10	0.3	1	0.08	58.2	6.409	0.3905
2015	12	1	14	55	10	0.3	1	0.13	137	6.409	0.5206
2015	12	1	15	5	10	0.3	1	0.22	131.9	6.409	0.9111
2015	12	1	15	15	10	0.3	1	0.23	123	6.409	1.1157

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	15	25	10	0.3	1	0.2	110.8	6.409	1.0785
2015	12	1	15	35	10	0.3	1	0.21	121.3	6.409	1.0413
2015	12	1	15	45	10	0.3	1	0.34	136.2	6.409	1.3388
2015	12	1	15	55	10	0.3	1	0.24	140.6	6.409	0.8553
2015	12	1	16	5	10	0.3	1	0.16	117.6	6.409	0.781
2015	12	1	16	15	10	0.3	1	0.06	90	6.409	0.3347
2015	12	1	16	25	10	0.3	1	0.16	148.6	6.409	0.4649
2015	12	1	16	35	10	0.3	1	0.2	129.6	6.409	0.8553
2015	12	1	16	45	10	0.3	1	0.24	125.6	6.409	1.1156
2015	12	1	16	55	10	0.3	1	0.12	111.8	6.409	0.6508
2015	12	1	17	5	10	0.3	1	0.13	110.2	6.409	0.7066
2015	12	1	17	15	10	0.3	1	0.16	117.1	6.409	0.7995
2015	12	1	17	25	10	0.3	1	0.15	85.1	6.409	0.8739
2015	12	1	17	35	10	0.3	1	0.12	109.4	6.409	0.6322
2015	12	1	17	45	10	0.3	1	0.22	124.2	6.409	1.0413
2015	12	1	17	55	10	0.3	1	0.16	112.2	6.409	0.8181
2015	12	1	18	5	10	0.3	1	0.1	88	6.409	0.5392
2015	12	1	18	15	10	0.3	1	0.16	121.8	6.409	0.7809
2015	12	1	18	25	10	0.3	1	0.2	112.7	6.409	1.0227
2015	12	1	18	35	10	0.3	1	0.16	106.6	6.409	0.8739
2015	12	1	18	45	10	0.3	1	0.03	96.3	6.409	0.1673
2015	12	1	18	55	10	0.3	1	0.1	125.3	6.409	0.4463
2015	12	1	19	5	10	0.3	1	0.17	77.6	6.409	0.9297
2015	12	1	19	15	10	0.3	1	0.15	95.1	6.409	0.8367
2015	12	1	19	25	10	0.3	1	0.18	77	6.409	0.9669
2015	12	1	19	35	10	0.3	1	0.15	94.9	6.409	0.8739
2015	12	1	19	45	10	0.3	1	0.19	85.2	6.409	1.097
2015	12	1	19	55	10	0.3	1	0.2	89.1	6.409	1.1342
2015	12	1	20	5	10	0.3	1	0.18	92	6.409	1.0413
2015	12	1	20	15	10	0.3	1	0.2	123.7	6.409	0.9483
2015	12	1	20	25	10	0.3	1	0.12	164.5	6.409	0.1859
2015	12	1	20	35	10	0.3	1	0.23	149	6.409	0.6694
2015	12	1	20	45	10	0.3	1	0.21	127.4	6.409	0.9483
2015	12	1	20	55	10	0.3	1	0.21	135	6.409	0.8367
2015	12	1	21	5	10	0.3	1	0.22	125.3	6.409	1.0227
2015	12	1	21	15	10	0.3	1	0.2	114.9	6.409	1.0413
2015	12	1	21	25	10	0.3	1	0.12	140.6	6.409	0.4277
2015	12	1	21	35	10	0.3	1	0.21	136.9	6.409	0.8181
2015	12	1	21	45	10	0.3	1	0.18	113.3	6.409	0.9483
2015	12	1	21	55	10	0.3	1	0.3	134.6	6.409	1.2086
2015	12	1	22	5	10	0.3	1	0.14	97.9	6.409	0.7996
2015	12	1	22	15	10	0.3	1	0.33	127	6.409	1.5061
2015	12	1	22	25	10	0.3	1	0.33	127.8	6.409	1.4876
2015	12	1	22	35	10	0.3	1	0.28	126.9	6.409	1.2644
2015	12	1	22	45	10	0.3	1	0.31	132.8	6.409	1.283
2015	12	1	22	55	10	0.3	1	0.3	122.8	6.409	1.4132

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	23	5	10	0.3	1	0.07	71.6	6.409	0.3905
2015	12	1	23	15	10	0.3	1	0.22	125.3	6.409	1.0227
2015	12	1	23	25	10	0.3	1	0.19	122.3	6.409	0.9111
2015	12	1	23	35	10	0.3	1	0.22	135.6	6.409	0.8554
2015	12	1	23	45	10	0.3	1	0.35	128.6	6.409	1.562
2015	12	1	23	55	10	0.3	1	0.4	118.2	6.409	2.0082
2015	12	2	0	5	10	0.3	1	0.3	121.3	6.409	1.469
2015	12	2	0	15	10	0.3	1	0.1	105.4	6.409	0.5392
2015	12	2	0	25	10	0.3	1	0.07	95.7	6.409	0.3719
2015	12	2	0	35	10	0.3	1	0.19	143.3	6.409	0.6508
2015	12	2	0	45	10	0.3	1	0.35	143.7	6.409	1.1901
2015	12	2	0	55	10	0.3	1	0.41	135.6	6.409	1.6364
2015	12	2	1	5	10	0.3	1	0.24	136.7	6.409	0.9297
2015	12	2	1	15	10	0.3	1	0.29	157.8	6.409	0.6136
2015	12	2	1	25	10	0.3	1	0.11	180	6.409	0
2015	12	2	1	35	10	0.3	1	0.1	164.1	6.409	0.1488
2015	12	2	1	45	10	0.3	1	0.15	180	6.409	0
2015	12	2	1	55	10	0.3	1	0.12	160	6.409	0.2231
2015	12	2	2	5	10	0.3	1	0.19	159.1	6.409	0.3905
2015	12	2	2	15	10	0.3	1	0.18	154.8	6.409	0.4463
2015	12	2	2	25	10	0.3	1	0.11	142.1	6.409	0.3905
2015	12	2	2	35	10	0.3	1	0.23	122.5	6.409	1.0785
2015	12	2	2	45	10	0.3	1	0.13	154.1	6.409	0.3347
2015	12	2	2	55	10	0.3	1	0.21	138.1	6.409	0.7996
2015	12	2	3	5	10	0.3	1	0.23	135	6.409	0.9298
2015	12	2	3	15	10	0.3	1	0.19	121.5	6.409	0.9112
2015	12	2	3	25	10	0.3	1	0.39	136.7	6.409	1.5062
2015	12	2	3	35	10	0.3	1	0.26	136.5	6.409	1.0227
2015	12	2	3	45	10	0.3	1	0.08	149	6.409	0.2231
2015	12	2	3	55	10	0.3	1	0.15	120.5	6.409	0.7252
2015	12	2	4	5	10	0.3	1	0.04	350.5	6.409	-0.0372
2015	12	2	4	15	10	0.3	1	0.07	147.1	6.409	0.2046
2015	12	2	4	25	10	0.3	1	0.07	40.9	6.409	0.2417
2015	12	2	4	35	10	0.3	1	0.09	135	6.409	0.3533
2015	12	2	4	45	10	0.3	1	0.17	146.6	6.409	0.5393
2015	12	2	4	55	10	0.3	1	0.05	335	6.409	-0.1302
2015	12	2	5	5	10	0.3	1	0.22	139.3	6.409	0.7996
2015	12	2	5	15	10	0.3	1	0.14	121.9	6.409	0.688
2015	12	2	5	25	10	0.3	1	0.15	128.1	6.409	0.688
2015	12	2	5	35	10	0.3	1	0.31	122.5	6.409	1.4876
2015	12	2	5	45	10	0.3	1	0.25	117.6	6.409	1.2459
2015	12	2	5	55	10	0.3	1	0.14	339	6.3897	-0.278
2015	12	2	6	5	10	0.3	1	0.1	59.3	6.3897	0.5005
2015	12	2	6	15	10	0.3	1	0.16	0	6.3897	0
2015	12	2	6	25	10	0.3	1	0.11	34.2	6.3897	0.3522
2015	12	2	6	35	10	0.3	1	0.08	46.7	6.3897	0.3151

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	6	45	10	0.3	1	0.3	118.3	6.3897	1.4828
2015	12	2	6	55	10	0.3	1	0.21	4.4	6.3897	0.0927
2015	12	2	7	5	10	0.3	1	0.29	111.9	6.3897	1.5199
2015	12	2	7	15	10	0.3	1	0.38	118.1	6.3897	1.8721
2015	12	2	7	25	10	0.3	1	0.16	22.4	6.3897	0.3522
2015	12	2	7	35	10	0.3	1	0.19	126.1	6.3897	0.8897
2015	12	2	7	45	10	0.3	1	0.33	103.9	6.3897	1.7979
2015	12	2	7	55	10	0.3	1	0.35	109.8	6.3897	1.8535
2015	12	2	8	5	10	0.3	1	0.35	115.1	6.3897	1.7794
2015	12	2	8	15	10	0.3	1	0.26	107.5	6.3897	1.4087
2015	12	2	8	25	10	0.3	1	0.29	101.1	6.3897	1.6126
2015	12	2	8	35	10	0.3	1	0.16	47.5	6.3897	0.6673
2015	12	2	8	45	10	0.3	1	0.12	100.7	6.3897	0.6858
2015	12	2	8	55	10	0.3	1	0.18	80.5	6.3897	1.0009
2015	12	2	9	5	10	0.3	1	0.49	119.8	6.3897	2.3911
2015	12	2	9	15	10	0.3	1	0.19	92	6.3897	1.0565
2015	12	2	9	25	10	0.3	1	0.11	107.4	6.3897	0.5931
2015	12	2	9	35	10	0.3	1	0.29	117.4	6.3897	1.4643
2015	12	2	9	45	10	0.3	1	0.08	90	6.3897	0.4448
2015	12	2	9	55	10	0.3	1	0.07	90	6.3897	0.3707
2015	12	2	10	5	10	0.3	1	0.16	118.7	6.3897	0.7785
2015	12	2	10	15	10	0.3	1	0.21	125.6	6.3897	0.9824
2015	12	2	10	25	10	0.3	1	0.1	114.9	6.3897	0.519
2015	12	2	10	35	10	0.3	1	0.24	138.3	6.3897	0.9082
2015	12	2	10	45	10	0.3	1	0.16	135	6.3897	0.6302
2015	12	2	10	55	10	0.3	1	0.27	140.5	6.3897	0.9638
2015	12	2	11	5	10	0.3	1	0.2	156.8	6.3897	0.4448
2015	12	2	11	15	10	0.3	1	0.12	199.4	6.3897	-0.2224
2015	12	2	11	25	10	0.3	1	0.15	183.7	6.3897	-0.0556
2015	12	2	11	35	10	0.3	1	0.11	150.3	6.3897	0.2966
2015	12	2	11	45	10	0.3	1	0.2	164.6	6.3897	0.2966
2015	12	2	11	55	10	0.3	1	0.15	129.6	6.3897	0.6487
2015	12	2	12	5	10	0.3	1	0.34	135.8	6.3897	1.3345
2015	12	2	12	15	10	0.3	1	0.25	124.3	6.409	1.1715
2015	12	2	12	25	10	0.3	1	0.03	66	6.3897	0.1668
2015	12	2	12	35	10	0.3	1	0.1	78.3	6.3897	0.5375
2015	12	2	12	45	10	0.3	1	0.14	143.7	6.3897	0.4634
2015	12	2	12	55	10	0.3	1	0.13	140.2	6.3897	0.4634
2015	12	2	13	5	10	0.3	1	0.03	83.7	6.409	0.1673
2015	12	2	13	15	10	0.3	1	0.08	313.3	6.409	-0.3161
2015	12	2	13	25	10	0.3	1	0.06	338.7	6.409	-0.1302
2015	12	2	13	35	10	0.3	1	0.05	69	6.409	0.2417
2015	12	2	13	45	10	0.3	1	0.11	149.6	6.409	0.3161
2015	12	2	13	55	10	0.3	1	0.24	124.5	6.409	1.1342
2015	12	2	14	5	10	0.3	1	0.22	139.9	6.409	0.7995
2015	12	2	14	15	10	0.3	1	0.23	119.8	6.409	1.1342

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	14	25	10	0.3	1	0.19	135	6.409	0.7624
2015	12	2	14	35	10	0.3	1	0.13	104.4	6.409	0.7252
2015	12	2	14	45	10	0.3	1	0.15	121.2	6.409	0.7066
2015	12	2	14	55	10	0.3	1	0.16	98.1	6.3897	0.9082
2015	12	2	15	5	10	0.3	1	0.19	90	6.409	1.0599
2015	12	2	15	15	10	0.3	1	0.11	105.3	6.409	0.6136
2015	12	2	15	25	10	0.3	1	0.18	125.2	6.409	0.8181
2015	12	2	15	35	10	0.3	1	0.24	119	6.409	1.2086
2015	12	2	15	45	10	0.3	1	0.06	38.2	6.3897	0.2039
2015	12	2	15	55	10	0.3	1	0.13	40.9	6.3897	0.4819
2015	12	2	16	5	10	0.3	1	0.1	71	6.3897	0.5375
2015	12	2	16	15	10	0.3	1	0.19	108.4	6.3897	1.0008
2015	12	2	16	25	10	0.3	1	0.12	105.5	6.3897	0.6672
2015	12	2	16	35	10	0.3	1	0.14	88.7	6.3897	0.7969
2015	12	2	16	45	10	0.3	1	0.18	88	6.3897	1.0379
2015	12	2	16	55	10	0.3	1	0.11	106.9	6.3897	0.6116
2015	12	2	17	5	10	0.3	1	0.15	83.8	6.3897	0.8525
2015	12	2	17	15	10	0.3	1	0.14	72	6.3897	0.7413
2015	12	2	17	25	10	0.3	1	0.13	81.3	6.3897	0.7228
2015	12	2	17	35	10	0.3	1	0.2	114.8	6.3897	1.0008
2015	12	2	17	45	10	0.3	1	0.2	102	6.3897	1.1305
2015	12	2	17	55	10	0.3	1	0.2	90	6.3897	1.1491
2015	12	2	18	5	10	0.3	1	0.15	79.7	6.3897	0.8155
2015	12	2	18	15	10	0.3	1	0.16	73.7	6.3897	0.8896
2015	12	2	18	25	10	0.3	1	0.14	99.2	6.3897	0.7969
2015	12	2	18	35	10	0.3	1	0.21	81.1	6.3897	1.1861
2015	12	2	18	45	10	0.3	1	0.18	58.3	6.3897	0.8711
2015	12	2	18	55	10	0.3	1	0.13	62.1	6.3897	0.6301
2015	12	2	19	5	10	0.3	1	0.13	90	6.3897	0.7228
2015	12	2	19	15	10	0.3	1	0.17	94.4	6.3897	0.9637
2015	12	2	19	25	10	0.3	1	0.14	57	6.3897	0.6857
2015	12	2	19	35	10	0.3	1	0.2	115.7	6.409	1.0412
2015	12	2	19	45	10	0.3	1	0.22	108.2	6.409	1.19
2015	12	2	19	55	10	0.3	1	0.24	114.8	6.409	1.2458
2015	12	2	20	5	10	0.3	1	0.22	119.2	6.409	1.097
2015	12	2	20	15	10	0.3	1	0.21	128.5	6.409	0.9111
2015	12	2	20	25	10	0.3	1	0.15	116.6	6.409	0.7809
2015	12	2	20	35	10	0.3	1	0.1	95.7	6.409	0.5578
2015	12	2	20	45	10	0.3	1	0	135	6.409	0.0186
2015	12	2	20	55	10	0.3	1	0.03	36.9	6.409	0.1116
2015	12	2	21	5	10	0.3	1	0.07	87.3	6.409	0.3905
2015	12	2	21	15	10	0.3	1	0	0	6.409	0
2015	12	2	21	25	10	0.3	1	0.07	305.8	6.3897	-0.3336
2015	12	2	21	35	10	0.3	1	0.1	97.6	6.3897	0.556
2015	12	2	21	45	10	0.3	1	0.08	102.3	6.409	0.4277
2015	12	2	21	55	10	0.3	1	0.18	150.1	6.3897	0.5004

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	22	5	10	0.3	1	0.13	131.9	6.3897	0.5375
2015	12	2	22	15	10	0.3	1	0.15	124.4	6.3897	0.7043
2015	12	2	22	25	10	0.3	1	0.16	128.3	6.3897	0.7043
2015	12	2	22	35	10	0.3	1	0.17	115.1	6.3897	0.8711
2015	12	2	22	45	10	0.3	1	0.06	111.3	6.3897	0.3336
2015	12	2	22	55	10	0.3	1	0.09	119.5	6.3897	0.4263
2015	12	2	23	5	10	0.3	1	0.42	137.2	6.3897	1.5939
2015	12	2	23	15	10	0.3	1	0.23	133.9	6.3897	0.9452
2015	12	2	23	25	10	0.3	1	0.17	91.1	6.3897	0.9823
2015	12	2	23	35	10	0.3	1	0.28	134.1	6.3897	1.1491
2015	12	2	23	45	10	0.3	1	0.13	135	6.3897	0.5375
2015	12	2	23	55	10	0.3	1	0.2	121.1	6.3897	0.9823
2015	12	3	0	5	10	0.3	1	0.15	111.1	6.3897	0.8155
2015	12	3	0	15	10	0.3	1	0.07	53.1	6.3897	0.2965
2015	12	3	0	25	10	0.3	1	0.1	55.3	6.3897	0.4819
2015	12	3	0	35	10	0.3	1	0.04	180	6.3897	0
2015	12	3	0	45	10	0.3	1	0.16	117.1	6.3703	0.7944
2015	12	3	0	55	10	0.3	1	0.12	90	6.3703	0.6651
2015	12	3	1	5	10	0.3	1	0.2	129.7	6.3703	0.8683
2015	12	3	1	15	10	0.3	1	0.12	114.4	6.3703	0.6096
2015	12	3	1	25	10	0.3	1	0.16	125.9	6.3703	0.739
2015	12	3	1	35	10	0.3	1	0.09	100.9	6.3703	0.4803
2015	12	3	1	45	10	0.3	1	0.17	118.5	6.3703	0.8498
2015	12	3	1	55	10	0.3	1	0.21	115.4	6.3703	1.09
2015	12	3	2	5	10	0.3	1	0.24	120	6.3703	1.1823
2015	12	3	2	15	10	0.3	1	0.19	119.2	6.3703	0.9237
2015	12	3	2	25	10	0.3	1	0.19	126.1	6.3703	0.8868
2015	12	3	2	35	10	0.3	1	0.19	140.7	6.3703	0.6651
2015	12	3	2	45	10	0.3	1	0.22	99.5	6.3703	1.2193
2015	12	3	2	55	10	0.3	1	0.15	122.7	6.3703	0.7205
2015	12	3	3	5	10	0.3	1	0.1	133.7	6.3703	0.4064
2015	12	3	3	15	10	0.3	1	0.21	133.1	6.3703	0.8683
2015	12	3	3	25	10	0.3	1	0.09	156.3	6.3509	0.2026
2015	12	3	3	35	10	0.3	1	0.15	146	6.3509	0.4604
2015	12	3	3	45	10	0.3	1	0.17	105.6	6.3509	0.9207
2015	12	3	3	55	10	0.3	1	0.14	92.6	6.3509	0.8102
2015	12	3	4	5	10	0.3	1	0.18	142.3	6.3509	0.6261
2015	12	3	4	15	10	0.3	1	0.11	103.6	6.3509	0.6077
2015	12	3	4	25	10	0.3	1	0.13	126	6.3509	0.6077
2015	12	3	4	35	10	0.3	1	0.08	129.8	6.3509	0.3315
2015	12	3	4	45	10	0.3	1	0.12	169	6.3509	0.1289
2015	12	3	4	55	10	0.3	1	0.15	122.3	6.3509	0.6997
2015	12	3	5	5	10	0.3	1	0.12	135	6.3509	0.4604
2015	12	3	5	15	10	0.3	1	0.14	110.1	6.3509	0.755
2015	12	3	5	25	10	0.3	1	0.11	133.8	6.3509	0.4604
2015	12	3	5	35	10	0.3	1	0.11	173.1	6.3509	0.0737

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	5	45	10	0.3	1	0.2	162.5	6.3509	0.3315
2015	12	3	5	55	10	0.3	1	0.21	188.1	6.3509	-0.1657
2015	12	3	6	5	10	0.3	1	0.22	166	6.3509	0.2946
2015	12	3	6	15	10	0.3	1	0.21	176.4	6.3316	0.0734
2015	12	3	6	25	10	0.3	1	0.28	182	6.3316	-0.0551
2015	12	3	6	35	10	0.3	1	0.2	187.5	6.3316	-0.1468
2015	12	3	6	45	10	0.3	1	0.17	180	6.3316	0
2015	12	3	6	55	10	0.3	1	0.28	158.2	6.3316	0.5873
2015	12	3	7	5	10	0.3	1	0.18	203.3	6.3316	-0.4038
2015	12	3	7	15	10	0.3	1	0.17	174.5	6.3316	0.0918
2015	12	3	7	25	10	0.3	1	0.2	192.2	6.3316	-0.2386
2015	12	3	7	35	10	0.3	1	0.15	217.6	6.3316	-0.4956
2015	12	3	7	45	10	0.3	1	0.15	223.2	6.3316	-0.569
2015	12	3	7	55	10	0.3	1	0.11	161.6	6.3316	0.2019
2015	12	3	8	5	10	0.3	1	0.21	235.6	6.3316	-0.9911
2015	12	3	8	15	10	0.3	1	0.11	255.5	6.3316	-0.569
2015	12	3	8	25	10	0.3	1	0.1	238.4	6.3316	-0.4772
2015	12	3	8	35	10	0.3	1	0.15	234.9	6.3316	-0.6791
2015	12	3	8	45	10	0.3	1	0.11	192	6.3316	-0.1285
2015	12	3	8	55	10	0.3	1	0.12	209.9	6.3316	-0.3487
2015	12	3	9	5	10	0.3	1	0.14	246.4	6.3316	-0.7158
2015	12	3	9	15	10	0.3	1	0.13	237.5	6.3316	-0.6057
2015	12	3	9	25	10	0.3	1	0.16	229.1	6.3316	-0.6791
2015	12	3	9	35	10	0.3	1	0.2	216.5	6.3316	-0.6791
2015	12	3	9	45	10	0.3	1	0.17	215.5	6.3316	-0.5506
2015	12	3	9	55	10	0.3	1	0.19	183.9	6.3316	-0.0734
2015	12	3	10	5	10	0.3	1	0.22	194.4	6.3122	-0.311
2015	12	3	10	15	10	0.3	1	0.25	179.3	6.3316	0.0184
2015	12	3	10	25	10	0.3	1	0.26	182.9	6.3122	-0.0732
2015	12	3	10	35	10	0.3	1	0.22	206.2	6.3122	-0.5305
2015	12	3	10	45	10	0.3	1	0.15	161.6	6.3122	0.2561
2015	12	3	10	55	10	0.3	1	0.18	190.5	6.3122	-0.1829
2015	12	3	11	5	10	0.3	1	0.07	166	6.3122	0.0915
2015	12	3	11	15	10	0.3	1	0.05	31.6	6.3122	0.1463
2015	12	3	11	25	10	0.3	1	0.08	80.9	6.3122	0.4573
2015	12	3	11	35	10	0.3	1	0.15	79.9	6.3122	0.8232
2015	12	3	11	45	10	0.3	1	0.11	130	6.3122	0.4573
2015	12	3	11	55	10	0.3	1	0.19	120.1	6.3122	0.9147
2015	12	3	12	5	10	0.3	1	0.12	125.9	6.3122	0.5305
2015	12	3	12	15	10	0.3	1	0.17	100	6.3122	0.9329
2015	12	3	12	25	10	0.3	1	0.16	96.1	6.2929	0.8569
2015	12	3	12	35	10	0.3	1	0.13	87.2	6.2929	0.7475
2015	12	3	12	45	10	0.3	1	0.19	135	6.2929	0.7293
2015	12	3	12	55	10	0.3	1	0.2	122.1	6.2735	0.9268
2015	12	3	13	5	10	0.3	1	0.2	141	6.2542	0.6883
2015	12	3	13	15	10	0.3	1	0.14	112.8	6.2735	0.6906

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	13	25	10	0.3	1	0.12	131.6	6.2542	0.489
2015	12	3	13	35	10	0.3	1	0.19	121	6.2735	0.9086
2015	12	3	13	45	10	0.3	1	0.18	67.2	6.2735	0.9086
2015	12	3	13	55	10	0.3	1	0.11	78	6.2542	0.5977
2015	12	3	14	5	10	0.3	1	0.16	99.5	6.2735	0.8723
2015	12	3	14	15	10	0.3	1	0.15	111.1	6.2735	0.7996
2015	12	3	14	25	10	0.3	1	0.19	120.1	6.2929	0.9116
2015	12	3	14	35	10	0.3	1	0.18	98.3	6.2929	1.0028
2015	12	3	14	45	10	0.3	1	0.15	126.4	6.2735	0.6905
2015	12	3	14	55	10	0.3	1	0.18	129.1	6.2929	0.784
2015	12	3	15	5	10	0.3	1	0.17	88.9	6.3122	0.9512
2015	12	3	15	15	10	0.3	1	0.16	121.2	6.3316	0.7892
2015	12	3	15	25	10	0.3	1	0.16	100.6	6.3316	0.8809
2015	12	3	15	35	10	0.3	1	0.1	90	6.3316	0.5689
2015	12	3	15	45	10	0.3	1	0.18	76.5	6.3509	0.9943
2015	12	3	15	55	10	0.3	1	0.1	90	6.3509	0.5708
2015	12	3	16	5	10	0.3	1	0.18	101.3	6.3509	1.0127
2015	12	3	16	15	10	0.3	1	0.09	135	6.3703	0.351
2015	12	3	16	25	10	0.3	1	0.11	63.4	6.3703	0.5542
2015	12	3	16	35	10	0.3	1	0.12	69.1	6.3703	0.6281
2015	12	3	16	45	10	0.3	1	0.15	77.7	6.3897	0.8525
2015	12	3	16	55	10	0.3	1	0.2	116.1	6.3897	1.0193
2015	12	3	17	5	10	0.3	1	0.11	80	6.3897	0.6301
2015	12	3	17	15	10	0.3	1	0.19	85.2	6.3897	1.0935
2015	12	3	17	25	10	0.3	1	0.16	94.7	6.3897	0.9081
2015	12	3	17	35	10	0.3	1	0.18	90	6.409	1.0041
2015	12	3	17	45	10	0.3	1	0.16	103.2	6.409	0.8739
2015	12	3	17	55	10	0.3	1	0.15	95	6.409	0.8553
2015	12	3	18	5	10	0.3	1	0.22	103.8	6.409	1.2086
2015	12	3	18	15	10	0.3	1	0.2	104.9	6.409	1.1156
2015	12	3	18	25	10	0.3	1	0.17	90	6.4284	0.97
2015	12	3	18	35	10	0.3	1	0.2	109.9	6.4284	1.0819
2015	12	3	18	45	10	0.3	1	0.17	82.2	6.4284	0.9513
2015	12	3	18	55	10	0.3	1	0.12	83.7	6.4284	0.6715
2015	12	3	19	5	10	0.3	1	0.18	90	6.4284	1.026
2015	12	3	19	15	10	0.3	1	0.15	98.7	6.4477	0.8608
2015	12	3	19	25	10	0.3	1	0.18	81.4	6.4477	0.9918
2015	12	3	19	35	10	0.3	1	0.16	79.4	6.4477	0.8983
2015	12	3	19	45	10	0.3	1	0.16	122.4	6.4477	0.7673
2015	12	3	19	55	10	0.3	1	0.14	59.3	6.4477	0.6924
2015	12	3	20	5	10	0.3	1	0.24	115.5	6.4671	1.2203
2015	12	3	20	15	10	0.3	1	0.17	116.1	6.4671	0.8824
2015	12	3	20	25	10	0.3	1	0.24	110.6	6.4671	1.2954
2015	12	3	20	35	10	0.3	1	0.19	107.5	6.4671	1.0138
2015	12	3	20	45	10	0.3	1	0.24	90	6.4671	1.3893
2015	12	3	20	55	10	0.3	1	0.23	102.3	6.4671	1.2954

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	21	5	10	0.3	1	0.18	99.6	6.4864	0.9982
2015	12	3	21	15	10	0.3	1	0.27	108.2	6.4864	1.4879
2015	12	3	21	25	10	0.3	1	0.19	92	6.4864	1.0736
2015	12	3	21	35	10	0.3	1	0.22	116.6	6.5058	1.1337
2015	12	3	21	45	10	0.3	1	0.28	116	6.5252	1.4785
2015	12	3	21	55	10	0.3	1	0.19	110.9	6.5252	1.0425
2015	12	3	22	5	10	0.3	1	0.12	96.3	6.5445	0.6846
2015	12	3	22	15	10	0.3	1	0.31	113.3	6.5639	1.6405
2015	12	3	22	25	10	0.3	1	0.34	123.8	6.5639	1.6215
2015	12	3	22	35	10	0.3	1	0.22	100.2	6.5639	1.2781
2015	12	3	22	45	10	0.3	1	0.28	124.4	6.5639	1.3353
2015	12	3	22	55	10	0.3	1	0.28	125.4	6.5639	1.3163
2015	12	3	23	5	10	0.3	1	0.2	126.5	6.5639	0.9538
2015	12	3	23	15	10	0.3	1	0.23	95.7	6.5639	1.3353
2015	12	3	23	25	10	0.3	1	0.24	120	6.5639	1.2209
2015	12	3	23	35	10	0.3	1	0.23	107.9	6.5832	1.3013
2015	12	3	23	45	10	0.3	1	0.22	125.3	6.5832	1.0525
2015	12	3	23	55	10	0.3	1	0.26	128.3	6.5832	1.1865
2015	12	4	0	5	10	0.3	1	0.29	121.5	6.5832	1.4352
2015	12	4	0	15	10	0.3	1	0.24	112.7	6.5832	1.2822
2015	12	4	0	25	10	0.3	1	0.23	107.4	6.5832	1.2822
2015	12	4	0	35	10	0.3	1	0.22	115	6.5832	1.1482
2015	12	4	0	45	10	0.3	1	0.17	124.9	6.5832	0.8229
2015	12	4	0	55	10	0.3	1	0.16	102	6.5832	0.8994
2015	12	4	1	5	10	0.3	1	0.2	137	6.5832	0.7846
2015	12	4	1	15	10	0.3	1	0.25	108.2	6.5832	1.397
2015	12	4	1	25	10	0.3	1	0.19	125.1	6.5832	0.8994
2015	12	4	1	35	10	0.3	1	0.13	131.9	6.5832	0.555
2015	12	4	1	45	10	0.3	1	0.19	118.8	6.5832	0.976
2015	12	4	1	55	10	0.3	1	0.17	102.4	6.5832	0.9568
2015	12	4	2	5	10	0.3	1	0.14	112.8	6.5832	0.7272
2015	12	4	2	15	10	0.3	1	0.2	123.2	6.5832	0.9951
2015	12	4	2	25	10	0.3	1	0.23	121.7	6.5832	1.1482
2015	12	4	2	35	10	0.3	1	0.21	114.1	6.5832	1.1099
2015	12	4	2	45	10	0.3	1	0.1	125.3	6.5832	0.4593
2015	12	4	2	55	10	0.3	1	0.19	106.9	6.5832	1.0717
2015	12	4	3	5	10	0.3	1	0.18	138.6	6.5832	0.7081
2015	12	4	3	15	10	0.3	1	0.15	118.3	6.5832	0.7463
2015	12	4	3	25	10	0.3	1	0.21	107.3	6.5832	1.1674
2015	12	4	3	35	10	0.3	1	0.21	126.2	6.5832	0.9951
2015	12	4	3	45	10	0.3	1	0.2	133	6.5832	0.8612
2015	12	4	3	55	10	0.3	1	0.21	117.3	6.5832	1.1099
2015	12	4	4	5	10	0.3	1	0.19	112.2	6.5832	1.0334
2015	12	4	4	15	10	0.3	1	0.24	110.9	6.5832	1.3013
2015	12	4	4	25	10	0.3	1	0.2	131.6	6.5832	0.8612
2015	12	4	4	35	10	0.3	1	0.19	137.9	6.5832	0.7272

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	4	45	10	0.3	1	0.14	96.6	6.5832	0.8229
2015	12	4	4	55	10	0.3	1	0.22	125.3	6.5832	1.0525
2015	12	4	5	5	10	0.3	1	0.24	119.1	6.5832	1.2056
2015	12	4	5	15	10	0.3	1	0.19	148	6.5832	0.5741
2015	12	4	5	25	10	0.3	1	0.19	137.9	6.5832	0.7272
2015	12	4	5	35	10	0.3	1	0.2	119.5	6.5832	1.0143
2015	12	4	5	45	10	0.3	1	0.21	113	6.5832	1.1291
2015	12	4	5	55	10	0.3	1	0.17	131.2	6.5832	0.7655
2015	12	4	6	5	10	0.3	1	0.2	106.6	6.5832	1.0908
2015	12	4	6	15	10	0.3	1	0.21	117.8	6.5832	1.0908
2015	12	4	6	25	10	0.3	1	0.15	119.3	6.5832	0.7846
2015	12	4	6	35	10	0.3	1	0.21	104.7	6.5832	1.1674
2015	12	4	6	45	10	0.3	1	0.17	125.8	6.5832	0.8229
2015	12	4	6	55	10	0.3	1	0.16	137.6	6.5832	0.6124
2015	12	4	7	5	10	0.3	1	0.14	106.3	6.5832	0.7846
2015	12	4	7	15	10	0.3	1	0.22	96.9	6.5832	1.263
2015	12	4	7	25	10	0.3	1	0.17	99.1	6.5832	0.9569
2015	12	4	7	35	10	0.3	1	0.18	96.1	6.5832	1.0717
2015	12	4	7	45	10	0.3	1	0.14	144.8	6.5832	0.4593
2015	12	4	7	55	10	0.3	1	0.19	116.1	6.5832	0.976
2015	12	4	8	5	10	0.3	1	0.14	109.3	6.5832	0.7655
2015	12	4	8	15	10	0.3	1	0.17	108.8	6.5832	0.9569
2015	12	4	8	25	10	0.3	1	0.2	100.2	6.5832	1.1674
2015	12	4	8	35	10	0.3	1	0.16	112.9	6.5832	0.8612
2015	12	4	8	45	10	0.3	1	0.15	121.2	6.5832	0.7272
2015	12	4	8	55	10	0.3	1	0.17	128.8	6.5832	0.7846
2015	12	4	9	5	10	0.3	1	0.21	122.5	6.5639	1.0492
2015	12	4	9	15	10	0.3	1	0.2	108.7	6.5832	1.1291
2015	12	4	9	25	10	0.3	1	0.26	88.6	6.5832	1.531
2015	12	4	9	35	10	0.3	1	0.19	111.8	6.5832	1.0525
2015	12	4	9	45	10	0.3	1	0.22	109	6.5832	1.2248
2015	12	4	9	55	10	0.3	1	0.23	102.1	6.5832	1.3396
2015	12	4	10	5	10	0.3	1	0.27	80.8	6.5832	1.5309
2015	12	4	10	15	10	0.3	1	0.16	79.4	6.5832	0.9186
2015	12	4	10	25	10	0.3	1	0.21	116.6	6.5832	1.1099
2015	12	4	10	35	10	0.3	1	0.22	97.9	6.5832	1.2439
2015	12	4	10	45	10	0.3	1	0.24	114.4	6.5832	1.263
2015	12	4	10	55	10	0.3	1	0.19	88	6.5832	1.0908
2015	12	4	11	5	10	0.3	1	0.25	98.5	6.5832	1.4161
2015	12	4	11	15	10	0.3	1	0.21	93.5	6.5832	1.2439
2015	12	4	11	25	10	0.3	1	0.21	94.4	6.5832	1.2439
2015	12	4	11	35	10	0.3	1	0.26	100.2	6.5832	1.4926
2015	12	4	11	45	10	0.3	1	0.13	102.7	6.5832	0.7654
2015	12	4	11	55	10	0.3	1	0.22	119.2	6.5832	1.129
2015	12	4	12	5	10	0.3	1	0.2	81.5	6.5832	1.1482
2015	12	4	12	15	10	0.3	1	0.23	85.9	6.5832	1.3395

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	12	25	10	0.3	1	0.19	76.9	6.5832	1.0716
2015	12	4	12	35	10	0.3	1	0.21	99.9	6.5832	1.2056
2015	12	4	12	45	10	0.3	1	0.22	90	6.5639	1.2781
2015	12	4	12	55	10	0.3	1	0.18	108.4	6.5832	0.9759
2015	12	4	13	5	10	0.3	1	0.23	107.9	6.5832	1.3012
2015	12	4	13	15	10	0.3	1	0.2	86.2	6.5832	1.1481
2015	12	4	13	25	10	0.3	1	0.23	93.2	6.5639	1.3543
2015	12	4	13	35	10	0.3	1	0.21	105.1	6.5832	1.2055
2015	12	4	13	45	10	0.3	1	0.17	95.6	6.5832	0.9759
2015	12	4	13	55	10	0.3	1	0.2	99.3	6.5832	1.1673
2015	12	4	14	5	10	0.3	1	0.23	96.5	6.5639	1.3353
2015	12	4	14	15	10	0.3	1	0.19	105	6.5639	1.0682
2015	12	4	14	25	10	0.3	1	0.22	83.1	6.5639	1.259
2015	12	4	14	35	10	0.3	1	0.17	90	6.5639	1.011
2015	12	4	14	45	10	0.3	1	0.24	75	6.5639	1.3543
2015	12	4	14	55	10	0.3	1	0.17	90	6.5639	1.011
2015	12	4	15	5	10	0.3	1	0.2	75.1	6.5639	1.1445
2015	12	4	15	15	10	0.3	1	0.16	99.3	6.5445	0.9317
2015	12	4	15	25	10	0.3	1	0.25	68.7	6.5445	1.369
2015	12	4	15	35	10	0.3	1	0.3	51.1	6.5252	1.3647
2015	12	4	15	45	10	0.3	1	0.28	43.1	6.5252	1.0993
2015	12	4	15	55	10	0.3	1	0.28	56.3	6.5252	1.3647
2015	12	4	16	5	10	0.3	1	0.21	49.5	6.5252	0.9098
2015	12	4	16	15	10	0.3	1	0.34	59.5	6.5252	1.7059
2015	12	4	16	25	10	0.3	1	0.21	65.9	6.5252	1.0993
2015	12	4	16	35	10	0.3	1	0.25	60.4	6.5252	1.232
2015	12	4	16	45	10	0.3	1	0.2	65.2	6.5445	1.0268
2015	12	4	16	55	10	0.3	1	0.19	77.2	6.5445	1.0838
2015	12	4	17	5	10	0.3	1	0.26	88.6	6.5445	1.5212
2015	12	4	17	15	10	0.3	1	0.22	73.7	6.5445	1.2359
2015	12	4	17	25	10	0.3	1	0.24	107.4	6.5445	1.331
2015	12	4	17	35	10	0.3	1	0.17	90	6.5445	0.9888
2015	12	4	17	45	10	0.3	1	0.17	76.2	6.5445	0.9317
2015	12	4	17	55	10	0.3	1	0.21	88.2	6.5445	1.2169
2015	12	4	18	5	10	0.3	1	0.15	86.3	6.5445	0.8937
2015	12	4	18	15	10	0.3	1	0.1	90	6.5445	0.5704
2015	12	4	18	25	10	0.3	1	0.18	97.4	6.5445	1.0268
2015	12	4	18	35	10	0.3	1	0.2	115.3	6.5639	1.0491
2015	12	4	18	45	10	0.3	1	0.19	101.7	6.5639	1.1063
2015	12	4	18	55	10	0.3	1	0.19	86.1	6.5445	1.1219
2015	12	4	19	5	10	0.3	1	0.1	61.7	6.5639	0.4959
2015	12	4	19	15	10	0.3	1	0.22	97.7	6.5832	1.2821
2015	12	4	19	25	10	0.3	1	0.19	100.7	6.5639	1.1064
2015	12	4	19	35	10	0.3	1	0.12	71.6	6.5639	0.6867
2015	12	4	19	45	10	0.3	1	0.14	102.1	6.5832	0.8037
2015	12	4	19	55	10	0.3	1	0.15	102.8	6.5832	0.842

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	20	5	10	0.3	1	0.12	135	6.5832	0.4784
2015	12	4	20	15	10	0.3	1	0.15	112.5	6.5832	0.7846
2015	12	4	20	25	10	0.3	1	0.14	135	6.5832	0.5741
2015	12	4	20	35	10	0.3	1	0.25	113.6	6.5832	1.3586
2015	12	4	20	45	10	0.3	1	0.33	113.3	6.5832	1.7796
2015	12	4	20	55	10	0.3	1	0.25	117.9	6.5832	1.2629
2015	12	4	21	5	10	0.3	1	0.25	135.5	6.5832	1.0142
2015	12	4	21	15	10	0.3	1	0.16	113.5	6.5639	0.8775
2015	12	4	21	25	10	0.3	1	0.29	101.1	6.5639	1.6596
2015	12	4	21	35	10	0.3	1	0.14	99.7	6.5639	0.7821
2015	12	4	21	45	10	0.3	1	0.14	90	6.5639	0.8393
2015	12	4	21	55	10	0.3	1	0.15	97.6	6.5639	0.8584
2015	12	4	22	5	10	0.3	1	0.17	90	6.5639	1.011
2015	12	4	22	15	10	0.3	1	0.16	117.6	6.5639	0.8393
2015	12	4	22	25	10	0.3	1	0.11	123.2	6.5639	0.5532
2015	12	4	22	35	10	0.3	1	0.18	127.5	6.5639	0.8203
2015	12	4	22	45	10	0.3	1	0.19	135	6.5639	0.763
2015	12	4	22	55	10	0.3	1	0.25	127.9	6.5639	1.1255
2015	12	4	23	5	10	0.3	1	0.16	117.1	6.5445	0.8177
2015	12	4	23	15	10	0.3	1	0.18	129.9	6.5445	0.8177
2015	12	4	23	25	10	0.3	1	0.24	117.6	6.5445	1.236
2015	12	4	23	35	10	0.3	1	0.24	116.9	6.5445	1.236
2015	12	4	23	45	10	0.3	1	0.23	105.4	6.5252	1.3079
2015	12	4	23	55	10	0.3	1	0.17	130.2	6.5252	0.7393
2015	12	5	0	5	10	0.3	1	0.25	119.3	6.5058	1.2471
2015	12	5	0	15	10	0.3	1	0.13	120.5	6.5058	0.6424
2015	12	5	0	25	10	0.3	1	0.14	130.2	6.5058	0.6046
2015	12	5	0	35	10	0.3	1	0.21	123.9	6.4864	0.9794
2015	12	5	0	45	10	0.3	1	0.23	121	6.4864	1.1301
2015	12	5	0	55	10	0.3	1	0.28	119.6	6.4864	1.3938
2015	12	5	1	5	10	0.3	1	0.14	129.1	6.4864	0.6027
2015	12	5	1	15	10	0.3	1	0.13	124.5	6.4671	0.6008
2015	12	5	1	25	10	0.3	1	0.25	138.2	6.4671	0.9387
2015	12	5	1	35	10	0.3	1	0.2	129.7	6.4671	0.8824
2015	12	5	1	45	10	0.3	1	0.23	132.7	6.4671	0.9575
2015	12	5	1	55	10	0.3	1	0.22	139.2	6.4671	0.8261
2015	12	5	2	5	10	0.3	1	0.21	141.5	6.4671	0.7322
2015	12	5	2	15	10	0.3	1	0.18	125.2	6.4671	0.8261
2015	12	5	2	25	10	0.3	1	0.18	130.6	6.4477	0.786
2015	12	5	2	35	10	0.3	1	0.18	119.4	6.4477	0.8983
2015	12	5	2	45	10	0.3	1	0.18	100.5	6.4477	1.0106
2015	12	5	2	55	10	0.3	1	0.17	116.6	6.4477	0.8609
2015	12	5	3	5	10	0.3	1	0.25	113.9	6.4477	1.31
2015	12	5	3	15	10	0.3	1	0.25	134.5	6.4477	1.0293
2015	12	5	3	25	10	0.3	1	0.33	132.5	6.4477	1.3662
2015	12	5	3	35	10	0.3	1	0.22	114.2	6.4284	1.1193

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	3	45	10	0.3	1	0.2	125	6.4284	0.9327
2015	12	5	3	55	10	0.3	1	0.21	150.3	6.4284	0.5969
2015	12	5	4	5	10	0.3	1	0.17	103.2	6.4284	0.9514
2015	12	5	4	15	10	0.3	1	0.13	108.9	6.4284	0.7089
2015	12	5	4	25	10	0.3	1	0.2	106.3	6.4284	1.082
2015	12	5	4	35	10	0.3	1	0.2	103.1	6.4284	1.1193
2015	12	5	4	45	10	0.3	1	0.17	109.1	6.4284	0.9141
2015	12	5	4	55	10	0.3	1	0.15	127.9	6.4284	0.6716
2015	12	5	5	5	10	0.3	1	0.23	97.2	6.409	1.3202
2015	12	5	5	15	10	0.3	1	0.15	120.5	6.409	0.7252
2015	12	5	5	25	10	0.3	1	0.22	127	6.409	0.9855
2015	12	5	5	35	10	0.3	1	0.19	125.3	6.409	0.8925
2015	12	5	5	45	10	0.3	1	0.33	110.2	6.409	1.7665
2015	12	5	5	55	10	0.3	1	0.2	88.2	6.409	1.1529
2015	12	5	6	5	10	0.3	1	0.21	109.6	6.409	1.0971
2015	12	5	6	15	10	0.3	1	0.23	97.5	6.409	1.2644
2015	12	5	6	25	10	0.3	1	0.22	99.5	6.409	1.2272
2015	12	5	6	35	10	0.3	1	0.17	118.5	6.409	0.8553
2015	12	5	6	45	10	0.3	1	0.15	116.6	6.409	0.781
2015	12	5	6	55	10	0.3	1	0.09	119.2	6.409	0.4649
2015	12	5	7	5	10	0.3	1	0.2	115.7	6.3897	1.0379
2015	12	5	7	15	10	0.3	1	0.16	90	6.3897	0.9267
2015	12	5	7	25	10	0.3	1	0.2	107	6.3897	1.0935
2015	12	5	7	35	10	0.3	1	0.14	118.4	6.3897	0.6858
2015	12	5	7	45	10	0.3	1	0.23	90	6.3897	1.2974
2015	12	5	7	55	10	0.3	1	0.08	64.5	6.3897	0.3892
2015	12	5	8	5	10	0.3	1	0.26	98.9	6.3897	1.4271
2015	12	5	8	15	10	0.3	1	0.11	86.5	6.3897	0.6116
2015	12	5	8	25	10	0.3	1	0.32	123.7	6.3897	1.5013
2015	12	5	8	35	10	0.3	1	0.14	91.4	6.3897	0.7784
2015	12	5	8	45	10	0.3	1	0.14	99.7	6.3897	0.7599
2015	12	5	8	55	10	0.3	1	0.11	59.6	6.3897	0.5375
2015	12	5	9	5	10	0.3	1	0.01	135	6.3897	0.0371
2015	12	5	9	15	10	0.3	1	0.07	320.9	6.3897	-0.2409
2015	12	5	9	25	10	0.3	1	0.16	90	6.3897	0.9082
2015	12	5	9	35	10	0.3	1	0.16	64.5	6.3897	0.8155
2015	12	5	9	45	10	0.3	1	0.08	60.3	6.3897	0.3892
2015	12	5	9	55	10	0.3	1	0.1	55.8	6.3897	0.4634
2015	12	5	10	5	10	0.3	1	0.13	103	6.3897	0.7228
2015	12	5	10	15	10	0.3	1	0.05	346	6.3897	-0.0741
2015	12	5	10	25	10	0.3	1	0.1	114.1	6.3897	0.5375
2015	12	5	10	35	10	0.3	1	0.2	106.6	6.3897	1.0564
2015	12	5	10	45	10	0.3	1	0.23	116.6	6.3897	1.1862
2015	12	5	10	55	10	0.3	1	0.22	131.4	6.3897	0.9452
2015	12	5	11	5	10	0.3	1	0.15	136.8	6.3897	0.5745
2015	12	5	11	15	10	0.3	1	0.15	163.5	6.3897	0.2409

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	11	25	10	0.3	1	0.13	128.7	6.409	0.5578
2015	12	5	11	35	10	0.3	1	0.15	135	6.409	0.6136
2015	12	5	11	45	10	0.3	1	0.12	99.2	6.409	0.688
2015	12	5	11	55	10	0.3	1	0.17	113.2	6.409	0.9111
2015	12	5	12	5	10	0.3	1	0.17	128.8	6.409	0.7623
2015	12	5	12	15	10	0.3	1	0.17	90	6.409	0.9669
2015	12	5	12	25	10	0.3	1	0.25	126.9	6.409	1.1156
2015	12	5	12	35	10	0.3	1	0.17	119.5	6.409	0.8553
2015	12	5	12	45	10	0.3	1	0.2	110.2	6.4284	1.0633
2015	12	5	12	55	10	0.3	1	0.22	125.3	6.4284	1.026
2015	12	5	13	5	10	0.3	1	0.16	93.6	6.4284	0.8954
2015	12	5	13	15	10	0.3	1	0.15	101.6	6.4284	0.8208
2015	12	5	13	25	10	0.3	1	0.15	115.4	6.4284	0.7461
2015	12	5	13	35	10	0.3	1	0.13	109.4	6.4284	0.6902
2015	12	5	13	45	10	0.3	1	0.15	107.3	6.4284	0.8394
2015	12	5	13	55	10	0.3	1	0.17	91.1	6.4477	0.9918
2015	12	5	14	5	10	0.3	1	0.16	82.9	6.4477	0.8983
2015	12	5	14	15	10	0.3	1	0.13	84.1	6.4477	0.7298
2015	12	5	14	25	10	0.3	1	0.04	104	6.4477	0.2246
2015	12	5	14	35	10	0.3	1	0.09	126.5	6.4477	0.4304
2015	12	5	14	45	10	0.3	1	0.14	96.6	6.4671	0.8073
2015	12	5	14	55	10	0.3	1	0.15	96.2	6.4671	0.8636
2015	12	5	15	5	10	0.3	1	0.18	99.3	6.4671	1.0326
2015	12	5	15	15	10	0.3	1	0.14	81.9	6.4671	0.7885
2015	12	5	15	25	10	0.3	1	0.21	76.2	6.4477	1.1415
2015	12	5	15	35	10	0.3	1	0.24	69.1	6.4671	1.2766
2015	12	5	15	45	10	0.3	1	0.25	60.4	6.4671	1.2578
2015	12	5	15	55	10	0.3	1	0.23	101.3	6.4671	1.3142
2015	12	5	16	5	10	0.3	1	0.19	89	6.4864	1.0735
2015	12	5	16	15	10	0.3	1	0.25	96.8	6.4864	1.4125
2015	12	5	16	25	10	0.3	1	0.12	67.6	6.4864	0.6404
2015	12	5	16	35	10	0.3	1	0.23	83.5	6.4864	1.3184
2015	12	5	16	45	10	0.3	1	0.18	107.1	6.4864	0.9794
2015	12	5	16	55	10	0.3	1	0.19	84.1	6.4864	1.0924
2015	12	5	17	5	10	0.3	1	0.27	119.4	6.5058	1.3415
2015	12	5	17	15	10	0.3	1	0.12	107.9	6.5058	0.6424
2015	12	5	17	25	10	0.3	1	0.21	90	6.5058	1.2092
2015	12	5	17	35	10	0.3	1	0.15	93.8	6.5252	0.853
2015	12	5	17	45	10	0.3	1	0.07	87.3	6.5445	0.3993
2015	12	5	17	55	10	0.3	1	0.16	97.3	6.5445	0.8937
2015	12	5	18	5	10	0.3	1	0.21	97.2	6.5639	1.2017
2015	12	5	18	15	10	0.3	1	0.16	99.3	6.5832	0.9376
2015	12	5	18	25	10	0.3	1	0.14	107.2	6.5832	0.8037
2015	12	5	18	35	10	0.3	1	0.17	87.8	6.5832	0.9759
2015	12	5	18	45	10	0.3	1	0.1	59.3	6.5832	0.5167
2015	12	5	18	55	10	0.3	1	0.1	109.7	6.6026	0.5375

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	19	5	10	0.3	1	0.19	103.3	6.6026	1.0558
2015	12	5	19	15	10	0.3	1	0.1	135	6.6026	0.4031
2015	12	5	19	25	10	0.3	1	0.16	130	6.6026	0.7103
2015	12	5	19	35	10	0.3	1	0.22	121.8	6.6026	1.1134
2015	12	5	19	45	10	0.3	1	0.1	128.4	6.6026	0.4607
2015	12	5	19	55	10	0.3	1	0.25	132.4	6.6219	1.0976
2015	12	5	20	5	10	0.3	1	0.14	130.3	6.6219	0.6355
2015	12	5	20	15	10	0.3	1	0.19	124.2	6.6219	0.9051
2015	12	5	20	25	10	0.3	1	0.04	157.4	6.6219	0.0963
2015	12	5	20	35	10	0.3	1	0.07	135	6.6219	0.3081
2015	12	5	20	45	10	0.3	1	0.19	112.2	6.6413	1.0431
2015	12	5	20	55	10	0.3	1	0.08	138.2	6.6413	0.3284
2015	12	5	21	5	10	0.3	1	0.12	127.5	6.6413	0.5795
2015	12	5	21	15	10	0.3	1	0.19	125.7	6.6413	0.8886
2015	12	5	21	25	10	0.3	1	0.19	130.8	6.6413	0.8499
2015	12	5	21	35	10	0.3	1	0.22	116.2	6.6413	1.1783
2015	12	5	21	45	10	0.3	1	0.26	118.8	6.6413	1.3329
2015	12	5	21	55	10	0.3	1	0.28	121.4	6.6413	1.3908
2015	12	5	22	5	10	0.3	1	0.15	123.3	6.6413	0.7341
2015	12	5	22	15	10	0.3	1	0.29	120.1	6.6413	1.4681
2015	12	5	22	25	10	0.3	1	0.14	102.4	6.6413	0.792
2015	12	5	22	35	10	0.3	1	0.16	117.6	6.6413	0.85
2015	12	5	22	45	10	0.3	1	0.14	124.8	6.6413	0.6954
2015	12	5	22	55	10	0.3	1	0.22	126.5	6.6413	1.0431
2015	12	5	23	5	10	0.3	1	0.21	124.9	6.6413	1.0238
2015	12	5	23	15	10	0.3	1	0.12	117.3	6.6607	0.6395
2015	12	5	23	25	10	0.3	1	0.15	113.8	6.6413	0.8306
2015	12	5	23	35	10	0.3	1	0.18	131.3	6.6607	0.7945
2015	12	5	23	45	10	0.3	1	0.16	128.5	6.6607	0.7557
2015	12	5	23	55	10	0.3	1	0.22	119.2	6.6607	1.1433
2015	12	6	0	5	10	0.3	1	0.16	130.1	6.6607	0.7364
2015	12	6	0	15	10	0.3	1	0.21	119	6.6607	1.0852
2015	12	6	0	25	10	0.3	1	0.23	103.1	6.6607	1.3371
2015	12	6	0	35	10	0.3	1	0.27	114	6.6607	1.434
2015	12	6	0	45	10	0.3	1	0.29	114.6	6.6607	1.5696
2015	12	6	0	55	10	0.3	1	0.22	131.9	6.6607	0.9495
2015	12	6	1	5	10	0.3	1	0.25	109.6	6.6607	1.4146
2015	12	6	1	15	10	0.3	1	0.18	94.1	6.6607	1.0852
2015	12	6	1	25	10	0.3	1	0.24	115.9	6.6607	1.279
2015	12	6	1	35	10	0.3	1	0.24	104.4	6.6607	1.3565
2015	12	6	1	45	10	0.3	1	0.14	95.3	6.6607	0.8333
2015	12	6	1	55	10	0.3	1	0.27	124.3	6.6607	1.3371
2015	12	6	2	5	10	0.3	1	0.2	110.8	6.6607	1.1239
2015	12	6	2	15	10	0.3	1	0.17	103.2	6.6607	0.9883
2015	12	6	2	25	10	0.3	1	0.24	113.7	6.6607	1.279
2015	12	6	2	35	10	0.3	1	0.27	125.2	6.68	1.3218

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	2	45	10	0.3	1	0.21	107.9	6.6607	1.2015
2015	12	6	2	55	10	0.3	1	0.26	119.1	6.68	1.3607
2015	12	6	3	5	10	0.3	1	0.12	85.1	6.6607	0.6782
2015	12	6	3	15	10	0.3	1	0.17	108.8	6.68	0.9719
2015	12	6	3	25	10	0.3	1	0.2	118.7	6.68	1.0303
2015	12	6	3	35	10	0.3	1	0.23	116.9	6.68	1.2246
2015	12	6	3	45	10	0.3	1	0.28	125.9	6.68	1.3413
2015	12	6	3	55	10	0.3	1	0.19	115.7	6.68	1.0108
2015	12	6	4	5	10	0.3	1	0.21	130	6.68	0.9719
2015	12	6	4	15	10	0.3	1	0.19	108.7	6.68	1.0886
2015	12	6	4	25	10	0.3	1	0.28	126.5	6.68	1.3413
2015	12	6	4	35	10	0.3	1	0.25	108.9	6.68	1.419
2015	12	6	4	45	10	0.3	1	0.21	133.1	6.68	0.8942
2015	12	6	4	55	10	0.3	1	0.23	122.3	6.68	1.1663
2015	12	6	5	5	10	0.3	1	0.2	124.2	6.68	0.9719
2015	12	6	5	15	10	0.3	1	0.21	101.5	6.68	1.2441
2015	12	6	5	25	10	0.3	1	0.19	110.3	6.68	1.0497
2015	12	6	5	35	10	0.3	1	0.16	116.1	6.68	0.8747
2015	12	6	5	45	10	0.3	1	0.19	126.7	6.68	0.9136
2015	12	6	5	55	10	0.3	1	0.19	124	6.68	0.9525
2015	12	6	6	5	10	0.3	1	0.24	119.1	6.68	1.2247
2015	12	6	6	15	10	0.3	1	0.18	118.4	6.68	0.9331
2015	12	6	6	25	10	0.3	1	0.12	116.6	6.68	0.6609
2015	12	6	6	35	10	0.3	1	0.15	108	6.68	0.8359
2015	12	6	6	45	10	0.3	1	0.15	108	6.68	0.8359
2015	12	6	6	55	10	0.3	1	0.2	115.3	6.6994	1.0725
2015	12	6	7	5	10	0.3	1	0.15	108	6.6994	0.8385
2015	12	6	7	15	10	0.3	1	0.19	119.6	6.68	0.9914
2015	12	6	7	25	10	0.3	1	0.16	111.4	6.68	0.8942
2015	12	6	7	35	10	0.3	1	0.19	119.7	6.68	0.9525
2015	12	6	7	45	10	0.3	1	0.11	142.1	6.6994	0.4095
2015	12	6	7	55	10	0.3	1	0.24	125.2	6.6994	1.1895
2015	12	6	8	5	10	0.3	1	0.16	113.5	6.6994	0.897
2015	12	6	8	15	10	0.3	1	0.15	119.3	6.6994	0.7995
2015	12	6	8	25	10	0.3	1	0.15	136.7	6.7187	0.6259
2015	12	6	8	35	10	0.3	1	0.12	135	6.6994	0.4875
2015	12	6	8	45	10	0.3	1	0.15	118.2	6.6994	0.7995
2015	12	6	8	55	10	0.3	1	0.17	138.9	6.7187	0.665
2015	12	6	9	5	10	0.3	1	0.19	122.3	6.6994	0.9555
2015	12	6	9	15	10	0.3	1	0.15	127.9	6.7187	0.7042
2015	12	6	9	25	10	0.3	1	0.17	119.1	6.6994	0.8775
2015	12	6	9	35	10	0.3	1	0.19	135	6.7187	0.7824
2015	12	6	9	45	10	0.3	1	0.16	116.1	6.6994	0.8775
2015	12	6	9	55	10	0.3	1	0.11	118.1	6.6994	0.585
2015	12	6	10	5	10	0.3	1	0.1	114.1	6.6994	0.5655
2015	12	6	10	15	10	0.3	1	0.13	124.1	6.68	0.6609

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	10	25	10	0.3	1	0.16	109.9	6.68	0.9136
2015	12	6	10	35	10	0.3	1	0.13	124.9	6.6994	0.6435
2015	12	6	10	45	10	0.3	1	0.16	127.6	6.6994	0.7605
2015	12	6	10	55	10	0.3	1	0.17	109.1	6.68	0.9525
2015	12	6	11	5	10	0.3	1	0.16	108.8	6.6994	0.9165
2015	12	6	11	15	10	0.3	1	0.19	118.8	6.6994	0.9945
2015	12	6	11	25	10	0.3	1	0.13	119.2	6.6994	0.663
2015	12	6	11	35	10	0.3	1	0.16	97.3	6.6994	0.9165
2015	12	6	11	45	10	0.3	1	0.2	105.8	6.6994	1.1699
2015	12	6	11	55	10	0.3	1	0.2	117	6.6994	1.0334
2015	12	6	12	5	10	0.3	1	0.19	98.1	6.6994	1.0919
2015	12	6	12	15	10	0.3	1	0.12	91.5	6.6994	0.7215
2015	12	6	12	25	10	0.3	1	0.21	101.5	6.6994	1.2479
2015	12	6	12	35	10	0.3	1	0.31	106.9	6.6994	1.7354
2015	12	6	12	45	10	0.3	1	0.19	108.7	6.6994	1.0919
2015	12	6	12	55	10	0.3	1	0.2	104.3	6.6994	1.1504
2015	12	6	13	5	10	0.3	1	0.21	107.6	6.6994	1.1699
2015	12	6	13	15	10	0.3	1	0.22	99.5	6.6994	1.2869
2015	12	6	13	25	10	0.3	1	0.25	100	6.6994	1.4429
2015	12	6	13	35	10	0.3	1	0.19	107.8	6.6994	1.0919
2015	12	6	13	45	10	0.3	1	0.17	104.9	6.6994	0.9554
2015	12	6	13	55	10	0.3	1	0.12	99.2	6.6994	0.7214
2015	12	6	14	5	10	0.3	1	0.19	84.1	6.6994	1.1309
2015	12	6	14	15	10	0.3	1	0.21	94.4	6.6994	1.2674
2015	12	6	14	25	10	0.3	1	0.2	99.3	6.6994	1.1894
2015	12	6	14	35	10	0.3	1	0.32	64.8	6.6994	1.6963
2015	12	6	14	45	10	0.3	1	0.17	92.2	6.6994	1.0334
2015	12	6	14	55	10	0.3	1	0.16	99.5	6.6994	0.9359
2015	12	6	15	5	10	0.3	1	0.19	82.1	6.6994	1.1309
2015	12	6	15	15	10	0.3	1	0.15	93.7	6.6994	0.9164
2015	12	6	15	25	10	0.3	1	0.12	80.3	6.6994	0.6824
2015	12	6	15	35	10	0.3	1	0.11	90	6.6994	0.6629
2015	12	6	15	45	10	0.3	1	0.14	334	6.6994	-0.3705
2015	12	6	15	55	10	0.3	1	0.1	23.2	6.6994	0.234
2015	12	6	16	5	10	0.3	1	0.17	326.9	6.6994	-0.5459
2015	12	6	16	15	10	0.3	1	0.15	341.2	6.6994	-0.2925
2015	12	6	16	25	10	0.3	1	0.14	348.2	6.6994	-0.1755
2015	12	6	16	35	10	0.3	1	0.04	98.7	6.6994	0.2535
2015	12	6	16	45	10	0.3	1	0.1	62.6	6.6994	0.5264
2015	12	6	16	55	10	0.3	1	0.16	67.1	6.6994	0.8774
2015	12	6	17	5	10	0.3	1	0.19	83.2	6.6994	1.1504
2015	12	6	17	15	10	0.3	1	0.27	78.8	6.6994	1.5793
2015	12	6	17	25	10	0.3	1	0.24	79.6	6.6994	1.3844
2015	12	6	17	35	10	0.3	1	0.18	52.3	6.6994	0.8579
2015	12	6	17	45	10	0.3	1	0.18	73.2	6.6994	1.0334
2015	12	6	17	55	10	0.3	1	0.22	88.3	6.6994	1.2869

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	18	5	10	0.3	1	0.16	94.6	6.6994	0.9749
2015	12	6	18	15	10	0.3	1	0.23	96.5	6.6994	1.3649
2015	12	6	18	25	10	0.3	1	0.22	86.5	6.6994	1.2869
2015	12	6	18	35	10	0.3	1	0.14	84.4	6.6994	0.7994
2015	12	6	18	45	10	0.3	1	0.17	40.4	6.6994	0.6629
2015	12	6	18	55	10	0.3	1	0.11	60.5	6.6994	0.5849
2015	12	6	19	5	10	0.3	1	0.17	98.7	6.6994	1.0139
2015	12	6	19	15	10	0.3	1	0.13	59	6.6994	0.6824
2015	12	6	19	25	10	0.3	1	0.2	102.2	6.6994	1.1699
2015	12	6	19	35	10	0.3	1	0.16	135.8	6.6994	0.6629
2015	12	6	19	45	10	0.3	1	0.25	104.6	6.6994	1.4234
2015	12	6	19	55	10	0.3	1	0.22	116.9	6.6994	1.1894
2015	12	6	20	5	10	0.3	1	0.18	111.4	6.6994	0.9944
2015	12	6	20	15	10	0.3	1	0.23	114.7	6.6994	1.2284
2015	12	6	20	25	10	0.3	1	0.18	98.6	6.6994	1.0334
2015	12	6	20	35	10	0.3	1	0.2	118.7	6.6994	1.0334
2015	12	6	20	45	10	0.3	1	0.24	123.5	6.6994	1.2089
2015	12	6	20	55	10	0.3	1	0.25	100.7	6.6994	1.4429
2015	12	6	21	5	10	0.3	1	0.15	108.8	6.6994	0.8579
2015	12	6	21	15	10	0.3	1	0.18	118	6.6994	0.9554
2015	12	6	21	25	10	0.3	1	0.14	107.2	6.6994	0.8189
2015	12	6	21	35	10	0.3	1	0.09	72.3	6.6994	0.4875
2015	12	6	21	45	10	0.3	1	0.21	93.5	6.6994	1.2674
2015	12	6	21	55	10	0.3	1	0.2	113.2	6.6994	1.0919
2015	12	6	22	5	10	0.3	1	0.11	96.9	6.6994	0.6435
2015	12	6	22	15	10	0.3	1	0.21	113.8	6.6994	1.1504
2015	12	6	22	25	10	0.3	1	0.27	111.9	6.6994	1.5014
2015	12	6	22	35	10	0.3	1	0.24	104	6.6994	1.4039
2015	12	6	22	45	10	0.3	1	0.23	103.8	6.6994	1.3454
2015	12	6	22	55	10	0.3	1	0.22	108.4	6.6994	1.2284
2015	12	6	23	5	10	0.3	1	0.21	108.4	6.6994	1.1699
2015	12	6	23	15	10	0.3	1	0.15	112	6.7187	0.8215
2015	12	6	23	25	10	0.3	1	0.28	108	6.7187	1.5647
2015	12	6	23	35	10	0.3	1	0.2	111.4	6.7187	1.0953
2015	12	6	23	45	10	0.3	1	0.2	104.9	6.7187	1.1736
2015	12	6	23	55	10	0.3	1	0.21	126.7	6.7187	0.9975
2015	12	7	0	5	10	0.3	1	0.24	110.2	6.7187	1.33
2015	12	7	0	15	10	0.3	1	0.19	103.3	6.7187	1.0758
2015	12	7	0	25	10	0.3	1	0.22	109	6.7187	1.2518
2015	12	7	0	35	10	0.3	1	0.17	107.7	6.7381	0.981
2015	12	7	0	45	10	0.3	1	0.15	125.8	6.7381	0.7063
2015	12	7	0	55	10	0.3	1	0.23	122.5	6.7381	1.138
2015	12	7	1	5	10	0.3	1	0.15	102.3	6.7187	0.8997
2015	12	7	1	15	10	0.3	1	0.22	109.2	6.7381	1.2361
2015	12	7	1	25	10	0.3	1	0.17	104.3	6.7381	1.0006
2015	12	7	1	35	10	0.3	1	0.19	121	6.7381	0.981

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	1	45	10	0.3	1	0.22	125.3	6.7381	1.0791
2015	12	7	1	55	10	0.3	1	0.2	110.8	6.7381	1.138
2015	12	7	2	5	10	0.3	1	0.16	98.5	6.7381	0.9221
2015	12	7	2	15	10	0.3	1	0.25	116.2	6.7381	1.3145
2015	12	7	2	25	10	0.3	1	0.22	118.1	6.7381	1.1772
2015	12	7	2	35	10	0.3	1	0.21	109.3	6.7381	1.1772
2015	12	7	2	45	10	0.3	1	0.27	121.3	6.7381	1.3538
2015	12	7	2	55	10	0.3	1	0.22	110.4	6.7381	1.2164
2015	12	7	3	5	10	0.3	1	0.17	109.1	6.7381	0.9614
2015	12	7	3	15	10	0.3	1	0.1	84.3	6.7381	0.5886
2015	12	7	3	25	10	0.3	1	0.16	106.3	6.7381	0.9418
2015	12	7	3	35	10	0.3	1	0.21	124.9	6.7381	1.0399
2015	12	7	3	45	10	0.3	1	0.16	99.5	6.7381	0.9418
2015	12	7	3	55	10	0.3	1	0.24	111.2	6.7381	1.3145
2015	12	7	4	5	10	0.3	1	0.23	113.6	6.7381	1.2557
2015	12	7	4	15	10	0.3	1	0.22	104.9	6.7381	1.2557
2015	12	7	4	25	10	0.3	1	0.21	129.9	6.7381	0.9614
2015	12	7	4	35	10	0.3	1	0.23	114.4	6.7381	1.2557
2015	12	7	4	45	10	0.3	1	0.25	95.3	6.7381	1.4715
2015	12	7	4	55	10	0.3	1	0.12	127.2	6.7381	0.569
2015	12	7	5	5	10	0.3	1	0.21	98.9	6.7381	1.2557
2015	12	7	5	15	10	0.3	1	0.18	110.8	6.7381	0.981
2015	12	7	5	25	10	0.3	1	0.18	99.5	6.7381	1.0595
2015	12	7	5	35	10	0.3	1	0.18	128.3	6.7381	0.8437
2015	12	7	5	45	10	0.3	1	0.15	119.3	6.7381	0.8044
2015	12	7	5	55	10	0.3	1	0.28	113.6	6.7381	1.5304
2015	12	7	6	5	10	0.3	1	0.23	116.9	6.7381	1.2361
2015	12	7	6	15	10	0.3	1	0.22	105.7	6.7381	1.2557
2015	12	7	6	25	10	0.3	1	0.2	102	6.7381	1.1968
2015	12	7	6	35	10	0.3	1	0.18	102.3	6.7381	1.0791
2015	12	7	6	45	10	0.3	1	0.2	114.9	6.7381	1.0987
2015	12	7	6	55	10	0.3	1	0.2	129	6.7381	0.9221
2015	12	7	7	5	10	0.3	1	0.24	124.8	6.7381	1.1576
2015	12	7	7	15	10	0.3	1	0.21	113.8	6.7381	1.1576
2015	12	7	7	25	10	0.3	1	0.15	112	6.7381	0.824
2015	12	7	7	35	10	0.3	1	0.21	102.5	6.7574	1.2399
2015	12	7	7	45	10	0.3	1	0.22	124.9	6.7381	1.0987
2015	12	7	7	55	10	0.3	1	0.19	114.4	6.7381	1.0399
2015	12	7	8	5	10	0.3	1	0.16	124.3	6.7574	0.8069
2015	12	7	8	15	10	0.3	1	0.15	118.3	6.7574	0.7675
2015	12	7	8	25	10	0.3	1	0.2	125	6.7381	0.981
2015	12	7	8	35	10	0.3	1	0.18	135	6.7381	0.7456
2015	12	7	8	45	10	0.3	1	0.2	135.7	6.7574	0.8463
2015	12	7	8	55	10	0.3	1	0.15	132.4	6.7381	0.6671
2015	12	7	9	5	10	0.3	1	0.18	135	6.7381	0.7456
2015	12	7	9	15	10	0.3	1	0.17	124.6	6.7187	0.8215

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	9	25	10	0.3	1	0.2	129.7	6.7187	0.9193
2015	12	7	9	35	10	0.3	1	0.3	133.7	6.7187	1.3105
2015	12	7	9	45	10	0.3	1	0.17	131.2	6.7187	0.7824
2015	12	7	9	55	10	0.3	1	0.24	114.4	6.6994	1.2869
2015	12	7	10	5	10	0.3	1	0.21	127.4	6.6994	0.9945
2015	12	7	10	15	10	0.3	1	0.17	110.2	6.6994	0.9555
2015	12	7	10	25	10	0.3	1	0.17	130.2	6.6994	0.7605
2015	12	7	10	35	10	0.3	1	0.14	117.1	6.6994	0.7605
2015	12	7	10	45	10	0.3	1	0.2	105.4	6.6994	1.1309
2015	12	7	10	55	10	0.3	1	0.23	115.1	6.6994	1.2479
2015	12	7	11	5	10	0.3	1	0.16	95.9	6.6994	0.9359
2015	12	7	11	15	10	0.3	1	0.17	115.1	6.6994	0.9164
2015	12	7	11	25	10	0.3	1	0.23	104.2	6.6994	1.3064
2015	12	7	11	35	10	0.3	1	0.23	100.7	6.6994	1.3454
2015	12	7	11	45	10	0.3	1	0.21	94.5	6.6994	1.2479
2015	12	7	11	55	10	0.3	1	0.2	98.7	6.6994	1.1504
2015	12	7	12	5	10	0.3	1	0.16	73.4	6.6994	0.9164
2015	12	7	12	15	10	0.3	1	0.19	108.1	6.6994	1.0724
2015	12	7	12	25	10	0.3	1	0.2	102.4	6.6994	1.1504
2015	12	7	12	35	10	0.3	1	0.22	97.8	6.6994	1.2869
2015	12	7	12	45	10	0.3	1	0.23	87.6	6.6994	1.3844
2015	12	7	12	55	10	0.3	1	0.16	124	6.6994	0.7799
2015	12	7	13	5	10	0.3	1	0.1	70.3	6.6994	0.5459
2015	12	7	13	15	10	0.3	1	0.11	100.6	6.6994	0.6239
2015	12	7	13	25	10	0.3	1	0.11	63.4	6.6994	0.5849
2015	12	7	13	35	10	0.3	1	0.17	103.2	6.6994	0.9944
2015	12	7	13	45	10	0.3	1	0.19	124	6.6994	0.9554
2015	12	7	13	55	10	0.3	1	0.14	107.2	6.6994	0.8189
2015	12	7	14	5	10	0.3	1	0.25	101.9	6.6994	1.4818
2015	12	7	14	15	10	0.3	1	0.2	80.7	6.6994	1.1894
2015	12	7	14	25	10	0.3	1	0.18	62	6.6994	0.9554
2015	12	7	14	35	10	0.3	1	0.31	78.5	6.6994	1.8133
2015	12	7	14	45	10	0.3	1	0.19	86	6.6994	1.1114
2015	12	7	14	55	10	0.3	1	0.22	87.4	6.6994	1.3063
2015	12	7	15	5	10	0.3	1	0.24	80.5	6.6994	1.4038
2015	12	7	15	15	10	0.3	1	0.23	92.5	6.6994	1.3648
2015	12	7	15	25	10	0.3	1	0.28	86.6	6.6994	1.6573
2015	12	7	15	35	10	0.3	1	0.22	74.7	6.6994	1.2868
2015	12	7	15	45	10	0.3	1	0.39	100.7	6.6994	2.2617
2015	12	7	15	55	10	0.3	1	0.15	83.5	6.6994	0.8579
2015	12	7	16	5	10	0.3	1	0.27	99.9	6.6994	1.5598
2015	12	7	16	15	10	0.3	1	0.15	84.9	6.6994	0.8774
2015	12	7	16	25	10	0.3	1	0.18	109.7	6.68	1.0302
2015	12	7	16	35	10	0.3	1	0.11	68.2	6.68	0.5831
2015	12	7	16	45	10	0.3	1	0.23	98.2	6.6994	1.3453
2015	12	7	16	55	10	0.3	1	0.09	83.7	6.6994	0.5264

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	17	5	10	0.3	1	0.27	115.3	6.6994	1.4428
2015	12	7	17	15	10	0.3	1	0.12	70	6.6994	0.6434
2015	12	7	17	25	10	0.3	1	0.27	99.7	6.68	1.5938
2015	12	7	17	35	10	0.3	1	0.19	93.9	6.6994	1.1504
2015	12	7	17	45	10	0.3	1	0.17	95.4	6.6994	1.0334
2015	12	7	17	55	10	0.3	1	0.23	87.6	6.6994	1.3843
2015	12	7	18	5	10	0.3	1	0.22	102	6.6994	1.2868
2015	12	7	18	15	10	0.3	1	0.18	78.7	6.6994	1.0724
2015	12	7	18	25	10	0.3	1	0.12	52.5	6.6994	0.5849
2015	12	7	18	35	10	0.3	1	0.21	101	6.6994	1.2088
2015	12	7	18	45	10	0.3	1	0.2	110.8	6.6994	1.1309
2015	12	7	18	55	10	0.3	1	0.14	91.3	6.6994	0.8579
2015	12	7	19	5	10	0.3	1	0.19	95	6.6994	1.1114
2015	12	7	19	15	10	0.3	1	0.31	106.1	6.6994	1.7548
2015	12	7	19	25	10	0.3	1	0.28	94.8	6.6994	1.6378
2015	12	7	19	35	10	0.3	1	0.17	88.9	6.6994	1.0334
2015	12	7	19	45	10	0.3	1	0.15	101.1	6.6994	0.8969
2015	12	7	19	55	10	0.3	1	0.24	115.5	6.6994	1.2673
2015	12	7	20	5	10	0.3	1	0.31	107.5	6.6994	1.7353
2015	12	7	20	15	10	0.3	1	0.25	119.9	6.6994	1.2869
2015	12	7	20	25	10	0.3	1	0.24	88.5	6.6994	1.4428
2015	12	7	20	35	10	0.3	1	0.18	118.9	6.6994	0.9554
2015	12	7	20	45	10	0.3	1	0.2	93.8	6.6994	1.1894
2015	12	7	20	55	10	0.3	1	0.16	100.8	6.6994	0.9164
2015	12	7	21	5	10	0.3	1	0.16	100.8	6.6994	0.9164
2015	12	7	21	15	10	0.3	1	0.26	102.4	6.6994	1.5013
2015	12	7	21	25	10	0.3	1	0.22	106.3	6.6994	1.2674
2015	12	7	21	35	10	0.3	1	0.18	117	6.6994	0.9554
2015	12	7	21	45	10	0.3	1	0.14	101.8	6.6994	0.8384
2015	12	7	21	55	10	0.3	1	0.13	114.6	6.6994	0.6824
2015	12	7	22	5	10	0.3	1	0.06	119.4	6.6994	0.312
2015	12	7	22	15	10	0.3	1	0.15	117.7	6.6994	0.7799
2015	12	7	22	25	10	0.3	1	0.21	106.2	6.6994	1.2089
2015	12	7	22	35	10	0.3	1	0.26	119.7	6.6994	1.3649
2015	12	7	22	45	10	0.3	1	0.16	117.6	6.6994	0.8579
2015	12	7	22	55	10	0.3	1	0.26	112.6	6.6994	1.4039
2015	12	7	23	5	10	0.3	1	0.19	114.4	6.6994	1.0334
2015	12	7	23	15	10	0.3	1	0.24	111.9	6.6994	1.3064
2015	12	7	23	25	10	0.3	1	0.26	109.4	6.6994	1.4429
2015	12	7	23	35	10	0.3	1	0.23	109.5	6.6994	1.2674
2015	12	7	23	45	10	0.3	1	0.23	114	6.6994	1.2674
2015	12	7	23	55	10	0.3	1	0.19	111.6	6.6994	1.0334
2015	12	8	0	5	10	0.3	1	0.22	114.7	6.6994	1.1894
2015	12	8	0	15	10	0.3	1	0.28	100.9	6.6994	1.6184
2015	12	8	0	25	10	0.3	1	0.19	100	6.6994	1.1114
2015	12	8	0	35	10	0.3	1	0.2	73.4	6.6994	1.1114

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	0	45	10	0.3	1	0.18	108.4	6.6994	0.9944
2015	12	8	0	55	10	0.3	1	0.17	86.7	6.6994	1.0139
2015	12	8	1	5	10	0.3	1	0.16	91.1	6.68	0.9719
2015	12	8	1	15	10	0.3	1	0.2	104.3	6.6994	1.1504
2015	12	8	1	25	10	0.3	1	0.21	109.8	6.68	1.1857
2015	12	8	1	35	10	0.3	1	0.28	108	6.68	1.5551
2015	12	8	1	45	10	0.3	1	0.27	92.1	6.68	1.5745
2015	12	8	1	55	10	0.3	1	0.17	116.1	6.68	0.9136
2015	12	8	2	5	10	0.3	1	0.21	106.2	6.68	1.2052
2015	12	8	2	15	10	0.3	1	0.16	101.8	6.68	0.933
2015	12	8	2	25	10	0.3	1	0.22	101.3	6.68	1.2635
2015	12	8	2	35	10	0.3	1	0.22	89.2	6.68	1.3218
2015	12	8	2	45	10	0.3	1	0.2	109.3	6.68	1.108
2015	12	8	2	55	10	0.3	1	0.25	107.3	6.68	1.4384
2015	12	8	3	5	10	0.3	1	0.26	105.6	6.68	1.4579
2015	12	8	3	15	10	0.3	1	0.21	93.6	6.68	1.2441
2015	12	8	3	25	10	0.3	1	0.25	106.6	6.68	1.4384
2015	12	8	3	35	10	0.3	1	0.21	119	6.68	1.0885
2015	12	8	3	45	10	0.3	1	0.18	96.1	6.68	1.0885
2015	12	8	3	55	10	0.3	1	0.22	97.9	6.68	1.2635
2015	12	8	4	5	10	0.3	1	0.21	108.4	6.68	1.1663
2015	12	8	4	15	10	0.3	1	0.21	110.1	6.68	1.1663
2015	12	8	4	25	10	0.3	1	0.24	109.9	6.68	1.3412
2015	12	8	4	35	10	0.3	1	0.2	110.2	6.68	1.108
2015	12	8	4	45	10	0.3	1	0.24	117.3	6.68	1.2829
2015	12	8	4	55	10	0.3	1	0.21	107.6	6.68	1.1663
2015	12	8	5	5	10	0.3	1	0.17	127.3	6.68	0.8164
2015	12	8	5	15	10	0.3	1	0.22	120.4	6.68	1.1274
2015	12	8	5	25	10	0.3	1	0.24	110.4	6.68	1.3607
2015	12	8	5	35	10	0.3	1	0.24	111.7	6.68	1.3218
2015	12	8	5	45	10	0.3	1	0.19	119.7	6.68	0.9525
2015	12	8	5	55	10	0.3	1	0.19	107.5	6.68	1.0497
2015	12	8	6	5	10	0.3	1	0.26	93.6	6.68	1.5551
2015	12	8	6	15	10	0.3	1	0.22	99.5	6.68	1.2829
2015	12	8	6	25	10	0.3	1	0.19	105	6.68	1.0886
2015	12	8	6	35	10	0.3	1	0.23	100.8	6.68	1.3218
2015	12	8	6	45	10	0.3	1	0.19	114.4	6.68	1.0302
2015	12	8	6	55	10	0.3	1	0.2	114.9	6.68	1.0886
2015	12	8	7	5	10	0.3	1	0.19	112.2	6.68	1.0497
2015	12	8	7	15	10	0.3	1	0.21	109.3	6.68	1.1663
2015	12	8	7	25	10	0.3	1	0.22	122.3	6.68	1.108
2015	12	8	7	35	10	0.3	1	0.16	110.3	6.68	0.8942
2015	12	8	7	45	10	0.3	1	0.2	96.7	6.68	1.1663
2015	12	8	7	55	10	0.3	1	0.18	121.3	6.68	0.8942
2015	12	8	8	5	10	0.3	1	0.2	104.9	6.68	1.1663
2015	12	8	8	15	10	0.3	1	0.24	118.7	6.68	1.2441

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	8	25	10	0.3	1	0.17	119.5	6.68	0.8942
2015	12	8	8	35	10	0.3	1	0.15	117.7	6.68	0.7775
2015	12	8	8	45	10	0.3	1	0.16	114.9	6.68	0.8358
2015	12	8	8	55	10	0.3	1	0.22	125.3	6.68	1.0691
2015	12	8	9	5	10	0.3	1	0.14	101.8	6.68	0.8358
2015	12	8	9	15	10	0.3	1	0.2	109.7	6.68	1.0885
2015	12	8	9	25	10	0.3	1	0.18	112.8	6.68	0.9719
2015	12	8	9	35	10	0.3	1	0.12	116.6	6.68	0.6609
2015	12	8	9	45	10	0.3	1	0.12	104	6.68	0.6998
2015	12	8	9	55	10	0.3	1	0.18	90	6.68	1.0885
2015	12	8	10	5	10	0.3	1	0.22	105.7	6.68	1.244
2015	12	8	10	15	10	0.3	1	0.1	90	6.68	0.622
2015	12	8	10	25	10	0.3	1	0.18	117	6.68	0.9525
2015	12	8	10	35	10	0.3	1	0.19	107.8	6.68	1.0885
2015	12	8	10	45	10	0.3	1	0.16	76.8	6.68	0.9136
2015	12	8	10	55	10	0.3	1	0.17	85.6	6.68	1.0108
2015	12	8	11	5	10	0.3	1	0.16	129.2	6.68	0.7386
2015	12	8	11	15	10	0.3	1	0.22	111.5	6.68	1.1857
2015	12	8	11	25	10	0.3	1	0.15	97.6	6.68	0.8747
2015	12	8	11	35	10	0.3	1	0.2	119.1	6.68	1.0496
2015	12	8	11	45	10	0.3	1	0.26	100.8	6.68	1.5356
2015	12	8	11	55	10	0.3	1	0.17	120.6	6.68	0.8553
2015	12	8	12	5	10	0.3	1	0.09	109.1	6.68	0.5054
2015	12	8	12	15	10	0.3	1	0.09	105.1	6.68	0.5054
2015	12	8	12	25	10	0.3	1	0.09	77.5	6.68	0.5248
2015	12	8	12	35	10	0.3	1	0.09	137.9	6.68	0.3693
2015	12	8	12	45	10	0.3	1	0.18	103.8	6.68	1.0302
2015	12	8	12	55	10	0.3	1	0.21	107	6.68	1.2051
2015	12	8	13	5	10	0.3	1	0.16	86.6	6.68	0.9719
2015	12	8	13	15	10	0.3	1	0.26	72.5	6.68	1.4772
2015	12	8	13	25	10	0.3	1	0.17	112.6	6.68	0.933
2015	12	8	13	35	10	0.3	1	0.2	89.1	6.68	1.2051
2015	12	8	13	45	10	0.3	1	0.26	97.8	6.68	1.555
2015	12	8	13	55	10	0.3	1	0.18	108.8	6.68	1.0302
2015	12	8	14	5	10	0.3	1	0.26	106.1	6.68	1.4772
2015	12	8	14	15	10	0.3	1	0.18	78.5	6.68	1.0496
2015	12	8	14	25	10	0.3	1	0.25	81.7	6.68	1.4578
2015	12	8	14	35	10	0.3	1	0.22	105.5	6.68	1.2634
2015	12	8	14	45	10	0.3	1	0.25	84.7	6.68	1.4772
2015	12	8	14	55	10	0.3	1	0.28	83.4	6.68	1.6716
2015	12	8	15	5	10	0.3	1	0.25	93	6.68	1.4772
2015	12	8	15	15	10	0.3	1	0.24	83.7	6.68	1.3995
2015	12	8	15	25	10	0.3	1	0.28	89.3	6.68	1.6716
2015	12	8	15	35	10	0.3	1	0.24	82.1	6.68	1.3995
2015	12	8	15	45	10	0.3	1	0.23	70.8	6.68	1.2828
2015	12	8	15	55	10	0.3	1	0.2	76.9	6.68	1.1662

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	16	5	10	0.3	1	0.23	94	6.68	1.38
2015	12	8	16	15	10	0.3	1	0.26	88.5	6.68	1.5355
2015	12	8	16	25	10	0.3	1	0.23	88.4	6.68	1.38
2015	12	8	16	35	10	0.3	1	0.22	85	6.68	1.3217
2015	12	8	16	45	10	0.3	1	0.22	92.5	6.68	1.3217
2015	12	8	16	55	10	0.3	1	0.18	114.7	6.68	0.9718
2015	12	8	17	5	10	0.3	1	0.19	122.3	6.68	0.9524
2015	12	8	17	15	10	0.3	1	0.13	121.7	6.68	0.6609
2015	12	8	17	25	10	0.3	1	0.16	108.8	6.68	0.9135
2015	12	8	17	35	10	0.3	1	0.21	102.9	6.68	1.1856
2015	12	8	17	45	10	0.3	1	0.19	103.3	6.68	1.069
2015	12	8	17	55	10	0.3	1	0.22	94.2	6.68	1.3217
2015	12	8	18	5	10	0.3	1	0.19	81.2	6.68	1.1273
2015	12	8	18	15	10	0.3	1	0.22	103.8	6.68	1.2634
2015	12	8	18	25	10	0.3	1	0.2	108.7	6.68	1.1468
2015	12	8	18	35	10	0.3	1	0.19	96.8	6.68	1.1468
2015	12	8	18	45	10	0.3	1	0.12	93.2	6.68	0.6997
2015	12	8	18	55	10	0.3	1	0.27	98.4	6.68	1.5744
2015	12	8	19	5	10	0.3	1	0.21	115.8	6.68	1.1273
2015	12	8	19	15	10	0.3	1	0.15	91.2	6.68	0.9135
2015	12	8	19	25	10	0.3	1	0.25	112.5	6.68	1.3606
2015	12	8	19	35	10	0.3	1	0.29	96.6	6.68	1.691
2015	12	8	19	45	10	0.3	1	0.22	99.3	6.68	1.3023
2015	12	8	19	55	10	0.3	1	0.21	106.4	6.68	1.1857
2015	12	8	20	5	10	0.3	1	0.14	93.9	6.68	0.8552
2015	12	8	20	15	10	0.3	1	0.21	102.5	6.68	1.2245
2015	12	8	20	25	10	0.3	1	0.18	114.2	6.68	0.9524
2015	12	8	20	35	10	0.3	1	0.21	103.8	6.68	1.1857
2015	12	8	20	45	10	0.3	1	0.25	118.2	6.68	1.3023
2015	12	8	20	55	10	0.3	1	0.18	122.8	6.68	0.8747
2015	12	8	21	5	10	0.3	1	0.19	102.1	6.68	1.0885
2015	12	8	21	15	10	0.3	1	0.17	83.2	6.68	0.9719
2015	12	8	21	25	10	0.3	1	0.2	107	6.68	1.1468
2015	12	8	21	35	10	0.3	1	0.25	107	6.68	1.3995
2015	12	8	21	45	10	0.3	1	0.23	86.7	6.68	1.3606
2015	12	8	21	55	10	0.3	1	0.27	100.6	6.68	1.555
2015	12	8	22	5	10	0.3	1	0.23	108.4	6.68	1.2829
2015	12	8	22	15	10	0.3	1	0.21	106.7	6.68	1.1662
2015	12	8	22	25	10	0.3	1	0.27	113.2	6.68	1.4967
2015	12	8	22	35	10	0.3	1	0.24	96.9	6.68	1.4384
2015	12	8	22	45	10	0.3	1	0.23	104.2	6.68	1.3023
2015	12	8	22	55	10	0.3	1	0.21	95.4	6.68	1.2246
2015	12	8	23	5	10	0.3	1	0.22	94.3	6.68	1.3023
2015	12	8	23	15	10	0.3	1	0.24	83.7	6.6994	1.4039
2015	12	8	23	25	10	0.3	1	0.18	109.4	6.6994	0.9944
2015	12	8	23	35	10	0.3	1	0.22	96.7	6.6994	1.3259

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	23	45	10	0.3	1	0.27	102	6.6994	1.5598
2015	12	8	23	55	10	0.3	1	0.22	90	6.6994	1.2869
2015	12	9	0	5	10	0.3	1	0.23	91.7	6.6994	1.3454
2015	12	9	0	15	10	0.3	1	0.25	97.6	6.68	1.4578
2015	12	9	0	25	10	0.3	1	0.22	102.2	6.6994	1.2674
2015	12	9	0	35	10	0.3	1	0.21	106.2	6.6994	1.2089
2015	12	9	0	45	10	0.3	1	0.25	99.8	6.6994	1.4624
2015	12	9	0	55	10	0.3	1	0.2	107.5	6.6994	1.1114
2015	12	9	1	5	10	0.3	1	0.3	110	6.6994	1.6573
2015	12	9	1	15	10	0.3	1	0.19	97	6.6994	1.1114
2015	12	9	1	25	10	0.3	1	0.26	103.7	6.6994	1.5209
2015	12	9	1	35	10	0.3	1	0.3	106.6	6.6994	1.6963
2015	12	9	1	45	10	0.3	1	0.22	96	6.6994	1.3064
2015	12	9	1	55	10	0.3	1	0.23	111.5	6.6994	1.2869
2015	12	9	2	5	10	0.3	1	0.24	102.9	6.6994	1.3649
2015	12	9	2	15	10	0.3	1	0.21	109.8	6.6994	1.1894
2015	12	9	2	25	10	0.3	1	0.22	93.5	6.6994	1.2869
2015	12	9	2	35	10	0.3	1	0.2	111.4	6.6994	1.0919
2015	12	9	2	45	10	0.3	1	0.25	104.6	6.6994	1.4234
2015	12	9	2	55	10	0.3	1	0.21	103.8	6.6994	1.1894
2015	12	9	3	5	10	0.3	1	0.23	94.8	6.6994	1.3844
2015	12	9	3	15	10	0.3	1	0.25	102.2	6.6994	1.4429
2015	12	9	3	25	10	0.3	1	0.26	113.3	6.6994	1.4039
2015	12	9	3	35	10	0.3	1	0.22	115.8	6.6994	1.1699
2015	12	9	3	45	10	0.3	1	0.26	115.9	6.6994	1.3649
2015	12	9	3	55	10	0.3	1	0.3	95	6.68	1.7688
2015	12	9	4	5	10	0.3	1	0.19	106.9	6.68	1.0885
2015	12	9	4	15	10	0.3	1	0.25	102.9	6.6994	1.4429
2015	12	9	4	25	10	0.3	1	0.21	115	6.68	1.1274
2015	12	9	4	35	10	0.3	1	0.19	107.5	6.68	1.0496
2015	12	9	4	45	10	0.3	1	0.2	98.4	6.68	1.1857
2015	12	9	4	55	10	0.3	1	0.28	111.4	6.68	1.5356
2015	12	9	5	5	10	0.3	1	0.22	96.7	6.68	1.3218
2015	12	9	5	15	10	0.3	1	0.25	106	6.68	1.419
2015	12	9	5	25	10	0.3	1	0.23	98.2	6.6994	1.3454
2015	12	9	5	35	10	0.3	1	0.26	115.6	6.68	1.3801
2015	12	9	5	45	10	0.3	1	0.17	104.3	6.68	0.9913
2015	12	9	5	55	10	0.3	1	0.27	100.6	6.68	1.555
2015	12	9	6	5	10	0.3	1	0.18	80.7	6.6994	1.0724
2015	12	9	6	15	10	0.3	1	0.27	108.9	6.68	1.5356
2015	12	9	6	25	10	0.3	1	0.24	110.4	6.68	1.3607
2015	12	9	6	35	10	0.3	1	0.24	110.4	6.68	1.3607
2015	12	9	6	45	10	0.3	1	0.19	105.7	6.6994	1.1114
2015	12	9	6	55	10	0.3	1	0.25	102.4	6.68	1.419
2015	12	9	7	5	10	0.3	1	0.26	101.6	6.68	1.5162
2015	12	9	7	15	10	0.3	1	0.17	99.1	6.68	0.9719

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	7	25	10	0.3	1	0.2	103.1	6.68	1.1663
2015	12	9	7	35	10	0.3	1	0.22	97.8	6.6994	1.2869
2015	12	9	7	45	10	0.3	1	0.22	96	6.6994	1.3064
2015	12	9	7	55	10	0.3	1	0.2	103.6	6.6994	1.1309
2015	12	9	8	5	10	0.3	1	0.21	93.5	6.6994	1.2674
2015	12	9	8	15	10	0.3	1	0.2	100.4	6.6994	1.1699
2015	12	9	8	25	10	0.3	1	0.23	112.6	6.6994	1.2674
2015	12	9	8	35	10	0.3	1	0.15	96.5	6.6994	0.8579
2015	12	9	8	45	10	0.3	1	0.22	101	6.68	1.3023
2015	12	9	8	55	10	0.3	1	0.25	114.6	6.6994	1.3649
2015	12	9	9	5	10	0.3	1	0.24	120.4	6.6994	1.2284
2015	12	9	9	15	10	0.3	1	0.16	112.2	6.68	0.8553
2015	12	9	9	25	10	0.3	1	0.23	104.2	6.6994	1.3064
2015	12	9	9	35	10	0.3	1	0.21	98.1	6.6994	1.2284
2015	12	9	9	45	10	0.3	1	0.16	87.6	6.6994	0.9359
2015	12	9	9	55	10	0.3	1	0.17	110.2	6.6994	0.9554
2015	12	9	10	5	10	0.3	1	0.26	107.7	6.6994	1.4624
2015	12	9	10	15	10	0.3	1	0.23	101.6	6.6994	1.3259
2015	12	9	10	25	10	0.3	1	0.23	111.8	6.6994	1.2674
2015	12	9	10	35	10	0.3	1	0.15	112.7	6.6994	0.8384
2015	12	9	10	45	10	0.3	1	0.18	97.4	6.6994	1.0529
2015	12	9	10	55	10	0.3	1	0.16	104	6.6994	0.9359
2015	12	9	11	5	10	0.3	1	0.13	126.9	6.6994	0.6239
2015	12	9	11	15	10	0.3	1	0.15	98.7	6.6994	0.8969
2015	12	9	11	25	10	0.3	1	0.19	72.2	6.6994	1.0919
2015	12	9	11	35	10	0.3	1	0.12	86.7	6.6994	0.6824
2015	12	9	11	45	10	0.3	1	0.1	90	6.6994	0.6044
2015	12	9	11	55	10	0.3	1	0.13	109.4	6.6994	0.7214
2015	12	9	12	5	10	0.3	1	0.22	95	6.6994	1.3259
2015	12	9	12	15	10	0.3	1	0.22	118.1	6.6994	1.1309
2015	12	9	12	25	10	0.3	1	0.2	99.3	6.6994	1.1894
2015	12	9	12	35	10	0.3	1	0.2	101.1	6.6994	1.1894
2015	12	9	12	45	10	0.3	1	0.21	94.5	6.6994	1.2478
2015	12	9	12	55	10	0.3	1	0.28	78.7	6.6994	1.6573
2015	12	9	13	5	10	0.3	1	0.22	102	6.6994	1.2868
2015	12	9	13	15	10	0.3	1	0.18	95.2	6.6994	1.0724
2015	12	9	13	25	10	0.3	1	0.21	101.8	6.6994	1.2088
2015	12	9	13	35	10	0.3	1	0.17	105.6	6.6994	0.9749
2015	12	9	13	45	10	0.3	1	0.19	96	6.6994	1.1113
2015	12	9	13	55	10	0.3	1	0.2	94.8	6.6994	1.1698
2015	12	9	14	5	10	0.3	1	0.17	91.1	6.6994	1.0139
2015	12	9	14	15	10	0.3	1	0.2	88.1	6.6994	1.1893
2015	12	9	14	25	10	0.3	1	0.22	85.7	6.6994	1.2868
2015	12	9	14	35	10	0.3	1	0.15	100.3	6.6994	0.8579
2015	12	9	14	45	10	0.3	1	0.21	117.3	6.6994	1.1308
2015	12	9	14	55	10	0.3	1	0.14	97	6.6994	0.7994

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	15	5	10	0.3	1	0.19	110.3	6.6994	1.0528
2015	12	9	15	15	10	0.3	1	0.18	96.3	6.6994	1.0528
2015	12	9	15	25	10	0.3	1	0.21	106.7	6.6994	1.1698
2015	12	9	15	35	10	0.3	1	0.2	121.1	6.6994	1.0333
2015	12	9	15	45	10	0.3	1	0.18	85.8	6.6994	1.0723
2015	12	9	15	55	10	0.3	1	0.24	111.2	6.6994	1.3063
2015	12	9	16	5	10	0.3	1	0.19	99.1	6.6994	1.0918
2015	12	9	16	15	10	0.3	1	0.24	120.8	6.6994	1.2088
2015	12	9	16	25	10	0.3	1	0.25	100.7	6.6994	1.4428
2015	12	9	16	35	10	0.3	1	0.28	116.3	6.6994	1.5013
2015	12	9	16	45	10	0.3	1	0.12	93	6.6994	0.7409
2015	12	9	16	55	10	0.3	1	0.09	49.4	6.6994	0.4094
2015	12	9	17	5	10	0.3	1	0.09	55.7	6.6994	0.4289
2015	12	9	17	15	10	0.3	1	0.33	112.8	6.6994	1.8132
2015	12	9	17	25	10	0.3	1	0.18	104.5	6.6994	1.0528
2015	12	9	17	35	10	0.3	1	0.17	99.1	6.6994	0.9748
2015	12	9	17	45	10	0.3	1	0.2	98.7	6.6994	1.1503
2015	12	9	17	55	10	0.3	1	0.15	90	6.6994	0.8969
2015	12	9	18	5	10	0.3	1	0.25	76.9	6.6994	1.4233
2015	12	9	18	15	10	0.3	1	0.17	91.1	6.6994	1.0138
2015	12	9	18	25	10	0.3	1	0.24	91.5	6.7187	1.4472
2015	12	9	18	35	10	0.3	1	0.22	111.2	6.7187	1.2126
2015	12	9	18	45	10	0.3	1	0.22	107.6	6.6994	1.2283
2015	12	9	18	55	10	0.3	1	0.15	98.8	6.6994	0.8774
2015	12	9	19	5	10	0.3	1	0.19	86.1	6.7187	1.1539
2015	12	9	19	15	10	0.3	1	0.29	114.2	6.7187	1.5646
2015	12	9	19	25	10	0.3	1	0.17	123.4	6.7187	0.8605
2015	12	9	19	35	10	0.3	1	0.2	105.2	6.7187	1.1539
2015	12	9	19	45	10	0.3	1	0.25	107	6.7187	1.4081
2015	12	9	19	55	10	0.3	1	0.26	115.9	6.7187	1.369
2015	12	9	20	5	10	0.3	1	0.23	104.6	6.7187	1.3495
2015	12	9	20	15	10	0.3	1	0.21	97.2	6.7187	1.2321
2015	12	9	20	25	10	0.3	1	0.16	103.2	6.7187	0.9192
2015	12	9	20	35	10	0.3	1	0.24	113.4	6.7187	1.3104
2015	12	9	20	45	10	0.3	1	0.19	88.1	6.7187	1.1539
2015	12	9	20	55	10	0.3	1	0.27	102.8	6.7187	1.545
2015	12	9	21	5	10	0.3	1	0.23	104.2	6.7187	1.3104
2015	12	9	21	15	10	0.3	1	0.25	99.8	6.7187	1.4668
2015	12	9	21	25	10	0.3	1	0.22	90.9	6.7187	1.3104
2015	12	9	21	35	10	0.3	1	0.26	89.3	6.7187	1.5646
2015	12	9	21	45	10	0.3	1	0.25	90	6.7187	1.4864
2015	12	9	21	55	10	0.3	1	0.13	110.7	6.7187	0.7236
2015	12	9	22	5	10	0.3	1	0.25	102.4	6.7187	1.4277
2015	12	9	22	15	10	0.3	1	0.31	100.5	6.7187	1.7993
2015	12	9	22	25	10	0.3	1	0.28	110.6	6.7187	1.5646
2015	12	9	22	35	10	0.3	1	0.24	102.7	6.7187	1.3886

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	22	45	10	0.3	1	0.24	98.8	6.7187	1.3886
2015	12	9	22	55	10	0.3	1	0.23	88.4	6.7187	1.3886
2015	12	9	23	5	10	0.3	1	0.25	123.7	6.7187	1.2322
2015	12	9	23	15	10	0.3	1	0.17	95.4	6.7187	1.0366
2015	12	9	23	25	10	0.3	1	0.24	94	6.7187	1.4082
2015	12	9	23	35	10	0.3	1	0.26	90	6.7187	1.5647
2015	12	9	23	45	10	0.3	1	0.21	88.2	6.7187	1.2517
2015	12	9	23	55	10	0.3	1	0.23	97.5	6.7187	1.33
2015	12	10	0	5	10	0.3	1	0.22	114.7	6.7187	1.1931
2015	12	10	0	15	10	0.3	1	0.23	85.2	6.7187	1.3886
2015	12	10	0	25	10	0.3	1	0.21	97	6.7187	1.2713
2015	12	10	0	35	10	0.3	1	0.19	116.1	6.7187	1.0366
2015	12	10	0	45	10	0.3	1	0.22	93.4	6.6994	1.3064
2015	12	10	0	55	10	0.3	1	0.24	105.2	6.7187	1.3691
2015	12	10	1	5	10	0.3	1	0.2	92.9	6.7187	1.1735
2015	12	10	1	15	10	0.3	1	0.18	94.2	6.6994	1.0724
2015	12	10	1	25	10	0.3	1	0.28	100	6.6994	1.6573
2015	12	10	1	35	10	0.3	1	0.27	87.9	6.7187	1.5842
2015	12	10	1	45	10	0.3	1	0.22	92.6	6.7187	1.2909
2015	12	10	1	55	10	0.3	1	0.23	96.5	6.7187	1.3691
2015	12	10	2	5	10	0.3	1	0.29	109.7	6.6994	1.6378
2015	12	10	2	15	10	0.3	1	0.24	100.2	6.6994	1.4039
2015	12	10	2	25	10	0.3	1	0.26	100.2	6.6994	1.5209
2015	12	10	2	35	10	0.3	1	0.2	99.3	6.6994	1.1894
2015	12	10	2	45	10	0.3	1	0.19	93.9	6.6994	1.1504
2015	12	10	2	55	10	0.3	1	0.23	105.6	6.6994	1.3259
2015	12	10	3	5	10	0.3	1	0.19	90	6.6994	1.1114
2015	12	10	3	15	10	0.3	1	0.26	90	6.6994	1.5404
2015	12	10	3	25	10	0.3	1	0.24	113.7	6.6994	1.2869
2015	12	10	3	35	10	0.3	1	0.24	103.7	6.6994	1.3649
2015	12	10	3	45	10	0.3	1	0.21	93.5	6.6994	1.2674
2015	12	10	3	55	10	0.3	1	0.26	104.6	6.6994	1.5014
2015	12	10	4	5	10	0.3	1	0.25	101.9	6.6994	1.4819
2015	12	10	4	15	10	0.3	1	0.24	92.4	6.6994	1.4234
2015	12	10	4	25	10	0.3	1	0.21	100.6	6.6994	1.2479
2015	12	10	4	35	10	0.3	1	0.2	102	6.6994	1.1894
2015	12	10	4	45	10	0.3	1	0.22	100.3	6.6994	1.2869
2015	12	10	4	55	10	0.3	1	0.27	105.6	6.6994	1.5404
2015	12	10	5	5	10	0.3	1	0.18	101.3	6.6994	1.0724
2015	12	10	5	15	10	0.3	1	0.26	103.3	6.6994	1.4819
2015	12	10	5	25	10	0.3	1	0.24	104	6.6994	1.4039
2015	12	10	5	35	10	0.3	1	0.26	103.3	6.6994	1.4819
2015	12	10	5	45	10	0.3	1	0.21	105.3	6.6994	1.2089
2015	12	10	5	55	10	0.3	1	0.28	101.4	6.7187	1.6429
2015	12	10	6	5	10	0.3	1	0.19	116.1	6.6994	1.0334
2015	12	10	6	15	10	0.3	1	0.26	96.5	6.6994	1.5404

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	6	25	10	0.3	1	0.2	102	6.7187	1.1931
2015	12	10	6	35	10	0.3	1	0.23	100.8	6.7187	1.33
2015	12	10	6	45	10	0.3	1	0.28	110.8	6.6994	1.5404
2015	12	10	6	55	10	0.3	1	0.26	92.9	6.6994	1.5209
2015	12	10	7	5	10	0.3	1	0.21	99.2	6.6994	1.2089
2015	12	10	7	15	10	0.3	1	0.24	114.1	6.6994	1.3064
2015	12	10	7	25	10	0.3	1	0.25	103.1	6.68	1.419
2015	12	10	7	35	10	0.3	1	0.27	102.8	6.68	1.5356
2015	12	10	7	45	10	0.3	1	0.25	96.1	6.6994	1.4624
2015	12	10	7	55	10	0.3	1	0.2	97.6	6.6994	1.1699
2015	12	10	8	5	10	0.3	1	0.25	93.8	6.6994	1.4624
2015	12	10	8	15	10	0.3	1	0.27	103.5	6.6994	1.5404
2015	12	10	8	25	10	0.3	1	0.27	105.6	6.6994	1.5404
2015	12	10	8	35	10	0.3	1	0.24	91.6	6.6994	1.4039
2015	12	10	8	45	10	0.3	1	0.23	93.2	6.7187	1.3887
2015	12	10	8	55	10	0.3	1	0.2	93.7	6.6994	1.2089
2015	12	10	9	5	10	0.3	1	0.22	95.2	6.6994	1.2869
2015	12	10	9	15	10	0.3	1	0.28	88	6.6994	1.6378
2015	12	10	9	25	10	0.3	1	0.25	100.4	6.6994	1.4818
2015	12	10	9	35	10	0.3	1	0.25	91.5	6.6994	1.4623
2015	12	10	9	45	10	0.3	1	0.21	107.9	6.7187	1.2126
2015	12	10	9	55	10	0.3	1	0.21	93.6	6.6994	1.2479
2015	12	10	10	5	10	0.3	1	0.19	86	6.7187	1.1148
2015	12	10	10	15	10	0.3	1	0.26	93.6	6.6994	1.5403
2015	12	10	10	25	10	0.3	1	0.26	101.6	6.6994	1.5208
2015	12	10	10	35	10	0.3	1	0.33	87.7	6.6994	1.9303
2015	12	10	10	45	10	0.3	1	0.21	98.9	6.6994	1.2479
2015	12	10	10	55	10	0.3	1	0.22	99.3	6.6994	1.3063
2015	12	10	11	5	10	0.3	1	0.26	84.1	6.6994	1.5208
2015	12	10	11	15	10	0.3	1	0.23	84.4	6.6994	1.3843
2015	12	10	11	25	10	0.3	1	0.24	105	6.6994	1.3843
2015	12	10	11	35	10	0.3	1	0.18	96.2	6.6994	1.0724
2015	12	10	11	45	10	0.3	1	0.24	105.2	6.6994	1.3648
2015	12	10	11	55	10	0.3	1	0.24	105.2	6.6994	1.3648
2015	12	10	12	5	10	0.3	1	0.21	90.9	6.6994	1.2673
2015	12	10	12	15	10	0.3	1	0.18	90	6.6994	1.0529
2015	12	10	12	25	10	0.3	1	0.23	92.5	6.6994	1.3648
2015	12	10	12	35	10	0.3	1	0.22	88.3	6.6994	1.3063
2015	12	10	12	45	10	0.3	1	0.23	104.6	6.6994	1.3453
2015	12	10	12	55	10	0.3	1	0.3	95.7	6.6994	1.7548
2015	12	10	13	5	10	0.3	1	0.17	69	6.6994	0.9164
2015	12	10	13	15	10	0.3	1	0.22	91.7	6.6994	1.2868
2015	12	10	13	25	10	0.3	1	0.23	82.6	6.6994	1.3453
2015	12	10	13	35	10	0.3	1	0.23	92.5	6.6994	1.3648
2015	12	10	13	45	10	0.3	1	0.24	79.6	6.6994	1.3843
2015	12	10	13	55	10	0.3	1	0.26	68.9	6.6994	1.4623

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	14	5	10	0.3	1	0.26	92.1	6.6994	1.5598
2015	12	10	14	15	10	0.3	1	0.24	94.7	6.6994	1.4233
2015	12	10	14	25	10	0.3	1	0.24	83.1	6.6994	1.4428
2015	12	10	14	35	10	0.3	1	0.23	77.4	6.6994	1.3063
2015	12	10	14	45	10	0.3	1	0.25	96.7	6.6994	1.5013
2015	12	10	14	55	10	0.3	1	0.22	74.5	6.6994	1.2673
2015	12	10	15	5	10	0.3	1	0.21	104.3	6.6994	1.2283
2015	12	10	15	15	10	0.3	1	0.27	84.4	6.7187	1.6037
2015	12	10	15	25	10	0.3	1	0.26	79	6.7187	1.5059
2015	12	10	15	35	10	0.3	1	0.23	88.4	6.6994	1.3843
2015	12	10	15	45	10	0.3	1	0.26	79.8	6.7187	1.5255
2015	12	10	15	55	10	0.3	1	0.2	86.2	6.7187	1.193
2015	12	10	16	5	10	0.3	1	0.26	73.7	6.7187	1.4668
2015	12	10	16	15	10	0.3	1	0.22	80.7	6.7187	1.3104
2015	12	10	16	25	10	0.3	1	0.22	85.7	6.7187	1.2908
2015	12	10	16	35	10	0.3	1	0.19	94.9	6.7187	1.1343
2015	12	10	16	45	10	0.3	1	0.17	84.4	6.7187	0.9974
2015	12	10	16	55	10	0.3	1	0.21	90.9	6.7187	1.2712
2015	12	10	17	5	10	0.3	1	0.24	95.4	6.7187	1.4473
2015	12	10	17	15	10	0.3	1	0.27	90	6.7187	1.5842
2015	12	10	17	25	10	0.3	1	0.23	96.5	6.7187	1.369
2015	12	10	17	35	10	0.3	1	0.2	77.6	6.6994	1.1503
2015	12	10	17	45	10	0.3	1	0.25	91.5	6.6994	1.5013
2015	12	10	17	55	10	0.3	1	0.28	74.8	6.6994	1.5793
2015	12	10	18	5	10	0.3	1	0.3	85.6	6.6994	1.7937
2015	12	10	18	15	10	0.3	1	0.22	93.4	6.7187	1.3299
2015	12	10	18	25	10	0.3	1	0.32	75.5	6.7187	1.8188
2015	12	10	18	35	10	0.3	1	0.29	78.9	6.7187	1.7015
2015	12	10	18	45	10	0.3	1	0.22	96.8	6.7187	1.3104
2015	12	10	18	55	10	0.3	1	0.25	78.5	6.7187	1.4473
2015	12	10	19	5	10	0.3	1	0.3	74.7	6.7187	1.7211
2015	12	10	19	15	10	0.3	1	0.2	84.5	6.7187	1.2126
2015	12	10	19	25	10	0.3	1	0.22	85.7	6.7187	1.2908
2015	12	10	19	35	10	0.3	1	0.28	82.1	6.7187	1.6819
2015	12	10	19	45	10	0.3	1	0.24	93.1	6.7187	1.4473
2015	12	10	19	55	10	0.3	1	0.24	93.9	6.7187	1.4473
2015	12	10	20	5	10	0.3	1	0.22	86.6	6.7187	1.3104
2015	12	10	20	15	10	0.3	1	0.29	78.3	6.7187	1.7015
2015	12	10	20	25	10	0.3	1	0.29	84.8	6.7187	1.7211
2015	12	10	20	35	10	0.3	1	0.17	96.8	6.7381	0.9809
2015	12	10	20	45	10	0.3	1	0.23	85.9	6.7187	1.3495
2015	12	10	20	55	10	0.3	1	0.3	85.6	6.7187	1.7993
2015	12	10	21	5	10	0.3	1	0.22	90	6.7187	1.3104
2015	12	10	21	15	10	0.3	1	0.26	90	6.7187	1.5255
2015	12	10	21	25	10	0.3	1	0.27	90.7	6.7187	1.6233
2015	12	10	21	35	10	0.3	1	0.26	95.1	6.7187	1.5451

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	21	45	10	0.3	1	0.25	90.8	6.7187	1.4668
2015	12	10	21	55	10	0.3	1	0.26	81.3	6.7187	1.5255
2015	12	10	22	5	10	0.3	1	0.26	82.2	6.7187	1.5646
2015	12	10	22	15	10	0.3	1	0.18	104.5	6.7187	1.0561
2015	12	10	22	25	10	0.3	1	0.21	108.7	6.7187	1.2126
2015	12	10	22	35	10	0.3	1	0.21	100.6	6.7187	1.2517
2015	12	10	22	45	10	0.3	1	0.2	86.2	6.7187	1.1735
2015	12	10	22	55	10	0.3	1	0.16	85.4	6.7187	0.9779
2015	12	10	23	5	10	0.3	1	0.24	85.2	6.7187	1.4082
2015	12	10	23	15	10	0.3	1	0.22	114.7	6.7187	1.193
2015	12	10	23	25	10	0.3	1	0.24	90	6.7187	1.4277
2015	12	10	23	35	10	0.3	1	0.24	95.6	6.7187	1.4082
2015	12	10	23	45	10	0.3	1	0.19	83.2	6.7187	1.1539
2015	12	10	23	55	10	0.3	1	0.26	82.9	6.7187	1.5646
2015	12	11	0	5	10	0.3	1	0.23	87.6	6.7187	1.3886
2015	12	11	0	15	10	0.3	1	0.25	90	6.7187	1.4668
2015	12	11	0	25	10	0.3	1	0.21	81.9	6.7187	1.2321
2015	12	11	0	35	10	0.3	1	0.19	82.1	6.7187	1.1344
2015	12	11	0	45	10	0.3	1	0.3	82.6	6.7187	1.7993
2015	12	11	0	55	10	0.3	1	0.25	99.2	6.7187	1.4473
2015	12	11	1	5	10	0.3	1	0.23	90	6.7187	1.3886
2015	12	11	1	15	10	0.3	1	0.24	85.3	6.7187	1.4277
2015	12	11	1	25	10	0.3	1	0.23	82.7	6.7187	1.3691
2015	12	11	1	35	10	0.3	1	0.2	93.8	6.7187	1.193
2015	12	11	1	45	10	0.3	1	0.27	87.2	6.7187	1.6038
2015	12	11	1	55	10	0.3	1	0.22	97.7	6.7187	1.3104
2015	12	11	2	5	10	0.3	1	0.18	97.4	6.7187	1.0561
2015	12	11	2	15	10	0.3	1	0.24	93.9	6.7187	1.4277
2015	12	11	2	25	10	0.3	1	0.24	99.6	6.7187	1.3886
2015	12	11	2	35	10	0.3	1	0.23	90	6.7187	1.3886
2015	12	11	2	45	10	0.3	1	0.16	98.1	6.6994	0.9554
2015	12	11	2	55	10	0.3	1	0.22	95.1	6.7187	1.3104
2015	12	11	3	5	10	0.3	1	0.19	84.1	6.7187	1.1344
2015	12	11	3	15	10	0.3	1	0.28	101.4	6.6994	1.6378
2015	12	11	3	25	10	0.3	1	0.28	93.3	6.7187	1.682
2015	12	11	3	35	10	0.3	1	0.25	93.8	6.7187	1.4669
2015	12	11	3	45	10	0.3	1	0.21	90	6.7187	1.2322
2015	12	11	3	55	10	0.3	1	0.23	99.2	6.6994	1.3258
2015	12	11	4	5	10	0.3	1	0.14	98.1	6.7187	0.8214
2015	12	11	4	15	10	0.3	1	0.28	100	6.7187	1.6624
2015	12	11	4	25	10	0.3	1	0.22	77.8	6.7187	1.2713
2015	12	11	4	35	10	0.3	1	0.25	101.5	6.7187	1.4473
2015	12	11	4	45	10	0.3	1	0.32	96.4	6.7187	1.9167
2015	12	11	4	55	10	0.3	1	0.2	96.5	6.6994	1.1894
2015	12	11	5	5	10	0.3	1	0.25	112.2	6.6994	1.3843
2015	12	11	5	15	10	0.3	1	0.2	94.7	6.6994	1.1894

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	5	25	10	0.3	1	0.21	98	6.6994	1.2479
2015	12	11	5	35	10	0.3	1	0.19	96.8	6.6994	1.1504
2015	12	11	5	45	10	0.3	1	0.16	90	6.6994	0.9359
2015	12	11	5	55	10	0.3	1	0.19	88.1	6.6994	1.1504
2015	12	11	6	5	10	0.3	1	0.2	95.7	6.6994	1.1699
2015	12	11	6	15	10	0.3	1	0.18	90	6.6994	1.0919
2015	12	11	6	25	10	0.3	1	0.23	109.2	6.6994	1.2869
2015	12	11	6	35	10	0.3	1	0.28	88	6.6994	1.6768
2015	12	11	6	45	10	0.3	1	0.23	102.6	6.6994	1.3064
2015	12	11	6	55	10	0.3	1	0.3	96.3	6.6994	1.7548
2015	12	11	7	5	10	0.3	1	0.15	90	6.6994	0.9164
2015	12	11	7	15	10	0.3	1	0.3	104.8	6.6994	1.6963
2015	12	11	7	25	10	0.3	1	0.25	110.8	6.6994	1.3843
2015	12	11	7	35	10	0.3	1	0.23	99.9	6.6994	1.3454
2015	12	11	7	45	10	0.3	1	0.17	109.8	6.6994	0.9749
2015	12	11	7	55	10	0.3	1	0.19	103.3	6.6994	1.0724
2015	12	11	8	5	10	0.3	1	0.26	100.2	6.6994	1.5208
2015	12	11	8	15	10	0.3	1	0.22	106.3	6.6994	1.2674
2015	12	11	8	25	10	0.3	1	0.2	103.1	6.6994	1.1699
2015	12	11	8	35	10	0.3	1	0.15	96.3	6.6994	0.8774
2015	12	11	8	45	10	0.3	1	0.2	99.3	6.6994	1.1894
2015	12	11	8	55	10	0.3	1	0.18	113.7	6.6994	0.9749
2015	12	11	9	5	10	0.3	1	0.23	95.6	6.6994	1.3843
2015	12	11	9	15	10	0.3	1	0.18	112	6.6994	1.0139
2015	12	11	9	25	10	0.3	1	0.16	122.7	6.6994	0.8189
2015	12	11	9	35	10	0.3	1	0.14	116	6.6994	0.7604
2015	12	11	9	45	10	0.3	1	0.2	98.4	6.6994	1.1894
2015	12	11	9	55	10	0.3	1	0.19	91.9	6.6994	1.1504
2015	12	11	10	5	10	0.3	1	0.25	86.9	6.6994	1.4623
2015	12	11	10	15	10	0.3	1	0.2	104.5	6.6994	1.1309
2015	12	11	10	25	10	0.3	1	0.23	116.6	6.6994	1.2089
2015	12	11	10	35	10	0.3	1	0.21	113.4	6.6994	1.1699
2015	12	11	10	45	10	0.3	1	0.19	112.5	6.6994	1.0334
2015	12	11	10	55	10	0.3	1	0.19	89	6.6994	1.1309
2015	12	11	11	5	10	0.3	1	0.17	98.7	6.6994	1.0139
2015	12	11	11	15	10	0.3	1	0.22	96.7	6.6994	1.3258
2015	12	11	11	25	10	0.3	1	0.2	75.5	6.6994	1.1308
2015	12	11	11	35	10	0.3	1	0.19	94.8	6.6994	1.1503
2015	12	11	11	45	10	0.3	1	0.21	91.8	6.6994	1.2283
2015	12	11	11	55	10	0.3	1	0.25	93.8	6.6994	1.4818
2015	12	11	12	5	10	0.3	1	0.29	113.7	6.6994	1.5988
2015	12	11	12	15	10	0.3	1	0.15	101.6	6.6994	0.8579
2015	12	11	12	25	10	0.3	1	0.14	105.4	6.6994	0.7799
2015	12	11	12	35	10	0.3	1	0.21	105.1	6.6994	1.2283
2015	12	11	12	45	10	0.3	1	0.16	125	6.6994	0.7799
2015	12	11	12	55	10	0.3	1	0.24	94.7	6.6994	1.4233

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	13	5	10	0.3	1	0.22	94.2	6.6994	1.3258
2015	12	11	13	15	10	0.3	1	0.2	116.6	6.6994	1.0528
2015	12	11	13	25	10	0.3	1	0.24	87.6	6.6607	1.4144
2015	12	11	13	35	10	0.3	1	0.22	90.9	6.68	1.3022
2015	12	11	13	45	10	0.3	1	0.2	90	6.68	1.1856
2015	12	11	13	55	10	0.3	1	0.3	90.6	6.68	1.7493
2015	12	11	14	5	10	0.3	1	0.19	96.8	6.68	1.1467
2015	12	11	14	15	10	0.3	1	0.22	94.3	6.68	1.3022
2015	12	11	14	25	10	0.3	1	0.25	106.6	6.68	1.4383
2015	12	11	14	35	10	0.3	1	0.16	68.6	6.68	0.8941
2015	12	11	14	45	10	0.3	1	0.27	87.2	6.68	1.5938
2015	12	11	14	55	10	0.3	1	0.19	78.3	6.68	1.1273
2015	12	11	15	5	10	0.3	1	0.15	83.7	6.68	0.8746
2015	12	11	15	15	10	0.3	1	0.23	82.6	6.68	1.3411
2015	12	11	15	25	10	0.3	1	0.28	82.6	6.68	1.6521
2015	12	11	15	35	10	0.3	1	0.23	82.8	6.68	1.38
2015	12	11	15	45	10	0.3	1	0.2	81.5	6.68	1.1662
2015	12	11	15	55	10	0.3	1	0.23	69.7	6.6607	1.2594
2015	12	11	16	5	10	0.3	1	0.24	74.3	6.68	1.38
2015	12	11	16	15	10	0.3	1	0.24	90	6.68	1.4383
2015	12	11	16	25	10	0.3	1	0.22	77.2	6.68	1.2828
2015	12	11	16	35	10	0.3	1	0.26	54.9	6.6607	1.2401
2015	12	11	16	45	10	0.3	1	0.19	72.5	6.68	1.0496
2015	12	11	16	55	10	0.3	1	0.21	55.6	6.68	1.0496
2015	12	11	17	5	10	0.3	1	0.23	90	6.6607	1.337
2015	12	11	17	15	10	0.3	1	0.23	72.1	6.68	1.3217
2015	12	11	17	25	10	0.3	1	0.18	74.2	6.6607	1.0269
2015	12	11	17	35	10	0.3	1	0.15	64	6.68	0.7969
2015	12	11	17	45	10	0.3	1	0.28	86.6	6.68	1.6327
2015	12	11	17	55	10	0.3	1	0.24	90	6.68	1.3994
2015	12	11	18	5	10	0.3	1	0.21	92.7	6.6607	1.2207
2015	12	11	18	15	10	0.3	1	0.21	82.8	6.68	1.2245
2015	12	11	18	25	10	0.3	1	0.17	105.9	6.6607	0.9494
2015	12	11	18	35	10	0.3	1	0.17	95.5	6.68	1.0107
2015	12	11	18	45	10	0.3	1	0.15	101.3	6.68	0.8747
2015	12	11	18	55	10	0.3	1	0.08	124.4	6.68	0.3693
2015	12	11	19	5	10	0.3	1	0.22	139.8	6.68	0.8552
2015	12	11	19	15	10	0.3	1	0.21	123.7	6.68	1.0496
2015	12	11	19	25	10	0.3	1	0.24	142.7	6.68	0.8747
2015	12	11	19	35	10	0.3	1	0.19	158.2	6.68	0.4276
2015	12	11	19	45	10	0.3	1	0.13	140.2	6.68	0.4859
2015	12	11	19	55	10	0.3	1	0.23	145.4	6.68	0.7775
2015	12	11	20	5	10	0.3	1	0.1	148.4	6.68	0.311
2015	12	11	20	15	10	0.3	1	0.13	131.1	6.68	0.6025
2015	12	11	20	25	10	0.3	1	0.12	104	6.68	0.6997
2015	12	11	20	35	10	0.3	1	0.1	124.2	6.68	0.4859

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	20	45	10	0.3	1	0.24	111.9	6.68	1.3023
2015	12	11	20	55	10	0.3	1	0.21	90.9	6.68	1.2245
2015	12	11	21	5	10	0.3	1	0.19	94.9	6.6607	1.1239
2015	12	11	21	15	10	0.3	1	0.1	102.7	6.6607	0.6007
2015	12	11	21	25	10	0.3	1	0.21	101.8	6.6607	1.2014
2015	12	11	21	35	10	0.3	1	0.17	109.5	6.6607	0.9301
2015	12	11	21	45	10	0.3	1	0.18	116.1	6.6607	0.9495
2015	12	11	21	55	10	0.3	1	0.15	111.1	6.6607	0.8526
2015	12	11	22	5	10	0.3	1	0.21	97.4	6.6607	1.2014
2015	12	11	22	15	10	0.3	1	0.27	108	6.6607	1.492
2015	12	11	22	25	10	0.3	1	0.17	95.6	6.6607	0.9882
2015	12	11	22	35	10	0.3	1	0.15	107.7	6.6607	0.8526
2015	12	11	22	45	10	0.3	1	0.21	106.2	6.6607	1.2014
2015	12	11	22	55	10	0.3	1	0.16	106.3	6.6607	0.9301
2015	12	11	23	5	10	0.3	1	0.19	96	6.6607	1.1045
2015	12	11	23	15	10	0.3	1	0.26	105.6	6.6607	1.4533
2015	12	11	23	25	10	0.3	1	0.28	95.4	6.6607	1.6277
2015	12	11	23	35	10	0.3	1	0.2	101.5	6.6607	1.1433
2015	12	11	23	45	10	0.3	1	0.23	105	6.6607	1.2983
2015	12	11	23	55	10	0.3	1	0.22	114.7	6.6607	1.182
2015	12	12	0	5	10	0.3	1	0.14	94.1	6.6607	0.8138
2015	12	12	0	15	10	0.3	1	0.19	90	6.6607	1.1433
2015	12	12	0	25	10	0.3	1	0.2	90	6.6607	1.182
2015	12	12	0	35	10	0.3	1	0.19	95.9	6.6607	1.1239
2015	12	12	0	45	10	0.3	1	0.17	100.2	6.6607	0.9689
2015	12	12	0	55	10	0.3	1	0.17	96.5	6.6607	1.027
2015	12	12	1	5	10	0.3	1	0.21	106.7	6.6607	1.1627
2015	12	12	1	15	10	0.3	1	0.24	107.4	6.6607	1.3564
2015	12	12	1	25	10	0.3	1	0.25	104.6	6.6607	1.4146
2015	12	12	1	35	10	0.3	1	0.27	104	6.6413	1.5454
2015	12	12	1	45	10	0.3	1	0.23	99.7	6.6607	1.3564
2015	12	12	1	55	10	0.3	1	0.17	86.8	6.6413	1.0238
2015	12	12	2	5	10	0.3	1	0.15	110.4	6.6413	0.8306
2015	12	12	2	15	10	0.3	1	0.22	88.3	6.6413	1.2943
2015	12	12	2	25	10	0.3	1	0.23	90.8	6.6413	1.3329
2015	12	12	2	35	10	0.3	1	0.23	93.3	6.6413	1.3329
2015	12	12	2	45	10	0.3	1	0.21	91.8	6.6413	1.2556
2015	12	12	2	55	10	0.3	1	0.18	99.5	6.6413	1.0431
2015	12	12	3	5	10	0.3	1	0.24	114.8	6.6413	1.2943
2015	12	12	3	15	10	0.3	1	0.24	104.4	6.6413	1.3522
2015	12	12	3	25	10	0.3	1	0.26	99.6	6.6413	1.4874
2015	12	12	3	35	10	0.3	1	0.24	85.3	6.6413	1.4102
2015	12	12	3	45	10	0.3	1	0.19	97.1	6.6413	1.0818
2015	12	12	3	55	10	0.3	1	0.18	99.6	6.6413	1.0238
2015	12	12	4	5	10	0.3	1	0.22	97.9	6.6413	1.2556
2015	12	12	4	15	10	0.3	1	0.23	93.3	6.6413	1.3329

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	4	25	10	0.3	1	0.17	100.9	6.6413	1.0045
2015	12	12	4	35	10	0.3	1	0.27	92.8	6.6413	1.584
2015	12	12	4	45	10	0.3	1	0.24	68.6	6.6413	1.3329
2015	12	12	4	55	10	0.3	1	0.16	90	6.6413	0.9272
2015	12	12	5	5	10	0.3	1	0.27	98.3	6.6413	1.584
2015	12	12	5	15	10	0.3	1	0.23	100.7	6.6413	1.3329
2015	12	12	5	25	10	0.3	1	0.22	78.7	6.6413	1.2557
2015	12	12	5	35	10	0.3	1	0.27	95.6	6.6413	1.5647
2015	12	12	5	45	10	0.3	1	0.25	86.2	6.6413	1.4488
2015	12	12	5	55	10	0.3	1	0.27	94.9	6.6413	1.5841
2015	12	12	6	5	10	0.3	1	0.26	97.1	6.6413	1.5454
2015	12	12	6	15	10	0.3	1	0.22	84.8	6.6413	1.275
2015	12	12	6	25	10	0.3	1	0.15	87.6	6.6413	0.9079
2015	12	12	6	35	10	0.3	1	0.17	102.4	6.6413	0.9659
2015	12	12	6	45	10	0.3	1	0.24	103.5	6.6413	1.3716
2015	12	12	6	55	10	0.3	1	0.17	98.9	6.6413	0.9852
2015	12	12	7	5	10	0.3	1	0.21	101.5	6.6413	1.2363
2015	12	12	7	15	10	0.3	1	0.19	93.9	6.6413	1.1398
2015	12	12	7	25	10	0.3	1	0.25	110.1	6.6413	1.3716
2015	12	12	7	35	10	0.3	1	0.15	101.3	6.6413	0.8693
2015	12	12	7	45	10	0.3	1	0.21	119.7	6.6413	1.0818
2015	12	12	7	55	10	0.3	1	0.19	100	6.6413	1.1011
2015	12	12	8	5	10	0.3	1	0.2	117.4	6.6413	1.0432
2015	12	12	8	15	10	0.3	1	0.2	82.5	6.6413	1.1784
2015	12	12	8	25	10	0.3	1	0.21	111.8	6.6413	1.1591
2015	12	12	8	35	10	0.3	1	0.16	115	6.6413	0.8693
2015	12	12	8	45	10	0.3	1	0.18	90	6.6413	1.0432
2015	12	12	8	55	10	0.3	1	0.14	92.6	6.6413	0.85
2015	12	12	9	5	10	0.3	1	0.21	106.2	6.6413	1.1977
2015	12	12	9	15	10	0.3	1	0.19	110.3	6.6413	1.0432
2015	12	12	9	25	10	0.3	1	0.2	106.6	6.6219	1.0977
2015	12	12	9	35	10	0.3	1	0.24	94	6.6219	1.3865
2015	12	12	9	45	10	0.3	1	0.15	105.3	6.6219	0.8473
2015	12	12	9	55	10	0.3	1	0.21	90	6.6219	1.2517
2015	12	12	10	5	10	0.3	1	0.18	85.9	6.6219	1.0784
2015	12	12	10	15	10	0.3	1	0.24	97	6.6219	1.4058
2015	12	12	10	25	10	0.3	1	0.26	101.6	6.6413	1.5068
2015	12	12	10	35	10	0.3	1	0.17	96.6	6.6219	1.0014
2015	12	12	10	45	10	0.3	1	0.16	98.1	6.6219	0.9436
2015	12	12	10	55	10	0.3	1	0.16	100.6	6.6219	0.9243
2015	12	12	11	5	10	0.3	1	0.17	95.5	6.6219	1.0014
2015	12	12	11	15	10	0.3	1	0.18	106.8	6.6413	1.0238
2015	12	12	11	25	10	0.3	1	0.25	102.4	6.6413	1.4102
2015	12	12	11	35	10	0.3	1	0.26	92.9	6.6413	1.5068
2015	12	12	11	45	10	0.3	1	0.22	89.2	6.6413	1.3136
2015	12	12	11	55	10	0.3	1	0.2	110.2	6.6413	1.1011

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	12	5	10	0.3	1	0.22	105.3	6.6413	1.2749
2015	12	12	12	15	10	0.3	1	0.17	90	6.6413	1.0238
2015	12	12	12	25	10	0.3	1	0.13	102.7	6.6413	0.7727
2015	12	12	12	35	10	0.3	1	0.23	85.9	6.6413	1.3522
2015	12	12	12	45	10	0.3	1	0.24	100.9	6.6413	1.4101
2015	12	12	12	55	10	0.3	1	0.25	99.2	6.6413	1.4295
2015	12	12	13	5	10	0.3	1	0.2	115.3	6.6413	1.0624
2015	12	12	13	15	10	0.3	1	0.18	91	6.6413	1.0624
2015	12	12	13	25	10	0.3	1	0.16	90	6.6413	0.9658
2015	12	12	13	35	10	0.3	1	0.19	99	6.6413	1.1011
2015	12	12	13	45	10	0.3	1	0.23	104.8	6.6413	1.3135
2015	12	12	13	55	10	0.3	1	0.19	90	6.6413	1.1011
2015	12	12	14	5	10	0.3	1	0.22	95	6.6413	1.3135
2015	12	12	14	15	10	0.3	1	0.16	65	6.6413	0.8693
2015	12	12	14	25	10	0.3	1	0.11	84.6	6.6413	0.6181
2015	12	12	14	35	10	0.3	1	0.19	108.1	6.6413	1.0624
2015	12	12	14	45	10	0.3	1	0.19	105.7	6.6413	1.101
2015	12	12	14	55	10	0.3	1	0.18	109.1	6.6413	1.0045
2015	12	12	15	5	10	0.3	1	0.17	109.5	6.6413	0.9272
2015	12	12	15	15	10	0.3	1	0.16	83	6.6413	0.9465
2015	12	12	15	25	10	0.3	1	0.18	91	6.6413	1.0624
2015	12	12	15	35	10	0.3	1	0.12	104	6.6413	0.6954
2015	12	12	15	45	10	0.3	1	0.19	112.5	6.6413	1.0238
2015	12	12	15	55	10	0.3	1	0.15	113.7	6.6413	0.792
2015	12	12	16	5	10	0.3	1	0.16	115	6.6413	0.8693
2015	12	12	16	15	10	0.3	1	0.09	135	6.6413	0.367
2015	12	12	16	25	10	0.3	1	0.16	114.4	6.6413	0.8499
2015	12	12	16	35	10	0.3	1	0.28	130.2	6.6413	1.2556
2015	12	12	16	45	10	0.3	1	0.19	125.7	6.6413	0.8886
2015	12	12	16	55	10	0.3	1	0.15	101.3	6.6413	0.8693
2015	12	12	17	5	10	0.3	1	0.17	128.7	6.6413	0.7727
2015	12	12	17	15	10	0.3	1	0.15	149	6.6413	0.4636
2015	12	12	17	25	10	0.3	1	0.14	135.9	6.6413	0.5795
2015	12	12	17	35	10	0.3	1	0.2	127.8	6.6413	0.9465
2015	12	12	17	45	10	0.3	1	0.27	131	6.6413	1.1783
2015	12	12	17	55	10	0.3	1	0.26	127.7	6.6413	1.1976
2015	12	12	18	5	10	0.3	1	0.23	123.2	6.6413	1.1204
2015	12	12	18	15	10	0.3	1	0.2	103.1	6.6413	1.159
2015	12	12	18	25	10	0.3	1	0.23	127.5	6.6413	1.0817
2015	12	12	18	35	10	0.3	1	0.2	88.1	6.6413	1.1783
2015	12	12	18	45	10	0.3	1	0.26	114.6	6.6413	1.3908
2015	12	12	18	55	10	0.3	1	0.19	129.4	6.6413	0.8692
2015	12	12	19	5	10	0.3	1	0.26	117.9	6.6413	1.3522
2015	12	12	19	15	10	0.3	1	0.28	121.3	6.6607	1.4339
2015	12	12	19	25	10	0.3	1	0.26	117.9	6.6413	1.3522
2015	12	12	19	35	10	0.3	1	0.24	107.7	6.6607	1.337

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	19	45	10	0.3	1	0.25	107.7	6.6607	1.3952
2015	12	12	19	55	10	0.3	1	0.21	95.3	6.6607	1.2595
2015	12	12	20	5	10	0.3	1	0.26	101	6.6607	1.492
2015	12	12	20	15	10	0.3	1	0.2	115.7	6.6607	1.0464
2015	12	12	20	25	10	0.3	1	0.22	117.7	6.6607	1.1433
2015	12	12	20	35	10	0.3	1	0.17	110.2	6.6607	0.9495
2015	12	12	20	45	10	0.3	1	0.21	121.4	6.6607	1.0464
2015	12	12	20	55	10	0.3	1	0.18	125.2	6.6607	0.8526
2015	12	12	21	5	10	0.3	1	0.23	111.3	6.6607	1.2401
2015	12	12	21	15	10	0.3	1	0.18	103.8	6.6607	1.027
2015	12	12	21	25	10	0.3	1	0.16	105.8	6.6607	0.8914
2015	12	12	21	35	10	0.3	1	0.24	102.9	6.6607	1.3564
2015	12	12	21	45	10	0.3	1	0.18	117	6.6607	0.9495
2015	12	12	21	55	10	0.3	1	0.17	114.6	6.6607	0.9301
2015	12	12	22	5	10	0.3	1	0.27	104.2	6.6607	1.5308
2015	12	12	22	15	10	0.3	1	0.22	96.7	6.6607	1.3177
2015	12	12	22	25	10	0.3	1	0.22	112	6.6607	1.2014
2015	12	12	22	35	10	0.3	1	0.23	110	6.6607	1.2789
2015	12	12	22	45	10	0.3	1	0.24	90	6.6607	1.3952
2015	12	12	22	55	10	0.3	1	0.33	111.5	6.6607	1.8215
2015	12	12	23	5	10	0.3	1	0.26	96.6	6.6607	1.5115
2015	12	12	23	15	10	0.3	1	0.23	100.5	6.6607	1.3564
2015	12	12	23	25	10	0.3	1	0.2	91	6.6607	1.1627
2015	12	12	23	35	10	0.3	1	0.2	96.4	6.6607	1.2014
2015	12	12	23	45	10	0.3	1	0.21	107.9	6.6607	1.2014
2015	12	12	23	55	10	0.3	1	0.27	94.8	6.6607	1.6084
2015	12	13	0	5	10	0.3	1	0.18	91	6.6607	1.0852
2015	12	13	0	15	10	0.3	1	0.21	109.8	6.6607	1.1821
2015	12	13	0	25	10	0.3	1	0.24	93.9	6.6607	1.434
2015	12	13	0	35	10	0.3	1	0.22	97.9	6.6607	1.2596
2015	12	13	0	45	10	0.3	1	0.29	92.6	6.6607	1.7053
2015	12	13	0	55	10	0.3	1	0.18	109.1	6.6607	1.0077
2015	12	13	1	5	10	0.3	1	0.25	102.9	6.6607	1.434
2015	12	13	1	15	10	0.3	1	0.15	93.8	6.6607	0.872
2015	12	13	1	25	10	0.3	1	0.16	107.7	6.6607	0.9108
2015	12	13	1	35	10	0.3	1	0.22	108.4	6.6607	1.2208
2015	12	13	1	45	10	0.3	1	0.23	100.5	6.6607	1.3565
2015	12	13	1	55	10	0.3	1	0.21	95.4	6.6607	1.2208
2015	12	13	2	5	10	0.3	1	0.28	103.7	6.6607	1.589
2015	12	13	2	15	10	0.3	1	0.27	94.9	6.6607	1.589
2015	12	13	2	25	10	0.3	1	0.17	90	6.6413	1.0238
2015	12	13	2	35	10	0.3	1	0.21	113.4	6.6413	1.1591
2015	12	13	2	45	10	0.3	1	0.24	92.4	6.6413	1.4102
2015	12	13	2	55	10	0.3	1	0.2	101.5	6.6413	1.1398
2015	12	13	3	5	10	0.3	1	0.21	100.6	6.6413	1.2363
2015	12	13	3	15	10	0.3	1	0.22	95.2	6.6413	1.275

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	3	25	10	0.3	1	0.18	92	6.6413	1.0818
2015	12	13	3	35	10	0.3	1	0.18	100.5	6.6413	1.0432
2015	12	13	3	45	10	0.3	1	0.21	90	6.6413	1.2363
2015	12	13	3	55	10	0.3	1	0.2	95.6	6.6413	1.1784
2015	12	13	4	5	10	0.3	1	0.23	100	6.6413	1.3136
2015	12	13	4	15	10	0.3	1	0.25	113.5	6.6413	1.3329
2015	12	13	4	25	10	0.3	1	0.22	90.9	6.6413	1.275
2015	12	13	4	35	10	0.3	1	0.25	90.8	6.6413	1.4682
2015	12	13	4	45	10	0.3	1	0.19	91	6.6413	1.1204
2015	12	13	4	55	10	0.3	1	0.25	107	6.6413	1.3909
2015	12	13	5	5	10	0.3	1	0.29	95.1	6.6413	1.7193
2015	12	13	5	15	10	0.3	1	0.18	94.2	6.6413	1.0432
2015	12	13	5	25	10	0.3	1	0.25	102.8	6.6413	1.4489
2015	12	13	5	35	10	0.3	1	0.2	93.8	6.6413	1.1591
2015	12	13	5	45	10	0.3	1	0.27	104.5	6.6413	1.5648
2015	12	13	5	55	10	0.3	1	0.22	94.3	6.6413	1.2943
2015	12	13	6	5	10	0.3	1	0.22	99.5	6.6413	1.275
2015	12	13	6	15	10	0.3	1	0.24	91.6	6.6413	1.4102
2015	12	13	6	25	10	0.3	1	0.22	97.9	6.6413	1.2557
2015	12	13	6	35	10	0.3	1	0.24	102.5	6.6413	1.3909
2015	12	13	6	45	10	0.3	1	0.24	90	6.6413	1.3909
2015	12	13	6	55	10	0.3	1	0.22	95	6.6413	1.3136
2015	12	13	7	5	10	0.3	1	0.24	107.7	6.6413	1.333
2015	12	13	7	15	10	0.3	1	0.22	86.6	6.6413	1.3136
2015	12	13	7	25	10	0.3	1	0.23	93.3	6.6413	1.333
2015	12	13	7	35	10	0.3	1	0.27	110.9	6.6413	1.4682
2015	12	13	7	45	10	0.3	1	0.23	97.5	6.6413	1.3136
2015	12	13	7	55	10	0.3	1	0.22	87.4	6.6413	1.275
2015	12	13	8	5	10	0.3	1	0.25	110.8	6.6413	1.3716
2015	12	13	8	15	10	0.3	1	0.25	102.2	6.6413	1.4295
2015	12	13	8	25	10	0.3	1	0.21	99.9	6.6413	1.217
2015	12	13	8	35	10	0.3	1	0.22	103.2	6.6413	1.2364
2015	12	13	8	45	10	0.3	1	0.23	101.6	6.6413	1.3136
2015	12	13	8	55	10	0.3	1	0.19	97.9	6.6413	1.1205
2015	12	13	9	5	10	0.3	1	0.2	103.1	6.6413	1.1591
2015	12	13	9	15	10	0.3	1	0.17	103.8	6.6413	0.9466
2015	12	13	9	25	10	0.3	1	0.16	88.9	6.6413	0.9659
2015	12	13	9	35	10	0.3	1	0.19	107.2	6.6413	1.0625
2015	12	13	9	45	10	0.3	1	0.2	106.1	6.6219	1.1362
2015	12	13	9	55	10	0.3	1	0.26	108.4	6.6413	1.4489
2015	12	13	10	5	10	0.3	1	0.24	105	6.6413	1.3716
2015	12	13	10	15	10	0.3	1	0.2	96.4	6.6413	1.1977
2015	12	13	10	25	10	0.3	1	0.24	90	6.6413	1.3909
2015	12	13	10	35	10	0.3	1	0.23	105.4	6.6413	1.3329
2015	12	13	10	45	10	0.3	1	0.27	110	6.6413	1.4875
2015	12	13	10	55	10	0.3	1	0.25	98.2	6.6413	1.4681

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	11	5	10	0.3	1	0.23	115.1	6.6413	1.2363
2015	12	13	11	15	10	0.3	1	0.28	102.2	6.6413	1.6034
2015	12	13	11	25	10	0.3	1	0.17	81.3	6.6413	1.0045
2015	12	13	11	35	10	0.3	1	0.2	88.1	6.6413	1.1784
2015	12	13	11	45	10	0.3	1	0.17	90	6.6413	0.9852
2015	12	13	11	55	10	0.3	1	0.27	99.2	6.6413	1.5454
2015	12	13	12	5	10	0.3	1	0.18	105.1	6.6413	1.0045
2015	12	13	12	15	10	0.3	1	0.17	106.4	6.6413	0.9852
2015	12	13	12	25	10	0.3	1	0.26	108.4	6.6219	1.4443
2015	12	13	12	35	10	0.3	1	0.26	102.3	6.6413	1.5068
2015	12	13	12	45	10	0.3	1	0.2	101.5	6.6219	1.1362
2015	12	13	12	55	10	0.3	1	0.17	99.8	6.6413	1.0045
2015	12	13	13	5	10	0.3	1	0.23	100.7	6.6219	1.3287
2015	12	13	13	15	10	0.3	1	0.2	104.9	6.6219	1.1554
2015	12	13	13	25	10	0.3	1	0.27	97.7	6.6219	1.5598
2015	12	13	13	35	10	0.3	1	0.21	103.6	6.6219	1.1939
2015	12	13	13	45	10	0.3	1	0.19	96.8	6.6219	1.1362
2015	12	13	13	55	10	0.3	1	0.19	97	6.6219	1.0976
2015	12	13	14	5	10	0.3	1	0.18	101.7	6.6219	1.0206
2015	12	13	14	15	10	0.3	1	0.19	112.9	6.6219	1.0014
2015	12	13	14	25	10	0.3	1	0.23	86.8	6.6219	1.3672
2015	12	13	14	35	10	0.3	1	0.27	75.1	6.6219	1.5213
2015	12	13	14	45	10	0.3	1	0.23	83.6	6.6219	1.3672
2015	12	13	14	55	10	0.3	1	0.26	90	6.6219	1.5213
2015	12	13	15	5	10	0.3	1	0.16	85.4	6.6219	0.9628
2015	12	13	15	15	10	0.3	1	0.22	79.7	6.6219	1.2709
2015	12	13	15	25	10	0.3	1	0.25	66.5	6.6219	1.3287
2015	12	13	15	35	10	0.3	1	0.36	54.6	6.6219	1.7331
2015	12	13	15	45	10	0.3	1	0.2	77.8	6.6219	1.1554
2015	12	13	15	55	10	0.3	1	0.28	69.8	6.6219	1.5213
2015	12	13	16	5	10	0.3	1	0.26	77.7	6.6219	1.502
2015	12	13	16	15	10	0.3	1	0.24	72.8	6.6219	1.3672
2015	12	13	16	25	10	0.3	1	0.25	68.7	6.6219	1.3865
2015	12	13	16	35	10	0.3	1	0.32	65	6.6219	1.6946
2015	12	13	16	45	10	0.3	1	0.26	63.4	6.6219	1.3865
2015	12	13	16	55	10	0.3	1	0.27	66	6.6219	1.425
2015	12	13	17	5	10	0.3	1	0.29	79.5	6.6219	1.6561
2015	12	13	17	15	10	0.3	1	0.28	66.1	6.6219	1.5213
2015	12	13	17	25	10	0.3	1	0.22	79.8	6.6219	1.2902
2015	12	13	17	35	10	0.3	1	0.26	60.3	6.6219	1.348
2015	12	13	17	45	10	0.3	1	0.27	65.9	6.6219	1.4635
2015	12	13	17	55	10	0.3	1	0.26	69.3	6.6219	1.425
2015	12	13	18	5	10	0.3	1	0.28	57.4	6.6219	1.3865
2015	12	13	18	15	10	0.3	1	0.29	63.7	6.6219	1.5213
2015	12	13	18	25	10	0.3	1	0.35	61.8	6.6219	1.8294
2015	12	13	18	35	10	0.3	1	0.27	71.6	6.6219	1.502

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	18	45	10	0.3	1	0.26	71.1	6.6219	1.4635
2015	12	13	18	55	10	0.3	1	0.21	58.3	6.6219	1.0591
2015	12	13	19	5	10	0.3	1	0.22	67.2	6.6219	1.1939
2015	12	13	19	15	10	0.3	1	0.23	54.3	6.6219	1.0976
2015	12	13	19	25	10	0.3	1	0.23	90	6.6219	1.348
2015	12	13	19	35	10	0.3	1	0.28	84	6.6026	1.6509
2015	12	13	19	45	10	0.3	1	0.34	62.2	6.6219	1.7909
2015	12	13	19	55	10	0.3	1	0.26	66.7	6.6219	1.3865
2015	12	13	20	5	10	0.3	1	0.25	87.7	6.6219	1.4635
2015	12	13	20	15	10	0.3	1	0.23	79.5	6.6219	1.348
2015	12	13	20	25	10	0.3	1	0.24	77.1	6.6219	1.348
2015	12	13	20	35	10	0.3	1	0.24	71.8	6.6219	1.348
2015	12	13	20	45	10	0.3	1	0.28	64	6.6219	1.4635
2015	12	13	20	55	10	0.3	1	0.23	76.2	6.6219	1.3287
2015	12	13	21	5	10	0.3	1	0.27	80.9	6.6219	1.5598
2015	12	13	21	15	10	0.3	1	0.28	73.9	6.6219	1.5983
2015	12	13	21	25	10	0.3	1	0.3	82	6.6219	1.7716
2015	12	13	21	35	10	0.3	1	0.22	75.6	6.6413	1.2749
2015	12	13	21	45	10	0.3	1	0.23	93.3	6.6219	1.348
2015	12	13	21	55	10	0.3	1	0.26	79.8	6.6413	1.5067
2015	12	13	22	5	10	0.3	1	0.21	84.6	6.6219	1.2132
2015	12	13	22	15	10	0.3	1	0.19	59.9	6.6413	0.9659
2015	12	13	22	25	10	0.3	1	0.22	85	6.6219	1.3095
2015	12	13	22	35	10	0.3	1	0.17	81.1	6.6219	0.9821
2015	12	13	22	45	10	0.3	1	0.17	85.7	6.6413	1.0238
2015	12	13	22	55	10	0.3	1	0.23	90	6.6413	1.3522
2015	12	13	23	5	10	0.3	1	0.18	76	6.6413	1.0045
2015	12	13	23	15	10	0.3	1	0.21	77.1	6.6413	1.1784
2015	12	13	23	25	10	0.3	1	0.18	98.6	6.6413	1.0238
2015	12	13	23	35	10	0.3	1	0.24	90.8	6.6219	1.425
2015	12	13	23	45	10	0.3	1	0.18	76.2	6.6219	1.0206
2015	12	13	23	55	10	0.3	1	0.16	101.8	6.6219	0.9243
2015	12	14	0	5	10	0.3	1	0.2	85.4	6.6413	1.1977
2015	12	14	0	15	10	0.3	1	0.21	93.6	6.6413	1.2363
2015	12	14	0	25	10	0.3	1	0.2	97.6	6.6219	1.1554
2015	12	14	0	35	10	0.3	1	0.23	93.2	6.6219	1.3673
2015	12	14	0	45	10	0.3	1	0.18	91	6.6219	1.0591
2015	12	14	0	55	10	0.3	1	0.21	101	6.6219	1.1939
2015	12	14	1	5	10	0.3	1	0.25	101.9	6.6219	1.4635
2015	12	14	1	15	10	0.3	1	0.26	87.1	6.6219	1.5406
2015	12	14	1	25	10	0.3	1	0.22	107.1	6.6219	1.2517
2015	12	14	1	35	10	0.3	1	0.24	109.7	6.6219	1.348
2015	12	14	1	45	10	0.3	1	0.31	74.6	6.6219	1.7524
2015	12	14	1	55	10	0.3	1	0.21	90	6.6219	1.2517
2015	12	14	2	5	10	0.3	1	0.18	98.3	6.6219	1.0592
2015	12	14	2	15	10	0.3	1	0.22	100.5	6.6219	1.2517

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	2	25	10	0.3	1	0.13	92.8	6.6219	0.7896
2015	12	14	2	35	10	0.3	1	0.12	77.5	6.6219	0.6933
2015	12	14	2	45	10	0.3	1	0.14	86	6.6219	0.8281
2015	12	14	2	55	10	0.3	1	0.18	70.9	6.6219	1.0014
2015	12	14	3	5	10	0.3	1	0.22	92.6	6.6219	1.271
2015	12	14	3	15	10	0.3	1	0.22	98.5	6.6219	1.2903
2015	12	14	3	25	10	0.3	1	0.2	100.4	6.6219	1.1555
2015	12	14	3	35	10	0.3	1	0.17	77.6	6.6219	0.9629
2015	12	14	3	45	10	0.3	1	0.18	101.3	6.6219	1.0592
2015	12	14	3	55	10	0.3	1	0.2	87.2	6.6219	1.1747
2015	12	14	4	5	10	0.3	1	0.17	107.7	6.6026	0.9599
2015	12	14	4	15	10	0.3	1	0.16	69.7	6.6026	0.8831
2015	12	14	4	25	10	0.3	1	0.15	90	6.6219	0.9051
2015	12	14	4	35	10	0.3	1	0.16	105.5	6.6026	0.9023
2015	12	14	4	45	10	0.3	1	0.22	99.5	6.6219	1.271
2015	12	14	4	55	10	0.3	1	0.22	88.3	6.6219	1.3095
2015	12	14	5	5	10	0.3	1	0.28	90	6.6219	1.6562
2015	12	14	5	15	10	0.3	1	0.23	86.7	6.6219	1.348
2015	12	14	5	25	10	0.3	1	0.26	92.9	6.6219	1.5406
2015	12	14	5	35	10	0.3	1	0.26	96.4	6.6219	1.5406
2015	12	14	5	45	10	0.3	1	0.2	90	6.6219	1.194
2015	12	14	5	55	10	0.3	1	0.21	91.8	6.6026	1.2286
2015	12	14	6	5	10	0.3	1	0.21	91.8	6.6026	1.2478
2015	12	14	6	15	10	0.3	1	0.22	87.4	6.6026	1.267
2015	12	14	6	25	10	0.3	1	0.2	105.4	6.6026	1.1135
2015	12	14	6	35	10	0.3	1	0.25	103.5	6.6219	1.4443
2015	12	14	6	45	10	0.3	1	0.21	80.8	6.6026	1.1902
2015	12	14	6	55	10	0.3	1	0.19	105.9	6.6219	1.0784
2015	12	14	7	5	10	0.3	1	0.2	76.4	6.6026	1.1135
2015	12	14	7	15	10	0.3	1	0.19	108.7	6.6219	1.0784
2015	12	14	7	25	10	0.3	1	0.25	94.5	6.6026	1.4782
2015	12	14	7	35	10	0.3	1	0.23	88.4	6.6026	1.3438
2015	12	14	7	45	10	0.3	1	0.15	100.1	6.6026	0.8639
2015	12	14	7	55	10	0.3	1	0.2	89.1	6.6026	1.1711
2015	12	14	8	5	10	0.3	1	0.18	84.8	6.6026	1.0559
2015	12	14	8	15	10	0.3	1	0.2	85.2	6.6026	1.1519
2015	12	14	8	25	10	0.3	1	0.24	90.8	6.6026	1.3822
2015	12	14	8	35	10	0.3	1	0.22	90	6.6026	1.3054
2015	12	14	8	45	10	0.3	1	0.18	92.1	6.6026	1.0559
2015	12	14	8	55	10	0.3	1	0.19	82	6.6026	1.0943
2015	12	14	9	5	10	0.3	1	0.21	101	6.6026	1.1903
2015	12	14	9	15	10	0.3	1	0.15	87.5	6.6026	0.8831
2015	12	14	9	25	10	0.3	1	0.17	135	6.6026	0.6911
2015	12	14	9	35	10	0.3	1	0.2	112.7	6.5832	1.0526
2015	12	14	9	45	10	0.3	1	0.19	90	6.5832	1.1291
2015	12	14	9	55	10	0.3	1	0.18	87.9	6.5832	1.0526

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	10	5	10	0.3	1	0.21	110.4	6.5832	1.1291
2015	12	14	10	15	10	0.3	1	0.16	94.7	6.5832	0.9377
2015	12	14	10	25	10	0.3	1	0.17	64.4	6.5832	0.8803
2015	12	14	10	35	10	0.3	1	0.14	94	6.6026	0.8255
2015	12	14	10	45	10	0.3	1	0.16	72.3	6.5832	0.8994
2015	12	14	10	55	10	0.3	1	0.19	87	6.6026	1.0943
2015	12	14	11	5	10	0.3	1	0.2	94.6	6.5832	1.1865
2015	12	14	11	15	10	0.3	1	0.23	93.3	6.6026	1.3246
2015	12	14	11	25	10	0.3	1	0.16	90	6.6026	0.9599
2015	12	14	11	35	10	0.3	1	0.17	85.7	6.5832	1.0143
2015	12	14	11	45	10	0.3	1	0.22	85	6.6026	1.3054
2015	12	14	11	55	10	0.3	1	0.16	68.6	6.6026	0.8831
2015	12	14	12	5	10	0.3	1	0.23	98.4	6.5832	1.3013
2015	12	14	12	15	10	0.3	1	0.19	75.7	6.5832	1.0525
2015	12	14	12	25	10	0.3	1	0.15	100.1	6.5832	0.8612
2015	12	14	12	35	10	0.3	1	0.22	76	6.5832	1.2247
2015	12	14	12	45	10	0.3	1	0.2	77.8	6.5832	1.1482
2015	12	14	12	55	10	0.3	1	0.12	67.6	6.5832	0.6506
2015	12	14	13	5	10	0.3	1	0.22	80.4	6.5832	1.2439
2015	12	14	13	15	10	0.3	1	0.2	90	6.5832	1.1865
2015	12	14	13	25	10	0.3	1	0.17	78.1	6.5832	0.9951
2015	12	14	13	35	10	0.3	1	0.19	59.5	6.5832	0.976
2015	12	14	13	45	10	0.3	1	0.17	92.2	6.5832	0.9951
2015	12	14	13	55	10	0.3	1	0.19	78.3	6.6026	1.1134
2015	12	14	14	5	10	0.3	1	0.21	62.6	6.5832	1.0716
2015	12	14	14	15	10	0.3	1	0.2	69.4	6.5832	1.0716
2015	12	14	14	25	10	0.3	1	0.11	78.4	6.5832	0.6506
2015	12	14	14	35	10	0.3	1	0.23	85.9	6.6026	1.3438
2015	12	14	14	45	10	0.3	1	0.14	84.6	6.6026	0.8063
2015	12	14	14	55	10	0.3	1	0.17	83.4	6.5832	0.9951
2015	12	14	15	5	10	0.3	1	0.2	86.2	6.5832	1.1673
2015	12	14	15	15	10	0.3	1	0.14	62.9	6.5639	0.744
2015	12	14	15	25	10	0.3	1	0.16	100.4	6.5832	0.9377
2015	12	14	15	35	10	0.3	1	0.29	101.8	6.6026	1.6509
2015	12	14	15	45	10	0.3	1	0.21	99.2	6.5832	1.1865
2015	12	14	15	55	10	0.3	1	0.21	99.2	6.6026	1.1902
2015	12	14	16	5	10	0.3	1	0.18	92.1	6.6026	1.0366
2015	12	14	16	15	10	0.3	1	0.19	73.1	6.6026	1.075
2015	12	14	16	25	10	0.3	1	0.2	68.6	6.6026	1.075
2015	12	14	16	35	10	0.3	1	0.19	82.1	6.6026	1.1134
2015	12	14	16	45	10	0.3	1	0.18	58.3	6.6026	0.9023
2015	12	14	16	55	10	0.3	1	0.23	78.4	6.6026	1.3054
2015	12	14	17	5	10	0.3	1	0.21	81.1	6.6026	1.2286
2015	12	14	17	15	10	0.3	1	0.14	90	6.6026	0.8447
2015	12	14	17	25	10	0.3	1	0.19	92	6.6026	1.0942
2015	12	14	17	35	10	0.3	1	0.18	99.3	6.6026	1.0558

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	17	45	10	0.3	1	0.23	105.6	6.6026	1.3054
2015	12	14	17	55	10	0.3	1	0.14	129.1	6.6026	0.6143
2015	12	14	18	5	10	0.3	1	0.11	113.6	6.6026	0.6143
2015	12	14	18	15	10	0.3	1	0.11	90	6.6026	0.6719
2015	12	14	18	25	10	0.3	1	0.17	84.4	6.6026	0.9791
2015	12	14	18	35	10	0.3	1	0.22	108.4	6.6026	1.2094
2015	12	14	18	45	10	0.3	1	0.11	96.9	6.6026	0.6335
2015	12	14	18	55	10	0.3	1	0.07	74.1	6.6026	0.4031
2015	12	14	19	5	10	0.3	1	0.13	103	6.6026	0.7487
2015	12	14	19	15	10	0.3	1	0.16	121.8	6.6026	0.8063
2015	12	14	19	25	10	0.3	1	0.15	92.5	6.6026	0.8831
2015	12	14	19	35	10	0.3	1	0.22	90	6.6026	1.2862
2015	12	14	19	45	10	0.3	1	0.15	114.3	6.6026	0.8063
2015	12	14	19	55	10	0.3	1	0.18	109.4	6.6219	0.9821
2015	12	14	20	5	10	0.3	1	0.17	111.6	6.6219	0.9244
2015	12	14	20	15	10	0.3	1	0.19	101.1	6.6219	1.0784
2015	12	14	20	25	10	0.3	1	0.15	113.7	6.6219	0.7896
2015	12	14	20	35	10	0.3	1	0.2	120.8	6.6026	0.9983
2015	12	14	20	45	10	0.3	1	0.18	100.5	6.6026	1.0367
2015	12	14	20	55	10	0.3	1	0.2	142.2	6.6026	0.7295
2015	12	14	21	5	10	0.3	1	0.19	125.7	6.6026	0.8831
2015	12	14	21	15	10	0.3	1	0.17	135	6.6026	0.7103
2015	12	14	21	25	10	0.3	1	0.21	135	6.6026	0.8639
2015	12	14	21	35	10	0.3	1	0.2	145.2	6.6026	0.6527
2015	12	14	21	45	10	0.3	1	0.23	139	6.6026	0.9023
2015	12	14	21	55	10	0.3	1	0.26	143.9	6.6026	0.8831
2015	12	14	22	5	10	0.3	1	0.26	148.3	6.6026	0.8063
2015	12	14	22	15	10	0.3	1	0.17	157.4	6.6026	0.384
2015	12	14	22	25	10	0.3	1	0.16	153.9	6.6026	0.4224
2015	12	14	22	35	10	0.3	1	0.18	129.8	6.6026	0.8063
2015	12	14	22	45	10	0.3	1	0.11	137.4	6.6026	0.4416
2015	12	14	22	55	10	0.3	1	0.17	105.4	6.6026	0.9791
2015	12	14	23	5	10	0.3	1	0.19	153.4	6.6026	0.4991
2015	12	14	23	15	10	0.3	1	0.21	118.5	6.6026	1.0943
2015	12	14	23	25	10	0.3	1	0.18	98.6	6.6026	1.0175
2015	12	14	23	35	10	0.3	1	0.17	109.1	6.6026	0.9407
2015	12	14	23	45	10	0.3	1	0.27	102.1	6.6026	1.5167
2015	12	14	23	55	10	0.3	1	0.15	100.1	6.6026	0.8639
2015	12	15	0	5	10	0.3	1	0.15	103.7	6.6026	0.8639
2015	12	15	0	15	10	0.3	1	0.15	114.9	6.6026	0.7871
2015	12	15	0	25	10	0.3	1	0.18	107.8	6.6026	1.0175
2015	12	15	0	35	10	0.3	1	0.22	101.3	6.6026	1.2479
2015	12	15	0	45	10	0.3	1	0.23	117.7	6.6026	1.1711
2015	12	15	0	55	10	0.3	1	0.21	126	6.6026	0.9791
2015	12	15	1	5	10	0.3	1	0.15	115.5	6.6026	0.8063
2015	12	15	1	15	10	0.3	1	0.18	115.1	6.6026	0.9407

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	1	25	10	0.3	1	0.2	135	6.5832	0.8421
2015	12	15	1	35	10	0.3	1	0.23	111.8	6.5832	1.244
2015	12	15	1	45	10	0.3	1	0.17	112.2	6.5832	0.9378
2015	12	15	1	55	10	0.3	1	0.18	112.4	6.5832	0.9761
2015	12	15	2	5	10	0.3	1	0.11	112.1	6.5832	0.6124
2015	12	15	2	15	10	0.3	1	0.18	130.5	6.5832	0.7847
2015	12	15	2	25	10	0.3	1	0.19	110.7	6.5832	1.0143
2015	12	15	2	35	10	0.3	1	0.13	101.9	6.5832	0.7273
2015	12	15	2	45	10	0.3	1	0.2	90	6.5832	1.1483
2015	12	15	2	55	10	0.3	1	0.17	103.8	6.5832	0.9378
2015	12	15	3	5	10	0.3	1	0.22	99.5	6.5832	1.2631
2015	12	15	3	15	10	0.3	1	0.13	85.5	6.5832	0.7273
2015	12	15	3	25	10	0.3	1	0.28	91.4	6.5832	1.6076
2015	12	15	3	35	10	0.3	1	0.18	115.1	6.5832	0.9378
2015	12	15	3	45	10	0.3	1	0.22	108.2	6.5832	1.2249
2015	12	15	3	55	10	0.3	1	0.23	110.3	6.5832	1.244
2015	12	15	4	5	10	0.3	1	0.16	90	6.5832	0.9378
2015	12	15	4	15	10	0.3	1	0.2	96.5	6.5832	1.1675
2015	12	15	4	25	10	0.3	1	0.21	84.6	6.5639	1.221
2015	12	15	4	35	10	0.3	1	0.2	112.8	6.5832	1.0909
2015	12	15	4	45	10	0.3	1	0.2	101.5	6.5832	1.1292
2015	12	15	4	55	10	0.3	1	0.16	109.6	6.5639	0.8585
2015	12	15	5	5	10	0.3	1	0.15	108	6.5639	0.8204
2015	12	15	5	15	10	0.3	1	0.19	102.1	6.5832	1.0718
2015	12	15	5	25	10	0.3	1	0.25	104.2	6.5832	1.4354
2015	12	15	5	35	10	0.3	1	0.25	123.7	6.5639	1.2019
2015	12	15	5	45	10	0.3	1	0.14	132.2	6.5639	0.6105
2015	12	15	5	55	10	0.3	1	0.16	108.4	6.5639	0.8585
2015	12	15	6	5	10	0.3	1	0.26	105.4	6.5639	1.45
2015	12	15	6	15	10	0.3	1	0.2	127.6	6.5639	0.9158
2015	12	15	6	25	10	0.3	1	0.22	105.5	6.5639	1.2401
2015	12	15	6	35	10	0.3	1	0.18	116.6	6.5639	0.9539
2015	12	15	6	45	10	0.3	1	0.13	117.9	6.5639	0.6487
2015	12	15	6	55	10	0.3	1	0.18	108.4	6.5639	0.973
2015	12	15	7	5	10	0.3	1	0.18	133.5	6.5639	0.7441
2015	12	15	7	15	10	0.3	1	0.21	105.3	6.5639	1.1829
2015	12	15	7	25	10	0.3	1	0.22	131.3	6.5445	0.9509
2015	12	15	7	35	10	0.3	1	0.17	103.2	6.5445	0.9699
2015	12	15	7	45	10	0.3	1	0.17	108.4	6.5639	0.9158
2015	12	15	7	55	10	0.3	1	0.17	91.1	6.5445	0.9699
2015	12	15	8	5	10	0.3	1	0.12	90	6.5445	0.7227
2015	12	15	8	15	10	0.3	1	0.14	105.4	6.5445	0.7607
2015	12	15	8	25	10	0.3	1	0.12	107	6.5445	0.6847
2015	12	15	8	35	10	0.3	1	0.2	103.3	6.5445	1.1221
2015	12	15	8	45	10	0.3	1	0.18	110.4	6.5445	0.9699
2015	12	15	8	55	10	0.3	1	0.13	103.3	6.5445	0.7227

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	9	5	10	0.3	1	0.22	86.6	6.5445	1.2933
2015	12	15	9	15	10	0.3	1	0.18	103	6.5445	0.989
2015	12	15	9	25	10	0.3	1	0.11	79.7	6.5445	0.6276
2015	12	15	9	35	10	0.3	1	0.2	108.4	6.5445	1.084
2015	12	15	9	45	10	0.3	1	0.12	115.9	6.5445	0.6276
2015	12	15	9	55	10	0.3	1	0.2	74.8	6.5445	1.1221
2015	12	15	10	5	10	0.3	1	0.19	119.7	6.5445	0.9319
2015	12	15	10	15	10	0.3	1	0.16	110.7	6.5445	0.8558
2015	12	15	10	25	10	0.3	1	0.11	126.5	6.5445	0.5135
2015	12	15	10	35	10	0.3	1	0.26	105.9	6.5445	1.4644
2015	12	15	10	45	10	0.3	1	0.15	127.9	6.5252	0.6825
2015	12	15	10	55	10	0.3	1	0.15	77.2	6.5252	0.8341
2015	12	15	11	5	10	0.3	1	0.17	107	6.5252	0.9289
2015	12	15	11	15	10	0.3	1	0.18	98.4	6.5058	1.0205
2015	12	15	11	25	10	0.3	1	0.17	92.2	6.5252	1.0048
2015	12	15	11	35	10	0.3	1	0.17	98.7	6.5252	0.9858
2015	12	15	11	45	10	0.3	1	0.18	100.7	6.5252	1.0048
2015	12	15	11	55	10	0.3	1	0.17	82.3	6.5058	0.9827
2015	12	15	12	5	10	0.3	1	0.07	90	6.5058	0.3968
2015	12	15	12	15	10	0.3	1	0.18	103	6.5058	0.9827
2015	12	15	12	25	10	0.3	1	0.22	107.1	6.5252	1.2322
2015	12	15	12	35	10	0.3	1	0.2	87.2	6.5252	1.1564
2015	12	15	12	45	10	0.3	1	0.12	96.5	6.5252	0.6635
2015	12	15	12	55	10	0.3	1	0.23	110.3	6.5252	1.2322
2015	12	15	13	5	10	0.3	1	0.12	86.8	6.5252	0.6825
2015	12	15	13	15	10	0.3	1	0.16	98.5	6.5445	0.8938
2015	12	15	13	25	10	0.3	1	0.17	99.1	6.5445	0.9509
2015	12	15	13	35	10	0.3	1	0.2	85.4	6.5445	1.1791
2015	12	15	13	45	10	0.3	1	0.16	78.5	6.5252	0.9289
2015	12	15	13	55	10	0.3	1	0.19	83.1	6.5252	1.0995
2015	12	15	14	5	10	0.3	1	0.19	91	6.5252	1.1185
2015	12	15	14	15	10	0.3	1	0.18	77	6.5445	0.9889
2015	12	15	14	25	10	0.3	1	0.19	75.3	6.5445	1.084
2015	12	15	14	35	10	0.3	1	0.17	82	6.5445	0.9509
2015	12	15	14	45	10	0.3	1	0.17	104.9	6.5445	0.9319
2015	12	15	14	55	10	0.3	1	0.23	85	6.5445	1.3122
2015	12	15	15	5	10	0.3	1	0.22	86.6	6.5445	1.2742
2015	12	15	15	15	10	0.3	1	0.23	93.2	6.5445	1.3502
2015	12	15	15	25	10	0.3	1	0.19	93.9	6.5445	1.103
2015	12	15	15	35	10	0.3	1	0.15	90	6.5445	0.8748
2015	12	15	15	45	10	0.3	1	0.2	82.4	6.5445	1.141
2015	12	15	15	55	10	0.3	1	0.23	98.4	6.5445	1.2932
2015	12	15	16	5	10	0.3	1	0.19	89	6.5445	1.103
2015	12	15	16	15	10	0.3	1	0.24	82.9	6.5639	1.3736
2015	12	15	16	25	10	0.3	1	0.19	86.1	6.5639	1.1256
2015	12	15	16	35	10	0.3	1	0.25	99.7	6.5639	1.4499

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	16	45	10	0.3	1	0.21	90	6.5639	1.2019
2015	12	15	16	55	10	0.3	1	0.15	114.9	6.5639	0.7822
2015	12	15	17	5	10	0.3	1	0.24	88.4	6.5639	1.3927
2015	12	15	17	15	10	0.3	1	0.18	82.5	6.5639	1.0111
2015	12	15	17	25	10	0.3	1	0.19	96.9	6.5639	1.1065
2015	12	15	17	35	10	0.3	1	0.22	104.4	6.5639	1.2591
2015	12	15	17	45	10	0.3	1	0.26	100	6.5639	1.5072
2015	12	15	17	55	10	0.3	1	0.16	94.6	6.5639	0.9539
2015	12	15	18	5	10	0.3	1	0.16	114.4	6.5639	0.8394
2015	12	15	18	15	10	0.3	1	0.22	95.2	6.5639	1.2591
2015	12	15	18	25	10	0.3	1	0.19	87.1	6.5639	1.1256
2015	12	15	18	35	10	0.3	1	0.18	69	6.5639	0.9921
2015	12	15	18	45	10	0.3	1	0.15	108	6.5639	0.8204
2015	12	15	18	55	10	0.3	1	0.17	103.5	6.5639	0.9539
2015	12	15	19	5	10	0.3	1	0.16	94.6	6.5639	0.9539
2015	12	15	19	15	10	0.3	1	0.14	99.7	6.5639	0.7822
2015	12	15	19	25	10	0.3	1	0.15	105.3	6.5639	0.8394
2015	12	15	19	35	10	0.3	1	0.19	80	6.5639	1.0874
2015	12	15	19	45	10	0.3	1	0.14	111	6.5639	0.744
2015	12	15	19	55	10	0.3	1	0.16	112.2	6.5639	0.8394
2015	12	15	20	5	10	0.3	1	0.22	109	6.5639	1.221
2015	12	15	20	15	10	0.3	1	0.1	104.9	6.5639	0.5723
2015	12	15	20	25	10	0.3	1	0.18	90	6.5639	1.0302
2015	12	15	20	35	10	0.3	1	0.16	130	6.5639	0.7059
2015	12	15	20	45	10	0.3	1	0.11	111.2	6.5639	0.5914
2015	12	15	20	55	10	0.3	1	0.13	129.8	6.5639	0.5723
2015	12	15	21	5	10	0.3	1	0.14	122.6	6.5639	0.6868
2015	12	15	21	15	10	0.3	1	0.17	126.4	6.5639	0.8013
2015	12	15	21	25	10	0.3	1	0.11	154.2	6.5639	0.2671
2015	12	15	21	35	10	0.3	1	0.18	108.4	6.5639	0.973
2015	12	15	21	45	10	0.3	1	0.13	123.7	6.5639	0.6296
2015	12	15	21	55	10	0.3	1	0.09	104	6.5639	0.5342
2015	12	15	22	5	10	0.3	1	0.2	147.9	6.5639	0.6105
2015	12	15	22	15	10	0.3	1	0.17	108.1	6.5832	0.9378
2015	12	15	22	25	10	0.3	1	0.16	139.9	6.5832	0.6124
2015	12	15	22	35	10	0.3	1	0.16	116	6.5832	0.823
2015	12	15	22	45	10	0.3	1	0.18	109.1	6.5832	0.9952
2015	12	15	22	55	10	0.3	1	0.2	112.3	6.5832	1.0718
2015	12	15	23	5	10	0.3	1	0.25	124.9	6.5832	1.2057
2015	12	15	23	15	10	0.3	1	0.2	109.7	6.5832	1.0718
2015	12	15	23	25	10	0.3	1	0.08	128.7	6.5832	0.3828
2015	12	15	23	35	10	0.3	1	0.09	83.9	6.5832	0.5359
2015	12	15	23	45	10	0.3	1	0.12	122.3	6.5832	0.5742
2015	12	15	23	55	10	0.3	1	0.07	69.1	6.5832	0.4019
2015	12	16	0	5	10	0.3	1	0.13	53.1	6.5832	0.6124
2015	12	16	0	15	10	0.3	1	0.16	133.3	6.5832	0.6699

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	0	25	10	0.3	1	0.05	212.7	6.5832	-0.1723
2015	12	16	0	35	10	0.3	1	0.14	106.7	6.5832	0.7656
2015	12	16	0	45	10	0.3	1	0.12	148	6.5832	0.3828
2015	12	16	0	55	10	0.3	1	0.19	108.1	6.5832	1.0526
2015	12	16	1	5	10	0.3	1	0.15	90	6.5832	0.8613
2015	12	16	1	15	10	0.3	1	0.18	108.4	6.5832	0.9761
2015	12	16	1	25	10	0.3	1	0.11	125.1	6.5832	0.5168
2015	12	16	1	35	10	0.3	1	0.16	123	6.5832	0.7656
2015	12	16	1	45	10	0.3	1	0.14	107.2	6.5832	0.8038
2015	12	16	1	55	10	0.3	1	0.08	115.5	6.5832	0.4019
2015	12	16	2	5	10	0.3	1	0.16	117.1	6.5832	0.823
2015	12	16	2	15	10	0.3	1	0.13	78.1	6.5832	0.7273
2015	12	16	2	25	10	0.3	1	0.15	120.5	6.5832	0.7464
2015	12	16	2	35	10	0.3	1	0.1	117.4	6.5832	0.5168
2015	12	16	2	45	10	0.3	1	0.14	95.2	6.5832	0.8421
2015	12	16	2	55	10	0.3	1	0.12	102.5	6.5832	0.689
2015	12	16	3	5	10	0.3	1	0.18	111.4	6.5832	0.9761
2015	12	16	3	15	10	0.3	1	0.13	109.4	6.5832	0.7082
2015	12	16	3	25	10	0.3	1	0.15	107.7	6.5832	0.8421
2015	12	16	3	35	10	0.3	1	0.12	123.7	6.5832	0.5742
2015	12	16	3	45	10	0.3	1	0.17	100.9	6.5832	0.9952
2015	12	16	3	55	10	0.3	1	0.21	90	6.5832	1.2249
2015	12	16	4	5	10	0.3	1	0.14	110.6	6.5832	0.7656
2015	12	16	4	15	10	0.3	1	0.13	96	6.5832	0.7273
2015	12	16	4	25	10	0.3	1	0.17	118.1	6.5832	0.8613
2015	12	16	4	35	10	0.3	1	0.17	115.6	6.5832	0.9187
2015	12	16	4	45	10	0.3	1	0.23	98.9	6.5832	1.3398
2015	12	16	4	55	10	0.3	1	0.16	124.3	6.5832	0.7847
2015	12	16	5	5	10	0.3	1	0.2	117.8	6.5832	1.0144
2015	12	16	5	15	10	0.3	1	0.16	112.4	6.5832	0.8804
2015	12	16	5	25	10	0.3	1	0.15	90	6.5832	0.8613
2015	12	16	5	35	10	0.3	1	0.14	120.3	6.5832	0.689
2015	12	16	5	45	10	0.3	1	0.12	88.5	6.5832	0.7273
2015	12	16	5	55	10	0.3	1	0.06	90	6.5832	0.3445
2015	12	16	6	5	10	0.3	1	0.2	105.2	6.5832	1.1292
2015	12	16	6	15	10	0.3	1	0.11	112.1	6.5832	0.6125
2015	12	16	6	25	10	0.3	1	0.16	87.7	6.5832	0.957
2015	12	16	6	35	10	0.3	1	0.17	94.3	6.5832	1.0144
2015	12	16	6	45	10	0.3	1	0.2	108.7	6.5832	1.1292
2015	12	16	6	55	10	0.3	1	0.15	110.9	6.5832	0.8039
2015	12	16	7	5	10	0.3	1	0.16	90	6.5832	0.957
2015	12	16	7	15	10	0.3	1	0.15	84.9	6.5832	0.8613
2015	12	16	7	25	10	0.3	1	0.12	107.4	6.5832	0.6699
2015	12	16	7	35	10	0.3	1	0.23	108.7	6.5832	1.2441
2015	12	16	7	45	10	0.3	1	0.19	105.3	6.5832	1.0527
2015	12	16	7	55	10	0.3	1	0.14	95.4	6.5832	0.8039

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	8	5	10	0.3	1	0.2	99.5	6.5832	1.1484
2015	12	16	8	15	10	0.3	1	0.1	109	6.5832	0.555
2015	12	16	8	25	10	0.3	1	0.13	121.7	6.5832	0.6507
2015	12	16	8	35	10	0.3	1	0.19	102.1	6.5832	1.0718
2015	12	16	8	45	10	0.3	1	0.16	95.7	6.5832	0.957
2015	12	16	8	55	10	0.3	1	0.17	101.3	6.5832	0.957
2015	12	16	9	5	10	0.3	1	0.15	116.6	6.5832	0.7656
2015	12	16	9	15	10	0.3	1	0.04	35	6.5832	0.134
2015	12	16	9	25	10	0.3	1	0.04	308.7	6.5832	-0.1914
2015	12	16	9	35	10	0.3	1	0.04	180	6.5832	0
2015	12	16	9	45	10	0.3	1	0.07	125.2	6.5832	0.3254
2015	12	16	9	55	10	0.3	1	0.23	116.6	6.5832	1.2249
2015	12	16	10	5	10	0.3	1	0.17	92.2	6.5639	0.9921
2015	12	16	10	15	10	0.3	1	0.19	103.8	6.6026	1.0944
2015	12	16	10	25	10	0.3	1	0.22	107.6	6.6026	1.2096
2015	12	16	10	35	10	0.3	1	0.23	115.8	6.5832	1.1866
2015	12	16	10	45	10	0.3	1	0.15	95	6.5832	0.8804
2015	12	16	10	55	10	0.3	1	0.15	98.8	6.5832	0.8613
2015	12	16	11	5	10	0.3	1	0.12	97.9	6.5832	0.689
2015	12	16	11	15	10	0.3	1	0.11	100.6	6.5832	0.6125
2015	12	16	11	25	10	0.3	1	0.12	93.1	6.5832	0.7081
2015	12	16	11	35	10	0.3	1	0.16	110.3	6.5832	0.8804
2015	12	16	11	45	10	0.3	1	0.28	122.2	6.5832	1.3971
2015	12	16	11	55	10	0.3	1	0.16	104	6.5832	0.9187
2015	12	16	12	5	10	0.3	1	0.24	109.2	6.5832	1.3206
2015	12	16	12	15	10	0.3	1	0.16	106.3	6.5832	0.9187
2015	12	16	12	25	10	0.3	1	0.18	99.6	6.5832	1.0144
2015	12	16	12	35	10	0.3	1	0.13	92.9	6.5832	0.7656
2015	12	16	12	45	10	0.3	1	0.17	117.1	6.5832	0.8612
2015	12	16	12	55	10	0.3	1	0.18	92.1	6.5832	1.0526
2015	12	16	13	5	10	0.3	1	0.15	90	6.5832	0.8995
2015	12	16	13	15	10	0.3	1	0.24	120.8	6.5832	1.1866
2015	12	16	13	25	10	0.3	1	0.22	107.1	6.5832	1.244
2015	12	16	13	35	10	0.3	1	0.2	126.5	6.5832	0.9569
2015	12	16	13	45	10	0.3	1	0.21	135	6.5832	0.8612
2015	12	16	13	55	10	0.3	1	0.24	116.2	6.5832	1.244
2015	12	16	14	5	10	0.3	1	0.2	121.1	6.5832	1.0143
2015	12	16	14	15	10	0.3	1	0.27	119.1	6.5832	1.378
2015	12	16	14	25	10	0.3	1	0.16	114	6.5832	0.8612
2015	12	16	14	35	10	0.3	1	0.16	130.7	6.5832	0.689
2015	12	16	14	45	10	0.3	1	0.25	126	6.5832	1.1866
2015	12	16	14	55	10	0.3	1	0.25	102.2	6.5832	1.4162
2015	12	16	15	5	10	0.3	1	0.25	90.8	6.5832	1.4354
2015	12	16	15	15	10	0.3	1	0.26	115.9	6.5832	1.3397
2015	12	16	15	25	10	0.3	1	0.24	125.2	6.5832	1.1674
2015	12	16	15	35	10	0.3	1	0.24	124.3	6.5832	1.1483

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	15	45	10	0.3	1	0.21	119.3	6.5832	1.0909
2015	12	16	15	55	10	0.3	1	0.26	92.1	6.5832	1.5311
2015	12	16	16	5	10	0.3	1	0.24	109.9	6.5832	1.3205
2015	12	16	16	15	10	0.3	1	0.25	114.6	6.5832	1.3397
2015	12	16	16	25	10	0.3	1	0.25	119.6	6.5832	1.244
2015	12	16	16	35	10	0.3	1	0.24	106.7	6.5832	1.3397
2015	12	16	16	45	10	0.3	1	0.27	92.8	6.5832	1.5693
2015	12	16	16	55	10	0.3	1	0.18	109.1	6.5832	0.9952
2015	12	16	17	5	10	0.3	1	0.27	121.6	6.5832	1.3397
2015	12	16	17	15	10	0.3	1	0.22	98.7	6.5832	1.244
2015	12	16	17	25	10	0.3	1	0.16	104.3	6.5832	0.8995
2015	12	16	17	35	10	0.3	1	0.14	67	6.5832	0.7655
2015	12	16	17	45	10	0.3	1	0.11	101.6	6.5832	0.6507
2015	12	16	17	55	10	0.3	1	0.12	71.6	6.5832	0.689
2015	12	16	18	5	10	0.3	1	0.18	94.2	6.5832	1.0335
2015	12	16	18	15	10	0.3	1	0.09	106.5	6.5832	0.5167
2015	12	16	18	25	10	0.3	1	0.16	90	6.5832	0.9378
2015	12	16	18	35	10	0.3	1	0.18	76.5	6.5832	1.0334
2015	12	16	18	45	10	0.3	1	0.15	86.3	6.5832	0.8803
2015	12	16	18	55	10	0.3	1	0.27	92.1	6.5832	1.5693
2015	12	16	19	5	10	0.3	1	0.18	107.1	6.5832	0.9952
2015	12	16	19	15	10	0.3	1	0.16	93.6	6.6026	0.9215
2015	12	16	19	25	10	0.3	1	0.23	118	6.6026	1.1903
2015	12	16	19	35	10	0.3	1	0.15	107.3	6.5832	0.8612
2015	12	16	19	45	10	0.3	1	0.11	74.7	6.6026	0.6335
2015	12	16	19	55	10	0.3	1	0.21	100.1	6.5832	1.1866
2015	12	16	20	5	10	0.3	1	0.24	95.5	6.6026	1.4015
2015	12	16	20	15	10	0.3	1	0.15	96.3	6.6026	0.8639
2015	12	16	20	25	10	0.3	1	0.27	116.3	6.6026	1.4015
2015	12	16	20	35	10	0.3	1	0.27	95.6	6.6026	1.5551
2015	12	16	20	45	10	0.3	1	0.25	102.4	6.6026	1.4015
2015	12	16	20	55	10	0.3	1	0.23	112.9	6.6026	1.2287
2015	12	16	21	5	10	0.3	1	0.21	111	6.6026	1.1519
2015	12	16	21	15	10	0.3	1	0.29	128	6.5832	1.3205
2015	12	16	21	25	10	0.3	1	0.28	119.2	6.5832	1.4354
2015	12	16	21	35	10	0.3	1	0.34	118.8	6.5832	1.7416
2015	12	16	21	45	10	0.3	1	0.3	117.1	6.5832	1.5693
2015	12	16	21	55	10	0.3	1	0.32	105.5	6.5832	1.799
2015	12	16	22	5	10	0.3	1	0.25	109.6	6.5832	1.3971
2015	12	16	22	15	10	0.3	1	0.24	106.7	6.5832	1.3397
2015	12	16	22	25	10	0.3	1	0.21	93.5	6.5832	1.244
2015	12	16	22	35	10	0.3	1	0.15	75.1	6.5832	0.8612
2015	12	16	22	45	10	0.3	1	0.12	118	6.5832	0.6124
2015	12	16	22	55	10	0.3	1	0.17	123.7	6.5832	0.8038
2015	12	16	23	5	10	0.3	1	0.19	104	6.5832	1.0718
2015	12	16	23	15	10	0.3	1	0.32	123.9	6.5832	1.5694

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	23	25	10	0.3	1	0.21	99	6.5832	1.2057
2015	12	16	23	35	10	0.3	1	0.46	119.3	6.5832	2.354
2015	12	16	23	45	10	0.3	1	0.41	120.9	6.5832	2.0478
2015	12	16	23	55	10	0.3	1	0.26	113.4	6.5832	1.4163
2015	12	17	0	5	10	0.3	1	0.34	126.9	6.5832	1.6077
2015	12	17	0	15	10	0.3	1	0.23	125.7	6.5832	1.0909
2015	12	17	0	25	10	0.3	1	0.29	123.3	6.5832	1.3971
2015	12	17	0	35	10	0.3	1	0.11	19	6.5832	0.2105
2015	12	17	0	45	10	0.3	1	0.09	315	6.5832	-0.3828
2015	12	17	0	55	10	0.3	1	0.17	109.5	6.5832	0.9187
2015	12	17	1	5	10	0.3	1	0.36	124.1	6.5832	1.7225
2015	12	17	1	15	10	0.3	1	0.31	110.9	6.5832	1.7034
2015	12	17	1	25	10	0.3	1	0.27	115	6.5832	1.4354
2015	12	17	1	35	10	0.3	1	0.24	124.3	6.5832	1.1483
2015	12	17	1	45	10	0.3	1	0.32	107.5	6.5832	1.7608
2015	12	17	1	55	10	0.3	1	0.13	77.3	6.5832	0.7656
2015	12	17	2	5	10	0.3	1	0.27	128	6.5832	1.2249
2015	12	17	2	15	10	0.3	1	0.28	109.1	6.5832	1.5503
2015	12	17	2	25	10	0.3	1	0.14	90	6.5832	0.8421
2015	12	17	2	35	10	0.3	1	0.18	100.3	6.5832	1.0527
2015	12	17	2	45	10	0.3	1	0.26	103.9	6.5832	1.4737
2015	12	17	2	55	10	0.3	1	0.11	88.2	6.5832	0.6125
2015	12	17	3	5	10	0.3	1	0.17	122.5	6.5832	0.8421
2015	12	17	3	15	10	0.3	1	0.1	90	6.5832	0.6125
2015	12	17	3	25	10	0.3	1	0.18	110.4	6.5832	0.9761
2015	12	17	3	35	10	0.3	1	0.15	39.8	6.5832	0.5742
2015	12	17	3	45	10	0.3	1	0.09	34.8	6.5832	0.3062
2015	12	17	3	55	10	0.3	1	0.12	62.7	6.5832	0.6316
2015	12	17	4	5	10	0.3	1	0.15	104	6.5832	0.8421
2015	12	17	4	15	10	0.3	1	0.12	75.6	6.5832	0.6699
2015	12	17	4	25	10	0.3	1	0.09	54	6.5832	0.4211
2015	12	17	4	35	10	0.3	1	0.12	83.7	6.5832	0.689
2015	12	17	4	45	10	0.3	1	0.11	90	6.5832	0.6507
2015	12	17	4	55	10	0.3	1	0.17	132.7	6.5832	0.7464
2015	12	17	5	5	10	0.3	1	0.09	96.3	6.5832	0.5168
2015	12	17	5	15	10	0.3	1	0.14	132.2	6.5832	0.6125
2015	12	17	5	25	10	0.3	1	0.12	105.5	6.5832	0.689
2015	12	17	5	35	10	0.3	1	0.11	28.1	6.5832	0.3062
2015	12	17	5	45	10	0.3	1	0.17	52.7	6.5832	0.8039
2015	12	17	5	55	10	0.3	1	0.1	105.9	6.5832	0.5359
2015	12	17	6	5	10	0.3	1	0.13	113.4	6.5832	0.7082
2015	12	17	6	15	10	0.3	1	0.18	90	6.5832	1.0527
2015	12	17	6	25	10	0.3	1	0.29	109	6.5832	1.6077
2015	12	17	6	35	10	0.3	1	0.3	119.1	6.5832	1.512
2015	12	17	6	45	10	0.3	1	0.15	119.9	6.5832	0.7656
2015	12	17	6	55	10	0.3	1	0.28	107.2	6.5639	1.5454

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	7	5	10	0.3	1	0.25	99.7	6.5832	1.4546
2015	12	17	7	15	10	0.3	1	0.31	110	6.5832	1.6843
2015	12	17	7	25	10	0.3	1	0.3	125.1	6.5832	1.4163
2015	12	17	7	35	10	0.3	1	0.3	117.1	6.5832	1.5694
2015	12	17	7	45	10	0.3	1	0.26	106.6	6.5639	1.4691
2015	12	17	7	55	10	0.3	1	0.21	108.2	6.5832	1.1675
2015	12	17	8	5	10	0.3	1	0.3	130.6	6.5832	1.3398
2015	12	17	8	15	10	0.3	1	0.27	110	6.5832	1.4737
2015	12	17	8	25	10	0.3	1	0.24	110.2	6.5832	1.3015
2015	12	17	8	35	10	0.3	1	0.18	94.2	6.5639	1.0303
2015	12	17	8	45	10	0.3	1	0.22	99.3	6.5639	1.2783
2015	12	17	8	55	10	0.3	1	0.25	124.9	6.5639	1.202
2015	12	17	9	5	10	0.3	1	0.19	109.4	6.5639	1.0303
2015	12	17	9	15	10	0.3	1	0.18	131.3	6.5639	0.7822
2015	12	17	9	25	10	0.3	1	0.17	121.9	6.5639	0.8586
2015	12	17	9	35	10	0.3	1	0.19	91	6.5639	1.0875
2015	12	17	9	45	10	0.3	1	0.2	80.5	6.5639	1.1447
2015	12	17	9	55	10	0.3	1	0.18	121.1	6.5639	0.9158
2015	12	17	10	5	10	0.3	1	0.13	85.6	6.5639	0.7441
2015	12	17	10	15	10	0.3	1	0.15	65.1	6.5639	0.7822
2015	12	17	10	25	10	0.3	1	0.11	75.5	6.5639	0.5914
2015	12	17	10	35	10	0.3	1	0.12	71.1	6.5639	0.6678
2015	12	17	10	45	10	0.3	1	0.16	90	6.5639	0.9539
2015	12	17	10	55	10	0.3	1	0.21	119.7	6.5639	1.0684
2015	12	17	11	5	10	0.3	1	0.27	96.2	6.5832	1.5885
2015	12	17	11	15	10	0.3	1	0.21	97.4	6.5832	1.1866
2015	12	17	11	25	10	0.3	1	0.14	123.7	6.5832	0.689
2015	12	17	11	35	10	0.3	1	0.18	93.2	6.5832	1.0335
2015	12	17	11	45	10	0.3	1	0.21	117	6.5832	1.0909
2015	12	17	11	55	10	0.3	1	0.19	101.9	6.5832	1.0909
2015	12	17	12	5	10	0.3	1	0.23	97.4	6.5832	1.3206
2015	12	17	12	15	10	0.3	1	0.25	115.9	6.5832	1.3014
2015	12	17	12	25	10	0.3	1	0.23	110.3	6.5832	1.244
2015	12	17	12	35	10	0.3	1	0.27	116.3	6.5832	1.4354
2015	12	17	12	45	10	0.3	1	0.14	119.6	6.5832	0.7081
2015	12	17	12	55	10	0.3	1	0.2	106.3	6.5832	1.11
2015	12	17	13	5	10	0.3	1	0.22	90	6.5832	1.2631
2015	12	17	13	15	10	0.3	1	0.14	90	6.5832	0.8421
2015	12	17	13	25	10	0.3	1	0.2	109	6.5832	1.11
2015	12	17	13	35	10	0.3	1	0.31	114.1	6.5832	1.665
2015	12	17	13	45	10	0.3	1	0.24	113.7	6.5832	1.2631
2015	12	17	13	55	10	0.3	1	0.22	101.8	6.5832	1.2822
2015	12	17	14	5	10	0.3	1	0.2	90	6.5832	1.1483
2015	12	17	14	15	10	0.3	1	0.16	116.1	6.5832	0.8612
2015	12	17	14	25	10	0.3	1	0.23	123.2	6.5832	1.11
2015	12	17	14	35	10	0.3	1	0.15	99	6.5832	0.8421

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	14	45	10	0.3	1	0.26	127.2	6.5832	1.1865
2015	12	17	14	55	10	0.3	1	0.22	127	6.5832	1.0143
2015	12	17	15	5	10	0.3	1	0.21	116.6	6.5832	1.11
2015	12	17	15	15	10	0.3	1	0.23	114	6.5832	1.2439
2015	12	17	15	25	10	0.3	1	0.27	119.1	6.5832	1.3779
2015	12	17	15	35	10	0.3	1	0.28	109.9	6.5832	1.531
2015	12	17	15	45	10	0.3	1	0.3	105.7	6.5639	1.6979
2015	12	17	15	55	10	0.3	1	0.27	107.4	6.5639	1.5262
2015	12	17	16	5	10	0.3	1	0.21	111.3	6.5639	1.1256
2015	12	17	16	15	10	0.3	1	0.32	97.1	6.5639	1.8314
2015	12	17	16	25	10	0.3	1	0.31	114.7	6.5639	1.6597
2015	12	17	16	35	10	0.3	1	0.31	116.8	6.5639	1.5834
2015	12	17	16	45	10	0.3	1	0.36	96.8	6.5639	2.0794
2015	12	17	16	55	10	0.3	1	0.25	108.9	6.5639	1.3926
2015	12	17	17	5	10	0.3	1	0.24	113.7	6.5639	1.2591
2015	12	17	17	15	10	0.3	1	0.22	117.7	6.5639	1.1255
2015	12	17	17	25	10	0.3	1	0.19	127.1	6.5639	0.8585
2015	12	17	17	35	10	0.3	1	0.22	85.8	6.5639	1.2972
2015	12	17	17	45	10	0.3	1	0.25	101.9	6.5639	1.4499
2015	12	17	17	55	10	0.3	1	0.24	95.6	6.5639	1.3735
2015	12	17	18	5	10	0.3	1	0.18	94.2	6.5639	1.0302
2015	12	17	18	15	10	0.3	1	0.18	121.3	6.5639	0.8775
2015	12	17	18	25	10	0.3	1	0.12	96.5	6.5639	0.6677
2015	12	17	18	35	10	0.3	1	0.2	81.3	6.5639	1.1255
2015	12	17	18	45	10	0.3	1	0.14	80.3	6.5639	0.7822
2015	12	17	18	55	10	0.3	1	0.35	99.8	6.5639	1.984
2015	12	17	19	5	10	0.3	1	0.18	117.5	6.5639	0.9538
2015	12	17	19	15	10	0.3	1	0.19	104.3	6.5639	1.0492
2015	12	17	19	25	10	0.3	1	0.25	110.8	6.5639	1.3545
2015	12	17	19	35	10	0.3	1	0.18	106.1	6.5639	0.992
2015	12	17	19	45	10	0.3	1	0.38	119.2	6.5639	1.9077
2015	12	17	19	55	10	0.3	1	0.37	127	6.5639	1.6979
2015	12	17	20	5	10	0.3	1	0.16	90	6.5832	0.9377
2015	12	17	20	15	10	0.3	1	0.3	117.7	6.5639	1.5262
2015	12	17	20	25	10	0.3	1	0.26	98.1	6.5639	1.4689
2015	12	17	20	35	10	0.3	1	0.26	105.4	6.5639	1.4499
2015	12	17	20	45	10	0.3	1	0.22	106.5	6.5832	1.2248
2015	12	17	20	55	10	0.3	1	0.32	114.2	6.5832	1.7032
2015	12	17	21	5	10	0.3	1	0.31	109.6	6.5832	1.7224
2015	12	17	21	15	10	0.3	1	0.29	113	6.5832	1.531
2015	12	17	21	25	10	0.3	1	0.24	121.9	6.5832	1.1674
2015	12	17	21	35	10	0.3	1	0.23	122.8	6.5832	1.1291
2015	12	17	21	45	10	0.3	1	0.27	114	6.5832	1.4162
2015	12	17	21	55	10	0.3	1	0.27	112.2	6.5832	1.4545
2015	12	17	22	5	10	0.3	1	0.23	107.4	6.5832	1.2822
2015	12	17	22	15	10	0.3	1	0.3	122.8	6.5832	1.4545

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	22	25	10	0.3	1	0.18	104	6.5832	0.9952
2015	12	17	22	35	10	0.3	1	0.22	104	6.5832	1.2248
2015	12	17	22	45	10	0.3	1	0.2	95.5	6.5832	1.1865
2015	12	17	22	55	10	0.3	1	0.17	114.6	6.5832	0.9186
2015	12	17	23	5	10	0.3	1	0.27	95.6	6.5832	1.5693
2015	12	17	23	15	10	0.3	1	0.19	90	6.5832	1.11
2015	12	17	23	25	10	0.3	1	0.26	105.9	6.5832	1.4736
2015	12	17	23	35	10	0.3	1	0.18	106.5	6.5832	1.0335
2015	12	17	23	45	10	0.3	1	0.23	111.8	6.5832	1.244
2015	12	17	23	55	10	0.3	1	0.26	100.8	6.5832	1.5119
2015	12	18	0	5	10	0.3	1	0.25	113.9	6.5639	1.3354
2015	12	18	0	15	10	0.3	1	0.25	113.5	6.5832	1.3205
2015	12	18	0	25	10	0.3	1	0.17	97.7	6.5832	0.9952
2015	12	18	0	35	10	0.3	1	0.25	90	6.5639	1.4308
2015	12	18	0	45	10	0.3	1	0.18	90	6.5639	1.0493
2015	12	18	0	55	10	0.3	1	0.09	92.1	6.5832	0.5167
2015	12	18	1	5	10	0.3	1	0.06	45	6.5639	0.2289
2015	12	18	1	15	10	0.3	1	0.17	86.6	6.5639	0.973
2015	12	18	1	25	10	0.3	1	0.17	100.9	6.5639	0.9921
2015	12	18	1	35	10	0.3	1	0.25	112.2	6.5639	1.3545
2015	12	18	1	45	10	0.3	1	0.3	115.4	6.5639	1.5644
2015	12	18	1	55	10	0.3	1	0.3	117.7	6.5639	1.5644
2015	12	18	2	5	10	0.3	1	0.29	121	6.5639	1.4309
2015	12	18	2	15	10	0.3	1	0.34	126	6.5639	1.6026
2015	12	18	2	25	10	0.3	1	0.4	121.5	6.5639	1.9651
2015	12	18	2	35	10	0.3	1	0.21	121.4	6.5639	1.0302
2015	12	18	2	45	10	0.3	1	0.25	134.5	6.5639	1.0302
2015	12	18	2	55	10	0.3	1	0.29	124	6.5639	1.4118
2015	12	18	3	5	10	0.3	1	0.26	121.5	6.5639	1.2783
2015	12	18	3	15	10	0.3	1	0.16	106.3	6.5639	0.9158
2015	12	18	3	25	10	0.3	1	0.17	116.1	6.5639	0.8967
2015	12	18	3	35	10	0.3	1	0.15	110	6.5639	0.8395
2015	12	18	3	45	10	0.3	1	0.17	124	6.5639	0.8204
2015	12	18	3	55	10	0.3	1	0.08	80.5	6.5639	0.4579
2015	12	18	4	5	10	0.3	1	0.09	120.3	6.5639	0.4579
2015	12	18	4	15	10	0.3	1	0.19	122.3	6.5639	0.9348
2015	12	18	4	25	10	0.3	1	0.23	108.2	6.5639	1.2783
2015	12	18	4	35	10	0.3	1	0.18	103	6.5639	0.9921
2015	12	18	4	45	10	0.3	1	0.17	94.4	6.5639	0.9921
2015	12	18	4	55	10	0.3	1	0.12	107	6.5639	0.6868
2015	12	18	5	5	10	0.3	1	0.14	121.4	6.5639	0.6868
2015	12	18	5	15	10	0.3	1	0.12	124.6	6.5639	0.5533
2015	12	18	5	25	10	0.3	1	0.28	115.7	6.5639	1.4691
2015	12	18	5	35	10	0.3	1	0.16	113.4	6.5639	0.8395
2015	12	18	5	45	10	0.3	1	0.29	113.6	6.5639	1.5263
2015	12	18	5	55	10	0.3	1	0.27	110.2	6.5639	1.45

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	6	5	10	0.3	1	0.25	110.6	6.5639	1.3737
2015	12	18	6	15	10	0.3	1	0.25	114.2	6.5639	1.3164
2015	12	18	6	25	10	0.3	1	0.16	90	6.5639	0.9158
2015	12	18	6	35	10	0.3	1	0.22	125.1	6.5639	1.0303
2015	12	18	6	45	10	0.3	1	0.21	124.7	6.5639	0.9921
2015	12	18	6	55	10	0.3	1	0.21	97.1	6.5639	1.221
2015	12	18	7	5	10	0.3	1	0.18	110.4	6.5639	0.973
2015	12	18	7	15	10	0.3	1	0.23	105.8	6.5639	1.2783
2015	12	18	7	25	10	0.3	1	0.21	110.4	6.5639	1.1256
2015	12	18	7	35	10	0.3	1	0.13	115.9	6.5639	0.6678
2015	12	18	7	45	10	0.3	1	0.1	105.9	6.5639	0.5342
2015	12	18	7	55	10	0.3	1	0.12	101	6.5639	0.6868
2015	12	18	8	5	10	0.3	1	0.13	81.5	6.5639	0.7632
2015	12	18	8	15	10	0.3	1	0.13	111.3	6.5639	0.6868
2015	12	18	8	25	10	0.3	1	0.25	86.2	6.5639	1.45
2015	12	18	8	35	10	0.3	1	0.12	102.5	6.5639	0.6868
2015	12	18	8	45	10	0.3	1	0.15	135	6.5639	0.6296
2015	12	18	8	55	10	0.3	1	0.1	86.1	6.5639	0.5533
2015	12	18	9	5	10	0.3	1	0.09	88	6.5639	0.5342
2015	12	18	9	15	10	0.3	1	0.07	35.2	6.5639	0.2289
2015	12	18	9	25	10	0.3	1	0.11	86.4	6.5639	0.6105
2015	12	18	9	35	10	0.3	1	0.04	51.3	6.5639	0.1908
2015	12	18	9	45	10	0.3	1	0.09	92	6.5639	0.5342
2015	12	18	9	55	10	0.3	1	0.25	99.7	6.5639	1.45
2015	12	18	10	5	10	0.3	1	0.25	119.6	6.5639	1.2783
2015	12	18	10	15	10	0.3	1	0.23	131.5	6.5639	0.9921
2015	12	18	10	25	10	0.3	1	0.23	111.3	6.5639	1.221
2015	12	18	10	35	10	0.3	1	0.17	96.7	6.5639	0.973
2015	12	18	10	45	10	0.3	1	0.25	107.3	6.5639	1.4118
2015	12	18	10	55	10	0.3	1	0.24	114.1	6.5639	1.2783
2015	12	18	11	5	10	0.3	1	0.13	131.9	6.5639	0.5533
2015	12	18	11	15	10	0.3	1	0.14	129.3	6.5639	0.6296
2015	12	18	11	25	10	0.3	1	0.17	117.1	6.5639	0.8585
2015	12	18	11	35	10	0.3	1	0.25	112.8	6.5639	1.3164
2015	12	18	11	45	10	0.3	1	0.29	128.7	6.5639	1.3355
2015	12	18	11	55	10	0.3	1	0.2	119.5	6.5639	1.0111
2015	12	18	12	5	10	0.3	1	0.11	112.1	6.5639	0.6105
2015	12	18	12	15	10	0.3	1	0.13	100.2	6.5639	0.744
2015	12	18	12	25	10	0.3	1	0.16	95.7	6.5639	0.9539
2015	12	18	12	35	10	0.3	1	0.14	107.6	6.5639	0.7822
2015	12	18	12	45	10	0.3	1	0.21	123.7	6.5639	1.0302
2015	12	18	12	55	10	0.3	1	0.24	96.9	6.5639	1.4117
2015	12	18	13	5	10	0.3	1	0.25	114.9	6.5639	1.3164
2015	12	18	13	15	10	0.3	1	0.21	107	6.5639	1.1828
2015	12	18	13	25	10	0.3	1	0.21	100.8	6.5639	1.2019
2015	12	18	13	35	10	0.3	1	0.17	108.8	6.5639	0.9539

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	13	45	10	0.3	1	0.25	121	6.5445	1.2361
2015	12	18	13	55	10	0.3	1	0.19	114	6.5639	1.0302
2015	12	18	14	5	10	0.3	1	0.19	125.7	6.5639	0.8776
2015	12	18	14	15	10	0.3	1	0.28	85.2	6.5639	1.6025
2015	12	18	14	25	10	0.3	1	0.23	104.2	6.5639	1.2782
2015	12	18	14	35	10	0.3	1	0.22	99.3	6.5639	1.2782
2015	12	18	14	45	10	0.3	1	0.2	87.2	6.5639	1.1637
2015	12	18	14	55	10	0.3	1	0.21	86.4	6.5639	1.2019
2015	12	18	15	5	10	0.3	1	0.2	108.1	6.5639	1.1065
2015	12	18	15	15	10	0.3	1	0.26	92.2	6.5639	1.5071
2015	12	18	15	25	10	0.3	1	0.28	90	6.5639	1.6215
2015	12	18	15	35	10	0.3	1	0.2	73	6.5639	1.1255
2015	12	18	15	45	10	0.3	1	0.21	92.7	6.5639	1.2209
2015	12	18	15	55	10	0.3	1	0.21	109.3	6.5639	1.1446
2015	12	18	16	5	10	0.3	1	0.25	90	6.5639	1.4308
2015	12	18	16	15	10	0.3	1	0.14	113	6.5639	0.7631
2015	12	18	16	25	10	0.3	1	0.17	87.8	6.5639	0.9729
2015	12	18	16	35	10	0.3	1	0.13	115.3	6.5639	0.6868
2015	12	18	16	45	10	0.3	1	0.26	105.4	6.5639	1.4498
2015	12	18	16	55	10	0.3	1	0.24	104.8	6.5639	1.3735
2015	12	18	17	5	10	0.3	1	0.19	113.1	6.5445	1.0269
2015	12	18	17	15	10	0.3	1	0.25	110.6	6.5445	1.3692
2015	12	18	17	25	10	0.3	1	0.1	124.7	6.5445	0.4944
2015	12	18	17	35	10	0.3	1	0.2	90	6.5445	1.141
2015	12	18	17	45	10	0.3	1	0.23	90	6.5445	1.3312
2015	12	18	17	55	10	0.3	1	0.2	97.7	6.5445	1.122
2015	12	18	18	5	10	0.3	1	0.17	83.5	6.5445	1.0079
2015	12	18	18	15	10	0.3	1	0.33	126.1	6.5445	1.5403
2015	12	18	18	25	10	0.3	1	0.16	93.4	6.5445	0.9508
2015	12	18	18	35	10	0.3	1	0.26	105.4	6.5445	1.4453
2015	12	18	18	45	10	0.3	1	0.17	81.1	6.5445	0.9698
2015	12	18	18	55	10	0.3	1	0.27	92.1	6.5445	1.5593
2015	12	18	19	5	10	0.3	1	0.23	103.8	6.5445	1.3121
2015	12	18	19	15	10	0.3	1	0.24	103.3	6.5639	1.3735
2015	12	18	19	25	10	0.3	1	0.29	103.7	6.5445	1.6354
2015	12	18	19	35	10	0.3	1	0.21	104.3	6.5639	1.2018
2015	12	18	19	45	10	0.3	1	0.19	93.9	6.5445	1.122
2015	12	18	19	55	10	0.3	1	0.24	122.4	6.5445	1.198
2015	12	18	20	5	10	0.3	1	0.18	119.4	6.5639	0.9157
2015	12	18	20	15	10	0.3	1	0.16	141	6.5639	0.5723
2015	12	18	20	25	10	0.3	1	0.22	123.7	6.5639	1.0874
2015	12	18	20	35	10	0.3	1	0.26	122.3	6.5639	1.2972
2015	12	18	20	45	10	0.3	1	0.23	116.6	6.5639	1.1828
2015	12	18	20	55	10	0.3	1	0.14	140.5	6.5639	0.5342
2015	12	18	21	5	10	0.3	1	0.24	115.9	6.5639	1.2591
2015	12	18	21	15	10	0.3	1	0.22	108.4	6.5639	1.2019

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	21	25	10	0.3	1	0.25	118.9	6.5639	1.2782
2015	12	18	21	35	10	0.3	1	0.22	106.8	6.5639	1.2019
2015	12	18	21	45	10	0.3	1	0.29	115.4	6.5639	1.5262
2015	12	18	21	55	10	0.3	1	0.25	121	6.5639	1.24
2015	12	18	22	5	10	0.3	1	0.25	116.6	6.5639	1.2972
2015	12	18	22	15	10	0.3	1	0.22	117.3	6.5639	1.1446
2015	12	18	22	25	10	0.3	1	0.23	125.5	6.5639	1.0683
2015	12	18	22	35	10	0.3	1	0.23	129.2	6.5639	1.0302
2015	12	18	22	45	10	0.3	1	0.25	122	6.5639	1.2209
2015	12	18	22	55	10	0.3	1	0.22	119.6	6.5639	1.1065
2015	12	18	23	5	10	0.3	1	0.22	127	6.5639	1.0111
2015	12	18	23	15	10	0.3	1	0.17	135	6.5639	0.7059
2015	12	18	23	25	10	0.3	1	0.24	113.4	6.5639	1.2782
2015	12	18	23	35	10	0.3	1	0.19	112.5	6.5639	1.0111
2015	12	18	23	45	10	0.3	1	0.18	94.2	6.5639	1.0302
2015	12	18	23	55	10	0.3	1	0.06	83.7	6.5639	0.3434
2015	12	19	0	5	10	0.3	1	0.09	106.5	6.5639	0.5151
2015	12	19	0	15	10	0.3	1	0.09	129	6.5639	0.4006
2015	12	19	0	25	10	0.3	1	0.11	91.6	6.5639	0.6677
2015	12	19	0	35	10	0.3	1	0.18	90	6.5639	1.0302
2015	12	19	0	45	10	0.3	1	0.15	101.3	6.5639	0.8585
2015	12	19	0	55	10	0.3	1	0.15	106.5	6.5639	0.8394
2015	12	19	1	5	10	0.3	1	0.17	96.5	6.5639	1.0111
2015	12	19	1	15	10	0.3	1	0.2	103.6	6.5445	1.103
2015	12	19	1	25	10	0.3	1	0.18	110.4	6.5445	0.9699
2015	12	19	1	35	10	0.3	1	0.27	114	6.5639	1.4118
2015	12	19	1	45	10	0.3	1	0.07	143.1	6.5639	0.2289
2015	12	19	1	55	10	0.3	1	0.18	89	6.5445	1.065
2015	12	19	2	5	10	0.3	1	0.16	102.9	6.5639	0.9157
2015	12	19	2	15	10	0.3	1	0.21	106.4	6.5445	1.1601
2015	12	19	2	25	10	0.3	1	0.18	99.5	6.5445	1.027
2015	12	19	2	35	10	0.3	1	0.24	110.9	6.5445	1.2932
2015	12	19	2	45	10	0.3	1	0.22	112.3	6.5445	1.1601
2015	12	19	2	55	10	0.3	1	0.19	111.3	6.5445	1.027
2015	12	19	3	5	10	0.3	1	0.22	104.4	6.5445	1.2552
2015	12	19	3	15	10	0.3	1	0.23	118	6.5445	1.1791
2015	12	19	3	25	10	0.3	1	0.24	108.2	6.5445	1.3313
2015	12	19	3	35	10	0.3	1	0.26	121.1	6.5445	1.2932
2015	12	19	3	45	10	0.3	1	0.22	107.9	6.5445	1.2362
2015	12	19	3	55	10	0.3	1	0.29	124.4	6.5445	1.3883
2015	12	19	4	5	10	0.3	1	0.26	120.8	6.5445	1.2742
2015	12	19	4	15	10	0.3	1	0.26	135	6.5445	1.084
2015	12	19	4	25	10	0.3	1	0.15	113.8	6.5445	0.8178
2015	12	19	4	35	10	0.3	1	0.19	128.8	6.5639	0.8776
2015	12	19	4	45	10	0.3	1	0.19	103.3	6.5445	1.046
2015	12	19	4	55	10	0.3	1	0.2	105.2	6.5445	1.1221

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	5	5	10	0.3	1	0.17	135.8	6.5445	0.6847
2015	12	19	5	15	10	0.3	1	0.26	118.2	6.5445	1.3123
2015	12	19	5	25	10	0.3	1	0.17	75.1	6.5445	0.9319
2015	12	19	5	35	10	0.3	1	0.22	113.1	6.5445	1.1601
2015	12	19	5	45	10	0.3	1	0.18	130.5	6.5445	0.7797
2015	12	19	5	55	10	0.3	1	0.17	111.2	6.5445	0.9319
2015	12	19	6	5	10	0.3	1	0.24	119.7	6.5445	1.1981
2015	12	19	6	15	10	0.3	1	0.18	130.5	6.5445	0.7797
2015	12	19	6	25	10	0.3	1	0.21	111.8	6.5445	1.1411
2015	12	19	6	35	10	0.3	1	0.23	124.1	6.5445	1.1221
2015	12	19	6	45	10	0.3	1	0.2	132.3	6.5445	0.8368
2015	12	19	6	55	10	0.3	1	0.18	115.2	6.5445	0.9699
2015	12	19	7	5	10	0.3	1	0.24	136.1	6.5445	0.9509
2015	12	19	7	15	10	0.3	1	0.22	103.8	6.5445	1.2362
2015	12	19	7	25	10	0.3	1	0.29	108.8	6.5445	1.6166
2015	12	19	7	35	10	0.3	1	0.25	114.6	6.5445	1.3313
2015	12	19	7	45	10	0.3	1	0.21	111	6.5445	1.1411
2015	12	19	7	55	10	0.3	1	0.25	127.9	6.5445	1.1221
2015	12	19	8	5	10	0.3	1	0.24	101.9	6.5445	1.3503
2015	12	19	8	15	10	0.3	1	0.3	122.5	6.5445	1.4644
2015	12	19	8	25	10	0.3	1	0.19	114	6.5445	1.027
2015	12	19	8	35	10	0.3	1	0.26	130.8	6.5445	1.1221
2015	12	19	8	45	10	0.3	1	0.16	118.6	6.5445	0.8368
2015	12	19	8	55	10	0.3	1	0.27	116.3	6.5445	1.3883
2015	12	19	9	5	10	0.3	1	0.29	129.5	6.5445	1.2932
2015	12	19	9	15	10	0.3	1	0.24	120.4	6.5445	1.1982
2015	12	19	9	25	10	0.3	1	0.23	125.7	6.5445	1.084
2015	12	19	9	35	10	0.3	1	0.19	118.8	6.5445	0.9699
2015	12	19	9	45	10	0.3	1	0.21	116.6	6.5445	1.065
2015	12	19	9	55	10	0.3	1	0.13	123.3	6.5445	0.6086
2015	12	19	10	5	10	0.3	1	0.19	127.5	6.5445	0.8939
2015	12	19	10	15	10	0.3	1	0.16	104.3	6.5445	0.8939
2015	12	19	10	25	10	0.3	1	0.15	127.9	6.5445	0.6847
2015	12	19	10	35	10	0.3	1	0.23	117.3	6.5445	1.1791
2015	12	19	10	45	10	0.3	1	0.19	114.8	6.5445	0.9889
2015	12	19	10	55	10	0.3	1	0.25	135	6.5445	1.027
2015	12	19	11	5	10	0.3	1	0.24	116.9	6.5445	1.2362
2015	12	19	11	15	10	0.3	1	0.25	112.2	6.5445	1.3503
2015	12	19	11	25	10	0.3	1	0.25	135	6.5445	1.027
2015	12	19	11	35	10	0.3	1	0.16	128.3	6.5445	0.7227
2015	12	19	11	45	10	0.3	1	0.23	118.7	6.5445	1.1791
2015	12	19	11	55	10	0.3	1	0.26	103	6.5445	1.4834
2015	12	19	12	5	10	0.3	1	0.21	97.2	6.5445	1.1981
2015	12	19	12	15	10	0.3	1	0.2	103.6	6.5445	1.103
2015	12	19	12	25	10	0.3	1	0.21	108.7	6.5445	1.1791
2015	12	19	12	35	10	0.3	1	0.28	120.8	6.5445	1.3693

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	12	45	10	0.3	1	0.24	106.5	6.5445	1.3502
2015	12	19	12	55	10	0.3	1	0.23	121.2	6.5445	1.1601
2015	12	19	13	5	10	0.3	1	0.22	122.3	6.5445	1.084
2015	12	19	13	15	10	0.3	1	0.17	103.5	6.5445	0.9509
2015	12	19	13	25	10	0.3	1	0.14	95.2	6.5445	0.8368
2015	12	19	13	35	10	0.3	1	0.11	68.2	6.5445	0.5705
2015	12	19	13	45	10	0.3	1	0.11	15.7	6.5445	0.1712
2015	12	19	13	55	10	0.3	1	0.1	45	6.5445	0.4184
2015	12	19	14	5	10	0.3	1	0.12	83.8	6.5445	0.7036
2015	12	19	14	15	10	0.3	1	0.15	96.5	6.5445	0.8368
2015	12	19	14	25	10	0.3	1	0.17	117.6	6.5445	0.8748
2015	12	19	14	35	10	0.3	1	0.11	112.8	6.5445	0.5895
2015	12	19	14	45	10	0.3	1	0.18	93.2	6.5445	1.0269
2015	12	19	14	55	10	0.3	1	0.18	107.1	6.5445	0.9889
2015	12	19	15	5	10	0.3	1	0.3	116	6.5445	1.5594
2015	12	19	15	15	10	0.3	1	0.26	107.7	6.5445	1.4263
2015	12	19	15	25	10	0.3	1	0.31	105.5	6.5445	1.7115
2015	12	19	15	35	10	0.3	1	0.26	127.2	6.5445	1.179
2015	12	19	15	45	10	0.3	1	0.29	119.5	6.5445	1.4453
2015	12	19	15	55	10	0.3	1	0.24	125.6	6.5445	1.141
2015	12	19	16	5	10	0.3	1	0.32	117.1	6.5445	1.6354
2015	12	19	16	15	10	0.3	1	0.28	110.9	6.5252	1.5355
2015	12	19	16	25	10	0.3	1	0.29	106.6	6.5252	1.5923
2015	12	19	16	35	10	0.3	1	0.26	107	6.5252	1.4217
2015	12	19	16	45	10	0.3	1	0.26	123.3	6.5252	1.2701
2015	12	19	16	55	10	0.3	1	0.22	101.3	6.5252	1.2322
2015	12	19	17	5	10	0.3	1	0.27	98.4	6.5252	1.5355
2015	12	19	17	15	10	0.3	1	0.23	104.2	6.5252	1.2701
2015	12	19	17	25	10	0.3	1	0.19	105.9	6.5252	1.0616
2015	12	19	17	35	10	0.3	1	0.23	90	6.5252	1.3269
2015	12	19	17	45	10	0.3	1	0.17	85.5	6.5252	0.9668
2015	12	19	17	55	10	0.3	1	0.2	86.3	6.5252	1.1753
2015	12	19	18	5	10	0.3	1	0.25	88.5	6.5252	1.4407
2015	12	19	18	15	10	0.3	1	0.19	99.1	6.5252	1.0615
2015	12	19	18	25	10	0.3	1	0.25	96.8	6.5252	1.4217
2015	12	19	18	35	10	0.3	1	0.26	101.7	6.5252	1.4596
2015	12	19	18	45	10	0.3	1	0.29	95.3	6.5252	1.6492
2015	12	19	18	55	10	0.3	1	0.33	112.4	6.5252	1.744
2015	12	19	19	5	10	0.3	1	0.21	92.7	6.5252	1.1942
2015	12	19	19	15	10	0.3	1	0.24	113.8	6.5252	1.289
2015	12	19	19	25	10	0.3	1	0.25	109.1	6.5252	1.3648
2015	12	19	19	35	10	0.3	1	0.11	81.6	6.5445	0.6466
2015	12	19	19	45	10	0.3	1	0.22	110.9	6.5445	1.198
2015	12	19	19	55	10	0.3	1	0.24	110.4	6.5445	1.3312
2015	12	19	20	5	10	0.3	1	0.2	102.4	6.5445	1.122
2015	12	19	20	15	10	0.3	1	0.25	109.1	6.5445	1.3692

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	20	25	10	0.3	1	0.3	118.8	6.5445	1.5213
2015	12	19	20	35	10	0.3	1	0.3	117.1	6.5445	1.5594
2015	12	19	20	45	10	0.3	1	0.27	126.2	6.5445	1.2741
2015	12	19	20	55	10	0.3	1	0.23	104	6.5445	1.2931
2015	12	19	21	5	10	0.3	1	0.27	113.5	6.5445	1.4453
2015	12	19	21	15	10	0.3	1	0.26	115.9	6.5445	1.3312
2015	12	19	21	25	10	0.3	1	0.22	108.4	6.5445	1.198
2015	12	19	21	35	10	0.3	1	0.24	102.5	6.5445	1.3692
2015	12	19	21	45	10	0.3	1	0.21	104.7	6.5445	1.16
2015	12	19	21	55	10	0.3	1	0.24	107.7	6.5445	1.3121
2015	12	19	22	5	10	0.3	1	0.36	116.1	6.5445	1.8636
2015	12	19	22	15	10	0.3	1	0.32	120.5	6.5445	1.6164
2015	12	19	22	25	10	0.3	1	0.21	102.5	6.5445	1.198
2015	12	19	22	35	10	0.3	1	0.27	117.8	6.5445	1.3692
2015	12	19	22	45	10	0.3	1	0.21	126.2	6.5445	0.9889
2015	12	19	22	55	10	0.3	1	0.32	127.1	6.5445	1.4833
2015	12	19	23	5	10	0.3	1	0.33	128.6	6.5445	1.5023
2015	12	19	23	15	10	0.3	1	0.4	123.6	6.5445	1.9207
2015	12	19	23	25	10	0.3	1	0.4	132.4	6.5445	1.7305
2015	12	19	23	35	10	0.3	1	0.29	120.3	6.5445	1.4643
2015	12	19	23	45	10	0.3	1	0.33	114.5	6.5445	1.7496
2015	12	19	23	55	10	0.3	1	0.26	121.5	6.5445	1.2741
2015	12	20	0	5	10	0.3	1	0.28	121.3	6.5445	1.4073
2015	12	20	0	15	10	0.3	1	0.3	130.1	6.5445	1.3312
2015	12	20	0	25	10	0.3	1	0.21	109.8	6.5445	1.16
2015	12	20	0	35	10	0.3	1	0.15	93.7	6.5445	0.8748
2015	12	20	0	45	10	0.3	1	0.13	51.1	6.5445	0.5895
2015	12	20	0	55	10	0.3	1	0.06	42.7	6.5445	0.2282
2015	12	20	1	5	10	0.3	1	0.07	59.9	6.5445	0.3613
2015	12	20	1	15	10	0.3	1	0.1	58.4	6.5445	0.4944
2015	12	20	1	25	10	0.3	1	0.04	4.8	6.5445	0.019
2015	12	20	1	35	10	0.3	1	0.15	52.4	6.5445	0.6656
2015	12	20	1	45	10	0.3	1	0.07	63.4	6.5445	0.3803
2015	12	20	1	55	10	0.3	1	0.15	113.8	6.5445	0.8177
2015	12	20	2	5	10	0.3	1	0.1	114.1	6.5445	0.5515
2015	12	20	2	15	10	0.3	1	0.13	73.9	6.5445	0.7227
2015	12	20	2	25	10	0.3	1	0.19	119.6	6.5445	0.9699
2015	12	20	2	35	10	0.3	1	0.2	104.5	6.5445	1.103
2015	12	20	2	45	10	0.3	1	0.26	104.7	6.5445	1.4453
2015	12	20	2	55	10	0.3	1	0.18	115.2	6.5445	0.9699
2015	12	20	3	5	10	0.3	1	0.16	109.9	6.5445	0.8938
2015	12	20	3	15	10	0.3	1	0.23	107.4	6.5445	1.2742
2015	12	20	3	25	10	0.3	1	0.22	109.5	6.5445	1.1791
2015	12	20	3	35	10	0.3	1	0.22	88.3	6.5445	1.2932
2015	12	20	3	45	10	0.3	1	0.12	97.9	6.5445	0.6846
2015	12	20	3	55	10	0.3	1	0.2	109	6.5445	1.103

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	4	5	10	0.3	1	0.28	115.3	6.5445	1.4453
2015	12	20	4	15	10	0.3	1	0.3	118.3	6.5445	1.5214
2015	12	20	4	25	10	0.3	1	0.21	125.6	6.5445	1.0079
2015	12	20	4	35	10	0.3	1	0.24	100.1	6.5445	1.3883
2015	12	20	4	45	10	0.3	1	0.23	127	6.5445	1.084
2015	12	20	4	55	10	0.3	1	0.25	99.1	6.5445	1.4263
2015	12	20	5	5	10	0.3	1	0.23	110	6.5445	1.2552
2015	12	20	5	15	10	0.3	1	0.29	128.2	6.5445	1.3312
2015	12	20	5	25	10	0.3	1	0.17	112.6	6.5445	0.9128
2015	12	20	5	35	10	0.3	1	0.2	117	6.5445	1.0079
2015	12	20	5	45	10	0.3	1	0.18	115.2	6.5445	0.9699
2015	12	20	5	55	10	0.3	1	0.22	123	6.5445	1.084
2015	12	20	6	5	10	0.3	1	0.23	117.3	6.5445	1.1791
2015	12	20	6	15	10	0.3	1	0.17	128.8	6.5445	0.7797
2015	12	20	6	25	10	0.3	1	0.17	98.9	6.5252	0.9668
2015	12	20	6	35	10	0.3	1	0.25	119.6	6.5445	1.2361
2015	12	20	6	45	10	0.3	1	0.09	112.6	6.5252	0.455
2015	12	20	6	55	10	0.3	1	0.17	145.1	6.5252	0.5687
2015	12	20	7	5	10	0.3	1	0.15	125.1	6.5445	0.7037
2015	12	20	7	15	10	0.3	1	0.05	71.6	6.5252	0.2844
2015	12	20	7	25	10	0.3	1	0.05	127.6	6.5252	0.2464
2015	12	20	7	35	10	0.3	1	0.1	105.9	6.5252	0.5308
2015	12	20	7	45	10	0.3	1	0.07	135	6.5445	0.3043
2015	12	20	7	55	10	0.3	1	0.2	145.2	6.5252	0.6446
2015	12	20	8	5	10	0.3	1	0.12	143.7	6.5445	0.4184
2015	12	20	8	15	10	0.3	1	0.06	171	6.5252	0.0569
2015	12	20	8	25	10	0.3	1	0.08	139.9	6.5445	0.3043
2015	12	20	8	35	10	0.3	1	0.05	166	6.5252	0.0758
2015	12	20	8	45	10	0.3	1	0.24	146.5	6.5252	0.7773
2015	12	20	8	55	10	0.3	1	0.28	128.9	6.5252	1.2701
2015	12	20	9	5	10	0.3	1	0.22	123	6.5445	1.084
2015	12	20	9	15	10	0.3	1	0.2	128.4	6.5252	0.91
2015	12	20	9	25	10	0.3	1	0.1	104.9	6.5252	0.5687
2015	12	20	9	35	10	0.3	1	0.18	115.1	6.5445	0.9319
2015	12	20	9	45	10	0.3	1	0.2	129.6	6.5252	0.872
2015	12	20	9	55	10	0.3	1	0.24	116.9	6.5252	1.2322
2015	12	20	10	5	10	0.3	1	0.24	107.7	6.5445	1.3122
2015	12	20	10	15	10	0.3	1	0.23	108.4	6.5252	1.2512
2015	12	20	10	25	10	0.3	1	0.23	116.6	6.5252	1.2133
2015	12	20	10	35	10	0.3	1	0.19	117.9	6.5252	0.9668
2015	12	20	10	45	10	0.3	1	0.19	122.6	6.5252	0.9479
2015	12	20	10	55	10	0.3	1	0.24	112.4	6.5252	1.2891
2015	12	20	11	5	10	0.3	1	0.17	137.3	6.5252	0.6824
2015	12	20	11	15	10	0.3	1	0.19	98.8	6.5252	1.0995
2015	12	20	11	25	10	0.3	1	0.21	109	6.5252	1.1564
2015	12	20	11	35	10	0.3	1	0.15	107.3	6.5252	0.8531

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	11	45	10	0.3	1	0.2	109.9	6.5252	1.0995
2015	12	20	11	55	10	0.3	1	0.16	91.1	6.5445	0.9509
2015	12	20	12	5	10	0.3	1	0.19	112.2	6.5445	1.0269
2015	12	20	12	15	10	0.3	1	0.16	142.7	6.5445	0.5515
2015	12	20	12	25	10	0.3	1	0.22	120	6.5445	1.122
2015	12	20	12	35	10	0.3	1	0.17	118.1	6.5445	0.8558
2015	12	20	12	45	10	0.3	1	0.16	106.3	6.5445	0.9128
2015	12	20	12	55	10	0.3	1	0.2	110.6	6.5445	1.0649
2015	12	20	13	5	10	0.3	1	0.18	113.7	6.5445	0.9508
2015	12	20	13	15	10	0.3	1	0.17	100.2	6.5445	0.9508
2015	12	20	13	25	10	0.3	1	0.22	102	6.5445	1.2551
2015	12	20	13	35	10	0.3	1	0.28	104	6.5445	1.5974
2015	12	20	13	45	10	0.3	1	0.19	111.8	6.5445	1.0459
2015	12	20	13	55	10	0.3	1	0.23	99.2	6.5445	1.2931
2015	12	20	14	5	10	0.3	1	0.22	109.2	6.5445	1.198
2015	12	20	14	15	10	0.3	1	0.25	107.5	6.5445	1.3882
2015	12	20	14	25	10	0.3	1	0.16	109.9	6.5445	0.8938
2015	12	20	14	35	10	0.3	1	0.16	104.3	6.5445	0.8938
2015	12	20	14	45	10	0.3	1	0.16	92.3	6.5445	0.9318
2015	12	20	14	55	10	0.3	1	0.17	81.3	6.5445	0.9888
2015	12	20	15	5	10	0.3	1	0.24	85.2	6.5445	1.3692
2015	12	20	15	15	10	0.3	1	0.16	98.5	6.5445	0.8938
2015	12	20	15	25	10	0.3	1	0.14	94.1	6.5445	0.7987
2015	12	20	15	35	10	0.3	1	0.16	77.1	6.5639	0.9157
2015	12	20	15	45	10	0.3	1	0.23	100.7	6.5639	1.3163
2015	12	20	15	55	10	0.3	1	0.25	87	6.5639	1.4689
2015	12	20	16	5	10	0.3	1	0.2	110.2	6.5639	1.0874
2015	12	20	16	15	10	0.3	1	0.2	94.6	6.5639	1.1827
2015	12	20	16	25	10	0.3	1	0.19	82.9	6.5639	1.0683
2015	12	20	16	35	10	0.3	1	0.19	90	6.5639	1.0874
2015	12	20	16	45	10	0.3	1	0.19	83.2	6.5639	1.1255
2015	12	20	16	55	10	0.3	1	0.2	92.8	6.5639	1.1637
2015	12	20	17	5	10	0.3	1	0.13	78.1	6.5639	0.7249
2015	12	20	17	15	10	0.3	1	0.19	89	6.5639	1.1064
2015	12	20	17	25	10	0.3	1	0.17	95.6	6.5639	0.9729
2015	12	20	17	35	10	0.3	1	0.18	88	6.5639	1.0683
2015	12	20	17	45	10	0.3	1	0.14	97	6.5639	0.7821
2015	12	20	17	55	10	0.3	1	0.15	86.2	6.5639	0.8584
2015	12	20	18	5	10	0.3	1	0.21	83.8	6.5639	1.2209
2015	12	20	18	15	10	0.3	1	0.2	107	6.5832	1.1291
2015	12	20	18	25	10	0.3	1	0.23	76.8	6.5832	1.3013
2015	12	20	18	35	10	0.3	1	0.19	87	6.5832	1.1099
2015	12	20	18	45	10	0.3	1	0.17	124	6.5832	0.8229
2015	12	20	18	55	10	0.3	1	0.21	90	6.5832	1.2248
2015	12	20	19	5	10	0.3	1	0.2	106.3	6.5832	1.1099
2015	12	20	19	15	10	0.3	1	0.23	122.5	6.5832	1.1099

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	19	25	10	0.3	1	0.11	112.1	6.5832	0.6124
2015	12	20	19	35	10	0.3	1	0.18	102.3	6.5832	1.0525
2015	12	20	19	45	10	0.3	1	0.21	113	6.5832	1.1291
2015	12	20	19	55	10	0.3	1	0.22	93.4	6.5832	1.3013
2015	12	20	20	5	10	0.3	1	0.14	117.1	6.5832	0.7463
2015	12	20	20	15	10	0.3	1	0.16	105.8	6.5832	0.8803
2015	12	20	20	25	10	0.3	1	0.14	77.9	6.5832	0.8038
2015	12	20	20	35	10	0.3	1	0.24	130	6.5832	1.0717
2015	12	20	20	45	10	0.3	1	0.19	103.3	6.6026	1.0559
2015	12	20	20	55	10	0.3	1	0.15	101.6	6.6026	0.8447
2015	12	20	21	5	10	0.3	1	0.15	112	6.6026	0.8063
2015	12	20	21	15	10	0.3	1	0.15	96.2	6.6026	0.8831
2015	12	20	21	25	10	0.3	1	0.23	119.8	6.6026	1.171
2015	12	20	21	35	10	0.3	1	0.19	94.8	6.6026	1.1327
2015	12	20	21	45	10	0.3	1	0.18	104	6.6026	0.9983
2015	12	20	21	55	10	0.3	1	0.25	99	6.6026	1.459
2015	12	20	22	5	10	0.3	1	0.22	106.8	6.6026	1.2094
2015	12	20	22	15	10	0.3	1	0.23	112.2	6.6026	1.267
2015	12	20	22	25	10	0.3	1	0.22	120.4	6.6026	1.1135
2015	12	20	22	35	10	0.3	1	0.23	122.8	6.6026	1.1327
2015	12	20	22	45	10	0.3	1	0.19	121	6.6026	0.9599
2015	12	20	22	55	10	0.3	1	0.23	106.1	6.6026	1.2671
2015	12	20	23	5	10	0.3	1	0.18	108.1	6.6026	0.9983
2015	12	20	23	15	10	0.3	1	0.22	108.4	6.6026	1.2095
2015	12	20	23	25	10	0.3	1	0.18	95.2	6.6026	1.0559
2015	12	20	23	35	10	0.3	1	0.23	133.2	6.6026	0.9599
2015	12	20	23	45	10	0.3	1	0.23	107.2	6.6026	1.3055
2015	12	20	23	55	10	0.3	1	0.18	106.5	6.6026	1.0367
2015	12	21	0	5	10	0.3	1	0.2	107.5	6.6026	1.0943
2015	12	21	0	15	10	0.3	1	0.22	111.6	6.6026	1.2095
2015	12	21	0	25	10	0.3	1	0.2	102.4	6.6026	1.1327
2015	12	21	0	35	10	0.3	1	0.21	118.5	6.6026	1.0943
2015	12	21	0	45	10	0.3	1	0.24	121.1	6.6026	1.2095
2015	12	21	0	55	10	0.3	1	0.23	111	6.6026	1.2479
2015	12	21	1	5	10	0.3	1	0.2	100.2	6.6026	1.1711
2015	12	21	1	15	10	0.3	1	0.22	111.5	6.6026	1.1711
2015	12	21	1	25	10	0.3	1	0.25	113.6	6.6026	1.3631
2015	12	21	1	35	10	0.3	1	0.17	105.6	6.6026	0.9599
2015	12	21	1	45	10	0.3	1	0.19	115.7	6.6026	0.9983
2015	12	21	1	55	10	0.3	1	0.2	107.2	6.6026	1.1135
2015	12	21	2	5	10	0.3	1	0.25	112.9	6.6026	1.3631
2015	12	21	2	15	10	0.3	1	0.24	101	6.6026	1.3823
2015	12	21	2	25	10	0.3	1	0.29	124	6.6026	1.4207
2015	12	21	2	35	10	0.3	1	0.17	117.6	6.6026	0.8831
2015	12	21	2	45	10	0.3	1	0.17	108.8	6.6026	0.9599
2015	12	21	2	55	10	0.3	1	0.24	123.5	6.6026	1.1903

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	3	5	10	0.3	1	0.22	122.3	6.6026	1.0943
2015	12	21	3	15	10	0.3	1	0.15	110.4	6.6026	0.8255
2015	12	21	3	25	10	0.3	1	0.28	122.4	6.6026	1.3631
2015	12	21	3	35	10	0.3	1	0.25	123.9	6.6026	1.2287
2015	12	21	3	45	10	0.3	1	0.27	124.5	6.6026	1.2863
2015	12	21	3	55	10	0.3	1	0.26	110.5	6.6026	1.4399
2015	12	21	4	5	10	0.3	1	0.26	109.8	6.5832	1.4354
2015	12	21	4	15	10	0.3	1	0.2	108.7	6.5832	1.1292
2015	12	21	4	25	10	0.3	1	0.2	118.2	6.5832	1.0335
2015	12	21	4	35	10	0.3	1	0.18	95.3	6.5832	1.0335
2015	12	21	4	45	10	0.3	1	0.28	119.8	6.5832	1.4354
2015	12	21	4	55	10	0.3	1	0.21	100.1	6.5832	1.1866
2015	12	21	5	5	10	0.3	1	0.26	104.6	6.5832	1.4736
2015	12	21	5	15	10	0.3	1	0.23	97.3	6.5832	1.3397
2015	12	21	5	25	10	0.3	1	0.21	102.3	6.5832	1.2248
2015	12	21	5	35	10	0.3	1	0.21	98	6.5832	1.2248
2015	12	21	5	45	10	0.3	1	0.22	107.1	6.5832	1.244
2015	12	21	5	55	10	0.3	1	0.25	119.6	6.5832	1.244
2015	12	21	6	5	10	0.3	1	0.25	113.2	6.5832	1.3397
2015	12	21	6	15	10	0.3	1	0.25	102	6.5832	1.4354
2015	12	21	6	25	10	0.3	1	0.16	112.4	6.5832	0.8804
2015	12	21	6	35	10	0.3	1	0.24	100.2	6.5832	1.378
2015	12	21	6	45	10	0.3	1	0.23	116.6	6.5832	1.2248
2015	12	21	6	55	10	0.3	1	0.22	123.9	6.5832	1.0526
2015	12	21	7	5	10	0.3	1	0.28	114.8	6.5832	1.4928
2015	12	21	7	15	10	0.3	1	0.21	113.4	6.5832	1.1483
2015	12	21	7	25	10	0.3	1	0.23	110.3	6.5832	1.244
2015	12	21	7	35	10	0.3	1	0.24	100.2	6.5832	1.378
2015	12	21	7	45	10	0.3	1	0.26	110	6.5832	1.4162
2015	12	21	7	55	10	0.3	1	0.25	121.8	6.5832	1.2631
2015	12	21	8	5	10	0.3	1	0.22	118.8	6.5832	1.1483
2015	12	21	8	15	10	0.3	1	0.2	115.3	6.5832	1.0526
2015	12	21	8	25	10	0.3	1	0.22	98.7	6.5832	1.244
2015	12	21	8	35	10	0.3	1	0.25	107.3	6.5832	1.4162
2015	12	21	8	45	10	0.3	1	0.26	115.9	6.5832	1.3397
2015	12	21	8	55	10	0.3	1	0.26	115.9	6.5832	1.3779
2015	12	21	9	5	10	0.3	1	0.21	128.1	6.5832	0.976
2015	12	21	9	15	10	0.3	1	0.25	99.8	6.5832	1.4354
2015	12	21	9	25	10	0.3	1	0.24	110.9	6.5832	1.3014
2015	12	21	9	35	10	0.3	1	0.25	107.5	6.5832	1.3971
2015	12	21	9	45	10	0.3	1	0.21	118.5	6.5832	1.0909
2015	12	21	9	55	10	0.3	1	0.19	101.7	6.5832	1.11
2015	12	21	10	5	10	0.3	1	0.23	103.8	6.5832	1.3205
2015	12	21	10	15	10	0.3	1	0.23	109.7	6.5832	1.2822
2015	12	21	10	25	10	0.3	1	0.15	108.8	6.5832	0.8421
2015	12	21	10	35	10	0.3	1	0.23	114.4	6.5832	1.2248

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	10	45	10	0.3	1	0.21	103.4	6.5832	1.2057
2015	12	21	10	55	10	0.3	1	0.2	119.1	6.5832	1.0334
2015	12	21	11	5	10	0.3	1	0.17	118	6.5832	0.8995
2015	12	21	11	15	10	0.3	1	0.2	96.4	6.5832	1.1865
2015	12	21	11	25	10	0.3	1	0.26	115.9	6.5832	1.3779
2015	12	21	11	35	10	0.3	1	0.26	95.1	6.5832	1.4927
2015	12	21	11	45	10	0.3	1	0.2	114.4	6.5832	1.0526
2015	12	21	11	55	10	0.3	1	0.16	98.1	6.5832	0.9377
2015	12	21	12	5	10	0.3	1	0.2	106.1	6.5832	1.1291
2015	12	21	12	15	10	0.3	1	0.17	107	6.5832	0.9377
2015	12	21	12	25	10	0.3	1	0.19	93.9	6.5832	1.1291
2015	12	21	12	35	10	0.3	1	0.21	118.5	6.5832	1.0908
2015	12	21	12	45	10	0.3	1	0.22	98.7	6.5832	1.2439
2015	12	21	12	55	10	0.3	1	0.17	104.6	6.5832	0.9569
2015	12	21	13	5	10	0.3	1	0.17	120.4	6.5832	0.8803
2015	12	21	13	15	10	0.3	1	0.23	112.2	6.5832	1.2631
2015	12	21	13	25	10	0.3	1	0.22	111.6	6.5832	1.2057
2015	12	21	13	35	10	0.3	1	0.25	109.9	6.5832	1.3779
2015	12	21	13	45	10	0.3	1	0.24	127.3	6.5832	1.1291
2015	12	21	13	55	10	0.3	1	0.17	118	6.5832	0.8995
2015	12	21	14	5	10	0.3	1	0.24	100.1	6.5832	1.397
2015	12	21	14	15	10	0.3	1	0.18	101.7	6.5832	1.0143
2015	12	21	14	25	10	0.3	1	0.25	88.5	6.5832	1.4544
2015	12	21	14	35	10	0.3	1	0.17	91.1	6.5832	1.0143
2015	12	21	14	45	10	0.3	1	0.22	79.8	6.5832	1.2822
2015	12	21	14	55	10	0.3	1	0.24	90.8	6.5832	1.3779
2015	12	21	15	5	10	0.3	1	0.23	77.4	6.5832	1.2822
2015	12	21	15	15	10	0.3	1	0.1	99.8	6.5832	0.555
2015	12	21	15	25	10	0.3	1	0.2	69.2	6.5832	1.11
2015	12	21	15	35	10	0.3	1	0.23	77.9	6.5832	1.3396
2015	12	21	15	45	10	0.3	1	0.22	83.3	6.5832	1.3013
2015	12	21	15	55	10	0.3	1	0.21	57.8	6.5832	1.0334
2015	12	21	16	5	10	0.3	1	0.18	93.1	6.5832	1.0525
2015	12	21	16	15	10	0.3	1	0.2	73.9	6.5832	1.1291
2015	12	21	16	25	10	0.3	1	0.25	65.1	6.5832	1.3205
2015	12	21	16	35	10	0.3	1	0.2	79.8	6.5832	1.1674
2015	12	21	16	45	10	0.3	1	0.16	86.4	6.5832	0.9186
2015	12	21	16	55	10	0.3	1	0.13	84.3	6.5832	0.7655
2015	12	21	17	5	10	0.3	1	0.21	86.4	6.5832	1.2056
2015	12	21	17	15	10	0.3	1	0.24	76.7	6.5832	1.3779
2015	12	21	17	25	10	0.3	1	0.24	96.2	6.5832	1.4161
2015	12	21	17	35	10	0.3	1	0.2	62.2	6.5832	1.0525
2015	12	21	17	45	10	0.3	1	0.25	68.1	6.5832	1.3779
2015	12	21	17	55	10	0.3	1	0.24	70.3	6.5832	1.3396
2015	12	21	18	5	10	0.3	1	0.26	69	6.5832	1.397
2015	12	21	18	15	10	0.3	1	0.2	92.8	6.5832	1.1674

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	18	25	10	0.3	1	0.16	85.3	6.5832	0.9377
2015	12	21	18	35	10	0.3	1	0.22	83.3	6.5832	1.3013
2015	12	21	18	45	10	0.3	1	0.2	96.4	6.5832	1.1865
2015	12	21	18	55	10	0.3	1	0.16	111.4	6.5832	0.8803
2015	12	21	19	5	10	0.3	1	0.2	90	6.5639	1.1827
2015	12	21	19	15	10	0.3	1	0.16	92.3	6.5832	0.9377
2015	12	21	19	25	10	0.3	1	0.11	88.2	6.5639	0.6104
2015	12	21	19	35	10	0.3	1	0.16	104	6.5639	0.9157
2015	12	21	19	45	10	0.3	1	0.19	107.8	6.5832	1.0717
2015	12	21	19	55	10	0.3	1	0.14	102.1	6.5639	0.8012
2015	12	21	20	5	10	0.3	1	0.1	101.7	6.5639	0.5532
2015	12	21	20	15	10	0.3	1	0.17	115.6	6.5832	0.8803
2015	12	21	20	25	10	0.3	1	0.21	113.4	6.5832	1.1482
2015	12	21	20	35	10	0.3	1	0.16	105.8	6.5639	0.8775
2015	12	21	20	45	10	0.3	1	0.22	127.2	6.5639	1.0301
2015	12	21	20	55	10	0.3	1	0.18	112.8	6.5639	0.9538
2015	12	21	21	5	10	0.3	1	0.18	138.7	6.5639	0.6868
2015	12	21	21	15	10	0.3	1	0.15	126.4	6.5639	0.7249
2015	12	21	21	25	10	0.3	1	0.21	105.3	6.5639	1.1828
2015	12	21	21	35	10	0.3	1	0.27	108.4	6.5639	1.488
2015	12	21	21	45	10	0.3	1	0.18	112.4	6.5639	0.9729
2015	12	21	21	55	10	0.3	1	0.22	118.5	6.5639	1.1255
2015	12	21	22	5	10	0.3	1	0.22	104.7	6.5639	1.24
2015	12	21	22	15	10	0.3	1	0.27	132	6.5639	1.1637
2015	12	21	22	25	10	0.3	1	0.23	90	6.5639	1.3354
2015	12	21	22	35	10	0.3	1	0.1	110.8	6.5639	0.5532
2015	12	21	22	45	10	0.3	1	0.23	114.8	6.5639	1.24
2015	12	21	22	55	10	0.3	1	0.25	121.2	6.5639	1.2591
2015	12	21	23	5	10	0.3	1	0.23	115.5	6.5639	1.2018
2015	12	21	23	15	10	0.3	1	0.21	117.8	6.5639	1.0874
2015	12	21	23	25	10	0.3	1	0.26	111	6.5639	1.3926
2015	12	21	23	35	10	0.3	1	0.19	99	6.5639	1.0874
2015	12	21	23	45	10	0.3	1	0.13	78.4	6.5639	0.744
2015	12	21	23	55	10	0.3	1	0.24	121.8	6.5639	1.2018
2015	12	22	0	5	10	0.3	1	0.21	116.2	6.5639	1.0874
2015	12	22	0	15	10	0.3	1	0.17	109.1	6.5445	0.9318
2015	12	22	0	25	10	0.3	1	0.18	107.4	6.5639	0.9729
2015	12	22	0	35	10	0.3	1	0.2	109.9	6.5445	1.103
2015	12	22	0	45	10	0.3	1	0.19	119.6	6.5445	0.9698
2015	12	22	0	55	10	0.3	1	0.21	105.1	6.5445	1.198
2015	12	22	1	5	10	0.3	1	0.17	114.1	6.5445	0.8938
2015	12	22	1	15	10	0.3	1	0.2	115.7	6.5445	1.0649
2015	12	22	1	25	10	0.3	1	0.25	98.2	6.5445	1.4453
2015	12	22	1	35	10	0.3	1	0.22	112.8	6.5445	1.179
2015	12	22	1	45	10	0.3	1	0.2	115.7	6.5445	1.0649
2015	12	22	1	55	10	0.3	1	0.22	94.2	6.5445	1.2931

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	2	5	10	0.3	1	0.19	107.5	6.5445	1.0269
2015	12	22	2	15	10	0.3	1	0.19	112.5	6.5445	1.0079
2015	12	22	2	25	10	0.3	1	0.25	106.3	6.5445	1.3692
2015	12	22	2	35	10	0.3	1	0.18	129	6.5445	0.7987
2015	12	22	2	45	10	0.3	1	0.18	104	6.5445	0.9889
2015	12	22	2	55	10	0.3	1	0.2	107.9	6.5445	1.122
2015	12	22	3	5	10	0.3	1	0.23	118.7	6.5445	1.179
2015	12	22	3	15	10	0.3	1	0.21	118.5	6.5445	1.084
2015	12	22	3	25	10	0.3	1	0.15	115.4	6.5445	0.7607
2015	12	22	3	35	10	0.3	1	0.22	124.9	6.5445	1.0649
2015	12	22	3	45	10	0.3	1	0.19	108.4	6.5252	1.0236
2015	12	22	3	55	10	0.3	1	0.16	128.3	6.5445	0.7226
2015	12	22	4	5	10	0.3	1	0.24	105	6.5445	1.3502
2015	12	22	4	15	10	0.3	1	0.13	85.7	6.5252	0.7583
2015	12	22	4	25	10	0.3	1	0.2	108.1	6.5058	1.096
2015	12	22	4	35	10	0.3	1	0.18	106.5	6.5445	1.0269
2015	12	22	4	45	10	0.3	1	0.28	107.2	6.5252	1.5355
2015	12	22	4	55	10	0.3	1	0.18	99.3	6.5252	1.0426
2015	12	22	5	5	10	0.3	1	0.21	101.7	6.5252	1.1943
2015	12	22	5	15	10	0.3	1	0.19	95.9	6.5252	1.0995
2015	12	22	5	25	10	0.3	1	0.24	90	6.5252	1.3649
2015	12	22	5	35	10	0.3	1	0.19	100.7	6.5252	1.0995
2015	12	22	5	45	10	0.3	1	0.24	105.9	6.5252	1.3269
2015	12	22	5	55	10	0.3	1	0.21	99.8	6.5252	1.2132
2015	12	22	6	5	10	0.3	1	0.19	106.9	6.5252	1.0616
2015	12	22	6	15	10	0.3	1	0.14	102.1	6.5058	0.7936
2015	12	22	6	25	10	0.3	1	0.18	100.5	6.5252	1.0236
2015	12	22	6	35	10	0.3	1	0.26	101.7	6.5252	1.4596
2015	12	22	6	45	10	0.3	1	0.17	94.5	6.5058	0.9637
2015	12	22	6	55	10	0.3	1	0.26	107.3	6.5058	1.455
2015	12	22	7	5	10	0.3	1	0.25	111.9	6.5252	1.3649
2015	12	22	7	15	10	0.3	1	0.2	91.9	6.5058	1.1338
2015	12	22	7	25	10	0.3	1	0.17	104.6	6.5058	0.9448
2015	12	22	7	35	10	0.3	1	0.19	97.9	6.5252	1.0995
2015	12	22	7	45	10	0.3	1	0.22	93.4	6.5058	1.2849
2015	12	22	7	55	10	0.3	1	0.14	102.1	6.5058	0.7936
2015	12	22	8	5	10	0.3	1	0.19	122	6.4864	0.9041
2015	12	22	8	15	10	0.3	1	0.17	123.7	6.4864	0.7911
2015	12	22	8	25	10	0.3	1	0.18	115.6	6.4864	0.9418
2015	12	22	8	35	10	0.3	1	0.18	90	6.5058	1.0204
2015	12	22	8	45	10	0.3	1	0.17	108.8	6.4864	0.9418
2015	12	22	8	55	10	0.3	1	0.22	109	6.5058	1.2093
2015	12	22	9	5	10	0.3	1	0.18	123.1	6.4864	0.8664
2015	12	22	9	15	10	0.3	1	0.16	100.4	6.4671	0.92
2015	12	22	9	25	10	0.3	1	0.2	104.3	6.4671	1.1077
2015	12	22	9	35	10	0.3	1	0.2	114.4	6.4671	1.0326

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	9	45	10	0.3	1	0.16	92.3	6.4671	0.92
2015	12	22	9	55	10	0.3	1	0.23	104	6.4671	1.2767
2015	12	22	10	5	10	0.3	1	0.27	110	6.4671	1.4457
2015	12	22	10	15	10	0.3	1	0.22	110.9	6.4671	1.1828
2015	12	22	10	25	10	0.3	1	0.22	95	6.4671	1.2767
2015	12	22	10	35	10	0.3	1	0.17	113.6	6.4671	0.9012
2015	12	22	10	45	10	0.3	1	0.19	107.2	6.4477	1.0293
2015	12	22	10	55	10	0.3	1	0.23	99.7	6.4477	1.31
2015	12	22	11	5	10	0.3	1	0.17	93.2	6.4671	0.9951
2015	12	22	11	15	10	0.3	1	0.18	105.1	6.4671	0.9763
2015	12	22	11	25	10	0.3	1	0.19	90	6.4671	1.0702
2015	12	22	11	35	10	0.3	1	0.15	92.4	6.4671	0.8824
2015	12	22	11	45	10	0.3	1	0.2	90.9	6.4477	1.1416
2015	12	22	11	55	10	0.3	1	0.15	70	6.4477	0.8234
2015	12	22	12	5	10	0.3	1	0.19	101.1	6.4477	1.048
2015	12	22	12	15	10	0.3	1	0.14	94	6.4477	0.8047
2015	12	22	12	25	10	0.3	1	0.16	88.9	6.4477	0.9357
2015	12	22	12	35	10	0.3	1	0.24	63.8	6.4477	1.2164
2015	12	22	12	45	10	0.3	1	0.23	62.3	6.4477	1.1415
2015	12	22	12	55	10	0.3	1	0.14	65.2	6.4477	0.7298
2015	12	22	13	5	10	0.3	1	0.13	53.1	6.4477	0.5988
2015	12	22	13	15	10	0.3	1	0.17	76.8	6.4477	0.9544
2015	12	22	13	25	10	0.3	1	0.2	76.9	6.4671	1.1264
2015	12	22	13	35	10	0.3	1	0.14	72.8	6.4284	0.7834
2015	12	22	13	45	10	0.3	1	0.22	92.6	6.4284	1.2311
2015	12	22	13	55	10	0.3	1	0.19	86	6.4284	1.0632
2015	12	22	14	5	10	0.3	1	0.21	114.6	6.4477	1.1041
2015	12	22	14	15	10	0.3	1	0.1	49	6.4477	0.4304
2015	12	22	14	25	10	0.3	1	0.26	92.9	6.4284	1.4923
2015	12	22	14	35	10	0.3	1	0.17	88.9	6.4284	0.9886
2015	12	22	14	45	10	0.3	1	0.18	84.9	6.4284	1.0446
2015	12	22	14	55	10	0.3	1	0.19	93	6.4477	1.0667
2015	12	22	15	5	10	0.3	1	0.15	79.7	6.4284	0.8207
2015	12	22	15	15	10	0.3	1	0.24	70.1	6.4284	1.2871
2015	12	22	15	25	10	0.3	1	0.22	72.6	6.4284	1.1938
2015	12	22	15	35	10	0.3	1	0.22	94.2	6.4284	1.2684
2015	12	22	15	45	10	0.3	1	0.23	80.1	6.4284	1.2871
2015	12	22	15	55	10	0.3	1	0.19	66.9	6.4284	1.0073
2015	12	22	16	5	10	0.3	1	0.12	80.8	6.4284	0.6902
2015	12	22	16	15	10	0.3	1	0.1	61.7	6.4477	0.4866
2015	12	22	16	25	10	0.3	1	0.24	75.8	6.4477	1.3287
2015	12	22	16	35	10	0.3	1	0.21	82.6	6.4477	1.1602
2015	12	22	16	45	10	0.3	1	0.15	59	6.4284	0.7461
2015	12	22	16	55	10	0.3	1	0.14	56.7	6.4477	0.655
2015	12	22	17	5	10	0.3	1	0.18	80.7	6.4477	1.0292
2015	12	22	17	15	10	0.3	1	0.15	86.2	6.4477	0.8421

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	17	25	10	0.3	1	0.2	59.7	6.4477	0.9918
2015	12	22	17	35	10	0.3	1	0.23	56.1	6.4477	1.0854
2015	12	22	17	45	10	0.3	1	0.16	65	6.4284	0.8394
2015	12	22	17	55	10	0.3	1	0.18	58.9	6.4284	0.8954
2015	12	22	18	5	10	0.3	1	0.21	66.6	6.4477	1.1228
2015	12	22	18	15	10	0.3	1	0.22	65.3	6.4477	1.1415
2015	12	22	18	25	10	0.3	1	0.25	49.3	6.4477	1.0667
2015	12	22	18	35	10	0.3	1	0.23	59.5	6.4477	1.1415
2015	12	22	18	45	10	0.3	1	0.23	70	6.4477	1.2351
2015	12	22	18	55	10	0.3	1	0.22	58	6.4477	1.048
2015	12	22	19	5	10	0.3	1	0.24	45	6.4477	0.9731
2015	12	22	19	15	10	0.3	1	0.19	67.1	6.4477	0.9731
2015	12	22	19	25	10	0.3	1	0.16	73.7	6.4477	0.8982
2015	12	22	19	35	10	0.3	1	0.15	84.9	6.4477	0.8421
2015	12	22	19	45	10	0.3	1	0.16	81.9	6.4477	0.917
2015	12	22	19	55	10	0.3	1	0.17	60.4	6.4477	0.8234
2015	12	22	20	5	10	0.3	1	0.13	78.7	6.4477	0.7485
2015	12	22	20	15	10	0.3	1	0.2	73	6.4477	1.1041
2015	12	22	20	25	10	0.3	1	0.12	85.1	6.4477	0.655
2015	12	22	20	35	10	0.3	1	0.17	96.8	6.4477	0.9357
2015	12	22	20	45	10	0.3	1	0.16	93.4	6.4477	0.9357
2015	12	22	20	55	10	0.3	1	0.19	70.9	6.4477	1.0292
2015	12	22	21	5	10	0.3	1	0.18	86.9	6.4477	1.0292
2015	12	22	21	15	10	0.3	1	0.19	69.3	6.4477	0.9918
2015	12	22	21	25	10	0.3	1	0.2	86.2	6.4477	1.1228
2015	12	22	21	35	10	0.3	1	0.17	81.3	6.4477	0.9731
2015	12	22	21	45	10	0.3	1	0.23	86.7	6.4477	1.2912
2015	12	22	21	55	10	0.3	1	0.15	86.3	6.4477	0.8795
2015	12	22	22	5	10	0.3	1	0.12	104.4	6.4477	0.655
2015	12	22	22	15	10	0.3	1	0.2	101.5	6.4477	1.1041
2015	12	22	22	25	10	0.3	1	0.21	103.6	6.4477	1.1603
2015	12	22	22	35	10	0.3	1	0.2	120	6.4477	0.9731
2015	12	22	22	45	10	0.3	1	0.14	87.3	6.4477	0.8047
2015	12	22	22	55	10	0.3	1	0.15	112.7	6.4477	0.8047
2015	12	22	23	5	10	0.3	1	0.16	105.5	6.4477	0.8796
2015	12	22	23	15	10	0.3	1	0.12	118.6	6.4477	0.6176
2015	12	22	23	25	10	0.3	1	0.15	105.3	6.4477	0.8234
2015	12	22	23	35	10	0.3	1	0.19	103.3	6.4477	1.0293
2015	12	22	23	45	10	0.3	1	0.2	116.1	6.4477	1.0293
2015	12	22	23	55	10	0.3	1	0.24	91.6	6.4477	1.3474
2015	12	23	0	5	10	0.3	1	0.17	84.4	6.4477	0.9544
2015	12	23	0	15	10	0.3	1	0.12	114.4	6.4477	0.6176
2015	12	23	0	25	10	0.3	1	0.12	116.6	6.4477	0.6363
2015	12	23	0	35	10	0.3	1	0.18	95.3	6.4477	1.0106
2015	12	23	0	45	10	0.3	1	0.2	93.8	6.4477	1.1416
2015	12	23	0	55	10	0.3	1	0.22	95.2	6.4477	1.2351

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	1	5	10	0.3	1	0.17	110.2	6.4477	0.917
2015	12	23	1	15	10	0.3	1	0.22	121.1	6.4477	1.0854
2015	12	23	1	25	10	0.3	1	0.2	98.7	6.4477	1.1041
2015	12	23	1	35	10	0.3	1	0.17	114.6	6.4477	0.8983
2015	12	23	1	45	10	0.3	1	0.18	107.1	6.4477	0.9731
2015	12	23	1	55	10	0.3	1	0.2	122.4	6.4477	0.9731
2015	12	23	2	5	10	0.3	1	0.15	112	6.4477	0.786
2015	12	23	2	15	10	0.3	1	0.18	108.1	6.4477	0.9732
2015	12	23	2	25	10	0.3	1	0.21	111.3	6.4477	1.1042
2015	12	23	2	35	10	0.3	1	0.21	85.5	6.4477	1.1977
2015	12	23	2	45	10	0.3	1	0.15	108	6.4477	0.8047
2015	12	23	2	55	10	0.3	1	0.14	84.7	6.4477	0.8047
2015	12	23	3	5	10	0.3	1	0.18	132.8	6.4477	0.7673
2015	12	23	3	15	10	0.3	1	0.15	113.2	6.4477	0.786
2015	12	23	3	25	10	0.3	1	0.2	100.4	6.4477	1.1229
2015	12	23	3	35	10	0.3	1	0.15	102.3	6.4477	0.8609
2015	12	23	3	45	10	0.3	1	0.18	107.4	6.4284	0.9514
2015	12	23	3	55	10	0.3	1	0.13	107.5	6.4477	0.7112
2015	12	23	4	5	10	0.3	1	0.19	94.8	6.4477	1.1042
2015	12	23	4	15	10	0.3	1	0.2	98.4	6.4284	1.1379
2015	12	23	4	25	10	0.3	1	0.08	117.6	6.4284	0.3917
2015	12	23	4	35	10	0.3	1	0.15	91.2	6.4284	0.8768
2015	12	23	4	45	10	0.3	1	0.16	112.9	6.4284	0.8395
2015	12	23	4	55	10	0.3	1	0.18	109.7	6.4284	0.9887
2015	12	23	5	5	10	0.3	1	0.19	67.5	6.4284	0.9887
2015	12	23	5	15	10	0.3	1	0.18	108.4	6.4284	0.9514
2015	12	23	5	25	10	0.3	1	0.2	98.7	6.4284	1.1006
2015	12	23	5	35	10	0.3	1	0.15	110.4	6.4284	0.8022
2015	12	23	5	45	10	0.3	1	0.17	104.3	6.4284	0.9514
2015	12	23	5	55	10	0.3	1	0.17	124	6.4284	0.8022
2015	12	23	6	5	10	0.3	1	0.14	111.8	6.4284	0.7462
2015	12	23	6	15	10	0.3	1	0.2	124.2	6.4284	0.9327
2015	12	23	6	25	10	0.3	1	0.18	111	6.4284	0.97
2015	12	23	6	35	10	0.3	1	0.18	85.8	6.4284	1.026
2015	12	23	6	45	10	0.3	1	0.18	103	6.4284	0.97
2015	12	23	6	55	10	0.3	1	0.17	104.3	6.4284	0.9514
2015	12	23	7	5	10	0.3	1	0.16	107.7	6.4284	0.8768
2015	12	23	7	15	10	0.3	1	0.18	108.4	6.4284	0.9514
2015	12	23	7	25	10	0.3	1	0.18	119	6.4284	0.8768
2015	12	23	7	35	10	0.3	1	0.23	97.2	6.4284	1.3245
2015	12	23	7	45	10	0.3	1	0.22	123.5	6.4284	1.0447
2015	12	23	7	55	10	0.3	1	0.17	93.2	6.4284	0.9887
2015	12	23	8	5	10	0.3	1	0.2	105.4	6.4284	1.082
2015	12	23	8	15	10	0.3	1	0.18	110.8	6.4284	0.9327
2015	12	23	8	25	10	0.3	1	0.2	104	6.4284	1.1193
2015	12	23	8	35	10	0.3	1	0.19	107.5	6.4284	1.0074

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	8	45	10	0.3	1	0.18	117.5	6.4284	0.9327
2015	12	23	8	55	10	0.3	1	0.18	103.5	6.4284	1.0074
2015	12	23	9	5	10	0.3	1	0.17	101.3	6.4284	0.9327
2015	12	23	9	15	10	0.3	1	0.2	86.2	6.4284	1.1379
2015	12	23	9	25	10	0.3	1	0.25	112.2	6.4284	1.3245
2015	12	23	9	35	10	0.3	1	0.15	82.4	6.4284	0.8395
2015	12	23	9	45	10	0.3	1	0.2	118.7	6.4284	0.9887
2015	12	23	9	55	10	0.3	1	0.18	103.5	6.4284	1.0074
2015	12	23	10	5	10	0.3	1	0.19	101.9	6.4284	1.0633
2015	12	23	10	15	10	0.3	1	0.1	114.1	6.4284	0.541
2015	12	23	10	25	10	0.3	1	0.19	113.9	6.4284	0.97
2015	12	23	10	35	10	0.3	1	0.19	93.9	6.4284	1.1006
2015	12	23	10	45	10	0.3	1	0.23	116.6	6.4284	1.1939
2015	12	23	10	55	10	0.3	1	0.18	111.4	6.4284	0.9514
2015	12	23	11	5	10	0.3	1	0.14	136	6.4284	0.541
2015	12	23	11	15	10	0.3	1	0.18	119	6.4284	0.8768
2015	12	23	11	25	10	0.3	1	0.18	123.7	6.4284	0.8394
2015	12	23	11	35	10	0.3	1	0.17	99.8	6.4284	0.97
2015	12	23	11	45	10	0.3	1	0.14	121.4	6.4284	0.6715
2015	12	23	11	55	10	0.3	1	0.17	122.5	6.4284	0.8208
2015	12	23	12	5	10	0.3	1	0.2	112	6.4284	1.0633
2015	12	23	12	15	10	0.3	1	0.18	85.8	6.4284	1.026
2015	12	23	12	25	10	0.3	1	0.22	107.9	6.4284	1.2125
2015	12	23	12	35	10	0.3	1	0.22	113.1	6.4284	1.1379
2015	12	23	12	45	10	0.3	1	0.16	90	6.4284	0.8954
2015	12	23	12	55	10	0.3	1	0.14	103.1	6.4284	0.8021
2015	12	23	13	5	10	0.3	1	0.22	122	6.4284	1.0446
2015	12	23	13	15	10	0.3	1	0.17	84.4	6.4284	0.9513
2015	12	23	13	25	10	0.3	1	0.17	125.8	6.4284	0.8021
2015	12	23	13	35	10	0.3	1	0.13	132	6.4284	0.5596
2015	12	23	13	45	10	0.3	1	0.22	102	6.4284	1.2311
2015	12	23	13	55	10	0.3	1	0.22	103.8	6.4284	1.2125
2015	12	23	14	5	10	0.3	1	0.18	114.2	6.4284	0.914
2015	12	23	14	15	10	0.3	1	0.2	110.8	6.4284	1.0819
2015	12	23	14	25	10	0.3	1	0.24	106.2	6.4284	1.2871
2015	12	23	14	35	10	0.3	1	0.16	104	6.4284	0.8954
2015	12	23	14	45	10	0.3	1	0.21	90.9	6.4284	1.2125
2015	12	23	14	55	10	0.3	1	0.12	108.4	6.4284	0.6715
2015	12	23	15	5	10	0.3	1	0.15	117.7	6.4284	0.7461
2015	12	23	15	15	10	0.3	1	0.16	88.9	6.4284	0.9327
2015	12	23	15	25	10	0.3	1	0.13	97.5	6.4284	0.7088
2015	12	23	15	35	10	0.3	1	0.14	84.8	6.4284	0.8207
2015	12	23	15	45	10	0.3	1	0.27	105.6	6.4284	1.4736
2015	12	23	15	55	10	0.3	1	0.15	88.8	6.4284	0.8767
2015	12	23	16	5	10	0.3	1	0.12	118.7	6.4284	0.5783
2015	12	23	16	15	10	0.3	1	0.18	121.3	6.4284	0.8581

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	16	25	10	0.3	1	0.17	115.1	6.4284	0.8767
2015	12	23	16	35	10	0.3	1	0.2	78	6.4284	1.1378
2015	12	23	16	45	10	0.3	1	0.19	104.3	6.4284	1.0259
2015	12	23	16	55	10	0.3	1	0.17	90	6.4284	0.9886
2015	12	23	17	5	10	0.3	1	0.18	115.1	6.4284	0.914
2015	12	23	17	15	10	0.3	1	0.19	108.1	6.4284	1.0259
2015	12	23	17	25	10	0.3	1	0.17	103.8	6.4284	0.914
2015	12	23	17	35	10	0.3	1	0.14	95.2	6.4284	0.8207
2015	12	23	17	45	10	0.3	1	0.2	101.5	6.4284	1.1005
2015	12	23	17	55	10	0.3	1	0.16	90	6.4284	0.8954
2015	12	23	18	5	10	0.3	1	0.15	100.3	6.4284	0.8207
2015	12	23	18	15	10	0.3	1	0.15	92.5	6.4284	0.8581
2015	12	23	18	25	10	0.3	1	0.15	94.9	6.4284	0.8767
2015	12	23	18	35	10	0.3	1	0.21	101	6.4284	1.1565
2015	12	23	18	45	10	0.3	1	0.12	72.1	6.4284	0.6342
2015	12	23	18	55	10	0.3	1	0.22	83.9	6.4284	1.2311
2015	12	23	19	5	10	0.3	1	0.18	67.2	6.4284	0.9327
2015	12	23	19	15	10	0.3	1	0.15	104	6.4284	0.8207
2015	12	23	19	25	10	0.3	1	0.21	90.9	6.4284	1.2125
2015	12	23	19	35	10	0.3	1	0.17	72.3	6.4284	0.9327
2015	12	23	19	45	10	0.3	1	0.17	81.3	6.4284	0.97
2015	12	23	19	55	10	0.3	1	0.2	82.4	6.4284	1.1192
2015	12	23	20	5	10	0.3	1	0.16	85.3	6.4284	0.914
2015	12	23	20	15	10	0.3	1	0.2	91.9	6.4284	1.1379
2015	12	23	20	25	10	0.3	1	0.16	90	6.4284	0.8954
2015	12	23	20	35	10	0.3	1	0.19	111.6	6.4284	0.9886
2015	12	23	20	45	10	0.3	1	0.15	105.6	6.4284	0.8021
2015	12	23	20	55	10	0.3	1	0.19	102.1	6.4284	1.0446
2015	12	23	21	5	10	0.3	1	0.19	116.1	6.4284	0.9513
2015	12	23	21	15	10	0.3	1	0.22	101.3	6.4284	1.2125
2015	12	23	21	25	10	0.3	1	0.21	103.6	6.4284	1.1565
2015	12	23	21	35	10	0.3	1	0.17	107	6.4284	0.914
2015	12	23	21	45	10	0.3	1	0.18	108.1	6.4284	0.97
2015	12	23	21	55	10	0.3	1	0.18	109.4	6.4284	0.9513
2015	12	23	22	5	10	0.3	1	0.18	112.8	6.4284	0.9327
2015	12	23	22	15	10	0.3	1	0.14	94	6.4284	0.8021
2015	12	23	22	25	10	0.3	1	0.15	101.1	6.4284	0.8581
2015	12	23	22	35	10	0.3	1	0.21	115.3	6.4284	1.0633
2015	12	23	22	45	10	0.3	1	0.19	111.6	6.4284	0.9887
2015	12	23	22	55	10	0.3	1	0.18	118.4	6.4284	0.8954
2015	12	23	23	5	10	0.3	1	0.18	90	6.4284	1.0446
2015	12	23	23	15	10	0.3	1	0.16	94.8	6.4284	0.8954
2015	12	23	23	25	10	0.3	1	0.2	98.4	6.4284	1.1379
2015	12	23	23	35	10	0.3	1	0.15	113.2	6.4284	0.7835
2015	12	23	23	45	10	0.3	1	0.17	101.1	6.4284	0.9514
2015	12	23	23	55	10	0.3	1	0.22	97.8	6.4284	1.2312

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	0	5	10	0.3	1	0.17	92.2	6.4284	0.97
2015	12	24	0	15	10	0.3	1	0.18	109.1	6.4284	0.97
2015	12	24	0	25	10	0.3	1	0.17	115.1	6.4284	0.8767
2015	12	24	0	35	10	0.3	1	0.19	113.9	6.4284	0.97
2015	12	24	0	45	10	0.3	1	0.16	104.6	6.4284	0.8581
2015	12	24	0	55	10	0.3	1	0.18	90	6.4284	1.0073
2015	12	24	1	5	10	0.3	1	0.19	86.1	6.4284	1.0819
2015	12	24	1	15	10	0.3	1	0.18	99.6	6.4284	0.9887
2015	12	24	1	25	10	0.3	1	0.21	98	6.4284	1.1939
2015	12	24	1	35	10	0.3	1	0.23	95	6.4284	1.2871
2015	12	24	1	45	10	0.3	1	0.15	106.8	6.4284	0.8021
2015	12	24	1	55	10	0.3	1	0.17	99.1	6.4284	0.9327
2015	12	24	2	5	10	0.3	1	0.2	96.7	6.4284	1.1193
2015	12	24	2	15	10	0.3	1	0.12	93	6.4284	0.7089
2015	12	24	2	25	10	0.3	1	0.12	120.1	6.4284	0.5783
2015	12	24	2	35	10	0.3	1	0.22	120	6.4284	1.1006
2015	12	24	2	45	10	0.3	1	0.17	85.7	6.4284	0.9887
2015	12	24	2	55	10	0.3	1	0.21	99.2	6.4284	1.1566
2015	12	24	3	5	10	0.3	1	0.12	129.6	6.4284	0.541
2015	12	24	3	15	10	0.3	1	0.15	95	6.4284	0.8581
2015	12	24	3	25	10	0.3	1	0.19	91.9	6.4284	1.1006
2015	12	24	3	35	10	0.3	1	0.12	87	6.4284	0.7089
2015	12	24	3	45	10	0.3	1	0.17	102.4	6.4284	0.9327
2015	12	24	3	55	10	0.3	1	0.14	91.4	6.4284	0.7835
2015	12	24	4	5	10	0.3	1	0.18	111	6.4284	0.9701
2015	12	24	4	15	10	0.3	1	0.24	109.7	6.4284	1.3058
2015	12	24	4	25	10	0.3	1	0.21	90	6.4284	1.1939
2015	12	24	4	35	10	0.3	1	0.14	95.4	6.4284	0.7835
2015	12	24	4	45	10	0.3	1	0.14	105.9	6.4284	0.7835
2015	12	24	4	55	10	0.3	1	0.21	109.6	6.4284	1.1006
2015	12	24	5	5	10	0.3	1	0.24	104.2	6.4284	1.3245
2015	12	24	5	15	10	0.3	1	0.17	128.7	6.4284	0.7462
2015	12	24	5	25	10	0.3	1	0.18	111	6.4284	0.9701
2015	12	24	5	35	10	0.3	1	0.15	109.7	6.4284	0.7835
2015	12	24	5	45	10	0.3	1	0.18	99.3	6.4284	1.026
2015	12	24	5	55	10	0.3	1	0.19	118.3	6.4284	0.9701
2015	12	24	6	5	10	0.3	1	0.21	99.9	6.4284	1.1753
2015	12	24	6	15	10	0.3	1	0.11	105.7	6.4284	0.597
2015	12	24	6	25	10	0.3	1	0.12	111.5	6.4284	0.6156
2015	12	24	6	35	10	0.3	1	0.17	98.7	6.4284	0.9701
2015	12	24	6	45	10	0.3	1	0.21	117	6.4284	1.0634
2015	12	24	6	55	10	0.3	1	0.2	110.6	6.4284	1.0447
2015	12	24	7	5	10	0.3	1	0.18	110.4	6.4284	0.9514
2015	12	24	7	15	10	0.3	1	0.15	110	6.4284	0.8208
2015	12	24	7	25	10	0.3	1	0.27	117.2	6.4284	1.3432
2015	12	24	7	35	10	0.3	1	0.18	115.1	6.4284	0.9141

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	7	45	10	0.3	1	0.2	98.7	6.4284	1.1007
2015	12	24	7	55	10	0.3	1	0.17	119.6	6.4284	0.8208
2015	12	24	8	5	10	0.3	1	0.25	109.4	6.4284	1.3245
2015	12	24	8	15	10	0.3	1	0.2	109	6.4284	1.082
2015	12	24	8	25	10	0.3	1	0.22	135.6	6.4284	0.8582
2015	12	24	8	35	10	0.3	1	0.21	118.5	6.4284	1.0634
2015	12	24	8	45	10	0.3	1	0.19	108.7	6.4284	1.0447
2015	12	24	8	55	10	0.3	1	0.19	99.1	6.4284	1.0447
2015	12	24	9	5	10	0.3	1	0.15	118.8	6.4284	0.7462
2015	12	24	9	15	10	0.3	1	0.26	105.6	6.4284	1.3992
2015	12	24	9	25	10	0.3	1	0.16	109.6	6.4284	0.8395
2015	12	24	9	35	10	0.3	1	0.23	115.5	6.4284	1.1753
2015	12	24	9	45	10	0.3	1	0.22	120.4	6.4284	1.082
2015	12	24	9	55	10	0.3	1	0.21	121.4	6.4284	1.0074
2015	12	24	10	5	10	0.3	1	0.22	90.9	6.4284	1.2313
2015	12	24	10	15	10	0.3	1	0.17	113.1	6.4284	0.8768
2015	12	24	10	25	10	0.3	1	0.25	116.9	6.4284	1.2499
2015	12	24	10	35	10	0.3	1	0.2	102.4	6.4284	1.1007
2015	12	24	10	45	10	0.3	1	0.19	133.6	6.4284	0.7649
2015	12	24	10	55	10	0.3	1	0.14	117.1	6.4284	0.7276
2015	12	24	11	5	10	0.3	1	0.2	109.9	6.4284	1.082
2015	12	24	11	15	10	0.3	1	0.15	118.8	6.4284	0.7462
2015	12	24	11	25	10	0.3	1	0.23	97.3	6.4284	1.3058
2015	12	24	11	35	10	0.3	1	0.22	120.1	6.4284	1.0633
2015	12	24	11	45	10	0.3	1	0.14	105.4	6.4284	0.7462
2015	12	24	11	55	10	0.3	1	0.14	97.9	6.409	0.7996
2015	12	24	12	5	10	0.3	1	0.21	109.6	6.4284	1.1006
2015	12	24	12	15	10	0.3	1	0.2	120	6.4284	0.97
2015	12	24	12	25	10	0.3	1	0.21	113.8	6.4284	1.1006
2015	12	24	12	35	10	0.3	1	0.17	106.4	6.4284	0.9514
2015	12	24	12	45	10	0.3	1	0.2	107.5	6.4284	1.0633
2015	12	24	12	55	10	0.3	1	0.21	99.2	6.4284	1.1566
2015	12	24	13	5	10	0.3	1	0.21	80.1	6.4284	1.1752
2015	12	24	13	15	10	0.3	1	0.23	91.6	6.4284	1.3058
2015	12	24	13	25	10	0.3	1	0.12	111.8	6.4284	0.6529
2015	12	24	13	35	10	0.3	1	0.19	116.1	6.4284	0.9514
2015	12	24	13	45	10	0.3	1	0.16	101.5	6.4284	0.9141
2015	12	24	13	55	10	0.3	1	0.14	103.1	6.4284	0.8021
2015	12	24	14	5	10	0.3	1	0.08	99.5	6.4284	0.4477
2015	12	24	14	15	10	0.3	1	0.21	118.5	6.4284	1.0633
2015	12	24	14	25	10	0.3	1	0.14	116.6	6.4284	0.7089
2015	12	24	14	35	10	0.3	1	0.21	105.3	6.4284	1.1566
2015	12	24	14	45	10	0.3	1	0.19	88.1	6.4284	1.1006
2015	12	24	14	55	10	0.3	1	0.14	100.5	6.4477	0.8047
2015	12	24	15	5	10	0.3	1	0.11	86.6	6.4284	0.6342
2015	12	24	15	15	10	0.3	1	0.14	108	6.4284	0.7462

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	15	25	10	0.3	1	0.17	90	6.4284	0.97
2015	12	24	15	35	10	0.3	1	0.22	98.7	6.4284	1.2125
2015	12	24	15	45	10	0.3	1	0.13	77.3	6.4284	0.7462
2015	12	24	15	55	10	0.3	1	0.15	98.7	6.4284	0.8581
2015	12	24	16	5	10	0.3	1	0.21	97.4	6.4284	1.1566
2015	12	24	16	15	10	0.3	1	0.15	101.3	6.4284	0.8394
2015	12	24	16	25	10	0.3	1	0.14	103.1	6.4284	0.8021
2015	12	24	16	35	10	0.3	1	0.19	98.8	6.4284	1.0819
2015	12	24	16	45	10	0.3	1	0.23	86.7	6.4284	1.3058
2015	12	24	16	55	10	0.3	1	0.17	83.2	6.4477	0.9357
2015	12	24	17	5	10	0.3	1	0.17	108.8	6.4284	0.9327
2015	12	24	17	15	10	0.3	1	0.19	112.9	6.4477	0.9732
2015	12	24	17	25	10	0.3	1	0.21	87.3	6.4477	1.1977
2015	12	24	17	35	10	0.3	1	0.2	89	6.4477	1.1229
2015	12	24	17	45	10	0.3	1	0.19	97	6.4477	1.0667
2015	12	24	17	55	10	0.3	1	0.19	81.9	6.4477	1.048
2015	12	24	18	5	10	0.3	1	0.15	87.5	6.4284	0.8581
2015	12	24	18	15	10	0.3	1	0.19	90	6.4477	1.1041
2015	12	24	18	25	10	0.3	1	0.18	98.3	6.4284	1.026
2015	12	24	18	35	10	0.3	1	0.15	61.7	6.4284	0.7275
2015	12	24	18	45	10	0.3	1	0.2	87.1	6.4284	1.1192
2015	12	24	18	55	10	0.3	1	0.24	73.5	6.4284	1.3244
2015	12	24	19	5	10	0.3	1	0.12	94.9	6.4284	0.6529
2015	12	24	19	15	10	0.3	1	0.1	106.7	6.4284	0.5596
2015	12	24	19	25	10	0.3	1	0.15	68	6.4284	0.7835
2015	12	24	19	35	10	0.3	1	0.16	99.5	6.4284	0.8954
2015	12	24	19	45	10	0.3	1	0.19	75.7	6.4284	1.026
2015	12	24	19	55	10	0.3	1	0.19	74.1	6.4284	1.0446
2015	12	24	20	5	10	0.3	1	0.17	70.9	6.4284	0.914
2015	12	24	20	15	10	0.3	1	0.18	85.9	6.4477	1.048
2015	12	24	20	25	10	0.3	1	0.22	71.6	6.4477	1.179
2015	12	24	20	35	10	0.3	1	0.26	80	6.4477	1.4784
2015	12	24	20	45	10	0.3	1	0.17	80.9	6.4477	0.9357
2015	12	24	20	55	10	0.3	1	0.13	70.6	6.4477	0.6924
2015	12	24	21	5	10	0.3	1	0.22	66.1	6.4477	1.1416
2015	12	24	21	15	10	0.3	1	0.19	90	6.4477	1.0854
2015	12	24	21	25	10	0.3	1	0.24	70.3	6.4477	1.31
2015	12	24	21	35	10	0.3	1	0.21	103.6	6.4477	1.1603
2015	12	24	21	45	10	0.3	1	0.21	85.5	6.4477	1.1977
2015	12	24	21	55	10	0.3	1	0.18	68.6	6.4477	0.9544
2015	12	24	22	5	10	0.3	1	0.2	75.7	6.4477	1.1042
2015	12	24	22	15	10	0.3	1	0.13	77.3	6.4477	0.7486
2015	12	24	22	25	10	0.3	1	0.2	92.8	6.4477	1.1416
2015	12	24	22	35	10	0.3	1	0.21	86.4	6.4477	1.1977
2015	12	24	22	45	10	0.3	1	0.17	80.9	6.4477	0.9357
2015	12	24	22	55	10	0.3	1	0.23	77.7	6.4477	1.2913

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	23	5	10	0.3	1	0.24	79.6	6.4477	1.3287
2015	12	24	23	15	10	0.3	1	0.23	68.7	6.4477	1.1977
2015	12	24	23	25	10	0.3	1	0.17	65.9	6.4477	0.8796
2015	12	24	23	35	10	0.3	1	0.14	79.2	6.4477	0.786
2015	12	24	23	45	10	0.3	1	0.22	83.1	6.4477	1.2352
2015	12	24	23	55	10	0.3	1	0.18	93.1	6.4477	1.0293
2015	12	25	0	5	10	0.3	1	0.2	70.7	6.4477	1.0667
2015	12	25	0	15	10	0.3	1	0.17	90	6.4477	0.9732
2015	12	25	0	25	10	0.3	1	0.19	76.7	6.4477	1.0293
2015	12	25	0	35	10	0.3	1	0.26	76.8	6.4477	1.441
2015	12	25	0	45	10	0.3	1	0.23	80	6.4477	1.2726
2015	12	25	0	55	10	0.3	1	0.15	90	6.4477	0.8796
2015	12	25	1	5	10	0.3	1	0.2	97.5	6.4477	1.1416
2015	12	25	1	15	10	0.3	1	0.17	75.1	6.4477	0.917
2015	12	25	1	25	10	0.3	1	0.23	85.2	6.4477	1.3288
2015	12	25	1	35	10	0.3	1	0.16	88.9	6.4477	0.9357
2015	12	25	1	45	10	0.3	1	0.23	99.1	6.4477	1.2913
2015	12	25	1	55	10	0.3	1	0.19	119.7	6.4477	0.917
2015	12	25	2	5	10	0.3	1	0.14	119.6	6.4477	0.6925
2015	12	25	2	15	10	0.3	1	0.17	105.4	6.4477	0.9545
2015	12	25	2	25	10	0.3	1	0.22	104.9	6.4477	1.1978
2015	12	25	2	35	10	0.3	1	0.18	99.3	6.4477	1.0293
2015	12	25	2	45	10	0.3	1	0.18	100.5	6.4477	1.0106
2015	12	25	2	55	10	0.3	1	0.18	90	6.4477	1.0106
2015	12	25	3	5	10	0.3	1	0.18	99.5	6.4477	1.0106
2015	12	25	3	15	10	0.3	1	0.19	122	6.4477	0.8983
2015	12	25	3	25	10	0.3	1	0.18	100.3	6.4477	1.0293
2015	12	25	3	35	10	0.3	1	0.21	107.9	6.4477	1.1603
2015	12	25	3	45	10	0.3	1	0.23	96.4	6.4477	1.3288
2015	12	25	3	55	10	0.3	1	0.2	103.6	6.4477	1.0855
2015	12	25	4	5	10	0.3	1	0.2	99.6	6.4477	1.1042
2015	12	25	4	15	10	0.3	1	0.13	85.7	6.4477	0.7486
2015	12	25	4	25	10	0.3	1	0.19	104.7	6.4477	1.0668
2015	12	25	4	35	10	0.3	1	0.2	115.7	6.4477	1.0481
2015	12	25	4	45	10	0.3	1	0.19	96.9	6.4477	1.0855
2015	12	25	4	55	10	0.3	1	0.23	115.5	6.4477	1.1791
2015	12	25	5	5	10	0.3	1	0.23	96.4	6.4284	1.3245
2015	12	25	5	15	10	0.3	1	0.15	100.3	6.4477	0.8235
2015	12	25	5	25	10	0.3	1	0.19	113.9	6.4477	0.9732
2015	12	25	5	35	10	0.3	1	0.22	90.9	6.4477	1.2539
2015	12	25	5	45	10	0.3	1	0.16	109.9	6.4284	0.8768
2015	12	25	5	55	10	0.3	1	0.17	128.7	6.4284	0.7462
2015	12	25	6	5	10	0.3	1	0.22	104	6.4284	1.1939
2015	12	25	6	15	10	0.3	1	0.2	119.9	6.4284	1.0074
2015	12	25	6	25	10	0.3	1	0.22	107.6	6.4284	1.1753
2015	12	25	6	35	10	0.3	1	0.15	112	6.4284	0.7835

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	6	45	10	0.3	1	0.18	135	6.4284	0.7276
2015	12	25	6	55	10	0.3	1	0.24	99.6	6.4284	1.3245
2015	12	25	7	5	10	0.3	1	0.23	109.2	6.4284	1.2313
2015	12	25	7	15	10	0.3	1	0.18	97.3	6.4477	1.0294
2015	12	25	7	25	10	0.3	1	0.19	110.3	6.4477	1.0107
2015	12	25	7	35	10	0.3	1	0.15	132.3	6.4284	0.6156
2015	12	25	7	45	10	0.3	1	0.18	102.3	6.4284	1.0261
2015	12	25	7	55	10	0.3	1	0.17	108.1	6.4284	0.9141
2015	12	25	8	5	10	0.3	1	0.18	97.4	6.4284	1.0074
2015	12	25	8	15	10	0.3	1	0.24	130.5	6.4284	1.0261
2015	12	25	8	25	10	0.3	1	0.25	129.2	6.4284	1.1193
2015	12	25	8	35	10	0.3	1	0.18	112.4	6.4284	0.9514
2015	12	25	8	45	10	0.3	1	0.17	109.5	6.4477	0.8984
2015	12	25	8	55	10	0.3	1	0.17	111.2	6.4284	0.9141
2015	12	25	9	5	10	0.3	1	0.17	122.1	6.4284	0.8022
2015	12	25	9	15	10	0.3	1	0.18	107.8	6.4284	0.9888
2015	12	25	9	25	10	0.3	1	0.2	144.2	6.4284	0.6716
2015	12	25	9	35	10	0.3	1	0.28	120.8	6.4284	1.3432
2015	12	25	9	45	10	0.3	1	0.17	121	6.4284	0.8395
2015	12	25	9	55	10	0.3	1	0.21	122.9	6.4284	1.0074
2015	12	25	10	5	10	0.3	1	0.27	106.2	6.4284	1.4738
2015	12	25	10	15	10	0.3	1	0.15	105.3	6.4284	0.8208
2015	12	25	10	25	10	0.3	1	0.18	130.5	6.4284	0.7649
2015	12	25	10	35	10	0.3	1	0.18	131.3	6.4284	0.7649
2015	12	25	10	45	10	0.3	1	0.17	112.2	6.4284	0.9141
2015	12	25	10	55	10	0.3	1	0.15	115.5	6.4284	0.7835
2015	12	25	11	5	10	0.3	1	0.14	136	6.4284	0.541
2015	12	25	11	15	10	0.3	1	0.14	117.2	6.4284	0.6902
2015	12	25	11	25	10	0.3	1	0.19	133.6	6.4284	0.7835
2015	12	25	11	35	10	0.3	1	0.22	118.5	6.4284	1.1007
2015	12	25	11	45	10	0.3	1	0.23	123.9	6.4284	1.082
2015	12	25	11	55	10	0.3	1	0.19	95	6.4284	1.0633
2015	12	25	12	5	10	0.3	1	0.18	128.2	6.4284	0.7835
2015	12	25	12	15	10	0.3	1	0.29	103.1	6.4284	1.6043
2015	12	25	12	25	10	0.3	1	0.22	85.7	6.4284	1.2499
2015	12	25	12	35	10	0.3	1	0.22	126.5	6.4284	1.0074
2015	12	25	12	45	10	0.3	1	0.13	90	6.4284	0.7648
2015	12	25	12	55	10	0.3	1	0.15	118.3	6.4284	0.7275
2015	12	25	13	5	10	0.3	1	0.17	138.1	6.4284	0.6529
2015	12	25	13	15	10	0.3	1	0.2	117	6.4284	0.9887
2015	12	25	13	25	10	0.3	1	0.18	99.3	6.4284	1.026
2015	12	25	13	35	10	0.3	1	0.21	123.4	6.4284	0.9887
2015	12	25	13	45	10	0.3	1	0.2	101.5	6.4284	1.1006
2015	12	25	13	55	10	0.3	1	0.2	110.2	6.409	1.0599
2015	12	25	14	5	10	0.3	1	0.15	114.3	6.409	0.781
2015	12	25	14	15	10	0.3	1	0.22	112.8	6.409	1.1528

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	14	25	10	0.3	1	0.16	96.1	6.409	0.8739
2015	12	25	14	35	10	0.3	1	0.16	91.1	6.4284	0.9327
2015	12	25	14	45	10	0.3	1	0.16	104.3	6.4284	0.8768
2015	12	25	14	55	10	0.3	1	0.12	116.6	6.4284	0.6343
2015	12	25	15	5	10	0.3	1	0.17	103.2	6.4284	0.9514
2015	12	25	15	15	10	0.3	1	0.15	108.4	6.4284	0.7835
2015	12	25	15	25	10	0.3	1	0.24	103.3	6.4284	1.3431
2015	12	25	15	35	10	0.3	1	0.16	93.6	6.4284	0.8954
2015	12	25	15	45	10	0.3	1	0.25	109.9	6.4284	1.3431
2015	12	25	15	55	10	0.3	1	0.21	123.7	6.4284	1.0073
2015	12	25	16	5	10	0.3	1	0.14	113.6	6.409	0.7252
2015	12	25	16	15	10	0.3	1	0.14	97.9	6.409	0.7996
2015	12	25	16	25	10	0.3	1	0.12	116.6	6.409	0.6322
2015	12	25	16	35	10	0.3	1	0.21	105.1	6.4284	1.1752
2015	12	25	16	45	10	0.3	1	0.14	106.3	6.4284	0.7648
2015	12	25	16	55	10	0.3	1	0.23	122.1	6.4284	1.1006
2015	12	25	17	5	10	0.3	1	0.16	115	6.4284	0.8395
2015	12	25	17	15	10	0.3	1	0.16	102.9	6.4284	0.8954
2015	12	25	17	25	10	0.3	1	0.18	123.4	6.4284	0.8768
2015	12	25	17	35	10	0.3	1	0.21	121.7	6.409	1.0227
2015	12	25	17	45	10	0.3	1	0.27	86.6	6.4284	1.5483
2015	12	25	17	55	10	0.3	1	0.18	97.3	6.409	1.0227
2015	12	25	18	5	10	0.3	1	0.14	69	6.4284	0.7275
2015	12	25	18	15	10	0.3	1	0.19	108.4	6.4284	1.0074
2015	12	25	18	25	10	0.3	1	0.18	89	6.409	1.0413
2015	12	25	18	35	10	0.3	1	0.19	120.5	6.409	0.9483
2015	12	25	18	45	10	0.3	1	0.16	102.9	6.409	0.8925
2015	12	25	18	55	10	0.3	1	0.18	98.3	6.409	1.0227
2015	12	25	19	5	10	0.3	1	0.17	81.3	6.409	0.9669
2015	12	25	19	15	10	0.3	1	0.12	102.2	6.409	0.688
2015	12	25	19	25	10	0.3	1	0.14	102.1	6.409	0.781
2015	12	25	19	35	10	0.3	1	0.17	113.6	6.409	0.8925
2015	12	25	19	45	10	0.3	1	0.13	115.9	6.409	0.6508
2015	12	25	19	55	10	0.3	1	0.17	112	6.409	0.8739
2015	12	25	20	5	10	0.3	1	0.11	88.4	6.409	0.6508
2015	12	25	20	15	10	0.3	1	0.15	60.7	6.409	0.7624
2015	12	25	20	25	10	0.3	1	0.17	100	6.409	0.9483
2015	12	25	20	35	10	0.3	1	0.13	92.8	6.4284	0.7648
2015	12	25	20	45	10	0.3	1	0.13	84.3	6.409	0.7438
2015	12	25	20	55	10	0.3	1	0.16	91.1	6.409	0.9297
2015	12	25	21	5	10	0.3	1	0.2	97.5	6.4284	1.1379
2015	12	25	21	15	10	0.3	1	0.21	92.7	6.4284	1.1939
2015	12	25	21	25	10	0.3	1	0.21	111	6.409	1.1157
2015	12	25	21	35	10	0.3	1	0.14	99.5	6.409	0.781
2015	12	25	21	45	10	0.3	1	0.2	85.2	6.4284	1.1193
2015	12	25	21	55	10	0.3	1	0.16	105.8	6.4284	0.8581

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	22	5	10	0.3	1	0.21	117.3	6.4284	1.082
2015	12	25	22	15	10	0.3	1	0.24	90	6.4284	1.3618
2015	12	25	22	25	10	0.3	1	0.15	110.4	6.4284	0.8022
2015	12	25	22	35	10	0.3	1	0.2	90.9	6.4284	1.138
2015	12	25	22	45	10	0.3	1	0.18	73.9	6.4284	0.9701
2015	12	25	22	55	10	0.3	1	0.19	115.7	6.4284	0.9701
2015	12	25	23	5	10	0.3	1	0.15	112	6.4284	0.7835
2015	12	25	23	15	10	0.3	1	0.18	103.8	6.4284	0.9887
2015	12	25	23	25	10	0.3	1	0.14	95.6	6.4284	0.7649
2015	12	25	23	35	10	0.3	1	0.16	104	6.4284	0.8955
2015	12	25	23	45	10	0.3	1	0.19	105.3	6.4284	1.026
2015	12	25	23	55	10	0.3	1	0.16	121.4	6.4284	0.7649
2015	12	26	0	5	10	0.3	1	0.15	114.9	6.4284	0.7649
2015	12	26	0	15	10	0.3	1	0.2	124.5	6.4284	0.9514
2015	12	26	0	25	10	0.3	1	0.15	81.3	6.4284	0.8582
2015	12	26	0	35	10	0.3	1	0.13	101.3	6.4284	0.7462
2015	12	26	0	45	10	0.3	1	0.17	111.2	6.4284	0.9141
2015	12	26	0	55	10	0.3	1	0.26	101.7	6.4284	1.4365
2015	12	26	1	5	10	0.3	1	0.14	92.6	6.4284	0.8208
2015	12	26	1	15	10	0.3	1	0.13	98.5	6.4284	0.7462
2015	12	26	1	25	10	0.3	1	0.22	120	6.4284	1.1007
2015	12	26	1	35	10	0.3	1	0.2	119.5	6.4284	0.9888
2015	12	26	1	45	10	0.3	1	0.14	117.2	6.4284	0.6903
2015	12	26	1	55	10	0.3	1	0.15	127.9	6.4284	0.6716
2015	12	26	2	5	10	0.3	1	0.16	106.9	6.4284	0.8582
2015	12	26	2	15	10	0.3	1	0.13	91.4	6.4284	0.7649
2015	12	26	2	25	10	0.3	1	0.17	124	6.4284	0.8022
2015	12	26	2	35	10	0.3	1	0.15	114.9	6.4284	0.7649
2015	12	26	2	45	10	0.3	1	0.18	109.1	6.4284	0.9701
2015	12	26	2	55	10	0.3	1	0.19	116.6	6.4284	0.9701
2015	12	26	3	5	10	0.3	1	0.21	102.3	6.4284	1.194
2015	12	26	3	15	10	0.3	1	0.18	126.7	6.4284	0.8022
2015	12	26	3	25	10	0.3	1	0.2	113.2	6.4284	1.0447
2015	12	26	3	35	10	0.3	1	0.21	108.4	6.4477	1.123
2015	12	26	3	45	10	0.3	1	0.21	108.4	6.4284	1.1194
2015	12	26	3	55	10	0.3	1	0.22	108.4	6.4284	1.1753
2015	12	26	4	5	10	0.3	1	0.18	107.8	6.4284	0.9888
2015	12	26	4	15	10	0.3	1	0.19	114.4	6.4284	0.9888
2015	12	26	4	25	10	0.3	1	0.18	101.7	6.4284	0.9888
2015	12	26	4	35	10	0.3	1	0.21	108.4	6.4284	1.1194
2015	12	26	4	45	10	0.3	1	0.21	136.2	6.4284	0.8395
2015	12	26	4	55	10	0.3	1	0.21	113	6.4284	1.1007
2015	12	26	5	5	10	0.3	1	0.21	104.7	6.4284	1.138
2015	12	26	5	15	10	0.3	1	0.21	113.4	6.4477	1.123
2015	12	26	5	25	10	0.3	1	0.17	122.1	6.4671	0.8074
2015	12	26	5	35	10	0.3	1	0.24	106.2	6.4477	1.2914

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	5	45	10	0.3	1	0.24	131.6	6.4477	1.0107
2015	12	26	5	55	10	0.3	1	0.22	142.3	6.4477	0.7674
2015	12	26	6	5	10	0.3	1	0.12	113.8	6.4477	0.6364
2015	12	26	6	15	10	0.3	1	0.21	110.4	6.4477	1.1043
2015	12	26	6	25	10	0.3	1	0.25	108.9	6.4477	1.3663
2015	12	26	6	35	10	0.3	1	0.22	111.5	6.4477	1.1417
2015	12	26	6	45	10	0.3	1	0.22	123.2	6.4477	1.0294
2015	12	26	6	55	10	0.3	1	0.19	130.1	6.4477	0.8235
2015	12	26	7	5	10	0.3	1	0.18	106.8	6.4477	0.992
2015	12	26	7	15	10	0.3	1	0.21	113.3	6.4477	1.0856
2015	12	26	7	25	10	0.3	1	0.25	105.3	6.4477	1.3663
2015	12	26	7	35	10	0.3	1	0.15	123.3	6.4477	0.7112
2015	12	26	7	45	10	0.3	1	0.17	92.2	6.4477	0.992
2015	12	26	7	55	10	0.3	1	0.21	134.4	6.4671	0.8637
2015	12	26	8	5	10	0.3	1	0.22	136.8	6.4477	0.8423
2015	12	26	8	15	10	0.3	1	0.2	114.8	6.4671	1.014
2015	12	26	8	25	10	0.3	1	0.19	114	6.4477	1.0107
2015	12	26	8	35	10	0.3	1	0.27	109.7	6.4671	1.4646
2015	12	26	8	45	10	0.3	1	0.24	113.1	6.4284	1.2686
2015	12	26	8	55	10	0.3	1	0.15	122.7	6.4284	0.7276
2015	12	26	9	5	10	0.3	1	0.27	126.6	6.4477	1.2353
2015	12	26	9	15	10	0.3	1	0.15	122	6.4284	0.7463
2015	12	26	9	25	10	0.3	1	0.2	117.8	6.4284	0.9888
2015	12	26	9	35	10	0.3	1	0.16	134.2	6.4477	0.6738
2015	12	26	9	45	10	0.3	1	0.23	115.8	6.4284	1.1567
2015	12	26	9	55	10	0.3	1	0.22	129.6	6.4284	0.9701
2015	12	26	10	5	10	0.3	1	0.17	126.4	6.4284	0.7836
2015	12	26	10	15	10	0.3	1	0.17	120	6.4284	0.8395
2015	12	26	10	25	10	0.3	1	0.14	117.1	6.4284	0.7276
2015	12	26	10	35	10	0.3	1	0.17	105.4	6.4284	0.9515
2015	12	26	10	45	10	0.3	1	0.19	90	6.4284	1.0634
2015	12	26	10	55	10	0.3	1	0.15	110	6.4284	0.8209
2015	12	26	11	5	10	0.3	1	0.15	116.6	6.4284	0.7836
2015	12	26	11	15	10	0.3	1	0.22	118.8	6.409	1.1158
2015	12	26	11	25	10	0.3	1	0.2	126.5	6.4284	0.9328
2015	12	26	11	35	10	0.3	1	0.24	121.9	6.4284	1.138
2015	12	26	11	45	10	0.3	1	0.16	121.8	6.4284	0.7836
2015	12	26	11	55	10	0.3	1	0.22	111.5	6.4284	1.138
2015	12	26	12	5	10	0.3	1	0.23	117.6	6.4284	1.1753
2015	12	26	12	15	10	0.3	1	0.25	102.2	6.4284	1.3805
2015	12	26	12	25	10	0.3	1	0.21	109	6.409	1.1343
2015	12	26	12	35	10	0.3	1	0.2	111.6	6.4284	1.082
2015	12	26	12	45	10	0.3	1	0.13	81.5	6.409	0.7438
2015	12	26	12	55	10	0.3	1	0.27	105.1	6.4284	1.4552
2015	12	26	13	5	10	0.3	1	0.22	113.5	6.409	1.1529
2015	12	26	13	15	10	0.3	1	0.18	99.5	6.4284	1.0074

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	13	25	10	0.3	1	0.19	95.9	6.409	1.0785
2015	12	26	13	35	10	0.3	1	0.31	128.1	6.409	1.3761
2015	12	26	13	45	10	0.3	1	0.17	126.4	6.409	0.781
2015	12	26	13	55	10	0.3	1	0.19	91	6.409	1.0971
2015	12	26	14	5	10	0.3	1	0.19	118.3	6.409	0.967
2015	12	26	14	15	10	0.3	1	0.18	105.5	6.409	1.0041
2015	12	26	14	25	10	0.3	1	0.17	105.4	6.409	0.9484
2015	12	26	14	35	10	0.3	1	0.19	106.9	6.409	1.0413
2015	12	26	14	45	10	0.3	1	0.18	83.9	6.409	1.0413
2015	12	26	14	55	10	0.3	1	0.15	103.7	6.409	0.8368
2015	12	26	15	5	10	0.3	1	0.22	102	6.409	1.2273
2015	12	26	15	15	10	0.3	1	0.16	99.3	6.409	0.9112
2015	12	26	15	25	10	0.3	1	0.19	93	6.409	1.0785
2015	12	26	15	35	10	0.3	1	0.22	81.4	6.409	1.2273
2015	12	26	15	45	10	0.3	1	0.22	91.7	6.409	1.2645
2015	12	26	15	55	10	0.3	1	0.23	100	6.409	1.2645
2015	12	26	16	5	10	0.3	1	0.16	102	6.409	0.874
2015	12	26	16	15	10	0.3	1	0.14	105.9	6.409	0.781
2015	12	26	16	25	10	0.3	1	0.21	120.7	6.409	1.0041
2015	12	26	16	35	10	0.3	1	0.27	107.4	6.409	1.4876
2015	12	26	16	45	10	0.3	1	0.22	96.9	6.409	1.2273
2015	12	26	16	55	10	0.3	1	0.17	102.2	6.409	0.9484
2015	12	26	17	5	10	0.3	1	0.2	129.6	6.409	0.8554
2015	12	26	17	15	10	0.3	1	0.2	90.9	6.409	1.1343
2015	12	26	17	25	10	0.3	1	0.19	101.7	6.409	1.0785
2015	12	26	17	35	10	0.3	1	0.18	123.1	6.409	0.8554
2015	12	26	17	45	10	0.3	1	0.17	122.1	6.409	0.7996
2015	12	26	17	55	10	0.3	1	0.18	129.1	6.409	0.7996
2015	12	26	18	5	10	0.3	1	0.24	108.7	6.409	1.2645
2015	12	26	18	15	10	0.3	1	0.19	91	6.409	1.0971
2015	12	26	18	25	10	0.3	1	0.14	87.3	6.409	0.781
2015	12	26	18	35	10	0.3	1	0.13	94.2	6.409	0.7624
2015	12	26	18	45	10	0.3	1	0.13	92.9	6.409	0.7252
2015	12	26	18	55	10	0.3	1	0.25	109.6	6.409	1.3575
2015	12	26	19	5	10	0.3	1	0.15	90	6.409	0.8368
2015	12	26	19	15	10	0.3	1	0.23	105.4	6.409	1.2831
2015	12	26	19	25	10	0.3	1	0.11	83.3	6.409	0.6322
2015	12	26	19	35	10	0.3	1	0.25	101.5	6.409	1.3761
2015	12	26	19	45	10	0.3	1	0.16	90	6.409	0.9112
2015	12	26	19	55	10	0.3	1	0.15	76.3	6.409	0.8368
2015	12	26	20	5	10	0.3	1	0.21	93.6	6.409	1.1715
2015	12	26	20	15	10	0.3	1	0.25	104.2	6.409	1.3947
2015	12	26	20	25	10	0.3	1	0.24	99.3	6.409	1.3575
2015	12	26	20	35	10	0.3	1	0.23	91.6	6.409	1.3203
2015	12	26	20	45	10	0.3	1	0.14	141.8	6.409	0.4835
2015	12	26	20	55	10	0.3	1	0.18	129	6.3897	0.7785

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	21	5	10	0.3	1	0.18	99.6	6.409	0.9856
2015	12	26	21	15	10	0.3	1	0.18	126.7	6.3897	0.797
2015	12	26	21	25	10	0.3	1	0.14	114.8	6.3897	0.7229
2015	12	26	21	35	10	0.3	1	0.22	104.9	6.3897	1.1863
2015	12	26	21	45	10	0.3	1	0.21	93.6	6.3897	1.1677
2015	12	26	21	55	10	0.3	1	0.09	105.1	6.409	0.4835
2015	12	26	22	5	10	0.3	1	0.13	125.7	6.3897	0.5931
2015	12	26	22	15	10	0.3	1	0.15	128.1	6.3897	0.6858
2015	12	26	22	25	10	0.3	1	0.15	109.7	6.409	0.781
2015	12	26	22	35	10	0.3	1	0.22	106.5	6.3897	1.1863
2015	12	26	22	45	10	0.3	1	0.21	93.6	6.409	1.1901
2015	12	26	22	55	10	0.3	1	0.11	101.6	6.3897	0.6302
2015	12	26	23	5	10	0.3	1	0.14	107.2	6.409	0.781
2015	12	26	23	15	10	0.3	1	0.18	122.8	6.3897	0.8341
2015	12	26	23	25	10	0.3	1	0.19	98	6.3897	1.0565
2015	12	26	23	35	10	0.3	1	0.14	106.7	6.3897	0.7414
2015	12	26	23	45	10	0.3	1	0.22	93.4	6.3897	1.2419
2015	12	26	23	55	10	0.3	1	0.17	90	6.3897	0.9824
2015	12	27	0	5	10	0.3	1	0.22	94.3	6.3897	1.2234
2015	12	27	0	15	10	0.3	1	0.15	83.5	6.3897	0.8156
2015	12	27	0	25	10	0.3	1	0.15	118.3	6.409	0.7252
2015	12	27	0	35	10	0.3	1	0.2	122.4	6.409	0.967
2015	12	27	0	45	10	0.3	1	0.15	88.8	6.409	0.8554
2015	12	27	0	55	10	0.3	1	0.15	95	6.409	0.8554
2015	12	27	1	5	10	0.3	1	0.22	98.7	6.409	1.2087
2015	12	27	1	15	10	0.3	1	0.16	84.1	6.409	0.8926
2015	12	27	1	25	10	0.3	1	0.18	109.7	6.409	0.9856
2015	12	27	1	35	10	0.3	1	0.22	110.6	6.409	1.1902
2015	12	27	1	45	10	0.3	1	0.15	100.3	6.409	0.8182
2015	12	27	1	55	10	0.3	1	0.12	90	6.409	0.6881
2015	12	27	2	5	10	0.3	1	0.19	105.9	6.409	1.0414
2015	12	27	2	15	10	0.3	1	0.22	121.6	6.409	1.06
2015	12	27	2	25	10	0.3	1	0.17	121.9	6.409	0.8368
2015	12	27	2	35	10	0.3	1	0.17	129.5	6.409	0.7439
2015	12	27	2	45	10	0.3	1	0.13	101.9	6.409	0.7067
2015	12	27	2	55	10	0.3	1	0.15	105.3	6.409	0.8182
2015	12	27	3	5	10	0.3	1	0.16	125	6.409	0.7439
2015	12	27	3	15	10	0.3	1	0.18	114.7	6.409	0.9298
2015	12	27	3	25	10	0.3	1	0.17	135	6.409	0.6695
2015	12	27	3	35	10	0.3	1	0.15	110	6.409	0.8182
2015	12	27	3	45	10	0.3	1	0.21	105.9	6.409	1.1716
2015	12	27	3	55	10	0.3	1	0.22	105.7	6.409	1.1902
2015	12	27	4	5	10	0.3	1	0.23	120.3	6.409	1.1158
2015	12	27	4	15	10	0.3	1	0.18	111	6.409	0.967
2015	12	27	4	25	10	0.3	1	0.23	111	6.409	1.2088
2015	12	27	4	35	10	0.3	1	0.26	124.1	6.409	1.2088

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	4	45	10	0.3	1	0.24	120.1	6.409	1.153
2015	12	27	4	55	10	0.3	1	0.24	115.2	6.409	1.2274
2015	12	27	5	5	10	0.3	1	0.19	105.3	6.409	1.0228
2015	12	27	5	15	10	0.3	1	0.24	111.7	6.409	1.2646
2015	12	27	5	25	10	0.3	1	0.16	116.6	6.409	0.8183
2015	12	27	5	35	10	0.3	1	0.24	132.3	6.409	1.0228
2015	12	27	5	45	10	0.3	1	0.17	124.9	6.409	0.7997
2015	12	27	5	55	10	0.3	1	0.22	111.5	6.409	1.1344
2015	12	27	6	5	10	0.3	1	0.27	102.8	6.409	1.4691
2015	12	27	6	15	10	0.3	1	0.25	117.9	6.409	1.2646
2015	12	27	6	25	10	0.3	1	0.21	127.4	6.409	0.9484
2015	12	27	6	35	10	0.3	1	0.19	110.7	6.409	0.9856
2015	12	27	6	45	10	0.3	1	0.23	117.3	6.409	1.153
2015	12	27	6	55	10	0.3	1	0.2	131.6	6.409	0.8369
2015	12	27	7	5	10	0.3	1	0.25	114.2	6.409	1.2832
2015	12	27	7	15	10	0.3	1	0.19	127.3	6.409	0.8554
2015	12	27	7	25	10	0.3	1	0.28	117.2	6.4284	1.4179
2015	12	27	7	35	10	0.3	1	0.25	106.3	6.409	1.339
2015	12	27	7	45	10	0.3	1	0.23	133.2	6.409	0.9298
2015	12	27	7	55	10	0.3	1	0.2	113.6	6.409	1.0228
2015	12	27	8	5	10	0.3	1	0.2	125.2	6.409	0.9484
2015	12	27	8	15	10	0.3	1	0.24	119.7	6.409	1.1716
2015	12	27	8	25	10	0.3	1	0.2	119.1	6.409	0.967
2015	12	27	8	35	10	0.3	1	0.29	116.9	6.409	1.4691
2015	12	27	8	45	10	0.3	1	0.18	123.4	6.409	0.874
2015	12	27	8	55	10	0.3	1	0.16	109.6	6.409	0.8369
2015	12	27	9	5	10	0.3	1	0.23	101.3	6.409	1.3018
2015	12	27	9	15	10	0.3	1	0.27	166.6	6.409	0.3533
2015	12	27	9	25	10	0.3	1	0.25	177.8	6.409	0.0558
2015	12	27	9	35	10	0.3	1	0.65	205	6.409	-1.5621
2015	12	27	9	45	10	0.3	1	0.43	63.6	6.409	2.1758
2015	12	27	9	55	10	0.3	1	0.62	205.2	6.4864	-1.5259
2015	12	27	10	5	10	0.3	1	1.01	210.6	6.4477	-2.9386
2015	12	27	10	15	10	0.3	1	0.94	210.5	6.5252	-2.749
2015	12	27	10	25	10	0.3	1	0.45	78.5	6.5832	2.5455
2015	12	27	10	35	10	0.3	1	0.23	141.3	6.4671	0.8262
2015	12	27	10	45	10	0.3	1	1.44	215.2	6.5058	-4.7812
2015	12	27	10	55	10	0.3	1	0.56	210	6.5252	-1.6115
2015	12	27	11	5	10	0.3	1	3.5	46.7	6.5058	14.6836
2015	12	27	11	15	10	0.3	1	1.1	216.3	6.5058	-3.7418
2015	12	27	11	25	10	0.3	1	0.17	139	6.5058	0.6236
2015	12	27	11	35	10	0.3	1	1.51	222.4	6.409	-5.7834
2015	12	27	11	45	10	0.3	1	0.15	160.8	6.409	0.2789
2015	12	27	11	55	10	0.3	1	0.34	65.4	6.409	1.748
2015	12	27	12	5	10	0.3	1	0.27	82.5	6.409	1.5435
2015	12	27	12	15	10	0.3	1	0.26	124.1	6.409	1.2087

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	12	25	10	0.3	1	0.2	121.9	6.409	0.9856
2015	12	27	12	35	10	0.3	1	0.21	119.7	6.409	1.0414
2015	12	27	12	45	10	0.3	1	0.25	125.8	6.409	1.1344
2015	12	27	12	55	10	0.3	1	0.19	119.7	6.409	0.9112
2015	12	27	13	5	10	0.3	1	0.22	104.4	6.409	1.2273
2015	12	27	13	15	10	0.3	1	0.25	96.8	6.409	1.3947
2015	12	27	13	25	10	0.3	1	0.21	116.2	6.409	1.06
2015	12	27	13	35	10	0.3	1	0.17	124.6	6.409	0.781
2015	12	27	13	45	10	0.3	1	0.14	131.2	6.409	0.5951
2015	12	27	13	55	10	0.3	1	0.22	109	6.409	1.1901
2015	12	27	14	5	10	0.3	1	0.17	88.9	6.409	0.9484
2015	12	27	14	15	10	0.3	1	0.18	120.8	6.409	0.874
2015	12	27	14	25	10	0.3	1	0.19	92.9	6.409	1.0972
2015	12	27	14	35	10	0.3	1	0.21	104.7	6.409	1.1344
2015	12	27	14	45	10	0.3	1	0.22	115.4	6.409	1.1344
2015	12	27	14	55	10	0.3	1	0.21	110.4	6.409	1.0972
2015	12	27	15	5	10	0.3	1	0.25	109.1	6.409	1.3389
2015	12	27	15	15	10	0.3	1	0.21	100.6	6.409	1.1901
2015	12	27	15	25	10	0.3	1	0.18	107.1	6.409	0.967
2015	12	27	15	35	10	0.3	1	0.16	112.2	6.409	0.8182
2015	12	27	15	45	10	0.3	1	0.17	99.1	6.409	0.9298
2015	12	27	15	55	10	0.3	1	0.13	99	6.409	0.7067
2015	12	27	16	5	10	0.3	1	0.22	106.5	6.3897	1.1863
2015	12	27	16	15	10	0.3	1	0.18	108.4	6.3897	0.9453
2015	12	27	16	25	10	0.3	1	0.21	126.2	6.3897	0.9639
2015	12	27	16	35	10	0.3	1	0.14	84.8	6.3897	0.8156
2015	12	27	16	45	10	0.3	1	0.2	100.6	6.3897	1.0936
2015	12	27	16	55	10	0.3	1	0.18	102.8	6.3897	0.9824
2015	12	27	17	5	10	0.3	1	0.2	70.7	6.3897	1.0565
2015	12	27	17	15	10	0.3	1	0.09	107.1	6.3897	0.4819
2015	12	27	17	25	10	0.3	1	0.15	117.7	6.3897	0.7414
2015	12	27	17	35	10	0.3	1	0.16	134.2	6.3897	0.6673
2015	12	27	17	45	10	0.3	1	0.24	90	6.3897	1.3716
2015	12	27	17	55	10	0.3	1	0.24	110.2	6.3897	1.2604
2015	12	27	18	5	10	0.3	1	0.09	120.3	6.3897	0.4449
2015	12	27	18	15	10	0.3	1	0.17	122.5	6.3897	0.8156
2015	12	27	18	25	10	0.3	1	0.14	117.8	6.3897	0.7044
2015	12	27	18	35	10	0.3	1	0.19	110.9	6.3897	1.0195
2015	12	27	18	45	10	0.3	1	0.19	121.8	6.3897	0.9268
2015	12	27	18	55	10	0.3	1	0.22	84.1	6.3897	1.2604
2015	12	27	19	5	10	0.3	1	0.18	97.5	6.3897	0.9824
2015	12	27	19	15	10	0.3	1	0.16	92.3	6.3897	0.9268
2015	12	27	19	25	10	0.3	1	0.17	112.2	6.409	0.9112
2015	12	27	19	35	10	0.3	1	0.19	93.9	6.3897	1.0751
2015	12	27	19	45	10	0.3	1	0.21	117.8	6.409	1.06
2015	12	27	19	55	10	0.3	1	0.16	94.7	6.3897	0.9082

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	20	5	10	0.3	1	0.12	99.5	6.409	0.6694
2015	12	27	20	15	10	0.3	1	0.18	116.6	6.409	0.8926
2015	12	27	20	25	10	0.3	1	0.19	120.6	6.409	0.9112
2015	12	27	20	35	10	0.3	1	0.21	107.3	6.3897	1.1307
2015	12	27	20	45	10	0.3	1	0.12	110.4	6.3897	0.6487
2015	12	27	20	55	10	0.3	1	0.19	127.3	6.409	0.8554
2015	12	27	21	5	10	0.3	1	0.14	105	6.409	0.7624
2015	12	27	21	15	10	0.3	1	0.17	124.9	6.409	0.7996
2015	12	27	21	25	10	0.3	1	0.18	101.5	6.409	1.0042
2015	12	27	21	35	10	0.3	1	0.16	130.1	6.3897	0.7043
2015	12	27	21	45	10	0.3	1	0.16	116.1	6.409	0.8368
2015	12	27	21	55	10	0.3	1	0.17	112.2	6.409	0.9112
2015	12	27	22	5	10	0.3	1	0.2	111.4	6.3897	1.038
2015	12	27	22	15	10	0.3	1	0.19	121.5	6.409	0.9112
2015	12	27	22	25	10	0.3	1	0.16	115	6.3897	0.8341
2015	12	27	22	35	10	0.3	1	0.19	109.4	6.409	1.0042
2015	12	27	22	45	10	0.3	1	0.18	112	6.3897	0.9638
2015	12	27	22	55	10	0.3	1	0.21	124.9	6.409	0.9856
2015	12	27	23	5	10	0.3	1	0.18	104.8	6.3897	0.9824
2015	12	27	23	15	10	0.3	1	0.15	110.4	6.3897	0.797
2015	12	27	23	25	10	0.3	1	0.22	112.4	6.3897	1.1677
2015	12	27	23	35	10	0.3	1	0.19	100	6.3897	1.0565
2015	12	27	23	45	10	0.3	1	0.12	128.2	6.3897	0.519
2015	12	27	23	55	10	0.3	1	0.19	98	6.3897	1.0565
2015	12	28	0	5	10	0.3	1	0.13	131.9	6.3897	0.5375
2015	12	28	0	15	10	0.3	1	0.12	109.4	6.3897	0.6302
2015	12	28	0	25	10	0.3	1	0.17	117.1	6.3897	0.8341
2015	12	28	0	35	10	0.3	1	0.19	127.3	6.3897	0.8526
2015	12	28	0	45	10	0.3	1	0.13	129.8	6.3897	0.5561
2015	12	28	0	55	10	0.3	1	0.13	120.5	6.3897	0.6302
2015	12	28	1	5	10	0.3	1	0.22	132.6	6.3897	0.9083
2015	12	28	1	15	10	0.3	1	0.18	102.5	6.3897	1.0009
2015	12	28	1	25	10	0.3	1	0.21	107	6.3897	1.1492
2015	12	28	1	35	10	0.3	1	0.16	126.6	6.3897	0.7229
2015	12	28	1	45	10	0.3	1	0.23	129.7	6.3897	0.9824
2015	12	28	1	55	10	0.3	1	0.17	112.6	6.3897	0.8897
2015	12	28	2	5	10	0.3	1	0.19	113.5	6.3897	0.9824
2015	12	28	2	15	10	0.3	1	0.15	110	6.3897	0.8156
2015	12	28	2	25	10	0.3	1	0.17	129.5	6.3897	0.7414
2015	12	28	2	35	10	0.3	1	0.17	131.2	6.3897	0.7414
2015	12	28	2	45	10	0.3	1	0.17	127.8	6.3897	0.7414
2015	12	28	2	55	10	0.3	1	0.22	96.8	6.3897	1.2419
2015	12	28	3	5	10	0.3	1	0.18	102.5	6.3897	1.0009
2015	12	28	3	15	10	0.3	1	0.21	114.1	6.3897	1.0751
2015	12	28	3	25	10	0.3	1	0.17	115.6	6.3897	0.8527
2015	12	28	3	35	10	0.3	1	0.23	125.5	6.3897	1.038

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	3	45	10	0.3	1	0.19	140.6	6.3897	0.6858
2015	12	28	3	55	10	0.3	1	0.18	125.4	6.3897	0.8341
2015	12	28	4	5	10	0.3	1	0.21	102.7	6.3897	1.1492
2015	12	28	4	15	10	0.3	1	0.15	104	6.3897	0.8156
2015	12	28	4	25	10	0.3	1	0.15	113.8	6.3897	0.7971
2015	12	28	4	35	10	0.3	1	0.15	129.6	6.3897	0.6488
2015	12	28	4	45	10	0.3	1	0.19	103.1	6.3897	1.038
2015	12	28	4	55	10	0.3	1	0.19	117.9	6.3897	0.9453
2015	12	28	5	5	10	0.3	1	0.17	98.7	6.3897	0.9639
2015	12	28	5	15	10	0.3	1	0.17	111.2	6.3897	0.9083
2015	12	28	5	25	10	0.3	1	0.2	123.2	6.3897	0.9639
2015	12	28	5	35	10	0.3	1	0.23	134.4	6.3897	0.9083
2015	12	28	5	45	10	0.3	1	0.26	120.5	6.3897	1.2605
2015	12	28	5	55	10	0.3	1	0.25	137.6	6.3897	0.9639
2015	12	28	6	5	10	0.3	1	0.22	122	6.3897	1.038
2015	12	28	6	15	10	0.3	1	0.19	124.2	6.3897	0.8712
2015	12	28	6	25	10	0.3	1	0.15	127.1	6.3897	0.6858
2015	12	28	6	35	10	0.3	1	0.22	112.4	6.3897	1.1678
2015	12	28	6	45	10	0.3	1	0.21	123.9	6.3897	0.9639
2015	12	28	6	55	10	0.3	1	0.26	108.2	6.3897	1.4088
2015	12	28	7	5	10	0.3	1	0.21	126.7	6.3897	0.9454
2015	12	28	7	15	10	0.3	1	0.19	133.6	6.3897	0.7785
2015	12	28	7	25	10	0.3	1	0.19	135	6.3897	0.7415
2015	12	28	7	35	10	0.3	1	0.17	112.2	6.3897	0.9083
2015	12	28	7	45	10	0.3	1	0.17	122.1	6.3897	0.7971
2015	12	28	7	55	10	0.3	1	0.19	103.8	6.3897	1.0566
2015	12	28	8	5	10	0.3	1	0.17	114.1	6.3897	0.8712
2015	12	28	8	15	10	0.3	1	0.16	99.5	6.3897	0.8897
2015	12	28	8	25	10	0.3	1	0.15	115.5	6.3897	0.7785
2015	12	28	8	35	10	0.3	1	0.18	131.3	6.3897	0.76
2015	12	28	8	45	10	0.3	1	0.21	135.6	6.3897	0.8156
2015	12	28	8	55	10	0.3	1	0.21	120.5	6.3897	1.038
2015	12	28	9	5	10	0.3	1	0.11	103.2	6.3897	0.6302
2015	12	28	9	15	10	0.3	1	0.22	107.4	6.3897	1.1863
2015	12	28	9	25	10	0.3	1	0.18	117.5	6.3897	0.8897
2015	12	28	9	35	10	0.3	1	0.13	117.8	6.3897	0.6673
2015	12	28	9	45	10	0.3	1	0.16	133.4	6.3897	0.6673
2015	12	28	9	55	10	0.3	1	0.17	112.2	6.3897	0.9083
2015	12	28	10	5	10	0.3	1	0.22	120.4	6.3897	1.0751
2015	12	28	10	15	10	0.3	1	0.16	131.6	6.3897	0.6673
2015	12	28	10	25	10	0.3	1	0.13	131.9	6.3897	0.5376
2015	12	28	10	35	10	0.3	1	0.19	131.6	6.3897	0.8156
2015	12	28	10	45	10	0.3	1	0.19	124	6.3897	0.9083
2015	12	28	10	55	10	0.3	1	0.22	118.1	6.3897	1.1122
2015	12	28	11	5	10	0.3	1	0.17	118	6.3897	0.8712
2015	12	28	11	15	10	0.3	1	0.2	127.6	6.3897	0.8897

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	11	25	10	0.3	1	0.22	115.4	6.3897	1.1307
2015	12	28	11	35	10	0.3	1	0.28	113.3	6.3897	1.4643
2015	12	28	11	45	10	0.3	1	0.17	93.4	6.3897	0.9453
2015	12	28	11	55	10	0.3	1	0.11	137.5	6.3897	0.4078
2015	12	28	12	5	10	0.3	1	0.18	112.4	6.3897	0.9453
2015	12	28	12	15	10	0.3	1	0.18	99.6	6.3897	0.9824
2015	12	28	12	25	10	0.3	1	0.23	113.3	6.3897	1.2048
2015	12	28	12	35	10	0.3	1	0.14	132.1	6.3897	0.5746
2015	12	28	12	45	10	0.3	1	0.21	131.3	6.3897	0.9083
2015	12	28	12	55	10	0.3	1	0.22	122.3	6.3897	1.0565
2015	12	28	13	5	10	0.3	1	0.21	132.5	6.3897	0.8897
2015	12	28	13	15	10	0.3	1	0.22	127.7	6.3897	0.9824
2015	12	28	13	25	10	0.3	1	0.2	137.7	6.3897	0.76
2015	12	28	13	35	10	0.3	1	0.18	116.6	6.3897	0.9268
2015	12	28	13	45	10	0.3	1	0.22	98.7	6.3703	1.2009
2015	12	28	13	55	10	0.3	1	0.21	135	6.3897	0.8526
2015	12	28	14	5	10	0.3	1	0.19	124.5	6.3897	0.8897
2015	12	28	14	15	10	0.3	1	0.2	135	6.3703	0.8129
2015	12	28	14	25	10	0.3	1	0.17	116.1	6.3703	0.8684
2015	12	28	14	35	10	0.3	1	0.21	122.9	6.3703	0.9977
2015	12	28	14	45	10	0.3	1	0.16	115	6.3703	0.8314
2015	12	28	14	55	10	0.3	1	0.18	132.8	6.3703	0.739
2015	12	28	15	5	10	0.3	1	0.17	127.3	6.3703	0.776
2015	12	28	15	15	10	0.3	1	0.11	128.9	6.3703	0.4804
2015	12	28	15	25	10	0.3	1	0.23	135	6.3509	0.9024
2015	12	28	15	35	10	0.3	1	0.14	105	6.3703	0.7575
2015	12	28	15	45	10	0.3	1	0.19	121.8	6.3703	0.9238
2015	12	28	15	55	10	0.3	1	0.14	129.1	6.3703	0.5912
2015	12	28	16	5	10	0.3	1	0.15	90	6.3509	0.8287
2015	12	28	16	15	10	0.3	1	0.18	85.8	6.3509	1.0128
2015	12	28	16	25	10	0.3	1	0.14	83.2	6.3509	0.7734
2015	12	28	16	35	10	0.3	1	0.19	71.9	6.3703	1.0161
2015	12	28	16	45	10	0.3	1	0.15	76.3	6.3509	0.8287
2015	12	28	16	55	10	0.3	1	0.2	70.1	6.3703	1.0716
2015	12	28	17	5	10	0.3	1	0.16	69.3	6.3703	0.8314
2015	12	28	17	15	10	0.3	1	0.17	69.8	6.3703	0.9053
2015	12	28	17	25	10	0.3	1	0.23	90	6.3703	1.2748
2015	12	28	17	35	10	0.3	1	0.17	53.8	6.3703	0.7575
2015	12	28	17	45	10	0.3	1	0.17	66.8	6.3703	0.9053
2015	12	28	17	55	10	0.3	1	0.22	63	6.3703	1.09
2015	12	28	18	5	10	0.3	1	0.21	77.7	6.3703	1.1824
2015	12	28	18	15	10	0.3	1	0.2	62.2	6.3703	1.0161
2015	12	28	18	25	10	0.3	1	0.17	74.6	6.3703	0.9422
2015	12	28	18	35	10	0.3	1	0.21	57.1	6.3703	0.9977
2015	12	28	18	45	10	0.3	1	0.26	55.3	6.3703	1.2009
2015	12	28	18	55	10	0.3	1	0.19	54.3	6.3703	0.8499

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	19	5	10	0.3	1	0.18	47.9	6.3703	0.7575
2015	12	28	19	15	10	0.3	1	0.24	56.1	6.3703	1.127
2015	12	28	19	25	10	0.3	1	0.22	53	6.3703	0.9792
2015	12	28	19	35	10	0.3	1	0.23	58.8	6.3703	1.127
2015	12	28	19	45	10	0.3	1	0.25	33.9	6.3703	0.7944
2015	12	28	19	55	10	0.3	1	0.18	45	6.3703	0.7205
2015	12	28	20	5	10	0.3	1	0.26	62.8	6.3703	1.2933
2015	12	28	20	15	10	0.3	1	0.33	59	6.3703	1.5704
2015	12	28	20	25	10	0.3	1	0.19	56	6.3703	0.9053
2015	12	28	20	35	10	0.3	1	0.26	46	6.3703	1.0346
2015	12	28	20	45	10	0.3	1	0.31	63.2	6.3703	1.5704
2015	12	28	20	55	10	0.3	1	0.24	52.8	6.3703	1.0716
2015	12	28	21	5	10	0.3	1	0.26	53.3	6.3703	1.1639
2015	12	28	21	15	10	0.3	1	0.21	57.3	6.3703	0.9792
2015	12	28	21	25	10	0.3	1	0.24	46.7	6.3703	0.9792
2015	12	28	21	35	10	0.3	1	0.24	47.7	6.3897	1.0194
2015	12	28	21	45	10	0.3	1	0.27	65.9	6.3897	1.4087
2015	12	28	21	55	10	0.3	1	0.25	47.6	6.3703	1.0531
2015	12	28	22	5	10	0.3	1	0.3	53.1	6.3897	1.3345
2015	12	28	22	15	10	0.3	1	0.3	48.6	6.3897	1.2604
2015	12	28	22	25	10	0.3	1	0.27	57.8	6.3897	1.2975
2015	12	28	22	35	10	0.3	1	0.12	73	6.3897	0.6673
2015	12	28	22	45	10	0.3	1	0.18	61	6.3703	0.8683
2015	12	28	22	55	10	0.3	1	0.2	35.5	6.3897	0.6487
2015	12	28	23	5	10	0.3	1	0.17	45	6.3703	0.6836
2015	12	28	23	15	10	0.3	1	0.14	21	6.3703	0.2771
2015	12	28	23	25	10	0.3	1	0.15	99	6.3897	0.8156
2015	12	28	23	35	10	0.3	1	0.15	64	6.3897	0.76
2015	12	28	23	45	10	0.3	1	0.18	87.9	6.3897	1.0195
2015	12	28	23	55	10	0.3	1	0.14	73.3	6.3897	0.7414
2015	12	29	0	5	10	0.3	1	0.16	90	6.3897	0.8897
2015	12	29	0	15	10	0.3	1	0.13	80.1	6.3897	0.7414
2015	12	29	0	25	10	0.3	1	0.14	80.5	6.3897	0.7785
2015	12	29	0	35	10	0.3	1	0.21	90	6.3897	1.1677
2015	12	29	0	45	10	0.3	1	0.18	102.8	6.3703	0.9792
2015	12	29	0	55	10	0.3	1	0.13	90	6.3703	0.739
2015	12	29	1	5	10	0.3	1	0.23	99.1	6.3703	1.2748
2015	12	29	1	15	10	0.3	1	0.15	78.7	6.3703	0.8314
2015	12	29	1	25	10	0.3	1	0.16	86.4	6.3897	0.8897
2015	12	29	1	35	10	0.3	1	0.23	96.4	6.3703	1.3118
2015	12	29	1	45	10	0.3	1	0.21	107.6	6.3897	1.1121
2015	12	29	1	55	10	0.3	1	0.15	104.9	6.3703	0.8314
2015	12	29	2	5	10	0.3	1	0.15	118.2	6.3703	0.7575
2015	12	29	2	15	10	0.3	1	0.19	102.1	6.3703	1.0346
2015	12	29	2	25	10	0.3	1	0.19	110	6.3703	1.0162
2015	12	29	2	35	10	0.3	1	0.17	101.9	6.3703	0.9607

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	2	45	10	0.3	1	0.19	76	6.3703	1.0346
2015	12	29	2	55	10	0.3	1	0.16	99.7	6.3703	0.8684
2015	12	29	3	5	10	0.3	1	0.2	136.3	6.3703	0.7945
2015	12	29	3	15	10	0.3	1	0.15	107.7	6.3703	0.8129
2015	12	29	3	25	10	0.3	1	0.17	109.1	6.3703	0.9053
2015	12	29	3	35	10	0.3	1	0.1	124.7	6.3703	0.4804
2015	12	29	3	45	10	0.3	1	0.22	104.9	6.3703	1.1824
2015	12	29	3	55	10	0.3	1	0.2	103.3	6.3703	1.0901
2015	12	29	4	5	10	0.3	1	0.19	101.1	6.3703	1.0346
2015	12	29	4	15	10	0.3	1	0.16	102.9	6.3703	0.8868
2015	12	29	4	25	10	0.3	1	0.17	117.1	6.3703	0.8314
2015	12	29	4	35	10	0.3	1	0.2	107.9	6.3703	1.0901
2015	12	29	4	45	10	0.3	1	0.25	111.5	6.3703	1.3118
2015	12	29	4	55	10	0.3	1	0.22	107.6	6.3703	1.164
2015	12	29	5	5	10	0.3	1	0.14	105.9	6.3703	0.776
2015	12	29	5	15	10	0.3	1	0.19	135.7	6.3703	0.739
2015	12	29	5	25	10	0.3	1	0.21	113	6.3703	1.0901
2015	12	29	5	35	10	0.3	1	0.16	120.2	6.3703	0.7945
2015	12	29	5	45	10	0.3	1	0.17	105.9	6.3703	0.9053
2015	12	29	5	55	10	0.3	1	0.21	128.1	6.3703	0.9423
2015	12	29	6	5	10	0.3	1	0.12	108.4	6.3703	0.6651
2015	12	29	6	15	10	0.3	1	0.14	130.2	6.3703	0.5912
2015	12	29	6	25	10	0.3	1	0.18	122.8	6.3703	0.8314
2015	12	29	6	35	10	0.3	1	0.15	85	6.3703	0.8499
2015	12	29	6	45	10	0.3	1	0.26	115.9	6.3703	1.3303
2015	12	29	6	55	10	0.3	1	0.22	118.5	6.3703	1.0901
2015	12	29	7	5	10	0.3	1	0.18	117.5	6.3703	0.8868
2015	12	29	7	15	10	0.3	1	0.16	108.8	6.3703	0.8684
2015	12	29	7	25	10	0.3	1	0.13	113.4	6.3703	0.6836
2015	12	29	7	35	10	0.3	1	0.14	106.7	6.3703	0.739
2015	12	29	7	45	10	0.3	1	0.18	120.8	6.3703	0.8684
2015	12	29	7	55	10	0.3	1	0.17	114.1	6.3703	0.8684
2015	12	29	8	5	10	0.3	1	0.22	90	6.3703	1.2564
2015	12	29	8	15	10	0.3	1	0.16	135	6.3703	0.6282
2015	12	29	8	25	10	0.3	1	0.15	135	6.3703	0.6097
2015	12	29	8	35	10	0.3	1	0.13	99.9	6.3703	0.739
2015	12	29	8	45	10	0.3	1	0.15	110	6.3703	0.8129
2015	12	29	8	55	10	0.3	1	0.13	137.1	6.3703	0.4804
2015	12	29	9	5	10	0.3	1	0.21	123.7	6.3703	0.9977
2015	12	29	9	15	10	0.3	1	0.16	118.6	6.3703	0.8129
2015	12	29	9	25	10	0.3	1	0.2	98.5	6.3703	1.1086
2015	12	29	9	35	10	0.3	1	0.17	115.6	6.3703	0.8868
2015	12	29	9	45	10	0.3	1	0.19	117.9	6.3703	0.9423
2015	12	29	9	55	10	0.3	1	0.13	128	6.3703	0.5912
2015	12	29	10	5	10	0.3	1	0.08	82.9	6.3703	0.4434
2015	12	29	10	15	10	0.3	1	0.15	126.9	6.3703	0.6651

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	10	25	10	0.3	1	0.17	116.1	6.3703	0.8684
2015	12	29	10	35	10	0.3	1	0.14	111	6.3703	0.7206
2015	12	29	10	45	10	0.3	1	0.18	108.8	6.3703	0.9792
2015	12	29	10	55	10	0.3	1	0.12	108.4	6.3703	0.6651
2015	12	29	11	5	10	0.3	1	0.25	95.9	6.3703	1.4226
2015	12	29	11	15	10	0.3	1	0.2	129.6	6.3703	0.8499
2015	12	29	11	25	10	0.3	1	0.18	88.9	6.3703	0.9977
2015	12	29	11	35	10	0.3	1	0.19	135	6.3703	0.776
2015	12	29	11	45	10	0.3	1	0.15	116.6	6.3703	0.739
2015	12	29	11	55	10	0.3	1	0.16	96.1	6.3703	0.8683
2015	12	29	12	5	10	0.3	1	0.19	101.1	6.3703	1.0346
2015	12	29	12	15	10	0.3	1	0.17	84.6	6.3703	0.9792
2015	12	29	12	25	10	0.3	1	0.19	110.7	6.3703	0.9792
2015	12	29	12	35	10	0.3	1	0.22	118.5	6.3703	1.09
2015	12	29	12	45	10	0.3	1	0.18	115.2	6.3703	0.9422
2015	12	29	12	55	10	0.3	1	0.15	116	6.3703	0.7575
2015	12	29	13	5	10	0.3	1	0.19	103.1	6.3703	1.0346
2015	12	29	13	15	10	0.3	1	0.15	102.8	6.3703	0.8129
2015	12	29	13	25	10	0.3	1	0.26	108.7	6.3703	1.3671
2015	12	29	13	35	10	0.3	1	0.22	113.9	6.3703	1.127
2015	12	29	13	45	10	0.3	1	0.11	115	6.3703	0.5542
2015	12	29	13	55	10	0.3	1	0.15	100.3	6.3703	0.8129
2015	12	29	14	5	10	0.3	1	0.14	107.2	6.3703	0.7759
2015	12	29	14	15	10	0.3	1	0.18	99.5	6.3703	0.9976
2015	12	29	14	25	10	0.3	1	0.17	102.2	6.3703	0.9422
2015	12	29	14	35	10	0.3	1	0.17	117.6	6.3703	0.8498
2015	12	29	14	45	10	0.3	1	0.14	122.6	6.3703	0.6651
2015	12	29	14	55	10	0.3	1	0.17	118.5	6.3703	0.8498
2015	12	29	15	5	10	0.3	1	0.18	123.7	6.3703	0.8314
2015	12	29	15	15	10	0.3	1	0.14	67.7	6.3703	0.7205
2015	12	29	15	25	10	0.3	1	0.19	92	6.3703	1.0531
2015	12	29	15	35	10	0.3	1	0.14	90	6.3703	0.8129
2015	12	29	15	45	10	0.3	1	0.2	90	6.3703	1.1085
2015	12	29	15	55	10	0.3	1	0.13	105.1	6.3703	0.6836
2015	12	29	16	5	10	0.3	1	0.14	108	6.3703	0.739
2015	12	29	16	15	10	0.3	1	0.17	96.7	6.3703	0.9422
2015	12	29	16	25	10	0.3	1	0.16	99.7	6.3703	0.8683
2015	12	29	16	35	10	0.3	1	0.16	84.3	6.3703	0.9237
2015	12	29	16	45	10	0.3	1	0.14	76.6	6.3703	0.7759
2015	12	29	16	55	10	0.3	1	0.18	98.4	6.3703	0.9976
2015	12	29	17	5	10	0.3	1	0.19	65.6	6.3703	0.9792
2015	12	29	17	15	10	0.3	1	0.11	95.4	6.3703	0.5912
2015	12	29	17	25	10	0.3	1	0.13	94.3	6.3703	0.739
2015	12	29	17	35	10	0.3	1	0.19	60.3	6.3703	0.9053
2015	12	29	17	45	10	0.3	1	0.2	107.5	6.3703	1.0531
2015	12	29	17	55	10	0.3	1	0.16	73.7	6.3703	0.8868

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	18	5	10	0.3	1	0.18	73.5	6.3703	0.9976
2015	12	29	18	15	10	0.3	1	0.11	91.6	6.3703	0.6466
2015	12	29	18	25	10	0.3	1	0.2	93.7	6.3703	1.1454
2015	12	29	18	35	10	0.3	1	0.19	71.9	6.3703	1.0161
2015	12	29	18	45	10	0.3	1	0.15	80.1	6.3703	0.8498
2015	12	29	18	55	10	0.3	1	0.12	99.2	6.3703	0.6836
2015	12	29	19	5	10	0.3	1	0.21	116.2	6.3703	1.0531
2015	12	29	19	15	10	0.3	1	0.13	105.1	6.3703	0.6836
2015	12	29	19	25	10	0.3	1	0.19	101.7	6.3703	1.0715
2015	12	29	19	35	10	0.3	1	0.13	126.6	6.3703	0.5727
2015	12	29	19	45	10	0.3	1	0.23	106.9	6.3703	1.2193
2015	12	29	19	55	10	0.3	1	0.12	99.2	6.3703	0.6836
2015	12	29	20	5	10	0.3	1	0.12	90	6.3703	0.6651
2015	12	29	20	15	10	0.3	1	0.21	101	6.3703	1.1454
2015	12	29	20	25	10	0.3	1	0.17	90	6.3703	0.9422
2015	12	29	20	35	10	0.3	1	0.12	104.4	6.3703	0.6466
2015	12	29	20	45	10	0.3	1	0.14	101.8	6.3703	0.7944
2015	12	29	20	55	10	0.3	1	0.17	96.5	6.3703	0.9792
2015	12	29	21	5	10	0.3	1	0.14	105.9	6.3703	0.7759
2015	12	29	21	15	10	0.3	1	0.18	97.3	6.3703	1.0161
2015	12	29	21	25	10	0.3	1	0.16	104	6.3703	0.8868
2015	12	29	21	35	10	0.3	1	0.19	105.3	6.3703	1.0161
2015	12	29	21	45	10	0.3	1	0.12	111.5	6.3703	0.6097
2015	12	29	21	55	10	0.3	1	0.15	123.7	6.3703	0.7205
2015	12	29	22	5	10	0.3	1	0.18	123.1	6.3703	0.8498
2015	12	29	22	15	10	0.3	1	0.23	131	6.3703	0.9792
2015	12	29	22	25	10	0.3	1	0.12	115.2	6.3703	0.6281
2015	12	29	22	35	10	0.3	1	0.19	146	6.3703	0.6097
2015	12	29	22	45	10	0.3	1	0.21	124.7	6.3703	0.9607
2015	12	29	22	55	10	0.3	1	0.14	111	6.3703	0.7205
2015	12	29	23	5	10	0.3	1	0.12	124.6	6.3703	0.5358
2015	12	29	23	15	10	0.3	1	0.19	113.5	6.3703	0.9792
2015	12	29	23	25	10	0.3	1	0.2	105.2	6.3703	1.09
2015	12	29	23	35	10	0.3	1	0.16	97.1	6.3703	0.8868
2015	12	29	23	45	10	0.3	1	0.16	109.6	6.3703	0.8314
2015	12	29	23	55	10	0.3	1	0.17	103.8	6.3703	0.9053
2015	12	30	0	5	10	0.3	1	0.22	120.4	6.3703	1.0716
2015	12	30	0	15	10	0.3	1	0.17	110.2	6.3703	0.9053
2015	12	30	0	25	10	0.3	1	0.21	106.4	6.3703	1.127
2015	12	30	0	35	10	0.3	1	0.14	124.8	6.3703	0.6651
2015	12	30	0	45	10	0.3	1	0.23	115.1	6.3703	1.1824
2015	12	30	0	55	10	0.3	1	0.22	111.2	6.3703	1.1455
2015	12	30	1	5	10	0.3	1	0.2	119.1	6.3703	0.9977
2015	12	30	1	15	10	0.3	1	0.2	90	6.3703	1.1085
2015	12	30	1	25	10	0.3	1	0.16	115.5	6.3703	0.8129
2015	12	30	1	35	10	0.3	1	0.18	94.1	6.3703	1.0346

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	1	45	10	0.3	1	0.2	127.1	6.3703	0.9053
2015	12	30	1	55	10	0.3	1	0.2	90.9	6.3703	1.127
2015	12	30	2	5	10	0.3	1	0.14	111.8	6.3703	0.739
2015	12	30	2	15	10	0.3	1	0.17	134.2	6.3703	0.6836
2015	12	30	2	25	10	0.3	1	0.17	104.6	6.3703	0.9238
2015	12	30	2	35	10	0.3	1	0.12	132.8	6.3703	0.4988
2015	12	30	2	45	10	0.3	1	0.15	107.7	6.3703	0.8129
2015	12	30	2	55	10	0.3	1	0.19	127.5	6.3703	0.8684
2015	12	30	3	5	10	0.3	1	0.16	100.6	6.3703	0.8868
2015	12	30	3	15	10	0.3	1	0.17	135	6.3703	0.6836
2015	12	30	3	25	10	0.3	1	0.2	115.3	6.3703	1.0162
2015	12	30	3	35	10	0.3	1	0.21	120.5	6.3703	1.0346
2015	12	30	3	45	10	0.3	1	0.26	101.7	6.3703	1.4226
2015	12	30	3	55	10	0.3	1	0.17	134.2	6.3703	0.6836
2015	12	30	4	5	10	0.3	1	0.22	127.6	6.3703	0.9607
2015	12	30	4	15	10	0.3	1	0.19	119.7	6.3703	0.9053
2015	12	30	4	25	10	0.3	1	0.26	126.3	6.3703	1.1825
2015	12	30	4	35	10	0.3	1	0.15	122	6.3703	0.739
2015	12	30	4	45	10	0.3	1	0.19	116.1	6.3703	0.9792
2015	12	30	4	55	10	0.3	1	0.22	104.7	6.3703	1.2009
2015	12	30	5	5	10	0.3	1	0.17	131	6.3703	0.7021
2015	12	30	5	15	10	0.3	1	0.18	80.5	6.3703	0.9977
2015	12	30	5	25	10	0.3	1	0.21	97.2	6.3703	1.164
2015	12	30	5	35	10	0.3	1	0.11	104.5	6.3703	0.5728
2015	12	30	5	45	10	0.3	1	0.14	113	6.3509	0.7366
2015	12	30	5	55	10	0.3	1	0.17	113.6	6.3703	0.8869
2015	12	30	6	5	10	0.3	1	0.17	98.9	6.3703	0.9423
2015	12	30	6	15	10	0.3	1	0.15	106.5	6.3703	0.8129
2015	12	30	6	25	10	0.3	1	0.11	97.1	6.3703	0.5912
2015	12	30	6	35	10	0.3	1	0.13	95.7	6.3509	0.7366
2015	12	30	6	45	10	0.3	1	0.12	102.5	6.3703	0.6651
2015	12	30	6	55	10	0.3	1	0.19	113.9	6.3509	0.9576
2015	12	30	7	5	10	0.3	1	0.15	101.1	6.3509	0.8471
2015	12	30	7	15	10	0.3	1	0.16	141.7	6.3703	0.5543
2015	12	30	7	25	10	0.3	1	0.15	121.6	6.3703	0.7206
2015	12	30	7	35	10	0.3	1	0.14	120.1	6.3703	0.7021
2015	12	30	7	45	10	0.3	1	0.12	102.5	6.3703	0.6651
2015	12	30	7	55	10	0.3	1	0.07	144.2	6.3703	0.2402
2015	12	30	8	5	10	0.3	1	0.13	119.7	6.3703	0.6467
2015	12	30	8	15	10	0.3	1	0.09	126.5	6.3703	0.425
2015	12	30	8	25	10	0.3	1	0.17	128.8	6.3703	0.7575
2015	12	30	8	35	10	0.3	1	0.18	136.5	6.3509	0.6998
2015	12	30	8	45	10	0.3	1	0.16	99.3	6.3509	0.9024
2015	12	30	8	55	10	0.3	1	0.22	110.9	6.3509	1.1602
2015	12	30	9	5	10	0.3	1	0.23	113.3	6.3509	1.197
2015	12	30	9	15	10	0.3	1	0.13	120.5	6.3703	0.6282

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	9	25	10	0.3	1	0.09	119.5	6.3509	0.4236
2015	12	30	9	35	10	0.3	1	0.13	132	6.3509	0.5525
2015	12	30	9	45	10	0.3	1	0.08	97.4	6.3509	0.4236
2015	12	30	9	55	10	0.3	1	0.15	113.2	6.3509	0.7735
2015	12	30	10	5	10	0.3	1	0.13	126.9	6.3509	0.5893
2015	12	30	10	15	10	0.3	1	0.15	115.4	6.3509	0.7366
2015	12	30	10	25	10	0.3	1	0.15	95.1	6.3509	0.8287
2015	12	30	10	35	10	0.3	1	0.12	99.5	6.3509	0.663
2015	12	30	10	45	10	0.3	1	0.1	105.4	6.3509	0.5341
2015	12	30	10	55	10	0.3	1	0.16	105.5	6.3509	0.8655
2015	12	30	11	5	10	0.3	1	0.16	104	6.3703	0.8868
2015	12	30	11	15	10	0.3	1	0.19	111.6	6.3703	0.9792
2015	12	30	11	25	10	0.3	1	0.16	108.4	6.3703	0.8314
2015	12	30	11	35	10	0.3	1	0.22	111.5	6.3703	1.127
2015	12	30	11	45	10	0.3	1	0.11	115	6.3703	0.5543
2015	12	30	11	55	10	0.3	1	0.17	110.2	6.3703	0.9053
2015	12	30	12	5	10	0.3	1	0.17	108.8	6.3703	0.9238
2015	12	30	12	15	10	0.3	1	0.12	135	6.3703	0.4804
2015	12	30	12	25	10	0.3	1	0.21	106.7	6.3703	1.1085
2015	12	30	12	35	10	0.3	1	0.15	136.7	6.3703	0.5912
2015	12	30	12	45	10	0.3	1	0.21	114.1	6.3703	1.0716
2015	12	30	12	55	10	0.3	1	0.17	88.9	6.3703	0.9792
2015	12	30	13	5	10	0.3	1	0.15	97.6	6.3703	0.8314
2015	12	30	13	15	10	0.3	1	0.24	124.8	6.3703	1.09
2015	12	30	13	25	10	0.3	1	0.16	85.2	6.3703	0.8868
2015	12	30	13	35	10	0.3	1	0.18	98.4	6.3703	0.9977
2015	12	30	13	45	10	0.3	1	0.13	85.6	6.3703	0.7205
2015	12	30	13	55	10	0.3	1	0.2	115.7	6.3703	1.0346
2015	12	30	14	5	10	0.3	1	0.19	125.9	6.3703	0.8683
2015	12	30	14	15	10	0.3	1	0.2	112.7	6.3509	1.0128
2015	12	30	14	25	10	0.3	1	0.2	96.7	6.3703	1.1085
2015	12	30	14	35	10	0.3	1	0.17	108.8	6.3703	0.9238
2015	12	30	14	45	10	0.3	1	0.15	128.1	6.3703	0.6836
2015	12	30	14	55	10	0.3	1	0.2	119.1	6.3703	0.9977
2015	12	30	15	5	10	0.3	1	0.14	97	6.3703	0.7575
2015	12	30	15	15	10	0.3	1	0.15	135	6.3703	0.5912
2015	12	30	15	25	10	0.3	1	0.19	114.8	6.3703	0.9607
2015	12	30	15	35	10	0.3	1	0.17	108.1	6.3703	0.9053
2015	12	30	15	45	10	0.3	1	0.09	124.8	6.3703	0.4249
2015	12	30	15	55	10	0.3	1	0.15	114.9	6.3703	0.7575
2015	12	30	16	5	10	0.3	1	0.13	120.5	6.3703	0.6282
2015	12	30	16	15	10	0.3	1	0.24	117.3	6.3703	1.1824
2015	12	30	16	36	20	0.3	1	0.21	102.3	6.3703	1.1824
2015	12	30	16	46	20	0.3	1	0.15	124	6.3509	0.6813
2015	12	30	16	56	20	0.3	1	0.22	123.9	6.3703	1.0161
2015	12	30	17	6	20	0.3	1	0.14	105	6.3703	0.7575

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	17	16	20	0.3	1	0.19	103.1	6.3703	1.0346
2015	12	30	17	26	20	0.3	1	0.13	115.9	6.3703	0.6466
2015	12	30	17	36	20	0.3	1	0.22	137.4	6.3703	0.8498
2015	12	30	17	46	20	0.3	1	0.21	108.7	6.3703	1.1454
2015	12	30	17	56	20	0.3	1	0.18	126.9	6.3703	0.8129
2015	12	30	18	6	20	0.3	1	0.19	116.6	6.3703	0.9607
2015	12	30	18	16	20	0.3	1	0.19	111.3	6.3703	0.9976
2015	12	30	18	26	20	0.3	1	0.14	113.6	6.3703	0.7205
2015	12	30	18	36	20	0.3	1	0.15	116	6.3703	0.7575
2015	12	30	18	46	20	0.3	1	0.11	108.4	6.3703	0.6097
2015	12	30	18	56	20	0.3	1	0.19	122	6.3703	0.8868
2015	12	30	19	6	20	0.3	1	0.2	124.8	6.3703	0.9053
2015	12	30	19	16	20	0.3	1	0.14	116.6	6.3703	0.702
2015	12	30	19	26	20	0.3	1	0.2	129.8	6.3703	0.8868
2015	12	30	19	36	20	0.3	1	0.22	97.7	6.3703	1.2378
2015	12	30	19	46	20	0.3	1	0.15	123.3	6.3703	0.702
2015	12	30	19	56	20	0.3	1	0.2	140.2	6.3703	0.739
2015	12	30	20	6	20	0.3	1	0.2	131	6.3703	0.8498
2015	12	30	20	16	20	0.3	1	0.14	133.1	6.3703	0.5727
2015	12	30	20	26	20	0.3	1	0.2	107.5	6.3703	1.0531
2015	12	30	20	36	20	0.3	1	0.13	130.8	6.3703	0.5358
2015	12	30	20	46	20	0.3	1	0.14	135	6.3703	0.5727
2015	12	30	20	56	20	0.3	1	0.22	130.1	6.3703	0.9422
2015	12	30	21	6	20	0.3	1	0.15	112	6.3703	0.7759
2015	12	30	21	16	20	0.3	1	0.13	121.7	6.3703	0.6281
2015	12	30	21	26	20	0.3	1	0.18	95.3	6.3703	0.9976
2015	12	30	21	36	20	0.3	1	0.14	98.1	6.3703	0.7759
2015	12	30	21	46	20	0.3	1	0.19	114.4	6.3703	0.9792
2015	12	30	21	56	20	0.3	1	0.2	118.7	6.3703	0.9792
2015	12	30	22	6	20	0.3	1	0.18	127.7	6.3703	0.8129
2015	12	30	22	16	20	0.3	1	0.11	101.6	6.3703	0.6281
2015	12	30	22	26	20	0.3	1	0.13	124.5	6.3703	0.5912
2015	12	30	22	36	20	0.3	1	0.15	126.1	6.3703	0.6836
2015	12	30	22	46	20	0.3	1	0.17	109.5	6.3703	0.8868
2015	12	30	22	56	20	0.3	1	0.23	117.3	6.3703	1.1454
2015	12	30	23	6	20	0.3	1	0.13	115.9	6.3703	0.6836
2015	12	30	23	16	20	0.3	1	0.19	104.7	6.3703	1.0531
2015	12	30	23	26	20	0.3	1	0.17	109.8	6.3703	0.9237
2015	12	30	23	36	20	0.3	1	0.22	135.6	6.3703	0.8498
2015	12	30	23	46	20	0.3	1	0.14	119.6	6.3703	0.6836
2015	12	30	23	56	20	0.3	1	0.15	99.9	6.3703	0.8498
2015	12	31	0	6	20	0.3	1	0.25	121.8	6.3703	1.2193
2015	12	31	0	16	20	0.3	1	0.17	105.4	6.3703	0.9422
2015	12	31	0	26	20	0.3	1	0.2	93.7	6.3703	1.1455
2015	12	31	0	36	20	0.3	1	0.14	117.2	6.3703	0.6836
2015	12	31	0	46	20	0.3	1	0.18	110.4	6.3703	0.9422

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	0	56	20	0.3	1	0.15	124	6.3703	0.6836
2015	12	31	1	6	20	0.3	1	0.16	110.7	6.3703	0.8314
2015	12	31	1	16	20	0.3	1	0.16	110.7	6.3703	0.8314
2015	12	31	1	26	20	0.3	1	0.19	99.1	6.3703	1.0346
2015	12	31	1	36	20	0.3	1	0.18	120.8	6.3703	0.8683
2015	12	31	1	46	20	0.3	1	0.19	120.5	6.3703	0.9422
2015	12	31	1	56	20	0.3	1	0.08	101.8	6.3703	0.4434
2015	12	31	2	6	20	0.3	1	0.17	117.1	6.3703	0.8314
2015	12	31	2	16	20	0.3	1	0.2	109	6.3703	1.0716
2015	12	31	2	26	20	0.3	1	0.19	120.1	6.3703	0.9238
2015	12	31	2	36	20	0.3	1	0.14	118.4	6.3703	0.6836
2015	12	31	2	46	20	0.3	1	0.18	125.2	6.3703	0.8129
2015	12	31	2	56	20	0.3	1	0.22	106.5	6.3703	1.1824
2015	12	31	3	6	20	0.3	1	0.17	118.5	6.3703	0.8499
2015	12	31	3	16	20	0.3	1	0.1	104.9	6.3703	0.5543
2015	12	31	3	26	20	0.3	1	0.22	102.2	6.3703	1.2009
2015	12	31	3	36	20	0.3	1	0.13	102.7	6.3703	0.739
2015	12	31	3	46	20	0.3	1	0.19	116.1	6.3703	0.9423
2015	12	31	3	56	20	0.3	1	0.12	137.3	6.3703	0.4434
2015	12	31	4	6	20	0.3	1	0.17	93.2	6.3703	0.9792
2015	12	31	4	16	20	0.3	1	0.21	115.3	6.3703	1.0531
2015	12	31	4	26	20	0.3	1	0.2	125.5	6.3703	0.9053
2015	12	31	4	36	20	0.3	1	0.17	93.2	6.3703	0.9792
2015	12	31	4	46	20	0.3	1	0.2	94.7	6.3703	1.127
2015	12	31	4	56	20	0.3	1	0.14	109.3	6.3703	0.739
2015	12	31	5	6	20	0.3	1	0.21	116.2	6.3703	1.0531
2015	12	31	5	16	20	0.3	1	0.13	95.7	6.3703	0.739
2015	12	31	5	26	20	0.3	1	0.14	122.6	6.3703	0.6651
2015	12	31	5	36	20	0.3	1	0.16	119.2	6.3703	0.7945
2015	12	31	5	46	20	0.3	1	0.17	131.1	6.3703	0.7206
2015	12	31	5	56	20	0.3	1	0.18	107.1	6.3703	0.9607
2015	12	31	6	6	20	0.3	1	0.24	97	6.3703	1.3487
2015	12	31	6	16	20	0.3	1	0.17	111.6	6.3703	0.8868
2015	12	31	6	26	20	0.3	1	0.2	112.7	6.3703	1.0162
2015	12	31	6	36	20	0.3	1	0.17	111	6.3703	0.8684
2015	12	31	6	46	20	0.3	1	0.12	106.4	6.3703	0.6282
2015	12	31	6	56	20	0.3	1	0.18	121.3	6.3703	0.8499
2015	12	31	7	6	20	0.3	1	0.2	102.6	6.3703	1.0716
2015	12	31	7	16	20	0.3	1	0.17	112.6	6.3703	0.8868
2015	12	31	7	26	20	0.3	1	0.2	114.8	6.3703	0.9977
2015	12	31	7	36	20	0.3	1	0.22	136.2	6.3703	0.8684
2015	12	31	7	46	20	0.3	1	0.2	109.3	6.3703	1.0531
2015	12	31	7	56	20	0.3	1	0.17	131	6.3703	0.7021
2015	12	31	8	6	20	0.3	1	0.22	108.4	6.3703	1.164
2015	12	31	8	16	20	0.3	1	0.21	134.4	6.3703	0.8314
2015	12	31	8	26	20	0.3	1	0.15	121	6.3703	0.739

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	8	36	20	0.3	1	0.19	96	6.3703	1.0531
2015	12	31	8	46	20	0.3	1	0.17	96.7	6.3703	0.9423
2015	12	31	8	56	20	0.3	1	0.14	111	6.3703	0.7206
2015	12	31	9	6	20	0.3	1	0.2	117.8	6.3703	0.9792
2015	12	31	9	16	20	0.3	1	0.13	143.1	6.3703	0.4434
2015	12	31	9	26	20	0.3	1	0.14	127.1	6.3703	0.6097
2015	12	31	9	36	20	0.3	1	0.12	119.4	6.3509	0.5893
2015	12	31	9	46	20	0.3	1	0.16	126.6	6.3509	0.7182
2015	12	31	9	56	20	0.3	1	0.1	95.7	6.3703	0.5543
2015	12	31	10	6	20	0.3	1	0.14	112.8	6.3509	0.6998
2015	12	31	10	16	20	0.3	1	0.17	126.4	6.3703	0.776
2015	12	31	10	26	20	0.3	1	0.17	108.4	6.3703	0.8868
2015	12	31	10	36	20	0.3	1	0.13	118.5	6.3509	0.6445
2015	12	31	10	46	20	0.3	1	0.19	127.1	6.3509	0.8287
2015	12	31	10	56	20	0.3	1	0.22	111.5	6.3509	1.1233
2015	12	31	11	6	20	0.3	1	0.18	90	6.3703	1.0161
2015	12	31	11	16	20	0.3	1	0.18	127.5	6.3703	0.7944
2015	12	31	11	26	20	0.3	1	0.13	100.2	6.3703	0.7205
2015	12	31	11	36	20	0.3	1	0.16	121.4	6.3703	0.7575
2015	12	31	11	46	20	0.3	1	0.23	116.2	6.3703	1.1639
2015	12	31	11	56	20	0.3	1	0.11	104	6.3703	0.5912
2015	12	31	12	6	20	0.3	1	0.19	108.7	6.3703	1.0346
2015	12	31	12	16	20	0.3	1	0.19	122	6.3703	0.8868
2015	12	31	12	26	20	0.3	1	0.17	109.5	6.3703	0.8868
2015	12	31	12	36	20	0.3	1	0.18	95.2	6.3703	1.0161
2015	12	31	12	46	20	0.3	1	0.18	106.5	6.3703	0.9976
2015	12	31	12	56	20	0.3	1	0.17	109.5	6.3703	0.8868
2015	12	31	13	6	20	0.3	1	0.14	130.2	6.3703	0.5912
2015	12	31	13	16	20	0.3	1	0.18	99.6	6.3703	0.9792
2015	12	31	13	26	20	0.3	1	0.21	91.8	6.3703	1.2008
2015	12	31	13	36	20	0.3	1	0.18	112.4	6.3703	0.9422
2015	12	31	13	46	20	0.3	1	0.16	85.2	6.3703	0.8868
2015	12	31	13	56	20	0.3	1	0.13	92.8	6.3703	0.7575
2015	12	31	14	6	20	0.3	1	0.22	115	6.3703	1.1085
2015	12	31	14	16	20	0.3	1	0.15	127.1	6.3703	0.6836
2015	12	31	14	26	20	0.3	1	0.17	113.1	6.3703	0.8683
2015	12	31	14	36	20	0.3	1	0.19	86.1	6.3703	1.09
2015	12	31	14	46	20	0.3	1	0.16	82.9	6.3703	0.8868
2015	12	31	14	56	20	0.3	1	0.25	57.1	6.3703	1.2008
2015	12	31	15	6	20	0.3	1	0.22	57.7	6.3703	1.053
2015	12	31	15	16	20	0.3	1	0.23	61.6	6.3703	1.1269
2015	12	31	15	26	20	0.3	1	0.12	77.8	6.3703	0.6835
2015	12	31	15	36	20	0.3	1	0.29	49.1	6.3703	1.2378
2015	12	31	15	46	20	0.3	1	0.24	43.3	6.3703	0.9237
2015	12	31	15	56	20	0.3	1	0.27	77.3	6.3703	1.4779
2015	12	31	16	6	20	0.3	1	0.13	73.9	6.3703	0.702

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	16	16	20	0.3	1	0.14	78.2	6.3703	0.7944
2015	12	31	16	26	20	0.3	1	0.16	46.6	6.3703	0.6651
2015	12	31	16	36	20	0.3	1	0.17	85.5	6.3703	0.9422
2015	12	31	16	46	20	0.3	1	0.19	108.7	6.3703	1.0346
2015	12	31	16	56	20	0.3	1	0.14	94.1	6.3703	0.7759
2015	12	31	17	6	20	0.3	1	0.17	86.6	6.3703	0.9422
2015	12	31	17	16	20	0.3	1	0.1	42.4	6.3703	0.388
2015	12	31	17	26	20	0.3	1	0.17	76.2	6.3703	0.9052
2015	12	31	17	36	20	0.3	1	0.08	106.9	6.3703	0.4249
2015	12	31	17	46	20	0.3	1	0.15	75.7	6.3703	0.7944
2015	12	31	17	56	20	0.3	1	0.19	76	6.3509	1.0312
2015	12	31	18	6	20	0.3	1	0.17	57.5	6.3509	0.8102
2015	12	31	18	16	20	0.3	1	0.1	107.2	6.3703	0.5358
2015	12	31	18	26	20	0.3	1	0.14	46.8	6.3703	0.5912
2015	12	31	18	36	20	0.3	1	0.18	90	6.3703	0.9976
2015	12	31	18	46	20	0.3	1	0.12	66.2	6.3703	0.6281
2015	12	31	18	56	20	0.3	1	0.22	94.2	6.3703	1.2563
2015	12	31	19	6	20	0.3	1	0.13	109.4	6.3703	0.6835
2015	12	31	19	16	20	0.3	1	0.12	77.8	6.3703	0.6835
2015	12	31	19	26	20	0.3	1	0.25	93.8	6.3703	1.404
2015	12	31	19	36	20	0.3	1	0.14	91.3	6.3703	0.7944
2015	12	31	19	46	20	0.3	1	0.17	91.1	6.3703	0.9791
2015	12	31	19	56	20	0.3	1	0.15	112.5	6.3703	0.7574
2015	12	31	20	6	20	0.3	1	0.1	84.3	6.3703	0.5542
2015	12	31	20	16	20	0.3	1	0.16	85.4	6.3703	0.9237
2015	12	31	20	26	20	0.3	1	0.14	120.1	6.3703	0.702
2015	12	31	20	36	20	0.3	1	0.21	90.9	6.3703	1.1639
2015	12	31	20	46	20	0.3	1	0.15	120.5	6.3703	0.7205
2015	12	31	20	56	20	0.3	1	0.15	125.4	6.3703	0.702
2015	12	31	21	6	20	0.3	1	0.12	118	6.3703	0.5912
2015	12	31	21	16	20	0.3	1	0.14	88.7	6.3703	0.7944
2015	12	31	21	26	20	0.3	1	0.11	105.7	6.3703	0.5912
2015	12	31	21	36	20	0.3	1	0.19	119.2	6.3703	0.9237
2015	12	31	21	46	20	0.3	1	0.17	97.7	6.3703	0.9607
2015	12	31	21	56	20	0.3	1	0.16	124	6.3703	0.739
2015	12	31	22	6	20	0.3	1	0.1	114.1	6.3703	0.5358
2015	12	31	22	16	20	0.3	1	0.15	106.5	6.3703	0.8129
2015	12	31	22	26	20	0.3	1	0.19	114	6.3703	0.9976
2015	12	31	22	36	20	0.3	1	0.19	103.3	6.3703	1.0161
2015	12	31	22	46	20	0.3	1	0.11	103.6	6.3703	0.6097
2015	12	31	22	56	20	0.3	1	0.22	123	6.3703	1.0531
2015	12	31	23	6	20	0.3	1	0.22	136.8	6.3703	0.8498
2015	12	31	23	16	20	0.3	1	0.2	128.2	6.3703	0.8683
2015	12	31	23	26	20	0.3	1	0.13	122.5	6.3703	0.6097
2015	12	31	23	36	20	0.3	1	0.11	91.8	6.3703	0.5912
2015	12	31	23	46	20	0.3	1	0.13	135	6.3703	0.5358

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	23	56	20	0.3	1	0.11	95.2	6.3703	0.6097

Goose Lake Return
Station 0367

Date	Flow (cfs)
12/1/2015	1.065
12/2/2015	1.107
12/3/2015	1.119
12/4/2015	1.106
12/5/2015	0.964
12/6/2015	0.761
12/7/2015	0.64
12/8/2015	0.773
12/9/2015	1.094
12/10/2015	1.276
12/11/2015	1.351
12/12/2015	1.332
12/13/2015	1.226
12/14/2015	1.158
12/15/2015	1.043
12/16/2015	1.035
12/17/2015	1.097
12/18/2015	1.159
12/19/2015	1.204
12/20/2015	1.232
12/21/2015	1.258
12/22/2015	1.248
12/23/2015	1.255
12/24/2015	1.266
12/25/2015	1.266
12/26/2015	1.2
12/27/2015	1.192
12/28/2015	1.179
12/29/2015	1.127
12/30/2015	1.124
12/31/2015	1.108

Goose Lake Return Gage

DATE	TIME	GAGE
12/1/2015	12:00:00 AM	0.42
12/1/2015	12:15:00 AM	0.42
12/1/2015	12:30:00 AM	0.42
12/1/2015	12:45:00 AM	0.42
12/1/2015	1:00:00 AM	0.42
12/1/2015	1:15:00 AM	0.42
12/1/2015	1:30:00 AM	0.42
12/1/2015	1:45:00 AM	0.42
12/1/2015	2:00:00 AM	0.42
12/1/2015	2:15:00 AM	0.41
12/1/2015	2:30:00 AM	0.41
12/1/2015	2:45:00 AM	0.41
12/1/2015	3:00:00 AM	0.41
12/1/2015	3:15:00 AM	0.41
12/1/2015	3:30:00 AM	0.41
12/1/2015	3:45:00 AM	0.41
12/1/2015	4:00:00 AM	0.41
12/1/2015	4:15:00 AM	0.41
12/1/2015	4:30:00 AM	0.41
12/1/2015	4:45:00 AM	0.41
12/1/2015	5:00:00 AM	0.41
12/1/2015	5:15:00 AM	0.41
12/1/2015	5:30:00 AM	0.42
12/1/2015	5:45:00 AM	0.42
12/1/2015	6:00:00 AM	0.42
12/1/2015	6:15:00 AM	0.42
12/1/2015	6:30:00 AM	0.42
12/1/2015	6:45:00 AM	0.42
12/1/2015	7:00:00 AM	0.42
12/1/2015	7:15:00 AM	0.42
12/1/2015	7:30:00 AM	0.42
12/1/2015	7:45:00 AM	0.42
12/1/2015	8:00:00 AM	0.42
12/1/2015	8:15:00 AM	0.42
12/1/2015	8:30:00 AM	0.42
12/1/2015	8:45:00 AM	0.42
12/1/2015	9:00:00 AM	0.42
12/1/2015	9:15:00 AM	0.43
12/1/2015	9:30:00 AM	0.43
12/1/2015	9:45:00 AM	0.44
12/1/2015	10:00:00 AM	0.44
12/1/2015	10:15:00 AM	0.44
12/1/2015	10:30:00 AM	0.44
12/1/2015	10:45:00 AM	0.46
12/1/2015	11:00:00 AM	0.46
12/1/2015	11:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/1/2015	11:30:00 AM	0.46
12/1/2015	11:45:00 AM	0.45
12/1/2015	12:00:00 PM	0.45
12/1/2015	12:15:00 PM	0.45
12/1/2015	12:30:00 PM	0.45
12/1/2015	12:45:00 PM	0.45
12/1/2015	1:00:00 PM	0.45
12/1/2015	1:15:00 PM	0.44
12/1/2015	1:30:00 PM	0.44
12/1/2015	1:45:00 PM	0.44
12/1/2015	2:00:00 PM	0.44
12/1/2015	2:15:00 PM	0.44
12/1/2015	2:30:00 PM	0.44
12/1/2015	2:45:00 PM	0.44
12/1/2015	3:00:00 PM	0.44
12/1/2015	3:15:00 PM	0.44
12/1/2015	3:30:00 PM	0.44
12/1/2015	3:45:00 PM	0.44
12/1/2015	4:00:00 PM	0.44
12/1/2015	4:15:00 PM	0.43
12/1/2015	4:30:00 PM	0.43
12/1/2015	4:45:00 PM	0.43
12/1/2015	5:00:00 PM	0.43
12/1/2015	5:15:00 PM	0.43
12/1/2015	5:30:00 PM	0.43
12/1/2015	5:45:00 PM	0.43
12/1/2015	6:00:00 PM	0.43
12/1/2015	6:15:00 PM	0.43
12/1/2015	6:30:00 PM	0.43
12/1/2015	6:45:00 PM	0.43
12/1/2015	7:00:00 PM	0.44
12/1/2015	7:15:00 PM	0.43
12/1/2015	7:30:00 PM	0.43
12/1/2015	7:45:00 PM	0.43
12/1/2015	8:00:00 PM	0.43
12/1/2015	8:15:00 PM	0.43
12/1/2015	8:30:00 PM	0.43
12/1/2015	8:45:00 PM	0.43
12/1/2015	9:00:00 PM	0.43
12/1/2015	9:15:00 PM	0.43
12/1/2015	9:30:00 PM	0.43
12/1/2015	9:45:00 PM	0.43
12/1/2015	10:00:00 PM	0.43
12/1/2015	10:15:00 PM	0.43
12/1/2015	10:30:00 PM	0.43
12/1/2015	10:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
12/1/2015	11:00:00 PM	0.43
12/1/2015	11:15:00 PM	0.43
12/1/2015	11:30:00 PM	0.43
12/1/2015	11:45:00 PM	0.43
12/2/2015	12:00:00 AM	0.44
12/2/2015	12:15:00 AM	0.44
12/2/2015	12:30:00 AM	0.44
12/2/2015	12:45:00 AM	0.44
12/2/2015	1:00:00 AM	0.44
12/2/2015	1:15:00 AM	0.44
12/2/2015	1:30:00 AM	0.44
12/2/2015	1:45:00 AM	0.44
12/2/2015	2:00:00 AM	0.44
12/2/2015	2:15:00 AM	0.44
12/2/2015	2:30:00 AM	0.44
12/2/2015	2:45:00 AM	0.44
12/2/2015	3:00:00 AM	0.44
12/2/2015	3:15:00 AM	0.44
12/2/2015	3:30:00 AM	0.44
12/2/2015	3:45:00 AM	0.44
12/2/2015	4:00:00 AM	0.44
12/2/2015	4:15:00 AM	0.44
12/2/2015	4:30:00 AM	0.44
12/2/2015	4:45:00 AM	0.43
12/2/2015	5:00:00 AM	0.43
12/2/2015	5:15:00 AM	0.43
12/2/2015	5:30:00 AM	0.43
12/2/2015	5:45:00 AM	0.43
12/2/2015	6:00:00 AM	0.43
12/2/2015	6:15:00 AM	0.43
12/2/2015	6:30:00 AM	0.43
12/2/2015	6:45:00 AM	0.43
12/2/2015	7:00:00 AM	0.43
12/2/2015	7:15:00 AM	0.43
12/2/2015	7:30:00 AM	0.43
12/2/2015	7:45:00 AM	0.43
12/2/2015	8:00:00 AM	0.43
12/2/2015	8:15:00 AM	0.43
12/2/2015	8:30:00 AM	0.43
12/2/2015	8:45:00 AM	0.43
12/2/2015	9:00:00 AM	0.44
12/2/2015	9:15:00 AM	0.44
12/2/2015	9:30:00 AM	0.44
12/2/2015	9:45:00 AM	0.45
12/2/2015	10:00:00 AM	0.45
12/2/2015	10:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/2/2015	10:30:00 AM	0.46
12/2/2015	10:45:00 AM	0.46
12/2/2015	11:00:00 AM	0.46
12/2/2015	11:15:00 AM	0.46
12/2/2015	11:30:00 AM	0.46
12/2/2015	11:45:00 AM	0.46
12/2/2015	12:00:00 PM	0.45
12/2/2015	12:15:00 PM	0.45
12/2/2015	12:30:00 PM	0.44
12/2/2015	12:45:00 PM	0.44
12/2/2015	1:00:00 PM	0.44
12/2/2015	1:15:00 PM	0.44
12/2/2015	1:30:00 PM	0.44
12/2/2015	1:45:00 PM	0.44
12/2/2015	2:00:00 PM	0.44
12/2/2015	2:15:00 PM	0.44
12/2/2015	2:30:00 PM	0.44
12/2/2015	2:45:00 PM	0.44
12/2/2015	3:00:00 PM	0.44
12/2/2015	3:15:00 PM	0.44
12/2/2015	3:30:00 PM	0.44
12/2/2015	3:45:00 PM	0.44
12/2/2015	4:00:00 PM	0.44
12/2/2015	4:15:00 PM	0.44
12/2/2015	4:30:00 PM	0.44
12/2/2015	4:45:00 PM	0.44
12/2/2015	5:00:00 PM	0.44
12/2/2015	5:15:00 PM	0.44
12/2/2015	5:30:00 PM	0.44
12/2/2015	5:45:00 PM	0.44
12/2/2015	6:00:00 PM	0.44
12/2/2015	6:15:00 PM	0.44
12/2/2015	6:30:00 PM	0.44
12/2/2015	6:45:00 PM	0.44
12/2/2015	7:00:00 PM	0.44
12/2/2015	7:15:00 PM	0.44
12/2/2015	7:30:00 PM	0.44
12/2/2015	7:45:00 PM	0.44
12/2/2015	8:00:00 PM	0.44
12/2/2015	8:15:00 PM	0.44
12/2/2015	8:30:00 PM	0.44
12/2/2015	8:45:00 PM	0.44
12/2/2015	9:00:00 PM	0.44
12/2/2015	9:15:00 PM	0.44
12/2/2015	9:30:00 PM	0.44
12/2/2015	9:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/2/2015	10:00:00 PM	0.44
12/2/2015	10:15:00 PM	0.44
12/2/2015	10:30:00 PM	0.44
12/2/2015	10:45:00 PM	0.44
12/2/2015	11:00:00 PM	0.44
12/2/2015	11:15:00 PM	0.44
12/2/2015	11:30:00 PM	0.44
12/2/2015	11:45:00 PM	0.44
12/3/2015	12:00:00 AM	0.44
12/3/2015	12:15:00 AM	0.44
12/3/2015	12:30:00 AM	0.44
12/3/2015	12:45:00 AM	0.44
12/3/2015	1:00:00 AM	0.44
12/3/2015	1:15:00 AM	0.44
12/3/2015	1:30:00 AM	0.44
12/3/2015	1:45:00 AM	0.44
12/3/2015	2:00:00 AM	0.44
12/3/2015	2:15:00 AM	0.44
12/3/2015	2:30:00 AM	0.44
12/3/2015	2:45:00 AM	0.44
12/3/2015	3:00:00 AM	0.44
12/3/2015	3:15:00 AM	0.44
12/3/2015	3:30:00 AM	0.44
12/3/2015	3:45:00 AM	0.44
12/3/2015	4:00:00 AM	0.44
12/3/2015	4:15:00 AM	0.44
12/3/2015	4:30:00 AM	0.44
12/3/2015	4:45:00 AM	0.44
12/3/2015	5:00:00 AM	0.44
12/3/2015	5:15:00 AM	0.44
12/3/2015	5:30:00 AM	0.44
12/3/2015	5:45:00 AM	0.44
12/3/2015	6:00:00 AM	0.44
12/3/2015	6:15:00 AM	0.44
12/3/2015	6:30:00 AM	0.45
12/3/2015	6:45:00 AM	0.45
12/3/2015	7:00:00 AM	0.44
12/3/2015	7:15:00 AM	0.44
12/3/2015	7:30:00 AM	0.44
12/3/2015	7:45:00 AM	0.44
12/3/2015	8:00:00 AM	0.44
12/3/2015	8:15:00 AM	0.44
12/3/2015	8:30:00 AM	0.44
12/3/2015	8:45:00 AM	0.44
12/3/2015	9:00:00 AM	0.44
12/3/2015	9:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/3/2015	9:30:00 AM	0.44
12/3/2015	9:45:00 AM	0.45
12/3/2015	10:00:00 AM	0.45
12/3/2015	10:15:00 AM	0.45
12/3/2015	10:30:00 AM	0.45
12/3/2015	10:45:00 AM	0.45
12/3/2015	11:00:00 AM	0.45
12/3/2015	11:15:00 AM	0.45
12/3/2015	11:30:00 AM	0.45
12/3/2015	11:45:00 AM	0.45
12/3/2015	12:00:00 PM	0.45
12/3/2015	12:15:00 PM	0.45
12/3/2015	12:30:00 PM	0.45
12/3/2015	12:45:00 PM	0.45
12/3/2015	1:00:00 PM	0.46
12/3/2015	1:15:00 PM	0.46
12/3/2015	1:30:00 PM	0.45
12/3/2015	1:45:00 PM	0.45
12/3/2015	2:00:00 PM	0.45
12/3/2015	2:15:00 PM	0.45
12/3/2015	2:30:00 PM	0.45
12/3/2015	2:45:00 PM	0.45
12/3/2015	3:00:00 PM	0.45
12/3/2015	3:15:00 PM	0.45
12/3/2015	3:30:00 PM	0.45
12/3/2015	3:45:00 PM	0.45
12/3/2015	4:00:00 PM	0.45
12/3/2015	4:15:00 PM	0.44
12/3/2015	4:30:00 PM	0.44
12/3/2015	4:45:00 PM	0.44
12/3/2015	5:00:00 PM	0.44
12/3/2015	5:15:00 PM	0.44
12/3/2015	5:30:00 PM	0.44
12/3/2015	5:45:00 PM	0.44
12/3/2015	6:00:00 PM	0.44
12/3/2015	6:15:00 PM	0.44
12/3/2015	6:30:00 PM	0.44
12/3/2015	6:45:00 PM	0.44
12/3/2015	7:00:00 PM	0.44
12/3/2015	7:15:00 PM	0.44
12/3/2015	7:30:00 PM	0.44
12/3/2015	7:45:00 PM	0.44
12/3/2015	8:00:00 PM	0.44
12/3/2015	8:15:00 PM	0.44
12/3/2015	8:30:00 PM	0.44
12/3/2015	8:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/3/2015	9:00:00 PM	0.44
12/3/2015	9:15:00 PM	0.44
12/3/2015	9:30:00 PM	0.44
12/3/2015	9:45:00 PM	0.44
12/3/2015	10:00:00 PM	0.44
12/3/2015	10:15:00 PM	0.44
12/3/2015	10:30:00 PM	0.44
12/3/2015	10:45:00 PM	0.44
12/3/2015	11:00:00 PM	0.44
12/3/2015	11:15:00 PM	0.44
12/3/2015	11:30:00 PM	0.44
12/3/2015	11:45:00 PM	0.44
12/4/2015	12:00:00 AM	0.44
12/4/2015	12:15:00 AM	0.44
12/4/2015	12:30:00 AM	0.44
12/4/2015	12:45:00 AM	0.44
12/4/2015	1:00:00 AM	0.44
12/4/2015	1:15:00 AM	0.44
12/4/2015	1:30:00 AM	0.44
12/4/2015	1:45:00 AM	0.44
12/4/2015	2:00:00 AM	0.44
12/4/2015	2:15:00 AM	0.44
12/4/2015	2:30:00 AM	0.44
12/4/2015	2:45:00 AM	0.44
12/4/2015	3:00:00 AM	0.44
12/4/2015	3:15:00 AM	0.44
12/4/2015	3:30:00 AM	0.44
12/4/2015	3:45:00 AM	0.44
12/4/2015	4:00:00 AM	0.44
12/4/2015	4:15:00 AM	0.44
12/4/2015	4:30:00 AM	0.44
12/4/2015	4:45:00 AM	0.44
12/4/2015	5:00:00 AM	0.44
12/4/2015	5:15:00 AM	0.44
12/4/2015	5:30:00 AM	0.44
12/4/2015	5:45:00 AM	0.44
12/4/2015	6:00:00 AM	0.44
12/4/2015	6:15:00 AM	0.44
12/4/2015	6:30:00 AM	0.44
12/4/2015	6:45:00 AM	0.44
12/4/2015	7:00:00 AM	0.44
12/4/2015	7:15:00 AM	0.44
12/4/2015	7:30:00 AM	0.44
12/4/2015	7:45:00 AM	0.44
12/4/2015	8:00:00 AM	0.44
12/4/2015	8:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/4/2015	8:30:00 AM	0.44
12/4/2015	8:45:00 AM	0.44
12/4/2015	9:00:00 AM	0.44
12/4/2015	9:15:00 AM	0.44
12/4/2015	9:30:00 AM	0.44
12/4/2015	9:45:00 AM	0.44
12/4/2015	10:00:00 AM	0.44
12/4/2015	10:15:00 AM	0.44
12/4/2015	10:30:00 AM	0.44
12/4/2015	10:45:00 AM	0.44
12/4/2015	11:00:00 AM	0.44
12/4/2015	11:15:00 AM	0.44
12/4/2015	11:30:00 AM	0.45
12/4/2015	11:45:00 AM	0.45
12/4/2015	12:00:00 PM	0.45
12/4/2015	12:15:00 PM	0.45
12/4/2015	12:30:00 PM	0.45
12/4/2015	12:45:00 PM	0.45
12/4/2015	1:00:00 PM	0.45
12/4/2015	1:15:00 PM	0.44
12/4/2015	1:30:00 PM	0.44
12/4/2015	1:45:00 PM	0.44
12/4/2015	2:00:00 PM	0.44
12/4/2015	2:15:00 PM	0.44
12/4/2015	2:30:00 PM	0.44
12/4/2015	2:45:00 PM	0.44
12/4/2015	3:00:00 PM	0.44
12/4/2015	3:15:00 PM	0.44
12/4/2015	3:30:00 PM	0.44
12/4/2015	3:45:00 PM	0.44
12/4/2015	4:00:00 PM	0.44
12/4/2015	4:15:00 PM	0.44
12/4/2015	4:30:00 PM	0.44
12/4/2015	4:45:00 PM	0.44
12/4/2015	5:00:00 PM	0.44
12/4/2015	5:15:00 PM	0.44
12/4/2015	5:30:00 PM	0.44
12/4/2015	5:45:00 PM	0.44
12/4/2015	6:00:00 PM	0.44
12/4/2015	6:15:00 PM	0.44
12/4/2015	6:30:00 PM	0.44
12/4/2015	6:45:00 PM	0.44
12/4/2015	7:00:00 PM	0.44
12/4/2015	7:15:00 PM	0.44
12/4/2015	7:30:00 PM	0.44
12/4/2015	7:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/4/2015	8:00:00 PM	0.44
12/4/2015	8:15:00 PM	0.44
12/4/2015	8:30:00 PM	0.44
12/4/2015	8:45:00 PM	0.44
12/4/2015	9:00:00 PM	0.44
12/4/2015	9:15:00 PM	0.44
12/4/2015	9:30:00 PM	0.44
12/4/2015	9:45:00 PM	0.44
12/4/2015	10:00:00 PM	0.44
12/4/2015	10:15:00 PM	0.43
12/4/2015	10:30:00 PM	0.43
12/4/2015	10:45:00 PM	0.43
12/4/2015	11:00:00 PM	0.43
12/4/2015	11:15:00 PM	0.43
12/4/2015	11:30:00 PM	0.43
12/4/2015	11:45:00 PM	0.43
12/5/2015	12:00:00 AM	0.43
12/5/2015	12:15:00 AM	0.43
12/5/2015	12:30:00 AM	0.42
12/5/2015	12:45:00 AM	0.42
12/5/2015	1:00:00 AM	0.42
12/5/2015	1:15:00 AM	0.42
12/5/2015	1:30:00 AM	0.42
12/5/2015	1:45:00 AM	0.42
12/5/2015	2:00:00 AM	0.42
12/5/2015	2:15:00 AM	0.42
12/5/2015	2:30:00 AM	0.42
12/5/2015	2:45:00 AM	0.42
12/5/2015	3:00:00 AM	0.42
12/5/2015	3:15:00 AM	0.42
12/5/2015	3:30:00 AM	0.42
12/5/2015	3:45:00 AM	0.42
12/5/2015	4:00:00 AM	0.42
12/5/2015	4:15:00 AM	0.42
12/5/2015	4:30:00 AM	0.42
12/5/2015	4:45:00 AM	0.42
12/5/2015	5:00:00 AM	0.42
12/5/2015	5:15:00 AM	0.42
12/5/2015	5:30:00 AM	0.42
12/5/2015	5:45:00 AM	0.42
12/5/2015	6:00:00 AM	0.42
12/5/2015	6:15:00 AM	0.42
12/5/2015	6:30:00 AM	0.42
12/5/2015	6:45:00 AM	0.42
12/5/2015	7:00:00 AM	0.42
12/5/2015	7:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
12/5/2015	7:30:00 AM	0.41
12/5/2015	7:45:00 AM	0.41
12/5/2015	8:00:00 AM	0.4
12/5/2015	8:15:00 AM	0.4
12/5/2015	8:30:00 AM	0.4
12/5/2015	8:45:00 AM	0.4
12/5/2015	9:00:00 AM	0.4
12/5/2015	9:15:00 AM	0.4
12/5/2015	9:30:00 AM	0.4
12/5/2015	9:45:00 AM	0.4
12/5/2015	10:00:00 AM	0.4
12/5/2015	10:15:00 AM	0.4
12/5/2015	10:30:00 AM	0.4
12/5/2015	10:45:00 AM	0.4
12/5/2015	11:00:00 AM	0.4
12/5/2015	11:15:00 AM	0.4
12/5/2015	11:30:00 AM	0.4
12/5/2015	11:45:00 AM	0.4
12/5/2015	12:00:00 PM	0.4
12/5/2015	12:15:00 PM	0.4
12/5/2015	12:30:00 PM	0.4
12/5/2015	12:45:00 PM	0.4
12/5/2015	1:00:00 PM	0.4
12/5/2015	1:15:00 PM	0.4
12/5/2015	1:30:00 PM	0.4
12/5/2015	1:45:00 PM	0.4
12/5/2015	2:00:00 PM	0.4
12/5/2015	2:15:00 PM	0.4
12/5/2015	2:30:00 PM	0.4
12/5/2015	2:45:00 PM	0.4
12/5/2015	3:00:00 PM	0.4
12/5/2015	3:15:00 PM	0.4
12/5/2015	3:30:00 PM	0.4
12/5/2015	3:45:00 PM	0.4
12/5/2015	4:00:00 PM	0.4
12/5/2015	4:15:00 PM	0.4
12/5/2015	4:30:00 PM	0.4
12/5/2015	4:45:00 PM	0.4
12/5/2015	5:00:00 PM	0.4
12/5/2015	5:15:00 PM	0.4
12/5/2015	5:30:00 PM	0.39
12/5/2015	5:45:00 PM	0.39
12/5/2015	6:00:00 PM	0.39
12/5/2015	6:15:00 PM	0.39
12/5/2015	6:30:00 PM	0.39
12/5/2015	6:45:00 PM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
12/5/2015	7:00:00 PM	0.39
12/5/2015	7:15:00 PM	0.39
12/5/2015	7:30:00 PM	0.39
12/5/2015	7:45:00 PM	0.39
12/5/2015	8:00:00 PM	0.39
12/5/2015	8:15:00 PM	0.39
12/5/2015	8:30:00 PM	0.39
12/5/2015	8:45:00 PM	0.38
12/5/2015	9:00:00 PM	0.38
12/5/2015	9:15:00 PM	0.38
12/5/2015	9:30:00 PM	0.38
12/5/2015	9:45:00 PM	0.38
12/5/2015	10:00:00 PM	0.38
12/5/2015	10:15:00 PM	0.38
12/5/2015	10:30:00 PM	0.38
12/5/2015	10:45:00 PM	0.38
12/5/2015	11:00:00 PM	0.38
12/5/2015	11:15:00 PM	0.38
12/5/2015	11:30:00 PM	0.38
12/5/2015	11:45:00 PM	0.38
12/6/2015	12:00:00 AM	0.38
12/6/2015	12:15:00 AM	0.38
12/6/2015	12:30:00 AM	0.38
12/6/2015	12:45:00 AM	0.38
12/6/2015	1:00:00 AM	0.38
12/6/2015	1:15:00 AM	0.37
12/6/2015	1:30:00 AM	0.37
12/6/2015	1:45:00 AM	0.37
12/6/2015	2:00:00 AM	0.37
12/6/2015	2:15:00 AM	0.37
12/6/2015	2:30:00 AM	0.37
12/6/2015	2:45:00 AM	0.37
12/6/2015	3:00:00 AM	0.37
12/6/2015	3:15:00 AM	0.36
12/6/2015	3:30:00 AM	0.36
12/6/2015	3:45:00 AM	0.36
12/6/2015	4:00:00 AM	0.36
12/6/2015	4:15:00 AM	0.36
12/6/2015	4:30:00 AM	0.36
12/6/2015	4:45:00 AM	0.36
12/6/2015	5:00:00 AM	0.36
12/6/2015	5:15:00 AM	0.36
12/6/2015	5:30:00 AM	0.36
12/6/2015	5:45:00 AM	0.36
12/6/2015	6:00:00 AM	0.36
12/6/2015	6:15:00 AM	0.36

Goose Lake Return Gage

DATE	TIME	GAGE
12/6/2015	6:30:00 AM	0.36
12/6/2015	6:45:00 AM	0.36
12/6/2015	7:00:00 AM	0.36
12/6/2015	7:15:00 AM	0.36
12/6/2015	7:30:00 AM	0.36
12/6/2015	7:45:00 AM	0.36
12/6/2015	8:00:00 AM	0.36
12/6/2015	8:15:00 AM	0.36
12/6/2015	8:30:00 AM	0.35
12/6/2015	8:45:00 AM	0.35
12/6/2015	9:00:00 AM	0.35
12/6/2015	9:15:00 AM	0.35
12/6/2015	9:30:00 AM	0.36
12/6/2015	9:45:00 AM	0.36
12/6/2015	10:00:00 AM	0.36
12/6/2015	10:15:00 AM	0.35
12/6/2015	10:30:00 AM	0.34
12/6/2015	10:45:00 AM	0.34
12/6/2015	11:00:00 AM	0.34
12/6/2015	11:15:00 AM	0.34
12/6/2015	11:30:00 AM	0.34
12/6/2015	11:45:00 AM	0.34
12/6/2015	12:00:00 PM	0.34
12/6/2015	12:15:00 PM	0.34
12/6/2015	12:30:00 PM	0.34
12/6/2015	12:45:00 PM	0.34
12/6/2015	1:00:00 PM	0.34
12/6/2015	1:15:00 PM	0.34
12/6/2015	1:30:00 PM	0.34
12/6/2015	1:45:00 PM	0.34
12/6/2015	2:00:00 PM	0.34
12/6/2015	2:15:00 PM	0.34
12/6/2015	2:30:00 PM	0.34
12/6/2015	2:45:00 PM	0.34
12/6/2015	3:00:00 PM	0.34
12/6/2015	3:15:00 PM	0.34
12/6/2015	3:30:00 PM	0.34
12/6/2015	3:45:00 PM	0.34
12/6/2015	4:00:00 PM	0.34
12/6/2015	4:15:00 PM	0.34
12/6/2015	4:30:00 PM	0.34
12/6/2015	4:45:00 PM	0.34
12/6/2015	5:00:00 PM	0.34
12/6/2015	5:15:00 PM	0.33
12/6/2015	5:30:00 PM	0.33
12/6/2015	5:45:00 PM	0.33

Goose Lake Return Gage

DATE	TIME	GAGE
12/6/2015	6:00:00 PM	0.33
12/6/2015	6:15:00 PM	0.33
12/6/2015	6:30:00 PM	0.33
12/6/2015	6:45:00 PM	0.33
12/6/2015	7:00:00 PM	0.33
12/6/2015	7:15:00 PM	0.32
12/6/2015	7:30:00 PM	0.32
12/6/2015	7:45:00 PM	0.32
12/6/2015	8:00:00 PM	0.32
12/6/2015	8:15:00 PM	0.33
12/6/2015	8:30:00 PM	0.33
12/6/2015	8:45:00 PM	0.33
12/6/2015	9:00:00 PM	0.32
12/6/2015	9:15:00 PM	0.32
12/6/2015	9:30:00 PM	0.32
12/6/2015	9:45:00 PM	0.32
12/6/2015	10:00:00 PM	0.32
12/6/2015	10:15:00 PM	0.32
12/6/2015	10:30:00 PM	0.32
12/6/2015	10:45:00 PM	0.32
12/6/2015	11:00:00 PM	0.32
12/6/2015	11:15:00 PM	0.32
12/6/2015	11:30:00 PM	0.32
12/6/2015	11:45:00 PM	0.32
12/7/2015	12:00:00 AM	0.32
12/7/2015	12:15:00 AM	0.32
12/7/2015	12:30:00 AM	0.32
12/7/2015	12:45:00 AM	0.32
12/7/2015	1:00:00 AM	0.32
12/7/2015	1:15:00 AM	0.32
12/7/2015	1:30:00 AM	0.32
12/7/2015	1:45:00 AM	0.32
12/7/2015	2:00:00 AM	0.32
12/7/2015	2:15:00 AM	0.32
12/7/2015	2:30:00 AM	0.32
12/7/2015	2:45:00 AM	0.32
12/7/2015	3:00:00 AM	0.32
12/7/2015	3:15:00 AM	0.32
12/7/2015	3:30:00 AM	0.32
12/7/2015	3:45:00 AM	0.32
12/7/2015	4:00:00 AM	0.32
12/7/2015	4:15:00 AM	0.32
12/7/2015	4:30:00 AM	0.32
12/7/2015	4:45:00 AM	0.32
12/7/2015	5:00:00 AM	0.31
12/7/2015	5:15:00 AM	0.31

Goose Lake Return Gage

DATE	TIME	GAGE
12/7/2015	5:30:00 AM	0.31
12/7/2015	5:45:00 AM	0.31
12/7/2015	6:00:00 AM	0.31
12/7/2015	6:15:00 AM	0.31
12/7/2015	6:30:00 AM	0.31
12/7/2015	6:45:00 AM	0.31
12/7/2015	7:00:00 AM	0.31
12/7/2015	7:15:00 AM	0.31
12/7/2015	7:30:00 AM	0.31
12/7/2015	7:45:00 AM	0.31
12/7/2015	8:00:00 AM	0.31
12/7/2015	8:15:00 AM	0.31
12/7/2015	8:30:00 AM	0.31
12/7/2015	8:45:00 AM	0.31
12/7/2015	9:00:00 AM	0.31
12/7/2015	9:15:00 AM	0.31
12/7/2015	9:30:00 AM	0.31
12/7/2015	9:45:00 AM	0.31
12/7/2015	10:00:00 AM	0.31
12/7/2015	10:15:00 AM	0.31
12/7/2015	10:30:00 AM	0.3
12/7/2015	10:45:00 AM	0.3
12/7/2015	11:00:00 AM	0.3
12/7/2015	11:15:00 AM	0.3
12/7/2015	11:30:00 AM	0.3
12/7/2015	11:45:00 AM	0.3
12/7/2015	12:00:00 PM	0.3
12/7/2015	12:15:00 PM	0.3
12/7/2015	12:30:00 PM	0.3
12/7/2015	12:45:00 PM	0.3
12/7/2015	1:00:00 PM	0.3
12/7/2015	1:15:00 PM	0.3
12/7/2015	1:30:00 PM	0.3
12/7/2015	1:45:00 PM	0.3
12/7/2015	2:00:00 PM	0.3
12/7/2015	2:15:00 PM	0.3
12/7/2015	2:30:00 PM	0.3
12/7/2015	2:45:00 PM	0.3
12/7/2015	3:00:00 PM	0.3
12/7/2015	3:15:00 PM	0.3
12/7/2015	3:30:00 PM	0.3
12/7/2015	3:45:00 PM	0.3
12/7/2015	4:00:00 PM	0.3
12/7/2015	4:15:00 PM	0.3
12/7/2015	4:30:00 PM	0.3
12/7/2015	4:45:00 PM	0.3

Goose Lake Return Gage

DATE	TIME	GAGE
12/7/2015	5:00:00 PM	0.3
12/7/2015	5:15:00 PM	0.3
12/7/2015	5:30:00 PM	0.3
12/7/2015	5:45:00 PM	0.3
12/7/2015	6:00:00 PM	0.3
12/7/2015	6:15:00 PM	0.3
12/7/2015	6:30:00 PM	0.3
12/7/2015	6:45:00 PM	0.3
12/7/2015	7:00:00 PM	0.3
12/7/2015	7:15:00 PM	0.31
12/7/2015	7:30:00 PM	0.31
12/7/2015	7:45:00 PM	0.31
12/7/2015	8:00:00 PM	0.31
12/7/2015	8:15:00 PM	0.31
12/7/2015	8:30:00 PM	0.31
12/7/2015	8:45:00 PM	0.31
12/7/2015	9:00:00 PM	0.31
12/7/2015	9:15:00 PM	0.31
12/7/2015	9:30:00 PM	0.31
12/7/2015	9:45:00 PM	0.31
12/7/2015	10:00:00 PM	0.31
12/7/2015	10:15:00 PM	0.31
12/7/2015	10:30:00 PM	0.31
12/7/2015	10:45:00 PM	0.32
12/7/2015	11:00:00 PM	0.32
12/7/2015	11:15:00 PM	0.32
12/7/2015	11:30:00 PM	0.32
12/7/2015	11:45:00 PM	0.32
12/8/2015	12:00:00 AM	0.32
12/8/2015	12:15:00 AM	0.32
12/8/2015	12:30:00 AM	0.32
12/8/2015	12:45:00 AM	0.32
12/8/2015	1:00:00 AM	0.32
12/8/2015	1:15:00 AM	0.32
12/8/2015	1:30:00 AM	0.32
12/8/2015	1:45:00 AM	0.32
12/8/2015	2:00:00 AM	0.32
12/8/2015	2:15:00 AM	0.32
12/8/2015	2:30:00 AM	0.32
12/8/2015	2:45:00 AM	0.32
12/8/2015	3:00:00 AM	0.32
12/8/2015	3:15:00 AM	0.32
12/8/2015	3:30:00 AM	0.32
12/8/2015	3:45:00 AM	0.32
12/8/2015	4:00:00 AM	0.32
12/8/2015	4:15:00 AM	0.32

Goose Lake Return Gage

DATE	TIME	GAGE
12/8/2015	4:30:00 AM	0.32
12/8/2015	4:45:00 AM	0.33
12/8/2015	5:00:00 AM	0.33
12/8/2015	5:15:00 AM	0.33
12/8/2015	5:30:00 AM	0.33
12/8/2015	5:45:00 AM	0.33
12/8/2015	6:00:00 AM	0.33
12/8/2015	6:15:00 AM	0.33
12/8/2015	6:30:00 AM	0.33
12/8/2015	6:45:00 AM	0.33
12/8/2015	7:00:00 AM	0.34
12/8/2015	7:15:00 AM	0.34
12/8/2015	7:30:00 AM	0.34
12/8/2015	7:45:00 AM	0.34
12/8/2015	8:00:00 AM	0.34
12/8/2015	8:15:00 AM	0.34
12/8/2015	8:30:00 AM	0.34
12/8/2015	8:45:00 AM	0.34
12/8/2015	9:00:00 AM	0.34
12/8/2015	9:15:00 AM	0.34
12/8/2015	9:30:00 AM	0.34
12/8/2015	9:45:00 AM	0.34
12/8/2015	10:00:00 AM	0.34
12/8/2015	10:15:00 AM	0.34
12/8/2015	10:30:00 AM	0.34
12/8/2015	10:45:00 AM	0.34
12/8/2015	11:00:00 AM	0.34
12/8/2015	11:15:00 AM	0.34
12/8/2015	11:30:00 AM	0.34
12/8/2015	11:45:00 AM	0.34
12/8/2015	12:00:00 PM	0.34
12/8/2015	12:15:00 PM	0.35
12/8/2015	12:30:00 PM	0.35
12/8/2015	12:45:00 PM	0.35
12/8/2015	1:00:00 PM	0.35
12/8/2015	1:15:00 PM	0.35
12/8/2015	1:30:00 PM	0.35
12/8/2015	1:45:00 PM	0.36
12/8/2015	2:00:00 PM	0.36
12/8/2015	2:15:00 PM	0.36
12/8/2015	2:30:00 PM	0.36
12/8/2015	2:45:00 PM	0.36
12/8/2015	3:00:00 PM	0.36
12/8/2015	3:15:00 PM	0.36
12/8/2015	3:30:00 PM	0.36
12/8/2015	3:45:00 PM	0.36

Goose Lake Return Gage

DATE	TIME	GAGE
12/8/2015	4:00:00 PM	0.36
12/8/2015	4:15:00 PM	0.36
12/8/2015	4:30:00 PM	0.36
12/8/2015	4:45:00 PM	0.36
12/8/2015	5:00:00 PM	0.36
12/8/2015	5:15:00 PM	0.36
12/8/2015	5:30:00 PM	0.36
12/8/2015	5:45:00 PM	0.36
12/8/2015	6:00:00 PM	0.36
12/8/2015	6:15:00 PM	0.36
12/8/2015	6:30:00 PM	0.36
12/8/2015	6:45:00 PM	0.37
12/8/2015	7:00:00 PM	0.37
12/8/2015	7:15:00 PM	0.38
12/8/2015	7:30:00 PM	0.38
12/8/2015	7:45:00 PM	0.38
12/8/2015	8:00:00 PM	0.38
12/8/2015	8:15:00 PM	0.38
12/8/2015	8:30:00 PM	0.38
12/8/2015	8:45:00 PM	0.38
12/8/2015	9:00:00 PM	0.38
12/8/2015	9:15:00 PM	0.38
12/8/2015	9:30:00 PM	0.38
12/8/2015	9:45:00 PM	0.38
12/8/2015	10:00:00 PM	0.38
12/8/2015	10:15:00 PM	0.38
12/8/2015	10:30:00 PM	0.38
12/8/2015	10:45:00 PM	0.38
12/8/2015	11:00:00 PM	0.38
12/8/2015	11:15:00 PM	0.38
12/8/2015	11:30:00 PM	0.39
12/8/2015	11:45:00 PM	0.38
12/9/2015	12:00:00 AM	0.38
12/9/2015	12:15:00 AM	0.38
12/9/2015	12:30:00 AM	0.38
12/9/2015	12:45:00 AM	0.39
12/9/2015	1:00:00 AM	0.39
12/9/2015	1:15:00 AM	0.4
12/9/2015	1:30:00 AM	0.4
12/9/2015	1:45:00 AM	0.4
12/9/2015	2:00:00 AM	0.4
12/9/2015	2:15:00 AM	0.4
12/9/2015	2:30:00 AM	0.4
12/9/2015	2:45:00 AM	0.4
12/9/2015	3:00:00 AM	0.4
12/9/2015	3:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
12/9/2015	3:30:00 AM	0.4
12/9/2015	3:45:00 AM	0.4
12/9/2015	4:00:00 AM	0.4
12/9/2015	4:15:00 AM	0.4
12/9/2015	4:30:00 AM	0.41
12/9/2015	4:45:00 AM	0.41
12/9/2015	5:00:00 AM	0.41
12/9/2015	5:15:00 AM	0.41
12/9/2015	5:30:00 AM	0.42
12/9/2015	5:45:00 AM	0.42
12/9/2015	6:00:00 AM	0.42
12/9/2015	6:15:00 AM	0.42
12/9/2015	6:30:00 AM	0.42
12/9/2015	6:45:00 AM	0.42
12/9/2015	7:00:00 AM	0.42
12/9/2015	7:15:00 AM	0.42
12/9/2015	7:30:00 AM	0.43
12/9/2015	7:45:00 AM	0.43
12/9/2015	8:00:00 AM	0.43
12/9/2015	8:15:00 AM	0.43
12/9/2015	8:30:00 AM	0.43
12/9/2015	8:45:00 AM	0.43
12/9/2015	9:00:00 AM	0.43
12/9/2015	9:15:00 AM	0.44
12/9/2015	9:30:00 AM	0.44
12/9/2015	9:45:00 AM	0.44
12/9/2015	10:00:00 AM	0.44
12/9/2015	10:15:00 AM	0.44
12/9/2015	10:30:00 AM	0.44
12/9/2015	10:45:00 AM	0.44
12/9/2015	11:00:00 AM	0.44
12/9/2015	11:15:00 AM	0.44
12/9/2015	11:30:00 AM	0.44
12/9/2015	11:45:00 AM	0.44
12/9/2015	12:00:00 PM	0.44
12/9/2015	12:15:00 PM	0.44
12/9/2015	12:30:00 PM	0.44
12/9/2015	12:45:00 PM	0.44
12/9/2015	1:00:00 PM	0.44
12/9/2015	1:15:00 PM	0.44
12/9/2015	1:30:00 PM	0.45
12/9/2015	1:45:00 PM	0.45
12/9/2015	2:00:00 PM	0.45
12/9/2015	2:15:00 PM	0.45
12/9/2015	2:30:00 PM	0.45
12/9/2015	2:45:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
12/9/2015	3:00:00 PM	0.45
12/9/2015	3:15:00 PM	0.46
12/9/2015	3:30:00 PM	0.46
12/9/2015	3:45:00 PM	0.45
12/9/2015	4:00:00 PM	0.46
12/9/2015	4:15:00 PM	0.46
12/9/2015	4:30:00 PM	0.46
12/9/2015	4:45:00 PM	0.46
12/9/2015	5:00:00 PM	0.46
12/9/2015	5:15:00 PM	0.46
12/9/2015	5:30:00 PM	0.46
12/9/2015	5:45:00 PM	0.46
12/9/2015	6:00:00 PM	0.46
12/9/2015	6:15:00 PM	0.46
12/9/2015	6:30:00 PM	0.46
12/9/2015	6:45:00 PM	0.46
12/9/2015	7:00:00 PM	0.46
12/9/2015	7:15:00 PM	0.46
12/9/2015	7:30:00 PM	0.46
12/9/2015	7:45:00 PM	0.46
12/9/2015	8:00:00 PM	0.46
12/9/2015	8:15:00 PM	0.46
12/9/2015	8:30:00 PM	0.46
12/9/2015	8:45:00 PM	0.46
12/9/2015	9:00:00 PM	0.46
12/9/2015	9:15:00 PM	0.46
12/9/2015	9:30:00 PM	0.46
12/9/2015	9:45:00 PM	0.46
12/9/2015	10:00:00 PM	0.46
12/9/2015	10:15:00 PM	0.46
12/9/2015	10:30:00 PM	0.46
12/9/2015	10:45:00 PM	0.46
12/9/2015	11:00:00 PM	0.46
12/9/2015	11:15:00 PM	0.46
12/9/2015	11:30:00 PM	0.46
12/9/2015	11:45:00 PM	0.46
12/10/2015	12:00:00 AM	0.46
12/10/2015	12:15:00 AM	0.46
12/10/2015	12:30:00 AM	0.46
12/10/2015	12:45:00 AM	0.46
12/10/2015	1:00:00 AM	0.46
12/10/2015	1:15:00 AM	0.47
12/10/2015	1:30:00 AM	0.47
12/10/2015	1:45:00 AM	0.47
12/10/2015	2:00:00 AM	0.47
12/10/2015	2:15:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/10/2015	2:30:00 AM	0.47
12/10/2015	2:45:00 AM	0.47
12/10/2015	3:00:00 AM	0.47
12/10/2015	3:15:00 AM	0.47
12/10/2015	3:30:00 AM	0.47
12/10/2015	3:45:00 AM	0.47
12/10/2015	4:00:00 AM	0.47
12/10/2015	4:15:00 AM	0.48
12/10/2015	4:30:00 AM	0.48
12/10/2015	4:45:00 AM	0.48
12/10/2015	5:00:00 AM	0.48
12/10/2015	5:15:00 AM	0.48
12/10/2015	5:30:00 AM	0.48
12/10/2015	5:45:00 AM	0.48
12/10/2015	6:00:00 AM	0.48
12/10/2015	6:15:00 AM	0.48
12/10/2015	6:30:00 AM	0.48
12/10/2015	6:45:00 AM	0.48
12/10/2015	7:00:00 AM	0.48
12/10/2015	7:15:00 AM	0.48
12/10/2015	7:30:00 AM	0.48
12/10/2015	7:45:00 AM	0.48
12/10/2015	8:00:00 AM	0.48
12/10/2015	8:15:00 AM	0.48
12/10/2015	8:30:00 AM	0.48
12/10/2015	8:45:00 AM	0.48
12/10/2015	9:00:00 AM	0.48
12/10/2015	9:15:00 AM	0.48
12/10/2015	9:30:00 AM	0.48
12/10/2015	9:45:00 AM	0.48
12/10/2015	10:00:00 AM	0.48
12/10/2015	10:15:00 AM	0.48
12/10/2015	10:30:00 AM	0.48
12/10/2015	10:45:00 AM	0.48
12/10/2015	11:00:00 AM	0.48
12/10/2015	11:15:00 AM	0.48
12/10/2015	11:30:00 AM	0.48
12/10/2015	11:45:00 AM	0.48
12/10/2015	12:00:00 PM	0.49
12/10/2015	12:15:00 PM	0.48
12/10/2015	12:30:00 PM	0.48
12/10/2015	12:45:00 PM	0.48
12/10/2015	1:00:00 PM	0.48
12/10/2015	1:15:00 PM	0.49
12/10/2015	1:30:00 PM	0.49
12/10/2015	1:45:00 PM	0.49

Goose Lake Return Gage

DATE	TIME	GAGE
12/10/2015	2:00:00 PM	0.49
12/10/2015	2:15:00 PM	0.49
12/10/2015	2:30:00 PM	0.49
12/10/2015	2:45:00 PM	0.49
12/10/2015	3:00:00 PM	0.48
12/10/2015	3:15:00 PM	0.48
12/10/2015	3:30:00 PM	0.48
12/10/2015	3:45:00 PM	0.48
12/10/2015	4:00:00 PM	0.48
12/10/2015	4:15:00 PM	0.49
12/10/2015	4:30:00 PM	0.48
12/10/2015	4:45:00 PM	0.48
12/10/2015	5:00:00 PM	0.48
12/10/2015	5:15:00 PM	0.49
12/10/2015	5:30:00 PM	0.49
12/10/2015	5:45:00 PM	0.49
12/10/2015	6:00:00 PM	0.49
12/10/2015	6:15:00 PM	0.49
12/10/2015	6:30:00 PM	0.49
12/10/2015	6:45:00 PM	0.49
12/10/2015	7:00:00 PM	0.49
12/10/2015	7:15:00 PM	0.49
12/10/2015	7:30:00 PM	0.49
12/10/2015	7:45:00 PM	0.49
12/10/2015	8:00:00 PM	0.49
12/10/2015	8:15:00 PM	0.49
12/10/2015	8:30:00 PM	0.49
12/10/2015	8:45:00 PM	0.49
12/10/2015	9:00:00 PM	0.49
12/10/2015	9:15:00 PM	0.49
12/10/2015	9:30:00 PM	0.49
12/10/2015	9:45:00 PM	0.49
12/10/2015	10:00:00 PM	0.49
12/10/2015	10:15:00 PM	0.5
12/10/2015	10:30:00 PM	0.5
12/10/2015	10:45:00 PM	0.5
12/10/2015	11:00:00 PM	0.5
12/10/2015	11:15:00 PM	0.5
12/10/2015	11:30:00 PM	0.5
12/10/2015	11:45:00 PM	0.49
12/11/2015	12:00:00 AM	0.5
12/11/2015	12:15:00 AM	0.5
12/11/2015	12:30:00 AM	0.49
12/11/2015	12:45:00 AM	0.5
12/11/2015	1:00:00 AM	0.5
12/11/2015	1:15:00 AM	0.5

Goose Lake Return Gage

DATE	TIME	GAGE
12/11/2015	1:30:00 AM	0.5
12/11/2015	1:45:00 AM	0.5
12/11/2015	2:00:00 AM	0.5
12/11/2015	2:15:00 AM	0.5
12/11/2015	2:30:00 AM	0.5
12/11/2015	2:45:00 AM	0.5
12/11/2015	3:00:00 AM	0.5
12/11/2015	3:15:00 AM	0.5
12/11/2015	3:30:00 AM	0.5
12/11/2015	3:45:00 AM	0.5
12/11/2015	4:00:00 AM	0.5
12/11/2015	4:15:00 AM	0.5
12/11/2015	4:30:00 AM	0.5
12/11/2015	4:45:00 AM	0.5
12/11/2015	5:00:00 AM	0.5
12/11/2015	5:15:00 AM	0.5
12/11/2015	5:30:00 AM	0.5
12/11/2015	5:45:00 AM	0.5
12/11/2015	6:00:00 AM	0.5
12/11/2015	6:15:00 AM	0.5
12/11/2015	6:30:00 AM	0.5
12/11/2015	6:45:00 AM	0.5
12/11/2015	7:00:00 AM	0.5
12/11/2015	7:15:00 AM	0.5
12/11/2015	7:30:00 AM	0.5
12/11/2015	7:45:00 AM	0.5
12/11/2015	8:00:00 AM	0.5
12/11/2015	8:15:00 AM	0.5
12/11/2015	8:30:00 AM	0.5
12/11/2015	8:45:00 AM	0.5
12/11/2015	9:00:00 AM	0.5
12/11/2015	9:15:00 AM	0.5
12/11/2015	9:30:00 AM	0.5
12/11/2015	9:45:00 AM	0.5
12/11/2015	10:00:00 AM	0.5
12/11/2015	10:15:00 AM	0.5
12/11/2015	10:30:00 AM	0.5
12/11/2015	10:45:00 AM	0.5
12/11/2015	11:00:00 AM	0.5
12/11/2015	11:15:00 AM	0.5
12/11/2015	11:30:00 AM	0.5
12/11/2015	11:45:00 AM	0.5
12/11/2015	12:00:00 PM	0.5
12/11/2015	12:15:00 PM	0.5
12/11/2015	12:30:00 PM	0.5
12/11/2015	12:45:00 PM	0.5

Goose Lake Return Gage

DATE	TIME	GAGE
12/11/2015	1:00:00 PM	0.5
12/11/2015	1:15:00 PM	0.5
12/11/2015	1:30:00 PM	0.5
12/11/2015	1:45:00 PM	0.5
12/11/2015	2:00:00 PM	0.5
12/11/2015	2:15:00 PM	0.5
12/11/2015	2:30:00 PM	0.5
12/11/2015	2:45:00 PM	0.5
12/11/2015	3:00:00 PM	0.5
12/11/2015	3:15:00 PM	0.51
12/11/2015	3:30:00 PM	0.51
12/11/2015	3:45:00 PM	0.51
12/11/2015	4:00:00 PM	0.51
12/11/2015	4:15:00 PM	0.51
12/11/2015	4:30:00 PM	0.51
12/11/2015	4:45:00 PM	0.5
12/11/2015	5:00:00 PM	0.5
12/11/2015	5:15:00 PM	0.5
12/11/2015	5:30:00 PM	0.5
12/11/2015	5:45:00 PM	0.5
12/11/2015	6:00:00 PM	0.5
12/11/2015	6:15:00 PM	0.5
12/11/2015	6:30:00 PM	0.5
12/11/2015	6:45:00 PM	0.5
12/11/2015	7:00:00 PM	0.5
12/11/2015	7:15:00 PM	0.5
12/11/2015	7:30:00 PM	0.5
12/11/2015	7:45:00 PM	0.5
12/11/2015	8:00:00 PM	0.5
12/11/2015	8:15:00 PM	0.5
12/11/2015	8:30:00 PM	0.5
12/11/2015	8:45:00 PM	0.5
12/11/2015	9:00:00 PM	0.5
12/11/2015	9:15:00 PM	0.5
12/11/2015	9:30:00 PM	0.5
12/11/2015	9:45:00 PM	0.5
12/11/2015	10:00:00 PM	0.5
12/11/2015	10:15:00 PM	0.5
12/11/2015	10:30:00 PM	0.5
12/11/2015	10:45:00 PM	0.5
12/11/2015	11:00:00 PM	0.5
12/11/2015	11:15:00 PM	0.5
12/11/2015	11:30:00 PM	0.5
12/11/2015	11:45:00 PM	0.5
12/12/2015	12:00:00 AM	0.5
12/12/2015	12:15:00 AM	0.5

Goose Lake Return Gage

DATE	TIME	GAGE
12/12/2015	12:30:00 AM	0.5
12/12/2015	12:45:00 AM	0.5
12/12/2015	1:00:00 AM	0.5
12/12/2015	1:15:00 AM	0.5
12/12/2015	1:30:00 AM	0.5
12/12/2015	1:45:00 AM	0.5
12/12/2015	2:00:00 AM	0.5
12/12/2015	2:15:00 AM	0.5
12/12/2015	2:30:00 AM	0.5
12/12/2015	2:45:00 AM	0.5
12/12/2015	3:00:00 AM	0.5
12/12/2015	3:15:00 AM	0.5
12/12/2015	3:30:00 AM	0.5
12/12/2015	3:45:00 AM	0.5
12/12/2015	4:00:00 AM	0.5
12/12/2015	4:15:00 AM	0.5
12/12/2015	4:30:00 AM	0.5
12/12/2015	4:45:00 AM	0.5
12/12/2015	5:00:00 AM	0.5
12/12/2015	5:15:00 AM	0.5
12/12/2015	5:30:00 AM	0.5
12/12/2015	5:45:00 AM	0.5
12/12/2015	6:00:00 AM	0.5
12/12/2015	6:15:00 AM	0.5
12/12/2015	6:30:00 AM	0.5
12/12/2015	6:45:00 AM	0.5
12/12/2015	7:00:00 AM	0.5
12/12/2015	7:15:00 AM	0.5
12/12/2015	7:30:00 AM	0.5
12/12/2015	7:45:00 AM	0.5
12/12/2015	8:00:00 AM	0.5
12/12/2015	8:15:00 AM	0.5
12/12/2015	8:30:00 AM	0.5
12/12/2015	8:45:00 AM	0.5
12/12/2015	9:00:00 AM	0.5
12/12/2015	9:15:00 AM	0.5
12/12/2015	9:30:00 AM	0.5
12/12/2015	9:45:00 AM	0.5
12/12/2015	10:00:00 AM	0.5
12/12/2015	10:15:00 AM	0.5
12/12/2015	10:30:00 AM	0.5
12/12/2015	10:45:00 AM	0.5
12/12/2015	11:00:00 AM	0.5
12/12/2015	11:15:00 AM	0.5
12/12/2015	11:30:00 AM	0.5
12/12/2015	11:45:00 AM	0.5

Goose Lake Return Gage

DATE	TIME	GAGE
12/12/2015	12:00:00 PM	0.5
12/12/2015	12:15:00 PM	0.5
12/12/2015	12:30:00 PM	0.5
12/12/2015	12:45:00 PM	0.5
12/12/2015	1:00:00 PM	0.5
12/12/2015	1:15:00 PM	0.5
12/12/2015	1:30:00 PM	0.5
12/12/2015	1:45:00 PM	0.5
12/12/2015	2:00:00 PM	0.5
12/12/2015	2:15:00 PM	0.5
12/12/2015	2:30:00 PM	0.5
12/12/2015	2:45:00 PM	0.5
12/12/2015	3:00:00 PM	0.5
12/12/2015	3:15:00 PM	0.5
12/12/2015	3:30:00 PM	0.5
12/12/2015	3:45:00 PM	0.5
12/12/2015	4:00:00 PM	0.5
12/12/2015	4:15:00 PM	0.5
12/12/2015	4:30:00 PM	0.5
12/12/2015	4:45:00 PM	0.49
12/12/2015	5:00:00 PM	0.49
12/12/2015	5:15:00 PM	0.49
12/12/2015	5:30:00 PM	0.49
12/12/2015	5:45:00 PM	0.49
12/12/2015	6:00:00 PM	0.49
12/12/2015	6:15:00 PM	0.49
12/12/2015	6:30:00 PM	0.49
12/12/2015	6:45:00 PM	0.49
12/12/2015	7:00:00 PM	0.49
12/12/2015	7:15:00 PM	0.49
12/12/2015	7:30:00 PM	0.49
12/12/2015	7:45:00 PM	0.49
12/12/2015	8:00:00 PM	0.49
12/12/2015	8:15:00 PM	0.49
12/12/2015	8:30:00 PM	0.49
12/12/2015	8:45:00 PM	0.49
12/12/2015	9:00:00 PM	0.49
12/12/2015	9:15:00 PM	0.49
12/12/2015	9:30:00 PM	0.48
12/12/2015	9:45:00 PM	0.48
12/12/2015	10:00:00 PM	0.48
12/12/2015	10:15:00 PM	0.48
12/12/2015	10:30:00 PM	0.48
12/12/2015	10:45:00 PM	0.48
12/12/2015	11:00:00 PM	0.48
12/12/2015	11:15:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/12/2015	11:30:00 PM	0.48
12/12/2015	11:45:00 PM	0.48
12/13/2015	12:00:00 AM	0.48
12/13/2015	12:15:00 AM	0.48
12/13/2015	12:30:00 AM	0.48
12/13/2015	12:45:00 AM	0.48
12/13/2015	1:00:00 AM	0.48
12/13/2015	1:15:00 AM	0.48
12/13/2015	1:30:00 AM	0.48
12/13/2015	1:45:00 AM	0.48
12/13/2015	2:00:00 AM	0.48
12/13/2015	2:15:00 AM	0.48
12/13/2015	2:30:00 AM	0.48
12/13/2015	2:45:00 AM	0.48
12/13/2015	3:00:00 AM	0.48
12/13/2015	3:15:00 AM	0.48
12/13/2015	3:30:00 AM	0.48
12/13/2015	3:45:00 AM	0.48
12/13/2015	4:00:00 AM	0.48
12/13/2015	4:15:00 AM	0.48
12/13/2015	4:30:00 AM	0.48
12/13/2015	4:45:00 AM	0.48
12/13/2015	5:00:00 AM	0.48
12/13/2015	5:15:00 AM	0.48
12/13/2015	5:30:00 AM	0.48
12/13/2015	5:45:00 AM	0.48
12/13/2015	6:00:00 AM	0.48
12/13/2015	6:15:00 AM	0.48
12/13/2015	6:30:00 AM	0.48
12/13/2015	6:45:00 AM	0.48
12/13/2015	7:00:00 AM	0.48
12/13/2015	7:15:00 AM	0.48
12/13/2015	7:30:00 AM	0.48
12/13/2015	7:45:00 AM	0.48
12/13/2015	8:00:00 AM	0.48
12/13/2015	8:15:00 AM	0.47
12/13/2015	8:30:00 AM	0.47
12/13/2015	8:45:00 AM	0.47
12/13/2015	9:00:00 AM	0.47
12/13/2015	9:15:00 AM	0.47
12/13/2015	9:30:00 AM	0.47
12/13/2015	9:45:00 AM	0.47
12/13/2015	10:00:00 AM	0.47
12/13/2015	10:15:00 AM	0.47
12/13/2015	10:30:00 AM	0.47
12/13/2015	10:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/13/2015	11:00:00 AM	0.47
12/13/2015	11:15:00 AM	0.47
12/13/2015	11:30:00 AM	0.47
12/13/2015	11:45:00 AM	0.47
12/13/2015	12:00:00 PM	0.47
12/13/2015	12:15:00 PM	0.47
12/13/2015	12:30:00 PM	0.47
12/13/2015	12:45:00 PM	0.47
12/13/2015	1:00:00 PM	0.47
12/13/2015	1:15:00 PM	0.47
12/13/2015	1:30:00 PM	0.47
12/13/2015	1:45:00 PM	0.47
12/13/2015	2:00:00 PM	0.47
12/13/2015	2:15:00 PM	0.47
12/13/2015	2:30:00 PM	0.46
12/13/2015	2:45:00 PM	0.47
12/13/2015	3:00:00 PM	0.47
12/13/2015	3:15:00 PM	0.47
12/13/2015	3:30:00 PM	0.47
12/13/2015	3:45:00 PM	0.47
12/13/2015	4:00:00 PM	0.47
12/13/2015	4:15:00 PM	0.46
12/13/2015	4:30:00 PM	0.46
12/13/2015	4:45:00 PM	0.46
12/13/2015	5:00:00 PM	0.46
12/13/2015	5:15:00 PM	0.46
12/13/2015	5:30:00 PM	0.46
12/13/2015	5:45:00 PM	0.46
12/13/2015	6:00:00 PM	0.46
12/13/2015	6:15:00 PM	0.46
12/13/2015	6:30:00 PM	0.46
12/13/2015	6:45:00 PM	0.46
12/13/2015	7:00:00 PM	0.46
12/13/2015	7:15:00 PM	0.46
12/13/2015	7:30:00 PM	0.46
12/13/2015	7:45:00 PM	0.46
12/13/2015	8:00:00 PM	0.46
12/13/2015	8:15:00 PM	0.46
12/13/2015	8:30:00 PM	0.46
12/13/2015	8:45:00 PM	0.46
12/13/2015	9:00:00 PM	0.46
12/13/2015	9:15:00 PM	0.46
12/13/2015	9:30:00 PM	0.46
12/13/2015	9:45:00 PM	0.46
12/13/2015	10:00:00 PM	0.46
12/13/2015	10:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/13/2015	10:30:00 PM	0.46
12/13/2015	10:45:00 PM	0.46
12/13/2015	11:00:00 PM	0.46
12/13/2015	11:15:00 PM	0.46
12/13/2015	11:30:00 PM	0.46
12/13/2015	11:45:00 PM	0.46
12/14/2015	12:00:00 AM	0.46
12/14/2015	12:15:00 AM	0.46
12/14/2015	12:30:00 AM	0.46
12/14/2015	12:45:00 AM	0.46
12/14/2015	1:00:00 AM	0.46
12/14/2015	1:15:00 AM	0.46
12/14/2015	1:30:00 AM	0.46
12/14/2015	1:45:00 AM	0.46
12/14/2015	2:00:00 AM	0.46
12/14/2015	2:15:00 AM	0.46
12/14/2015	2:30:00 AM	0.46
12/14/2015	2:45:00 AM	0.46
12/14/2015	3:00:00 AM	0.46
12/14/2015	3:15:00 AM	0.46
12/14/2015	3:30:00 AM	0.46
12/14/2015	3:45:00 AM	0.46
12/14/2015	4:00:00 AM	0.46
12/14/2015	4:15:00 AM	0.46
12/14/2015	4:30:00 AM	0.46
12/14/2015	4:45:00 AM	0.46
12/14/2015	5:00:00 AM	0.46
12/14/2015	5:15:00 AM	0.46
12/14/2015	5:30:00 AM	0.46
12/14/2015	5:45:00 AM	0.46
12/14/2015	6:00:00 AM	0.46
12/14/2015	6:15:00 AM	0.46
12/14/2015	6:30:00 AM	0.46
12/14/2015	6:45:00 AM	0.46
12/14/2015	7:00:00 AM	0.46
12/14/2015	7:15:00 AM	0.46
12/14/2015	7:30:00 AM	0.46
12/14/2015	7:45:00 AM	0.46
12/14/2015	8:00:00 AM	0.46
12/14/2015	8:15:00 AM	0.46
12/14/2015	8:30:00 AM	0.46
12/14/2015	8:45:00 AM	0.46
12/14/2015	9:00:00 AM	0.46
12/14/2015	9:15:00 AM	0.46
12/14/2015	9:30:00 AM	0.46
12/14/2015	9:45:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/14/2015	10:00:00 AM	0.46
12/14/2015	10:15:00 AM	0.46
12/14/2015	10:30:00 AM	0.46
12/14/2015	10:45:00 AM	0.46
12/14/2015	11:00:00 AM	0.46
12/14/2015	11:15:00 AM	0.46
12/14/2015	11:30:00 AM	0.46
12/14/2015	11:45:00 AM	0.46
12/14/2015	12:00:00 PM	0.46
12/14/2015	12:15:00 PM	0.46
12/14/2015	12:30:00 PM	0.45
12/14/2015	12:45:00 PM	0.46
12/14/2015	1:00:00 PM	0.46
12/14/2015	1:15:00 PM	0.45
12/14/2015	1:30:00 PM	0.45
12/14/2015	1:45:00 PM	0.45
12/14/2015	2:00:00 PM	0.46
12/14/2015	2:15:00 PM	0.46
12/14/2015	2:30:00 PM	0.45
12/14/2015	2:45:00 PM	0.46
12/14/2015	3:00:00 PM	0.46
12/14/2015	3:15:00 PM	0.45
12/14/2015	3:30:00 PM	0.45
12/14/2015	3:45:00 PM	0.46
12/14/2015	4:00:00 PM	0.45
12/14/2015	4:15:00 PM	0.45
12/14/2015	4:30:00 PM	0.45
12/14/2015	4:45:00 PM	0.45
12/14/2015	5:00:00 PM	0.45
12/14/2015	5:15:00 PM	0.44
12/14/2015	5:30:00 PM	0.44
12/14/2015	5:45:00 PM	0.44
12/14/2015	6:00:00 PM	0.44
12/14/2015	6:15:00 PM	0.44
12/14/2015	6:30:00 PM	0.44
12/14/2015	6:45:00 PM	0.44
12/14/2015	7:00:00 PM	0.44
12/14/2015	7:15:00 PM	0.44
12/14/2015	7:30:00 PM	0.44
12/14/2015	7:45:00 PM	0.44
12/14/2015	8:00:00 PM	0.44
12/14/2015	8:15:00 PM	0.44
12/14/2015	8:30:00 PM	0.44
12/14/2015	8:45:00 PM	0.44
12/14/2015	9:00:00 PM	0.44
12/14/2015	9:15:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/14/2015	9:30:00 PM	0.44
12/14/2015	9:45:00 PM	0.44
12/14/2015	10:00:00 PM	0.44
12/14/2015	10:15:00 PM	0.44
12/14/2015	10:30:00 PM	0.44
12/14/2015	10:45:00 PM	0.44
12/14/2015	11:00:00 PM	0.44
12/14/2015	11:15:00 PM	0.44
12/14/2015	11:30:00 PM	0.44
12/14/2015	11:45:00 PM	0.44
12/15/2015	12:00:00 AM	0.44
12/15/2015	12:15:00 AM	0.44
12/15/2015	12:30:00 AM	0.44
12/15/2015	12:45:00 AM	0.44
12/15/2015	1:00:00 AM	0.44
12/15/2015	1:15:00 AM	0.44
12/15/2015	1:30:00 AM	0.44
12/15/2015	1:45:00 AM	0.44
12/15/2015	2:00:00 AM	0.44
12/15/2015	2:15:00 AM	0.44
12/15/2015	2:30:00 AM	0.44
12/15/2015	2:45:00 AM	0.44
12/15/2015	3:00:00 AM	0.44
12/15/2015	3:15:00 AM	0.44
12/15/2015	3:30:00 AM	0.43
12/15/2015	3:45:00 AM	0.42
12/15/2015	4:00:00 AM	0.41
12/15/2015	4:15:00 AM	0.4
12/15/2015	4:30:00 AM	0.39
12/15/2015	4:45:00 AM	0.38
12/15/2015	5:00:00 AM	0.38
12/15/2015	5:15:00 AM	0.38
12/15/2015	5:30:00 AM	0.37
12/15/2015	5:45:00 AM	0.37
12/15/2015	6:00:00 AM	0.37
12/15/2015	6:15:00 AM	0.38
12/15/2015	6:30:00 AM	0.38
12/15/2015	6:45:00 AM	0.38
12/15/2015	7:00:00 AM	0.38
12/15/2015	7:15:00 AM	0.38
12/15/2015	7:30:00 AM	0.38
12/15/2015	7:45:00 AM	0.38
12/15/2015	8:00:00 AM	0.38
12/15/2015	8:15:00 AM	0.38
12/15/2015	8:30:00 AM	0.38
12/15/2015	8:45:00 AM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
12/15/2015	9:00:00 AM	0.39
12/15/2015	9:15:00 AM	0.4
12/15/2015	9:30:00 AM	0.4
12/15/2015	9:45:00 AM	0.4
12/15/2015	10:00:00 AM	0.41
12/15/2015	10:15:00 AM	0.42
12/15/2015	10:30:00 AM	0.42
12/15/2015	10:45:00 AM	0.43
12/15/2015	11:00:00 AM	0.44
12/15/2015	11:15:00 AM	0.46
12/15/2015	11:30:00 AM	0.46
12/15/2015	11:45:00 AM	0.47
12/15/2015	12:00:00 PM	0.48
12/15/2015	12:15:00 PM	0.48
12/15/2015	12:30:00 PM	0.49
12/15/2015	12:45:00 PM	0.49
12/15/2015	1:00:00 PM	0.48
12/15/2015	1:15:00 PM	0.49
12/15/2015	1:30:00 PM	0.46
12/15/2015	1:45:00 PM	0.45
12/15/2015	2:00:00 PM	0.44
12/15/2015	2:15:00 PM	0.44
12/15/2015	2:30:00 PM	0.44
12/15/2015	2:45:00 PM	0.44
12/15/2015	3:00:00 PM	0.43
12/15/2015	3:15:00 PM	0.43
12/15/2015	3:30:00 PM	0.44
12/15/2015	3:45:00 PM	0.43
12/15/2015	4:00:00 PM	0.43
12/15/2015	4:15:00 PM	0.43
12/15/2015	4:30:00 PM	0.43
12/15/2015	4:45:00 PM	0.42
12/15/2015	5:00:00 PM	0.43
12/15/2015	5:15:00 PM	0.43
12/15/2015	5:30:00 PM	0.43
12/15/2015	5:45:00 PM	0.43
12/15/2015	6:00:00 PM	0.43
12/15/2015	6:15:00 PM	0.43
12/15/2015	6:30:00 PM	0.43
12/15/2015	6:45:00 PM	0.43
12/15/2015	7:00:00 PM	0.42
12/15/2015	7:15:00 PM	0.42
12/15/2015	7:30:00 PM	0.42
12/15/2015	7:45:00 PM	0.42
12/15/2015	8:00:00 PM	0.42
12/15/2015	8:15:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
12/15/2015	8:30:00 PM	0.42
12/15/2015	8:45:00 PM	0.42
12/15/2015	9:00:00 PM	0.42
12/15/2015	9:15:00 PM	0.42
12/15/2015	9:30:00 PM	0.42
12/15/2015	9:45:00 PM	0.42
12/15/2015	10:00:00 PM	0.42
12/15/2015	10:15:00 PM	0.42
12/15/2015	10:30:00 PM	0.42
12/15/2015	10:45:00 PM	0.42
12/15/2015	11:00:00 PM	0.42
12/15/2015	11:15:00 PM	0.42
12/15/2015	11:30:00 PM	0.42
12/15/2015	11:45:00 PM	0.42
12/16/2015	12:00:00 AM	0.42
12/16/2015	12:15:00 AM	0.42
12/16/2015	12:30:00 AM	0.43
12/16/2015	12:45:00 AM	0.42
12/16/2015	1:00:00 AM	0.42
12/16/2015	1:15:00 AM	0.42
12/16/2015	1:30:00 AM	0.42
12/16/2015	1:45:00 AM	0.42
12/16/2015	2:00:00 AM	0.42
12/16/2015	2:15:00 AM	0.42
12/16/2015	2:30:00 AM	0.41
12/16/2015	2:45:00 AM	0.4
12/16/2015	3:00:00 AM	0.41
12/16/2015	3:15:00 AM	0.4
12/16/2015	3:30:00 AM	0.4
12/16/2015	3:45:00 AM	0.4
12/16/2015	4:00:00 AM	0.4
12/16/2015	4:15:00 AM	0.4
12/16/2015	4:30:00 AM	0.4
12/16/2015	4:45:00 AM	0.4
12/16/2015	5:00:00 AM	0.4
12/16/2015	5:15:00 AM	0.4
12/16/2015	5:30:00 AM	0.4
12/16/2015	5:45:00 AM	0.4
12/16/2015	6:00:00 AM	0.4
12/16/2015	6:15:00 AM	0.4
12/16/2015	6:30:00 AM	0.4
12/16/2015	6:45:00 AM	0.4
12/16/2015	7:00:00 AM	0.4
12/16/2015	7:15:00 AM	0.4
12/16/2015	7:30:00 AM	0.4
12/16/2015	7:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
12/16/2015	8:00:00 AM	0.4
12/16/2015	8:15:00 AM	0.4
12/16/2015	8:30:00 AM	0.4
12/16/2015	8:45:00 AM	0.4
12/16/2015	9:00:00 AM	0.4
12/16/2015	9:15:00 AM	0.4
12/16/2015	9:30:00 AM	0.4
12/16/2015	9:45:00 AM	0.41
12/16/2015	10:00:00 AM	0.41
12/16/2015	10:15:00 AM	0.42
12/16/2015	10:30:00 AM	0.42
12/16/2015	10:45:00 AM	0.42
12/16/2015	11:00:00 AM	0.42
12/16/2015	11:15:00 AM	0.43
12/16/2015	11:30:00 AM	0.43
12/16/2015	11:45:00 AM	0.43
12/16/2015	12:00:00 PM	0.43
12/16/2015	12:15:00 PM	0.44
12/16/2015	12:30:00 PM	0.44
12/16/2015	12:45:00 PM	0.45
12/16/2015	1:00:00 PM	0.46
12/16/2015	1:15:00 PM	0.45
12/16/2015	1:30:00 PM	0.45
12/16/2015	1:45:00 PM	0.44
12/16/2015	2:00:00 PM	0.44
12/16/2015	2:15:00 PM	0.44
12/16/2015	2:30:00 PM	0.44
12/16/2015	2:45:00 PM	0.44
12/16/2015	3:00:00 PM	0.44
12/16/2015	3:15:00 PM	0.44
12/16/2015	3:30:00 PM	0.43
12/16/2015	3:45:00 PM	0.43
12/16/2015	4:00:00 PM	0.43
12/16/2015	4:15:00 PM	0.43
12/16/2015	4:30:00 PM	0.43
12/16/2015	4:45:00 PM	0.43
12/16/2015	5:00:00 PM	0.43
12/16/2015	5:15:00 PM	0.43
12/16/2015	5:30:00 PM	0.43
12/16/2015	5:45:00 PM	0.43
12/16/2015	6:00:00 PM	0.43
12/16/2015	6:15:00 PM	0.43
12/16/2015	6:30:00 PM	0.43
12/16/2015	6:45:00 PM	0.43
12/16/2015	7:00:00 PM	0.43
12/16/2015	7:15:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
12/16/2015	7:30:00 PM	0.43
12/16/2015	7:45:00 PM	0.43
12/16/2015	8:00:00 PM	0.43
12/16/2015	8:15:00 PM	0.43
12/16/2015	8:30:00 PM	0.43
12/16/2015	8:45:00 PM	0.43
12/16/2015	9:00:00 PM	0.43
12/16/2015	9:15:00 PM	0.43
12/16/2015	9:30:00 PM	0.43
12/16/2015	9:45:00 PM	0.43
12/16/2015	10:00:00 PM	0.43
12/16/2015	10:15:00 PM	0.43
12/16/2015	10:30:00 PM	0.43
12/16/2015	10:45:00 PM	0.43
12/16/2015	11:00:00 PM	0.43
12/16/2015	11:15:00 PM	0.43
12/16/2015	11:30:00 PM	0.43
12/16/2015	11:45:00 PM	0.43
12/17/2015	12:00:00 AM	0.42
12/17/2015	12:15:00 AM	0.42
12/17/2015	12:30:00 AM	0.42
12/17/2015	12:45:00 AM	0.42
12/17/2015	1:00:00 AM	0.42
12/17/2015	1:15:00 AM	0.42
12/17/2015	1:30:00 AM	0.42
12/17/2015	1:45:00 AM	0.42
12/17/2015	2:00:00 AM	0.41
12/17/2015	2:15:00 AM	0.41
12/17/2015	2:30:00 AM	0.41
12/17/2015	2:45:00 AM	0.41
12/17/2015	3:00:00 AM	0.42
12/17/2015	3:15:00 AM	0.41
12/17/2015	3:30:00 AM	0.41
12/17/2015	3:45:00 AM	0.41
12/17/2015	4:00:00 AM	0.41
12/17/2015	4:15:00 AM	0.41
12/17/2015	4:30:00 AM	0.41
12/17/2015	4:45:00 AM	0.42
12/17/2015	5:00:00 AM	0.42
12/17/2015	5:15:00 AM	0.42
12/17/2015	5:30:00 AM	0.42
12/17/2015	5:45:00 AM	0.42
12/17/2015	6:00:00 AM	0.42
12/17/2015	6:15:00 AM	0.42
12/17/2015	6:30:00 AM	0.42
12/17/2015	6:45:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
12/17/2015	7:00:00 AM	0.42
12/17/2015	7:15:00 AM	0.42
12/17/2015	7:30:00 AM	0.42
12/17/2015	7:45:00 AM	0.42
12/17/2015	8:00:00 AM	0.42
12/17/2015	8:15:00 AM	0.43
12/17/2015	8:30:00 AM	0.43
12/17/2015	8:45:00 AM	0.43
12/17/2015	9:00:00 AM	0.44
12/17/2015	9:15:00 AM	0.44
12/17/2015	9:30:00 AM	0.44
12/17/2015	9:45:00 AM	0.44
12/17/2015	10:00:00 AM	0.45
12/17/2015	10:15:00 AM	0.45
12/17/2015	10:30:00 AM	0.46
12/17/2015	10:45:00 AM	0.46
12/17/2015	11:00:00 AM	0.48
12/17/2015	11:15:00 AM	0.54
12/17/2015	11:30:00 AM	0.48
12/17/2015	11:45:00 AM	0.48
12/17/2015	12:00:00 PM	0.48
12/17/2015	12:15:00 PM	0.47
12/17/2015	12:30:00 PM	0.47
12/17/2015	12:45:00 PM	0.46
12/17/2015	1:00:00 PM	0.46
12/17/2015	1:15:00 PM	0.46
12/17/2015	1:30:00 PM	0.46
12/17/2015	1:45:00 PM	0.46
12/17/2015	2:00:00 PM	0.46
12/17/2015	2:15:00 PM	0.46
12/17/2015	2:30:00 PM	0.45
12/17/2015	2:45:00 PM	0.45
12/17/2015	3:00:00 PM	0.44
12/17/2015	3:15:00 PM	0.44
12/17/2015	3:30:00 PM	0.44
12/17/2015	3:45:00 PM	0.44
12/17/2015	4:00:00 PM	0.44
12/17/2015	4:15:00 PM	0.44
12/17/2015	4:30:00 PM	0.44
12/17/2015	4:45:00 PM	0.44
12/17/2015	5:00:00 PM	0.44
12/17/2015	5:15:00 PM	0.44
12/17/2015	5:30:00 PM	0.44
12/17/2015	5:45:00 PM	0.44
12/17/2015	6:00:00 PM	0.44
12/17/2015	6:15:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/17/2015	6:30:00 PM	0.44
12/17/2015	6:45:00 PM	0.44
12/17/2015	7:00:00 PM	0.44
12/17/2015	7:15:00 PM	0.44
12/17/2015	7:30:00 PM	0.44
12/17/2015	7:45:00 PM	0.44
12/17/2015	8:00:00 PM	0.44
12/17/2015	8:15:00 PM	0.44
12/17/2015	8:30:00 PM	0.44
12/17/2015	8:45:00 PM	0.44
12/17/2015	9:00:00 PM	0.44
12/17/2015	9:15:00 PM	0.44
12/17/2015	9:30:00 PM	0.44
12/17/2015	9:45:00 PM	0.44
12/17/2015	10:00:00 PM	0.44
12/17/2015	10:15:00 PM	0.44
12/17/2015	10:30:00 PM	0.44
12/17/2015	10:45:00 PM	0.44
12/17/2015	11:00:00 PM	0.44
12/17/2015	11:15:00 PM	0.44
12/17/2015	11:30:00 PM	0.43
12/17/2015	11:45:00 PM	0.43
12/18/2015	12:00:00 AM	0.43
12/18/2015	12:15:00 AM	0.42
12/18/2015	12:30:00 AM	0.42
12/18/2015	12:45:00 AM	0.42
12/18/2015	1:00:00 AM	0.42
12/18/2015	1:15:00 AM	0.42
12/18/2015	1:30:00 AM	0.42
12/18/2015	1:45:00 AM	0.42
12/18/2015	2:00:00 AM	0.42
12/18/2015	2:15:00 AM	0.42
12/18/2015	2:30:00 AM	0.42
12/18/2015	2:45:00 AM	0.42
12/18/2015	3:00:00 AM	0.42
12/18/2015	3:15:00 AM	0.43
12/18/2015	3:30:00 AM	0.43
12/18/2015	3:45:00 AM	0.43
12/18/2015	4:00:00 AM	0.43
12/18/2015	4:15:00 AM	0.43
12/18/2015	4:30:00 AM	0.43
12/18/2015	4:45:00 AM	0.43
12/18/2015	5:00:00 AM	0.43
12/18/2015	5:15:00 AM	0.43
12/18/2015	5:30:00 AM	0.43
12/18/2015	5:45:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
12/18/2015	6:00:00 AM	0.43
12/18/2015	6:15:00 AM	0.43
12/18/2015	6:30:00 AM	0.43
12/18/2015	6:45:00 AM	0.43
12/18/2015	7:00:00 AM	0.43
12/18/2015	7:15:00 AM	0.43
12/18/2015	7:30:00 AM	0.43
12/18/2015	7:45:00 AM	0.44
12/18/2015	8:00:00 AM	0.44
12/18/2015	8:15:00 AM	0.44
12/18/2015	8:30:00 AM	0.44
12/18/2015	8:45:00 AM	0.44
12/18/2015	9:00:00 AM	0.44
12/18/2015	9:15:00 AM	0.44
12/18/2015	9:30:00 AM	0.45
12/18/2015	9:45:00 AM	0.46
12/18/2015	10:00:00 AM	0.46
12/18/2015	10:15:00 AM	0.47
12/18/2015	10:30:00 AM	0.48
12/18/2015	10:45:00 AM	0.48
12/18/2015	11:00:00 AM	0.49
12/18/2015	11:15:00 AM	0.49
12/18/2015	11:30:00 AM	0.5
12/18/2015	11:45:00 AM	0.5
12/18/2015	12:00:00 PM	0.5
12/18/2015	12:15:00 PM	0.5
12/18/2015	12:30:00 PM	0.5
12/18/2015	12:45:00 PM	0.49
12/18/2015	1:00:00 PM	0.48
12/18/2015	1:15:00 PM	0.48
12/18/2015	1:30:00 PM	0.48
12/18/2015	1:45:00 PM	0.48
12/18/2015	2:00:00 PM	0.48
12/18/2015	2:15:00 PM	0.47
12/18/2015	2:30:00 PM	0.47
12/18/2015	2:45:00 PM	0.47
12/18/2015	3:00:00 PM	0.47
12/18/2015	3:15:00 PM	0.47
12/18/2015	3:30:00 PM	0.47
12/18/2015	3:45:00 PM	0.47
12/18/2015	4:00:00 PM	0.46
12/18/2015	4:15:00 PM	0.46
12/18/2015	4:30:00 PM	0.46
12/18/2015	4:45:00 PM	0.46
12/18/2015	5:00:00 PM	0.46
12/18/2015	5:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/18/2015	5:30:00 PM	0.46
12/18/2015	5:45:00 PM	0.46
12/18/2015	6:00:00 PM	0.46
12/18/2015	6:15:00 PM	0.46
12/18/2015	6:30:00 PM	0.46
12/18/2015	6:45:00 PM	0.46
12/18/2015	7:00:00 PM	0.46
12/18/2015	7:15:00 PM	0.46
12/18/2015	7:30:00 PM	0.46
12/18/2015	7:45:00 PM	0.46
12/18/2015	8:00:00 PM	0.46
12/18/2015	8:15:00 PM	0.46
12/18/2015	8:30:00 PM	0.46
12/18/2015	8:45:00 PM	0.46
12/18/2015	9:00:00 PM	0.46
12/18/2015	9:15:00 PM	0.46
12/18/2015	9:30:00 PM	0.46
12/18/2015	9:45:00 PM	0.46
12/18/2015	10:00:00 PM	0.46
12/18/2015	10:15:00 PM	0.46
12/18/2015	10:30:00 PM	0.46
12/18/2015	10:45:00 PM	0.46
12/18/2015	11:00:00 PM	0.46
12/18/2015	11:15:00 PM	0.46
12/18/2015	11:30:00 PM	0.46
12/18/2015	11:45:00 PM	0.46
12/19/2015	12:00:00 AM	0.46
12/19/2015	12:15:00 AM	0.46
12/19/2015	12:30:00 AM	0.44
12/19/2015	12:45:00 AM	0.44
12/19/2015	1:00:00 AM	0.44
12/19/2015	1:15:00 AM	0.44
12/19/2015	1:30:00 AM	0.44
12/19/2015	1:45:00 AM	0.44
12/19/2015	2:00:00 AM	0.44
12/19/2015	2:15:00 AM	0.44
12/19/2015	2:30:00 AM	0.44
12/19/2015	2:45:00 AM	0.44
12/19/2015	3:00:00 AM	0.44
12/19/2015	3:15:00 AM	0.44
12/19/2015	3:30:00 AM	0.44
12/19/2015	3:45:00 AM	0.44
12/19/2015	4:00:00 AM	0.44
12/19/2015	4:15:00 AM	0.44
12/19/2015	4:30:00 AM	0.44
12/19/2015	4:45:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/19/2015	5:00:00 AM	0.44
12/19/2015	5:15:00 AM	0.44
12/19/2015	5:30:00 AM	0.44
12/19/2015	5:45:00 AM	0.44
12/19/2015	6:00:00 AM	0.44
12/19/2015	6:15:00 AM	0.44
12/19/2015	6:30:00 AM	0.44
12/19/2015	6:45:00 AM	0.45
12/19/2015	7:00:00 AM	0.45
12/19/2015	7:15:00 AM	0.45
12/19/2015	7:30:00 AM	0.45
12/19/2015	7:45:00 AM	0.45
12/19/2015	8:00:00 AM	0.45
12/19/2015	8:15:00 AM	0.45
12/19/2015	8:30:00 AM	0.45
12/19/2015	8:45:00 AM	0.46
12/19/2015	9:00:00 AM	0.46
12/19/2015	9:15:00 AM	0.46
12/19/2015	9:30:00 AM	0.47
12/19/2015	9:45:00 AM	0.48
12/19/2015	10:00:00 AM	0.49
12/19/2015	10:15:00 AM	0.5
12/19/2015	10:30:00 AM	0.5
12/19/2015	10:45:00 AM	0.51
12/19/2015	11:00:00 AM	0.52
12/19/2015	11:15:00 AM	0.52
12/19/2015	11:30:00 AM	0.52
12/19/2015	11:45:00 AM	0.52
12/19/2015	12:00:00 PM	0.52
12/19/2015	12:15:00 PM	0.51
12/19/2015	12:30:00 PM	0.5
12/19/2015	12:45:00 PM	0.5
12/19/2015	1:00:00 PM	0.49
12/19/2015	1:15:00 PM	0.48
12/19/2015	1:30:00 PM	0.48
12/19/2015	1:45:00 PM	0.48
12/19/2015	2:00:00 PM	0.48
12/19/2015	2:15:00 PM	0.48
12/19/2015	2:30:00 PM	0.48
12/19/2015	2:45:00 PM	0.48
12/19/2015	3:00:00 PM	0.48
12/19/2015	3:15:00 PM	0.48
12/19/2015	3:30:00 PM	0.47
12/19/2015	3:45:00 PM	0.47
12/19/2015	4:00:00 PM	0.47
12/19/2015	4:15:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/19/2015	4:30:00 PM	0.47
12/19/2015	4:45:00 PM	0.47
12/19/2015	5:00:00 PM	0.47
12/19/2015	5:15:00 PM	0.47
12/19/2015	5:30:00 PM	0.47
12/19/2015	5:45:00 PM	0.47
12/19/2015	6:00:00 PM	0.47
12/19/2015	6:15:00 PM	0.46
12/19/2015	6:30:00 PM	0.46
12/19/2015	6:45:00 PM	0.47
12/19/2015	7:00:00 PM	0.47
12/19/2015	7:15:00 PM	0.47
12/19/2015	7:30:00 PM	0.46
12/19/2015	7:45:00 PM	0.46
12/19/2015	8:00:00 PM	0.46
12/19/2015	8:15:00 PM	0.46
12/19/2015	8:30:00 PM	0.46
12/19/2015	8:45:00 PM	0.46
12/19/2015	9:00:00 PM	0.46
12/19/2015	9:15:00 PM	0.46
12/19/2015	9:30:00 PM	0.46
12/19/2015	9:45:00 PM	0.46
12/19/2015	10:00:00 PM	0.46
12/19/2015	10:15:00 PM	0.46
12/19/2015	10:30:00 PM	0.46
12/19/2015	10:45:00 PM	0.47
12/19/2015	11:00:00 PM	0.46
12/19/2015	11:15:00 PM	0.47
12/19/2015	11:30:00 PM	0.46
12/19/2015	11:45:00 PM	0.46
12/20/2015	12:00:00 AM	0.46
12/20/2015	12:15:00 AM	0.46
12/20/2015	12:30:00 AM	0.46
12/20/2015	12:45:00 AM	0.47
12/20/2015	1:00:00 AM	0.47
12/20/2015	1:15:00 AM	0.47
12/20/2015	1:30:00 AM	0.46
12/20/2015	1:45:00 AM	0.47
12/20/2015	2:00:00 AM	0.47
12/20/2015	2:15:00 AM	0.47
12/20/2015	2:30:00 AM	0.47
12/20/2015	2:45:00 AM	0.47
12/20/2015	3:00:00 AM	0.47
12/20/2015	3:15:00 AM	0.47
12/20/2015	3:30:00 AM	0.47
12/20/2015	3:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/20/2015	4:00:00 AM	0.47
12/20/2015	4:15:00 AM	0.47
12/20/2015	4:30:00 AM	0.47
12/20/2015	4:45:00 AM	0.47
12/20/2015	5:00:00 AM	0.46
12/20/2015	5:15:00 AM	0.46
12/20/2015	5:30:00 AM	0.46
12/20/2015	5:45:00 AM	0.46
12/20/2015	6:00:00 AM	0.46
12/20/2015	6:15:00 AM	0.46
12/20/2015	6:30:00 AM	0.46
12/20/2015	6:45:00 AM	0.46
12/20/2015	7:00:00 AM	0.46
12/20/2015	7:15:00 AM	0.46
12/20/2015	7:30:00 AM	0.46
12/20/2015	7:45:00 AM	0.46
12/20/2015	8:00:00 AM	0.46
12/20/2015	8:15:00 AM	0.46
12/20/2015	8:30:00 AM	0.47
12/20/2015	8:45:00 AM	0.47
12/20/2015	9:00:00 AM	0.48
12/20/2015	9:15:00 AM	0.48
12/20/2015	9:30:00 AM	0.5
12/20/2015	9:45:00 AM	0.5
12/20/2015	10:00:00 AM	0.5
12/20/2015	10:15:00 AM	0.51
12/20/2015	10:30:00 AM	0.5
12/20/2015	10:45:00 AM	0.5
12/20/2015	11:00:00 AM	0.49
12/20/2015	11:15:00 AM	0.48
12/20/2015	11:30:00 AM	0.48
12/20/2015	11:45:00 AM	0.48
12/20/2015	12:00:00 PM	0.48
12/20/2015	12:15:00 PM	0.48
12/20/2015	12:30:00 PM	0.48
12/20/2015	12:45:00 PM	0.48
12/20/2015	1:00:00 PM	0.48
12/20/2015	1:15:00 PM	0.48
12/20/2015	1:30:00 PM	0.48
12/20/2015	1:45:00 PM	0.47
12/20/2015	2:00:00 PM	0.47
12/20/2015	2:15:00 PM	0.47
12/20/2015	2:30:00 PM	0.47
12/20/2015	2:45:00 PM	0.47
12/20/2015	3:00:00 PM	0.47
12/20/2015	3:15:00 PM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/20/2015	3:30:00 PM	0.47
12/20/2015	3:45:00 PM	0.47
12/20/2015	4:00:00 PM	0.47
12/20/2015	4:15:00 PM	0.47
12/20/2015	4:30:00 PM	0.47
12/20/2015	4:45:00 PM	0.47
12/20/2015	5:00:00 PM	0.47
12/20/2015	5:15:00 PM	0.47
12/20/2015	5:30:00 PM	0.47
12/20/2015	5:45:00 PM	0.47
12/20/2015	6:00:00 PM	0.47
12/20/2015	6:15:00 PM	0.47
12/20/2015	6:30:00 PM	0.47
12/20/2015	6:45:00 PM	0.47
12/20/2015	7:00:00 PM	0.47
12/20/2015	7:15:00 PM	0.47
12/20/2015	7:30:00 PM	0.47
12/20/2015	7:45:00 PM	0.47
12/20/2015	8:00:00 PM	0.47
12/20/2015	8:15:00 PM	0.47
12/20/2015	8:30:00 PM	0.47
12/20/2015	8:45:00 PM	0.47
12/20/2015	9:00:00 PM	0.47
12/20/2015	9:15:00 PM	0.47
12/20/2015	9:30:00 PM	0.47
12/20/2015	9:45:00 PM	0.47
12/20/2015	10:00:00 PM	0.47
12/20/2015	10:15:00 PM	0.47
12/20/2015	10:30:00 PM	0.47
12/20/2015	10:45:00 PM	0.47
12/20/2015	11:00:00 PM	0.47
12/20/2015	11:15:00 PM	0.47
12/20/2015	11:30:00 PM	0.47
12/20/2015	11:45:00 PM	0.47
12/21/2015	12:00:00 AM	0.47
12/21/2015	12:15:00 AM	0.47
12/21/2015	12:30:00 AM	0.47
12/21/2015	12:45:00 AM	0.47
12/21/2015	1:00:00 AM	0.47
12/21/2015	1:15:00 AM	0.47
12/21/2015	1:30:00 AM	0.47
12/21/2015	1:45:00 AM	0.47
12/21/2015	2:00:00 AM	0.48
12/21/2015	2:15:00 AM	0.48
12/21/2015	2:30:00 AM	0.48
12/21/2015	2:45:00 AM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/21/2015	3:00:00 AM	0.48
12/21/2015	3:15:00 AM	0.48
12/21/2015	3:30:00 AM	0.48
12/21/2015	3:45:00 AM	0.48
12/21/2015	4:00:00 AM	0.47
12/21/2015	4:15:00 AM	0.48
12/21/2015	4:30:00 AM	0.48
12/21/2015	4:45:00 AM	0.48
12/21/2015	5:00:00 AM	0.48
12/21/2015	5:15:00 AM	0.48
12/21/2015	5:30:00 AM	0.47
12/21/2015	5:45:00 AM	0.47
12/21/2015	6:00:00 AM	0.47
12/21/2015	6:15:00 AM	0.47
12/21/2015	6:30:00 AM	0.47
12/21/2015	6:45:00 AM	0.46
12/21/2015	7:00:00 AM	0.46
12/21/2015	7:15:00 AM	0.46
12/21/2015	7:30:00 AM	0.46
12/21/2015	7:45:00 AM	0.47
12/21/2015	8:00:00 AM	0.47
12/21/2015	8:15:00 AM	0.48
12/21/2015	8:30:00 AM	0.48
12/21/2015	8:45:00 AM	0.48
12/21/2015	9:00:00 AM	0.49
12/21/2015	9:15:00 AM	0.49
12/21/2015	9:30:00 AM	0.5
12/21/2015	9:45:00 AM	0.5
12/21/2015	10:00:00 AM	0.5
12/21/2015	10:15:00 AM	0.48
12/21/2015	10:30:00 AM	0.48
12/21/2015	10:45:00 AM	0.48
12/21/2015	11:00:00 AM	0.48
12/21/2015	11:15:00 AM	0.48
12/21/2015	11:30:00 AM	0.48
12/21/2015	11:45:00 AM	0.48
12/21/2015	12:00:00 PM	0.48
12/21/2015	12:15:00 PM	0.48
12/21/2015	12:30:00 PM	0.48
12/21/2015	12:45:00 PM	0.48
12/21/2015	1:00:00 PM	0.48
12/21/2015	1:15:00 PM	0.48
12/21/2015	1:30:00 PM	0.48
12/21/2015	1:45:00 PM	0.48
12/21/2015	2:00:00 PM	0.48
12/21/2015	2:15:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/21/2015	2:30:00 PM	0.48
12/21/2015	2:45:00 PM	0.48
12/21/2015	3:00:00 PM	0.48
12/21/2015	3:15:00 PM	0.48
12/21/2015	3:30:00 PM	0.48
12/21/2015	3:45:00 PM	0.48
12/21/2015	4:00:00 PM	0.48
12/21/2015	4:15:00 PM	0.48
12/21/2015	4:30:00 PM	0.48
12/21/2015	4:45:00 PM	0.48
12/21/2015	5:00:00 PM	0.48
12/21/2015	5:15:00 PM	0.48
12/21/2015	5:30:00 PM	0.48
12/21/2015	5:45:00 PM	0.48
12/21/2015	6:00:00 PM	0.48
12/21/2015	6:15:00 PM	0.48
12/21/2015	6:30:00 PM	0.48
12/21/2015	6:45:00 PM	0.48
12/21/2015	7:00:00 PM	0.48
12/21/2015	7:15:00 PM	0.48
12/21/2015	7:30:00 PM	0.48
12/21/2015	7:45:00 PM	0.48
12/21/2015	8:00:00 PM	0.47
12/21/2015	8:15:00 PM	0.47
12/21/2015	8:30:00 PM	0.48
12/21/2015	8:45:00 PM	0.48
12/21/2015	9:00:00 PM	0.48
12/21/2015	9:15:00 PM	0.48
12/21/2015	9:30:00 PM	0.48
12/21/2015	9:45:00 PM	0.48
12/21/2015	10:00:00 PM	0.48
12/21/2015	10:15:00 PM	0.48
12/21/2015	10:30:00 PM	0.48
12/21/2015	10:45:00 PM	0.48
12/21/2015	11:00:00 PM	0.48
12/21/2015	11:15:00 PM	0.48
12/21/2015	11:30:00 PM	0.48
12/21/2015	11:45:00 PM	0.47
12/22/2015	12:00:00 AM	0.47
12/22/2015	12:15:00 AM	0.47
12/22/2015	12:30:00 AM	0.47
12/22/2015	12:45:00 AM	0.47
12/22/2015	1:00:00 AM	0.47
12/22/2015	1:15:00 AM	0.47
12/22/2015	1:30:00 AM	0.47
12/22/2015	1:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/22/2015	2:00:00 AM	0.47
12/22/2015	2:15:00 AM	0.47
12/22/2015	2:30:00 AM	0.47
12/22/2015	2:45:00 AM	0.47
12/22/2015	3:00:00 AM	0.47
12/22/2015	3:15:00 AM	0.47
12/22/2015	3:30:00 AM	0.47
12/22/2015	3:45:00 AM	0.48
12/22/2015	4:00:00 AM	0.47
12/22/2015	4:15:00 AM	0.48
12/22/2015	4:30:00 AM	0.48
12/22/2015	4:45:00 AM	0.48
12/22/2015	5:00:00 AM	0.47
12/22/2015	5:15:00 AM	0.47
12/22/2015	5:30:00 AM	0.48
12/22/2015	5:45:00 AM	0.47
12/22/2015	6:00:00 AM	0.48
12/22/2015	6:15:00 AM	0.48
12/22/2015	6:30:00 AM	0.48
12/22/2015	6:45:00 AM	0.48
12/22/2015	7:00:00 AM	0.48
12/22/2015	7:15:00 AM	0.47
12/22/2015	7:30:00 AM	0.48
12/22/2015	7:45:00 AM	0.48
12/22/2015	8:00:00 AM	0.48
12/22/2015	8:15:00 AM	0.48
12/22/2015	8:30:00 AM	0.48
12/22/2015	8:45:00 AM	0.48
12/22/2015	9:00:00 AM	0.48
12/22/2015	9:15:00 AM	0.48
12/22/2015	9:30:00 AM	0.48
12/22/2015	9:45:00 AM	0.48
12/22/2015	10:00:00 AM	0.48
12/22/2015	10:15:00 AM	0.48
12/22/2015	10:30:00 AM	0.48
12/22/2015	10:45:00 AM	0.48
12/22/2015	11:00:00 AM	0.48
12/22/2015	11:15:00 AM	0.48
12/22/2015	11:30:00 AM	0.48
12/22/2015	11:45:00 AM	0.48
12/22/2015	12:00:00 PM	0.48
12/22/2015	12:15:00 PM	0.48
12/22/2015	12:30:00 PM	0.48
12/22/2015	12:45:00 PM	0.48
12/22/2015	1:00:00 PM	0.48
12/22/2015	1:15:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/22/2015	1:30:00 PM	0.48
12/22/2015	1:45:00 PM	0.48
12/22/2015	2:00:00 PM	0.48
12/22/2015	2:15:00 PM	0.48
12/22/2015	2:30:00 PM	0.48
12/22/2015	2:45:00 PM	0.48
12/22/2015	3:00:00 PM	0.48
12/22/2015	3:15:00 PM	0.48
12/22/2015	3:30:00 PM	0.48
12/22/2015	3:45:00 PM	0.48
12/22/2015	4:00:00 PM	0.48
12/22/2015	4:15:00 PM	0.48
12/22/2015	4:30:00 PM	0.48
12/22/2015	4:45:00 PM	0.48
12/22/2015	5:00:00 PM	0.48
12/22/2015	5:15:00 PM	0.48
12/22/2015	5:30:00 PM	0.48
12/22/2015	5:45:00 PM	0.48
12/22/2015	6:00:00 PM	0.47
12/22/2015	6:15:00 PM	0.47
12/22/2015	6:30:00 PM	0.47
12/22/2015	6:45:00 PM	0.47
12/22/2015	7:00:00 PM	0.47
12/22/2015	7:15:00 PM	0.47
12/22/2015	7:30:00 PM	0.47
12/22/2015	7:45:00 PM	0.47
12/22/2015	8:00:00 PM	0.47
12/22/2015	8:15:00 PM	0.47
12/22/2015	8:30:00 PM	0.47
12/22/2015	8:45:00 PM	0.47
12/22/2015	9:00:00 PM	0.47
12/22/2015	9:15:00 PM	0.47
12/22/2015	9:30:00 PM	0.47
12/22/2015	9:45:00 PM	0.47
12/22/2015	10:00:00 PM	0.47
12/22/2015	10:15:00 PM	0.47
12/22/2015	10:30:00 PM	0.47
12/22/2015	10:45:00 PM	0.47
12/22/2015	11:00:00 PM	0.47
12/22/2015	11:15:00 PM	0.47
12/22/2015	11:30:00 PM	0.47
12/22/2015	11:45:00 PM	0.47
12/23/2015	12:00:00 AM	0.47
12/23/2015	12:15:00 AM	0.47
12/23/2015	12:30:00 AM	0.47
12/23/2015	12:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
12/23/2015	1:00:00 AM	0.47
12/23/2015	1:15:00 AM	0.47
12/23/2015	1:30:00 AM	0.47
12/23/2015	1:45:00 AM	0.47
12/23/2015	2:00:00 AM	0.47
12/23/2015	2:15:00 AM	0.47
12/23/2015	2:30:00 AM	0.47
12/23/2015	2:45:00 AM	0.47
12/23/2015	3:00:00 AM	0.47
12/23/2015	3:15:00 AM	0.47
12/23/2015	3:30:00 AM	0.47
12/23/2015	3:45:00 AM	0.47
12/23/2015	4:00:00 AM	0.47
12/23/2015	4:15:00 AM	0.47
12/23/2015	4:30:00 AM	0.47
12/23/2015	4:45:00 AM	0.47
12/23/2015	5:00:00 AM	0.47
12/23/2015	5:15:00 AM	0.47
12/23/2015	5:30:00 AM	0.47
12/23/2015	5:45:00 AM	0.47
12/23/2015	6:00:00 AM	0.47
12/23/2015	6:15:00 AM	0.47
12/23/2015	6:30:00 AM	0.47
12/23/2015	6:45:00 AM	0.47
12/23/2015	7:00:00 AM	0.48
12/23/2015	7:15:00 AM	0.48
12/23/2015	7:30:00 AM	0.48
12/23/2015	7:45:00 AM	0.48
12/23/2015	8:00:00 AM	0.48
12/23/2015	8:15:00 AM	0.48
12/23/2015	8:30:00 AM	0.48
12/23/2015	8:45:00 AM	0.48
12/23/2015	9:00:00 AM	0.48
12/23/2015	9:15:00 AM	0.48
12/23/2015	9:30:00 AM	0.48
12/23/2015	9:45:00 AM	0.48
12/23/2015	10:00:00 AM	0.48
12/23/2015	10:15:00 AM	0.48
12/23/2015	10:30:00 AM	0.48
12/23/2015	10:45:00 AM	0.48
12/23/2015	11:00:00 AM	0.48
12/23/2015	11:15:00 AM	0.48
12/23/2015	11:30:00 AM	0.48
12/23/2015	11:45:00 AM	0.48
12/23/2015	12:00:00 PM	0.48
12/23/2015	12:15:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/23/2015	12:30:00 PM	0.48
12/23/2015	12:45:00 PM	0.48
12/23/2015	1:00:00 PM	0.48
12/23/2015	1:15:00 PM	0.48
12/23/2015	1:30:00 PM	0.48
12/23/2015	1:45:00 PM	0.48
12/23/2015	2:00:00 PM	0.48
12/23/2015	2:15:00 PM	0.48
12/23/2015	2:30:00 PM	0.48
12/23/2015	2:45:00 PM	0.48
12/23/2015	3:00:00 PM	0.48
12/23/2015	3:15:00 PM	0.48
12/23/2015	3:30:00 PM	0.48
12/23/2015	3:45:00 PM	0.48
12/23/2015	4:00:00 PM	0.48
12/23/2015	4:15:00 PM	0.48
12/23/2015	4:30:00 PM	0.48
12/23/2015	4:45:00 PM	0.48
12/23/2015	5:00:00 PM	0.48
12/23/2015	5:15:00 PM	0.48
12/23/2015	5:30:00 PM	0.48
12/23/2015	5:45:00 PM	0.48
12/23/2015	6:00:00 PM	0.48
12/23/2015	6:15:00 PM	0.48
12/23/2015	6:30:00 PM	0.48
12/23/2015	6:45:00 PM	0.48
12/23/2015	7:00:00 PM	0.48
12/23/2015	7:15:00 PM	0.48
12/23/2015	7:30:00 PM	0.48
12/23/2015	7:45:00 PM	0.48
12/23/2015	8:00:00 PM	0.48
12/23/2015	8:15:00 PM	0.48
12/23/2015	8:30:00 PM	0.48
12/23/2015	8:45:00 PM	0.48
12/23/2015	9:00:00 PM	0.48
12/23/2015	9:15:00 PM	0.48
12/23/2015	9:30:00 PM	0.48
12/23/2015	9:45:00 PM	0.48
12/23/2015	10:00:00 PM	0.48
12/23/2015	10:15:00 PM	0.48
12/23/2015	10:30:00 PM	0.48
12/23/2015	10:45:00 PM	0.48
12/23/2015	11:00:00 PM	0.48
12/23/2015	11:15:00 PM	0.48
12/23/2015	11:30:00 PM	0.48
12/23/2015	11:45:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/24/2015	12:00:00 AM	0.48
12/24/2015	12:15:00 AM	0.48
12/24/2015	12:30:00 AM	0.48
12/24/2015	12:45:00 AM	0.48
12/24/2015	1:00:00 AM	0.48
12/24/2015	1:15:00 AM	0.48
12/24/2015	1:30:00 AM	0.48
12/24/2015	1:45:00 AM	0.48
12/24/2015	2:00:00 AM	0.48
12/24/2015	2:15:00 AM	0.48
12/24/2015	2:30:00 AM	0.48
12/24/2015	2:45:00 AM	0.48
12/24/2015	3:00:00 AM	0.48
12/24/2015	3:15:00 AM	0.48
12/24/2015	3:30:00 AM	0.48
12/24/2015	3:45:00 AM	0.48
12/24/2015	4:00:00 AM	0.48
12/24/2015	4:15:00 AM	0.48
12/24/2015	4:30:00 AM	0.48
12/24/2015	4:45:00 AM	0.48
12/24/2015	5:00:00 AM	0.48
12/24/2015	5:15:00 AM	0.48
12/24/2015	5:30:00 AM	0.48
12/24/2015	5:45:00 AM	0.48
12/24/2015	6:00:00 AM	0.48
12/24/2015	6:15:00 AM	0.48
12/24/2015	6:30:00 AM	0.48
12/24/2015	6:45:00 AM	0.48
12/24/2015	7:00:00 AM	0.48
12/24/2015	7:15:00 AM	0.48
12/24/2015	7:30:00 AM	0.48
12/24/2015	7:45:00 AM	0.48
12/24/2015	8:00:00 AM	0.48
12/24/2015	8:15:00 AM	0.48
12/24/2015	8:30:00 AM	0.48
12/24/2015	8:45:00 AM	0.48
12/24/2015	9:00:00 AM	0.48
12/24/2015	9:15:00 AM	0.48
12/24/2015	9:30:00 AM	0.48
12/24/2015	9:45:00 AM	0.48
12/24/2015	10:00:00 AM	0.48
12/24/2015	10:15:00 AM	0.48
12/24/2015	10:30:00 AM	0.48
12/24/2015	10:45:00 AM	0.48
12/24/2015	11:00:00 AM	0.48
12/24/2015	11:15:00 AM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/24/2015	11:30:00 AM	0.48
12/24/2015	11:45:00 AM	0.48
12/24/2015	12:00:00 PM	0.48
12/24/2015	12:15:00 PM	0.48
12/24/2015	12:30:00 PM	0.48
12/24/2015	12:45:00 PM	0.48
12/24/2015	1:00:00 PM	0.48
12/24/2015	1:15:00 PM	0.48
12/24/2015	1:30:00 PM	0.48
12/24/2015	1:45:00 PM	0.48
12/24/2015	2:00:00 PM	0.48
12/24/2015	2:15:00 PM	0.48
12/24/2015	2:30:00 PM	0.48
12/24/2015	2:45:00 PM	0.48
12/24/2015	3:00:00 PM	0.48
12/24/2015	3:15:00 PM	0.48
12/24/2015	3:30:00 PM	0.48
12/24/2015	3:45:00 PM	0.48
12/24/2015	4:00:00 PM	0.48
12/24/2015	4:15:00 PM	0.48
12/24/2015	4:30:00 PM	0.48
12/24/2015	4:45:00 PM	0.48
12/24/2015	5:00:00 PM	0.48
12/24/2015	5:15:00 PM	0.48
12/24/2015	5:30:00 PM	0.48
12/24/2015	5:45:00 PM	0.48
12/24/2015	6:00:00 PM	0.48
12/24/2015	6:15:00 PM	0.48
12/24/2015	6:30:00 PM	0.48
12/24/2015	6:45:00 PM	0.48
12/24/2015	7:00:00 PM	0.48
12/24/2015	7:15:00 PM	0.48
12/24/2015	7:30:00 PM	0.48
12/24/2015	7:45:00 PM	0.48
12/24/2015	8:00:00 PM	0.48
12/24/2015	8:15:00 PM	0.48
12/24/2015	8:30:00 PM	0.48
12/24/2015	8:45:00 PM	0.48
12/24/2015	9:00:00 PM	0.48
12/24/2015	9:15:00 PM	0.48
12/24/2015	9:30:00 PM	0.48
12/24/2015	9:45:00 PM	0.48
12/24/2015	10:00:00 PM	0.48
12/24/2015	10:15:00 PM	0.48
12/24/2015	10:30:00 PM	0.48
12/24/2015	10:45:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/24/2015	11:00:00 PM	0.48
12/24/2015	11:15:00 PM	0.48
12/24/2015	11:30:00 PM	0.48
12/24/2015	11:45:00 PM	0.48
12/25/2015	12:00:00 AM	0.48
12/25/2015	12:15:00 AM	0.48
12/25/2015	12:30:00 AM	0.48
12/25/2015	12:45:00 AM	0.48
12/25/2015	1:00:00 AM	0.48
12/25/2015	1:15:00 AM	0.48
12/25/2015	1:30:00 AM	0.48
12/25/2015	1:45:00 AM	0.48
12/25/2015	2:00:00 AM	0.48
12/25/2015	2:15:00 AM	0.48
12/25/2015	2:30:00 AM	0.48
12/25/2015	2:45:00 AM	0.48
12/25/2015	3:00:00 AM	0.48
12/25/2015	3:15:00 AM	0.48
12/25/2015	3:30:00 AM	0.48
12/25/2015	3:45:00 AM	0.48
12/25/2015	4:00:00 AM	0.48
12/25/2015	4:15:00 AM	0.48
12/25/2015	4:30:00 AM	0.48
12/25/2015	4:45:00 AM	0.48
12/25/2015	5:00:00 AM	0.48
12/25/2015	5:15:00 AM	0.48
12/25/2015	5:30:00 AM	0.48
12/25/2015	5:45:00 AM	0.48
12/25/2015	6:00:00 AM	0.48
12/25/2015	6:15:00 AM	0.48
12/25/2015	6:30:00 AM	0.48
12/25/2015	6:45:00 AM	0.48
12/25/2015	7:00:00 AM	0.48
12/25/2015	7:15:00 AM	0.48
12/25/2015	7:30:00 AM	0.48
12/25/2015	7:45:00 AM	0.48
12/25/2015	8:00:00 AM	0.47
12/25/2015	8:15:00 AM	0.48
12/25/2015	8:30:00 AM	0.48
12/25/2015	8:45:00 AM	0.48
12/25/2015	9:00:00 AM	0.49
12/25/2015	9:15:00 AM	0.48
12/25/2015	9:30:00 AM	0.48
12/25/2015	9:45:00 AM	0.48
12/25/2015	10:00:00 AM	0.48
12/25/2015	10:15:00 AM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/25/2015	10:30:00 AM	0.48
12/25/2015	10:45:00 AM	0.48
12/25/2015	11:00:00 AM	0.48
12/25/2015	11:15:00 AM	0.48
12/25/2015	11:30:00 AM	0.48
12/25/2015	11:45:00 AM	0.48
12/25/2015	12:00:00 PM	0.48
12/25/2015	12:15:00 PM	0.48
12/25/2015	12:30:00 PM	0.48
12/25/2015	12:45:00 PM	0.48
12/25/2015	1:00:00 PM	0.48
12/25/2015	1:15:00 PM	0.48
12/25/2015	1:30:00 PM	0.48
12/25/2015	1:45:00 PM	0.48
12/25/2015	2:00:00 PM	0.48
12/25/2015	2:15:00 PM	0.48
12/25/2015	2:30:00 PM	0.48
12/25/2015	2:45:00 PM	0.48
12/25/2015	3:00:00 PM	0.48
12/25/2015	3:15:00 PM	0.48
12/25/2015	3:30:00 PM	0.48
12/25/2015	3:45:00 PM	0.48
12/25/2015	4:00:00 PM	0.48
12/25/2015	4:15:00 PM	0.48
12/25/2015	4:30:00 PM	0.48
12/25/2015	4:45:00 PM	0.48
12/25/2015	5:00:00 PM	0.48
12/25/2015	5:15:00 PM	0.48
12/25/2015	5:30:00 PM	0.48
12/25/2015	5:45:00 PM	0.48
12/25/2015	6:00:00 PM	0.48
12/25/2015	6:15:00 PM	0.48
12/25/2015	6:30:00 PM	0.48
12/25/2015	6:45:00 PM	0.48
12/25/2015	7:00:00 PM	0.48
12/25/2015	7:15:00 PM	0.48
12/25/2015	7:30:00 PM	0.48
12/25/2015	7:45:00 PM	0.48
12/25/2015	8:00:00 PM	0.48
12/25/2015	8:15:00 PM	0.48
12/25/2015	8:30:00 PM	0.48
12/25/2015	8:45:00 PM	0.48
12/25/2015	9:00:00 PM	0.48
12/25/2015	9:15:00 PM	0.48
12/25/2015	9:30:00 PM	0.48
12/25/2015	9:45:00 PM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
12/25/2015	10:00:00 PM	0.48
12/25/2015	10:15:00 PM	0.48
12/25/2015	10:30:00 PM	0.48
12/25/2015	10:45:00 PM	0.48
12/25/2015	11:00:00 PM	0.48
12/25/2015	11:15:00 PM	0.48
12/25/2015	11:30:00 PM	0.48
12/25/2015	11:45:00 PM	0.48
12/26/2015	12:00:00 AM	0.48
12/26/2015	12:15:00 AM	0.47
12/26/2015	12:30:00 AM	0.46
12/26/2015	12:45:00 AM	0.46
12/26/2015	1:00:00 AM	0.45
12/26/2015	1:15:00 AM	0.44
12/26/2015	1:30:00 AM	0.44
12/26/2015	1:45:00 AM	0.44
12/26/2015	2:00:00 AM	0.43
12/26/2015	2:15:00 AM	0.43
12/26/2015	2:30:00 AM	0.42
12/26/2015	2:45:00 AM	0.42
12/26/2015	3:00:00 AM	0.42
12/26/2015	3:15:00 AM	0.42
12/26/2015	3:30:00 AM	0.42
12/26/2015	3:45:00 AM	0.42
12/26/2015	4:00:00 AM	0.42
12/26/2015	4:15:00 AM	0.43
12/26/2015	4:30:00 AM	0.43
12/26/2015	4:45:00 AM	0.43
12/26/2015	5:00:00 AM	0.43
12/26/2015	5:15:00 AM	0.43
12/26/2015	5:30:00 AM	0.44
12/26/2015	5:45:00 AM	0.44
12/26/2015	6:00:00 AM	0.44
12/26/2015	6:15:00 AM	0.44
12/26/2015	6:30:00 AM	0.44
12/26/2015	6:45:00 AM	0.44
12/26/2015	7:00:00 AM	0.44
12/26/2015	7:15:00 AM	0.44
12/26/2015	7:30:00 AM	0.44
12/26/2015	7:45:00 AM	0.44
12/26/2015	8:00:00 AM	0.44
12/26/2015	8:15:00 AM	0.44
12/26/2015	8:30:00 AM	0.45
12/26/2015	8:45:00 AM	0.46
12/26/2015	9:00:00 AM	0.46
12/26/2015	9:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/26/2015	9:30:00 AM	0.46
12/26/2015	9:45:00 AM	0.48
12/26/2015	10:00:00 AM	0.48
12/26/2015	10:15:00 AM	0.49
12/26/2015	10:30:00 AM	0.5
12/26/2015	10:45:00 AM	0.52
12/26/2015	11:00:00 AM	0.52
12/26/2015	11:15:00 AM	0.54
12/26/2015	11:30:00 AM	0.54
12/26/2015	11:45:00 AM	0.54
12/26/2015	12:00:00 PM	0.52
12/26/2015	12:15:00 PM	0.5
12/26/2015	12:30:00 PM	0.48
12/26/2015	12:45:00 PM	0.48
12/26/2015	1:00:00 PM	0.48
12/26/2015	1:15:00 PM	0.48
12/26/2015	1:30:00 PM	0.48
12/26/2015	1:45:00 PM	0.48
12/26/2015	2:00:00 PM	0.48
12/26/2015	2:15:00 PM	0.48
12/26/2015	2:30:00 PM	0.47
12/26/2015	2:45:00 PM	0.47
12/26/2015	3:00:00 PM	0.47
12/26/2015	3:15:00 PM	0.47
12/26/2015	3:30:00 PM	0.47
12/26/2015	3:45:00 PM	0.48
12/26/2015	4:00:00 PM	0.47
12/26/2015	4:15:00 PM	0.47
12/26/2015	4:30:00 PM	0.47
12/26/2015	4:45:00 PM	0.47
12/26/2015	5:00:00 PM	0.47
12/26/2015	5:15:00 PM	0.47
12/26/2015	5:30:00 PM	0.47
12/26/2015	5:45:00 PM	0.47
12/26/2015	6:00:00 PM	0.47
12/26/2015	6:15:00 PM	0.47
12/26/2015	6:30:00 PM	0.47
12/26/2015	6:45:00 PM	0.47
12/26/2015	7:00:00 PM	0.47
12/26/2015	7:15:00 PM	0.47
12/26/2015	7:30:00 PM	0.47
12/26/2015	7:45:00 PM	0.47
12/26/2015	8:00:00 PM	0.47
12/26/2015	8:15:00 PM	0.47
12/26/2015	8:30:00 PM	0.47
12/26/2015	8:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/26/2015	9:00:00 PM	0.47
12/26/2015	9:15:00 PM	0.47
12/26/2015	9:30:00 PM	0.47
12/26/2015	9:45:00 PM	0.47
12/26/2015	10:00:00 PM	0.47
12/26/2015	10:15:00 PM	0.47
12/26/2015	10:30:00 PM	0.46
12/26/2015	10:45:00 PM	0.47
12/26/2015	11:00:00 PM	0.47
12/26/2015	11:15:00 PM	0.47
12/26/2015	11:30:00 PM	0.47
12/26/2015	11:45:00 PM	0.47
12/27/2015	12:00:00 AM	0.46
12/27/2015	12:15:00 AM	0.46
12/27/2015	12:30:00 AM	0.46
12/27/2015	12:45:00 AM	0.46
12/27/2015	1:00:00 AM	0.46
12/27/2015	1:15:00 AM	0.46
12/27/2015	1:30:00 AM	0.46
12/27/2015	1:45:00 AM	0.46
12/27/2015	2:00:00 AM	0.46
12/27/2015	2:15:00 AM	0.46
12/27/2015	2:30:00 AM	0.46
12/27/2015	2:45:00 AM	0.45
12/27/2015	3:00:00 AM	0.45
12/27/2015	3:15:00 AM	0.45
12/27/2015	3:30:00 AM	0.45
12/27/2015	3:45:00 AM	0.45
12/27/2015	4:00:00 AM	0.45
12/27/2015	4:15:00 AM	0.45
12/27/2015	4:30:00 AM	0.44
12/27/2015	4:45:00 AM	0.44
12/27/2015	5:00:00 AM	0.44
12/27/2015	5:15:00 AM	0.44
12/27/2015	5:30:00 AM	0.44
12/27/2015	5:45:00 AM	0.44
12/27/2015	6:00:00 AM	0.44
12/27/2015	6:15:00 AM	0.44
12/27/2015	6:30:00 AM	0.44
12/27/2015	6:45:00 AM	0.44
12/27/2015	7:00:00 AM	0.44
12/27/2015	7:15:00 AM	0.44
12/27/2015	7:30:00 AM	0.44
12/27/2015	7:45:00 AM	0.44
12/27/2015	8:00:00 AM	0.44
12/27/2015	8:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/27/2015	8:30:00 AM	0.44
12/27/2015	8:45:00 AM	0.44
12/27/2015	9:00:00 AM	0.44
12/27/2015	9:15:00 AM	0.46
12/27/2015	9:30:00 AM	0.46
12/27/2015	9:45:00 AM	0.47
12/27/2015	10:00:00 AM	0.48
12/27/2015	10:15:00 AM	0.48
12/27/2015	10:30:00 AM	0.49
12/27/2015	10:45:00 AM	0.5
12/27/2015	11:00:00 AM	0.5
12/27/2015	11:15:00 AM	0.5
12/27/2015	11:30:00 AM	0.5
12/27/2015	11:45:00 AM	0.49
12/27/2015	12:00:00 PM	0.49
12/27/2015	12:15:00 PM	0.48
12/27/2015	12:30:00 PM	0.48
12/27/2015	12:45:00 PM	0.48
12/27/2015	1:00:00 PM	0.48
12/27/2015	1:15:00 PM	0.48
12/27/2015	1:30:00 PM	0.48
12/27/2015	1:45:00 PM	0.48
12/27/2015	2:00:00 PM	0.48
12/27/2015	2:15:00 PM	0.48
12/27/2015	2:30:00 PM	0.48
12/27/2015	2:45:00 PM	0.48
12/27/2015	3:00:00 PM	0.48
12/27/2015	3:15:00 PM	0.47
12/27/2015	3:30:00 PM	0.47
12/27/2015	3:45:00 PM	0.47
12/27/2015	4:00:00 PM	0.47
12/27/2015	4:15:00 PM	0.47
12/27/2015	4:30:00 PM	0.46
12/27/2015	4:45:00 PM	0.46
12/27/2015	5:00:00 PM	0.46
12/27/2015	5:15:00 PM	0.46
12/27/2015	5:30:00 PM	0.46
12/27/2015	5:45:00 PM	0.46
12/27/2015	6:00:00 PM	0.46
12/27/2015	6:15:00 PM	0.46
12/27/2015	6:30:00 PM	0.46
12/27/2015	6:45:00 PM	0.46
12/27/2015	7:00:00 PM	0.46
12/27/2015	7:15:00 PM	0.46
12/27/2015	7:30:00 PM	0.46
12/27/2015	7:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/27/2015	8:00:00 PM	0.46
12/27/2015	8:15:00 PM	0.46
12/27/2015	8:30:00 PM	0.46
12/27/2015	8:45:00 PM	0.46
12/27/2015	9:00:00 PM	0.46
12/27/2015	9:15:00 PM	0.46
12/27/2015	9:30:00 PM	0.46
12/27/2015	9:45:00 PM	0.46
12/27/2015	10:00:00 PM	0.46
12/27/2015	10:15:00 PM	0.46
12/27/2015	10:30:00 PM	0.46
12/27/2015	10:45:00 PM	0.46
12/27/2015	11:00:00 PM	0.46
12/27/2015	11:15:00 PM	0.46
12/27/2015	11:30:00 PM	0.46
12/27/2015	11:45:00 PM	0.46
12/28/2015	12:00:00 AM	0.46
12/28/2015	12:15:00 AM	0.46
12/28/2015	12:30:00 AM	0.46
12/28/2015	12:45:00 AM	0.45
12/28/2015	1:00:00 AM	0.45
12/28/2015	1:15:00 AM	0.45
12/28/2015	1:30:00 AM	0.45
12/28/2015	1:45:00 AM	0.45
12/28/2015	2:00:00 AM	0.45
12/28/2015	2:15:00 AM	0.45
12/28/2015	2:30:00 AM	0.45
12/28/2015	2:45:00 AM	0.45
12/28/2015	3:00:00 AM	0.45
12/28/2015	3:15:00 AM	0.45
12/28/2015	3:30:00 AM	0.45
12/28/2015	3:45:00 AM	0.45
12/28/2015	4:00:00 AM	0.45
12/28/2015	4:15:00 AM	0.45
12/28/2015	4:30:00 AM	0.45
12/28/2015	4:45:00 AM	0.45
12/28/2015	5:00:00 AM	0.45
12/28/2015	5:15:00 AM	0.45
12/28/2015	5:30:00 AM	0.45
12/28/2015	5:45:00 AM	0.45
12/28/2015	6:00:00 AM	0.45
12/28/2015	6:15:00 AM	0.45
12/28/2015	6:30:00 AM	0.45
12/28/2015	6:45:00 AM	0.45
12/28/2015	7:00:00 AM	0.45
12/28/2015	7:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
12/28/2015	7:30:00 AM	0.45
12/28/2015	7:45:00 AM	0.45
12/28/2015	8:00:00 AM	0.44
12/28/2015	8:15:00 AM	0.44
12/28/2015	8:30:00 AM	0.44
12/28/2015	8:45:00 AM	0.45
12/28/2015	9:00:00 AM	0.45
12/28/2015	9:15:00 AM	0.45
12/28/2015	9:30:00 AM	0.46
12/28/2015	9:45:00 AM	0.46
12/28/2015	10:00:00 AM	0.48
12/28/2015	10:15:00 AM	0.48
12/28/2015	10:30:00 AM	0.48
12/28/2015	10:45:00 AM	0.5
12/28/2015	11:00:00 AM	0.5
12/28/2015	11:15:00 AM	0.5
12/28/2015	11:30:00 AM	0.48
12/28/2015	11:45:00 AM	0.48
12/28/2015	12:00:00 PM	0.48
12/28/2015	12:15:00 PM	0.48
12/28/2015	12:30:00 PM	0.48
12/28/2015	12:45:00 PM	0.47
12/28/2015	1:00:00 PM	0.47
12/28/2015	1:15:00 PM	0.47
12/28/2015	1:30:00 PM	0.47
12/28/2015	1:45:00 PM	0.47
12/28/2015	2:00:00 PM	0.47
12/28/2015	2:15:00 PM	0.47
12/28/2015	2:30:00 PM	0.46
12/28/2015	2:45:00 PM	0.46
12/28/2015	3:00:00 PM	0.46
12/28/2015	3:15:00 PM	0.46
12/28/2015	3:30:00 PM	0.46
12/28/2015	3:45:00 PM	0.46
12/28/2015	4:00:00 PM	0.46
12/28/2015	4:15:00 PM	0.46
12/28/2015	4:30:00 PM	0.46
12/28/2015	4:45:00 PM	0.46
12/28/2015	5:00:00 PM	0.46
12/28/2015	5:15:00 PM	0.46
12/28/2015	5:30:00 PM	0.46
12/28/2015	5:45:00 PM	0.46
12/28/2015	6:00:00 PM	0.46
12/28/2015	6:15:00 PM	0.46
12/28/2015	6:30:00 PM	0.46
12/28/2015	6:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
12/28/2015	7:00:00 PM	0.46
12/28/2015	7:15:00 PM	0.46
12/28/2015	7:30:00 PM	0.46
12/28/2015	7:45:00 PM	0.46
12/28/2015	8:00:00 PM	0.46
12/28/2015	8:15:00 PM	0.46
12/28/2015	8:30:00 PM	0.45
12/28/2015	8:45:00 PM	0.46
12/28/2015	9:00:00 PM	0.45
12/28/2015	9:15:00 PM	0.45
12/28/2015	9:30:00 PM	0.45
12/28/2015	9:45:00 PM	0.45
12/28/2015	10:00:00 PM	0.45
12/28/2015	10:15:00 PM	0.45
12/28/2015	10:30:00 PM	0.45
12/28/2015	10:45:00 PM	0.45
12/28/2015	11:00:00 PM	0.45
12/28/2015	11:15:00 PM	0.45
12/28/2015	11:30:00 PM	0.45
12/28/2015	11:45:00 PM	0.45
12/29/2015	12:00:00 AM	0.45
12/29/2015	12:15:00 AM	0.45
12/29/2015	12:30:00 AM	0.45
12/29/2015	12:45:00 AM	0.45
12/29/2015	1:00:00 AM	0.45
12/29/2015	1:15:00 AM	0.45
12/29/2015	1:30:00 AM	0.45
12/29/2015	1:45:00 AM	0.45
12/29/2015	2:00:00 AM	0.45
12/29/2015	2:15:00 AM	0.45
12/29/2015	2:30:00 AM	0.44
12/29/2015	2:45:00 AM	0.45
12/29/2015	3:00:00 AM	0.45
12/29/2015	3:15:00 AM	0.45
12/29/2015	3:30:00 AM	0.45
12/29/2015	3:45:00 AM	0.45
12/29/2015	4:00:00 AM	0.44
12/29/2015	4:15:00 AM	0.44
12/29/2015	4:30:00 AM	0.44
12/29/2015	4:45:00 AM	0.45
12/29/2015	5:00:00 AM	0.45
12/29/2015	5:15:00 AM	0.45
12/29/2015	5:30:00 AM	0.45
12/29/2015	5:45:00 AM	0.45
12/29/2015	6:00:00 AM	0.45
12/29/2015	6:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
12/29/2015	6:30:00 AM	0.44
12/29/2015	6:45:00 AM	0.44
12/29/2015	7:00:00 AM	0.45
12/29/2015	7:15:00 AM	0.45
12/29/2015	7:30:00 AM	0.45
12/29/2015	7:45:00 AM	0.44
12/29/2015	8:00:00 AM	0.45
12/29/2015	8:15:00 AM	0.45
12/29/2015	8:30:00 AM	0.45
12/29/2015	8:45:00 AM	0.45
12/29/2015	9:00:00 AM	0.45
12/29/2015	9:15:00 AM	0.46
12/29/2015	9:30:00 AM	0.45
12/29/2015	9:45:00 AM	0.45
12/29/2015	10:00:00 AM	0.44
12/29/2015	10:15:00 AM	0.44
12/29/2015	10:30:00 AM	0.44
12/29/2015	10:45:00 AM	0.45
12/29/2015	11:00:00 AM	0.45
12/29/2015	11:15:00 AM	0.45
12/29/2015	11:30:00 AM	0.45
12/29/2015	11:45:00 AM	0.46
12/29/2015	12:00:00 PM	0.46
12/29/2015	12:15:00 PM	0.45
12/29/2015	12:30:00 PM	0.45
12/29/2015	12:45:00 PM	0.46
12/29/2015	1:00:00 PM	0.45
12/29/2015	1:15:00 PM	0.45
12/29/2015	1:30:00 PM	0.44
12/29/2015	1:45:00 PM	0.45
12/29/2015	2:00:00 PM	0.45
12/29/2015	2:15:00 PM	0.45
12/29/2015	2:30:00 PM	0.44
12/29/2015	2:45:00 PM	0.44
12/29/2015	3:00:00 PM	0.44
12/29/2015	3:15:00 PM	0.44
12/29/2015	3:30:00 PM	0.44
12/29/2015	3:45:00 PM	0.44
12/29/2015	4:00:00 PM	0.44
12/29/2015	4:15:00 PM	0.44
12/29/2015	4:30:00 PM	0.44
12/29/2015	4:45:00 PM	0.44
12/29/2015	5:00:00 PM	0.44
12/29/2015	5:15:00 PM	0.44
12/29/2015	5:30:00 PM	0.44
12/29/2015	5:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/29/2015	6:00:00 PM	0.44
12/29/2015	6:15:00 PM	0.44
12/29/2015	6:30:00 PM	0.44
12/29/2015	6:45:00 PM	0.44
12/29/2015	7:00:00 PM	0.44
12/29/2015	7:15:00 PM	0.44
12/29/2015	7:30:00 PM	0.44
12/29/2015	7:45:00 PM	0.44
12/29/2015	8:00:00 PM	0.44
12/29/2015	8:15:00 PM	0.44
12/29/2015	8:30:00 PM	0.44
12/29/2015	8:45:00 PM	0.44
12/29/2015	9:00:00 PM	0.44
12/29/2015	9:15:00 PM	0.44
12/29/2015	9:30:00 PM	0.44
12/29/2015	9:45:00 PM	0.44
12/29/2015	10:00:00 PM	0.44
12/29/2015	10:15:00 PM	0.44
12/29/2015	10:30:00 PM	0.44
12/29/2015	10:45:00 PM	0.44
12/29/2015	11:00:00 PM	0.44
12/29/2015	11:15:00 PM	0.44
12/29/2015	11:30:00 PM	0.44
12/29/2015	11:45:00 PM	0.44
12/30/2015	12:00:00 AM	0.44
12/30/2015	12:15:00 AM	0.44
12/30/2015	12:30:00 AM	0.44
12/30/2015	12:45:00 AM	0.44
12/30/2015	1:00:00 AM	0.44
12/30/2015	1:15:00 AM	0.44
12/30/2015	1:30:00 AM	0.44
12/30/2015	1:45:00 AM	0.44
12/30/2015	2:00:00 AM	0.44
12/30/2015	2:15:00 AM	0.44
12/30/2015	2:30:00 AM	0.44
12/30/2015	2:45:00 AM	0.44
12/30/2015	3:00:00 AM	0.44
12/30/2015	3:15:00 AM	0.44
12/30/2015	3:30:00 AM	0.44
12/30/2015	3:45:00 AM	0.44
12/30/2015	4:00:00 AM	0.44
12/30/2015	4:15:00 AM	0.44
12/30/2015	4:30:00 AM	0.44
12/30/2015	4:45:00 AM	0.44
12/30/2015	5:00:00 AM	0.44
12/30/2015	5:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/30/2015	5:30:00 AM	0.44
12/30/2015	5:45:00 AM	0.44
12/30/2015	6:00:00 AM	0.44
12/30/2015	6:15:00 AM	0.44
12/30/2015	6:30:00 AM	0.44
12/30/2015	6:45:00 AM	0.44
12/30/2015	7:00:00 AM	0.44
12/30/2015	7:15:00 AM	0.44
12/30/2015	7:30:00 AM	0.44
12/30/2015	7:45:00 AM	0.44
12/30/2015	8:00:00 AM	0.44
12/30/2015	8:15:00 AM	0.44
12/30/2015	8:30:00 AM	0.44
12/30/2015	8:45:00 AM	0.44
12/30/2015	9:00:00 AM	0.44
12/30/2015	9:15:00 AM	0.44
12/30/2015	9:30:00 AM	0.44
12/30/2015	9:45:00 AM	0.44
12/30/2015	10:00:00 AM	0.45
12/30/2015	10:15:00 AM	0.46
12/30/2015	10:30:00 AM	0.46
12/30/2015	10:45:00 AM	0.46
12/30/2015	11:00:00 AM	0.47
12/30/2015	11:15:00 AM	0.47
12/30/2015	11:30:00 AM	0.46
12/30/2015	11:45:00 AM	0.46
12/30/2015	12:00:00 PM	0.46
12/30/2015	12:15:00 PM	0.45
12/30/2015	12:30:00 PM	0.45
12/30/2015	12:45:00 PM	0.45
12/30/2015	1:00:00 PM	0.46
12/30/2015	1:15:00 PM	0.46
12/30/2015	1:30:00 PM	0.46
12/30/2015	1:45:00 PM	0.46
12/30/2015	2:00:00 PM	0.46
12/30/2015	2:15:00 PM	0.45
12/30/2015	2:30:00 PM	0.46
12/30/2015	2:45:00 PM	0.46
12/30/2015	3:00:00 PM	0.46
12/30/2015	3:15:00 PM	0.45
12/30/2015	3:30:00 PM	0.45
12/30/2015	3:45:00 PM	0.45
12/30/2015	4:00:00 PM	0.45
12/30/2015	4:15:00 PM	0.44
12/30/2015	4:30:00 PM	0.44
12/30/2015	4:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/30/2015	5:00:00 PM	0.44
12/30/2015	5:15:00 PM	0.44
12/30/2015	5:30:00 PM	0.44
12/30/2015	5:45:00 PM	0.44
12/30/2015	6:00:00 PM	0.44
12/30/2015	6:15:00 PM	0.44
12/30/2015	6:30:00 PM	0.44
12/30/2015	6:45:00 PM	0.44
12/30/2015	7:00:00 PM	0.44
12/30/2015	7:15:00 PM	0.44
12/30/2015	7:30:00 PM	0.44
12/30/2015	7:45:00 PM	0.44
12/30/2015	8:00:00 PM	0.44
12/30/2015	8:15:00 PM	0.44
12/30/2015	8:30:00 PM	0.44
12/30/2015	8:45:00 PM	0.44
12/30/2015	9:00:00 PM	0.44
12/30/2015	9:15:00 PM	0.44
12/30/2015	9:30:00 PM	0.44
12/30/2015	9:45:00 PM	0.44
12/30/2015	10:00:00 PM	0.44
12/30/2015	10:15:00 PM	0.44
12/30/2015	10:30:00 PM	0.44
12/30/2015	10:45:00 PM	0.44
12/30/2015	11:00:00 PM	0.44
12/30/2015	11:15:00 PM	0.44
12/30/2015	11:30:00 PM	0.44
12/30/2015	11:45:00 PM	0.44
12/31/2015	12:00:00 AM	0.44
12/31/2015	12:15:00 AM	0.44
12/31/2015	12:30:00 AM	0.44
12/31/2015	12:45:00 AM	0.44
12/31/2015	1:00:00 AM	0.44
12/31/2015	1:15:00 AM	0.44
12/31/2015	1:30:00 AM	0.44
12/31/2015	1:45:00 AM	0.44
12/31/2015	2:00:00 AM	0.44
12/31/2015	2:15:00 AM	0.44
12/31/2015	2:30:00 AM	0.44
12/31/2015	2:45:00 AM	0.44
12/31/2015	3:00:00 AM	0.44
12/31/2015	3:15:00 AM	0.44
12/31/2015	3:30:00 AM	0.44
12/31/2015	3:45:00 AM	0.44
12/31/2015	4:00:00 AM	0.44
12/31/2015	4:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/31/2015	4:30:00 AM	0.44
12/31/2015	4:45:00 AM	0.44
12/31/2015	5:00:00 AM	0.44
12/31/2015	5:15:00 AM	0.44
12/31/2015	5:30:00 AM	0.44
12/31/2015	5:45:00 AM	0.44
12/31/2015	6:00:00 AM	0.44
12/31/2015	6:15:00 AM	0.44
12/31/2015	6:30:00 AM	0.44
12/31/2015	6:45:00 AM	0.44
12/31/2015	7:00:00 AM	0.44
12/31/2015	7:15:00 AM	0.44
12/31/2015	7:30:00 AM	0.44
12/31/2015	7:45:00 AM	0.44
12/31/2015	8:00:00 AM	0.44
12/31/2015	8:15:00 AM	0.44
12/31/2015	8:30:00 AM	0.44
12/31/2015	8:45:00 AM	0.44
12/31/2015	9:00:00 AM	0.44
12/31/2015	9:15:00 AM	0.44
12/31/2015	9:30:00 AM	0.44
12/31/2015	9:45:00 AM	0.44
12/31/2015	10:00:00 AM	0.44
12/31/2015	10:15:00 AM	0.44
12/31/2015	10:30:00 AM	0.45
12/31/2015	10:45:00 AM	0.45
12/31/2015	11:00:00 AM	0.44
12/31/2015	11:15:00 AM	0.45
12/31/2015	11:30:00 AM	0.44
12/31/2015	11:45:00 AM	0.45
12/31/2015	12:00:00 PM	0.45
12/31/2015	12:15:00 PM	0.44
12/31/2015	12:30:00 PM	0.44
12/31/2015	12:45:00 PM	0.44
12/31/2015	1:00:00 PM	0.44
12/31/2015	1:15:00 PM	0.44
12/31/2015	1:30:00 PM	0.44
12/31/2015	1:45:00 PM	0.44
12/31/2015	2:00:00 PM	0.44
12/31/2015	2:15:00 PM	0.44
12/31/2015	2:30:00 PM	0.44
12/31/2015	2:45:00 PM	0.44
12/31/2015	3:00:00 PM	0.44
12/31/2015	3:15:00 PM	0.44
12/31/2015	3:30:00 PM	0.44
12/31/2015	3:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
12/31/2015	4:00:00 PM	0.44
12/31/2015	4:15:00 PM	0.44
12/31/2015	4:30:00 PM	0.44
12/31/2015	4:45:00 PM	0.44
12/31/2015	5:00:00 PM	0.44
12/31/2015	5:15:00 PM	0.44
12/31/2015	5:30:00 PM	0.44
12/31/2015	5:45:00 PM	0.44
12/31/2015	6:00:00 PM	0.44
12/31/2015	6:15:00 PM	0.44
12/31/2015	6:30:00 PM	0.44
12/31/2015	6:45:00 PM	0.44
12/31/2015	7:00:00 PM	0.44
12/31/2015	7:15:00 PM	0.44
12/31/2015	7:30:00 PM	0.44
12/31/2015	7:45:00 PM	0.43
12/31/2015	8:00:00 PM	0.44
12/31/2015	8:15:00 PM	0.44
12/31/2015	8:30:00 PM	0.44
12/31/2015	8:45:00 PM	0.44
12/31/2015	9:00:00 PM	0.44
12/31/2015	9:15:00 PM	0.44
12/31/2015	9:30:00 PM	0.44
12/31/2015	9:45:00 PM	0.44
12/31/2015	10:00:00 PM	0.44
12/31/2015	10:15:00 PM	0.44
12/31/2015	10:30:00 PM	0.44
12/31/2015	10:45:00 PM	0.44
12/31/2015	11:00:00 PM	0.44
12/31/2015	11:15:00 PM	0.44
12/31/2015	11:30:00 PM	0.44
12/31/2015	11:45:00 PM	0.44

Billy Lake Return
Station 0213

Date	Flow (cfs)
12/1/2015	1.238
12/2/2015	1.294
12/3/2015	1.302
12/4/2015	1.269
12/5/2015	1.238
12/6/2015	1.268
12/7/2015	1.302
12/8/2015	1.245
12/9/2015	1.238
12/10/2015	1.266
12/11/2015	1.302
12/12/2015	1.302
12/13/2015	1.302
12/14/2015	1.266
12/15/2015	1.206
12/16/2015	1.174
12/17/2015	1.154
12/18/2015	1.063
12/19/2015	1.059
12/20/2015	1.097
12/21/2015	1.059
12/22/2015	1.063
12/23/2015	1.107
12/24/2015	1.112
12/25/2015	1.112
12/26/2015	1.122
12/27/2015	1.17
12/28/2015	1.174
12/29/2015	1.174
12/30/2015	1.174
12/31/2015	1.174

Billy Lake Return Gage

DATE	TIME	GAGE
12/1/2015	12:00:00 AM	0.3
12/1/2015	12:15:00 AM	0.3
12/1/2015	12:30:00 AM	0.3
12/1/2015	12:45:00 AM	0.3
12/1/2015	1:00:00 AM	0.3
12/1/2015	1:15:00 AM	0.3
12/1/2015	1:30:00 AM	0.3
12/1/2015	1:45:00 AM	0.3
12/1/2015	2:00:00 AM	0.3
12/1/2015	2:15:00 AM	0.3
12/1/2015	2:30:00 AM	0.3
12/1/2015	2:45:00 AM	0.3
12/1/2015	3:00:00 AM	0.3
12/1/2015	3:15:00 AM	0.3
12/1/2015	3:30:00 AM	0.3
12/1/2015	3:45:00 AM	0.3
12/1/2015	4:00:00 AM	0.3
12/1/2015	4:15:00 AM	0.3
12/1/2015	4:30:00 AM	0.3
12/1/2015	4:45:00 AM	0.3
12/1/2015	5:00:00 AM	0.3
12/1/2015	5:15:00 AM	0.3
12/1/2015	5:30:00 AM	0.3
12/1/2015	5:45:00 AM	0.3
12/1/2015	6:00:00 AM	0.3
12/1/2015	6:15:00 AM	0.3
12/1/2015	6:30:00 AM	0.3
12/1/2015	6:45:00 AM	0.3
12/1/2015	7:00:00 AM	0.3
12/1/2015	7:15:00 AM	0.3
12/1/2015	7:30:00 AM	0.3
12/1/2015	7:45:00 AM	0.3
12/1/2015	8:00:00 AM	0.3
12/1/2015	8:15:00 AM	0.3
12/1/2015	8:30:00 AM	0.3
12/1/2015	8:45:00 AM	0.3
12/1/2015	9:00:00 AM	0.3
12/1/2015	9:15:00 AM	0.3
12/1/2015	9:30:00 AM	0.3
12/1/2015	9:45:00 AM	0.3
12/1/2015	10:00:00 AM	0.3
12/1/2015	10:15:00 AM	0.3
12/1/2015	10:30:00 AM	0.3
12/1/2015	10:45:00 AM	0.3
12/1/2015	11:00:00 AM	0.3
12/1/2015	11:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/1/2015	11:30:00 AM	0.3
12/1/2015	11:45:00 AM	0.3
12/1/2015	12:00:00 PM	0.3
12/1/2015	12:15:00 PM	0.3
12/1/2015	12:30:00 PM	0.3
12/1/2015	12:45:00 PM	0.3
12/1/2015	1:00:00 PM	0.3
12/1/2015	1:15:00 PM	0.3
12/1/2015	1:30:00 PM	0.3
12/1/2015	1:45:00 PM	0.3
12/1/2015	2:00:00 PM	0.3
12/1/2015	2:15:00 PM	0.3
12/1/2015	2:30:00 PM	0.3
12/1/2015	2:45:00 PM	0.3
12/1/2015	3:00:00 PM	0.3
12/1/2015	3:15:00 PM	0.3
12/1/2015	3:30:00 PM	0.3
12/1/2015	3:45:00 PM	0.3
12/1/2015	4:00:00 PM	0.3
12/1/2015	4:15:00 PM	0.3
12/1/2015	4:30:00 PM	0.3
12/1/2015	4:45:00 PM	0.3
12/1/2015	5:00:00 PM	0.3
12/1/2015	5:15:00 PM	0.3
12/1/2015	5:30:00 PM	0.3
12/1/2015	5:45:00 PM	0.3
12/1/2015	6:00:00 PM	0.3
12/1/2015	6:15:00 PM	0.3
12/1/2015	6:30:00 PM	0.3
12/1/2015	6:45:00 PM	0.3
12/1/2015	7:00:00 PM	0.3
12/1/2015	7:15:00 PM	0.3
12/1/2015	7:30:00 PM	0.3
12/1/2015	7:45:00 PM	0.3
12/1/2015	8:00:00 PM	0.3
12/1/2015	8:15:00 PM	0.3
12/1/2015	8:30:00 PM	0.3
12/1/2015	8:45:00 PM	0.3
12/1/2015	9:00:00 PM	0.3
12/1/2015	9:15:00 PM	0.3
12/1/2015	9:30:00 PM	0.3
12/1/2015	9:45:00 PM	0.3
12/1/2015	10:00:00 PM	0.3
12/1/2015	10:15:00 PM	0.3
12/1/2015	10:30:00 PM	0.3
12/1/2015	10:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/1/2015	11:00:00 PM	0.3
12/1/2015	11:15:00 PM	0.3
12/1/2015	11:30:00 PM	0.3
12/1/2015	11:45:00 PM	0.3
12/2/2015	12:00:00 AM	0.3
12/2/2015	12:15:00 AM	0.3
12/2/2015	12:30:00 AM	0.3
12/2/2015	12:45:00 AM	0.3
12/2/2015	1:00:00 AM	0.3
12/2/2015	1:15:00 AM	0.3
12/2/2015	1:30:00 AM	0.3
12/2/2015	1:45:00 AM	0.3
12/2/2015	2:00:00 AM	0.3
12/2/2015	2:15:00 AM	0.3
12/2/2015	2:30:00 AM	0.3
12/2/2015	2:45:00 AM	0.3
12/2/2015	3:00:00 AM	0.3
12/2/2015	3:15:00 AM	0.31
12/2/2015	3:30:00 AM	0.31
12/2/2015	3:45:00 AM	0.31
12/2/2015	4:00:00 AM	0.31
12/2/2015	4:15:00 AM	0.31
12/2/2015	4:30:00 AM	0.31
12/2/2015	4:45:00 AM	0.31
12/2/2015	5:00:00 AM	0.31
12/2/2015	5:15:00 AM	0.31
12/2/2015	5:30:00 AM	0.31
12/2/2015	5:45:00 AM	0.31
12/2/2015	6:00:00 AM	0.31
12/2/2015	6:15:00 AM	0.31
12/2/2015	6:30:00 AM	0.31
12/2/2015	6:45:00 AM	0.31
12/2/2015	7:00:00 AM	0.31
12/2/2015	7:15:00 AM	0.31
12/2/2015	7:30:00 AM	0.31
12/2/2015	7:45:00 AM	0.31
12/2/2015	8:00:00 AM	0.31
12/2/2015	8:15:00 AM	0.31
12/2/2015	8:30:00 AM	0.31
12/2/2015	8:45:00 AM	0.31
12/2/2015	9:00:00 AM	0.31
12/2/2015	9:15:00 AM	0.31
12/2/2015	9:30:00 AM	0.31
12/2/2015	9:45:00 AM	0.31
12/2/2015	10:00:00 AM	0.31
12/2/2015	10:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/2/2015	10:30:00 AM	0.31
12/2/2015	10:45:00 AM	0.31
12/2/2015	11:00:00 AM	0.31
12/2/2015	11:15:00 AM	0.31
12/2/2015	11:30:00 AM	0.31
12/2/2015	11:45:00 AM	0.31
12/2/2015	12:00:00 PM	0.31
12/2/2015	12:15:00 PM	0.31
12/2/2015	12:30:00 PM	0.31
12/2/2015	12:45:00 PM	0.31
12/2/2015	1:00:00 PM	0.31
12/2/2015	1:15:00 PM	0.31
12/2/2015	1:30:00 PM	0.31
12/2/2015	1:45:00 PM	0.31
12/2/2015	2:00:00 PM	0.31
12/2/2015	2:15:00 PM	0.31
12/2/2015	2:30:00 PM	0.31
12/2/2015	2:45:00 PM	0.31
12/2/2015	3:00:00 PM	0.31
12/2/2015	3:15:00 PM	0.31
12/2/2015	3:30:00 PM	0.31
12/2/2015	3:45:00 PM	0.31
12/2/2015	4:00:00 PM	0.31
12/2/2015	4:15:00 PM	0.31
12/2/2015	4:30:00 PM	0.31
12/2/2015	4:45:00 PM	0.31
12/2/2015	5:00:00 PM	0.31
12/2/2015	5:15:00 PM	0.31
12/2/2015	5:30:00 PM	0.31
12/2/2015	5:45:00 PM	0.31
12/2/2015	6:00:00 PM	0.31
12/2/2015	6:15:00 PM	0.31
12/2/2015	6:30:00 PM	0.31
12/2/2015	6:45:00 PM	0.31
12/2/2015	7:00:00 PM	0.31
12/2/2015	7:15:00 PM	0.31
12/2/2015	7:30:00 PM	0.31
12/2/2015	7:45:00 PM	0.31
12/2/2015	8:00:00 PM	0.31
12/2/2015	8:15:00 PM	0.31
12/2/2015	8:30:00 PM	0.31
12/2/2015	8:45:00 PM	0.31
12/2/2015	9:00:00 PM	0.31
12/2/2015	9:15:00 PM	0.31
12/2/2015	9:30:00 PM	0.31
12/2/2015	9:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/2/2015	10:00:00 PM	0.31
12/2/2015	10:15:00 PM	0.31
12/2/2015	10:30:00 PM	0.31
12/2/2015	10:45:00 PM	0.31
12/2/2015	11:00:00 PM	0.31
12/2/2015	11:15:00 PM	0.31
12/2/2015	11:30:00 PM	0.31
12/2/2015	11:45:00 PM	0.31
12/3/2015	12:00:00 AM	0.31
12/3/2015	12:15:00 AM	0.31
12/3/2015	12:30:00 AM	0.31
12/3/2015	12:45:00 AM	0.31
12/3/2015	1:00:00 AM	0.31
12/3/2015	1:15:00 AM	0.31
12/3/2015	1:30:00 AM	0.31
12/3/2015	1:45:00 AM	0.31
12/3/2015	2:00:00 AM	0.31
12/3/2015	2:15:00 AM	0.31
12/3/2015	2:30:00 AM	0.31
12/3/2015	2:45:00 AM	0.31
12/3/2015	3:00:00 AM	0.31
12/3/2015	3:15:00 AM	0.31
12/3/2015	3:30:00 AM	0.31
12/3/2015	3:45:00 AM	0.31
12/3/2015	4:00:00 AM	0.31
12/3/2015	4:15:00 AM	0.31
12/3/2015	4:30:00 AM	0.31
12/3/2015	4:45:00 AM	0.31
12/3/2015	5:00:00 AM	0.31
12/3/2015	5:15:00 AM	0.31
12/3/2015	5:30:00 AM	0.31
12/3/2015	5:45:00 AM	0.31
12/3/2015	6:00:00 AM	0.31
12/3/2015	6:15:00 AM	0.31
12/3/2015	6:30:00 AM	0.31
12/3/2015	6:45:00 AM	0.31
12/3/2015	7:00:00 AM	0.31
12/3/2015	7:15:00 AM	0.31
12/3/2015	7:30:00 AM	0.31
12/3/2015	7:45:00 AM	0.31
12/3/2015	8:00:00 AM	0.31
12/3/2015	8:15:00 AM	0.31
12/3/2015	8:30:00 AM	0.31
12/3/2015	8:45:00 AM	0.31
12/3/2015	9:00:00 AM	0.31
12/3/2015	9:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/3/2015	9:30:00 AM	0.31
12/3/2015	9:45:00 AM	0.31
12/3/2015	10:00:00 AM	0.31
12/3/2015	10:15:00 AM	0.31
12/3/2015	10:30:00 AM	0.31
12/3/2015	10:45:00 AM	0.31
12/3/2015	11:00:00 AM	0.31
12/3/2015	11:15:00 AM	0.31
12/3/2015	11:30:00 AM	0.31
12/3/2015	11:45:00 AM	0.31
12/3/2015	12:00:00 PM	0.31
12/3/2015	12:15:00 PM	0.31
12/3/2015	12:30:00 PM	0.31
12/3/2015	12:45:00 PM	0.31
12/3/2015	1:00:00 PM	0.31
12/3/2015	1:15:00 PM	0.31
12/3/2015	1:30:00 PM	0.31
12/3/2015	1:45:00 PM	0.31
12/3/2015	2:00:00 PM	0.31
12/3/2015	2:15:00 PM	0.31
12/3/2015	2:30:00 PM	0.31
12/3/2015	2:45:00 PM	0.31
12/3/2015	3:00:00 PM	0.31
12/3/2015	3:15:00 PM	0.31
12/3/2015	3:30:00 PM	0.31
12/3/2015	3:45:00 PM	0.31
12/3/2015	4:00:00 PM	0.31
12/3/2015	4:15:00 PM	0.31
12/3/2015	4:30:00 PM	0.31
12/3/2015	4:45:00 PM	0.31
12/3/2015	5:00:00 PM	0.31
12/3/2015	5:15:00 PM	0.31
12/3/2015	5:30:00 PM	0.31
12/3/2015	5:45:00 PM	0.31
12/3/2015	6:00:00 PM	0.31
12/3/2015	6:15:00 PM	0.31
12/3/2015	6:30:00 PM	0.31
12/3/2015	6:45:00 PM	0.31
12/3/2015	7:00:00 PM	0.31
12/3/2015	7:15:00 PM	0.31
12/3/2015	7:30:00 PM	0.31
12/3/2015	7:45:00 PM	0.31
12/3/2015	8:00:00 PM	0.31
12/3/2015	8:15:00 PM	0.31
12/3/2015	8:30:00 PM	0.31
12/3/2015	8:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/3/2015	9:00:00 PM	0.31
12/3/2015	9:15:00 PM	0.31
12/3/2015	9:30:00 PM	0.31
12/3/2015	9:45:00 PM	0.31
12/3/2015	10:00:00 PM	0.31
12/3/2015	10:15:00 PM	0.31
12/3/2015	10:30:00 PM	0.31
12/3/2015	10:45:00 PM	0.31
12/3/2015	11:00:00 PM	0.31
12/3/2015	11:15:00 PM	0.31
12/3/2015	11:30:00 PM	0.31
12/3/2015	11:45:00 PM	0.31
12/4/2015	12:00:00 AM	0.31
12/4/2015	12:15:00 AM	0.31
12/4/2015	12:30:00 AM	0.31
12/4/2015	12:45:00 AM	0.31
12/4/2015	1:00:00 AM	0.31
12/4/2015	1:15:00 AM	0.31
12/4/2015	1:30:00 AM	0.31
12/4/2015	1:45:00 AM	0.31
12/4/2015	2:00:00 AM	0.31
12/4/2015	2:15:00 AM	0.31
12/4/2015	2:30:00 AM	0.31
12/4/2015	2:45:00 AM	0.31
12/4/2015	3:00:00 AM	0.31
12/4/2015	3:15:00 AM	0.31
12/4/2015	3:30:00 AM	0.31
12/4/2015	3:45:00 AM	0.31
12/4/2015	4:00:00 AM	0.31
12/4/2015	4:15:00 AM	0.31
12/4/2015	4:30:00 AM	0.31
12/4/2015	4:45:00 AM	0.31
12/4/2015	5:00:00 AM	0.31
12/4/2015	5:15:00 AM	0.31
12/4/2015	5:30:00 AM	0.31
12/4/2015	5:45:00 AM	0.31
12/4/2015	6:00:00 AM	0.31
12/4/2015	6:15:00 AM	0.31
12/4/2015	6:30:00 AM	0.31
12/4/2015	6:45:00 AM	0.31
12/4/2015	7:00:00 AM	0.31
12/4/2015	7:15:00 AM	0.31
12/4/2015	7:30:00 AM	0.31
12/4/2015	7:45:00 AM	0.31
12/4/2015	8:00:00 AM	0.31
12/4/2015	8:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/4/2015	8:30:00 AM	0.31
12/4/2015	8:45:00 AM	0.31
12/4/2015	9:00:00 AM	0.31
12/4/2015	9:15:00 AM	0.31
12/4/2015	9:30:00 AM	0.31
12/4/2015	9:45:00 AM	0.31
12/4/2015	10:00:00 AM	0.31
12/4/2015	10:15:00 AM	0.31
12/4/2015	10:30:00 AM	0.3
12/4/2015	10:45:00 AM	0.31
12/4/2015	11:00:00 AM	0.31
12/4/2015	11:15:00 AM	0.31
12/4/2015	11:30:00 AM	0.31
12/4/2015	11:45:00 AM	0.31
12/4/2015	12:00:00 PM	0.3
12/4/2015	12:15:00 PM	0.3
12/4/2015	12:30:00 PM	0.3
12/4/2015	12:45:00 PM	0.3
12/4/2015	1:00:00 PM	0.3
12/4/2015	1:15:00 PM	0.3
12/4/2015	1:30:00 PM	0.3
12/4/2015	1:45:00 PM	0.3
12/4/2015	2:00:00 PM	0.3
12/4/2015	2:15:00 PM	0.3
12/4/2015	2:30:00 PM	0.3
12/4/2015	2:45:00 PM	0.3
12/4/2015	3:00:00 PM	0.3
12/4/2015	3:15:00 PM	0.3
12/4/2015	3:30:00 PM	0.3
12/4/2015	3:45:00 PM	0.3
12/4/2015	4:00:00 PM	0.3
12/4/2015	4:15:00 PM	0.3
12/4/2015	4:30:00 PM	0.3
12/4/2015	4:45:00 PM	0.3
12/4/2015	5:00:00 PM	0.3
12/4/2015	5:15:00 PM	0.3
12/4/2015	5:30:00 PM	0.3
12/4/2015	5:45:00 PM	0.3
12/4/2015	6:00:00 PM	0.3
12/4/2015	6:15:00 PM	0.3
12/4/2015	6:30:00 PM	0.3
12/4/2015	6:45:00 PM	0.3
12/4/2015	7:00:00 PM	0.3
12/4/2015	7:15:00 PM	0.3
12/4/2015	7:30:00 PM	0.3
12/4/2015	7:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/4/2015	8:00:00 PM	0.3
12/4/2015	8:15:00 PM	0.3
12/4/2015	8:30:00 PM	0.3
12/4/2015	8:45:00 PM	0.3
12/4/2015	9:00:00 PM	0.3
12/4/2015	9:15:00 PM	0.3
12/4/2015	9:30:00 PM	0.3
12/4/2015	9:45:00 PM	0.3
12/4/2015	10:00:00 PM	0.3
12/4/2015	10:15:00 PM	0.3
12/4/2015	10:30:00 PM	0.3
12/4/2015	10:45:00 PM	0.3
12/4/2015	11:00:00 PM	0.3
12/4/2015	11:15:00 PM	0.3
12/4/2015	11:30:00 PM	0.3
12/4/2015	11:45:00 PM	0.3
12/5/2015	12:00:00 AM	0.3
12/5/2015	12:15:00 AM	0.3
12/5/2015	12:30:00 AM	0.3
12/5/2015	12:45:00 AM	0.3
12/5/2015	1:00:00 AM	0.3
12/5/2015	1:15:00 AM	0.3
12/5/2015	1:30:00 AM	0.3
12/5/2015	1:45:00 AM	0.3
12/5/2015	2:00:00 AM	0.3
12/5/2015	2:15:00 AM	0.3
12/5/2015	2:30:00 AM	0.3
12/5/2015	2:45:00 AM	0.3
12/5/2015	3:00:00 AM	0.3
12/5/2015	3:15:00 AM	0.3
12/5/2015	3:30:00 AM	0.3
12/5/2015	3:45:00 AM	0.3
12/5/2015	4:00:00 AM	0.3
12/5/2015	4:15:00 AM	0.3
12/5/2015	4:30:00 AM	0.3
12/5/2015	4:45:00 AM	0.3
12/5/2015	5:00:00 AM	0.3
12/5/2015	5:15:00 AM	0.3
12/5/2015	5:30:00 AM	0.3
12/5/2015	5:45:00 AM	0.3
12/5/2015	6:00:00 AM	0.3
12/5/2015	6:15:00 AM	0.3
12/5/2015	6:30:00 AM	0.3
12/5/2015	6:45:00 AM	0.3
12/5/2015	7:00:00 AM	0.3
12/5/2015	7:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/5/2015	7:30:00 AM	0.3
12/5/2015	7:45:00 AM	0.3
12/5/2015	8:00:00 AM	0.3
12/5/2015	8:15:00 AM	0.3
12/5/2015	8:30:00 AM	0.3
12/5/2015	8:45:00 AM	0.3
12/5/2015	9:00:00 AM	0.3
12/5/2015	9:15:00 AM	0.3
12/5/2015	9:30:00 AM	0.3
12/5/2015	9:45:00 AM	0.3
12/5/2015	10:00:00 AM	0.3
12/5/2015	10:15:00 AM	0.3
12/5/2015	10:30:00 AM	0.3
12/5/2015	10:45:00 AM	0.3
12/5/2015	11:00:00 AM	0.3
12/5/2015	11:15:00 AM	0.3
12/5/2015	11:30:00 AM	0.3
12/5/2015	11:45:00 AM	0.3
12/5/2015	12:00:00 PM	0.3
12/5/2015	12:15:00 PM	0.3
12/5/2015	12:30:00 PM	0.3
12/5/2015	12:45:00 PM	0.3
12/5/2015	1:00:00 PM	0.3
12/5/2015	1:15:00 PM	0.3
12/5/2015	1:30:00 PM	0.3
12/5/2015	1:45:00 PM	0.3
12/5/2015	2:00:00 PM	0.3
12/5/2015	2:15:00 PM	0.3
12/5/2015	2:30:00 PM	0.3
12/5/2015	2:45:00 PM	0.3
12/5/2015	3:00:00 PM	0.3
12/5/2015	3:15:00 PM	0.3
12/5/2015	3:30:00 PM	0.3
12/5/2015	3:45:00 PM	0.3
12/5/2015	4:00:00 PM	0.3
12/5/2015	4:15:00 PM	0.3
12/5/2015	4:30:00 PM	0.3
12/5/2015	4:45:00 PM	0.3
12/5/2015	5:00:00 PM	0.3
12/5/2015	5:15:00 PM	0.3
12/5/2015	5:30:00 PM	0.3
12/5/2015	5:45:00 PM	0.3
12/5/2015	6:00:00 PM	0.3
12/5/2015	6:15:00 PM	0.3
12/5/2015	6:30:00 PM	0.3
12/5/2015	6:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/5/2015	7:00:00 PM	0.3
12/5/2015	7:15:00 PM	0.3
12/5/2015	7:30:00 PM	0.3
12/5/2015	7:45:00 PM	0.3
12/5/2015	8:00:00 PM	0.3
12/5/2015	8:15:00 PM	0.3
12/5/2015	8:30:00 PM	0.3
12/5/2015	8:45:00 PM	0.3
12/5/2015	9:00:00 PM	0.3
12/5/2015	9:15:00 PM	0.3
12/5/2015	9:30:00 PM	0.3
12/5/2015	9:45:00 PM	0.3
12/5/2015	10:00:00 PM	0.3
12/5/2015	10:15:00 PM	0.3
12/5/2015	10:30:00 PM	0.3
12/5/2015	10:45:00 PM	0.3
12/5/2015	11:00:00 PM	0.3
12/5/2015	11:15:00 PM	0.3
12/5/2015	11:30:00 PM	0.3
12/5/2015	11:45:00 PM	0.3
12/6/2015	12:00:00 AM	0.3
12/6/2015	12:15:00 AM	0.3
12/6/2015	12:30:00 AM	0.3
12/6/2015	12:45:00 AM	0.3
12/6/2015	1:00:00 AM	0.3
12/6/2015	1:15:00 AM	0.3
12/6/2015	1:30:00 AM	0.3
12/6/2015	1:45:00 AM	0.3
12/6/2015	2:00:00 AM	0.3
12/6/2015	2:15:00 AM	0.3
12/6/2015	2:30:00 AM	0.3
12/6/2015	2:45:00 AM	0.3
12/6/2015	3:00:00 AM	0.3
12/6/2015	3:15:00 AM	0.3
12/6/2015	3:30:00 AM	0.3
12/6/2015	3:45:00 AM	0.3
12/6/2015	4:00:00 AM	0.3
12/6/2015	4:15:00 AM	0.3
12/6/2015	4:30:00 AM	0.3
12/6/2015	4:45:00 AM	0.3
12/6/2015	5:00:00 AM	0.3
12/6/2015	5:15:00 AM	0.3
12/6/2015	5:30:00 AM	0.3
12/6/2015	5:45:00 AM	0.3
12/6/2015	6:00:00 AM	0.3
12/6/2015	6:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/6/2015	6:30:00 AM	0.3
12/6/2015	6:45:00 AM	0.3
12/6/2015	7:00:00 AM	0.3
12/6/2015	7:15:00 AM	0.3
12/6/2015	7:30:00 AM	0.3
12/6/2015	7:45:00 AM	0.3
12/6/2015	8:00:00 AM	0.3
12/6/2015	8:15:00 AM	0.3
12/6/2015	8:30:00 AM	0.3
12/6/2015	8:45:00 AM	0.3
12/6/2015	9:00:00 AM	0.3
12/6/2015	9:15:00 AM	0.3
12/6/2015	9:30:00 AM	0.3
12/6/2015	9:45:00 AM	0.3
12/6/2015	10:00:00 AM	0.3
12/6/2015	10:15:00 AM	0.3
12/6/2015	10:30:00 AM	0.3
12/6/2015	10:45:00 AM	0.3
12/6/2015	11:00:00 AM	0.3
12/6/2015	11:15:00 AM	0.3
12/6/2015	11:30:00 AM	0.3
12/6/2015	11:45:00 AM	0.3
12/6/2015	12:00:00 PM	0.3
12/6/2015	12:15:00 PM	0.3
12/6/2015	12:30:00 PM	0.3
12/6/2015	12:45:00 PM	0.31
12/6/2015	1:00:00 PM	0.31
12/6/2015	1:15:00 PM	0.31
12/6/2015	1:30:00 PM	0.31
12/6/2015	1:45:00 PM	0.31
12/6/2015	2:00:00 PM	0.31
12/6/2015	2:15:00 PM	0.31
12/6/2015	2:30:00 PM	0.31
12/6/2015	2:45:00 PM	0.31
12/6/2015	3:00:00 PM	0.31
12/6/2015	3:15:00 PM	0.31
12/6/2015	3:30:00 PM	0.31
12/6/2015	3:45:00 PM	0.31
12/6/2015	4:00:00 PM	0.31
12/6/2015	4:15:00 PM	0.31
12/6/2015	4:30:00 PM	0.31
12/6/2015	4:45:00 PM	0.31
12/6/2015	5:00:00 PM	0.31
12/6/2015	5:15:00 PM	0.31
12/6/2015	5:30:00 PM	0.31
12/6/2015	5:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/6/2015	6:00:00 PM	0.31
12/6/2015	6:15:00 PM	0.31
12/6/2015	6:30:00 PM	0.31
12/6/2015	6:45:00 PM	0.31
12/6/2015	7:00:00 PM	0.31
12/6/2015	7:15:00 PM	0.31
12/6/2015	7:30:00 PM	0.31
12/6/2015	7:45:00 PM	0.31
12/6/2015	8:00:00 PM	0.31
12/6/2015	8:15:00 PM	0.31
12/6/2015	8:30:00 PM	0.31
12/6/2015	8:45:00 PM	0.31
12/6/2015	9:00:00 PM	0.31
12/6/2015	9:15:00 PM	0.31
12/6/2015	9:30:00 PM	0.31
12/6/2015	9:45:00 PM	0.31
12/6/2015	10:00:00 PM	0.31
12/6/2015	10:15:00 PM	0.31
12/6/2015	10:30:00 PM	0.31
12/6/2015	10:45:00 PM	0.31
12/6/2015	11:00:00 PM	0.31
12/6/2015	11:15:00 PM	0.31
12/6/2015	11:30:00 PM	0.31
12/6/2015	11:45:00 PM	0.31
12/7/2015	12:00:00 AM	0.31
12/7/2015	12:15:00 AM	0.31
12/7/2015	12:30:00 AM	0.31
12/7/2015	12:45:00 AM	0.31
12/7/2015	1:00:00 AM	0.31
12/7/2015	1:15:00 AM	0.31
12/7/2015	1:30:00 AM	0.31
12/7/2015	1:45:00 AM	0.31
12/7/2015	2:00:00 AM	0.31
12/7/2015	2:15:00 AM	0.31
12/7/2015	2:30:00 AM	0.31
12/7/2015	2:45:00 AM	0.31
12/7/2015	3:00:00 AM	0.31
12/7/2015	3:15:00 AM	0.31
12/7/2015	3:30:00 AM	0.31
12/7/2015	3:45:00 AM	0.31
12/7/2015	4:00:00 AM	0.31
12/7/2015	4:15:00 AM	0.31
12/7/2015	4:30:00 AM	0.31
12/7/2015	4:45:00 AM	0.31
12/7/2015	5:00:00 AM	0.31
12/7/2015	5:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/7/2015	5:30:00 AM	0.31
12/7/2015	5:45:00 AM	0.31
12/7/2015	6:00:00 AM	0.31
12/7/2015	6:15:00 AM	0.31
12/7/2015	6:30:00 AM	0.31
12/7/2015	6:45:00 AM	0.31
12/7/2015	7:00:00 AM	0.31
12/7/2015	7:15:00 AM	0.31
12/7/2015	7:30:00 AM	0.31
12/7/2015	7:45:00 AM	0.31
12/7/2015	8:00:00 AM	0.31
12/7/2015	8:15:00 AM	0.31
12/7/2015	8:30:00 AM	0.31
12/7/2015	8:45:00 AM	0.31
12/7/2015	9:00:00 AM	0.31
12/7/2015	9:15:00 AM	0.31
12/7/2015	9:30:00 AM	0.31
12/7/2015	9:45:00 AM	0.31
12/7/2015	10:00:00 AM	0.31
12/7/2015	10:15:00 AM	0.31
12/7/2015	10:30:00 AM	0.31
12/7/2015	10:45:00 AM	0.31
12/7/2015	11:00:00 AM	0.31
12/7/2015	11:15:00 AM	0.31
12/7/2015	11:30:00 AM	0.31
12/7/2015	11:45:00 AM	0.31
12/7/2015	12:00:00 PM	0.31
12/7/2015	12:15:00 PM	0.31
12/7/2015	12:30:00 PM	0.31
12/7/2015	12:45:00 PM	0.31
12/7/2015	1:00:00 PM	0.31
12/7/2015	1:15:00 PM	0.31
12/7/2015	1:30:00 PM	0.31
12/7/2015	1:45:00 PM	0.31
12/7/2015	2:00:00 PM	0.31
12/7/2015	2:15:00 PM	0.31
12/7/2015	2:30:00 PM	0.31
12/7/2015	2:45:00 PM	0.31
12/7/2015	3:00:00 PM	0.31
12/7/2015	3:15:00 PM	0.31
12/7/2015	3:30:00 PM	0.31
12/7/2015	3:45:00 PM	0.31
12/7/2015	4:00:00 PM	0.31
12/7/2015	4:15:00 PM	0.31
12/7/2015	4:30:00 PM	0.31
12/7/2015	4:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/7/2015	5:00:00 PM	0.31
12/7/2015	5:15:00 PM	0.31
12/7/2015	5:30:00 PM	0.31
12/7/2015	5:45:00 PM	0.31
12/7/2015	6:00:00 PM	0.31
12/7/2015	6:15:00 PM	0.31
12/7/2015	6:30:00 PM	0.31
12/7/2015	6:45:00 PM	0.31
12/7/2015	7:00:00 PM	0.31
12/7/2015	7:15:00 PM	0.31
12/7/2015	7:30:00 PM	0.31
12/7/2015	7:45:00 PM	0.31
12/7/2015	8:00:00 PM	0.31
12/7/2015	8:15:00 PM	0.31
12/7/2015	8:30:00 PM	0.31
12/7/2015	8:45:00 PM	0.31
12/7/2015	9:00:00 PM	0.31
12/7/2015	9:15:00 PM	0.31
12/7/2015	9:30:00 PM	0.31
12/7/2015	9:45:00 PM	0.31
12/7/2015	10:00:00 PM	0.31
12/7/2015	10:15:00 PM	0.31
12/7/2015	10:30:00 PM	0.31
12/7/2015	10:45:00 PM	0.31
12/7/2015	11:00:00 PM	0.31
12/7/2015	11:15:00 PM	0.31
12/7/2015	11:30:00 PM	0.31
12/7/2015	11:45:00 PM	0.31
12/8/2015	12:00:00 AM	0.31
12/8/2015	12:15:00 AM	0.31
12/8/2015	12:30:00 AM	0.31
12/8/2015	12:45:00 AM	0.31
12/8/2015	1:00:00 AM	0.31
12/8/2015	1:15:00 AM	0.31
12/8/2015	1:30:00 AM	0.31
12/8/2015	1:45:00 AM	0.31
12/8/2015	2:00:00 AM	0.31
12/8/2015	2:15:00 AM	0.31
12/8/2015	2:30:00 AM	0.31
12/8/2015	2:45:00 AM	0.31
12/8/2015	3:00:00 AM	0.3
12/8/2015	3:15:00 AM	0.3
12/8/2015	3:30:00 AM	0.3
12/8/2015	3:45:00 AM	0.3
12/8/2015	4:00:00 AM	0.3
12/8/2015	4:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/8/2015	4:30:00 AM	0.3
12/8/2015	4:45:00 AM	0.3
12/8/2015	5:00:00 AM	0.3
12/8/2015	5:15:00 AM	0.3
12/8/2015	5:30:00 AM	0.3
12/8/2015	5:45:00 AM	0.3
12/8/2015	6:00:00 AM	0.3
12/8/2015	6:15:00 AM	0.3
12/8/2015	6:30:00 AM	0.3
12/8/2015	6:45:00 AM	0.3
12/8/2015	7:00:00 AM	0.3
12/8/2015	7:15:00 AM	0.3
12/8/2015	7:30:00 AM	0.3
12/8/2015	7:45:00 AM	0.3
12/8/2015	8:00:00 AM	0.3
12/8/2015	8:15:00 AM	0.3
12/8/2015	8:30:00 AM	0.3
12/8/2015	8:45:00 AM	0.3
12/8/2015	9:00:00 AM	0.3
12/8/2015	9:15:00 AM	0.3
12/8/2015	9:30:00 AM	0.3
12/8/2015	9:45:00 AM	0.3
12/8/2015	10:00:00 AM	0.3
12/8/2015	10:15:00 AM	0.3
12/8/2015	10:30:00 AM	0.3
12/8/2015	10:45:00 AM	0.3
12/8/2015	11:00:00 AM	0.3
12/8/2015	11:15:00 AM	0.3
12/8/2015	11:30:00 AM	0.3
12/8/2015	11:45:00 AM	0.3
12/8/2015	12:00:00 PM	0.3
12/8/2015	12:15:00 PM	0.3
12/8/2015	12:30:00 PM	0.3
12/8/2015	12:45:00 PM	0.3
12/8/2015	1:00:00 PM	0.3
12/8/2015	1:15:00 PM	0.3
12/8/2015	1:30:00 PM	0.3
12/8/2015	1:45:00 PM	0.3
12/8/2015	2:00:00 PM	0.3
12/8/2015	2:15:00 PM	0.3
12/8/2015	2:30:00 PM	0.3
12/8/2015	2:45:00 PM	0.3
12/8/2015	3:00:00 PM	0.3
12/8/2015	3:15:00 PM	0.3
12/8/2015	3:30:00 PM	0.3
12/8/2015	3:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/8/2015	4:00:00 PM	0.3
12/8/2015	4:15:00 PM	0.3
12/8/2015	4:30:00 PM	0.3
12/8/2015	4:45:00 PM	0.3
12/8/2015	5:00:00 PM	0.3
12/8/2015	5:15:00 PM	0.3
12/8/2015	5:30:00 PM	0.3
12/8/2015	5:45:00 PM	0.3
12/8/2015	6:00:00 PM	0.3
12/8/2015	6:15:00 PM	0.3
12/8/2015	6:30:00 PM	0.3
12/8/2015	6:45:00 PM	0.3
12/8/2015	7:00:00 PM	0.3
12/8/2015	7:15:00 PM	0.3
12/8/2015	7:30:00 PM	0.3
12/8/2015	7:45:00 PM	0.3
12/8/2015	8:00:00 PM	0.3
12/8/2015	8:15:00 PM	0.3
12/8/2015	8:30:00 PM	0.3
12/8/2015	8:45:00 PM	0.3
12/8/2015	9:00:00 PM	0.3
12/8/2015	9:15:00 PM	0.3
12/8/2015	9:30:00 PM	0.3
12/8/2015	9:45:00 PM	0.3
12/8/2015	10:00:00 PM	0.3
12/8/2015	10:15:00 PM	0.3
12/8/2015	10:30:00 PM	0.3
12/8/2015	10:45:00 PM	0.3
12/8/2015	11:00:00 PM	0.3
12/8/2015	11:15:00 PM	0.3
12/8/2015	11:30:00 PM	0.3
12/8/2015	11:45:00 PM	0.3
12/9/2015	12:00:00 AM	0.3
12/9/2015	12:15:00 AM	0.3
12/9/2015	12:30:00 AM	0.3
12/9/2015	12:45:00 AM	0.3
12/9/2015	1:00:00 AM	0.3
12/9/2015	1:15:00 AM	0.3
12/9/2015	1:30:00 AM	0.3
12/9/2015	1:45:00 AM	0.3
12/9/2015	2:00:00 AM	0.3
12/9/2015	2:15:00 AM	0.3
12/9/2015	2:30:00 AM	0.3
12/9/2015	2:45:00 AM	0.3
12/9/2015	3:00:00 AM	0.3
12/9/2015	3:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/9/2015	3:30:00 AM	0.3
12/9/2015	3:45:00 AM	0.3
12/9/2015	4:00:00 AM	0.3
12/9/2015	4:15:00 AM	0.3
12/9/2015	4:30:00 AM	0.3
12/9/2015	4:45:00 AM	0.3
12/9/2015	5:00:00 AM	0.3
12/9/2015	5:15:00 AM	0.3
12/9/2015	5:30:00 AM	0.3
12/9/2015	5:45:00 AM	0.3
12/9/2015	6:00:00 AM	0.3
12/9/2015	6:15:00 AM	0.3
12/9/2015	6:30:00 AM	0.3
12/9/2015	6:45:00 AM	0.3
12/9/2015	7:00:00 AM	0.3
12/9/2015	7:15:00 AM	0.3
12/9/2015	7:30:00 AM	0.3
12/9/2015	7:45:00 AM	0.3
12/9/2015	8:00:00 AM	0.3
12/9/2015	8:15:00 AM	0.3
12/9/2015	8:30:00 AM	0.3
12/9/2015	8:45:00 AM	0.3
12/9/2015	9:00:00 AM	0.3
12/9/2015	9:15:00 AM	0.3
12/9/2015	9:30:00 AM	0.3
12/9/2015	9:45:00 AM	0.3
12/9/2015	10:00:00 AM	0.3
12/9/2015	10:15:00 AM	0.3
12/9/2015	10:30:00 AM	0.3
12/9/2015	10:45:00 AM	0.3
12/9/2015	11:00:00 AM	0.3
12/9/2015	11:15:00 AM	0.3
12/9/2015	11:30:00 AM	0.3
12/9/2015	11:45:00 AM	0.3
12/9/2015	12:00:00 PM	0.3
12/9/2015	12:15:00 PM	0.3
12/9/2015	12:30:00 PM	0.3
12/9/2015	12:45:00 PM	0.3
12/9/2015	1:00:00 PM	0.3
12/9/2015	1:15:00 PM	0.3
12/9/2015	1:30:00 PM	0.3
12/9/2015	1:45:00 PM	0.3
12/9/2015	2:00:00 PM	0.3
12/9/2015	2:15:00 PM	0.3
12/9/2015	2:30:00 PM	0.3
12/9/2015	2:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/9/2015	3:00:00 PM	0.3
12/9/2015	3:15:00 PM	0.3
12/9/2015	3:30:00 PM	0.3
12/9/2015	3:45:00 PM	0.3
12/9/2015	4:00:00 PM	0.3
12/9/2015	4:15:00 PM	0.3
12/9/2015	4:30:00 PM	0.3
12/9/2015	4:45:00 PM	0.3
12/9/2015	5:00:00 PM	0.3
12/9/2015	5:15:00 PM	0.3
12/9/2015	5:30:00 PM	0.3
12/9/2015	5:45:00 PM	0.3
12/9/2015	6:00:00 PM	0.3
12/9/2015	6:15:00 PM	0.3
12/9/2015	6:30:00 PM	0.3
12/9/2015	6:45:00 PM	0.3
12/9/2015	7:00:00 PM	0.3
12/9/2015	7:15:00 PM	0.3
12/9/2015	7:30:00 PM	0.3
12/9/2015	7:45:00 PM	0.3
12/9/2015	8:00:00 PM	0.3
12/9/2015	8:15:00 PM	0.3
12/9/2015	8:30:00 PM	0.3
12/9/2015	8:45:00 PM	0.3
12/9/2015	9:00:00 PM	0.3
12/9/2015	9:15:00 PM	0.3
12/9/2015	9:30:00 PM	0.3
12/9/2015	9:45:00 PM	0.3
12/9/2015	10:00:00 PM	0.3
12/9/2015	10:15:00 PM	0.3
12/9/2015	10:30:00 PM	0.3
12/9/2015	10:45:00 PM	0.3
12/9/2015	11:00:00 PM	0.3
12/9/2015	11:15:00 PM	0.3
12/9/2015	11:30:00 PM	0.3
12/9/2015	11:45:00 PM	0.3
12/10/2015	12:00:00 AM	0.3
12/10/2015	12:15:00 AM	0.3
12/10/2015	12:30:00 AM	0.3
12/10/2015	12:45:00 AM	0.3
12/10/2015	1:00:00 AM	0.3
12/10/2015	1:15:00 AM	0.3
12/10/2015	1:30:00 AM	0.3
12/10/2015	1:45:00 AM	0.3
12/10/2015	2:00:00 AM	0.3
12/10/2015	2:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/10/2015	2:30:00 AM	0.3
12/10/2015	2:45:00 AM	0.3
12/10/2015	3:00:00 AM	0.3
12/10/2015	3:15:00 AM	0.3
12/10/2015	3:30:00 AM	0.3
12/10/2015	3:45:00 AM	0.3
12/10/2015	4:00:00 AM	0.3
12/10/2015	4:15:00 AM	0.3
12/10/2015	4:30:00 AM	0.3
12/10/2015	4:45:00 AM	0.3
12/10/2015	5:00:00 AM	0.3
12/10/2015	5:15:00 AM	0.3
12/10/2015	5:30:00 AM	0.3
12/10/2015	5:45:00 AM	0.3
12/10/2015	6:00:00 AM	0.3
12/10/2015	6:15:00 AM	0.3
12/10/2015	6:30:00 AM	0.3
12/10/2015	6:45:00 AM	0.3
12/10/2015	7:00:00 AM	0.3
12/10/2015	7:15:00 AM	0.3
12/10/2015	7:30:00 AM	0.3
12/10/2015	7:45:00 AM	0.3
12/10/2015	8:00:00 AM	0.3
12/10/2015	8:15:00 AM	0.3
12/10/2015	8:30:00 AM	0.3
12/10/2015	8:45:00 AM	0.3
12/10/2015	9:00:00 AM	0.3
12/10/2015	9:15:00 AM	0.3
12/10/2015	9:30:00 AM	0.3
12/10/2015	9:45:00 AM	0.3
12/10/2015	10:00:00 AM	0.3
12/10/2015	10:15:00 AM	0.3
12/10/2015	10:30:00 AM	0.3
12/10/2015	10:45:00 AM	0.3
12/10/2015	11:00:00 AM	0.3
12/10/2015	11:15:00 AM	0.3
12/10/2015	11:30:00 AM	0.3
12/10/2015	11:45:00 AM	0.3
12/10/2015	12:00:00 PM	0.3
12/10/2015	12:15:00 PM	0.3
12/10/2015	12:30:00 PM	0.3
12/10/2015	12:45:00 PM	0.3
12/10/2015	1:00:00 PM	0.3
12/10/2015	1:15:00 PM	0.3
12/10/2015	1:30:00 PM	0.31
12/10/2015	1:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/10/2015	2:00:00 PM	0.31
12/10/2015	2:15:00 PM	0.31
12/10/2015	2:30:00 PM	0.31
12/10/2015	2:45:00 PM	0.31
12/10/2015	3:00:00 PM	0.31
12/10/2015	3:15:00 PM	0.31
12/10/2015	3:30:00 PM	0.31
12/10/2015	3:45:00 PM	0.31
12/10/2015	4:00:00 PM	0.31
12/10/2015	4:15:00 PM	0.31
12/10/2015	4:30:00 PM	0.31
12/10/2015	4:45:00 PM	0.31
12/10/2015	5:00:00 PM	0.31
12/10/2015	5:15:00 PM	0.31
12/10/2015	5:30:00 PM	0.31
12/10/2015	5:45:00 PM	0.31
12/10/2015	6:00:00 PM	0.31
12/10/2015	6:15:00 PM	0.31
12/10/2015	6:30:00 PM	0.31
12/10/2015	6:45:00 PM	0.31
12/10/2015	7:00:00 PM	0.31
12/10/2015	7:15:00 PM	0.31
12/10/2015	7:30:00 PM	0.31
12/10/2015	7:45:00 PM	0.31
12/10/2015	8:00:00 PM	0.31
12/10/2015	8:15:00 PM	0.31
12/10/2015	8:30:00 PM	0.31
12/10/2015	8:45:00 PM	0.31
12/10/2015	9:00:00 PM	0.31
12/10/2015	9:15:00 PM	0.31
12/10/2015	9:30:00 PM	0.31
12/10/2015	9:45:00 PM	0.31
12/10/2015	10:00:00 PM	0.31
12/10/2015	10:15:00 PM	0.31
12/10/2015	10:30:00 PM	0.31
12/10/2015	10:45:00 PM	0.31
12/10/2015	11:00:00 PM	0.31
12/10/2015	11:15:00 PM	0.31
12/10/2015	11:30:00 PM	0.31
12/10/2015	11:45:00 PM	0.31
12/11/2015	12:00:00 AM	0.31
12/11/2015	12:15:00 AM	0.31
12/11/2015	12:30:00 AM	0.31
12/11/2015	12:45:00 AM	0.31
12/11/2015	1:00:00 AM	0.31
12/11/2015	1:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/11/2015	1:30:00 AM	0.31
12/11/2015	1:45:00 AM	0.31
12/11/2015	2:00:00 AM	0.31
12/11/2015	2:15:00 AM	0.31
12/11/2015	2:30:00 AM	0.31
12/11/2015	2:45:00 AM	0.31
12/11/2015	3:00:00 AM	0.31
12/11/2015	3:15:00 AM	0.31
12/11/2015	3:30:00 AM	0.31
12/11/2015	3:45:00 AM	0.31
12/11/2015	4:00:00 AM	0.31
12/11/2015	4:15:00 AM	0.31
12/11/2015	4:30:00 AM	0.31
12/11/2015	4:45:00 AM	0.31
12/11/2015	5:00:00 AM	0.31
12/11/2015	5:15:00 AM	0.31
12/11/2015	5:30:00 AM	0.31
12/11/2015	5:45:00 AM	0.31
12/11/2015	6:00:00 AM	0.31
12/11/2015	6:15:00 AM	0.31
12/11/2015	6:30:00 AM	0.31
12/11/2015	6:45:00 AM	0.31
12/11/2015	7:00:00 AM	0.31
12/11/2015	7:15:00 AM	0.31
12/11/2015	7:30:00 AM	0.31
12/11/2015	7:45:00 AM	0.31
12/11/2015	8:00:00 AM	0.31
12/11/2015	8:15:00 AM	0.31
12/11/2015	8:30:00 AM	0.31
12/11/2015	8:45:00 AM	0.31
12/11/2015	9:00:00 AM	0.31
12/11/2015	9:15:00 AM	0.31
12/11/2015	9:30:00 AM	0.31
12/11/2015	9:45:00 AM	0.31
12/11/2015	10:00:00 AM	0.31
12/11/2015	10:15:00 AM	0.31
12/11/2015	10:30:00 AM	0.31
12/11/2015	10:45:00 AM	0.31
12/11/2015	11:00:00 AM	0.31
12/11/2015	11:15:00 AM	0.31
12/11/2015	11:30:00 AM	0.31
12/11/2015	11:45:00 AM	0.31
12/11/2015	12:00:00 PM	0.31
12/11/2015	12:15:00 PM	0.31
12/11/2015	12:30:00 PM	0.31
12/11/2015	12:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/11/2015	1:00:00 PM	0.31
12/11/2015	1:15:00 PM	0.31
12/11/2015	1:30:00 PM	0.31
12/11/2015	1:45:00 PM	0.31
12/11/2015	2:00:00 PM	0.31
12/11/2015	2:15:00 PM	0.31
12/11/2015	2:30:00 PM	0.31
12/11/2015	2:45:00 PM	0.31
12/11/2015	3:00:00 PM	0.31
12/11/2015	3:15:00 PM	0.31
12/11/2015	3:30:00 PM	0.31
12/11/2015	3:45:00 PM	0.31
12/11/2015	4:00:00 PM	0.31
12/11/2015	4:15:00 PM	0.31
12/11/2015	4:30:00 PM	0.31
12/11/2015	4:45:00 PM	0.31
12/11/2015	5:00:00 PM	0.31
12/11/2015	5:15:00 PM	0.31
12/11/2015	5:30:00 PM	0.31
12/11/2015	5:45:00 PM	0.31
12/11/2015	6:00:00 PM	0.31
12/11/2015	6:15:00 PM	0.31
12/11/2015	6:30:00 PM	0.31
12/11/2015	6:45:00 PM	0.31
12/11/2015	7:00:00 PM	0.31
12/11/2015	7:15:00 PM	0.31
12/11/2015	7:30:00 PM	0.31
12/11/2015	7:45:00 PM	0.31
12/11/2015	8:00:00 PM	0.31
12/11/2015	8:15:00 PM	0.31
12/11/2015	8:30:00 PM	0.31
12/11/2015	8:45:00 PM	0.31
12/11/2015	9:00:00 PM	0.31
12/11/2015	9:15:00 PM	0.31
12/11/2015	9:30:00 PM	0.31
12/11/2015	9:45:00 PM	0.31
12/11/2015	10:00:00 PM	0.31
12/11/2015	10:15:00 PM	0.31
12/11/2015	10:30:00 PM	0.31
12/11/2015	10:45:00 PM	0.31
12/11/2015	11:00:00 PM	0.31
12/11/2015	11:15:00 PM	0.31
12/11/2015	11:30:00 PM	0.31
12/11/2015	11:45:00 PM	0.31
12/12/2015	12:00:00 AM	0.31
12/12/2015	12:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/12/2015	12:30:00 AM	0.31
12/12/2015	12:45:00 AM	0.31
12/12/2015	1:00:00 AM	0.31
12/12/2015	1:15:00 AM	0.31
12/12/2015	1:30:00 AM	0.31
12/12/2015	1:45:00 AM	0.31
12/12/2015	2:00:00 AM	0.31
12/12/2015	2:15:00 AM	0.31
12/12/2015	2:30:00 AM	0.31
12/12/2015	2:45:00 AM	0.31
12/12/2015	3:00:00 AM	0.31
12/12/2015	3:15:00 AM	0.31
12/12/2015	3:30:00 AM	0.31
12/12/2015	3:45:00 AM	0.31
12/12/2015	4:00:00 AM	0.31
12/12/2015	4:15:00 AM	0.31
12/12/2015	4:30:00 AM	0.31
12/12/2015	4:45:00 AM	0.31
12/12/2015	5:00:00 AM	0.31
12/12/2015	5:15:00 AM	0.31
12/12/2015	5:30:00 AM	0.31
12/12/2015	5:45:00 AM	0.31
12/12/2015	6:00:00 AM	0.31
12/12/2015	6:15:00 AM	0.31
12/12/2015	6:30:00 AM	0.31
12/12/2015	6:45:00 AM	0.31
12/12/2015	7:00:00 AM	0.31
12/12/2015	7:15:00 AM	0.31
12/12/2015	7:30:00 AM	0.31
12/12/2015	7:45:00 AM	0.31
12/12/2015	8:00:00 AM	0.31
12/12/2015	8:15:00 AM	0.31
12/12/2015	8:30:00 AM	0.31
12/12/2015	8:45:00 AM	0.31
12/12/2015	9:00:00 AM	0.31
12/12/2015	9:15:00 AM	0.31
12/12/2015	9:30:00 AM	0.31
12/12/2015	9:45:00 AM	0.31
12/12/2015	10:00:00 AM	0.31
12/12/2015	10:15:00 AM	0.31
12/12/2015	10:30:00 AM	0.31
12/12/2015	10:45:00 AM	0.31
12/12/2015	11:00:00 AM	0.31
12/12/2015	11:15:00 AM	0.31
12/12/2015	11:30:00 AM	0.31
12/12/2015	11:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/12/2015	12:00:00 PM	0.31
12/12/2015	12:15:00 PM	0.31
12/12/2015	12:30:00 PM	0.31
12/12/2015	12:45:00 PM	0.31
12/12/2015	1:00:00 PM	0.31
12/12/2015	1:15:00 PM	0.31
12/12/2015	1:30:00 PM	0.31
12/12/2015	1:45:00 PM	0.31
12/12/2015	2:00:00 PM	0.31
12/12/2015	2:15:00 PM	0.31
12/12/2015	2:30:00 PM	0.31
12/12/2015	2:45:00 PM	0.31
12/12/2015	3:00:00 PM	0.31
12/12/2015	3:15:00 PM	0.31
12/12/2015	3:30:00 PM	0.31
12/12/2015	3:45:00 PM	0.31
12/12/2015	4:00:00 PM	0.31
12/12/2015	4:15:00 PM	0.31
12/12/2015	4:30:00 PM	0.31
12/12/2015	4:45:00 PM	0.31
12/12/2015	5:00:00 PM	0.31
12/12/2015	5:15:00 PM	0.31
12/12/2015	5:30:00 PM	0.31
12/12/2015	5:45:00 PM	0.31
12/12/2015	6:00:00 PM	0.31
12/12/2015	6:15:00 PM	0.31
12/12/2015	6:30:00 PM	0.31
12/12/2015	6:45:00 PM	0.31
12/12/2015	7:00:00 PM	0.31
12/12/2015	7:15:00 PM	0.31
12/12/2015	7:30:00 PM	0.31
12/12/2015	7:45:00 PM	0.31
12/12/2015	8:00:00 PM	0.31
12/12/2015	8:15:00 PM	0.31
12/12/2015	8:30:00 PM	0.31
12/12/2015	8:45:00 PM	0.31
12/12/2015	9:00:00 PM	0.31
12/12/2015	9:15:00 PM	0.31
12/12/2015	9:30:00 PM	0.31
12/12/2015	9:45:00 PM	0.31
12/12/2015	10:00:00 PM	0.31
12/12/2015	10:15:00 PM	0.31
12/12/2015	10:30:00 PM	0.31
12/12/2015	10:45:00 PM	0.31
12/12/2015	11:00:00 PM	0.31
12/12/2015	11:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/12/2015	11:30:00 PM	0.31
12/12/2015	11:45:00 PM	0.31
12/13/2015	12:00:00 AM	0.31
12/13/2015	12:15:00 AM	0.31
12/13/2015	12:30:00 AM	0.31
12/13/2015	12:45:00 AM	0.31
12/13/2015	1:00:00 AM	0.31
12/13/2015	1:15:00 AM	0.31
12/13/2015	1:30:00 AM	0.31
12/13/2015	1:45:00 AM	0.31
12/13/2015	2:00:00 AM	0.31
12/13/2015	2:15:00 AM	0.31
12/13/2015	2:30:00 AM	0.31
12/13/2015	2:45:00 AM	0.31
12/13/2015	3:00:00 AM	0.31
12/13/2015	3:15:00 AM	0.31
12/13/2015	3:30:00 AM	0.31
12/13/2015	3:45:00 AM	0.31
12/13/2015	4:00:00 AM	0.31
12/13/2015	4:15:00 AM	0.31
12/13/2015	4:30:00 AM	0.31
12/13/2015	4:45:00 AM	0.31
12/13/2015	5:00:00 AM	0.31
12/13/2015	5:15:00 AM	0.31
12/13/2015	5:30:00 AM	0.31
12/13/2015	5:45:00 AM	0.31
12/13/2015	6:00:00 AM	0.31
12/13/2015	6:15:00 AM	0.31
12/13/2015	6:30:00 AM	0.31
12/13/2015	6:45:00 AM	0.31
12/13/2015	7:00:00 AM	0.31
12/13/2015	7:15:00 AM	0.31
12/13/2015	7:30:00 AM	0.31
12/13/2015	7:45:00 AM	0.31
12/13/2015	8:00:00 AM	0.31
12/13/2015	8:15:00 AM	0.31
12/13/2015	8:30:00 AM	0.31
12/13/2015	8:45:00 AM	0.31
12/13/2015	9:00:00 AM	0.31
12/13/2015	9:15:00 AM	0.31
12/13/2015	9:30:00 AM	0.31
12/13/2015	9:45:00 AM	0.31
12/13/2015	10:00:00 AM	0.31
12/13/2015	10:15:00 AM	0.31
12/13/2015	10:30:00 AM	0.31
12/13/2015	10:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/13/2015	11:00:00 AM	0.31
12/13/2015	11:15:00 AM	0.31
12/13/2015	11:30:00 AM	0.31
12/13/2015	11:45:00 AM	0.31
12/13/2015	12:00:00 PM	0.31
12/13/2015	12:15:00 PM	0.31
12/13/2015	12:30:00 PM	0.31
12/13/2015	12:45:00 PM	0.31
12/13/2015	1:00:00 PM	0.31
12/13/2015	1:15:00 PM	0.31
12/13/2015	1:30:00 PM	0.31
12/13/2015	1:45:00 PM	0.31
12/13/2015	2:00:00 PM	0.31
12/13/2015	2:15:00 PM	0.31
12/13/2015	2:30:00 PM	0.31
12/13/2015	2:45:00 PM	0.31
12/13/2015	3:00:00 PM	0.31
12/13/2015	3:15:00 PM	0.31
12/13/2015	3:30:00 PM	0.31
12/13/2015	3:45:00 PM	0.31
12/13/2015	4:00:00 PM	0.31
12/13/2015	4:15:00 PM	0.31
12/13/2015	4:30:00 PM	0.31
12/13/2015	4:45:00 PM	0.31
12/13/2015	5:00:00 PM	0.31
12/13/2015	5:15:00 PM	0.31
12/13/2015	5:30:00 PM	0.31
12/13/2015	5:45:00 PM	0.31
12/13/2015	6:00:00 PM	0.31
12/13/2015	6:15:00 PM	0.31
12/13/2015	6:30:00 PM	0.31
12/13/2015	6:45:00 PM	0.31
12/13/2015	7:00:00 PM	0.31
12/13/2015	7:15:00 PM	0.31
12/13/2015	7:30:00 PM	0.31
12/13/2015	7:45:00 PM	0.31
12/13/2015	8:00:00 PM	0.31
12/13/2015	8:15:00 PM	0.31
12/13/2015	8:30:00 PM	0.31
12/13/2015	8:45:00 PM	0.31
12/13/2015	9:00:00 PM	0.31
12/13/2015	9:15:00 PM	0.31
12/13/2015	9:30:00 PM	0.31
12/13/2015	9:45:00 PM	0.31
12/13/2015	10:00:00 PM	0.31
12/13/2015	10:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/13/2015	10:30:00 PM	0.31
12/13/2015	10:45:00 PM	0.31
12/13/2015	11:00:00 PM	0.31
12/13/2015	11:15:00 PM	0.31
12/13/2015	11:30:00 PM	0.31
12/13/2015	11:45:00 PM	0.31
12/14/2015	12:00:00 AM	0.31
12/14/2015	12:15:00 AM	0.31
12/14/2015	12:30:00 AM	0.31
12/14/2015	12:45:00 AM	0.31
12/14/2015	1:00:00 AM	0.31
12/14/2015	1:15:00 AM	0.31
12/14/2015	1:30:00 AM	0.31
12/14/2015	1:45:00 AM	0.31
12/14/2015	2:00:00 AM	0.31
12/14/2015	2:15:00 AM	0.31
12/14/2015	2:30:00 AM	0.31
12/14/2015	2:45:00 AM	0.31
12/14/2015	3:00:00 AM	0.31
12/14/2015	3:15:00 AM	0.31
12/14/2015	3:30:00 AM	0.31
12/14/2015	3:45:00 AM	0.31
12/14/2015	4:00:00 AM	0.31
12/14/2015	4:15:00 AM	0.31
12/14/2015	4:30:00 AM	0.31
12/14/2015	4:45:00 AM	0.31
12/14/2015	5:00:00 AM	0.31
12/14/2015	5:15:00 AM	0.31
12/14/2015	5:30:00 AM	0.31
12/14/2015	5:45:00 AM	0.31
12/14/2015	6:00:00 AM	0.31
12/14/2015	6:15:00 AM	0.31
12/14/2015	6:30:00 AM	0.31
12/14/2015	6:45:00 AM	0.31
12/14/2015	7:00:00 AM	0.31
12/14/2015	7:15:00 AM	0.31
12/14/2015	7:30:00 AM	0.31
12/14/2015	7:45:00 AM	0.31
12/14/2015	8:00:00 AM	0.31
12/14/2015	8:15:00 AM	0.31
12/14/2015	8:30:00 AM	0.31
12/14/2015	8:45:00 AM	0.31
12/14/2015	9:00:00 AM	0.31
12/14/2015	9:15:00 AM	0.31
12/14/2015	9:30:00 AM	0.31
12/14/2015	9:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
12/14/2015	10:00:00 AM	0.31
12/14/2015	10:15:00 AM	0.31
12/14/2015	10:30:00 AM	0.3
12/14/2015	10:45:00 AM	0.3
12/14/2015	11:00:00 AM	0.3
12/14/2015	11:15:00 AM	0.3
12/14/2015	11:30:00 AM	0.3
12/14/2015	11:45:00 AM	0.3
12/14/2015	12:00:00 PM	0.3
12/14/2015	12:15:00 PM	0.3
12/14/2015	12:30:00 PM	0.3
12/14/2015	12:45:00 PM	0.3
12/14/2015	1:00:00 PM	0.3
12/14/2015	1:15:00 PM	0.3
12/14/2015	1:30:00 PM	0.3
12/14/2015	1:45:00 PM	0.3
12/14/2015	2:00:00 PM	0.3
12/14/2015	2:15:00 PM	0.3
12/14/2015	2:30:00 PM	0.3
12/14/2015	2:45:00 PM	0.3
12/14/2015	3:00:00 PM	0.3
12/14/2015	3:15:00 PM	0.3
12/14/2015	3:30:00 PM	0.3
12/14/2015	3:45:00 PM	0.3
12/14/2015	4:00:00 PM	0.3
12/14/2015	4:15:00 PM	0.3
12/14/2015	4:30:00 PM	0.3
12/14/2015	4:45:00 PM	0.3
12/14/2015	5:00:00 PM	0.3
12/14/2015	5:15:00 PM	0.3
12/14/2015	5:30:00 PM	0.3
12/14/2015	5:45:00 PM	0.3
12/14/2015	6:00:00 PM	0.3
12/14/2015	6:15:00 PM	0.3
12/14/2015	6:30:00 PM	0.3
12/14/2015	6:45:00 PM	0.3
12/14/2015	7:00:00 PM	0.3
12/14/2015	7:15:00 PM	0.3
12/14/2015	7:30:00 PM	0.3
12/14/2015	7:45:00 PM	0.3
12/14/2015	8:00:00 PM	0.3
12/14/2015	8:15:00 PM	0.3
12/14/2015	8:30:00 PM	0.3
12/14/2015	8:45:00 PM	0.3
12/14/2015	9:00:00 PM	0.3
12/14/2015	9:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/14/2015	9:30:00 PM	0.3
12/14/2015	9:45:00 PM	0.3
12/14/2015	10:00:00 PM	0.3
12/14/2015	10:15:00 PM	0.3
12/14/2015	10:30:00 PM	0.3
12/14/2015	10:45:00 PM	0.3
12/14/2015	11:00:00 PM	0.3
12/14/2015	11:15:00 PM	0.3
12/14/2015	11:30:00 PM	0.3
12/14/2015	11:45:00 PM	0.3
12/15/2015	12:00:00 AM	0.3
12/15/2015	12:15:00 AM	0.3
12/15/2015	12:30:00 AM	0.3
12/15/2015	12:45:00 AM	0.3
12/15/2015	1:00:00 AM	0.3
12/15/2015	1:15:00 AM	0.3
12/15/2015	1:30:00 AM	0.3
12/15/2015	1:45:00 AM	0.3
12/15/2015	2:00:00 AM	0.3
12/15/2015	2:15:00 AM	0.3
12/15/2015	2:30:00 AM	0.3
12/15/2015	2:45:00 AM	0.3
12/15/2015	3:00:00 AM	0.3
12/15/2015	3:15:00 AM	0.3
12/15/2015	3:30:00 AM	0.3
12/15/2015	3:45:00 AM	0.3
12/15/2015	4:00:00 AM	0.3
12/15/2015	4:15:00 AM	0.3
12/15/2015	4:30:00 AM	0.3
12/15/2015	4:45:00 AM	0.3
12/15/2015	5:00:00 AM	0.3
12/15/2015	5:15:00 AM	0.3
12/15/2015	5:30:00 AM	0.3
12/15/2015	5:45:00 AM	0.3
12/15/2015	6:00:00 AM	0.3
12/15/2015	6:15:00 AM	0.3
12/15/2015	6:30:00 AM	0.3
12/15/2015	6:45:00 AM	0.3
12/15/2015	7:00:00 AM	0.3
12/15/2015	7:15:00 AM	0.3
12/15/2015	7:30:00 AM	0.3
12/15/2015	7:45:00 AM	0.3
12/15/2015	8:00:00 AM	0.3
12/15/2015	8:15:00 AM	0.3
12/15/2015	8:30:00 AM	0.3
12/15/2015	8:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
12/15/2015	9:00:00 AM	0.3
12/15/2015	9:15:00 AM	0.3
12/15/2015	9:30:00 AM	0.3
12/15/2015	9:45:00 AM	0.3
12/15/2015	10:00:00 AM	0.3
12/15/2015	10:15:00 AM	0.3
12/15/2015	10:30:00 AM	0.3
12/15/2015	10:45:00 AM	0.3
12/15/2015	11:00:00 AM	0.3
12/15/2015	11:15:00 AM	0.3
12/15/2015	11:30:00 AM	0.3
12/15/2015	11:45:00 AM	0.3
12/15/2015	12:00:00 PM	0.3
12/15/2015	12:15:00 PM	0.29
12/15/2015	12:30:00 PM	0.29
12/15/2015	12:45:00 PM	0.29
12/15/2015	1:00:00 PM	0.29
12/15/2015	1:15:00 PM	0.29
12/15/2015	1:30:00 PM	0.29
12/15/2015	1:45:00 PM	0.29
12/15/2015	2:00:00 PM	0.29
12/15/2015	2:15:00 PM	0.29
12/15/2015	2:30:00 PM	0.29
12/15/2015	2:45:00 PM	0.29
12/15/2015	3:00:00 PM	0.29
12/15/2015	3:15:00 PM	0.29
12/15/2015	3:30:00 PM	0.29
12/15/2015	3:45:00 PM	0.29
12/15/2015	4:00:00 PM	0.29
12/15/2015	4:15:00 PM	0.29
12/15/2015	4:30:00 PM	0.29
12/15/2015	4:45:00 PM	0.29
12/15/2015	5:00:00 PM	0.29
12/15/2015	5:15:00 PM	0.29
12/15/2015	5:30:00 PM	0.29
12/15/2015	5:45:00 PM	0.29
12/15/2015	6:00:00 PM	0.29
12/15/2015	6:15:00 PM	0.29
12/15/2015	6:30:00 PM	0.29
12/15/2015	6:45:00 PM	0.29
12/15/2015	7:00:00 PM	0.29
12/15/2015	7:15:00 PM	0.29
12/15/2015	7:30:00 PM	0.29
12/15/2015	7:45:00 PM	0.29
12/15/2015	8:00:00 PM	0.29
12/15/2015	8:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/15/2015	8:30:00 PM	0.29
12/15/2015	8:45:00 PM	0.29
12/15/2015	9:00:00 PM	0.29
12/15/2015	9:15:00 PM	0.29
12/15/2015	9:30:00 PM	0.29
12/15/2015	9:45:00 PM	0.29
12/15/2015	10:00:00 PM	0.29
12/15/2015	10:15:00 PM	0.29
12/15/2015	10:30:00 PM	0.29
12/15/2015	10:45:00 PM	0.29
12/15/2015	11:00:00 PM	0.29
12/15/2015	11:15:00 PM	0.29
12/15/2015	11:30:00 PM	0.29
12/15/2015	11:45:00 PM	0.29
12/16/2015	12:00:00 AM	0.29
12/16/2015	12:15:00 AM	0.29
12/16/2015	12:30:00 AM	0.29
12/16/2015	12:45:00 AM	0.29
12/16/2015	1:00:00 AM	0.29
12/16/2015	1:15:00 AM	0.29
12/16/2015	1:30:00 AM	0.29
12/16/2015	1:45:00 AM	0.29
12/16/2015	2:00:00 AM	0.29
12/16/2015	2:15:00 AM	0.29
12/16/2015	2:30:00 AM	0.29
12/16/2015	2:45:00 AM	0.29
12/16/2015	3:00:00 AM	0.29
12/16/2015	3:15:00 AM	0.29
12/16/2015	3:30:00 AM	0.29
12/16/2015	3:45:00 AM	0.29
12/16/2015	4:00:00 AM	0.29
12/16/2015	4:15:00 AM	0.29
12/16/2015	4:30:00 AM	0.29
12/16/2015	4:45:00 AM	0.29
12/16/2015	5:00:00 AM	0.29
12/16/2015	5:15:00 AM	0.29
12/16/2015	5:30:00 AM	0.29
12/16/2015	5:45:00 AM	0.29
12/16/2015	6:00:00 AM	0.29
12/16/2015	6:15:00 AM	0.29
12/16/2015	6:30:00 AM	0.29
12/16/2015	6:45:00 AM	0.29
12/16/2015	7:00:00 AM	0.29
12/16/2015	7:15:00 AM	0.29
12/16/2015	7:30:00 AM	0.29
12/16/2015	7:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/16/2015	8:00:00 AM	0.29
12/16/2015	8:15:00 AM	0.29
12/16/2015	8:30:00 AM	0.29
12/16/2015	8:45:00 AM	0.29
12/16/2015	9:00:00 AM	0.29
12/16/2015	9:15:00 AM	0.29
12/16/2015	9:30:00 AM	0.29
12/16/2015	9:45:00 AM	0.29
12/16/2015	10:00:00 AM	0.29
12/16/2015	10:15:00 AM	0.29
12/16/2015	10:30:00 AM	0.29
12/16/2015	10:45:00 AM	0.29
12/16/2015	11:00:00 AM	0.29
12/16/2015	11:15:00 AM	0.29
12/16/2015	11:30:00 AM	0.29
12/16/2015	11:45:00 AM	0.29
12/16/2015	12:00:00 PM	0.29
12/16/2015	12:15:00 PM	0.29
12/16/2015	12:30:00 PM	0.29
12/16/2015	12:45:00 PM	0.29
12/16/2015	1:00:00 PM	0.29
12/16/2015	1:15:00 PM	0.29
12/17/2015	10:06:00 AM	0.29
12/18/2015	10:33:00 AM	0.27
12/19/2015	11:11:00 AM	0.27
12/20/2015	2:22:00 PM	0.28
12/21/2015	10:50:00 AM	0.27
12/22/2015	9:20:00 AM	0.27
12/23/2015	9:29:00 AM	0.28
12/24/2015	7:42:00 AM	0.28
12/25/2015	10:15:00 AM	0.28
12/26/2015	11:02:00 AM	0.28
12/27/2015	8:40:00 AM	0.29
12/28/2015	3:44:00 PM	0.29
12/29/2015	8:43:00 AM	0.29
12/29/2015	12:00:00 PM	0.29
12/29/2015	12:15:00 PM	0.29
12/29/2015	12:30:00 PM	0.29
12/29/2015	12:45:00 PM	0.29
12/29/2015	1:00:00 PM	0.29
12/29/2015	1:15:00 PM	0.29
12/29/2015	1:30:00 PM	0.29
12/29/2015	1:45:00 PM	0.29
12/29/2015	2:00:00 PM	0.29
12/29/2015	2:15:00 PM	0.29
12/29/2015	2:30:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/29/2015	2:45:00 PM	0.29
12/29/2015	3:00:00 PM	0.29
12/29/2015	3:15:00 PM	0.29
12/29/2015	3:30:00 PM	0.29
12/29/2015	3:45:00 PM	0.29
12/29/2015	4:00:00 PM	0.29
12/29/2015	4:15:00 PM	0.29
12/29/2015	4:30:00 PM	0.29
12/29/2015	4:45:00 PM	0.29
12/29/2015	5:00:00 PM	0.29
12/29/2015	5:15:00 PM	0.29
12/29/2015	5:30:00 PM	0.29
12/29/2015	5:45:00 PM	0.29
12/29/2015	6:00:00 PM	0.29
12/29/2015	6:15:00 PM	0.29
12/29/2015	6:30:00 PM	0.29
12/29/2015	6:45:00 PM	0.29
12/29/2015	7:00:00 PM	0.29
12/29/2015	7:15:00 PM	0.29
12/29/2015	7:30:00 PM	0.29
12/29/2015	7:45:00 PM	0.29
12/29/2015	8:00:00 PM	0.29
12/29/2015	8:15:00 PM	0.29
12/29/2015	8:30:00 PM	0.29
12/29/2015	8:45:00 PM	0.29
12/29/2015	9:00:00 PM	0.29
12/29/2015	9:15:00 PM	0.29
12/29/2015	9:30:00 PM	0.29
12/29/2015	9:45:00 PM	0.29
12/29/2015	10:00:00 PM	0.29
12/29/2015	10:15:00 PM	0.29
12/29/2015	10:30:00 PM	0.29
12/29/2015	10:45:00 PM	0.29
12/29/2015	11:00:00 PM	0.29
12/29/2015	11:15:00 PM	0.29
12/29/2015	11:30:00 PM	0.29
12/29/2015	11:45:00 PM	0.29
12/30/2015	12:00:00 AM	0.29
12/30/2015	12:15:00 AM	0.29
12/30/2015	12:30:00 AM	0.29
12/30/2015	12:45:00 AM	0.29
12/30/2015	1:00:00 AM	0.29
12/30/2015	1:15:00 AM	0.29
12/30/2015	1:30:00 AM	0.29
12/30/2015	1:45:00 AM	0.29
12/30/2015	2:00:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/30/2015	2:15:00 AM	0.29
12/30/2015	2:30:00 AM	0.29
12/30/2015	2:45:00 AM	0.29
12/30/2015	3:00:00 AM	0.29
12/30/2015	3:15:00 AM	0.29
12/30/2015	3:30:00 AM	0.29
12/30/2015	3:45:00 AM	0.29
12/30/2015	4:00:00 AM	0.29
12/30/2015	4:15:00 AM	0.29
12/30/2015	4:30:00 AM	0.29
12/30/2015	4:45:00 AM	0.29
12/30/2015	5:00:00 AM	0.29
12/30/2015	5:15:00 AM	0.29
12/30/2015	5:30:00 AM	0.29
12/30/2015	5:45:00 AM	0.29
12/30/2015	6:00:00 AM	0.29
12/30/2015	6:15:00 AM	0.29
12/30/2015	6:30:00 AM	0.29
12/30/2015	6:45:00 AM	0.29
12/30/2015	7:00:00 AM	0.29
12/30/2015	7:15:00 AM	0.29
12/30/2015	7:30:00 AM	0.29
12/30/2015	7:45:00 AM	0.29
12/30/2015	8:00:00 AM	0.29
12/30/2015	8:15:00 AM	0.29
12/30/2015	8:30:00 AM	0.29
12/30/2015	8:45:00 AM	0.29
12/30/2015	9:00:00 AM	0.29
12/30/2015	9:15:00 AM	0.29
12/30/2015	9:30:00 AM	0.29
12/30/2015	9:45:00 AM	0.29
12/30/2015	10:00:00 AM	0.29
12/30/2015	10:15:00 AM	0.29
12/30/2015	10:30:00 AM	0.29
12/30/2015	10:45:00 AM	0.29
12/30/2015	11:00:00 AM	0.29
12/30/2015	11:15:00 AM	0.29
12/30/2015	11:30:00 AM	0.29
12/30/2015	11:45:00 AM	0.29
12/30/2015	12:00:00 PM	0.29
12/30/2015	12:15:00 PM	0.29
12/30/2015	12:30:00 PM	0.29
12/30/2015	12:45:00 PM	0.29
12/30/2015	1:00:00 PM	0.29
12/30/2015	1:15:00 PM	0.29
12/30/2015	1:30:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/30/2015	1:45:00 PM	0.29
12/30/2015	2:00:00 PM	0.29
12/30/2015	2:15:00 PM	0.29
12/30/2015	2:30:00 PM	0.29
12/30/2015	2:45:00 PM	0.29
12/30/2015	3:00:00 PM	0.29
12/30/2015	3:15:00 PM	0.29
12/30/2015	3:30:00 PM	0.29
12/30/2015	3:45:00 PM	0.29
12/30/2015	4:00:00 PM	0.29
12/30/2015	4:15:00 PM	0.29
12/30/2015	4:30:00 PM	0.29
12/30/2015	4:45:00 PM	0.29
12/30/2015	5:00:00 PM	0.29
12/30/2015	5:15:00 PM	0.29
12/30/2015	5:30:00 PM	0.29
12/30/2015	5:45:00 PM	0.29
12/30/2015	6:00:00 PM	0.29
12/30/2015	6:15:00 PM	0.29
12/30/2015	6:30:00 PM	0.29
12/30/2015	6:45:00 PM	0.29
12/30/2015	7:00:00 PM	0.29
12/30/2015	7:15:00 PM	0.29
12/30/2015	7:30:00 PM	0.29
12/30/2015	7:45:00 PM	0.29
12/30/2015	8:00:00 PM	0.29
12/30/2015	8:15:00 PM	0.29
12/30/2015	8:30:00 PM	0.29
12/30/2015	8:45:00 PM	0.29
12/30/2015	9:00:00 PM	0.29
12/30/2015	9:15:00 PM	0.29
12/30/2015	9:30:00 PM	0.29
12/30/2015	9:45:00 PM	0.29
12/30/2015	10:00:00 PM	0.29
12/30/2015	10:15:00 PM	0.29
12/30/2015	10:30:00 PM	0.29
12/30/2015	10:45:00 PM	0.29
12/30/2015	11:00:00 PM	0.29
12/30/2015	11:15:00 PM	0.29
12/30/2015	11:30:00 PM	0.29
12/30/2015	11:45:00 PM	0.29
12/31/2015	12:00:00 AM	0.29
12/31/2015	12:15:00 AM	0.29
12/31/2015	12:30:00 AM	0.29
12/31/2015	12:45:00 AM	0.29
12/31/2015	1:00:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/31/2015	1:15:00 AM	0.29
12/31/2015	1:30:00 AM	0.29
12/31/2015	1:45:00 AM	0.29
12/31/2015	2:00:00 AM	0.29
12/31/2015	2:15:00 AM	0.29
12/31/2015	2:30:00 AM	0.29
12/31/2015	2:45:00 AM	0.29
12/31/2015	3:00:00 AM	0.29
12/31/2015	3:15:00 AM	0.29
12/31/2015	3:30:00 AM	0.29
12/31/2015	3:45:00 AM	0.29
12/31/2015	4:00:00 AM	0.29
12/31/2015	4:15:00 AM	0.29
12/31/2015	4:30:00 AM	0.29
12/31/2015	4:45:00 AM	0.29
12/31/2015	5:00:00 AM	0.29
12/31/2015	5:15:00 AM	0.29
12/31/2015	5:30:00 AM	0.29
12/31/2015	5:45:00 AM	0.29
12/31/2015	6:00:00 AM	0.29
12/31/2015	6:15:00 AM	0.29
12/31/2015	6:30:00 AM	0.29
12/31/2015	6:45:00 AM	0.29
12/31/2015	7:00:00 AM	0.29
12/31/2015	7:15:00 AM	0.29
12/31/2015	7:30:00 AM	0.29
12/31/2015	7:45:00 AM	0.29
12/31/2015	8:00:00 AM	0.29
12/31/2015	8:15:00 AM	0.29
12/31/2015	8:30:00 AM	0.29
12/31/2015	8:45:00 AM	0.29
12/31/2015	9:00:00 AM	0.29
12/31/2015	9:15:00 AM	0.29
12/31/2015	9:30:00 AM	0.29
12/31/2015	9:45:00 AM	0.29
12/31/2015	10:00:00 AM	0.29
12/31/2015	10:15:00 AM	0.29
12/31/2015	10:30:00 AM	0.29
12/31/2015	10:45:00 AM	0.29
12/31/2015	11:00:00 AM	0.29
12/31/2015	11:15:00 AM	0.29
12/31/2015	11:30:00 AM	0.29
12/31/2015	11:45:00 AM	0.29
12/31/2015	12:00:00 PM	0.29
12/31/2015	12:15:00 PM	0.29
12/31/2015	12:30:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
12/31/2015	12:45:00 PM	0.29
12/31/2015	1:00:00 PM	0.29
12/31/2015	1:15:00 PM	0.29
12/31/2015	1:30:00 PM	0.29
12/31/2015	1:45:00 PM	0.29
12/31/2015	2:00:00 PM	0.29
12/31/2015	2:15:00 PM	0.29
12/31/2015	2:30:00 PM	0.29
12/31/2015	2:45:00 PM	0.29
12/31/2015	3:00:00 PM	0.29
12/31/2015	3:15:00 PM	0.29
12/31/2015	3:30:00 PM	0.29
12/31/2015	3:45:00 PM	0.29
12/31/2015	4:00:00 PM	0.29
12/31/2015	4:15:00 PM	0.29
12/31/2015	4:30:00 PM	0.29
12/31/2015	4:45:00 PM	0.29
12/31/2015	5:00:00 PM	0.29
12/31/2015	5:15:00 PM	0.29
12/31/2015	5:30:00 PM	0.29
12/31/2015	5:45:00 PM	0.29
12/31/2015	6:00:00 PM	0.29
12/31/2015	6:15:00 PM	0.29
12/31/2015	6:30:00 PM	0.29
12/31/2015	6:45:00 PM	0.29
12/31/2015	7:00:00 PM	0.29
12/31/2015	7:15:00 PM	0.29
12/31/2015	7:30:00 PM	0.29
12/31/2015	7:45:00 PM	0.29
12/31/2015	8:00:00 PM	0.29
12/31/2015	8:15:00 PM	0.29
12/31/2015	8:30:00 PM	0.29
12/31/2015	8:45:00 PM	0.29
12/31/2015	9:00:00 PM	0.29
12/31/2015	9:15:00 PM	0.29
12/31/2015	9:30:00 PM	0.29
12/31/2015	9:45:00 PM	0.29
12/31/2015	10:00:00 PM	0.29
12/31/2015	10:15:00 PM	0.29
12/31/2015	10:30:00 PM	0.29
12/31/2015	10:45:00 PM	0.29
12/31/2015	11:00:00 PM	0.29
12/31/2015	11:15:00 PM	0.29
12/31/2015	11:30:00 PM	0.29
12/31/2015	11:45:00 PM	0.29
11/19/2015	4:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
11/19/2015	5:00:00 AM	0.28
11/19/2015	5:15:00 AM	0.28
11/19/2015	5:30:00 AM	0.28
11/19/2015	5:45:00 AM	0.28
11/19/2015	6:00:00 AM	0.28
11/19/2015	6:15:00 AM	0.28
11/19/2015	6:30:00 AM	0.28
11/19/2015	6:45:00 AM	0.28
11/19/2015	7:00:00 AM	0.28
11/19/2015	7:15:00 AM	0.28
11/19/2015	7:30:00 AM	0.28
11/19/2015	7:45:00 AM	0.28
11/19/2015	8:00:00 AM	0.28
11/19/2015	8:15:00 AM	0.28
11/19/2015	8:30:00 AM	0.28
11/19/2015	8:45:00 AM	0.28
11/19/2015	9:00:00 AM	0.28
11/19/2015	9:15:00 AM	0.28
11/19/2015	9:30:00 AM	0.28
11/19/2015	9:45:00 AM	0.29
11/19/2015	10:00:00 AM	0.29
11/19/2015	10:15:00 AM	0.29
11/19/2015	10:30:00 AM	0.29
11/19/2015	10:45:00 AM	0.29
11/19/2015	11:00:00 AM	0.29
11/19/2015	11:15:00 AM	0.29
11/19/2015	11:30:00 AM	0.29
11/19/2015	11:45:00 AM	0.29
11/19/2015	12:00:00 PM	0.29
11/19/2015	12:15:00 PM	0.29
11/19/2015	12:30:00 PM	0.29
11/19/2015	12:45:00 PM	0.29
11/19/2015	1:00:00 PM	0.29
11/19/2015	1:15:00 PM	0.29
11/19/2015	1:30:00 PM	0.29
11/19/2015	1:45:00 PM	0.29
11/19/2015	2:00:00 PM	0.29
11/19/2015	2:15:00 PM	0.29
11/19/2015	2:30:00 PM	0.29
11/19/2015	2:45:00 PM	0.29
11/19/2015	3:00:00 PM	0.29
11/19/2015	3:15:00 PM	0.29
11/19/2015	3:30:00 PM	0.29
11/19/2015	3:45:00 PM	0.29
11/19/2015	4:00:00 PM	0.29
11/19/2015	4:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/19/2015	4:30:00 PM	0.29
11/19/2015	4:45:00 PM	0.29
11/19/2015	5:00:00 PM	0.29
11/19/2015	5:15:00 PM	0.29
11/19/2015	5:30:00 PM	0.29
11/19/2015	5:45:00 PM	0.29
11/19/2015	6:00:00 PM	0.29
11/19/2015	6:15:00 PM	0.29
11/19/2015	6:30:00 PM	0.29
11/19/2015	6:45:00 PM	0.29
11/19/2015	7:00:00 PM	0.29
11/19/2015	7:15:00 PM	0.29
11/19/2015	7:30:00 PM	0.29
11/19/2015	7:45:00 PM	0.29
11/19/2015	8:00:00 PM	0.29
11/19/2015	8:15:00 PM	0.29
11/19/2015	8:30:00 PM	0.29
11/19/2015	8:45:00 PM	0.29
11/19/2015	9:00:00 PM	0.29
11/19/2015	9:15:00 PM	0.29
11/19/2015	9:30:00 PM	0.29
11/19/2015	9:45:00 PM	0.29
11/19/2015	10:00:00 PM	0.29
11/19/2015	10:15:00 PM	0.29
11/19/2015	10:30:00 PM	0.29
11/19/2015	10:45:00 PM	0.29
11/19/2015	11:00:00 PM	0.29
11/19/2015	11:15:00 PM	0.29
11/19/2015	11:30:00 PM	0.29
11/19/2015	11:45:00 PM	0.29
11/20/2015	12:00:00 AM	0.29
11/20/2015	12:15:00 AM	0.29
11/20/2015	12:30:00 AM	0.29
11/20/2015	12:45:00 AM	0.29
11/20/2015	1:00:00 AM	0.29
11/20/2015	1:15:00 AM	0.29
11/20/2015	1:30:00 AM	0.29
11/20/2015	1:45:00 AM	0.29
11/20/2015	2:00:00 AM	0.29
11/20/2015	2:15:00 AM	0.29
11/20/2015	2:30:00 AM	0.29
11/20/2015	2:45:00 AM	0.29
11/20/2015	3:00:00 AM	0.29
11/20/2015	3:15:00 AM	0.29
11/20/2015	3:30:00 AM	0.29
11/20/2015	3:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/20/2015	4:00:00 AM	0.29
11/20/2015	4:15:00 AM	0.29
11/20/2015	4:30:00 AM	0.29
11/20/2015	4:45:00 AM	0.29
11/20/2015	5:00:00 AM	0.29
11/20/2015	5:15:00 AM	0.29
11/20/2015	5:30:00 AM	0.29
11/20/2015	5:45:00 AM	0.29
11/20/2015	6:00:00 AM	0.29
11/20/2015	6:15:00 AM	0.29
11/20/2015	6:30:00 AM	0.29
11/20/2015	6:45:00 AM	0.29
11/20/2015	7:00:00 AM	0.29
11/20/2015	7:15:00 AM	0.29
11/20/2015	7:30:00 AM	0.29
11/20/2015	7:45:00 AM	0.29
11/20/2015	8:00:00 AM	0.29
11/20/2015	8:15:00 AM	0.29
11/20/2015	8:30:00 AM	0.29
11/20/2015	8:45:00 AM	0.29
11/20/2015	9:00:00 AM	0.29
11/20/2015	9:15:00 AM	0.29
11/20/2015	9:30:00 AM	0.29
11/20/2015	9:45:00 AM	0.29
11/20/2015	10:00:00 AM	0.29
11/20/2015	10:15:00 AM	0.29
11/20/2015	10:30:00 AM	0.29
11/20/2015	10:45:00 AM	0.29
11/20/2015	11:00:00 AM	0.29
11/20/2015	11:15:00 AM	0.29
11/20/2015	11:30:00 AM	0.29
11/20/2015	11:45:00 AM	0.29
11/20/2015	12:00:00 PM	0.29
11/20/2015	12:15:00 PM	0.29
11/20/2015	12:30:00 PM	0.29
11/20/2015	12:45:00 PM	0.29
11/20/2015	1:00:00 PM	0.29
11/20/2015	1:15:00 PM	0.29
11/20/2015	1:30:00 PM	0.29
11/20/2015	1:45:00 PM	0.29
11/20/2015	2:00:00 PM	0.29
11/20/2015	2:15:00 PM	0.29
11/20/2015	2:30:00 PM	0.29
11/20/2015	2:45:00 PM	0.29
11/20/2015	3:00:00 PM	0.29
11/20/2015	3:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/20/2015	3:30:00 PM	0.29
11/20/2015	3:45:00 PM	0.29
11/20/2015	4:00:00 PM	0.29
11/20/2015	4:15:00 PM	0.29
11/20/2015	4:30:00 PM	0.29
11/20/2015	4:45:00 PM	0.29
11/20/2015	5:00:00 PM	0.29
11/20/2015	5:15:00 PM	0.29
11/20/2015	5:30:00 PM	0.29
11/20/2015	5:45:00 PM	0.29
11/20/2015	6:00:00 PM	0.29
11/20/2015	6:15:00 PM	0.29
11/20/2015	6:30:00 PM	0.29
11/20/2015	6:45:00 PM	0.29
11/20/2015	7:00:00 PM	0.29
11/20/2015	7:15:00 PM	0.29
11/20/2015	7:30:00 PM	0.29
11/20/2015	7:45:00 PM	0.29
11/20/2015	8:00:00 PM	0.29
11/20/2015	8:15:00 PM	0.29
11/20/2015	8:30:00 PM	0.29
11/20/2015	8:45:00 PM	0.29
11/20/2015	9:00:00 PM	0.29
11/20/2015	9:15:00 PM	0.29
11/20/2015	9:30:00 PM	0.29
11/20/2015	9:45:00 PM	0.29
11/20/2015	10:00:00 PM	0.29
11/20/2015	10:15:00 PM	0.29
11/20/2015	10:30:00 PM	0.29
11/20/2015	10:45:00 PM	0.29
11/20/2015	11:00:00 PM	0.29
11/20/2015	11:15:00 PM	0.29
11/20/2015	11:30:00 PM	0.29
11/20/2015	11:45:00 PM	0.29
11/21/2015	12:00:00 AM	0.29
11/21/2015	12:15:00 AM	0.29
11/21/2015	12:30:00 AM	0.29
11/21/2015	12:45:00 AM	0.29
11/21/2015	1:00:00 AM	0.29
11/21/2015	1:15:00 AM	0.29
11/21/2015	1:30:00 AM	0.29
11/21/2015	1:45:00 AM	0.29
11/21/2015	2:00:00 AM	0.29
11/21/2015	2:15:00 AM	0.29
11/21/2015	2:30:00 AM	0.29
11/21/2015	2:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/21/2015	3:00:00 AM	0.29
11/21/2015	3:15:00 AM	0.29
11/21/2015	3:30:00 AM	0.29
11/21/2015	3:45:00 AM	0.29
11/21/2015	4:00:00 AM	0.29
11/21/2015	4:15:00 AM	0.29
11/21/2015	4:30:00 AM	0.29
11/21/2015	4:45:00 AM	0.29
11/21/2015	5:00:00 AM	0.29
11/21/2015	5:15:00 AM	0.29
11/21/2015	5:30:00 AM	0.29
11/21/2015	5:45:00 AM	0.29
11/21/2015	6:00:00 AM	0.29
11/21/2015	6:15:00 AM	0.29
11/21/2015	6:30:00 AM	0.29
11/21/2015	6:45:00 AM	0.29
11/21/2015	7:00:00 AM	0.29
11/21/2015	7:15:00 AM	0.29
11/21/2015	7:30:00 AM	0.29
11/21/2015	7:45:00 AM	0.29
11/21/2015	8:00:00 AM	0.29
11/21/2015	8:15:00 AM	0.29
11/21/2015	8:30:00 AM	0.29
11/21/2015	8:45:00 AM	0.29
11/21/2015	9:00:00 AM	0.29
11/21/2015	9:15:00 AM	0.29
11/21/2015	9:30:00 AM	0.29
11/21/2015	9:45:00 AM	0.29
11/21/2015	10:00:00 AM	0.29
11/21/2015	10:15:00 AM	0.29
11/21/2015	10:30:00 AM	0.29
11/21/2015	10:45:00 AM	0.29
11/21/2015	11:00:00 AM	0.29
11/21/2015	11:15:00 AM	0.29
11/21/2015	11:30:00 AM	0.29
11/21/2015	11:45:00 AM	0.29
11/21/2015	12:00:00 PM	0.29
11/21/2015	12:15:00 PM	0.29
11/21/2015	12:30:00 PM	0.29
11/21/2015	12:45:00 PM	0.29
11/21/2015	1:00:00 PM	0.29
11/21/2015	1:15:00 PM	0.29
11/21/2015	1:30:00 PM	0.29
11/21/2015	1:45:00 PM	0.29
11/21/2015	2:00:00 PM	0.29
11/21/2015	2:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/21/2015	2:30:00 PM	0.29
11/21/2015	2:45:00 PM	0.29
11/21/2015	3:00:00 PM	0.29
11/21/2015	3:15:00 PM	0.29
11/21/2015	3:30:00 PM	0.29
11/21/2015	3:45:00 PM	0.29
11/21/2015	4:00:00 PM	0.29
11/21/2015	4:15:00 PM	0.29
11/21/2015	4:30:00 PM	0.29
11/21/2015	4:45:00 PM	0.29
11/21/2015	5:00:00 PM	0.29
11/21/2015	5:15:00 PM	0.29
11/21/2015	5:30:00 PM	0.29
11/21/2015	5:45:00 PM	0.29
11/21/2015	6:00:00 PM	0.29
11/21/2015	6:15:00 PM	0.29
11/21/2015	6:30:00 PM	0.29
11/21/2015	6:45:00 PM	0.29
11/21/2015	7:00:00 PM	0.29
11/21/2015	7:15:00 PM	0.29
11/21/2015	7:30:00 PM	0.29
11/21/2015	7:45:00 PM	0.29
11/21/2015	8:00:00 PM	0.29
11/21/2015	8:15:00 PM	0.29
11/21/2015	8:30:00 PM	0.29
11/21/2015	8:45:00 PM	0.29
11/21/2015	9:00:00 PM	0.29
11/21/2015	9:15:00 PM	0.29
11/21/2015	9:30:00 PM	0.29
11/21/2015	9:45:00 PM	0.29
11/21/2015	10:00:00 PM	0.29
11/21/2015	10:15:00 PM	0.29
11/21/2015	10:30:00 PM	0.29
11/21/2015	10:45:00 PM	0.29
11/21/2015	11:00:00 PM	0.29
11/21/2015	11:15:00 PM	0.29
11/21/2015	11:30:00 PM	0.29
11/21/2015	11:45:00 PM	0.29
11/22/2015	12:00:00 AM	0.29
11/22/2015	12:15:00 AM	0.29
11/22/2015	12:30:00 AM	0.29
11/22/2015	12:45:00 AM	0.29
11/22/2015	1:00:00 AM	0.29
11/22/2015	1:15:00 AM	0.29
11/22/2015	1:30:00 AM	0.29
11/22/2015	1:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/22/2015	2:00:00 AM	0.29
11/22/2015	2:15:00 AM	0.29
11/22/2015	2:30:00 AM	0.29
11/22/2015	2:45:00 AM	0.29
11/22/2015	3:00:00 AM	0.29
11/22/2015	3:15:00 AM	0.29
11/22/2015	3:30:00 AM	0.29
11/22/2015	3:45:00 AM	0.29
11/22/2015	4:00:00 AM	0.29
11/22/2015	4:15:00 AM	0.29
11/22/2015	4:30:00 AM	0.29
11/22/2015	4:45:00 AM	0.29
11/22/2015	5:00:00 AM	0.29
11/22/2015	5:15:00 AM	0.29
11/22/2015	5:30:00 AM	0.29
11/22/2015	5:45:00 AM	0.29
11/22/2015	6:00:00 AM	0.29
11/22/2015	6:15:00 AM	0.29
11/22/2015	6:30:00 AM	0.29
11/22/2015	6:45:00 AM	0.29
11/22/2015	7:00:00 AM	0.29
11/22/2015	7:15:00 AM	0.29
11/22/2015	7:30:00 AM	0.29
11/22/2015	7:45:00 AM	0.29
11/22/2015	8:00:00 AM	0.29
11/22/2015	8:15:00 AM	0.29
11/22/2015	8:30:00 AM	0.29
11/22/2015	8:45:00 AM	0.29
11/22/2015	9:00:00 AM	0.29
11/22/2015	9:15:00 AM	0.29
11/22/2015	9:30:00 AM	0.29
11/22/2015	9:45:00 AM	0.29
11/22/2015	10:00:00 AM	0.29
11/22/2015	10:15:00 AM	0.29
11/22/2015	10:30:00 AM	0.29
11/22/2015	10:45:00 AM	0.29
11/22/2015	11:00:00 AM	0.29
11/22/2015	11:15:00 AM	0.3
11/22/2015	11:30:00 AM	0.3
11/22/2015	11:45:00 AM	0.3
11/22/2015	12:00:00 PM	0.3
11/22/2015	12:15:00 PM	0.3
11/22/2015	12:30:00 PM	0.3
11/22/2015	12:45:00 PM	0.3
11/22/2015	1:00:00 PM	0.3
11/22/2015	1:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/22/2015	1:30:00 PM	0.3
11/22/2015	1:45:00 PM	0.3
11/22/2015	2:00:00 PM	0.3
11/22/2015	2:15:00 PM	0.3
11/22/2015	2:30:00 PM	0.3
11/22/2015	2:45:00 PM	0.3
11/22/2015	3:00:00 PM	0.3
11/22/2015	3:15:00 PM	0.3
11/22/2015	3:30:00 PM	0.3
11/22/2015	3:45:00 PM	0.3
11/22/2015	4:00:00 PM	0.3
11/22/2015	4:15:00 PM	0.3
11/22/2015	4:30:00 PM	0.3
11/22/2015	4:45:00 PM	0.3
11/22/2015	5:00:00 PM	0.3
11/22/2015	5:15:00 PM	0.3
11/22/2015	5:30:00 PM	0.3
11/22/2015	5:45:00 PM	0.3
11/22/2015	6:00:00 PM	0.3
11/22/2015	6:15:00 PM	0.3
11/22/2015	6:30:00 PM	0.3
11/22/2015	6:45:00 PM	0.3
11/22/2015	7:00:00 PM	0.3
11/22/2015	7:15:00 PM	0.3
11/22/2015	7:30:00 PM	0.3
11/22/2015	7:45:00 PM	0.3
11/22/2015	8:00:00 PM	0.3
11/22/2015	8:15:00 PM	0.3
11/22/2015	8:30:00 PM	0.3
11/22/2015	8:45:00 PM	0.3
11/22/2015	9:00:00 PM	0.3
11/22/2015	9:15:00 PM	0.3
11/22/2015	9:30:00 PM	0.3
11/22/2015	9:45:00 PM	0.3
11/22/2015	10:00:00 PM	0.3
11/22/2015	10:15:00 PM	0.3
11/22/2015	10:30:00 PM	0.3
11/22/2015	10:45:00 PM	0.3
11/22/2015	11:00:00 PM	0.3
11/22/2015	11:15:00 PM	0.3
11/22/2015	11:30:00 PM	0.3
11/22/2015	11:45:00 PM	0.3
11/23/2015	12:00:00 AM	0.3
11/23/2015	12:15:00 AM	0.3
11/23/2015	12:30:00 AM	0.3
11/23/2015	12:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/23/2015	1:00:00 AM	0.3
11/23/2015	1:15:00 AM	0.3
11/23/2015	1:30:00 AM	0.3
11/23/2015	1:45:00 AM	0.3
11/23/2015	2:00:00 AM	0.3
11/23/2015	2:15:00 AM	0.3
11/23/2015	2:30:00 AM	0.3
11/23/2015	2:45:00 AM	0.3
11/23/2015	3:00:00 AM	0.3
11/23/2015	3:15:00 AM	0.3
11/23/2015	3:30:00 AM	0.3
11/23/2015	3:45:00 AM	0.3
11/23/2015	4:00:00 AM	0.3
11/23/2015	4:15:00 AM	0.3
11/23/2015	4:30:00 AM	0.3
11/23/2015	4:45:00 AM	0.3
11/23/2015	5:00:00 AM	0.3
11/23/2015	5:15:00 AM	0.3
11/23/2015	5:30:00 AM	0.3
11/23/2015	5:45:00 AM	0.3
11/23/2015	6:00:00 AM	0.3
11/23/2015	6:15:00 AM	0.3
11/23/2015	6:30:00 AM	0.3
11/23/2015	6:45:00 AM	0.3
11/23/2015	7:00:00 AM	0.3
11/23/2015	7:15:00 AM	0.3
11/23/2015	7:30:00 AM	0.3
11/23/2015	7:45:00 AM	0.3
11/23/2015	8:00:00 AM	0.3
11/23/2015	8:15:00 AM	0.3
11/23/2015	8:30:00 AM	0.3
11/23/2015	8:45:00 AM	0.3
11/23/2015	9:00:00 AM	0.3
11/23/2015	9:15:00 AM	0.3
11/23/2015	9:30:00 AM	0.3
11/23/2015	9:45:00 AM	0.3
11/23/2015	10:00:00 AM	0.3
11/23/2015	10:15:00 AM	0.3
11/23/2015	10:30:00 AM	0.3
11/23/2015	10:45:00 AM	0.3
11/23/2015	11:00:00 AM	0.3
11/23/2015	11:15:00 AM	0.3
11/23/2015	11:30:00 AM	0.3
11/23/2015	11:45:00 AM	0.3
11/23/2015	12:00:00 PM	0.3
11/23/2015	12:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/23/2015	12:30:00 PM	0.3
11/23/2015	12:45:00 PM	0.3
11/23/2015	1:00:00 PM	0.3
11/23/2015	1:15:00 PM	0.3
11/23/2015	1:30:00 PM	0.3
11/23/2015	1:45:00 PM	0.3
11/23/2015	2:00:00 PM	0.3
11/23/2015	2:15:00 PM	0.3
11/23/2015	2:30:00 PM	0.3
11/23/2015	2:45:00 PM	0.3
11/23/2015	3:00:00 PM	0.3
11/23/2015	3:15:00 PM	0.3
11/23/2015	3:30:00 PM	0.3
11/23/2015	3:45:00 PM	0.3
11/23/2015	4:00:00 PM	0.3
11/23/2015	4:15:00 PM	0.3
11/23/2015	4:30:00 PM	0.3
11/23/2015	4:45:00 PM	0.3
11/23/2015	5:00:00 PM	0.3
11/23/2015	5:15:00 PM	0.3
11/23/2015	5:30:00 PM	0.3
11/23/2015	5:45:00 PM	0.3
11/23/2015	6:00:00 PM	0.3
11/23/2015	6:15:00 PM	0.3
11/23/2015	6:30:00 PM	0.3
11/23/2015	6:45:00 PM	0.3
11/23/2015	7:00:00 PM	0.3
11/23/2015	7:15:00 PM	0.3
11/23/2015	7:30:00 PM	0.3
11/23/2015	7:45:00 PM	0.3
11/23/2015	8:00:00 PM	0.3
11/23/2015	8:15:00 PM	0.3
11/23/2015	8:30:00 PM	0.3
11/23/2015	8:45:00 PM	0.3
11/23/2015	9:00:00 PM	0.3
11/23/2015	9:15:00 PM	0.3
11/23/2015	9:30:00 PM	0.3
11/23/2015	9:45:00 PM	0.3
11/23/2015	10:00:00 PM	0.3
11/23/2015	10:15:00 PM	0.3
11/23/2015	10:30:00 PM	0.3
11/23/2015	10:45:00 PM	0.3
11/23/2015	11:00:00 PM	0.3
11/23/2015	11:15:00 PM	0.3
11/23/2015	11:30:00 PM	0.3
11/23/2015	11:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2015	12:00:00 AM	0.3
11/24/2015	12:15:00 AM	0.3
11/24/2015	12:30:00 AM	0.3
11/24/2015	12:45:00 AM	0.3
11/24/2015	1:00:00 AM	0.3
11/24/2015	1:15:00 AM	0.3
11/24/2015	1:30:00 AM	0.3
11/24/2015	1:45:00 AM	0.3
11/24/2015	2:00:00 AM	0.3
11/24/2015	2:15:00 AM	0.3
11/24/2015	2:30:00 AM	0.3
11/24/2015	2:45:00 AM	0.3
11/24/2015	3:00:00 AM	0.3
11/24/2015	3:15:00 AM	0.3
11/24/2015	3:30:00 AM	0.3
11/24/2015	3:45:00 AM	0.3
11/24/2015	4:00:00 AM	0.3
11/24/2015	4:15:00 AM	0.3
11/24/2015	4:30:00 AM	0.3
11/24/2015	4:45:00 AM	0.3
11/24/2015	5:00:00 AM	0.3
11/24/2015	5:15:00 AM	0.3
11/24/2015	5:30:00 AM	0.3
11/24/2015	5:45:00 AM	0.3
11/24/2015	6:00:00 AM	0.3
11/24/2015	6:15:00 AM	0.3
11/24/2015	6:30:00 AM	0.3
11/24/2015	6:45:00 AM	0.3
11/24/2015	7:00:00 AM	0.3
11/24/2015	7:15:00 AM	0.3
11/24/2015	7:30:00 AM	0.3
11/24/2015	7:45:00 AM	0.3
11/24/2015	8:00:00 AM	0.3
11/24/2015	8:15:00 AM	0.3
11/24/2015	8:30:00 AM	0.3
11/24/2015	8:45:00 AM	0.3
11/24/2015	9:00:00 AM	0.3
11/24/2015	9:15:00 AM	0.3
11/24/2015	9:30:00 AM	0.3
11/24/2015	9:45:00 AM	0.3
11/24/2015	10:00:00 AM	0.3
11/24/2015	10:15:00 AM	0.3
11/24/2015	10:30:00 AM	0.3
11/24/2015	10:45:00 AM	0.3
11/24/2015	11:00:00 AM	0.3
11/24/2015	11:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2015	11:30:00 AM	0.3
11/24/2015	11:45:00 AM	0.3
11/24/2015	12:00:00 PM	0.3
11/24/2015	12:15:00 PM	0.3
11/24/2015	12:30:00 PM	0.3
11/24/2015	12:45:00 PM	0.3
11/24/2015	1:00:00 PM	0.3
11/24/2015	1:15:00 PM	0.3
11/24/2015	1:30:00 PM	0.3
11/24/2015	1:45:00 PM	0.3
11/24/2015	2:00:00 PM	0.3
11/24/2015	2:15:00 PM	0.3
11/24/2015	2:30:00 PM	0.3
11/24/2015	2:45:00 PM	0.3
11/24/2015	3:00:00 PM	0.3
11/24/2015	3:15:00 PM	0.3
11/24/2015	3:30:00 PM	0.3
11/24/2015	3:45:00 PM	0.3
11/24/2015	4:00:00 PM	0.3
11/24/2015	4:15:00 PM	0.3
11/24/2015	4:30:00 PM	0.3
11/24/2015	4:45:00 PM	0.3
11/24/2015	5:00:00 PM	0.3
11/24/2015	5:15:00 PM	0.3
11/24/2015	5:30:00 PM	0.3
11/24/2015	5:45:00 PM	0.3
11/24/2015	6:00:00 PM	0.3
11/24/2015	6:15:00 PM	0.3
11/24/2015	6:30:00 PM	0.3
11/24/2015	6:45:00 PM	0.3
11/24/2015	7:00:00 PM	0.3
11/24/2015	7:15:00 PM	0.3
11/24/2015	7:30:00 PM	0.3
11/24/2015	7:45:00 PM	0.3
11/24/2015	8:00:00 PM	0.3
11/24/2015	8:15:00 PM	0.3
11/24/2015	8:30:00 PM	0.3
11/24/2015	8:45:00 PM	0.3
11/24/2015	9:00:00 PM	0.3
11/24/2015	9:15:00 PM	0.3
11/24/2015	9:30:00 PM	0.3
11/24/2015	9:45:00 PM	0.3
11/24/2015	10:00:00 PM	0.3
11/24/2015	10:15:00 PM	0.3
11/24/2015	10:30:00 PM	0.3
11/24/2015	10:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2015	11:00:00 PM	0.3
11/24/2015	11:15:00 PM	0.3
11/24/2015	11:30:00 PM	0.3
11/24/2015	11:45:00 PM	0.3
11/25/2015	12:00:00 AM	0.3
11/25/2015	12:15:00 AM	0.3
11/25/2015	12:30:00 AM	0.3
11/25/2015	12:45:00 AM	0.3
11/25/2015	1:00:00 AM	0.3
11/25/2015	1:15:00 AM	0.3
11/25/2015	1:30:00 AM	0.3
11/25/2015	1:45:00 AM	0.3
11/25/2015	2:00:00 AM	0.3
11/25/2015	2:15:00 AM	0.3
11/25/2015	2:30:00 AM	0.3
11/25/2015	2:45:00 AM	0.3
11/25/2015	3:00:00 AM	0.3
11/25/2015	3:15:00 AM	0.3
11/25/2015	3:30:00 AM	0.3
11/25/2015	3:45:00 AM	0.3
11/25/2015	4:00:00 AM	0.3
11/25/2015	4:15:00 AM	0.3
11/25/2015	4:30:00 AM	0.3
11/25/2015	4:45:00 AM	0.3
11/25/2015	5:00:00 AM	0.3
11/25/2015	5:15:00 AM	0.3
11/25/2015	5:30:00 AM	0.3
11/25/2015	5:45:00 AM	0.3
11/25/2015	6:00:00 AM	0.3
11/25/2015	6:15:00 AM	0.3
11/25/2015	6:30:00 AM	0.3
11/25/2015	6:45:00 AM	0.3
11/25/2015	7:00:00 AM	0.3
11/25/2015	7:15:00 AM	0.3
11/25/2015	7:30:00 AM	0.3
11/25/2015	7:45:00 AM	0.3
11/25/2015	8:00:00 AM	0.3
11/25/2015	8:15:00 AM	0.3
11/25/2015	8:30:00 AM	0.3
11/25/2015	8:45:00 AM	0.3
11/25/2015	9:00:00 AM	0.3
11/25/2015	9:15:00 AM	0.3
11/25/2015	9:30:00 AM	0.3
11/25/2015	9:45:00 AM	0.3
11/25/2015	10:00:00 AM	0.3
11/25/2015	10:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/25/2015	10:30:00 AM	0.3
11/25/2015	10:45:00 AM	0.3
11/25/2015	11:00:00 AM	0.3
11/25/2015	11:15:00 AM	0.3
11/25/2015	11:30:00 AM	0.3
11/25/2015	11:45:00 AM	0.3
11/25/2015	12:00:00 PM	0.3
11/25/2015	12:15:00 PM	0.3
11/25/2015	12:30:00 PM	0.3
11/25/2015	12:45:00 PM	0.3
11/25/2015	1:00:00 PM	0.3
11/25/2015	1:15:00 PM	0.3
11/25/2015	1:30:00 PM	0.3
11/25/2015	1:45:00 PM	0.3
11/25/2015	2:00:00 PM	0.3
11/25/2015	2:15:00 PM	0.3
11/25/2015	2:30:00 PM	0.3
11/25/2015	2:45:00 PM	0.3
11/25/2015	3:00:00 PM	0.3
11/25/2015	3:15:00 PM	0.3
11/25/2015	3:30:00 PM	0.3
11/25/2015	3:45:00 PM	0.3
11/25/2015	4:00:00 PM	0.3
11/25/2015	4:15:00 PM	0.3
11/25/2015	4:30:00 PM	0.3
11/25/2015	4:45:00 PM	0.3
11/25/2015	5:00:00 PM	0.3
11/25/2015	5:15:00 PM	0.3
11/25/2015	5:30:00 PM	0.3
11/25/2015	5:45:00 PM	0.3
11/25/2015	6:00:00 PM	0.3
11/25/2015	6:15:00 PM	0.3
11/25/2015	6:30:00 PM	0.3
11/25/2015	6:45:00 PM	0.3
11/25/2015	7:00:00 PM	0.3
11/25/2015	7:15:00 PM	0.3
11/25/2015	7:30:00 PM	0.3
11/25/2015	7:45:00 PM	0.3
11/25/2015	8:00:00 PM	0.3
11/25/2015	8:15:00 PM	0.3
11/25/2015	8:30:00 PM	0.3
11/25/2015	8:45:00 PM	0.3
11/25/2015	9:00:00 PM	0.3
11/25/2015	9:15:00 PM	0.3
11/25/2015	9:30:00 PM	0.3
11/25/2015	9:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/25/2015	10:00:00 PM	0.3
11/25/2015	10:15:00 PM	0.3
11/25/2015	10:30:00 PM	0.3
11/25/2015	10:45:00 PM	0.3
11/25/2015	11:00:00 PM	0.3
11/25/2015	11:15:00 PM	0.3
11/25/2015	11:30:00 PM	0.3
11/25/2015	11:45:00 PM	0.3
11/26/2015	12:00:00 AM	0.3
11/26/2015	12:15:00 AM	0.3
11/26/2015	12:30:00 AM	0.3
11/26/2015	12:45:00 AM	0.3
11/26/2015	1:00:00 AM	0.3
11/26/2015	1:15:00 AM	0.3
11/26/2015	1:30:00 AM	0.3
11/26/2015	1:45:00 AM	0.3
11/26/2015	2:00:00 AM	0.3
11/26/2015	2:15:00 AM	0.3
11/26/2015	2:30:00 AM	0.3
11/26/2015	2:45:00 AM	0.3
11/26/2015	3:00:00 AM	0.3
11/26/2015	3:15:00 AM	0.3
11/26/2015	3:30:00 AM	0.3
11/26/2015	3:45:00 AM	0.3
11/26/2015	4:00:00 AM	0.3
11/26/2015	4:15:00 AM	0.3
11/26/2015	4:30:00 AM	0.3
11/26/2015	4:45:00 AM	0.3
11/26/2015	5:00:00 AM	0.3
11/26/2015	5:15:00 AM	0.3
11/26/2015	5:30:00 AM	0.3
11/26/2015	5:45:00 AM	0.3
11/26/2015	6:00:00 AM	0.3
11/26/2015	6:15:00 AM	0.3
11/26/2015	6:30:00 AM	0.3
11/26/2015	6:45:00 AM	0.3
11/26/2015	7:00:00 AM	0.3
11/26/2015	7:15:00 AM	0.3
11/26/2015	7:30:00 AM	0.3
11/26/2015	7:45:00 AM	0.3
11/26/2015	8:00:00 AM	0.3
11/26/2015	8:15:00 AM	0.3
11/26/2015	8:30:00 AM	0.3
11/26/2015	8:45:00 AM	0.3
11/26/2015	9:00:00 AM	0.3
11/26/2015	9:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/26/2015	9:30:00 AM	0.3
11/26/2015	9:45:00 AM	0.3
11/26/2015	10:00:00 AM	0.3
11/26/2015	10:15:00 AM	0.3
11/26/2015	10:30:00 AM	0.3
11/26/2015	10:45:00 AM	0.3
11/26/2015	11:00:00 AM	0.3
11/26/2015	11:15:00 AM	0.3
11/26/2015	11:30:00 AM	0.3
11/26/2015	11:45:00 AM	0.3
11/26/2015	12:00:00 PM	0.3
11/26/2015	12:15:00 PM	0.3
11/26/2015	12:30:00 PM	0.3
11/26/2015	12:45:00 PM	0.3
11/26/2015	1:00:00 PM	0.3
11/26/2015	1:15:00 PM	0.3
11/26/2015	1:30:00 PM	0.3
11/26/2015	1:45:00 PM	0.3
11/26/2015	2:00:00 PM	0.3
11/26/2015	2:15:00 PM	0.3
11/26/2015	2:30:00 PM	0.3
11/26/2015	2:45:00 PM	0.3
11/26/2015	3:00:00 PM	0.3
11/26/2015	3:15:00 PM	0.3
11/26/2015	3:30:00 PM	0.3
11/26/2015	3:45:00 PM	0.3
11/26/2015	4:00:00 PM	0.3
11/26/2015	4:15:00 PM	0.3
11/26/2015	4:30:00 PM	0.3
11/26/2015	4:45:00 PM	0.3
11/26/2015	5:00:00 PM	0.3
11/26/2015	5:15:00 PM	0.3
11/26/2015	5:30:00 PM	0.3
11/26/2015	5:45:00 PM	0.3
11/26/2015	6:00:00 PM	0.3
11/26/2015	6:15:00 PM	0.3
11/26/2015	6:30:00 PM	0.3
11/26/2015	6:45:00 PM	0.3
11/26/2015	7:00:00 PM	0.3
11/26/2015	7:15:00 PM	0.3
11/26/2015	7:30:00 PM	0.3
11/26/2015	7:45:00 PM	0.3
11/26/2015	8:00:00 PM	0.3
11/26/2015	8:15:00 PM	0.3
11/26/2015	8:30:00 PM	0.3
11/26/2015	8:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/26/2015	9:00:00 PM	0.3
11/26/2015	9:15:00 PM	0.3
11/26/2015	9:30:00 PM	0.3
11/26/2015	9:45:00 PM	0.3
11/26/2015	10:00:00 PM	0.3
11/26/2015	10:15:00 PM	0.3
11/26/2015	10:30:00 PM	0.3
11/26/2015	10:45:00 PM	0.3
11/26/2015	11:00:00 PM	0.3
11/26/2015	11:15:00 PM	0.3
11/26/2015	11:30:00 PM	0.3
11/26/2015	11:45:00 PM	0.3
11/27/2015	12:00:00 AM	0.3
11/27/2015	12:15:00 AM	0.3
11/27/2015	12:30:00 AM	0.3
11/27/2015	12:45:00 AM	0.3
11/27/2015	1:00:00 AM	0.3
11/27/2015	1:15:00 AM	0.3
11/27/2015	1:30:00 AM	0.3
11/27/2015	1:45:00 AM	0.3
11/27/2015	2:00:00 AM	0.3
11/27/2015	2:15:00 AM	0.3
11/27/2015	2:30:00 AM	0.3
11/27/2015	2:45:00 AM	0.3
11/27/2015	3:00:00 AM	0.3
11/27/2015	3:15:00 AM	0.3
11/27/2015	3:30:00 AM	0.3
11/27/2015	3:45:00 AM	0.3
11/27/2015	4:00:00 AM	0.3
11/27/2015	4:15:00 AM	0.3
11/27/2015	4:30:00 AM	0.3
11/27/2015	4:45:00 AM	0.3
11/27/2015	5:00:00 AM	0.3
11/27/2015	5:15:00 AM	0.3
11/27/2015	5:30:00 AM	0.3
11/27/2015	5:45:00 AM	0.3
11/27/2015	6:00:00 AM	0.3
11/27/2015	6:15:00 AM	0.3
11/27/2015	6:30:00 AM	0.3
11/27/2015	6:45:00 AM	0.3
11/27/2015	7:00:00 AM	0.3
11/27/2015	7:15:00 AM	0.3
11/27/2015	7:30:00 AM	0.3
11/27/2015	7:45:00 AM	0.3
11/27/2015	8:00:00 AM	0.3
11/27/2015	8:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/27/2015	8:30:00 AM	0.3
11/27/2015	8:45:00 AM	0.3
11/27/2015	9:00:00 AM	0.3
11/27/2015	9:15:00 AM	0.3
11/27/2015	9:30:00 AM	0.3
11/27/2015	9:45:00 AM	0.3
11/27/2015	10:00:00 AM	0.3
11/27/2015	10:15:00 AM	0.3
11/27/2015	10:30:00 AM	0.3
11/27/2015	10:45:00 AM	0.3
11/27/2015	11:00:00 AM	0.3
11/27/2015	11:15:00 AM	0.3
11/27/2015	11:30:00 AM	0.3
11/27/2015	11:45:00 AM	0.3
11/27/2015	12:00:00 PM	0.3
11/27/2015	12:15:00 PM	0.3
11/27/2015	12:30:00 PM	0.3
11/27/2015	12:45:00 PM	0.3
11/27/2015	1:00:00 PM	0.3
11/27/2015	1:15:00 PM	0.3
11/27/2015	1:30:00 PM	0.3
11/27/2015	1:45:00 PM	0.3
11/27/2015	2:00:00 PM	0.3
11/27/2015	2:15:00 PM	0.3
11/27/2015	2:30:00 PM	0.3
11/27/2015	2:45:00 PM	0.3
11/27/2015	3:00:00 PM	0.3
11/27/2015	3:15:00 PM	0.3
11/27/2015	3:30:00 PM	0.3
11/27/2015	3:45:00 PM	0.3
11/27/2015	4:00:00 PM	0.3
11/27/2015	4:15:00 PM	0.3
11/27/2015	4:30:00 PM	0.3
11/27/2015	4:45:00 PM	0.3
11/27/2015	5:00:00 PM	0.3
11/27/2015	5:15:00 PM	0.3
11/27/2015	5:30:00 PM	0.3
11/27/2015	5:45:00 PM	0.3
11/27/2015	6:00:00 PM	0.3
11/27/2015	6:15:00 PM	0.3
11/27/2015	6:30:00 PM	0.3
11/27/2015	6:45:00 PM	0.3
11/27/2015	7:00:00 PM	0.3
11/27/2015	7:15:00 PM	0.3
11/27/2015	7:30:00 PM	0.3
11/27/2015	7:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/27/2015	8:00:00 PM	0.3
11/27/2015	8:15:00 PM	0.3
11/27/2015	8:30:00 PM	0.3
11/27/2015	8:45:00 PM	0.3
11/27/2015	9:00:00 PM	0.3
11/27/2015	9:15:00 PM	0.3
11/27/2015	9:30:00 PM	0.3
11/27/2015	9:45:00 PM	0.3
11/27/2015	10:00:00 PM	0.3
11/27/2015	10:15:00 PM	0.3
11/27/2015	10:30:00 PM	0.3
11/27/2015	10:45:00 PM	0.3
11/27/2015	11:00:00 PM	0.3
11/27/2015	11:15:00 PM	0.3
11/27/2015	11:30:00 PM	0.3
11/27/2015	11:45:00 PM	0.3
11/28/2015	12:00:00 AM	0.3
11/28/2015	12:15:00 AM	0.3
11/28/2015	12:30:00 AM	0.3
11/28/2015	12:45:00 AM	0.3
11/28/2015	1:00:00 AM	0.3
11/28/2015	1:15:00 AM	0.3
11/28/2015	1:30:00 AM	0.3
11/28/2015	1:45:00 AM	0.3
11/28/2015	2:00:00 AM	0.3
11/28/2015	2:15:00 AM	0.3
11/28/2015	2:30:00 AM	0.3
11/28/2015	2:45:00 AM	0.3
11/28/2015	3:00:00 AM	0.3
11/28/2015	3:15:00 AM	0.3
11/28/2015	3:30:00 AM	0.3
11/28/2015	3:45:00 AM	0.3
11/28/2015	4:00:00 AM	0.3
11/28/2015	4:15:00 AM	0.3
11/28/2015	4:30:00 AM	0.3
11/28/2015	4:45:00 AM	0.3
11/28/2015	5:00:00 AM	0.3
11/28/2015	5:15:00 AM	0.3
11/28/2015	5:30:00 AM	0.3
11/28/2015	5:45:00 AM	0.3
11/28/2015	6:00:00 AM	0.3
11/28/2015	6:15:00 AM	0.3
11/28/2015	6:30:00 AM	0.3
11/28/2015	6:45:00 AM	0.3
11/28/2015	7:00:00 AM	0.3
11/28/2015	7:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/28/2015	7:30:00 AM	0.3
11/28/2015	7:45:00 AM	0.3
11/28/2015	8:00:00 AM	0.3
11/28/2015	8:15:00 AM	0.3
11/28/2015	8:30:00 AM	0.3
11/28/2015	8:45:00 AM	0.3
11/28/2015	9:00:00 AM	0.3
11/28/2015	9:15:00 AM	0.3
11/28/2015	9:30:00 AM	0.3
11/28/2015	9:45:00 AM	0.3
11/28/2015	10:00:00 AM	0.3
11/28/2015	10:15:00 AM	0.3
11/28/2015	10:30:00 AM	0.3
11/28/2015	10:45:00 AM	0.3
11/28/2015	11:00:00 AM	0.3
11/28/2015	11:15:00 AM	0.3
11/28/2015	11:30:00 AM	0.3
11/28/2015	11:45:00 AM	0.3
11/28/2015	12:00:00 PM	0.3
11/28/2015	12:15:00 PM	0.3
11/28/2015	12:30:00 PM	0.3
11/28/2015	12:45:00 PM	0.3
11/28/2015	1:00:00 PM	0.3
11/28/2015	1:15:00 PM	0.3
11/28/2015	1:30:00 PM	0.3
11/28/2015	1:45:00 PM	0.3
11/28/2015	2:00:00 PM	0.3
11/28/2015	2:15:00 PM	0.3
11/28/2015	2:30:00 PM	0.3
11/28/2015	2:45:00 PM	0.3
11/28/2015	3:00:00 PM	0.3
11/28/2015	3:15:00 PM	0.3
11/28/2015	3:30:00 PM	0.3
11/28/2015	3:45:00 PM	0.3
11/28/2015	4:00:00 PM	0.3
11/28/2015	4:15:00 PM	0.3
11/28/2015	4:30:00 PM	0.3
11/28/2015	4:45:00 PM	0.3
11/28/2015	5:00:00 PM	0.3
11/28/2015	5:15:00 PM	0.3
11/28/2015	5:30:00 PM	0.3
11/28/2015	5:45:00 PM	0.3
11/28/2015	6:00:00 PM	0.3
11/28/2015	6:15:00 PM	0.3
11/28/2015	6:30:00 PM	0.3
11/28/2015	6:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/28/2015	7:00:00 PM	0.3
11/28/2015	7:15:00 PM	0.3
11/28/2015	7:30:00 PM	0.3
11/28/2015	7:45:00 PM	0.3
11/28/2015	8:00:00 PM	0.3
11/28/2015	8:15:00 PM	0.3
11/28/2015	8:30:00 PM	0.3
11/28/2015	8:45:00 PM	0.3
11/28/2015	9:00:00 PM	0.3
11/28/2015	9:15:00 PM	0.3
11/28/2015	9:30:00 PM	0.3
11/28/2015	9:45:00 PM	0.3
11/28/2015	10:00:00 PM	0.3
11/28/2015	10:15:00 PM	0.3
11/28/2015	10:30:00 PM	0.3
11/28/2015	10:45:00 PM	0.3
11/28/2015	11:00:00 PM	0.3
11/28/2015	11:15:00 PM	0.3
11/28/2015	11:30:00 PM	0.3
11/28/2015	11:45:00 PM	0.3
11/29/2015	12:00:00 AM	0.3
11/29/2015	12:15:00 AM	0.3
11/29/2015	12:30:00 AM	0.3
11/29/2015	12:45:00 AM	0.3
11/29/2015	1:00:00 AM	0.3
11/29/2015	1:15:00 AM	0.3
11/29/2015	1:30:00 AM	0.3
11/29/2015	1:45:00 AM	0.3
11/29/2015	2:00:00 AM	0.3
11/29/2015	2:15:00 AM	0.3
11/29/2015	2:30:00 AM	0.3
11/29/2015	2:45:00 AM	0.3
11/29/2015	3:00:00 AM	0.3
11/29/2015	3:15:00 AM	0.3
11/29/2015	3:30:00 AM	0.3
11/29/2015	3:45:00 AM	0.3
11/29/2015	4:00:00 AM	0.3
11/29/2015	4:15:00 AM	0.3
11/29/2015	4:30:00 AM	0.3
11/29/2015	4:45:00 AM	0.3
11/29/2015	5:00:00 AM	0.3
11/29/2015	5:15:00 AM	0.3
11/29/2015	5:30:00 AM	0.3
11/29/2015	5:45:00 AM	0.3
11/29/2015	6:00:00 AM	0.3
11/29/2015	6:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/29/2015	6:30:00 AM	0.3
11/29/2015	6:45:00 AM	0.3
11/29/2015	7:00:00 AM	0.3
11/29/2015	7:15:00 AM	0.3
11/29/2015	7:30:00 AM	0.3
11/29/2015	7:45:00 AM	0.3
11/29/2015	8:00:00 AM	0.3
11/29/2015	8:15:00 AM	0.3
11/29/2015	8:30:00 AM	0.3
11/29/2015	8:45:00 AM	0.3
11/29/2015	9:00:00 AM	0.3
11/29/2015	9:15:00 AM	0.3
11/29/2015	9:30:00 AM	0.3
11/29/2015	9:45:00 AM	0.3
11/29/2015	10:00:00 AM	0.3
11/29/2015	10:15:00 AM	0.3
11/29/2015	10:30:00 AM	0.3
11/29/2015	10:45:00 AM	0.3
11/29/2015	11:00:00 AM	0.3
11/29/2015	11:15:00 AM	0.3
11/29/2015	11:30:00 AM	0.3
11/29/2015	11:45:00 AM	0.3
11/29/2015	12:00:00 PM	0.3
11/29/2015	12:15:00 PM	0.3
11/29/2015	12:30:00 PM	0.3
11/29/2015	12:45:00 PM	0.3
11/29/2015	1:00:00 PM	0.3
11/29/2015	1:15:00 PM	0.3
11/29/2015	1:30:00 PM	0.3
11/29/2015	1:45:00 PM	0.3
11/29/2015	2:00:00 PM	0.3
11/29/2015	2:15:00 PM	0.3
11/29/2015	2:30:00 PM	0.3
11/29/2015	2:45:00 PM	0.3
11/29/2015	3:00:00 PM	0.3
11/29/2015	3:15:00 PM	0.3
11/29/2015	3:30:00 PM	0.3
11/29/2015	3:45:00 PM	0.3
11/29/2015	4:00:00 PM	0.3
11/29/2015	4:15:00 PM	0.3
11/29/2015	4:30:00 PM	0.3
11/29/2015	4:45:00 PM	0.3
11/29/2015	5:00:00 PM	0.3
11/29/2015	5:15:00 PM	0.3
11/29/2015	5:30:00 PM	0.3
11/29/2015	5:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/29/2015	6:00:00 PM	0.3
11/29/2015	6:15:00 PM	0.3
11/29/2015	6:30:00 PM	0.3
11/29/2015	6:45:00 PM	0.3
11/29/2015	7:00:00 PM	0.3
11/29/2015	7:15:00 PM	0.3
11/29/2015	7:30:00 PM	0.3
11/29/2015	7:45:00 PM	0.3
11/29/2015	8:00:00 PM	0.3
11/29/2015	8:15:00 PM	0.3
11/29/2015	8:30:00 PM	0.3
11/29/2015	8:45:00 PM	0.3
11/29/2015	9:00:00 PM	0.3
11/29/2015	9:15:00 PM	0.3
11/29/2015	9:30:00 PM	0.3
11/29/2015	9:45:00 PM	0.3
11/29/2015	10:00:00 PM	0.3
11/29/2015	10:15:00 PM	0.3
11/29/2015	10:30:00 PM	0.3
11/29/2015	10:45:00 PM	0.3
11/29/2015	11:00:00 PM	0.3
11/29/2015	11:15:00 PM	0.3
11/29/2015	11:30:00 PM	0.3
11/29/2015	11:45:00 PM	0.3
11/30/2015	12:00:00 AM	0.3
11/30/2015	12:15:00 AM	0.3
11/30/2015	12:30:00 AM	0.3
11/30/2015	12:45:00 AM	0.3
11/30/2015	1:00:00 AM	0.3
11/30/2015	1:15:00 AM	0.3
11/30/2015	1:30:00 AM	0.3
11/30/2015	1:45:00 AM	0.3
11/30/2015	2:00:00 AM	0.3
11/30/2015	2:15:00 AM	0.3
11/30/2015	2:30:00 AM	0.3
11/30/2015	2:45:00 AM	0.3
11/30/2015	3:00:00 AM	0.3
11/30/2015	3:15:00 AM	0.3
11/30/2015	3:30:00 AM	0.3
11/30/2015	3:45:00 AM	0.3
11/30/2015	4:00:00 AM	0.3
11/30/2015	4:15:00 AM	0.3
11/30/2015	4:30:00 AM	0.3
11/30/2015	4:45:00 AM	0.3
11/30/2015	5:00:00 AM	0.3
11/30/2015	5:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/30/2015	5:30:00 AM	0.3
11/30/2015	5:45:00 AM	0.3
11/30/2015	6:00:00 AM	0.3
11/30/2015	6:15:00 AM	0.3
11/30/2015	6:30:00 AM	0.3
11/30/2015	6:45:00 AM	0.3
11/30/2015	7:00:00 AM	0.3
11/30/2015	7:15:00 AM	0.3
11/30/2015	7:30:00 AM	0.3
11/30/2015	7:45:00 AM	0.3
11/30/2015	8:00:00 AM	0.3
11/30/2015	8:15:00 AM	0.3
11/30/2015	8:30:00 AM	0.3
11/30/2015	8:45:00 AM	0.3
11/30/2015	9:00:00 AM	0.3
11/30/2015	9:15:00 AM	0.3
11/30/2015	9:30:00 AM	0.3
11/30/2015	9:45:00 AM	0.3
11/30/2015	10:00:00 AM	0.3
11/30/2015	10:15:00 AM	0.3
11/30/2015	10:30:00 AM	0.3
11/30/2015	10:45:00 AM	0.3
11/30/2015	11:00:00 AM	0.3
11/30/2015	11:15:00 AM	0.3
11/30/2015	11:30:00 AM	0.3
11/30/2015	11:45:00 AM	0.3
11/30/2015	12:00:00 PM	0.3
11/30/2015	12:15:00 PM	0.3
11/30/2015	12:30:00 PM	0.3
11/30/2015	12:45:00 PM	0.3
11/30/2015	1:00:00 PM	0.3
11/30/2015	1:15:00 PM	0.3
11/30/2015	1:30:00 PM	0.3
11/30/2015	1:45:00 PM	0.3
11/30/2015	2:00:00 PM	0.3
11/30/2015	2:15:00 PM	0.3
11/30/2015	2:30:00 PM	0.3
11/30/2015	2:45:00 PM	0.3
11/30/2015	3:00:00 PM	0.3
11/30/2015	3:15:00 PM	0.3
11/30/2015	3:30:00 PM	0.3
11/30/2015	3:45:00 PM	0.3
11/30/2015	4:00:00 PM	0.3
11/30/2015	4:15:00 PM	0.3
11/30/2015	4:30:00 PM	0.3
11/30/2015	4:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/30/2015	5:00:00 PM	0.3
11/30/2015	5:15:00 PM	0.3
11/30/2015	5:30:00 PM	0.3
11/30/2015	5:45:00 PM	0.3
11/30/2015	6:00:00 PM	0.3
11/30/2015	6:15:00 PM	0.3
11/30/2015	6:30:00 PM	0.3
11/30/2015	6:45:00 PM	0.3
11/30/2015	7:00:00 PM	0.3
11/30/2015	7:15:00 PM	0.3
11/30/2015	7:30:00 PM	0.3
11/30/2015	7:45:00 PM	0.3
11/30/2015	8:00:00 PM	0.3
11/30/2015	8:15:00 PM	0.3
11/30/2015	8:30:00 PM	0.3
11/30/2015	8:45:00 PM	0.3
11/30/2015	9:00:00 PM	0.3
11/30/2015	9:15:00 PM	0.3
11/30/2015	9:30:00 PM	0.3
11/30/2015	9:45:00 PM	0.3
11/30/2015	10:00:00 PM	0.3
11/30/2015	10:15:00 PM	0.3
11/30/2015	10:30:00 PM	0.3
11/30/2015	10:45:00 PM	0.3
11/30/2015	11:00:00 PM	0.3
11/30/2015	11:15:00 PM	0.3
11/30/2015	11:30:00 PM	0.3
11/30/2015	11:45:00 PM	0.3

Station Number: 0354 Meas. No: 004

Station Name: LOR @ MAZOURKA Date: 12/03/2015

Party: MKH / BRP	Width: 20.7 ft	Processed by: MKH
Boat/Motor:	Area: 79.8 ft²	Mean Velocity: 0.573 ft/s
Gage Height: 4.14 ft	G.H.Change: 0.000 ft	Discharge: 45.7 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 2.26 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 4.34 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 3.85 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 68.10	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 48.8 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151203MOUK000r.mmt

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	*L*	***2***	***2***	***34***	***6.53***	***33.1***	***6.53***	***1.20***	***1.17***	***48.6***	***21***	***83***	***14:32***	***14:33***	***0.51***	***0.58***	***6***	***1***
001	R	***2***	***2***	***34***	***5.86***	***29.6***	***5.79***	***1.34***	***1.20***	***43.8***	***21***	***82***	***14:33***	***14:34***	***0.49***	***0.53***	***6***	***1***
002	L	***2***	***2***	***34***	***6.07***	***30.7***	***5.76***	***0.883***	***1.34***	***44.8***	***20***	***78***	***14:34***	***14:35***	***0.51***	***0.57***	***6***	***1***
003	R	***2***	***2***	***34***	***6.14***	***31.1***	***6.07***	***1.62***	***1.27***	***46.2***	***19***	***74***	***14:35***	***14:35***	***0.50***	***0.63***	***6***	***0***
004	L	***2***	***2***	***34***	***6.14***	***31.0***	***5.83***	***1.09***	***0.989***	***45.1***	***21***	***82***	***14:36***	***14:36***	***0.50***	***0.55***	***6***	***0***
Mean		**2**	**2**	**34**	**6.15**	**31.1**	**6.00**	**1.23**	**1.19**	**45.7**	**21**	**80**	**Total**	**00:04**	**0.50**	**0.57**	**6**	**1**
SDev		**0**	**0**	**0**	**0.243**	**1.28**	**0.325**	**0.277**	**0.133**	**1.85**	**1.0**	**4.0**			**0.01**	**0.04**		
SD/M		**0.00**	**0.00**	**0.00**	**0.04**	**0.04**	**0.05**	**0.23**	**0.11**	**0.04**	**0.05**	**0.05**			**0.02**	**0.06**		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Station Number: 0354 Meas. No: 004

Station Name: LOR @ MAZOURKA Date: 12/30/2015

Party: MKH / BRP	Width: 20.4 ft	Processed by: MKH
Boat/Motor:	Area: 77.9 ft²	Mean Velocity: 0.559 ft/s
Gage Height: 4.15 ft	G.H.Change: 0.000 ft	Discharge: 43.5 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 2.11 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 4.35 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 3.81 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 68.06	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 46.9 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151230LOR @ MAZOURKA000

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	34	5.58	28.2	5.37	1.31	0.989	41.5	20	78	14:37	14:37	0.47	0.53	6	1
001	R	2	2	33	5.79	29.3	5.26	1.62	1.70	43.6	20	78	14:38	14:38	0.53	0.56	6	0
002	*L*	*2*	*2*	*33*	*6.32*	*31.9*	*5.76*	*1.17*	*1.45*	*46.6*	*21*	*79*	*14:39*	*14:39*	*0.51*	*0.59*	*6*	*1*
003	R	*2*	*2*	*33*	*5.79*	*29.2*	*5.19*	*1.34*	*1.41*	*42.9*	*21*	*78*	*14:40*	*14:40*	*0.54*	*0.55*	*6*	*0*
004	L	*2*	*2*	*34*	*5.86*	*29.6*	*5.09*	*1.13*	*1.41*	*43.2*	*20*	*76*	*14:41*	*14:41*	*0.49*	*0.56*	*6*	*0*
Mean		2	2	33	5.87	29.6	5.33	1.31	1.39	43.5	20	78	**Total**	00:04	0.51	0.56	6	0
SDev		0	0	1	0.274	1.36	0.258	0.196	0.254	1.88	0.2	0.9			0.03	0.02		
SD/M		0.00	0.00	0.02	0.05	0.05	0.05	0.15	0.18	0.04	0.01	0.01			0.06	0.04		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	0	2	22	0.623	-0.157	3.825	0.01	0.007	0	21.5	24.9	77.4	88	97	0	38	39
2015	12	1	0	12	22	0.64	-0.138	3.825	0.01	0.007	0	21.1	25.4	76.5	88	98	0	39	39
2015	12	1	0	22	22	0.633	-0.138	3.825	0.01	0.007	0	21.5	24.9	77	88	97	0	38	39
2015	12	1	0	32	22	0.666	-0.112	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	0	42	22	0.633	-0.125	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	0	52	22	0.627	-0.102	3.825	0.013	0.01	0	21.9	25.4	77.4	89	98	0	38	39
2015	12	1	1	2	22	0.659	-0.144	3.825	0.01	0.007	0	22.4	24.9	77.4	89	97	0	37	39
2015	12	1	1	12	22	0.623	-0.135	3.825	0.013	0.01	0	22.4	25.8	77	89	99	0	37	39
2015	12	1	1	22	22	0.65	-0.138	3.825	0.01	0.007	0	22.8	25.8	77	90	99	0	37	39
2015	12	1	1	32	22	0.623	-0.157	3.825	0.01	0.007	0	21.9	25.8	77.4	89	99	0	38	39
2015	12	1	1	42	22	0.636	-0.112	3.825	0.01	0.007	0	22.4	25.4	77.4	90	98	0	38	39
2015	12	1	1	52	22	0.627	-0.161	3.825	0.01	0.007	0	22.4	25.4	76.5	89	98	0	37	39
2015	12	1	2	2	22	0.623	-0.154	3.825	0.01	0.007	0	21.9	25.4	76.5	89	98	0	38	39
2015	12	1	2	12	22	0.646	-0.151	3.825	0.013	0.01	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	2	22	22	0.63	-0.121	3.825	0.013	0.01	0	22.4	24.9	77	90	98	0	38	40
2015	12	1	2	32	22	0.65	-0.167	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	2	42	22	0.646	-0.131	3.825	0.01	0.007	0	22.4	26.2	77.4	90	99	0	38	38
2015	12	1	2	52	22	0.64	-0.115	3.825	0.01	0.007	0	21.9	24.9	77	89	98	0	38	40
2015	12	1	3	2	22	0.623	-0.144	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	3	12	22	0.646	-0.151	3.825	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	1	3	22	22	0.64	-0.131	3.825	0.01	0.007	0	22.4	25.4	77	90	98	0	38	39
2015	12	1	3	32	22	0.676	-0.151	3.825	0.01	0.007	0	22.4	25.8	76.1	90	99	0	38	39
2015	12	1	3	42	22	0.646	-0.157	3.825	0.01	0.007	0	22.4	25.4	77	90	98	0	38	39
2015	12	1	3	52	22	0.64	-0.151	3.825	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	1	4	2	22	0.617	-0.154	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	4	12	22	0.614	-0.125	3.825	0.013	0.01	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	4	22	22	0.643	-0.164	3.825	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	1	4	32	22	0.636	-0.164	3.825	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	1	4	42	22	0.633	-0.128	3.825	0.01	0.007	0	22.4	25.4	76.5	90	99	0	38	40
2015	12	1	4	52	22	0.646	-0.148	3.825	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	1	5	2	22	0.666	-0.157	3.825	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	1	5	12	22	0.636	-0.154	3.825	0.013	0.01	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	1	5	22	22	0.63	-0.125	3.822	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	1	5	32	22	0.64	-0.161	3.822	0.01	0.007	0	26.2	30.1	76.5	99	109	0	38	39
2015	12	1	5	42	22	0.607	-0.151	3.825	0.01	0.007	0	25.8	29.2	76.5	98	107	0	38	39
2015	12	1	5	52	22	0.62	-0.138	3.825	0.01	0.007	0	26.7	30.1	76.5	100	109	0	38	39
2015	12	1	6	2	22	0.64	-0.141	3.822	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	1	6	12	22	0.653	-0.171	3.825	0.01	0.007	0	22.8	26.2	76.1	91	100	0	38	39
2015	12	1	6	22	22	0.636	-0.128	3.822	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	1	6	32	22	0.643	-0.138	3.822	0.01	0.007	0	23.2	26.2	76.5	92	100	0	38	39
2015	12	1	6	42	22	0.623	-0.125	3.825	0.01	0.007	0	23.2	26.7	77	93	101	0	39	39
2015	12	1	6	52	22	0.656	-0.141	3.825	0.01	0.007	0	22.8	26.2	76.1	92	101	0	39	40
2015	12	1	7	2	22	0.64	-0.151	3.825	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	1	7	12	22	0.64	-0.131	3.825	0.01	0.007	0	23.2	26.2	77	92	100	0	38	39
2015	12	1	7	22	22	0.659	-0.118	3.825	0.01	0.007	0	23.2	26.2	76.1	91	100	0	37	39
2015	12	1	7	32	22	0.646	-0.135	3.825	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	7	42	22	0.669	-0.154	3.825	0.01	0.007	0	24.5	28	76.1	95	104	0	38	39
2015	12	1	7	52	22	0.636	-0.108	3.825	0.013	0.01	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	1	8	2	22	0.65	-0.141	3.825	0.013	0.01	0	23.6	26.7	76.1	93	101	0	38	39
2015	12	1	8	12	22	0.659	-0.115	3.825	0.01	0.007	0	23.6	27.1	76.5	93	102	0	38	39
2015	12	1	8	22	22	0.63	-0.112	3.825	0.01	0.007	0	23.2	26.7	76.5	92	102	0	38	40
2015	12	1	8	32	22	0.617	-0.135	3.829	0.01	0.007	0	23.6	26.7	76.5	93	102	0	38	40
2015	12	1	8	42	22	0.636	-0.135	3.829	0.01	0.007	0	23.6	27.1	76.5	93	102	0	38	39
2015	12	1	8	52	22	0.636	-0.131	3.829	0.01	0.007	0	23.6	26.7	77	93	101	0	38	39
2015	12	1	9	2	22	0.627	-0.125	3.829	0.01	0.007	0	23.2	27.1	76.5	93	102	0	39	39
2015	12	1	9	12	22	0.627	-0.128	3.829	0.01	0.007	0	23.6	26.7	76.5	93	101	0	38	39
2015	12	1	9	22	22	0.65	-0.135	3.829	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	1	9	32	22	0.64	-0.138	3.829	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	1	9	42	22	0.64	-0.121	3.829	0.01	0.007	0	23.2	26.7	77	92	102	0	38	40
2015	12	1	9	52	22	0.63	-0.125	3.829	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	1	10	2	22	0.656	-0.167	3.832	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	1	10	12	22	0.646	-0.148	3.832	0.013	0.01	0	23.2	26.7	77	92	101	0	38	39
2015	12	1	10	22	22	0.63	-0.138	3.832	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	1	10	32	22	0.64	-0.131	3.832	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	1	10	42	22	0.63	-0.141	3.832	0.01	0.007	0	22.8	26.2	76.1	91	100	0	38	39
2015	12	1	10	52	22	0.643	-0.138	3.832	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	1	11	2	22	0.614	-0.135	3.832	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	1	11	12	22	0.646	-0.112	3.832	0.013	0.01	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	1	11	22	22	0.604	-0.135	3.832	0.01	0.007	0	22.8	27.1	77	91	101	0	38	38
2015	12	1	11	32	22	0.63	-0.131	3.832	0.01	0.007	0	22.8	25.4	76.5	90	99	0	37	40
2015	12	1	11	42	22	0.63	-0.125	3.832	0.01	0.007	0	22.8	25.8	77	90	99	0	37	39
2015	12	1	11	52	22	0.643	-0.125	3.832	0.01	0.007	0	22.4	26.2	74	91	100	0	39	39
2015	12	1	12	2	22	0.62	-0.138	3.832	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	1	12	12	22	0.61	-0.138	3.832	0.016	0.013	0	23.2	26.2	77.4	92	100	0	38	39
2015	12	1	12	22	22	0.627	-0.157	3.832	0.01	0.007	0	22.8	26.2	71.8	91	100	0	38	39
2015	12	1	12	32	22	0.646	-0.112	3.835	0.016	0.013	0	23.2	26.7	77	92	101	0	38	39
2015	12	1	12	42	22	0.627	-0.121	3.832	0.013	0.01	0	22.8	25.8	76.5	90	99	0	37	39
2015	12	1	12	52	22	0.63	-0.138	3.832	0.01	0.007	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	1	13	2	22	0.604	-0.128	3.832	0.01	0.007	0	23.2	26.7	71.4	92	101	0	38	39
2015	12	1	13	12	22	0.63	-0.138	3.832	0.01	0.007	0	22.8	26.2	75.7	91	100	0	38	39
2015	12	1	13	22	22	0.636	-0.112	3.832	0.01	0.007	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	1	13	32	22	0.633	-0.154	3.832	0.013	0.01	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	1	13	42	22	0.623	-0.125	3.832	0.016	0.013	0	22.4	26.2	74.8	90	100	0	38	39
2015	12	1	13	52	22	0.656	-0.121	3.832	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	14	2	22	0.627	-0.144	3.832	0.01	0.007	0	22.4	26.2	76.5	91	100	0	39	39
2015	12	1	14	12	22	0.633	-0.144	3.832	0.01	0.007	0	22.4	26.7	76.5	90	100	0	38	38
2015	12	1	14	22	22	0.666	-0.118	3.829	0.01	0.007	0	22.4	25.8	74	90	99	0	38	39
2015	12	1	14	32	22	0.62	-0.115	3.829	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	14	42	22	0.6	-0.125	3.829	0.01	0.007	0	21.9	25.8	76.5	90	99	0	39	39
2015	12	1	14	52	22	0.669	-0.118	3.829	0.01	0.007	0	22.4	26.2	76.5	90	99	0	38	38
2015	12	1	15	2	22	0.617	-0.118	3.825	0.01	0.007	0	22.4	26.2	71.4	90	99	0	38	38
2015	12	1	15	12	22	0.636	-0.121	3.825	0.01	0.007	0	22.8	26.2	68.4	91	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	15	22	22	0.643	-0.125	3.825	0.01	0.007	0	22.4	25.8	68.8	90	99	0	38	39
2015	12	1	15	32	22	0.636	-0.131	3.825	0.01	0.007	0	22.4	25.8	75.7	90	99	0	38	39
2015	12	1	15	42	22	0.64	-0.138	3.825	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	1	15	52	22	0.656	-0.105	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	16	2	22	0.65	-0.131	3.825	0.01	0.007	0	21.5	25.4	77	88	98	0	38	39
2015	12	1	16	12	22	0.604	-0.125	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	16	22	22	0.627	-0.115	3.825	0.016	0.013	0	21.9	25.8	77.4	89	99	0	38	39
2015	12	1	16	32	22	0.636	-0.112	3.825	0.01	0.007	0	21.9	24.9	77	89	98	0	38	40
2015	12	1	16	42	22	0.623	-0.138	3.825	0.01	0.007	0	21.9	25.4	76.5	89	98	0	38	39
2015	12	1	16	52	22	0.653	-0.125	3.825	0.01	0.007	0	22.4	25.4	77	89	98	0	37	39
2015	12	1	17	2	22	0.633	-0.128	3.825	0.01	0.007	0	21.9	24.9	77	89	98	0	38	40
2015	12	1	17	12	22	0.636	-0.125	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	17	22	22	0.669	-0.125	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	17	32	22	0.636	-0.151	3.825	0.01	0.007	0	22.8	25.8	77	91	99	0	38	39
2015	12	1	17	42	22	0.656	-0.125	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	17	52	22	0.594	-0.115	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	18	2	22	0.62	-0.148	3.825	0.01	0.007	0	21.9	25.8	77	89	99	0	38	39
2015	12	1	18	12	22	0.636	-0.118	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	18	22	22	0.636	-0.161	3.825	0.01	0.007	0	21.9	25.4	76.5	89	98	0	38	39
2015	12	1	18	32	22	0.614	-0.115	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	18	42	22	0.627	-0.112	3.825	0.01	0.007	0	21.9	25.8	77.4	89	99	0	38	39
2015	12	1	18	52	22	0.61	-0.184	3.825	0.01	0.007	0	21.9	25.8	77	90	99	0	39	39
2015	12	1	19	2	22	0.65	-0.125	3.825	0.01	0.007	0	29.7	33.1	76.5	107	116	0	38	39
2015	12	1	19	12	22	0.666	-0.151	3.825	0.013	0.01	0	34	37.4	76.5	117	126	0	38	39
2015	12	1	19	22	22	0.64	-0.151	3.825	0.01	0.007	0	26.7	30.1	76.5	100	109	0	38	39
2015	12	1	19	32	22	0.659	-0.135	3.825	0.01	0.007	0	24.5	27.5	77.4	95	104	0	38	40
2015	12	1	19	42	22	0.633	-0.128	3.825	0.01	0.007	0	24.1	27.1	77	94	103	0	38	40
2015	12	1	19	52	22	0.623	-0.125	3.825	0.01	0.007	0	24.1	28	77.4	95	104	0	39	39
2015	12	1	20	2	22	0.617	-0.144	3.825	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	1	20	12	22	0.636	-0.157	3.825	0.01	0.007	0	25.4	28.8	76.5	97	106	0	38	39
2015	12	1	20	22	22	0.643	-0.092	3.825	0.01	0.007	0	25.4	29.2	77	97	107	0	38	39
2015	12	1	20	32	22	0.587	-0.131	3.825	0.01	0.007	0	26.2	29.7	77	99	108	0	38	39
2015	12	1	20	42	22	0.623	-0.121	3.825	0.013	0.01	0	25.4	28.8	77	97	106	0	38	39
2015	12	1	20	52	22	0.646	-0.151	3.825	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	1	21	2	22	0.594	-0.115	3.825	0.01	0.007	0	23.6	26.7	77	93	102	0	38	40
2015	12	1	21	12	22	0.627	-0.125	3.825	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	1	21	22	22	0.65	-0.125	3.825	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	1	21	32	22	0.591	-0.151	3.825	0.01	0.007	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	1	21	42	22	0.614	-0.131	3.825	0.01	0.007	0	22.8	26.2	77.4	91	100	0	38	39
2015	12	1	21	52	22	0.63	-0.131	3.825	0.01	0.007	0	22.4	26.2	77	91	100	0	39	39
2015	12	1	22	2	22	0.636	-0.144	3.825	0.01	0.007	0	22.8	26.7	77	91	100	0	38	38
2015	12	1	22	12	22	0.614	-0.115	3.825	0.01	0.007	0	21.9	25.8	76.5	90	99	0	39	39
2015	12	1	22	22	22	0.614	-0.121	3.825	0.01	0.007	0	22.8	25.8	77	90	99	0	37	39
2015	12	1	22	32	22	0.636	-0.115	3.825	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	1	22	42	22	0.65	-0.151	3.825	0.01	0.007	0	22.4	25.4	76.5	90	98	0	38	39
2015	12	1	22	52	22	0.627	-0.135	3.825	0.013	0.01	0	22.8	25.8	77	91	99	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	23	2	22	0.646	-0.138	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	23	12	22	0.627	-0.112	3.825	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	1	23	22	22	0.62	-0.131	3.825	0.01	0.007	0	22.4	25.4	77	90	99	0	38	40
2015	12	1	23	32	22	0.63	-0.125	3.825	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	1	23	42	22	0.604	-0.115	3.825	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	1	23	52	22	0.627	-0.138	3.825	0.01	0.007	0	21.9	25.4	76.5	89	98	0	38	39
2015	12	2	0	2	22	0.64	-0.141	3.825	0.013	0.01	0	21.9	25.8	77	90	99	0	39	39
2015	12	2	0	12	22	0.63	-0.131	3.825	0.01	0.007	0	22.8	26.2	77	91	101	0	38	40
2015	12	2	0	22	22	0.636	-0.131	3.825	0.01	0.007	0	21.9	26.2	76.5	90	100	0	39	39
2015	12	2	0	32	22	0.636	-0.118	3.825	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	2	0	42	22	0.6	-0.144	3.825	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	2	0	52	22	0.643	-0.18	3.825	0.013	0.01	0	26.2	30.1	76.5	99	109	0	38	39
2015	12	2	1	2	22	0.614	-0.115	3.825	0.01	0.007	0	27.5	31.4	76.5	102	112	0	38	39
2015	12	2	1	12	22	0.636	-0.157	3.825	0.01	0.007	0	23.6	28	76.5	93	103	0	38	38
2015	12	2	1	22	22	0.63	-0.148	3.825	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	2	1	32	22	0.62	-0.138	3.825	0.013	0.01	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	2	1	42	22	0.646	-0.141	3.825	0.01	0.007	0	23.6	27.5	76.5	93	102	0	38	38
2015	12	2	1	52	22	0.623	-0.128	3.825	0.01	0.007	0	24.1	26.7	76.1	93	101	0	37	39
2015	12	2	2	2	22	0.636	-0.144	3.825	0.01	0.007	0	27.1	30.1	76.1	101	110	0	38	40
2015	12	2	2	12	22	0.623	-0.125	3.825	0.01	0.007	0	34.4	37.8	73.5	118	127	0	38	39
2015	12	2	2	22	22	0.633	-0.128	3.825	0.01	0.007	0	33.1	37	75.7	116	124	0	39	38
2015	12	2	2	32	22	0.614	-0.131	3.825	0.01	0.007	0	25.8	29.2	76.5	97	106	0	37	38
2015	12	2	2	42	22	0.643	-0.128	3.825	0.01	0.007	0	24.1	27.5	76.1	94	103	0	38	39
2015	12	2	2	52	22	0.584	-0.148	3.825	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	2	3	2	22	0.62	-0.151	3.825	0.01	0.007	0	28.4	31.8	76.1	104	113	0	38	39
2015	12	2	3	12	22	0.633	-0.125	3.825	0.01	0.007	0	25.4	28.8	76.5	97	106	0	38	39
2015	12	2	3	22	22	0.62	-0.131	3.825	0.01	0.007	0	27.5	31	75.7	102	111	0	38	39
2015	12	2	3	32	22	0.607	-0.161	3.829	0.01	0.007	0	26.7	30.1	72.7	100	109	0	38	39
2015	12	2	3	42	22	0.62	-0.135	3.825	0.01	0.007	0	38.7	41.7	75.3	128	136	0	38	39
2015	12	2	3	52	22	0.607	-0.125	3.829	0.013	0.01	0	34.4	37.8	75.3	118	127	0	38	39
2015	12	2	4	2	22	0.61	-0.115	3.829	0.01	0.007	0	33.1	36.5	75.3	115	124	0	38	39
2015	12	2	4	12	22	0.63	-0.148	3.829	0.013	0.01	0	27.5	31.4	75.7	102	112	0	38	39
2015	12	2	4	22	22	0.6	-0.135	3.825	0.01	0.007	0	24.5	28	75.7	95	104	0	38	39
2015	12	2	4	32	22	0.627	-0.118	3.829	0.01	0.007	0	23.6	27.5	75.7	93	103	0	38	39
2015	12	2	4	42	22	0.617	-0.125	3.829	0.01	0.007	0	24.5	28	75.3	95	104	0	38	39
2015	12	2	4	52	22	0.633	-0.112	3.829	0.013	0.01	0	25.8	29.7	75.3	98	108	0	38	39
2015	12	2	5	2	22	0.643	-0.128	3.829	0.01	0.007	0	28	31.4	75.3	103	112	0	38	39
2015	12	2	5	12	22	0.643	-0.151	3.829	0.01	0.007	0	24.1	27.5	75.3	94	103	0	38	39
2015	12	2	5	22	22	0.646	-0.138	3.829	0.01	0.007	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	2	5	32	22	0.6	-0.128	3.829	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	5	42	22	0.607	-0.151	3.829	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	2	5	52	22	0.633	-0.125	3.829	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	2	6	2	22	0.65	-0.141	3.829	0.01	0.007	0	22.4	26.2	74.8	90	100	0	38	39
2015	12	2	6	12	22	0.62	-0.157	3.829	0.013	0.01	0	23.6	26.7	74.8	92	101	0	37	39
2015	12	2	6	22	22	0.659	-0.128	3.829	0.01	0.007	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	2	6	32	22	0.64	-0.151	3.829	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	6	42	22	0.643	-0.138	3.829	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	6	52	22	0.669	-0.148	3.829	0.01	0.007	0	22.4	26.2	74.4	91	100	0	39	39
2015	12	2	7	2	22	0.614	-0.121	3.832	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	7	12	22	0.653	-0.148	3.832	0.01	0.007	0	21.9	26.2	74	90	100	0	39	39
2015	12	2	7	22	22	0.646	-0.115	3.832	0.01	0.007	0	22.4	25.8	74	90	99	0	38	39
2015	12	2	7	32	22	0.656	-0.148	3.832	0.01	0.007	0	21.9	25.8	74	90	99	0	39	39
2015	12	2	7	42	22	0.633	-0.112	3.832	0.01	0.007	0	21.9	26.2	74	90	100	0	39	39
2015	12	2	7	52	22	0.64	-0.141	3.832	0.01	0.007	0	22.4	26.2	74	90	100	0	38	39
2015	12	2	8	2	22	0.627	-0.138	3.835	0.013	0.01	0	22.8	26.2	74	92	100	0	39	39
2015	12	2	8	12	22	0.62	-0.112	3.835	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	8	22	22	0.636	-0.125	3.835	0.013	0.01	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	8	32	22	0.65	-0.118	3.835	0.01	0.007	0	22.8	26.7	73.5	91	101	0	38	39
2015	12	2	8	42	22	0.627	-0.151	3.835	0.01	0.007	0	23.2	26.7	74	92	101	0	38	39
2015	12	2	8	52	22	0.617	-0.154	3.835	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	9	2	22	0.643	-0.144	3.835	0.01	0.007	0	23.2	26.7	74.4	92	101	0	38	39
2015	12	2	9	12	22	0.61	-0.141	3.839	0.013	0.01	0	22.8	26.7	73.1	91	101	0	38	39
2015	12	2	9	22	22	0.636	-0.154	3.839	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	2	9	32	22	0.597	-0.118	3.839	0.01	0.007	0	22.8	27.1	74	91	101	0	38	38
2015	12	2	9	42	22	0.604	-0.105	3.839	0.01	0.007	0	23.2	26.2	74	91	100	0	37	39
2015	12	2	9	52	22	0.571	-0.108	3.839	0.013	0.01	0	23.2	26.7	74	92	101	0	38	39
2015	12	2	10	2	22	0.646	-0.151	3.839	0.01	0.007	0	23.2	25.8	74.4	92	100	0	38	40
2015	12	2	10	12	22	0.63	-0.151	3.839	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	10	22	22	0.663	-0.144	3.839	0.01	0.007	0	22.8	26.2	69.7	91	101	0	38	40
2015	12	2	10	32	22	0.627	-0.112	3.839	0.013	0.01	0	22.8	26.7	73.5	91	101	0	38	39
2015	12	2	10	42	22	0.64	-0.141	3.839	0.01	0.007	0	23.2	26.7	72.2	92	101	0	38	39
2015	12	2	10	52	22	0.636	-0.121	3.839	0.01	0.007	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	2	11	2	22	0.643	-0.151	3.842	0.013	0.01	0	22.8	26.2	73.1	91	100	0	38	39
2015	12	2	11	12	22	0.617	-0.135	3.839	0.01	0.007	0	22.8	26.2	74	91	100	0	38	39
2015	12	2	11	22	22	0.646	-0.112	3.839	0.01	0.007	0	22.8	26.7	68.4	91	101	0	38	39
2015	12	2	11	32	22	0.577	-0.112	3.839	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	2	11	42	22	0.61	-0.102	3.839	0.01	0.007	0	23.2	26.2	74.8	91	100	0	37	39
2015	12	2	11	52	22	0.597	-0.092	3.839	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	2	12	2	22	0.666	-0.125	3.839	0.01	0.007	0	22.4	26.2	74.4	90	100	0	38	39
2015	12	2	12	12	22	0.646	-0.148	3.839	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	12	22	22	0.64	-0.128	3.839	0.013	0.01	0	23.2	26.2	74.8	92	100	0	38	39
2015	12	2	12	32	22	0.63	-0.121	3.839	0.013	0.01	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	2	12	42	22	0.62	-0.157	3.839	0.013	0.01	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	12	52	22	0.614	-0.102	3.839	0.01	0.007	0	22.8	26.7	74.4	91	100	0	38	38
2015	12	2	13	2	22	0.604	-0.138	3.839	0.01	0.007	0	23.6	26.7	74.8	92	101	0	37	39
2015	12	2	13	12	22	0.623	-0.118	3.839	0.01	0.007	0	22.8	25.8	74.8	91	100	0	38	40
2015	12	2	13	22	22	0.656	-0.138	3.839	0.01	0.007	0	22.4	26.7	75.3	90	100	0	38	38
2015	12	2	13	32	22	0.633	-0.128	3.839	0.01	0.007	0	22.4	25.8	75.3	90	99	0	38	39
2015	12	2	13	42	22	0.636	-0.125	3.839	0.01	0.007	0	22.4	26.2	74.8	90	100	0	38	39
2015	12	2	13	52	22	0.64	-0.108	3.835	0.01	0.007	0	22.4	26.7	75.3	91	100	0	39	38
2015	12	2	14	2	22	0.614	-0.148	3.835	0.013	0.01	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	14	12	22	0.64	-0.115	3.835	0.013	0.01	0	22.4	25.8	74.4	90	99	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	14	22	22	0.643	-0.138	3.835	0.01	0.007	0	22.4	26.2	74.8	90	100	0	38	39
2015	12	2	14	32	22	0.64	-0.125	3.839	0.013	0.01	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	2	14	42	22	0.591	-0.102	3.835	0.01	0.007	0	22.4	25.8	75.3	90	99	0	38	39
2015	12	2	14	52	22	0.627	-0.128	3.835	0.01	0.007	0	22.4	25.8	74.8	90	100	0	38	40
2015	12	2	15	2	22	0.623	-0.151	3.835	0.01	0.007	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	2	15	12	22	0.636	-0.144	3.835	0.01	0.007	0	22.4	25.8	75.3	90	99	0	38	39
2015	12	2	15	22	22	0.636	-0.138	3.835	0.013	0.01	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	2	15	32	22	0.614	-0.121	3.835	0.01	0.007	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	2	15	42	22	0.656	-0.125	3.835	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	2	15	52	22	0.63	-0.148	3.835	0.01	0.007	0	21.5	25.4	74.4	89	98	0	39	39
2015	12	2	16	2	22	0.604	-0.112	3.835	0.01	0.007	0	21.9	25.4	74.8	89	98	0	38	39
2015	12	2	16	12	22	0.659	-0.128	3.835	0.01	0.007	0	21.9	25.8	74.4	89	98	0	38	38
2015	12	2	16	22	22	0.659	-0.135	3.835	0.016	0.013	0	21.9	25.8	74.4	90	99	0	39	39
2015	12	2	16	32	22	0.614	-0.151	3.835	0.01	0.007	0	21.9	25.8	74.4	89	99	0	38	39
2015	12	2	16	42	22	0.659	-0.144	3.835	0.01	0.007	0	21.9	25.8	74.4	89	99	0	38	39
2015	12	2	16	52	22	0.669	-0.171	3.835	0.01	0.007	0	21.9	25.8	74.4	89	99	0	38	39
2015	12	2	17	2	22	0.62	-0.131	3.835	0.01	0.007	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	2	17	12	22	0.636	-0.131	3.835	0.01	0.007	0	23.2	26.2	74.4	91	100	0	37	39
2015	12	2	17	22	22	0.646	-0.148	3.835	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	17	32	22	0.623	-0.144	3.835	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	2	17	42	22	0.623	-0.135	3.839	0.013	0.01	0	22.4	25.8	74.4	90	100	0	38	40
2015	12	2	17	52	22	0.623	-0.118	3.835	0.01	0.007	0	22.4	25.8	74	90	99	0	38	39
2015	12	2	18	2	22	0.62	-0.141	3.839	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	2	18	12	22	0.623	-0.138	3.835	0.013	0.01	0	22.8	26.7	73.5	91	101	0	38	39
2015	12	2	18	22	22	0.64	-0.157	3.839	0.013	0.01	0	23.2	26.2	74	91	100	0	37	39
2015	12	2	18	32	22	0.65	-0.138	3.839	0.01	0.007	0	21.5	25.4	74.4	89	98	0	39	39
2015	12	2	18	42	22	0.636	-0.125	3.839	0.013	0.01	0	33.5	37.4	71.4	116	126	0	38	39
2015	12	2	18	52	22	0.63	-0.125	3.839	0.01	0.007	0	26.2	29.7	74.4	99	108	0	38	39
2015	12	2	19	2	22	0.614	-0.131	3.839	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	2	19	12	22	0.636	-0.135	3.839	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	2	19	22	22	0.65	-0.128	3.839	0.01	0.007	0	22.4	26.2	74	90	100	0	38	39
2015	12	2	19	32	22	0.656	-0.141	3.839	0.01	0.007	0	22.4	25.8	74.4	90	99	0	38	39
2015	12	2	19	42	22	0.614	-0.141	3.839	0.01	0.007	0	22.4	25.8	73.5	90	99	0	38	39
2015	12	2	19	52	22	0.663	-0.157	3.839	0.01	0.007	0	22.4	26.2	73.5	90	99	0	38	38
2015	12	2	20	2	22	0.64	-0.148	3.839	0.01	0.007	0	22.8	25.8	73.5	91	100	0	38	40
2015	12	2	20	12	22	0.653	-0.138	3.839	0.01	0.007	0	22.4	25.8	73.5	90	99	0	38	39
2015	12	2	20	22	22	0.653	-0.125	3.839	0.01	0.007	0	21.9	25.8	74	89	99	0	38	39
2015	12	2	20	32	22	0.666	-0.148	3.842	0.01	0.007	0	21.9	25.8	73.5	89	99	0	38	39
2015	12	2	20	42	22	0.63	-0.138	3.839	0.01	0.007	0	21.9	25.8	73.5	90	99	0	39	39
2015	12	2	20	52	22	0.669	-0.148	3.839	0.01	0.007	0	28.4	31.8	73.5	104	113	0	38	39
2015	12	2	21	2	22	0.659	-0.144	3.839	0.01	0.007	0	24.5	28.4	73.1	95	105	0	38	39
2015	12	2	21	12	22	0.653	-0.131	3.839	0.016	0.013	0	28.4	32.3	72.7	104	114	0	38	39
2015	12	2	21	22	22	0.663	-0.148	3.842	0.01	0.007	0	23.2	26.7	70.1	92	101	0	38	39
2015	12	2	21	32	22	0.653	-0.135	3.842	0.01	0.007	0	27.5	31	73.1	102	111	0	38	39
2015	12	2	21	42	22	0.65	-0.151	3.842	0.01	0.007	0	23.2	27.1	73.1	92	102	0	38	39
2015	12	2	21	52	22	0.63	-0.148	3.842	0.01	0.007	0	21.9	25.4	73.1	90	99	0	39	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	22	2	22	0.633	-0.098	3.842	0.01	0.007	0	22.4	25.8	72.7	89	99	0	37	39
2015	12	2	22	12	22	0.627	-0.138	3.842	0.01	0.007	0	22.4	25.4	71.4	90	99	0	38	40
2015	12	2	22	22	22	0.614	-0.135	3.845	0.01	0.007	0	22.8	26.2	73.1	91	100	0	38	39
2015	12	2	22	32	22	0.646	-0.141	3.845	0.01	0.007	0	23.6	27.1	72.2	93	102	0	38	39
2015	12	2	22	42	22	0.607	-0.125	3.848	0.013	0.01	0	25.4	28	73.1	96	104	0	37	39
2015	12	2	22	52	22	0.617	-0.128	3.845	0.01	0.007	0	22.4	26.2	72.7	90	100	0	38	39
2015	12	2	23	2	22	0.633	-0.135	3.848	0.01	0.007	0	22.4	25.8	72.7	90	99	0	38	39
2015	12	2	23	12	22	0.653	-0.141	3.848	0.01	0.007	0	22.4	25.8	72.7	90	99	0	38	39
2015	12	2	23	22	22	0.6	-0.135	3.848	0.01	0.007	0	22.4	26.2	72.7	90	100	0	38	39
2015	12	2	23	32	22	0.63	-0.125	3.852	0.013	0.01	0	21.9	25.4	72.7	89	98	0	38	39
2015	12	2	23	42	22	0.63	-0.167	3.852	0.01	0.007	0	22.4	25.8	73.1	90	99	0	38	39
2015	12	2	23	52	22	0.627	-0.138	3.852	0.01	0.007	0	23.2	26.2	72.7	91	100	0	37	39
2015	12	3	0	2	22	0.64	-0.161	3.852	0.01	0.007	0	22.4	26.2	73.1	90	100	0	38	39
2015	12	3	0	12	22	0.653	-0.112	3.855	0.01	0.007	0	22.8	26.2	72.7	91	100	0	38	39
2015	12	3	0	22	22	0.61	-0.131	3.852	0.01	0.007	0	22.4	26.2	73.1	90	100	0	38	39
2015	12	3	0	32	22	0.633	-0.151	3.855	0.013	0.01	0	23.6	27.1	73.1	93	102	0	38	39
2015	12	3	0	42	22	0.617	-0.135	3.855	0.01	0.007	0	26.2	30.1	73.5	99	109	0	38	39
2015	12	3	0	52	22	0.623	-0.121	3.855	0.01	0.007	0	30.1	33.5	73.1	107	117	0	37	39
2015	12	3	1	2	22	0.663	-0.144	3.855	0.01	0.007	0	32.3	36.1	73.5	113	123	0	38	39
2015	12	3	1	12	22	0.623	-0.135	3.855	0.01	0.007	0	32.7	36.1	73.1	114	123	0	38	39
2015	12	3	1	22	22	0.633	-0.138	3.855	0.01	0.007	0	29.7	33.1	73.1	107	116	0	38	39
2015	12	3	1	32	22	0.633	-0.151	3.855	0.01	0.007	0	34.4	37.8	74	118	127	0	38	39
2015	12	3	1	42	22	0.627	-0.112	3.855	0.01	0.007	0	25.8	29.2	74.4	98	107	0	38	39
2015	12	3	1	52	22	0.656	-0.141	3.855	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	3	2	2	22	0.676	-0.125	3.855	0.01	0.007	0	24.1	27.5	74.8	94	103	0	38	39
2015	12	3	2	12	22	0.627	-0.128	3.855	0.01	0.007	0	24.1	28	74.8	94	104	0	38	39
2015	12	3	2	22	22	0.646	-0.125	3.855	0.01	0.007	0	24.1	27.5	74.4	94	103	0	38	39
2015	12	3	2	32	22	0.673	-0.135	3.858	0.01	0.007	0	23.6	27.5	74.8	93	103	0	38	39
2015	12	3	2	42	22	0.659	-0.138	3.858	0.013	0.01	0	30.1	34	74.8	108	117	0	38	38
2015	12	3	2	52	22	0.63	-0.112	3.855	0.01	0.007	0	35.7	39.6	74.8	121	131	0	38	39
2015	12	3	3	2	22	0.62	-0.148	3.858	0.01	0.007	0	28.8	31.8	75.3	104	113	0	37	39
2015	12	3	3	12	22	0.617	-0.151	3.858	0.01	0.007	0	25.4	28.8	75.3	97	106	0	38	39
2015	12	3	3	22	22	0.669	-0.135	3.858	0.01	0.007	0	24.5	28	75.7	95	104	0	38	39
2015	12	3	3	32	22	0.627	-0.112	3.858	0.01	0.007	0	25.8	29.2	76.1	98	107	0	38	39
2015	12	3	3	42	22	0.659	-0.138	3.858	0.01	0.007	0	24.5	28	76.1	95	104	0	38	39
2015	12	3	3	52	22	0.6	-0.125	3.858	0.01	0.007	0	24.5	28.4	76.1	95	104	0	38	38
2015	12	3	4	2	22	0.63	-0.115	3.858	0.01	0.007	0	24.1	28	76.1	94	104	0	38	39
2015	12	3	4	12	22	0.666	-0.157	3.858	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	3	4	22	22	0.636	-0.138	3.858	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	3	4	32	22	0.607	-0.135	3.858	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	3	4	42	22	0.636	-0.128	3.858	0.01	0.007	0	26.2	30.1	76.1	99	109	0	38	39
2015	12	3	4	52	22	0.64	-0.121	3.862	0.01	0.007	0	24.9	28.4	77	95	104	0	37	38
2015	12	3	5	2	22	0.617	-0.115	3.858	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	3	5	12	22	0.63	-0.141	3.862	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	3	5	22	22	0.623	-0.131	3.862	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	3	5	32	22	0.673	-0.151	3.862	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	5	42	22	0.633	-0.125	3.862	0.016	0.013	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	3	5	52	22	0.659	-0.141	3.862	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	3	6	2	22	0.594	-0.157	3.862	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	3	6	12	22	0.604	-0.125	3.862	0.01	0.007	0	24.1	27.1	77.4	93	102	0	37	39
2015	12	3	6	22	22	0.65	-0.138	3.862	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	3	6	32	22	0.614	-0.148	3.862	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	3	6	42	22	0.653	-0.164	3.862	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	3	6	52	22	0.63	-0.115	3.862	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	3	7	2	22	0.633	-0.125	3.862	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	3	7	12	22	0.656	-0.151	3.862	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	3	7	22	22	0.656	-0.141	3.862	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	3	7	32	22	0.627	-0.125	3.862	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	3	7	42	22	0.627	-0.125	3.865	0.01	0.007	0	22.4	26.2	77	91	100	0	39	39
2015	12	3	7	52	22	0.65	-0.121	3.862	0.01	0.007	0	23.2	26.2	77	91	100	0	37	39
2015	12	3	8	2	22	0.614	-0.131	3.865	0.01	0.007	0	22.8	25.8	76.5	91	100	0	38	40
2015	12	3	8	12	22	0.627	-0.108	3.865	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	3	8	22	22	0.604	-0.121	3.865	0.013	0.01	0	22.8	27.1	77	91	101	0	38	38
2015	12	3	8	32	22	0.623	-0.144	3.865	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	3	8	42	22	0.656	-0.148	3.865	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	3	8	52	22	0.623	-0.128	3.865	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	3	9	2	22	0.61	-0.121	3.868	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	3	9	12	22	0.633	-0.112	3.868	0.01	0.007	0	23.6	26.7	77.4	92	102	0	37	40
2015	12	3	9	22	22	0.64	-0.112	3.868	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	3	9	32	22	0.646	-0.121	3.868	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	3	9	42	22	0.6	-0.112	3.868	0.01	0.007	0	23.2	26.2	77	92	101	0	38	40
2015	12	3	9	52	22	0.6	-0.115	3.868	0.01	0.007	0	23.2	27.1	76.5	92	101	0	38	38
2015	12	3	10	2	22	0.64	-0.125	3.868	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	3	10	12	22	0.623	-0.135	3.868	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	3	10	22	22	0.63	-0.128	3.868	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	3	10	32	22	0.62	-0.105	3.871	0.01	0.007	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	3	10	42	22	0.617	-0.125	3.868	0.01	0.007	0	23.2	27.1	69.2	92	102	0	38	39
2015	12	3	10	52	22	0.604	-0.112	3.868	0.01	0.007	0	23.2	26.7	75.3	92	101	0	38	39
2015	12	3	11	2	22	0.636	-0.121	3.868	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	3	11	12	22	0.643	-0.115	3.871	0.016	0.013	0	23.2	26.7	77	92	101	0	38	39
2015	12	3	11	22	22	0.646	-0.131	3.868	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	3	11	32	22	0.62	-0.128	3.871	0.01	0.007	0	23.6	26.7	61.9	93	101	0	38	39
2015	12	3	11	42	22	0.607	-0.135	3.871	0.01	0.007	0	24.5	28	56.3	95	103	0	38	38
2015	12	3	11	52	22	0.6	-0.128	3.871	0.01	0.007	0	25.4	29.2	58	97	106	0	38	38
2015	12	3	12	2	22	0.633	-0.118	3.875	0.01	0.007	0	24.1	27.5	58.9	94	103	0	38	39
2015	12	3	12	12	22	0.617	-0.148	3.871	0.016	0.013	0	24.9	28.4	50.3	96	105	0	38	39
2015	12	3	12	22	22	0.607	-0.141	3.871	0.01	0.007	0	26.2	30.1	50.7	99	109	0	38	39
2015	12	3	12	32	22	0.623	-0.128	3.871	0.01	0.007	0	25.8	28.8	50.3	98	106	0	38	39
2015	12	3	12	42	22	0.617	-0.121	3.871	0.01	0.007	0	25.8	29.2	49.9	98	107	0	38	39
2015	12	3	12	52	22	0.62	-0.151	3.871	0.01	0.007	0	24.9	29.2	48.2	96	106	0	38	38
2015	12	3	13	2	22	0.594	-0.102	3.868	0.013	0.01	0	25.4	28.4	52.9	96	105	0	37	39
2015	12	3	13	12	22	0.636	-0.167	3.871	0.01	0.007	0	26.2	29.2	49.9	98	107	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	13	22	22	0.574	-0.138	3.871	0.013	0.01	0	24.5	28.4	49	95	104	0	38	38
2015	12	3	13	32	22	0.607	-0.154	3.868	0.01	0.007	0	25.8	29.2	52.5	97	106	0	37	38
2015	12	3	13	42	22	0.597	-0.144	3.871	0.01	0.007	0	25.4	28	54.6	97	105	0	38	40
2015	12	3	13	52	22	0.623	-0.151	3.871	0.01	0.007	0	25.8	29.2	61.1	97	107	0	37	39
2015	12	3	14	2	22	0.581	-0.128	3.871	0.01	0.007	0	25.8	28.8	52.9	97	106	0	37	39
2015	12	3	14	12	22	0.591	-0.138	3.871	0.01	0.007	0	24.9	28	58.5	96	104	0	38	39
2015	12	3	14	22	22	0.591	-0.131	3.871	0.01	0.007	0	24.5	28	56.8	95	104	0	38	39
2015	12	3	14	32	22	0.594	-0.141	3.868	0.016	0.013	0	25.8	28.8	57.6	98	106	0	38	39
2015	12	3	14	42	22	0.594	-0.148	3.868	0.01	0.007	0	25.4	28.8	56.3	97	106	0	38	39
2015	12	3	14	52	22	0.653	-0.131	3.868	0.01	0.007	0	24.1	28	59.3	95	104	0	39	39
2015	12	3	15	2	22	0.64	-0.135	3.868	0.01	0.007	0	24.1	27.5	61.1	94	103	0	38	39
2015	12	3	15	12	22	0.617	-0.125	3.868	0.01	0.007	0	24.1	28	69.7	94	103	0	38	38
2015	12	3	15	22	22	0.64	-0.128	3.868	0.01	0.007	0	24.5	28.4	77.4	95	105	0	38	39
2015	12	3	15	32	22	0.623	-0.138	3.868	0.01	0.007	0	24.9	28.8	77.4	96	106	0	38	39
2015	12	3	15	42	22	0.63	-0.144	3.868	0.01	0.007	0	25.8	29.2	69.2	97	107	0	37	39
2015	12	3	15	52	22	0.63	-0.131	3.868	0.01	0.007	0	31.8	35.3	77	112	121	0	38	39
2015	12	3	16	2	22	0.623	-0.138	3.868	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	3	16	12	22	0.627	-0.164	3.868	0.016	0.013	0	24.5	27.1	77	94	103	0	37	40
2015	12	3	16	22	22	0.643	-0.135	3.868	0.013	0.01	0	22.4	26.7	77	91	101	0	39	39
2015	12	3	16	32	22	0.663	-0.161	3.868	0.01	0.007	0	27.5	31.4	77.4	102	112	0	38	39
2015	12	3	16	42	22	0.623	-0.125	3.868	0.01	0.007	0	24.1	27.5	77	94	103	0	38	39
2015	12	3	16	52	22	0.666	-0.151	3.868	0.013	0.01	0	24.5	28	77.4	95	104	0	38	39
2015	12	3	17	2	22	0.62	-0.138	3.868	0.013	0.01	0	26.2	29.7	77	99	108	0	38	39
2015	12	3	17	12	22	0.623	-0.128	3.868	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	3	17	22	22	0.636	-0.105	3.868	0.01	0.007	0	23.6	28	77	93	103	0	38	38
2015	12	3	17	32	22	0.653	-0.125	3.868	0.01	0.007	0	24.5	28	77	94	104	0	37	39
2015	12	3	17	42	22	0.636	-0.131	3.868	0.01	0.007	0	28	31.4	77.4	103	112	0	38	39
2015	12	3	17	52	22	0.64	-0.161	3.868	0.01	0.007	0	26.7	30.5	77.4	100	111	0	38	40
2015	12	3	18	2	22	0.627	-0.121	3.868	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	3	18	12	22	0.643	-0.128	3.868	0.01	0.007	0	24.5	27.5	77	94	103	0	37	39
2015	12	3	18	22	22	0.617	-0.151	3.868	0.01	0.007	0	24.1	28	76.5	94	104	0	38	39
2015	12	3	18	32	22	0.62	-0.128	3.868	0.01	0.007	0	24.9	28.4	77.4	95	105	0	37	39
2015	12	3	18	42	22	0.656	-0.112	3.871	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	3	18	52	22	0.627	-0.131	3.868	0.01	0.007	0	27.1	31	77	101	111	0	38	39
2015	12	3	19	2	22	0.597	-0.128	3.868	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	3	19	12	22	0.627	-0.121	3.868	0.01	0.007	0	23.6	28	77	93	103	0	38	38
2015	12	3	19	22	22	0.65	-0.118	3.868	0.01	0.007	0	25.4	29.2	77.4	97	106	0	38	38
2015	12	3	19	32	22	0.627	-0.131	3.868	0.01	0.007	0	24.9	28.4	77	95	105	0	37	39
2015	12	3	19	42	22	0.653	-0.131	3.868	0.01	0.007	0	24.9	28.4	76.5	96	105	0	38	39
2015	12	3	19	52	22	0.643	-0.118	3.871	0.013	0.01	0	24.5	28.4	77.4	95	105	0	38	39
2015	12	3	20	2	22	0.653	-0.121	3.868	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	3	20	12	22	0.65	-0.138	3.868	0.01	0.007	0	25.8	29.7	77	99	108	0	39	39
2015	12	3	20	22	22	0.646	-0.102	3.868	0.01	0.007	0	25.4	28.8	77.4	97	106	0	38	39
2015	12	3	20	32	22	0.666	-0.144	3.871	0.01	0.007	0	23.6	28	77.4	93	103	0	38	38
2015	12	3	20	42	22	0.627	-0.138	3.871	0.01	0.007	0	24.5	28	70.5	95	104	0	38	39
2015	12	3	20	52	22	0.636	-0.112	3.871	0.01	0.007	0	24.5	28	77	95	104	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	21	2	22	0.643	-0.125	3.871	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	3	21	12	22	0.636	-0.167	3.871	0.01	0.007	0	25.4	29.2	75.7	97	106	0	38	38
2015	12	3	21	22	22	0.61	-0.112	3.871	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	3	21	32	22	0.627	-0.128	3.871	0.013	0.01	0	24.9	28.8	68.8	96	106	0	38	39
2015	12	3	21	42	22	0.636	-0.125	3.871	0.01	0.007	0	29.2	32.7	76.1	106	115	0	38	39
2015	12	3	21	52	22	0.62	-0.121	3.871	0.01	0.007	0	27.5	31	77	102	111	0	38	39
2015	12	3	22	2	22	0.643	-0.131	3.871	0.013	0.01	0	27.5	31	76.5	102	111	0	38	39
2015	12	3	22	12	22	0.63	-0.115	3.871	0.013	0.01	0	24.1	28	68.4	95	104	0	39	39
2015	12	3	22	22	22	0.633	-0.128	3.871	0.01	0.007	0	24.9	28.4	75.3	96	105	0	38	39
2015	12	3	22	32	22	0.636	-0.125	3.871	0.01	0.007	0	24.5	28	76.5	95	104	0	38	39
2015	12	3	22	42	22	0.643	-0.144	3.871	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	3	22	52	22	0.614	-0.138	3.871	0.01	0.007	0	24.5	28.4	73.1	95	105	0	38	39
2015	12	3	23	2	22	0.607	-0.125	3.871	0.01	0.007	0	24.9	29.2	67.1	96	106	0	38	38
2015	12	3	23	12	22	0.633	-0.108	3.871	0.01	0.007	0	24.9	28.8	74.8	96	106	0	38	39
2015	12	3	23	22	22	0.61	-0.167	3.871	0.01	0.007	0	24.9	28.8	52.5	96	105	0	38	38
2015	12	3	23	32	22	0.607	-0.144	3.871	0.01	0.007	0	24.5	28	55.9	95	104	0	38	39
2015	12	3	23	42	22	0.666	-0.135	3.871	0.01	0.007	0	24.1	28	65.8	94	104	0	38	39
2015	12	3	23	52	22	0.62	-0.157	3.871	0.01	0.007	0	24.1	27.1	50.3	93	102	0	37	39
2015	12	4	0	2	22	0.653	-0.141	3.871	0.01	0.007	0	24.1	27.1	77	93	103	0	37	40
2015	12	4	0	12	22	0.633	-0.144	3.871	0.01	0.007	0	23.6	27.1	76.5	93	102	0	38	39
2015	12	4	0	22	22	0.633	-0.144	3.871	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	4	0	32	22	0.656	-0.118	3.871	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	4	0	42	22	0.617	-0.128	3.871	0.013	0.01	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	4	0	52	22	0.653	-0.125	3.871	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	4	1	2	22	0.653	-0.157	3.871	0.013	0.01	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	4	1	12	22	0.633	-0.125	3.871	0.01	0.007	0	23.2	27.5	76.5	92	102	0	38	38
2015	12	4	1	22	22	0.62	-0.138	3.875	0.01	0.007	0	23.2	27.5	77.8	92	102	0	38	38
2015	12	4	1	32	22	0.63	-0.118	3.871	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	4	1	42	22	0.623	-0.144	3.871	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	4	1	52	22	0.6	-0.105	3.871	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	4	2	2	22	0.666	-0.18	3.871	0.01	0.007	0	22.8	26.2	77.4	91	100	0	38	39
2015	12	4	2	12	22	0.62	-0.154	3.871	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	4	2	22	22	0.633	-0.135	3.875	0.01	0.007	0	22.8	27.1	77	91	101	0	38	38
2015	12	4	2	32	22	0.65	-0.161	3.871	0.01	0.007	0	22.8	26.7	77	91	100	0	38	38
2015	12	4	2	42	22	0.61	-0.105	3.871	0.013	0.01	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	4	2	52	22	0.64	-0.118	3.871	0.013	0.01	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	4	3	2	22	0.656	-0.148	3.871	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	4	3	12	22	0.659	-0.128	3.875	0.01	0.007	0	22.8	26.7	77	92	101	0	39	39
2015	12	4	3	22	22	0.646	-0.115	3.875	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	4	3	32	22	0.663	-0.151	3.871	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	4	3	42	22	0.636	-0.141	3.875	0.013	0.01	0	30.5	34	77	109	118	0	38	39
2015	12	4	3	52	22	0.653	-0.164	3.875	0.01	0.007	0	31	34.8	77.4	110	120	0	38	39
2015	12	4	4	2	22	0.633	-0.148	3.875	0.01	0.007	0	31	34	77.4	109	118	0	37	39
2015	12	4	4	12	22	0.633	-0.148	3.871	0.016	0.013	0	26.7	31	77.4	100	110	0	38	38
2015	12	4	4	22	22	0.659	-0.108	3.871	0.01	0.007	0	31	34.8	77	110	120	0	38	39
2015	12	4	4	32	22	0.65	-0.138	3.871	0.013	0.01	0	27.5	31	77.8	102	111	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	4	42	22	0.633	-0.151	3.871	0.01	0.007	0	24.9	28.4	77.4	96	105	0	38	39
2015	12	4	4	52	22	0.633	-0.115	3.871	0.013	0.01	0	25.4	29.2	77	97	107	0	38	39
2015	12	4	5	2	22	0.627	-0.138	3.875	0.01	0.007	0	27.1	30.5	77	101	110	0	38	39
2015	12	4	5	12	22	0.636	-0.121	3.875	0.01	0.007	0	30.5	34	77.4	108	118	0	37	39
2015	12	4	5	22	22	0.633	-0.161	3.871	0.013	0.01	0	24.5	28.4	77.4	95	105	0	38	39
2015	12	4	5	32	22	0.636	-0.125	3.871	0.01	0.007	0	24.1	27.1	77.8	93	102	0	37	39
2015	12	4	5	42	22	0.633	-0.128	3.871	0.01	0.007	0	23.6	27.5	77.4	93	103	0	38	39
2015	12	4	5	52	22	0.62	-0.131	3.871	0.01	0.007	0	22.8	27.1	77	91	101	0	38	38
2015	12	4	6	2	22	0.653	-0.138	3.871	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	4	6	12	22	0.617	-0.148	3.871	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	4	6	22	22	0.627	-0.115	3.871	0.01	0.007	0	23.2	26.2	77.4	92	101	0	38	40
2015	12	4	6	32	22	0.636	-0.131	3.871	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	4	6	42	22	0.607	-0.135	3.871	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	4	6	52	22	0.65	-0.138	3.871	0.01	0.007	0	22.4	26.7	77.4	90	100	0	38	38
2015	12	4	7	2	22	0.63	-0.128	3.871	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	4	7	12	22	0.61	-0.121	3.871	0.01	0.007	0	22.4	26.7	77.4	90	100	0	38	38
2015	12	4	7	22	22	0.62	-0.118	3.871	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	4	7	32	22	0.62	-0.138	3.871	0.01	0.007	0	22.8	26.7	77.4	91	100	0	38	38
2015	12	4	7	42	22	0.614	-0.128	3.871	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	4	7	52	22	0.623	-0.105	3.871	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	4	8	2	22	0.636	-0.121	3.871	0.016	0.013	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	4	8	12	22	0.65	-0.138	3.871	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	4	8	22	22	0.633	-0.135	3.871	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	4	8	32	22	0.623	-0.118	3.871	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	4	8	42	22	0.604	-0.128	3.871	0.01	0.007	0	23.6	27.1	76.5	93	102	0	38	39
2015	12	4	8	52	22	0.633	-0.151	3.871	0.01	0.007	0	24.5	28.4	75.3	95	104	0	38	38
2015	12	4	9	2	22	0.659	-0.131	3.871	0.01	0.007	0	23.6	27.5	76.1	93	103	0	38	39
2015	12	4	9	12	22	0.63	-0.135	3.871	0.01	0.007	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	4	9	22	22	0.587	-0.118	3.871	0.01	0.007	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	4	9	32	22	0.636	-0.128	3.871	0.01	0.007	0	23.2	26.7	75.3	92	101	0	38	39
2015	12	4	9	42	22	0.627	-0.121	3.871	0.013	0.01	0	23.2	27.1	74.8	92	102	0	38	39
2015	12	4	9	52	22	0.633	-0.141	3.871	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	4	10	2	22	0.627	-0.118	3.871	0.013	0.01	0	23.2	26.7	68.4	91	101	0	37	39
2015	12	4	10	12	22	0.653	-0.121	3.868	0.01	0.007	0	23.6	27.1	61.9	92	102	0	37	39
2015	12	4	10	22	22	0.614	-0.125	3.871	0.01	0.007	0	22.8	27.1	69.7	91	101	0	38	38
2015	12	4	10	32	22	0.64	-0.121	3.868	0.01	0.007	0	23.2	27.1	62.8	91	101	0	37	38
2015	12	4	10	42	22	0.617	-0.138	3.868	0.01	0.007	0	23.6	27.1	60.6	93	102	0	38	39
2015	12	4	10	52	22	0.617	-0.128	3.868	0.01	0.007	0	23.2	27.1	71.4	92	102	0	38	39
2015	12	4	11	2	22	0.614	-0.128	3.868	0.01	0.007	0	23.2	26.7	72.7	92	101	0	38	39
2015	12	4	11	12	22	0.62	-0.144	3.868	0.01	0.007	0	22.8	27.1	73.1	91	101	0	38	38
2015	12	4	11	22	22	0.64	-0.112	3.865	0.01	0.007	0	23.6	27.1	73.1	92	102	0	37	39
2015	12	4	11	32	22	0.627	-0.131	3.862	0.01	0.007	0	23.2	26.7	73.1	91	101	0	37	39
2015	12	4	11	42	22	0.62	-0.115	3.862	0.013	0.01	0	22.8	26.7	73.1	91	101	0	38	39
2015	12	4	11	52	22	0.591	-0.135	3.862	0.01	0.007	0	23.2	26.7	73.5	91	101	0	37	39
2015	12	4	12	2	22	0.617	-0.141	3.862	0.01	0.007	0	22.8	26.2	73.5	91	100	0	38	39
2015	12	4	12	12	22	0.633	-0.154	3.862	0.01	0.007	0	23.6	27.1	72.7	92	102	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	12	22	22	0.617	-0.131	3.862	0.01	0.007	0	23.2	27.1	74	91	101	0	37	38
2015	12	4	12	32	22	0.587	-0.118	3.858	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	4	12	42	22	0.643	-0.121	3.858	0.01	0.007	0	23.2	26.7	74.8	91	101	0	37	39
2015	12	4	12	52	22	0.617	-0.148	3.858	0.013	0.01	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	4	13	2	22	0.61	-0.125	3.858	0.01	0.007	0	22.4	26.7	74.4	90	100	0	38	38
2015	12	4	13	12	22	0.617	-0.135	3.858	0.01	0.007	0	24.1	27.5	75.3	93	103	0	37	39
2015	12	4	13	22	22	0.614	-0.138	3.858	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	4	13	32	22	0.61	-0.128	3.858	0.01	0.007	0	23.2	27.5	74	92	102	0	38	38
2015	12	4	13	42	22	0.633	-0.148	3.858	0.01	0.007	0	22.8	26.7	75.7	91	101	0	38	39
2015	12	4	13	52	22	0.633	-0.138	3.855	0.01	0.007	0	22.8	26.7	75.7	91	101	0	38	39
2015	12	4	14	2	22	0.623	-0.148	3.855	0.01	0.007	0	22.8	27.1	75.7	91	101	0	38	38
2015	12	4	14	12	22	0.656	-0.102	3.855	0.01	0.007	0	22.8	27.5	75.7	91	102	0	38	38
2015	12	4	14	22	22	0.636	-0.098	3.855	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	4	14	32	22	0.64	-0.148	3.852	0.01	0.007	0	23.2	27.1	75.7	92	101	0	38	38
2015	12	4	14	42	22	0.64	-0.148	3.852	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	4	14	52	22	0.64	-0.154	3.852	0.01	0.007	0	22.8	26.2	76.5	90	100	0	37	39
2015	12	4	15	2	22	0.63	-0.115	3.852	0.013	0.01	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	4	15	12	22	0.643	-0.121	3.852	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	4	15	22	22	0.646	-0.118	3.848	0.01	0.007	0	23.2	26.7	76.1	91	101	0	37	39
2015	12	4	15	32	22	0.64	-0.141	3.852	0.01	0.007	0	23.2	26.7	77	91	101	0	37	39
2015	12	4	15	42	22	0.604	-0.131	3.848	0.01	0.007	0	23.2	26.7	77	91	101	0	37	39
2015	12	4	15	52	22	0.607	-0.112	3.848	0.01	0.007	0	22.8	27.1	76.5	91	101	0	38	38
2015	12	4	16	2	22	0.64	-0.128	3.848	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	4	16	12	22	0.604	-0.102	3.848	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	4	16	22	22	0.61	-0.128	3.848	0.01	0.007	0	23.2	26.2	77.4	91	100	0	37	39
2015	12	4	16	32	22	0.614	-0.112	3.848	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	4	16	42	22	0.62	-0.115	3.848	0.01	0.007	0	23.2	26.7	77.4	91	100	0	37	38
2015	12	4	16	52	22	0.617	-0.128	3.848	0.01	0.007	0	23.2	26.2	77	91	100	0	37	39
2015	12	4	17	2	22	0.614	-0.138	3.848	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	4	17	12	22	0.636	-0.118	3.848	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	4	17	22	22	0.646	-0.135	3.848	0.013	0.01	0	22.8	26.7	77	91	101	0	38	39
2015	12	4	17	32	22	0.627	-0.135	3.848	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	4	17	42	22	0.623	-0.112	3.848	0.01	0.007	0	24.1	28	77	93	103	0	37	38
2015	12	4	17	52	22	0.61	-0.144	3.845	0.013	0.01	0	23.6	27.1	77.8	93	103	0	38	40
2015	12	4	18	2	22	0.63	-0.115	3.848	0.01	0.007	0	24.5	28.8	77.4	95	105	0	38	38
2015	12	4	18	12	22	0.6	-0.108	3.845	0.013	0.01	0	24.9	28.4	77.8	95	105	0	37	39
2015	12	4	18	22	22	0.62	-0.118	3.845	0.013	0.01	0	27.5	31	77	101	111	0	37	39
2015	12	4	18	32	22	0.62	-0.066	3.845	0.01	0.007	0	28	31.8	77.4	103	112	0	38	38
2015	12	4	18	42	22	0.636	-0.141	3.845	0.01	0.007	0	24.9	28.8	77.4	96	106	0	38	39
2015	12	4	18	52	22	0.65	-0.115	3.845	0.01	0.007	0	25.8	29.7	77.4	97	108	0	37	39
2015	12	4	19	2	22	0.64	-0.128	3.845	0.01	0.007	0	24.5	28.4	77.8	95	105	0	38	39
2015	12	4	19	12	22	0.63	-0.125	3.845	0.01	0.007	0	24.1	28	77.8	94	104	0	38	39
2015	12	4	19	22	22	0.594	-0.098	3.845	0.01	0.007	0	23.2	28	77.8	92	103	0	38	38
2015	12	4	19	32	22	0.607	-0.128	3.845	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	4	19	42	22	0.614	-0.148	3.845	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	4	19	52	22	0.64	-0.128	3.845	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	20	2	22	0.64	-0.141	3.842	0.01	0.007	0	23.6	28	77.8	93	103	0	38	38
2015	12	4	20	12	22	0.6	-0.135	3.842	0.01	0.007	0	23.6	27.5	77.4	93	102	0	38	38
2015	12	4	20	22	22	0.646	-0.108	3.842	0.01	0.007	0	23.2	27.5	77.4	92	102	0	38	38
2015	12	4	20	32	22	0.62	-0.115	3.842	0.01	0.007	0	23.6	27.1	77	92	102	0	37	39
2015	12	4	20	42	22	0.617	-0.095	3.842	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	4	20	52	22	0.64	-0.144	3.842	0.01	0.007	0	23.2	26.7	77	91	101	0	37	39
2015	12	4	21	2	22	0.64	-0.148	3.842	0.013	0.01	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	4	21	12	22	0.597	-0.118	3.842	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	4	21	22	22	0.65	-0.138	3.842	0.01	0.007	0	23.6	27.1	75.7	92	102	0	37	39
2015	12	4	21	32	22	0.61	-0.108	3.839	0.013	0.01	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	4	21	42	22	0.617	-0.112	3.839	0.01	0.007	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	4	21	52	22	0.591	-0.112	3.839	0.013	0.01	0	23.2	27.5	74.8	92	102	0	38	38
2015	12	4	22	2	22	0.62	-0.118	3.839	0.01	0.007	0	23.2	27.1	74.8	92	102	0	38	39
2015	12	4	22	12	22	0.623	-0.138	3.839	0.01	0.007	0	23.2	27.5	74.8	92	102	0	38	38
2015	12	4	22	22	22	0.62	-0.125	3.839	0.01	0.007	0	23.2	27.1	74.4	92	102	0	38	39
2015	12	4	22	32	22	0.607	-0.121	3.839	0.01	0.007	0	23.2	28	74.4	92	103	0	38	38
2015	12	4	22	42	22	0.623	-0.128	3.839	0.01	0.007	0	23.6	28	74.4	92	103	0	37	38
2015	12	4	22	52	22	0.614	-0.105	3.835	0.013	0.01	0	23.6	27.1	74	92	102	0	37	39
2015	12	4	23	2	22	0.623	-0.138	3.835	0.01	0.007	0	23.2	26.7	73.5	92	101	0	38	39
2015	12	4	23	12	22	0.584	-0.108	3.835	0.01	0.007	0	23.6	27.5	73.5	93	103	0	38	39
2015	12	4	23	22	22	0.63	-0.102	3.835	0.01	0.007	0	22.8	27.1	73.5	91	101	0	38	38
2015	12	4	23	32	22	0.659	-0.121	3.832	0.01	0.007	0	23.2	27.5	72.7	92	102	0	38	38
2015	12	4	23	42	22	0.63	-0.105	3.829	0.01	0.007	0	23.2	27.1	73.1	92	101	0	38	38
2015	12	4	23	52	22	0.627	-0.144	3.825	0.01	0.007	0	23.2	27.1	73.5	92	102	0	38	39
2015	12	5	0	2	22	0.614	-0.118	3.825	0.01	0.007	0	23.2	26.7	73.5	92	101	0	38	39
2015	12	5	0	12	22	0.636	-0.115	3.825	0.01	0.007	0	23.2	27.1	74	92	102	0	38	39
2015	12	5	0	22	22	0.604	-0.125	3.822	0.01	0.007	0	23.2	27.5	74	92	102	0	38	38
2015	12	5	0	32	22	0.646	-0.151	3.822	0.01	0.007	0	23.2	27.1	74	91	101	0	37	38
2015	12	5	0	42	22	0.646	-0.144	3.822	0.013	0.01	0	22.8	26.7	74.4	90	101	0	37	39
2015	12	5	0	52	22	0.627	-0.102	3.822	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	5	1	2	22	0.64	-0.105	3.822	0.01	0.007	0	23.2	27.1	74	92	102	0	38	39
2015	12	5	1	12	22	0.63	-0.108	3.819	0.01	0.007	0	22.8	27.1	74.4	91	102	0	38	39
2015	12	5	1	22	22	0.653	-0.148	3.819	0.01	0.007	0	22.4	26.7	74.4	90	101	0	38	39
2015	12	5	1	32	22	0.636	-0.144	3.819	0.013	0.01	0	23.2	27.5	74.8	92	102	0	38	38
2015	12	5	1	42	22	0.623	-0.131	3.819	0.01	0.007	0	23.6	27.1	75.3	92	102	0	37	39
2015	12	5	1	52	22	0.604	-0.102	3.819	0.013	0.01	0	23.2	27.1	75.3	91	102	0	37	39
2015	12	5	2	2	22	0.614	-0.105	3.819	0.01	0.007	0	22.8	27.1	75.3	91	101	0	38	38
2015	12	5	2	12	22	0.62	-0.118	3.819	0.01	0.007	0	22.8	26.7	74.8	91	100	0	38	38
2015	12	5	2	22	22	0.627	-0.128	3.819	0.01	0.007	0	23.6	27.1	75.3	92	102	0	37	39
2015	12	5	2	32	22	0.627	-0.115	3.816	0.01	0.007	0	22.8	27.1	75.3	91	101	0	38	38
2015	12	5	2	42	22	0.636	-0.161	3.816	0.01	0.007	0	23.2	26.7	75.3	91	101	0	37	39
2015	12	5	2	52	22	0.633	-0.115	3.816	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	5	3	2	22	0.627	-0.092	3.816	0.01	0.007	0	22.8	27.1	76.1	91	101	0	38	38
2015	12	5	3	12	22	0.617	-0.115	3.816	0.013	0.01	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	5	3	22	22	0.61	-0.151	3.816	0.01	0.007	0	22.8	27.1	75.7	91	101	0	38	38
2015	12	5	3	32	22	0.627	-0.121	3.816	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	3	42	22	0.627	-0.135	3.816	0.01	0.007	0	22.4	26.7	75.7	90	101	0	38	39
2015	12	5	3	52	22	0.633	-0.154	3.812	0.01	0.007	0	22.8	26.7	76.1	91	100	0	38	38
2015	12	5	4	2	22	0.643	-0.128	3.812	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	5	4	12	22	0.63	-0.135	3.812	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	5	4	22	22	0.614	-0.102	3.812	0.013	0.01	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	5	4	32	22	0.636	-0.151	3.812	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	5	4	42	22	0.614	-0.115	3.812	0.01	0.007	0	23.6	27.5	76.1	93	103	0	38	39
2015	12	5	4	52	22	0.614	-0.141	3.812	0.01	0.007	0	22.4	26.7	76.1	90	101	0	38	39
2015	12	5	5	2	22	0.636	-0.144	3.812	0.01	0.007	0	28.8	33.1	76.1	105	116	0	38	39
2015	12	5	5	12	22	0.627	-0.154	3.812	0.01	0.007	0	28.8	32.3	76.1	105	114	0	38	39
2015	12	5	5	22	22	0.614	-0.125	3.809	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	5	5	32	22	0.587	-0.118	3.809	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	5	5	42	22	0.6	-0.115	3.809	0.016	0.013	0	23.6	27.5	76.5	92	102	0	37	38
2015	12	5	5	52	22	0.623	-0.135	3.809	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	5	6	2	22	0.6	-0.092	3.809	0.01	0.007	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	5	6	12	22	0.653	-0.115	3.809	0.01	0.007	0	23.6	27.5	77.4	92	102	0	37	38
2015	12	5	6	22	22	0.646	-0.154	3.809	0.01	0.007	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	5	6	32	22	0.65	-0.125	3.809	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	5	6	42	22	0.627	-0.138	3.809	0.01	0.007	0	22.8	27.1	77.4	91	102	0	38	39
2015	12	5	6	52	22	0.646	-0.144	3.809	0.01	0.007	0	22.8	26.2	77.4	91	100	0	38	39
2015	12	5	7	2	22	0.62	-0.108	3.806	0.016	0.013	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	5	7	12	22	0.571	-0.105	3.806	0.01	0.007	0	23.2	26.7	77.8	91	101	0	37	39
2015	12	5	7	22	22	0.623	-0.135	3.806	0.01	0.007	0	22.4	26.2	77.8	90	100	0	38	39
2015	12	5	7	32	22	0.627	-0.138	3.806	0.01	0.007	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	5	7	42	22	0.591	-0.128	3.806	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	5	7	52	22	0.594	-0.125	3.806	0.016	0.013	0	22.4	26.7	77.8	90	100	0	38	38
2015	12	5	8	2	22	0.64	-0.128	3.806	0.01	0.007	0	22.8	26.7	77.8	91	101	0	38	39
2015	12	5	8	12	22	0.6	-0.128	3.806	0.01	0.007	0	23.2	27.1	77.8	91	101	0	37	38
2015	12	5	8	22	22	0.623	-0.128	3.806	0.01	0.007	0	23.2	26.7	77.8	91	101	0	37	39
2015	12	5	8	32	22	0.614	-0.098	3.806	0.01	0.007	0	23.2	27.1	77.8	91	101	0	37	38
2015	12	5	8	42	22	0.643	-0.128	3.806	0.01	0.007	0	22.8	26.7	77.8	91	101	0	38	39
2015	12	5	8	52	22	0.636	-0.098	3.806	0.013	0.01	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	5	9	2	22	0.617	-0.121	3.806	0.01	0.007	0	22.8	26.7	77.8	91	101	0	38	39
2015	12	5	9	12	22	0.63	-0.108	3.806	0.013	0.01	0	22.8	26.7	78.3	91	101	0	38	39
2015	12	5	9	22	22	0.607	-0.121	3.806	0.01	0.007	0	23.2	27.1	78.3	92	102	0	38	39
2015	12	5	9	32	22	0.653	-0.144	3.809	0.01	0.007	0	23.6	27.5	77.8	92	102	0	37	38
2015	12	5	9	42	22	0.607	-0.118	3.806	0.01	0.007	0	23.6	26.7	77.4	92	101	0	37	39
2015	12	5	9	52	22	0.623	-0.121	3.809	0.013	0.01	0	23.2	27.5	77.4	91	101	0	37	37
2015	12	5	10	2	22	0.597	-0.121	3.809	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	5	10	12	22	0.61	-0.144	3.809	0.01	0.007	0	22.8	26.7	67.1	91	101	0	38	39
2015	12	5	10	22	22	0.617	-0.154	3.809	0.01	0.007	0	23.2	27.5	77.4	92	102	0	38	38
2015	12	5	10	32	22	0.627	-0.135	3.806	0.01	0.007	0	23.2	27.1	77	91	101	0	37	38
2015	12	5	10	42	22	0.607	-0.144	3.809	0.01	0.007	0	22.8	27.1	76.1	91	101	0	38	38
2015	12	5	10	52	22	0.6	-0.125	3.809	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	5	11	2	22	0.587	-0.102	3.806	0.01	0.007	0	23.2	26.7	76.5	91	101	0	37	39
2015	12	5	11	12	22	0.594	-0.118	3.806	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	11	22	22	0.594	-0.135	3.806	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	5	11	32	22	0.607	-0.148	3.809	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	5	11	42	22	0.607	-0.141	3.806	0.01	0.007	0	23.2	27.5	76.1	92	102	0	38	38
2015	12	5	11	52	22	0.581	-0.131	3.806	0.01	0.007	0	23.2	26.7	72.2	91	101	0	37	39
2015	12	5	12	2	22	0.587	-0.102	3.806	0.013	0.01	0	23.2	26.7	75.7	91	101	0	37	39
2015	12	5	12	12	22	0.61	-0.135	3.806	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	5	12	22	22	0.577	-0.128	3.806	0.01	0.007	0	23.2	26.7	75.3	91	101	0	37	39
2015	12	5	12	32	22	0.614	-0.121	3.802	0.01	0.007	0	22.8	26.7	70.1	91	101	0	38	39
2015	12	5	12	42	22	0.617	-0.125	3.802	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	5	12	52	22	0.591	-0.128	3.802	0.01	0.007	0	22.8	27.1	74	91	101	0	38	38
2015	12	5	13	2	22	0.6	-0.144	3.799	0.01	0.007	0	22.8	26.7	73.1	91	101	0	38	39
2015	12	5	13	12	22	0.643	-0.171	3.802	0.01	0.007	0	22.4	26.2	73.5	90	100	0	38	39
2015	12	5	13	22	22	0.61	-0.118	3.802	0.01	0.007	0	23.2	26.7	73.5	91	101	0	37	39
2015	12	5	13	32	22	0.633	-0.141	3.799	0.013	0.01	0	22.8	26.7	68.4	91	101	0	38	39
2015	12	5	13	42	22	0.636	-0.141	3.796	0.01	0.007	0	23.6	27.1	72.7	92	102	0	37	39
2015	12	5	13	52	22	0.591	-0.167	3.796	0.013	0.01	0	24.1	27.5	55.5	93	102	0	37	38
2015	12	5	14	2	22	0.63	-0.177	3.799	0.013	0.01	0	24.1	26.7	52	93	101	0	37	39
2015	12	5	14	12	22	0.617	-0.171	3.796	0.01	0.007	0	24.1	27.5	53.3	94	103	0	38	39
2015	12	5	14	22	22	0.623	-0.154	3.793	0.01	0.007	0	23.6	26.7	59.3	92	101	0	37	39
2015	12	5	14	32	22	0.614	-0.164	3.789	0.013	0.01	0	23.2	26.7	58.5	92	101	0	38	39
2015	12	5	14	42	22	0.574	-0.167	3.789	0.01	0.007	0	23.6	27.1	54.6	93	102	0	38	39
2015	12	5	14	52	22	0.617	-0.151	3.789	0.01	0.007	0	24.1	27.1	58.9	93	102	0	37	39
2015	12	5	15	2	22	0.594	-0.135	3.786	0.013	0.01	0	23.6	27.1	58.9	92	102	0	37	39
2015	12	5	15	12	22	0.617	-0.144	3.786	0.013	0.01	0	23.6	27.1	59.8	93	101	0	38	38
2015	12	5	15	22	22	0.614	-0.164	3.786	0.01	0.007	0	22.8	27.1	64.5	91	101	0	38	38
2015	12	5	15	32	22	0.594	-0.144	3.783	0.01	0.007	0	23.2	27.1	61.5	92	102	0	38	39
2015	12	5	15	42	22	0.604	-0.141	3.783	0.01	0.007	0	23.6	27.5	62.8	92	102	0	37	38
2015	12	5	15	52	22	0.63	-0.151	3.783	0.013	0.01	0	23.2	27.1	74.8	91	101	0	37	38
2015	12	5	16	2	22	0.587	-0.118	3.783	0.01	0.007	0	22.8	26.7	74.8	91	100	0	38	38
2015	12	5	16	12	22	0.591	-0.131	3.783	0.01	0.007	0	23.2	26.7	75.3	91	101	0	37	39
2015	12	5	16	22	22	0.6	-0.141	3.783	0.01	0.007	0	23.2	26.7	74.8	91	101	0	37	39
2015	12	5	16	32	22	0.604	-0.131	3.783	0.01	0.007	0	22.4	27.1	75.7	90	101	0	38	38
2015	12	5	16	42	22	0.63	-0.118	3.783	0.01	0.007	0	23.2	27.1	75.7	91	101	0	37	38
2015	12	5	16	52	22	0.623	-0.154	3.783	0.013	0.01	0	22.4	26.7	75.7	91	101	0	39	39
2015	12	5	17	2	22	0.6	-0.108	3.78	0.01	0.007	0	22.8	27.1	75.3	91	101	0	38	38
2015	12	5	17	12	22	0.607	-0.102	3.78	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	5	17	22	22	0.597	-0.118	3.78	0.01	0.007	0	23.6	27.5	75.7	93	103	0	38	39
2015	12	5	17	32	22	0.627	-0.135	3.78	0.01	0.007	0	23.6	28	76.1	93	103	0	38	38
2015	12	5	17	42	22	0.617	-0.121	3.78	0.013	0.01	0	23.6	27.5	76.1	93	103	0	38	39
2015	12	5	17	52	22	0.627	-0.115	3.78	0.01	0.007	0	24.5	28.4	76.1	95	105	0	38	39
2015	12	5	18	2	22	0.627	-0.128	3.78	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	5	18	12	22	0.607	-0.154	3.78	0.016	0.013	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	5	18	22	22	0.61	-0.108	3.78	0.01	0.007	0	24.9	28.8	76.1	96	106	0	38	39
2015	12	5	18	32	22	0.607	-0.121	3.78	0.01	0.007	0	25.4	28.8	76.5	96	106	0	37	39
2015	12	5	18	42	22	0.636	-0.118	3.776	0.01	0.007	0	25.4	29.7	76.5	97	107	0	38	38
2015	12	5	18	52	22	0.604	-0.141	3.776	0.01	0.007	0	25.8	29.7	76.5	98	108	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	19	2	22	0.666	-0.121	3.776	0.01	0.007	0	25.4	29.7	76.5	97	107	0	38	38
2015	12	5	19	12	22	0.64	-0.164	3.776	0.01	0.007	0	27.1	30.5	77	100	110	0	37	39
2015	12	5	19	22	22	0.61	-0.118	3.776	0.016	0.013	0	24.5	28	77	95	104	0	38	39
2015	12	5	19	32	22	0.64	-0.131	3.776	0.01	0.007	0	24.1	28	77.4	94	104	0	38	39
2015	12	5	19	42	22	0.623	-0.138	3.776	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	5	19	52	22	0.614	-0.154	3.776	0.013	0.01	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	5	20	2	22	0.633	-0.128	3.776	0.016	0.013	0	24.1	27.5	77	93	103	0	37	39
2015	12	5	20	12	22	0.591	-0.118	3.776	0.013	0.01	0	24.1	27.1	77.4	93	102	0	37	39
2015	12	5	20	22	22	0.594	-0.115	3.776	0.01	0.007	0	24.1	27.5	77.8	93	102	0	37	38
2015	12	5	20	32	22	0.646	-0.125	3.776	0.01	0.007	0	24.1	28	77.4	93	103	0	37	38
2015	12	5	20	42	22	0.607	-0.121	3.776	0.01	0.007	0	23.6	27.5	77.4	92	102	0	37	38
2015	12	5	20	52	22	0.607	-0.131	3.776	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	5	21	2	22	0.627	-0.135	3.776	0.01	0.007	0	24.1	27.5	77.8	93	103	0	37	39
2015	12	5	21	12	22	0.627	-0.135	3.776	0.01	0.007	0	24.9	28.4	77.8	95	105	0	37	39
2015	12	5	21	22	22	0.607	-0.131	3.776	0.01	0.007	0	23.6	27.1	78.3	92	102	0	37	39
2015	12	5	21	32	22	0.604	-0.112	3.776	0.013	0.01	0	24.1	27.5	77.8	93	103	0	37	39
2015	12	5	21	42	22	0.62	-0.141	3.773	0.01	0.007	0	23.6	27.5	77.8	93	102	0	38	38
2015	12	5	21	52	22	0.63	-0.135	3.773	0.01	0.007	0	23.6	27.5	77.4	93	103	0	38	39
2015	12	5	22	2	22	0.594	-0.108	3.773	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	5	22	12	22	0.6	-0.118	3.773	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	5	22	22	22	0.614	-0.154	3.773	0.01	0.007	0	23.6	27.5	77.4	93	103	0	38	39
2015	12	5	22	32	22	0.627	-0.151	3.773	0.013	0.01	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	5	22	42	22	0.617	-0.131	3.773	0.013	0.01	0	23.6	28	77.4	93	103	0	38	38
2015	12	5	22	52	22	0.643	-0.138	3.773	0.01	0.007	0	23.6	27.5	77.8	92	102	0	37	38
2015	12	5	23	2	22	0.62	-0.118	3.773	0.01	0.007	0	23.6	28	78.3	93	103	0	38	38
2015	12	5	23	12	22	0.65	-0.121	3.773	0.01	0.007	0	23.2	27.5	77.8	92	102	0	38	38
2015	12	5	23	22	22	0.623	-0.118	3.773	0.01	0.007	0	23.6	27.1	77.4	92	102	0	37	39
2015	12	5	23	32	22	0.591	-0.154	3.773	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	5	23	42	22	0.604	-0.089	3.773	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	5	23	52	22	0.627	-0.141	3.773	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	6	0	2	22	0.607	-0.148	3.773	0.01	0.007	0	23.2	28	78.3	92	103	0	38	38
2015	12	6	0	12	22	0.577	-0.118	3.773	0.01	0.007	0	23.6	27.5	78.3	92	102	0	37	38
2015	12	6	0	22	22	0.623	-0.131	3.773	0.013	0.01	0	23.2	26.7	78.3	92	101	0	38	39
2015	12	6	0	32	22	0.63	-0.118	3.773	0.01	0.007	0	23.6	27.5	77.8	93	103	0	38	39
2015	12	6	0	42	22	0.623	-0.128	3.77	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	6	0	52	22	0.577	-0.102	3.77	0.01	0.007	0	23.6	28	77.8	93	103	0	38	38
2015	12	6	1	2	22	0.6	-0.151	3.77	0.016	0.013	0	23.6	27.1	77	92	102	0	37	39
2015	12	6	1	12	22	0.627	-0.098	3.77	0.01	0.007	0	22.8	27.5	77.8	91	102	0	38	38
2015	12	6	1	22	22	0.591	-0.115	3.77	0.013	0.01	0	23.2	27.1	78.3	92	102	0	38	39
2015	12	6	1	32	22	0.614	-0.108	3.77	0.01	0.007	0	23.2	27.5	78.3	91	102	0	37	38
2015	12	6	1	42	22	0.597	-0.128	3.77	0.01	0.007	0	23.2	26.7	78.3	91	101	0	37	39
2015	12	6	1	52	22	0.6	-0.151	3.77	0.01	0.007	0	23.6	27.5	77.8	92	102	0	37	38
2015	12	6	2	2	22	0.614	-0.128	3.77	0.01	0.007	0	22.8	27.5	77.8	91	102	0	38	38
2015	12	6	2	12	22	0.584	-0.144	3.77	0.01	0.007	0	23.2	27.1	78.3	92	102	0	38	39
2015	12	6	2	22	22	0.627	-0.148	3.77	0.016	0.013	0	23.2	26.7	77.8	91	101	0	37	39
2015	12	6	2	32	22	0.617	-0.098	3.77	0.01	0.007	0	24.1	28	77.8	93	103	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	2	42	22	0.604	-0.131	3.77	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	6	2	52	22	0.627	-0.079	3.766	0.01	0.007	0	22.8	27.5	77.8	92	102	0	39	38
2015	12	6	3	2	22	0.63	-0.115	3.77	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	6	3	12	22	0.607	-0.148	3.77	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	6	3	22	22	0.64	-0.131	3.766	0.01	0.007	0	23.2	26.7	75.7	91	101	0	37	39
2015	12	6	3	32	22	0.594	-0.135	3.766	0.01	0.007	0	23.6	27.1	76.5	92	101	0	37	38
2015	12	6	3	42	22	0.617	-0.121	3.766	0.01	0.007	0	24.9	28.8	77.4	96	106	0	38	39
2015	12	6	3	52	22	0.64	-0.157	3.766	0.01	0.007	0	25.4	29.2	77.4	97	107	0	38	39
2015	12	6	4	2	22	0.6	-0.102	3.766	0.013	0.01	0	25.4	28.8	77.4	96	106	0	37	39
2015	12	6	4	12	22	0.614	-0.115	3.766	0.01	0.007	0	23.6	28	77.4	93	103	0	38	38
2015	12	6	4	22	22	0.591	-0.138	3.766	0.013	0.01	0	24.9	28	77.4	95	104	0	37	39
2015	12	6	4	32	22	0.614	-0.131	3.766	0.01	0.007	0	25.4	29.7	77	97	108	0	38	39
2015	12	6	4	42	22	0.63	-0.125	3.766	0.01	0.007	0	24.1	28	77	93	103	0	37	38
2015	12	6	4	52	22	0.604	-0.151	3.766	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	6	5	2	22	0.614	-0.108	3.763	0.013	0.01	0	31.4	34.8	77	111	120	0	38	39
2015	12	6	5	12	22	0.62	-0.167	3.766	0.01	0.007	0	26.2	29.7	76.5	98	108	0	37	39
2015	12	6	5	22	22	0.656	-0.144	3.763	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	6	5	32	22	0.587	-0.108	3.766	0.01	0.007	0	24.1	27.1	77	93	102	0	37	39
2015	12	6	5	42	22	0.646	-0.144	3.766	0.01	0.007	0	22.8	27.5	76.5	91	102	0	38	38
2015	12	6	5	52	22	0.64	-0.115	3.763	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	6	6	2	22	0.64	-0.128	3.763	0.01	0.007	0	23.2	27.1	76.1	92	101	0	38	38
2015	12	6	6	12	22	0.607	-0.148	3.763	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	6	6	22	22	0.623	-0.138	3.763	0.01	0.007	0	23.2	27.5	75.7	92	102	0	38	38
2015	12	6	6	32	22	0.61	-0.125	3.763	0.01	0.007	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	6	6	42	22	0.62	-0.118	3.763	0.01	0.007	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	6	6	52	22	0.627	-0.128	3.763	0.01	0.007	0	23.2	27.5	75.7	92	102	0	38	38
2015	12	6	7	2	22	0.623	-0.138	3.763	0.01	0.007	0	22.8	27.1	75.3	91	101	0	38	38
2015	12	6	7	12	22	0.627	-0.131	3.763	0.01	0.007	0	23.2	27.1	74.8	91	102	0	37	39
2015	12	6	7	22	22	0.614	-0.144	3.763	0.01	0.007	0	23.6	27.1	75.3	92	102	0	37	39
2015	12	6	7	32	22	0.617	-0.154	3.763	0.013	0.01	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	6	7	42	22	0.617	-0.121	3.76	0.013	0.01	0	23.6	26.7	74.8	92	101	0	37	39
2015	12	6	7	52	22	0.633	-0.121	3.76	0.013	0.01	0	22.8	27.5	75.3	91	102	0	38	38
2015	12	6	8	2	22	0.62	-0.128	3.763	0.01	0.007	0	23.6	27.5	74.8	92	102	0	37	38
2015	12	6	8	12	22	0.61	-0.151	3.76	0.01	0.007	0	23.6	27.1	74.8	92	102	0	37	39
2015	12	6	8	22	22	0.62	-0.177	3.763	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	6	8	32	22	0.64	-0.138	3.763	0.01	0.007	0	24.5	28.4	74.8	94	104	0	37	38
2015	12	6	8	42	22	0.623	-0.138	3.763	0.01	0.007	0	23.6	27.5	74	93	103	0	38	39
2015	12	6	8	52	22	0.597	-0.128	3.763	0.013	0.01	0	24.1	26.7	74	93	102	0	37	40
2015	12	6	9	2	22	0.604	-0.148	3.763	0.01	0.007	0	23.6	27.5	74.4	93	103	0	38	39
2015	12	6	9	12	22	0.607	-0.121	3.763	0.01	0.007	0	23.2	26.7	74	92	101	0	38	39
2015	12	6	9	22	22	0.604	-0.141	3.763	0.013	0.01	0	23.2	27.1	74	92	101	0	38	38
2015	12	6	9	32	22	0.581	-0.118	3.763	0.01	0.007	0	23.2	27.1	74	92	102	0	38	39
2015	12	6	9	42	22	0.617	-0.141	3.763	0.01	0.007	0	23.2	26.7	74	92	101	0	38	39
2015	12	6	9	52	22	0.617	-0.128	3.763	0.01	0.007	0	23.6	27.1	73.5	92	102	0	37	39
2015	12	6	10	2	22	0.564	-0.154	3.763	0.01	0.007	0	23.2	27.5	73.5	92	102	0	38	38
2015	12	6	10	12	22	0.607	-0.128	3.763	0.01	0.007	0	23.6	27.1	73.1	92	101	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	10	22	22	0.607	-0.157	3.763	0.01	0.007	0	23.6	26.7	73.5	92	101	0	37	39
2015	12	6	10	32	22	0.61	-0.157	3.76	0.01	0.007	0	22.8	26.7	73.5	91	101	0	38	39
2015	12	6	10	42	22	0.594	-0.151	3.76	0.01	0.007	0	23.6	27.1	74	92	102	0	37	39
2015	12	6	10	52	22	0.591	-0.161	3.76	0.01	0.007	0	23.6	27.1	73.5	93	102	0	38	39
2015	12	6	11	2	22	0.617	-0.151	3.757	0.01	0.007	0	23.2	27.1	73.1	92	101	0	38	38
2015	12	6	11	12	22	0.587	-0.138	3.757	0.01	0.007	0	23.6	27.5	73.1	92	102	0	37	38
2015	12	6	11	22	22	0.6	-0.151	3.757	0.01	0.007	0	23.6	27.5	73.5	93	103	0	38	39
2015	12	6	11	32	22	0.6	-0.135	3.757	0.01	0.007	0	23.6	27.1	71.4	93	102	0	38	39
2015	12	6	11	42	22	0.614	-0.148	3.753	0.01	0.007	0	23.2	26.7	72.2	92	101	0	38	39
2015	12	6	11	52	22	0.61	-0.161	3.753	0.013	0.01	0	23.6	27.1	74	92	101	0	37	38
2015	12	6	12	2	22	0.584	-0.141	3.757	0.01	0.007	0	23.6	26.7	53.8	92	101	0	37	39
2015	12	6	12	12	22	0.62	-0.141	3.757	0.013	0.01	0	23.2	26.7	52.9	92	101	0	38	39
2015	12	6	12	22	22	0.574	-0.144	3.757	0.01	0.007	0	23.6	27.5	52.5	93	102	0	38	38
2015	12	6	12	32	22	0.6	-0.161	3.757	0.01	0.007	0	24.1	27.5	50.3	94	103	0	38	39
2015	12	6	12	42	22	0.577	-0.135	3.757	0.01	0.007	0	24.5	28.4	51.6	95	105	0	38	39
2015	12	6	12	52	22	0.591	-0.157	3.757	0.013	0.01	0	25.4	28.8	51.6	96	105	0	37	38
2015	12	6	13	2	22	0.604	-0.157	3.757	0.013	0.01	0	24.1	28	54.6	94	103	0	38	38
2015	12	6	13	12	22	0.594	-0.164	3.76	0.01	0.007	0	24.5	27.5	53.3	94	103	0	37	39
2015	12	6	13	22	22	0.62	-0.128	3.753	0.01	0.007	0	23.6	27.1	60.6	93	102	0	38	39
2015	12	6	13	32	22	0.607	-0.164	3.753	0.01	0.007	0	24.1	28	57.6	94	103	0	38	38
2015	12	6	13	42	22	0.627	-0.118	3.753	0.01	0.007	0	23.6	27.1	74	92	102	0	37	39
2015	12	6	13	52	22	0.633	-0.164	3.757	0.01	0.007	0	23.6	27.1	55.9	93	102	0	38	39
2015	12	6	14	2	22	0.61	-0.157	3.753	0.01	0.007	0	23.6	27.5	61.1	93	103	0	38	39
2015	12	6	14	12	22	0.591	-0.151	3.753	0.013	0.01	0	24.1	28	53.8	94	103	0	38	38
2015	12	6	14	22	22	0.571	-0.144	3.753	0.01	0.007	0	24.5	27.5	55.5	94	103	0	37	39
2015	12	6	14	32	22	0.61	-0.135	3.75	0.01	0.007	0	23.6	27.5	61.9	92	102	0	37	38
2015	12	6	14	42	22	0.617	-0.112	3.75	0.01	0.007	0	24.1	27.5	68.4	93	103	0	37	39
2015	12	6	14	52	22	0.571	-0.148	3.75	0.01	0.007	0	23.6	27.5	73.5	93	102	0	38	38
2015	12	6	15	2	22	0.581	-0.141	3.75	0.01	0.007	0	24.1	27.5	74.4	94	103	0	38	39
2015	12	6	15	12	22	0.65	-0.154	3.747	0.01	0.007	0	23.2	27.1	74.8	92	102	0	38	39
2015	12	6	15	22	22	0.614	-0.167	3.747	0.01	0.007	0	22.8	26.7	74	91	101	0	38	39
2015	12	6	15	32	22	0.64	-0.141	3.747	0.01	0.007	0	22.8	27.1	74.8	91	101	0	38	38
2015	12	6	15	42	22	0.604	-0.144	3.747	0.01	0.007	0	23.2	27.5	74.8	92	102	0	38	38
2015	12	6	15	52	22	0.64	-0.151	3.747	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	6	16	2	22	0.627	-0.144	3.747	0.016	0.013	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	6	16	12	22	0.61	-0.135	3.747	0.01	0.007	0	22.8	27.1	74.4	91	101	0	38	38
2015	12	6	16	22	22	0.617	-0.128	3.747	0.01	0.007	0	23.2	26.7	74.8	91	101	0	37	39
2015	12	6	16	32	22	0.617	-0.148	3.747	0.01	0.007	0	23.6	26.7	75.3	92	101	0	37	39
2015	12	6	16	42	22	0.617	-0.128	3.747	0.01	0.007	0	23.2	26.7	75.3	91	101	0	37	39
2015	12	6	16	52	22	0.584	-0.125	3.747	0.01	0.007	0	23.6	26.7	75.3	92	101	0	37	39
2015	12	6	17	2	22	0.614	-0.161	3.747	0.01	0.007	0	23.2	27.1	75.7	91	102	0	37	39
2015	12	6	17	12	22	0.633	-0.138	3.747	0.01	0.007	0	22.8	27.1	75.3	91	101	0	38	38
2015	12	6	17	22	22	0.604	-0.125	3.743	0.01	0.007	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	6	17	32	22	0.561	-0.151	3.743	0.01	0.007	0	23.6	27.5	74.8	92	102	0	37	38
2015	12	6	17	42	22	0.6	-0.141	3.747	0.01	0.007	0	24.1	27.5	75.7	93	102	0	37	38
2015	12	6	17	52	22	0.594	-0.141	3.747	0.01	0.007	0	24.1	28	75.7	93	103	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	18	2	22	0.617	-0.151	3.747	0.01	0.007	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	6	18	12	22	0.614	-0.131	3.743	0.013	0.01	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	6	18	22	22	0.64	-0.141	3.743	0.013	0.01	0	25.4	29.2	75.7	96	107	0	37	39
2015	12	6	18	32	22	0.62	-0.125	3.743	0.01	0.007	0	24.9	28.8	75.7	96	106	0	38	39
2015	12	6	18	42	22	0.62	-0.141	3.743	0.01	0.007	0	24.5	28	75.7	94	104	0	37	39
2015	12	6	18	52	22	0.614	-0.128	3.743	0.01	0.007	0	24.5	28.8	76.1	95	105	0	38	38
2015	12	6	19	2	22	0.591	-0.18	3.743	0.01	0.007	0	25.8	29.7	75.3	97	107	0	37	38
2015	12	6	19	12	22	0.6	-0.141	3.743	0.01	0.007	0	25.8	29.7	76.1	98	107	0	38	38
2015	12	6	19	22	22	0.627	-0.128	3.743	0.01	0.007	0	24.5	28.8	76.1	95	105	0	38	38
2015	12	6	19	32	22	0.597	-0.128	3.743	0.01	0.007	0	24.5	28	75.7	94	104	0	37	39
2015	12	6	19	42	22	0.64	-0.154	3.743	0.01	0.007	0	24.1	27.5	76.1	93	103	0	37	39
2015	12	6	19	52	22	0.61	-0.128	3.743	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	6	20	2	22	0.584	-0.144	3.743	0.01	0.007	0	24.1	27.1	76.5	93	102	0	37	39
2015	12	6	20	12	22	0.6	-0.157	3.743	0.01	0.007	0	23.6	28	76.1	93	103	0	38	38
2015	12	6	20	22	22	0.627	-0.128	3.743	0.01	0.007	0	23.6	27.5	76.1	93	102	0	38	38
2015	12	6	20	32	22	0.597	-0.141	3.743	0.013	0.01	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	6	20	42	22	0.607	-0.174	3.743	0.01	0.007	0	23.6	26.7	76.1	92	101	0	37	39
2015	12	6	20	52	22	0.623	-0.141	3.743	0.01	0.007	0	23.6	27.5	76.5	93	102	0	38	38
2015	12	6	21	2	22	0.584	-0.151	3.74	0.01	0.007	0	23.6	27.5	76.5	92	102	0	37	38
2015	12	6	21	12	22	0.61	-0.141	3.743	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	6	21	22	22	0.614	-0.164	3.74	0.01	0.007	0	23.6	27.5	76.5	93	102	0	38	38
2015	12	6	21	32	22	0.617	-0.128	3.74	0.01	0.007	0	24.1	27.5	76.5	93	102	0	37	38
2015	12	6	21	42	22	0.6	-0.151	3.743	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	6	21	52	22	0.604	-0.135	3.74	0.01	0.007	0	23.2	27.1	77	92	101	0	38	38
2015	12	6	22	2	22	0.587	-0.148	3.74	0.013	0.01	0	23.6	27.1	77	92	102	0	37	39
2015	12	6	22	12	22	0.591	-0.121	3.74	0.01	0.007	0	23.2	27.1	76.1	92	101	0	38	38
2015	12	6	22	22	22	0.614	-0.141	3.74	0.01	0.007	0	23.6	27.5	77	93	102	0	38	38
2015	12	6	22	32	22	0.6	-0.167	3.74	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	6	22	42	22	0.587	-0.164	3.74	0.01	0.007	0	24.9	28.4	76.5	96	105	0	38	39
2015	12	6	22	52	22	0.597	-0.157	3.74	0.013	0.01	0	24.5	28	77	95	104	0	38	39
2015	12	6	23	2	22	0.627	-0.131	3.74	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	6	23	12	22	0.623	-0.174	3.74	0.01	0.007	0	24.1	27.5	75.7	93	103	0	37	39
2015	12	6	23	22	22	0.577	-0.108	3.74	0.013	0.01	0	24.9	29.2	77	96	106	0	38	38
2015	12	6	23	32	22	0.614	-0.112	3.74	0.01	0.007	0	24.1	28	77	94	103	0	38	38
2015	12	6	23	42	22	0.591	-0.141	3.74	0.01	0.007	0	25.4	29.2	75.7	97	107	0	38	39
2015	12	6	23	52	22	0.627	-0.161	3.74	0.013	0.01	0	25.8	29.7	77	97	107	0	37	38
2015	12	7	0	2	22	0.584	-0.161	3.74	0.013	0.01	0	23.6	27.5	77	92	102	0	37	38
2015	12	7	0	12	22	0.568	-0.135	3.74	0.013	0.01	0	23.6	27.5	76.5	92	102	0	37	38
2015	12	7	0	22	22	0.607	-0.164	3.74	0.01	0.007	0	24.1	27.5	77	93	103	0	37	39
2015	12	7	0	32	22	0.594	-0.141	3.74	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	7	0	42	22	0.63	-0.151	3.74	0.01	0.007	0	23.6	26.7	77.4	92	101	0	37	39
2015	12	7	0	52	22	0.623	-0.164	3.74	0.016	0.013	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	7	1	2	22	0.623	-0.148	3.74	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	7	1	12	22	0.614	-0.131	3.74	0.01	0.007	0	23.2	27.5	77	92	102	0	38	38
2015	12	7	1	22	22	0.617	-0.138	3.74	0.013	0.01	0	23.6	26.7	77.4	92	101	0	37	39
2015	12	7	1	32	22	0.614	-0.131	3.74	0.013	0.01	0	23.2	26.7	77.4	91	101	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	1	42	22	0.614	-0.141	3.74	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	7	1	52	22	0.614	-0.121	3.74	0.01	0.007	0	24.1	27.5	77	93	103	0	37	39
2015	12	7	2	2	22	0.62	-0.144	3.74	0.01	0.007	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	7	2	12	22	0.627	-0.177	3.74	0.01	0.007	0	23.2	27.1	77.4	92	101	0	38	38
2015	12	7	2	22	22	0.574	-0.131	3.737	0.01	0.007	0	23.2	27.5	77.4	92	102	0	38	38
2015	12	7	2	32	22	0.627	-0.121	3.737	0.01	0.007	0	23.2	26.7	77	91	101	0	37	39
2015	12	7	2	42	22	0.604	-0.121	3.737	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	7	2	52	22	0.617	-0.141	3.737	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	7	3	2	22	0.627	-0.151	3.74	0.01	0.007	0	23.6	26.7	77.4	92	101	0	37	39
2015	12	7	3	12	22	0.653	-0.144	3.737	0.01	0.007	0	28.4	32.3	77	103	113	0	37	38
2015	12	7	3	22	22	0.61	-0.128	3.74	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	7	3	32	22	0.577	-0.167	3.74	0.01	0.007	0	23.6	27.1	77	92	102	0	37	39
2015	12	7	3	42	22	0.584	-0.118	3.737	0.01	0.007	0	23.2	27.1	77.4	91	101	0	37	38
2015	12	7	3	52	22	0.604	-0.115	3.737	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	7	4	2	22	0.63	-0.135	3.737	0.01	0.007	0	27.1	31	77.4	100	111	0	37	39
2015	12	7	4	12	22	0.64	-0.148	3.737	0.01	0.007	0	27.5	31	77.4	101	111	0	37	39
2015	12	7	4	22	22	0.633	-0.128	3.737	0.01	0.007	0	25.4	29.7	77	97	107	0	38	38
2015	12	7	4	32	22	0.64	-0.135	3.737	0.01	0.007	0	24.5	28.8	77	96	106	0	39	39
2015	12	7	4	42	22	0.617	-0.164	3.737	0.01	0.007	0	25.4	29.7	77	97	107	0	38	38
2015	12	7	4	52	22	0.643	-0.105	3.737	0.01	0.007	0	24.5	27.5	77.4	94	103	0	37	39
2015	12	7	5	2	22	0.64	-0.154	3.737	0.016	0.013	0	27.1	31	77.4	101	111	0	38	39
2015	12	7	5	12	22	0.62	-0.154	3.737	0.01	0.007	0	26.7	30.1	77.8	99	109	0	37	39
2015	12	7	5	22	22	0.597	-0.128	3.737	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	7	5	32	22	0.604	-0.115	3.737	0.01	0.007	0	23.6	27.1	77.4	92	102	0	37	39
2015	12	7	5	42	22	0.633	-0.148	3.737	0.01	0.007	0	23.2	27.1	77.4	92	101	0	38	38
2015	12	7	5	52	22	0.627	-0.138	3.737	0.01	0.007	0	23.2	27.1	77.4	92	101	0	38	38
2015	12	7	6	2	22	0.636	-0.115	3.737	0.01	0.007	0	22.8	27.5	77.4	91	102	0	38	38
2015	12	7	6	12	22	0.604	-0.151	3.737	0.01	0.007	0	24.1	27.1	77.4	93	102	0	37	39
2015	12	7	6	22	22	0.64	-0.121	3.737	0.01	0.007	0	23.2	27.1	77.4	91	101	0	37	38
2015	12	7	6	32	22	0.6	-0.141	3.737	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	7	6	42	22	0.61	-0.151	3.737	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	7	6	52	22	0.623	-0.138	3.737	0.01	0.007	0	22.8	26.7	77	91	100	0	38	38
2015	12	7	7	2	22	0.617	-0.141	3.737	0.01	0.007	0	22.8	27.1	77	92	102	0	39	39
2015	12	7	7	12	22	0.614	-0.171	3.737	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	7	7	22	22	0.617	-0.131	3.737	0.013	0.01	0	24.1	27.1	77.4	93	102	0	37	39
2015	12	7	7	32	22	0.627	-0.138	3.737	0.01	0.007	0	23.2	26.2	77.4	91	100	0	37	39
2015	12	7	7	42	22	0.62	-0.154	3.737	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	7	7	52	22	0.6	-0.174	3.737	0.01	0.007	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	7	8	2	22	0.614	-0.151	3.737	0.01	0.007	0	22.8	27.1	77.4	91	101	0	38	38
2015	12	7	8	12	22	0.614	-0.118	3.737	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	7	8	22	22	0.607	-0.157	3.737	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	7	8	32	22	0.617	-0.151	3.737	0.01	0.007	0	23.6	27.1	77.8	93	102	0	38	39
2015	12	7	8	42	22	0.604	-0.115	3.737	0.01	0.007	0	23.2	27.5	77.8	92	102	0	38	38
2015	12	7	8	52	22	0.591	-0.141	3.74	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	7	9	2	22	0.604	-0.131	3.74	0.013	0.01	0	23.2	27.5	77.8	92	102	0	38	38
2015	12	7	9	12	22	0.581	-0.164	3.74	0.01	0.007	0	23.2	27.5	77.4	92	102	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	9	22	22	0.636	-0.135	3.74	0.01	0.007	0	23.2	27.1	73.1	92	102	0	38	39
2015	12	7	9	32	22	0.61	-0.151	3.74	0.01	0.007	0	23.6	27.1	74	93	102	0	38	39
2015	12	7	9	42	22	0.633	-0.138	3.74	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	7	9	52	22	0.61	-0.144	3.74	0.01	0.007	0	23.6	27.5	77.8	93	102	0	38	38
2015	12	7	10	2	22	0.617	-0.141	3.74	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	7	10	12	22	0.604	-0.128	3.74	0.01	0.007	0	23.2	27.1	77.8	92	102	0	38	39
2015	12	7	10	22	22	0.587	-0.121	3.74	0.01	0.007	0	23.6	26.7	78.3	92	101	0	37	39
2015	12	7	10	32	22	0.623	-0.131	3.74	0.013	0.01	0	23.6	27.5	78.3	92	103	0	37	39
2015	12	7	10	42	22	0.62	-0.118	3.74	0.01	0.007	0	23.2	27.1	78.3	92	101	0	38	38
2015	12	7	10	52	22	0.62	-0.131	3.74	0.01	0.007	0	23.2	27.5	77.8	92	102	0	38	38
2015	12	7	11	2	22	0.587	-0.128	3.743	0.01	0.007	0	23.2	27.5	78.3	92	102	0	38	38
2015	12	7	11	12	22	0.607	-0.128	3.743	0.01	0.007	0	23.6	27.1	77.8	92	102	0	37	39
2015	12	7	11	22	22	0.636	-0.131	3.743	0.01	0.007	0	23.6	27.5	78.3	93	103	0	38	39
2015	12	7	11	32	22	0.623	-0.131	3.74	0.01	0.007	0	23.6	28	77.8	93	103	0	38	38
2015	12	7	11	42	22	0.594	-0.118	3.74	0.01	0.007	0	23.2	28	78.3	92	103	0	38	38
2015	12	7	11	52	22	0.617	-0.141	3.74	0.01	0.007	0	23.2	27.1	78.7	92	102	0	38	39
2015	12	7	12	2	22	0.604	-0.085	3.74	0.013	0.01	0	24.1	28	77.8	93	103	0	37	38
2015	12	7	12	12	22	0.594	-0.118	3.74	0.01	0.007	0	23.6	27.5	78.3	93	102	0	38	38
2015	12	7	12	22	22	0.607	-0.121	3.74	0.01	0.007	0	23.6	27.5	78.3	92	103	0	37	39
2015	12	7	12	32	22	0.6	-0.144	3.743	0.01	0.007	0	23.2	27.5	78.3	92	102	0	38	38
2015	12	7	12	42	22	0.63	-0.128	3.74	0.016	0.013	0	24.1	28	78.3	93	103	0	37	38
2015	12	7	12	52	22	0.614	-0.131	3.74	0.01	0.007	0	23.6	28	77.4	93	103	0	38	38
2015	12	7	13	2	22	0.604	-0.118	3.74	0.01	0.007	0	23.2	27.1	78.3	92	102	0	38	39
2015	12	7	13	12	22	0.584	-0.121	3.74	0.013	0.01	0	24.5	28	76.1	94	104	0	37	39
2015	12	7	13	22	22	0.62	-0.131	3.74	0.016	0.013	0	23.6	27.5	68.8	93	102	0	38	38
2015	12	7	13	32	22	0.594	-0.118	3.74	0.016	0.013	0	23.6	28	78.3	92	103	0	37	38
2015	12	7	13	42	22	0.61	-0.138	3.74	0.01	0.007	0	24.1	28.4	78.3	94	104	0	38	38
2015	12	7	13	52	22	0.594	-0.102	3.74	0.01	0.007	0	24.5	28.4	77	94	104	0	37	38
2015	12	7	14	2	22	0.62	-0.131	3.74	0.01	0.007	0	24.5	28.4	75.7	94	104	0	37	38
2015	12	7	14	12	22	0.597	-0.121	3.737	0.01	0.007	0	24.5	28.4	76.1	94	104	0	37	38
2015	12	7	14	22	22	0.62	-0.138	3.737	0.01	0.007	0	24.1	28.4	74.4	94	104	0	38	38
2015	12	7	14	32	22	0.627	-0.135	3.737	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	7	14	42	22	0.63	-0.141	3.737	0.01	0.007	0	24.5	28.8	77	95	105	0	38	38
2015	12	7	14	52	22	0.623	-0.148	3.737	0.01	0.007	0	24.5	28.8	77	95	105	0	38	38
2015	12	7	15	2	22	0.63	-0.121	3.737	0.013	0.01	0	24.5	28	77.4	94	104	0	37	39
2015	12	7	15	12	22	0.617	-0.141	3.734	0.01	0.007	0	23.6	28	77.4	93	104	0	38	39
2015	12	7	15	22	22	0.63	-0.141	3.734	0.013	0.01	0	24.1	28.4	77.4	94	104	0	38	38
2015	12	7	15	32	22	0.617	-0.112	3.734	0.01	0.007	0	24.1	28	77	93	103	0	37	38
2015	12	7	15	42	22	0.61	-0.125	3.734	0.01	0.007	0	23.6	27.1	76.1	92	102	0	37	39
2015	12	7	15	52	22	0.594	-0.125	3.734	0.01	0.007	0	23.2	26.7	77.4	91	101	0	37	39
2015	12	7	16	2	22	0.61	-0.128	3.734	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	7	16	12	22	0.604	-0.138	3.734	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	7	16	22	22	0.61	-0.115	3.734	0.01	0.007	0	24.1	28	77.4	93	103	0	37	38
2015	12	7	16	32	22	0.607	-0.115	3.734	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	7	16	42	22	0.607	-0.128	3.734	0.01	0.007	0	23.6	28	77	93	103	0	38	38
2015	12	7	16	52	22	0.617	-0.125	3.734	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	17	2	22	0.607	-0.121	3.734	0.01	0.007	0	24.1	28	77	93	103	0	37	38
2015	12	7	17	12	22	0.591	-0.118	3.734	0.01	0.007	0	24.1	28	76.5	93	103	0	37	38
2015	12	7	17	22	22	0.63	-0.125	3.734	0.01	0.007	0	24.1	28	76.5	93	103	0	37	38
2015	12	7	17	32	22	0.643	-0.131	3.734	0.01	0.007	0	24.5	28.4	75.7	94	104	0	37	38
2015	12	7	17	42	22	0.633	-0.131	3.73	0.01	0.007	0	24.1	28	76.1	94	104	0	38	39
2015	12	7	17	52	22	0.604	-0.112	3.734	0.016	0.013	0	24.9	29.2	76.1	96	106	0	38	38
2015	12	7	18	2	22	0.617	-0.154	3.73	0.01	0.007	0	24.5	28.4	76.1	94	104	0	37	38
2015	12	7	18	12	22	0.594	-0.131	3.73	0.01	0.007	0	24.1	28	76.1	94	104	0	38	39
2015	12	7	18	22	22	0.607	-0.138	3.73	0.01	0.007	0	24.5	28	75.7	94	104	0	37	39
2015	12	7	18	32	22	0.633	-0.121	3.73	0.01	0.007	0	24.1	28.4	75.7	94	105	0	38	39
2015	12	7	18	42	22	0.64	-0.131	3.73	0.01	0.007	0	24.1	28	75.7	94	104	0	38	39
2015	12	7	18	52	22	0.643	-0.115	3.73	0.01	0.007	0	25.4	30.1	75.7	97	108	0	38	38
2015	12	7	19	2	22	0.577	-0.121	3.73	0.01	0.007	0	25.4	28.8	75.7	96	106	0	37	39
2015	12	7	19	12	22	0.636	-0.118	3.73	0.01	0.007	0	25.8	29.7	74.8	98	108	0	38	39
2015	12	7	19	22	22	0.633	-0.154	3.73	0.013	0.01	0	25.4	29.2	74.8	96	106	0	37	38
2015	12	7	19	32	22	0.594	-0.144	3.73	0.01	0.007	0	25.4	28.8	75.3	96	106	0	37	39
2015	12	7	19	42	22	0.61	-0.144	3.73	0.016	0.013	0	24.9	28.8	74.8	95	105	0	37	38
2015	12	7	19	52	22	0.617	-0.141	3.73	0.01	0.007	0	25.8	30.1	74.8	98	108	0	38	38
2015	12	7	20	2	22	0.659	-0.144	3.73	0.01	0.007	0	27.1	30.5	74.8	100	110	0	37	39
2015	12	7	20	12	22	0.617	-0.128	3.73	0.01	0.007	0	25.4	28.8	74.8	96	106	0	37	39
2015	12	7	20	22	22	0.607	-0.095	3.73	0.01	0.007	0	24.5	29.2	74.8	95	106	0	38	38
2015	12	7	20	32	22	0.594	-0.118	3.73	0.013	0.01	0	24.5	28.8	74	94	105	0	37	38
2015	12	7	20	42	22	0.584	-0.141	3.73	0.01	0.007	0	24.1	28	74.4	94	104	0	38	39
2015	12	7	20	52	22	0.587	-0.095	3.73	0.01	0.007	0	24.1	28.4	74.4	94	105	0	38	39
2015	12	7	21	2	22	0.63	-0.161	3.73	0.01	0.007	0	24.1	28	74	94	104	0	38	39
2015	12	7	21	12	22	0.62	-0.108	3.73	0.01	0.007	0	24.9	28.8	74	95	104	0	37	37
2015	12	7	21	22	22	0.623	-0.102	3.73	0.01	0.007	0	24.1	28	74	94	104	0	38	39
2015	12	7	21	32	22	0.597	-0.118	3.727	0.01	0.007	0	24.1	28.8	74	94	105	0	38	38
2015	12	7	21	42	22	0.623	-0.128	3.727	0.01	0.007	0	24.1	28.4	74.4	94	104	0	38	38
2015	12	7	21	52	22	0.63	-0.135	3.727	0.01	0.007	0	24.1	28	74	93	103	0	37	38
2015	12	7	22	2	22	0.623	-0.128	3.727	0.01	0.007	0	24.1	28	74	94	104	0	38	39
2015	12	7	22	12	22	0.63	-0.141	3.727	0.013	0.01	0	24.1	28	73.5	93	104	0	37	39
2015	12	7	22	22	22	0.597	-0.121	3.724	0.01	0.007	0	24.1	28	73.5	94	104	0	38	39
2015	12	7	22	32	22	0.581	-0.118	3.724	0.013	0.01	0	24.5	28	74	94	104	0	37	39
2015	12	7	22	42	22	0.62	-0.128	3.724	0.01	0.007	0	24.1	28	74	94	103	0	38	38
2015	12	7	22	52	22	0.62	-0.118	3.724	0.01	0.007	0	24.1	28.4	74	93	104	0	37	38
2015	12	7	23	2	22	0.584	-0.115	3.724	0.01	0.007	0	25.4	28.8	73.5	96	106	0	37	39
2015	12	7	23	12	22	0.627	-0.128	3.724	0.01	0.007	0	24.1	28	73.5	94	104	0	38	39
2015	12	7	23	22	22	0.614	-0.148	3.72	0.013	0.01	0	24.1	28.4	73.5	93	104	0	37	38
2015	12	7	23	32	22	0.627	-0.105	3.72	0.01	0.007	0	23.6	28.4	73.5	94	104	0	39	38
2015	12	7	23	42	22	0.614	-0.154	3.724	0.01	0.007	0	24.5	28.4	73.5	94	104	0	37	38
2015	12	7	23	52	22	0.594	-0.151	3.72	0.013	0.01	0	24.9	28	73.5	94	104	0	36	39
2015	12	8	0	2	22	0.594	-0.144	3.72	0.013	0.01	0	24.1	28.4	74	94	104	0	38	38
2015	12	8	0	12	22	0.62	-0.154	3.72	0.01	0.007	0	24.5	27.5	73.5	94	103	0	37	39
2015	12	8	0	22	22	0.594	-0.115	3.72	0.01	0.007	0	24.5	29.2	73.5	95	106	0	38	38
2015	12	8	0	32	22	0.607	-0.157	3.72	0.013	0.01	0	24.1	28.4	73.5	94	104	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	0	42	22	0.607	-0.105	3.72	0.01	0.007	0	23.6	28	74	94	104	0	39	39
2015	12	8	0	52	22	0.63	-0.144	3.717	0.016	0.013	0	23.6	27.5	74	93	103	0	38	39
2015	12	8	1	2	22	0.607	-0.128	3.72	0.01	0.007	0	24.9	28.4	74	95	105	0	37	39
2015	12	8	1	12	22	0.597	-0.128	3.717	0.01	0.007	0	24.9	28.4	73.5	95	105	0	37	39
2015	12	8	1	22	22	0.62	-0.144	3.717	0.013	0.01	0	24.1	28	73.5	94	104	0	38	39
2015	12	8	1	32	22	0.614	-0.128	3.717	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	8	1	42	22	0.614	-0.128	3.717	0.01	0.007	0	23.6	28	74	93	104	0	38	39
2015	12	8	1	52	22	0.62	-0.125	3.717	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	8	2	2	22	0.607	-0.121	3.717	0.01	0.007	0	24.1	28	74	93	103	0	37	38
2015	12	8	2	12	22	0.607	-0.148	3.717	0.01	0.007	0	24.1	28	74	94	104	0	38	39
2015	12	8	2	22	22	0.646	-0.164	3.717	0.01	0.007	0	24.1	28.4	73.5	94	104	0	38	38
2015	12	8	2	32	22	0.607	-0.118	3.717	0.013	0.01	0	24.1	28	74	93	104	0	37	39
2015	12	8	2	42	22	0.63	-0.121	3.717	0.01	0.007	0	24.1	28	74.4	93	103	0	37	38
2015	12	8	2	52	22	0.597	-0.105	3.717	0.01	0.007	0	24.5	28.4	73.5	94	104	0	37	38
2015	12	8	3	2	22	0.587	-0.138	3.717	0.013	0.01	0	24.5	28.4	73.5	94	104	0	37	38
2015	12	8	3	12	22	0.61	-0.144	3.717	0.01	0.007	0	24.5	28.4	74	94	104	0	37	38
2015	12	8	3	22	22	0.62	-0.118	3.717	0.01	0.007	0	24.5	28.4	74	94	104	0	37	38
2015	12	8	3	32	22	0.623	-0.141	3.714	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	8	3	42	22	0.607	-0.125	3.717	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	8	3	52	22	0.607	-0.118	3.714	0.01	0.007	0	24.1	28	74	93	103	0	37	38
2015	12	8	4	2	22	0.62	-0.144	3.717	0.01	0.007	0	23.6	28	74	93	104	0	38	39
2015	12	8	4	12	22	0.627	-0.118	3.714	0.01	0.007	0	23.6	28	74.4	94	104	0	39	39
2015	12	8	4	22	22	0.604	-0.138	3.714	0.01	0.007	0	24.1	28	73.5	94	104	0	38	39
2015	12	8	4	32	22	0.6	-0.118	3.714	0.01	0.007	0	23.6	28	74	93	103	0	38	38
2015	12	8	4	42	22	0.614	-0.121	3.717	0.01	0.007	0	24.5	28	74.4	94	104	0	37	39
2015	12	8	4	52	22	0.617	-0.144	3.714	0.01	0.007	0	23.6	28	74	93	103	0	38	38
2015	12	8	5	2	22	0.617	-0.128	3.714	0.013	0.01	0	23.6	27.5	74	93	103	0	38	39
2015	12	8	5	12	22	0.63	-0.151	3.714	0.013	0.01	0	24.1	28	74.4	94	103	0	38	38
2015	12	8	5	22	22	0.594	-0.115	3.714	0.01	0.007	0	23.6	28	74	93	103	0	38	38
2015	12	8	5	32	22	0.636	-0.135	3.714	0.01	0.007	0	24.1	28	74	93	103	0	37	38
2015	12	8	5	42	22	0.614	-0.121	3.714	0.01	0.007	0	24.9	28.8	73.1	96	106	0	38	39
2015	12	8	5	52	22	0.633	-0.141	3.714	0.01	0.007	0	25.4	29.2	73.5	97	107	0	38	39
2015	12	8	6	2	22	0.633	-0.174	3.714	0.01	0.007	0	26.7	30.1	73.5	99	109	0	37	39
2015	12	8	6	12	22	0.63	-0.118	3.714	0.01	0.007	0	27.1	31	74	101	111	0	38	39
2015	12	8	6	22	22	0.617	-0.141	3.714	0.01	0.007	0	25.8	29.2	74	97	107	0	37	39
2015	12	8	6	32	22	0.607	-0.118	3.714	0.01	0.007	0	24.5	28.4	74.4	94	105	0	37	39
2015	12	8	6	42	22	0.591	-0.131	3.714	0.01	0.007	0	24.1	28	74.4	94	104	0	38	39
2015	12	8	6	52	22	0.591	-0.157	3.714	0.01	0.007	0	23.6	28.4	74	93	104	0	38	38
2015	12	8	7	2	22	0.62	-0.151	3.714	0.01	0.007	0	23.2	27.1	74	92	102	0	38	39
2015	12	8	7	12	22	0.604	-0.118	3.714	0.01	0.007	0	23.6	27.5	74.4	93	103	0	38	39
2015	12	8	7	22	22	0.617	-0.118	3.714	0.01	0.007	0	23.6	27.1	74	92	102	0	37	39
2015	12	8	7	32	22	0.614	-0.131	3.714	0.01	0.007	0	24.1	27.5	74	93	103	0	37	39
2015	12	8	7	42	22	0.587	-0.121	3.714	0.01	0.007	0	23.6	27.5	74.4	93	102	0	38	38
2015	12	8	7	52	22	0.627	-0.128	3.714	0.01	0.007	0	24.5	27.5	74.4	94	103	0	37	39
2015	12	8	8	2	22	0.614	-0.121	3.714	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	8	8	12	22	0.633	-0.128	3.714	0.013	0.01	0	24.5	28.4	74	95	105	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	8	22	22	0.617	-0.161	3.717	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	8	8	32	22	0.62	-0.141	3.717	0.01	0.007	0	23.6	28.4	74.4	93	104	0	38	38
2015	12	8	8	42	22	0.633	-0.131	3.714	0.01	0.007	0	23.6	28	74.4	93	103	0	38	38
2015	12	8	8	52	22	0.587	-0.148	3.714	0.01	0.007	0	23.6	27.5	74.4	93	103	0	38	39
2015	12	8	9	2	22	0.568	-0.118	3.717	0.01	0.007	0	23.6	28	74.8	93	103	0	38	38
2015	12	8	9	12	22	0.607	-0.118	3.717	0.01	0.007	0	24.1	27.5	74.8	93	103	0	37	39
2015	12	8	9	22	22	0.604	-0.112	3.717	0.01	0.007	0	23.2	27.5	74.8	92	103	0	38	39
2015	12	8	9	32	22	0.594	-0.105	3.717	0.01	0.007	0	24.1	28	74.8	93	103	0	37	38
2015	12	8	9	42	22	0.607	-0.115	3.717	0.01	0.007	0	23.6	27.5	74.8	93	102	0	38	38
2015	12	8	9	52	22	0.614	-0.128	3.717	0.01	0.007	0	24.5	28.8	74.4	94	104	0	37	37
2015	12	8	10	2	22	0.627	-0.154	3.717	0.01	0.007	0	24.5	28	74.4	94	104	0	37	39
2015	12	8	10	12	22	0.594	-0.108	3.717	0.01	0.007	0	24.5	28.8	74.4	95	105	0	38	38
2015	12	8	10	22	22	0.614	-0.148	3.717	0.01	0.007	0	24.1	28	74.4	94	104	0	38	39
2015	12	8	10	32	22	0.584	-0.092	3.717	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	8	10	42	22	0.65	-0.144	3.717	0.013	0.01	0	24.1	27.5	71.4	94	103	0	38	39
2015	12	8	10	52	22	0.61	-0.135	3.72	0.01	0.007	0	24.1	28	75.3	93	103	0	37	38
2015	12	8	11	2	22	0.584	-0.131	3.72	0.01	0.007	0	24.1	28.4	74.8	93	104	0	37	38
2015	12	8	11	12	22	0.64	-0.154	3.72	0.01	0.007	0	24.5	27.5	74.4	94	103	0	37	39
2015	12	8	11	22	22	0.597	-0.135	3.72	0.01	0.007	0	23.6	28	74.4	93	103	0	38	38
2015	12	8	11	32	22	0.633	-0.144	3.72	0.01	0.007	0	24.5	28	59.8	94	103	0	37	38
2015	12	8	11	42	22	0.604	-0.138	3.72	0.01	0.007	0	24.1	28.4	64.9	94	104	0	38	38
2015	12	8	11	52	22	0.597	-0.138	3.717	0.01	0.007	0	24.5	28.4	67.5	95	104	0	38	38
2015	12	8	12	2	22	0.604	-0.118	3.717	0.013	0.01	0	24.9	28.4	74.8	95	105	0	37	39
2015	12	8	12	12	22	0.6	-0.115	3.717	0.01	0.007	0	24.5	28.4	75.3	94	105	0	37	39
2015	12	8	12	22	22	0.604	-0.128	3.717	0.01	0.007	0	24.5	28.4	75.3	95	105	0	38	39
2015	12	8	12	32	22	0.61	-0.141	3.717	0.01	0.007	0	24.1	28	74.4	94	104	0	38	39
2015	12	8	12	42	22	0.614	-0.118	3.72	0.01	0.007	0	25.4	28.4	74.8	96	105	0	37	39
2015	12	8	12	52	22	0.607	-0.105	3.717	0.01	0.007	0	24.5	28.4	74.8	94	104	0	37	38
2015	12	8	13	2	22	0.6	-0.108	3.717	0.01	0.007	0	24.9	28.4	75.7	96	105	0	38	39
2015	12	8	13	12	22	0.623	-0.154	3.717	0.01	0.007	0	25.4	28.4	75.7	96	105	0	37	39
2015	12	8	13	22	22	0.623	-0.151	3.717	0.01	0.007	0	23.6	28.4	75.3	93	104	0	38	38
2015	12	8	13	32	22	0.591	-0.135	3.717	0.01	0.007	0	24.5	28.8	75.3	95	105	0	38	38
2015	12	8	13	42	22	0.597	-0.118	3.72	0.01	0.007	0	24.5	28.8	74.8	95	105	0	38	38
2015	12	8	13	52	22	0.591	-0.098	3.717	0.01	0.007	0	24.5	28.4	75.3	95	104	0	38	38
2015	12	8	14	2	22	0.6	-0.131	3.717	0.01	0.007	0	24.1	27.5	74.8	94	103	0	38	39
2015	12	8	14	12	22	0.62	-0.154	3.717	0.016	0.016	0	24.5	28	75.7	94	104	0	37	39
2015	12	8	14	22	22	0.6	-0.131	3.717	0.01	0.007	0	24.5	28	75.3	95	104	0	38	39
2015	12	8	14	32	22	0.607	-0.144	3.717	0.013	0.01	0	24.5	28.4	75.3	94	104	0	37	38
2015	12	8	14	42	22	0.607	-0.141	3.717	0.01	0.007	0	24.1	27.5	75.3	93	103	0	37	39
2015	12	8	14	52	22	0.627	-0.125	3.717	0.01	0.007	0	23.6	27.5	75.3	93	103	0	38	39
2015	12	8	15	2	22	0.568	-0.118	3.717	0.01	0.007	0	24.5	28	75.3	94	104	0	37	39
2015	12	8	15	12	22	0.63	-0.105	3.717	0.013	0.01	0	24.1	28	75.3	93	103	0	37	38
2015	12	8	15	22	22	0.597	-0.118	3.717	0.01	0.007	0	24.1	28	75.3	93	103	0	37	38
2015	12	8	15	32	22	0.633	-0.128	3.717	0.01	0.007	0	24.1	27.5	74.8	93	102	0	37	38
2015	12	8	15	42	22	0.604	-0.121	3.717	0.01	0.007	0	23.2	27.5	75.3	92	102	0	38	38
2015	12	8	15	52	22	0.594	-0.141	3.717	0.01	0.007	0	24.1	28	75.3	93	103	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	16	2	22	0.607	-0.144	3.717	0.01	0.007	0	24.1	28	74.8	93	103	0	37	38
2015	12	8	16	12	22	0.62	-0.125	3.717	0.01	0.007	0	23.6	27.1	74.8	92	102	0	37	39
2015	12	8	16	22	22	0.633	-0.135	3.717	0.01	0.007	0	24.5	28	74.8	94	103	0	37	38
2015	12	8	16	32	22	0.64	-0.121	3.717	0.01	0.007	0	24.1	27.5	74.8	93	103	0	37	39
2015	12	8	16	42	22	0.63	-0.112	3.717	0.013	0.01	0	24.1	28	74.8	93	103	0	37	38
2015	12	8	16	52	22	0.607	-0.144	3.717	0.013	0.01	0	24.1	27.1	74.8	93	102	0	37	39
2015	12	8	17	2	22	0.627	-0.161	3.717	0.01	0.007	0	24.1	27.5	74.8	93	103	0	37	39
2015	12	8	17	12	22	0.61	-0.108	3.717	0.01	0.007	0	24.5	28.4	74.8	94	104	0	37	38
2015	12	8	17	22	22	0.617	-0.131	3.717	0.01	0.007	0	24.1	28	74.8	93	103	0	37	38
2015	12	8	17	32	22	0.62	-0.138	3.717	0.01	0.007	0	24.1	28	74.8	94	104	0	38	39
2015	12	8	17	42	22	0.61	-0.141	3.717	0.01	0.007	0	24.1	28	74.8	94	104	0	38	39
2015	12	8	17	52	22	0.617	-0.098	3.717	0.01	0.007	0	24.9	28.4	74.4	94	104	0	36	38
2015	12	8	18	2	22	0.623	-0.118	3.717	0.01	0.007	0	24.9	28.8	74.4	95	105	0	37	38
2015	12	8	18	12	22	0.607	-0.118	3.717	0.01	0.007	0	24.9	28.4	74.4	95	105	0	37	39
2015	12	8	18	22	22	0.604	-0.128	3.717	0.01	0.007	0	24.1	28	74.8	93	104	0	37	39
2015	12	8	18	32	22	0.614	-0.105	3.717	0.01	0.007	0	24.1	27.5	74	93	103	0	37	39
2015	12	8	18	42	22	0.6	-0.135	3.717	0.013	0.01	0	24.1	28.4	75.3	94	104	0	38	38
2015	12	8	18	52	22	0.62	-0.161	3.717	0.01	0.007	0	24.1	28	74.4	93	103	0	37	38
2015	12	8	19	2	22	0.584	-0.144	3.717	0.01	0.007	0	24.1	28	74.4	93	103	0	37	38
2015	12	8	19	12	22	0.633	-0.131	3.717	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	8	19	22	22	0.627	-0.141	3.717	0.01	0.007	0	24.9	28.4	74.4	95	104	0	37	38
2015	12	8	19	32	22	0.597	-0.128	3.717	0.01	0.007	0	25.4	29.2	74.4	96	106	0	37	38
2015	12	8	19	42	22	0.62	-0.174	3.717	0.01	0.007	0	25.4	29.2	74.4	96	106	0	37	38
2015	12	8	19	52	22	0.623	-0.121	3.717	0.013	0.01	0	25.4	29.2	74	96	106	0	37	38
2015	12	8	20	2	22	0.633	-0.144	3.717	0.01	0.007	0	24.9	28.8	74.4	96	106	0	38	39
2015	12	8	20	12	22	0.614	-0.128	3.717	0.01	0.007	0	26.2	30.1	74.4	98	108	0	37	38
2015	12	8	20	22	22	0.617	-0.161	3.717	0.01	0.007	0	26.7	30.5	74.4	99	109	0	37	38
2015	12	8	20	32	22	0.62	-0.138	3.717	0.01	0.007	0	26.2	30.1	73.5	98	108	0	37	38
2015	12	8	20	42	22	0.633	-0.138	3.717	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	8	20	52	22	0.584	-0.105	3.717	0.01	0.007	0	24.9	28.8	74.8	96	106	0	38	39
2015	12	8	21	2	22	0.607	-0.131	3.717	0.01	0.007	0	25.8	29.2	74.4	97	107	0	37	39
2015	12	8	21	12	22	0.614	-0.102	3.717	0.01	0.007	0	25.8	30.1	74	98	109	0	38	39
2015	12	8	21	22	22	0.63	-0.112	3.717	0.013	0.01	0	33.5	37.8	74	116	126	0	38	38
2015	12	8	21	32	22	0.594	-0.148	3.717	0.01	0.007	0	26.2	30.5	74.4	99	109	0	38	38
2015	12	8	21	42	22	0.627	-0.141	3.72	0.013	0.01	0	26.2	29.7	73.5	98	108	0	37	39
2015	12	8	21	52	22	0.623	-0.128	3.72	0.01	0.007	0	25.4	29.7	74.4	97	107	0	38	38
2015	12	8	22	2	22	0.627	-0.125	3.72	0.01	0.007	0	25.8	29.2	74.4	97	107	0	37	39
2015	12	8	22	12	22	0.568	-0.115	3.72	0.01	0.007	0	25.8	29.7	74	98	108	0	38	39
2015	12	8	22	22	22	0.604	-0.141	3.72	0.016	0.013	0	24.9	28.4	74	95	106	0	37	40
2015	12	8	22	32	22	0.6	-0.125	3.72	0.013	0.01	0	24.5	28.4	74	95	105	0	38	39
2015	12	8	22	42	22	0.64	-0.121	3.724	0.01	0.007	0	24.9	28.8	73.5	95	105	0	37	38
2015	12	8	22	52	22	0.617	-0.144	3.724	0.013	0.01	0	24.9	28.4	74	95	105	0	37	39
2015	12	8	23	2	22	0.627	-0.144	3.724	0.01	0.007	0	24.1	28.8	73.5	94	105	0	38	38
2015	12	8	23	12	22	0.607	-0.144	3.727	0.01	0.007	0	24.1	28	73.5	94	104	0	38	39
2015	12	8	23	22	22	0.591	-0.131	3.727	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	8	23	32	22	0.614	-0.131	3.727	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	23	42	22	0.623	-0.157	3.727	0.01	0.007	0	24.9	28.4	74	95	105	0	37	39
2015	12	8	23	52	22	0.62	-0.105	3.727	0.013	0.01	0	24.5	28	74	94	104	0	37	39
2015	12	9	0	2	22	0.63	-0.154	3.73	0.013	0.01	0	24.9	28.4	73.5	94	104	0	36	38
2015	12	9	0	12	22	0.614	-0.118	3.73	0.01	0.007	0	23.6	28	74.4	94	104	0	39	39
2015	12	9	0	22	22	0.604	-0.138	3.73	0.01	0.007	0	24.5	28	74	94	104	0	37	39
2015	12	9	0	32	22	0.63	-0.131	3.73	0.01	0.007	0	24.9	28.8	74.4	95	105	0	37	38
2015	12	9	0	42	22	0.587	-0.138	3.73	0.01	0.007	0	24.9	28.4	74	95	104	0	37	38
2015	12	9	0	52	22	0.584	-0.115	3.73	0.01	0.007	0	24.1	28.4	74.4	94	104	0	38	38
2015	12	9	1	2	22	0.617	-0.131	3.73	0.01	0.007	0	24.1	28.8	74.4	94	105	0	38	38
2015	12	9	1	12	22	0.584	-0.157	3.73	0.01	0.007	0	24.9	28.4	74.8	95	105	0	37	39
2015	12	9	1	22	22	0.604	-0.138	3.734	0.01	0.007	0	25.4	28.8	74.8	96	105	0	37	38
2015	12	9	1	32	22	0.604	-0.131	3.734	0.01	0.007	0	24.1	28.4	75.3	94	104	0	38	38
2015	12	9	1	42	22	0.623	-0.148	3.734	0.01	0.007	0	23.6	28	74.8	93	104	0	38	39
2015	12	9	1	52	22	0.6	-0.135	3.734	0.013	0.01	0	24.9	28.8	74.8	94	105	0	36	38
2015	12	9	2	2	22	0.604	-0.118	3.734	0.013	0.01	0	24.9	28.8	74.8	95	105	0	37	38
2015	12	9	2	12	22	0.571	-0.108	3.734	0.01	0.007	0	24.5	28.8	75.3	94	105	0	37	38
2015	12	9	2	22	22	0.614	-0.171	3.734	0.01	0.007	0	24.5	28	74.8	94	104	0	37	39
2015	12	9	2	32	22	0.63	-0.121	3.734	0.01	0.007	0	24.5	28.4	74.8	95	105	0	38	39
2015	12	9	2	42	22	0.607	-0.131	3.734	0.013	0.01	0	24.5	28	75.7	94	104	0	37	39
2015	12	9	2	52	22	0.627	-0.151	3.734	0.01	0.007	0	24.1	28	75.7	94	104	0	38	39
2015	12	9	3	2	22	0.587	-0.131	3.734	0.01	0.007	0	24.5	28.4	75.7	94	104	0	37	38
2015	12	9	3	12	22	0.61	-0.118	3.734	0.01	0.007	0	23.6	28	76.1	93	104	0	38	39
2015	12	9	3	22	22	0.633	-0.131	3.734	0.01	0.007	0	24.9	28.4	76.5	96	105	0	38	39
2015	12	9	3	32	22	0.633	-0.128	3.734	0.01	0.007	0	24.1	28.4	76.5	94	104	0	38	38
2015	12	9	3	42	22	0.62	-0.135	3.734	0.013	0.01	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	9	3	52	22	0.623	-0.105	3.734	0.013	0.01	0	24.9	29.2	76.5	96	106	0	38	38
2015	12	9	4	2	22	0.62	-0.121	3.734	0.01	0.007	0	24.1	28.4	76.1	94	104	0	38	38
2015	12	9	4	12	22	0.627	-0.125	3.737	0.01	0.007	0	24.5	28	76.5	94	104	0	37	39
2015	12	9	4	22	22	0.656	-0.131	3.737	0.01	0.007	0	24.1	28	76.5	93	103	0	37	38
2015	12	9	4	32	22	0.604	-0.118	3.737	0.01	0.007	0	24.5	28.4	76.5	94	104	0	37	38
2015	12	9	4	42	22	0.617	-0.131	3.737	0.01	0.007	0	24.5	27.5	77	94	103	0	37	39
2015	12	9	4	52	22	0.581	-0.105	3.737	0.01	0.007	0	24.9	28.4	77	96	105	0	38	39
2015	12	9	5	2	22	0.594	-0.135	3.737	0.01	0.007	0	24.1	28	77.4	94	103	0	38	38
2015	12	9	5	12	22	0.617	-0.098	3.737	0.01	0.007	0	24.9	28	76.5	95	104	0	37	39
2015	12	9	5	22	22	0.617	-0.125	3.737	0.013	0.01	0	32.3	36.1	77.4	112	123	0	37	39
2015	12	9	5	32	22	0.646	-0.144	3.737	0.016	0.013	0	27.5	30.5	77.4	101	110	0	37	39
2015	12	9	5	42	22	0.61	-0.141	3.737	0.01	0.007	0	26.2	29.7	77.8	98	107	0	37	38
2015	12	9	5	52	22	0.627	-0.151	3.737	0.013	0.01	0	25.8	29.2	77.8	98	107	0	38	39
2015	12	9	6	2	22	0.614	-0.148	3.737	0.016	0.013	0	26.7	30.1	77.8	99	108	0	37	38
2015	12	9	6	12	22	0.62	-0.154	3.737	0.013	0.01	0	25.4	28.4	77.4	96	105	0	37	39
2015	12	9	6	22	22	0.607	-0.112	3.737	0.01	0.007	0	24.5	28	77.4	95	104	0	38	39
2015	12	9	6	32	22	0.61	-0.125	3.74	0.01	0.007	0	24.9	28.4	78.3	95	104	0	37	38
2015	12	9	6	42	22	0.646	-0.177	3.74	0.01	0.007	0	35.7	39.1	77.4	120	129	0	37	38
2015	12	9	6	52	22	0.607	-0.144	3.74	0.01	0.007	0	28	31.4	78.3	102	111	0	37	38
2015	12	9	7	2	22	0.581	-0.161	3.74	0.013	0.01	0	24.9	28.4	77.8	95	105	0	37	39
2015	12	9	7	12	22	0.597	-0.148	3.74	0.01	0.007	0	24.1	28	78.3	94	104	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	7	22	22	0.597	-0.118	3.74	0.01	0.007	0	24.9	28.4	79.1	95	105	0	37	39
2015	12	9	7	32	22	0.62	-0.144	3.74	0.01	0.007	0	24.1	28	78.3	94	104	0	38	39
2015	12	9	7	42	22	0.623	-0.138	3.74	0.01	0.007	0	23.6	28	78.7	93	103	0	38	38
2015	12	9	7	52	22	0.623	-0.154	3.74	0.016	0.013	0	24.5	27.5	77.8	94	103	0	37	39
2015	12	9	8	2	22	0.633	-0.115	3.74	0.01	0.007	0	24.1	28	78.7	94	103	0	38	38
2015	12	9	8	12	22	0.604	-0.131	3.74	0.01	0.007	0	24.1	28	77.8	94	104	0	38	39
2015	12	9	8	22	22	0.643	-0.141	3.74	0.01	0.007	0	24.1	28.4	78.3	94	104	0	38	38
2015	12	9	8	32	22	0.633	-0.144	3.743	0.01	0.007	0	24.1	28.4	78.3	94	104	0	38	38
2015	12	9	8	42	22	0.614	-0.138	3.743	0.013	0.01	0	24.1	28.4	78.3	94	104	0	38	38
2015	12	9	8	52	22	0.597	-0.118	3.743	0.01	0.007	0	24.5	28	78.3	94	104	0	37	39
2015	12	9	9	2	22	0.591	-0.115	3.743	0.01	0.007	0	24.1	28	78.3	94	103	0	38	38
2015	12	9	9	12	22	0.614	-0.118	3.743	0.01	0.007	0	24.1	27.5	78.3	93	102	0	37	38
2015	12	9	9	22	22	0.62	-0.131	3.743	0.01	0.007	0	24.5	27.5	78.3	94	103	0	37	39
2015	12	9	9	32	22	0.623	-0.125	3.747	0.01	0.007	0	24.5	28.4	78.3	94	104	0	37	38
2015	12	9	9	42	22	0.62	-0.164	3.747	0.01	0.007	0	24.1	27.5	78.3	93	103	0	37	39
2015	12	9	9	52	22	0.614	-0.148	3.747	0.01	0.007	0	24.9	28.4	78.3	95	104	0	37	38
2015	12	9	10	2	22	0.604	-0.128	3.747	0.01	0.007	0	24.9	28.4	78.3	95	104	0	37	38
2015	12	9	10	12	22	0.617	-0.125	3.747	0.01	0.007	0	24.5	28.4	77.8	95	105	0	38	39
2015	12	9	10	22	22	0.62	-0.154	3.747	0.01	0.007	0	24.5	28.8	77.8	95	105	0	38	38
2015	12	9	10	32	22	0.623	-0.151	3.75	0.01	0.007	0	24.1	28	77.8	93	104	0	37	39
2015	12	9	10	42	22	0.61	-0.138	3.747	0.01	0.007	0	24.9	28.4	77.8	95	105	0	37	39
2015	12	9	10	52	22	0.61	-0.138	3.75	0.01	0.007	0	24.9	28	78.3	95	104	0	37	39
2015	12	9	11	2	22	0.627	-0.138	3.75	0.016	0.013	0	25.4	29.7	77	97	107	0	38	38
2015	12	9	11	12	22	0.597	-0.125	3.75	0.01	0.007	0	24.9	28.4	77.4	95	105	0	37	39
2015	12	9	11	22	22	0.614	-0.131	3.75	0.013	0.01	0	24.9	28.8	77.8	96	105	0	38	38
2015	12	9	11	32	22	0.623	-0.144	3.75	0.01	0.007	0	25.8	28.8	77.8	96	105	0	36	38
2015	12	9	11	42	22	0.607	-0.108	3.753	0.01	0.007	0	25.8	29.7	77.8	97	106	0	37	37
2015	12	9	11	52	22	0.633	-0.151	3.75	0.01	0.007	0	25.4	28.8	76.1	96	106	0	37	39
2015	12	9	12	2	22	0.604	-0.079	3.753	0.01	0.007	0	25.8	29.7	74	97	107	0	37	38
2015	12	9	12	12	22	0.62	-0.144	3.75	0.01	0.007	0	25.4	28.8	77.8	96	105	0	37	38
2015	12	9	12	22	22	0.61	-0.138	3.75	0.013	0.01	0	26.2	30.1	77.4	99	108	0	38	38
2015	12	9	12	32	22	0.63	-0.154	3.75	0.01	0.007	0	24.9	28.4	77.8	96	105	0	38	39
2015	12	9	12	42	22	0.64	-0.131	3.753	0.013	0.01	0	25.4	28.8	77.8	96	106	0	37	39
2015	12	9	12	52	22	0.636	-0.144	3.753	0.01	0.007	0	24.9	28.8	75.7	95	105	0	37	38
2015	12	9	13	2	22	0.61	-0.161	3.753	0.01	0.007	0	25.4	29.2	77.8	96	106	0	37	38
2015	12	9	13	12	22	0.597	-0.092	3.753	0.01	0.007	0	25.8	29.7	78.7	97	107	0	37	38
2015	12	9	13	22	22	0.604	-0.144	3.753	0.01	0.007	0	25.8	29.7	77.8	97	107	0	37	38
2015	12	9	13	32	22	0.617	-0.135	3.753	0.01	0.007	0	26.2	30.1	78.3	98	108	0	37	38
2015	12	9	13	42	22	0.617	-0.154	3.753	0.01	0.007	0	24.9	28.4	77.4	95	105	0	37	39
2015	12	9	13	52	22	0.62	-0.154	3.753	0.013	0.01	0	25.8	29.7	77.4	97	107	0	37	38
2015	12	9	14	2	22	0.623	-0.131	3.753	0.013	0.01	0	25.4	28.4	77.8	96	105	0	37	39
2015	12	9	14	12	22	0.62	-0.118	3.753	0.01	0.007	0	25.4	29.2	77.8	96	106	0	37	38
2015	12	9	14	22	22	0.646	-0.144	3.753	0.01	0.007	0	24.9	28.8	75.3	95	105	0	37	38
2015	12	9	14	32	22	0.614	-0.154	3.753	0.013	0.01	0	25.4	29.2	76.1	97	107	0	38	39
2015	12	9	14	42	22	0.64	-0.108	3.75	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	9	14	52	22	0.627	-0.157	3.75	0.013	0.01	0	26.2	29.7	67.9	98	107	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	15	2	22	0.604	-0.131	3.753	0.01	0.007	0	25.8	29.2	57.6	97	107	0	37	39
2015	12	9	15	12	22	0.617	-0.144	3.75	0.01	0.007	0	24.9	29.2	67.5	96	106	0	38	38
2015	12	9	15	22	22	0.65	-0.161	3.75	0.01	0.007	0	25.8	29.2	76.1	97	107	0	37	39
2015	12	9	15	32	22	0.6	-0.144	3.75	0.01	0.007	0	25.4	28.4	63.6	96	105	0	37	39
2015	12	9	15	42	22	0.63	-0.148	3.75	0.01	0.007	0	25.4	29.2	63.2	96	105	0	37	37
2015	12	9	15	52	22	0.633	-0.151	3.75	0.01	0.007	0	25.4	28.8	74	96	106	0	37	39
2015	12	9	16	2	22	0.627	-0.135	3.75	0.01	0.007	0	25.8	29.7	73.1	97	108	0	37	39
2015	12	9	16	12	22	0.623	-0.157	3.75	0.01	0.007	0	24.9	28.8	61.5	95	105	0	37	38
2015	12	9	16	22	22	0.614	-0.141	3.75	0.01	0.007	0	24.9	28.8	77.4	95	106	0	37	39
2015	12	9	16	32	22	0.62	-0.121	3.75	0.01	0.007	0	25.8	29.2	77.8	97	107	0	37	39
2015	12	9	16	42	22	0.636	-0.164	3.75	0.01	0.007	0	24.1	28.4	77.4	94	105	0	38	39
2015	12	9	16	52	22	0.633	-0.125	3.75	0.01	0.007	0	24.9	28.4	77	96	105	0	38	39
2015	12	9	17	2	22	0.62	-0.131	3.75	0.01	0.007	0	24.5	28.4	77.4	94	104	0	37	38
2015	12	9	17	12	22	0.6	-0.125	3.75	0.01	0.007	0	25.8	29.7	77.4	97	107	0	37	38
2015	12	9	17	22	22	0.659	-0.154	3.75	0.01	0.007	0	24.9	28.8	77	95	105	0	37	38
2015	12	9	17	32	22	0.584	-0.131	3.75	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	9	17	42	22	0.61	-0.138	3.75	0.013	0.01	0	26.2	30.1	75.3	98	108	0	37	38
2015	12	9	17	52	22	0.663	-0.141	3.75	0.01	0.007	0	24.9	29.2	77.4	96	106	0	38	38
2015	12	9	18	2	22	0.64	-0.141	3.75	0.01	0.007	0	25.4	29.2	77.4	96	107	0	37	39
2015	12	9	18	12	22	0.646	-0.131	3.75	0.01	0.007	0	25.4	29.7	77	97	107	0	38	38
2015	12	9	18	22	22	0.614	-0.118	3.753	0.01	0.007	0	26.2	30.1	77.4	98	108	0	37	38
2015	12	9	18	32	22	0.623	-0.141	3.753	0.01	0.007	0	25.4	28.8	77	96	106	0	37	39
2015	12	9	18	42	22	0.587	-0.118	3.753	0.01	0.007	0	24.9	29.2	76.5	96	106	0	38	38
2015	12	9	18	52	22	0.64	-0.148	3.753	0.01	0.007	0	25.8	29.2	77	97	106	0	37	38
2015	12	9	19	2	22	0.623	-0.128	3.753	0.01	0.007	0	25.4	29.7	77	97	107	0	38	38
2015	12	9	19	12	22	0.587	-0.118	3.753	0.01	0.007	0	25.4	29.2	77	96	106	0	37	38
2015	12	9	19	22	22	0.614	-0.131	3.753	0.01	0.007	0	25.4	29.2	67.5	97	107	0	38	39
2015	12	9	19	32	22	0.633	-0.118	3.753	0.01	0.007	0	25.4	29.7	76.5	97	107	0	38	38
2015	12	9	19	42	22	0.61	-0.154	3.753	0.01	0.007	0	26.2	29.2	76.5	98	107	0	37	39
2015	12	9	19	52	22	0.627	-0.115	3.753	0.01	0.007	0	26.2	29.7	76.1	98	108	0	37	39
2015	12	9	20	2	22	0.574	-0.157	3.753	0.01	0.007	0	25.8	30.1	76.1	98	108	0	38	38
2015	12	9	20	12	22	0.623	-0.125	3.753	0.01	0.007	0	26.7	31	77	100	111	0	38	39
2015	12	9	20	22	22	0.61	-0.131	3.753	0.01	0.007	0	26.7	31	75.7	100	110	0	38	38
2015	12	9	20	32	22	0.623	-0.128	3.757	0.01	0.007	0	27.5	31.8	76.5	102	113	0	38	39
2015	12	9	20	42	22	0.63	-0.112	3.757	0.01	0.007	0	26.2	30.5	76.5	99	109	0	38	38
2015	12	9	20	52	22	0.617	-0.141	3.757	0.01	0.007	0	26.2	30.1	76.5	98	108	0	37	38
2015	12	9	21	2	22	0.623	-0.138	3.753	0.01	0.007	0	25.8	30.1	75.7	98	108	0	38	38
2015	12	9	21	12	22	0.604	-0.148	3.757	0.01	0.007	0	25.8	30.1	76.5	98	108	0	38	38
2015	12	9	21	22	22	0.623	-0.138	3.757	0.01	0.007	0	27.5	31	76.1	101	111	0	37	39
2015	12	9	21	32	22	0.636	-0.128	3.757	0.01	0.007	0	26.2	30.1	76.1	98	108	0	37	38
2015	12	9	21	42	22	0.61	-0.121	3.757	0.01	0.007	0	26.2	31	75.7	99	110	0	38	38
2015	12	9	21	52	22	0.64	-0.131	3.757	0.013	0.01	0	26.7	30.5	76.1	99	109	0	37	38
2015	12	9	22	2	22	0.584	-0.154	3.757	0.01	0.007	0	25.8	29.7	65.8	98	108	0	38	39
2015	12	9	22	12	22	0.597	-0.141	3.757	0.01	0.007	0	26.2	30.5	76.1	99	109	0	38	38
2015	12	9	22	22	22	0.64	-0.138	3.757	0.01	0.007	0	25.4	29.7	75.7	97	107	0	38	38
2015	12	9	22	32	22	0.64	-0.105	3.757	0.01	0.007	0	28	32.7	75.7	103	113	0	38	37

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	22	42	22	0.623	-0.144	3.757	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	9	22	52	22	0.623	-0.151	3.76	0.01	0.007	0	25.8	30.1	75.3	98	108	0	38	38
2015	12	9	23	2	22	0.614	-0.115	3.76	0.01	0.007	0	25.4	29.7	75.7	97	107	0	38	38
2015	12	9	23	12	22	0.587	-0.095	3.76	0.01	0.007	0	25.8	29.2	75.3	97	107	0	37	39
2015	12	9	23	22	22	0.617	-0.131	3.76	0.01	0.007	0	25.8	29.2	75.3	97	107	0	37	39
2015	12	9	23	32	22	0.604	-0.131	3.76	0.01	0.007	0	25.4	29.7	74.8	97	107	0	38	38
2015	12	9	23	42	22	0.633	-0.141	3.76	0.01	0.007	0	25.4	29.7	73.5	97	107	0	38	38
2015	12	9	23	52	22	0.607	-0.141	3.76	0.013	0.01	0	25.4	29.7	74.4	97	107	0	38	38
2015	12	10	0	2	22	0.627	-0.144	3.76	0.01	0.007	0	25.4	29.2	74.4	96	106	0	37	38
2015	12	10	0	12	22	0.656	-0.154	3.76	0.01	0.007	0	25.8	29.7	74.8	97	107	0	37	38
2015	12	10	0	22	22	0.627	-0.118	3.76	0.01	0.007	0	25.4	29.7	74.8	97	107	0	38	38
2015	12	10	0	32	22	0.591	-0.118	3.76	0.01	0.007	0	25.4	29.2	75.3	97	107	0	38	39
2015	12	10	0	42	22	0.6	-0.148	3.76	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	10	0	52	22	0.61	-0.144	3.763	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	10	1	2	22	0.627	-0.131	3.763	0.013	0.01	0	25.8	30.1	74	97	108	0	37	38
2015	12	10	1	12	22	0.614	-0.135	3.763	0.01	0.007	0	26.2	30.1	73.1	98	108	0	37	38
2015	12	10	1	22	22	0.63	-0.138	3.763	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	10	1	32	22	0.6	-0.125	3.763	0.01	0.007	0	25.8	29.7	73.5	98	108	0	38	39
2015	12	10	1	42	22	0.62	-0.148	3.766	0.01	0.007	0	26.2	30.5	74	99	109	0	38	38
2015	12	10	1	52	22	0.63	-0.131	3.77	0.013	0.01	0	26.2	30.5	73.5	98	109	0	37	38
2015	12	10	2	2	22	0.62	-0.138	3.77	0.01	0.007	0	26.2	30.1	73.5	98	108	0	37	38
2015	12	10	2	12	22	0.62	-0.144	3.77	0.01	0.007	0	25.8	30.1	72.7	98	108	0	38	38
2015	12	10	2	22	22	0.62	-0.148	3.773	0.01	0.007	0	25.8	30.1	73.5	98	108	0	38	38
2015	12	10	2	32	22	0.614	-0.115	3.773	0.01	0.007	0	26.2	30.1	73.5	98	108	0	37	38
2015	12	10	2	42	22	0.62	-0.128	3.773	0.01	0.007	0	26.2	30.1	71	99	108	0	38	38
2015	12	10	2	52	22	0.604	-0.141	3.773	0.01	0.007	0	25.4	29.7	74.4	97	108	0	38	39
2015	12	10	3	2	22	0.597	-0.131	3.773	0.01	0.007	0	26.2	30.5	72.2	99	109	0	38	38
2015	12	10	3	12	22	0.627	-0.115	3.776	0.01	0.007	0	25.8	30.5	74.4	98	109	0	38	38
2015	12	10	3	22	22	0.623	-0.121	3.773	0.013	0.01	0	26.7	30.1	74	99	109	0	37	39
2015	12	10	3	32	22	0.65	-0.115	3.776	0.01	0.007	0	26.2	30.1	74.4	98	108	0	37	38
2015	12	10	3	42	22	0.597	-0.151	3.776	0.01	0.007	0	26.2	29.2	75.3	98	107	0	37	39
2015	12	10	3	52	22	0.643	-0.115	3.776	0.01	0.007	0	25.8	30.1	74.4	98	108	0	38	38
2015	12	10	4	2	22	0.63	-0.118	3.776	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	10	4	12	22	0.61	-0.092	3.776	0.01	0.007	0	25.8	30.1	75.7	97	108	0	37	38
2015	12	10	4	22	22	0.627	-0.105	3.776	0.01	0.007	0	26.2	30.5	76.1	99	109	0	38	38
2015	12	10	4	32	22	0.614	-0.171	3.776	0.01	0.007	0	26.7	30.5	76.1	99	109	0	37	38
2015	12	10	4	42	22	0.646	-0.148	3.776	0.013	0.01	0	25.8	29.7	76.1	98	108	0	38	39
2015	12	10	4	52	22	0.63	-0.157	3.776	0.01	0.007	0	24.9	29.2	76.5	96	106	0	38	38
2015	12	10	5	2	22	0.614	-0.138	3.78	0.01	0.007	0	26.2	30.5	77	98	109	0	37	38
2015	12	10	5	12	22	0.614	-0.128	3.78	0.01	0.007	0	26.7	30.1	76.5	99	108	0	37	38
2015	12	10	5	22	22	0.623	-0.131	3.78	0.013	0.01	0	25.8	29.7	76.5	97	107	0	37	38
2015	12	10	5	32	22	0.6	-0.131	3.78	0.013	0.01	0	25.4	29.7	76.5	97	107	0	38	38
2015	12	10	5	42	22	0.63	-0.095	3.78	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	10	5	52	22	0.633	-0.161	3.78	0.01	0.007	0	31	34.8	77.4	109	119	0	37	38
2015	12	10	6	2	22	0.617	-0.144	3.78	0.01	0.007	0	26.7	31	77	100	110	0	38	38
2015	12	10	6	12	22	0.614	-0.144	3.78	0.01	0.007	0	26.7	30.5	63.6	99	109	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	6	22	22	0.633	-0.108	3.78	0.01	0.007	0	28	32.7	77.8	103	114	0	38	38
2015	12	10	6	32	22	0.61	-0.102	3.783	0.013	0.01	0	27.1	31.4	77.4	100	111	0	37	38
2015	12	10	6	42	22	0.604	-0.128	3.783	0.01	0.007	0	26.2	30.1	77.8	98	108	0	37	38
2015	12	10	6	52	22	0.591	-0.135	3.78	0.01	0.007	0	26.2	29.7	77.4	98	108	0	37	39
2015	12	10	7	2	22	0.617	-0.157	3.783	0.013	0.01	0	32.3	37	78.3	113	124	0	38	38
2015	12	10	7	12	22	0.63	-0.138	3.783	0.01	0.007	0	32.3	36.5	64.5	112	123	0	37	38
2015	12	10	7	22	22	0.636	-0.144	3.783	0.01	0.007	0	28.4	32.7	78.3	104	115	0	38	39
2015	12	10	7	32	22	0.636	-0.144	3.783	0.01	0.007	0	26.2	30.1	77	99	109	0	38	39
2015	12	10	7	42	22	0.636	-0.112	3.783	0.01	0.007	0	26.7	30.5	77.8	99	109	0	37	38
2015	12	10	7	52	22	0.65	-0.151	3.783	0.01	0.007	0	26.2	30.5	76.1	99	109	0	38	38
2015	12	10	8	2	22	0.62	-0.128	3.783	0.01	0.007	0	25.4	29.2	74.4	97	107	0	38	39
2015	12	10	8	12	22	0.594	-0.118	3.783	0.01	0.007	0	25.8	30.1	77.8	97	107	0	37	37
2015	12	10	8	22	22	0.62	-0.118	3.786	0.01	0.007	0	25.8	29.2	66.7	98	107	0	38	39
2015	12	10	8	32	22	0.587	-0.154	3.786	0.013	0.01	0	24.9	29.7	77.4	96	107	0	38	38
2015	12	10	8	42	22	0.627	-0.144	3.786	0.01	0.007	0	25.4	29.2	66.7	97	106	0	38	38
2015	12	10	8	52	22	0.64	-0.115	3.786	0.01	0.007	0	25.8	29.7	72.2	98	108	0	38	39
2015	12	10	9	2	22	0.591	-0.118	3.786	0.01	0.007	0	26.2	29.7	74.8	98	108	0	37	39
2015	12	10	9	12	22	0.61	-0.128	3.786	0.013	0.01	0	26.2	30.1	77.8	99	109	0	38	39
2015	12	10	9	22	22	0.627	-0.135	3.786	0.01	0.007	0	25.8	29.7	77.8	97	107	0	37	38
2015	12	10	9	32	22	0.617	-0.135	3.786	0.01	0.007	0	25.8	29.7	77.8	97	107	0	37	38
2015	12	10	9	42	22	0.61	-0.112	3.789	0.016	0.013	0	25.4	29.2	77.8	97	107	0	38	39
2015	12	10	9	52	22	0.63	-0.118	3.789	0.01	0.007	0	25.8	30.1	74.8	98	108	0	38	38
2015	12	10	10	2	22	0.623	-0.118	3.789	0.016	0.013	0	25.4	29.2	77.4	96	106	0	37	38
2015	12	10	10	12	22	0.6	-0.105	3.789	0.013	0.01	0	26.2	29.7	72.7	99	108	0	38	39
2015	12	10	10	22	22	0.6	-0.131	3.789	0.016	0.013	0	26.2	30.1	65.8	98	108	0	37	38
2015	12	10	10	32	22	0.64	-0.144	3.789	0.01	0.007	0	25.4	29.2	77.8	96	106	0	37	38
2015	12	10	10	42	22	0.61	-0.138	3.789	0.01	0.007	0	26.2	30.1	77.4	98	108	0	37	38
2015	12	10	10	52	22	0.607	-0.157	3.789	0.01	0.007	0	25.8	30.1	66.2	98	108	0	38	38
2015	12	10	11	2	22	0.581	-0.135	3.789	0.013	0.01	0	26.7	30.5	52.5	99	109	0	37	38
2015	12	10	11	12	22	0.597	-0.118	3.789	0.01	0.007	0	28.4	31.8	52.9	104	113	0	38	39
2015	12	10	11	22	22	0.62	-0.144	3.789	0.01	0.007	0	27.1	31	57.2	101	110	0	38	38
2015	12	10	11	32	22	0.614	-0.144	3.793	0.01	0.007	0	26.7	30.1	54.2	99	109	0	37	39
2015	12	10	11	42	22	0.591	-0.144	3.793	0.01	0.007	0	27.1	30.5	56.8	100	109	0	37	38
2015	12	10	11	52	22	0.646	-0.164	3.789	0.013	0.01	0	27.1	31	67.1	100	110	0	37	38
2015	12	10	12	2	22	0.65	-0.161	3.789	0.01	0.007	0	26.2	30.1	72.7	98	108	0	37	38
2015	12	10	12	12	22	0.617	-0.118	3.793	0.01	0.007	0	27.5	31	77	101	111	0	37	39
2015	12	10	12	22	22	0.604	-0.128	3.793	0.01	0.007	0	27.1	31	72.7	100	110	0	37	38
2015	12	10	12	32	22	0.62	-0.102	3.793	0.01	0.007	0	27.1	31.4	76.1	101	111	0	38	38
2015	12	10	12	42	22	0.643	-0.151	3.793	0.01	0.007	0	25.8	30.1	74	98	108	0	38	38
2015	12	10	12	52	22	0.604	-0.148	3.793	0.01	0.007	0	26.7	31.4	77.4	100	111	0	38	38
2015	12	10	13	2	22	0.64	-0.118	3.793	0.016	0.013	0	27.5	31	63.6	101	110	0	37	38
2015	12	10	13	12	22	0.65	-0.125	3.793	0.01	0.007	0	28	31.8	76.5	102	112	0	37	38
2015	12	10	13	22	22	0.61	-0.144	3.793	0.013	0.01	0	27.1	31	75.3	100	110	0	37	38
2015	12	10	13	32	22	0.614	-0.135	3.796	0.01	0.007	0	28	31.4	77.4	102	112	0	37	39
2015	12	10	13	42	22	0.64	-0.125	3.793	0.013	0.01	0	26.2	30.5	77	98	109	0	37	38
2015	12	10	13	52	22	0.659	-0.128	3.796	0.01	0.007	0	28	32.3	77	103	114	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	14	2	22	0.604	-0.144	3.796	0.013	0.01	0	27.1	31.4	74.4	101	111	0	38	38
2015	12	10	14	12	22	0.623	-0.144	3.796	0.01	0.007	0	27.1	30.5	76.5	100	110	0	37	39
2015	12	10	14	22	22	0.623	-0.131	3.796	0.013	0.01	0	29.2	33.1	73.5	106	116	0	38	39
2015	12	10	14	32	22	0.63	-0.131	3.799	0.01	0.007	0	28	31.4	59.3	102	111	0	37	38
2015	12	10	14	42	22	0.636	-0.112	3.796	0.01	0.007	0	27.5	31	76.1	101	111	0	37	39
2015	12	10	14	52	22	0.63	-0.112	3.796	0.01	0.007	0	28	31.4	76.1	102	111	0	37	38
2015	12	10	15	2	22	0.617	-0.148	3.796	0.01	0.007	0	26.7	30.5	73.5	100	110	0	38	39
2015	12	10	15	12	22	0.633	-0.089	3.799	0.01	0.007	0	27.5	31.4	53.3	102	111	0	38	38
2015	12	10	15	22	22	0.61	-0.112	3.802	0.01	0.007	0	28.4	31.8	53.8	103	112	0	37	38
2015	12	10	15	32	22	0.656	-0.151	3.799	0.01	0.007	0	27.5	31.4	74.8	101	111	0	37	38
2015	12	10	15	42	22	0.627	-0.128	3.799	0.01	0.007	0	26.7	30.5	67.1	99	109	0	37	38
2015	12	10	15	52	22	0.646	-0.138	3.799	0.01	0.007	0	27.1	31	76.1	100	110	0	37	38
2015	12	10	16	2	22	0.591	-0.118	3.799	0.01	0.007	0	26.2	31	74.8	99	110	0	38	38
2015	12	10	16	12	22	0.63	-0.135	3.799	0.01	0.007	0	26.7	31	75.7	100	110	0	38	38
2015	12	10	16	22	22	0.63	-0.148	3.799	0.01	0.007	0	26.7	30.5	63.2	100	109	0	38	38
2015	12	10	16	32	22	0.643	-0.112	3.799	0.01	0.007	0	27.1	31	75.7	100	110	0	37	38
2015	12	10	16	42	22	0.61	-0.144	3.802	0.01	0.007	0	27.5	31.4	59.3	101	111	0	37	38
2015	12	10	16	52	22	0.591	-0.118	3.799	0.016	0.013	0	26.7	30.5	67.5	99	109	0	37	38
2015	12	10	17	2	22	0.633	-0.151	3.802	0.01	0.007	0	25.8	30.1	75.3	98	108	0	38	38
2015	12	10	17	12	22	0.617	-0.141	3.802	0.01	0.007	0	27.1	31.4	74.4	100	111	0	37	38
2015	12	10	17	22	22	0.643	-0.135	3.802	0.01	0.007	0	27.1	30.5	74.4	100	110	0	37	39
2015	12	10	17	32	22	0.63	-0.121	3.802	0.01	0.007	0	26.7	30.1	74.8	99	109	0	37	39
2015	12	10	17	42	22	0.604	-0.102	3.802	0.013	0.01	0	26.7	31.4	71.8	100	111	0	38	38
2015	12	10	17	52	22	0.617	-0.125	3.806	0.01	0.007	0	28	31.8	67.1	102	111	0	37	37
2015	12	10	18	2	22	0.63	-0.138	3.809	0.01	0.007	0	27.5	31	58.5	101	110	0	37	38
2015	12	10	18	12	22	0.591	-0.118	3.806	0.013	0.01	0	27.1	30.5	68.8	100	109	0	37	38
2015	12	10	18	22	22	0.659	-0.135	3.806	0.01	0.007	0	26.7	30.5	73.5	100	109	0	38	38
2015	12	10	18	32	22	0.63	-0.098	3.809	0.01	0.007	0	28	31.8	60.6	101	111	0	36	37
2015	12	10	18	42	22	0.6	-0.112	3.809	0.016	0.013	0	27.5	31.4	74	101	111	0	37	38
2015	12	10	18	52	22	0.62	-0.105	3.809	0.013	0.01	0	27.5	31	67.5	101	111	0	37	39
2015	12	10	19	2	22	0.64	-0.151	3.812	0.01	0.007	0	27.5	31	74	101	111	0	37	39
2015	12	10	19	12	22	0.607	-0.138	3.816	0.01	0.007	0	27.1	31	74	100	110	0	37	38
2015	12	10	19	22	22	0.627	-0.148	3.816	0.013	0.01	0	26.7	31	73.5	100	110	0	38	38
2015	12	10	19	32	22	0.623	-0.135	3.819	0.013	0.01	0	26.7	31	74	100	110	0	38	38
2015	12	10	19	42	22	0.607	-0.108	3.819	0.016	0.016	0	27.1	31.4	70.5	100	111	0	37	38
2015	12	10	19	52	22	0.617	-0.108	3.816	0.01	0.007	0	27.1	30.5	51.6	100	110	0	37	39
2015	12	10	20	2	22	0.607	-0.115	3.819	0.01	0.007	0	29.7	32.7	56.8	106	115	0	37	39
2015	12	10	20	12	22	0.581	-0.082	3.819	0.016	0.013	0	28.4	32.7	75.3	103	114	0	37	38
2015	12	10	20	22	22	0.64	-0.135	3.822	0.01	0.007	0	27.1	31	75.3	100	110	0	37	38
2015	12	10	20	32	22	0.643	-0.131	3.822	0.01	0.007	0	26.7	31	75.7	100	111	0	38	39
2015	12	10	20	42	22	0.62	-0.095	3.822	0.016	0.013	0	28	31.4	61.5	102	112	0	37	39
2015	12	10	20	52	22	0.62	-0.098	3.822	0.01	0.007	0	28	31.8	76.1	102	112	0	37	38
2015	12	10	21	2	22	0.63	-0.154	3.822	0.01	0.007	0	27.5	31.8	69.7	101	111	0	37	37
2015	12	10	21	12	22	0.627	-0.148	3.822	0.01	0.007	0	27.5	31.4	64.5	101	111	0	37	38
2015	12	10	21	22	22	0.646	-0.102	3.822	0.01	0.007	0	28.4	31.4	53.8	103	112	0	37	39
2015	12	10	21	32	22	0.607	-0.118	3.822	0.01	0.007	0	28.4	31.4	53.3	104	112	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	21	42	22	0.63	-0.135	3.825	0.01	0.007	0	27.5	31.4	62.8	101	111	0	37	38
2015	12	10	21	52	22	0.666	-0.105	3.825	0.01	0.007	0	28	31	54.6	102	110	0	37	38
2015	12	10	22	2	22	0.686	-0.112	3.822	0.01	0.007	0	29.2	32.7	51.6	106	114	0	38	38
2015	12	10	22	12	22	0.656	-0.082	3.822	0.01	0.007	0	32.3	35.7	49.9	112	121	0	37	38
2015	12	10	22	22	22	0.646	-0.092	3.825	0.01	0.007	0	34.4	37.8	51.6	118	126	0	38	38
2015	12	10	22	32	22	0.64	-0.098	3.825	0.01	0.007	0	32.7	37	52.5	114	123	0	38	37
2015	12	10	22	42	22	0.633	-0.121	3.825	0.01	0.007	0	31	34.4	56.3	110	119	0	38	39
2015	12	10	22	52	22	0.656	-0.118	3.825	0.01	0.007	0	30.1	33.5	59.8	107	117	0	37	39
2015	12	10	23	2	22	0.679	-0.052	3.825	0.01	0.007	0	30.1	33.1	50.7	107	115	0	37	38
2015	12	10	23	12	22	0.633	-0.089	3.829	0.01	0.007	0	30.5	34	52.9	108	117	0	37	38
2015	12	10	23	22	22	0.614	-0.135	3.829	0.01	0.007	0	29.7	33.5	62.4	106	116	0	37	38
2015	12	10	23	32	22	0.623	-0.135	3.829	0.016	0.013	0	29.2	32.7	65.8	106	115	0	38	39
2015	12	10	23	42	22	0.623	-0.125	3.829	0.01	0.007	0	28.8	31.8	61.5	104	113	0	37	39
2015	12	10	23	52	22	0.623	-0.125	3.832	0.01	0.007	0	28	32.3	66.7	102	113	0	37	38
2015	12	11	0	2	22	0.633	-0.105	3.832	0.01	0.007	0	27.5	31.4	78.3	101	111	0	37	38
2015	12	11	0	12	22	0.614	-0.131	3.832	0.01	0.007	0	28	31.4	73.1	101	111	0	36	38
2015	12	11	0	22	22	0.653	-0.144	3.832	0.01	0.007	0	28	31.4	64.5	102	110	0	37	37
2015	12	11	0	32	22	0.633	-0.118	3.832	0.01	0.007	0	27.5	31.4	59.8	101	111	0	37	38
2015	12	11	0	42	22	0.663	-0.102	3.832	0.01	0.007	0	28.4	32.3	53.8	103	112	0	37	37
2015	12	11	0	52	22	0.627	-0.118	3.832	0.01	0.007	0	28	31.4	56.8	102	111	0	37	38
2015	12	11	1	2	22	0.702	-0.098	3.832	0.01	0.007	0	28	31.4	54.6	102	111	0	37	38
2015	12	11	1	12	22	0.62	-0.125	3.832	0.01	0.007	0	27.5	31.8	74.8	101	111	0	37	37
2015	12	11	1	22	22	0.62	-0.154	3.832	0.013	0.01	0	27.1	31.4	71	101	111	0	38	38
2015	12	11	1	32	22	0.607	-0.131	3.832	0.01	0.007	0	38.7	42.1	74.4	126	136	0	36	38
2015	12	11	1	42	22	0.659	-0.141	3.832	0.01	0.007	0	28.4	31.8	61.5	103	113	0	37	39
2015	12	11	1	52	22	0.62	-0.138	3.832	0.01	0.007	0	28	31.8	69.7	102	112	0	37	38
2015	12	11	2	2	22	0.659	-0.138	3.835	0.013	0.01	0	28.8	31.8	58	104	112	0	37	38
2015	12	11	2	12	22	0.627	-0.105	3.835	0.01	0.007	0	28	31.4	55.5	102	111	0	37	38
2015	12	11	2	22	22	0.659	-0.105	3.835	0.013	0.01	0	28	31	53.8	102	110	0	37	38
2015	12	11	2	32	22	0.623	-0.115	3.835	0.01	0.007	0	27.5	31	58.9	101	110	0	37	38
2015	12	11	2	42	22	0.633	-0.131	3.835	0.013	0.01	0	27.1	31.4	76.5	100	111	0	37	38
2015	12	11	2	52	22	0.62	-0.144	3.835	0.01	0.007	0	27.5	31	61.9	101	111	0	37	39
2015	12	11	3	2	22	0.627	-0.138	3.835	0.01	0.007	0	26.7	31.8	77.8	100	111	0	38	37
2015	12	11	3	12	22	0.653	-0.118	3.835	0.013	0.01	0	27.5	31.4	77.8	101	111	0	37	38
2015	12	11	3	22	22	0.656	-0.125	3.835	0.01	0.007	0	26.7	31.4	77	100	111	0	38	38
2015	12	11	3	32	22	0.62	-0.121	3.835	0.01	0.007	0	27.1	30.5	76.1	100	110	0	37	39
2015	12	11	3	42	22	0.633	-0.135	3.839	0.01	0.007	0	27.1	30.5	70.1	100	109	0	37	38
2015	12	11	3	52	22	0.636	-0.105	3.839	0.01	0.007	0	27.5	31.4	59.8	101	111	0	37	38
2015	12	11	4	2	22	0.633	-0.135	3.839	0.01	0.007	0	27.1	31.4	74.8	101	111	0	38	38
2015	12	11	4	12	22	0.636	-0.108	3.839	0.01	0.007	0	28	31.8	70.5	102	112	0	37	38
2015	12	11	4	22	22	0.653	-0.148	3.839	0.01	0.007	0	27.1	31	77	100	110	0	37	38
2015	12	11	4	32	22	0.633	-0.141	3.839	0.013	0.01	0	27.1	30.5	77	100	109	0	37	38
2015	12	11	4	42	22	0.63	-0.121	3.839	0.01	0.007	0	27.1	30.5	77	100	110	0	37	39
2015	12	11	4	52	22	0.627	-0.121	3.839	0.01	0.007	0	26.7	31	77	99	110	0	37	38
2015	12	11	5	2	22	0.659	-0.151	3.839	0.01	0.007	0	27.5	31	76.1	100	110	0	36	38
2015	12	11	5	12	22	0.633	-0.121	3.839	0.01	0.007	0	27.1	31	76.1	100	110	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	5	22	22	0.633	-0.144	3.842	0.01	0.007	0	27.1	31	74.4	100	110	0	37	38
2015	12	11	5	32	22	0.617	-0.154	3.842	0.01	0.007	0	27.1	31	69.7	100	110	0	37	38
2015	12	11	5	42	22	0.64	-0.115	3.842	0.01	0.007	0	27.1	31	75.7	100	110	0	37	38
2015	12	11	5	52	22	0.614	-0.131	3.842	0.013	0.01	0	26.7	31	76.1	100	110	0	38	38
2015	12	11	6	2	22	0.646	-0.148	3.842	0.01	0.007	0	27.1	30.1	75.7	99	109	0	36	39
2015	12	11	6	12	22	0.607	-0.121	3.842	0.013	0.01	0	26.7	30.5	75.7	100	110	0	38	39
2015	12	11	6	22	22	0.63	-0.121	3.842	0.01	0.007	0	28	32.3	74.8	102	113	0	37	38
2015	12	11	6	32	22	0.594	-0.154	3.842	0.016	0.013	0	30.1	34	74.4	107	117	0	37	38
2015	12	11	6	42	22	0.673	-0.108	3.842	0.013	0.01	0	28	31.8	72.7	102	112	0	37	38
2015	12	11	6	52	22	0.643	-0.105	3.848	0.01	0.007	0	28.4	31.4	52.5	103	111	0	37	38
2015	12	11	7	2	22	0.663	-0.089	3.852	0.013	0.01	0	28.4	31.8	52	103	112	0	37	38
2015	12	11	7	12	22	0.663	-0.075	3.852	0.01	0.007	0	28.4	31.4	51.2	103	111	0	37	38
2015	12	11	7	22	22	0.673	-0.098	3.852	0.013	0.01	0	28.4	30.5	53.8	102	110	0	36	39
2015	12	11	7	32	22	0.623	-0.089	3.848	0.01	0.007	0	28	31.4	53.8	102	111	0	37	38
2015	12	11	7	42	22	0.623	-0.105	3.848	0.01	0.007	0	27.1	31	57.2	100	110	0	37	38
2015	12	11	7	52	22	0.63	-0.108	3.845	0.01	0.007	0	27.5	31.4	72.7	101	111	0	37	38
2015	12	11	8	2	22	0.61	-0.095	3.848	0.01	0.007	0	27.1	31	63.6	100	110	0	37	38
2015	12	11	8	12	22	0.65	-0.105	3.855	0.016	0.013	0	27.1	31	55	100	109	0	37	37
2015	12	11	8	22	22	0.63	-0.121	3.848	0.01	0.007	0	26.7	29.7	62.4	99	108	0	37	39
2015	12	11	8	32	22	0.607	-0.128	3.852	0.01	0.007	0	26.7	31	72.7	99	109	0	37	37
2015	12	11	8	42	22	0.65	-0.131	3.852	0.016	0.013	0	27.1	30.5	71.8	99	109	0	36	38
2015	12	11	8	52	22	0.623	-0.118	3.852	0.01	0.007	0	26.2	30.1	70.1	98	108	0	37	38
2015	12	11	9	2	22	0.614	-0.131	3.858	0.01	0.007	0	26.2	30.1	72.7	98	108	0	37	38
2015	12	11	9	12	22	0.636	-0.154	3.858	0.013	0.01	0	27.5	31.4	72.7	100	111	0	36	38
2015	12	11	9	22	22	0.614	-0.128	3.862	0.01	0.007	0	28	31.4	65.8	101	111	0	36	38
2015	12	11	9	32	22	0.61	-0.148	3.862	0.01	0.007	0	27.1	31	63.6	100	110	0	37	38
2015	12	11	9	42	22	0.627	-0.148	3.865	0.01	0.007	0	25.8	30.1	72.2	97	108	0	37	38
2015	12	11	9	52	22	0.65	-0.128	3.865	0.01	0.007	0	25.4	29.2	74.4	97	107	0	38	39
2015	12	11	10	2	22	0.633	-0.128	3.868	0.01	0.007	0	26.2	30.1	73.5	98	108	0	37	38
2015	12	11	10	12	22	0.61	-0.108	3.868	0.01	0.007	0	25.8	29.2	74.4	97	107	0	37	39
2015	12	11	10	22	22	0.6	-0.148	3.868	0.01	0.007	0	26.2	29.7	73.5	98	108	0	37	39
2015	12	11	10	32	22	0.627	-0.161	3.868	0.016	0.013	0	25.8	29.7	74.8	97	107	0	37	38
2015	12	11	10	42	22	0.627	-0.141	3.868	0.01	0.007	0	26.2	29.7	74.8	98	107	0	37	38
2015	12	11	10	52	22	0.669	-0.121	3.868	0.01	0.007	0	25.4	29.7	75.3	96	107	0	37	38
2015	12	11	11	2	22	0.607	-0.138	3.868	0.01	0.007	0	26.2	30.1	75.3	98	108	0	37	38
2015	12	11	11	12	22	0.64	-0.157	3.871	0.01	0.007	0	26.2	30.1	73.1	98	108	0	37	38
2015	12	11	11	22	22	0.636	-0.125	3.871	0.01	0.007	0	25.8	29.7	74	97	108	0	37	39
2015	12	11	11	32	22	0.6	-0.108	3.871	0.016	0.013	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	11	11	42	22	0.643	-0.112	3.871	0.013	0.01	0	26.7	31	76.1	99	110	0	37	38
2015	12	11	11	52	22	0.62	-0.121	3.871	0.01	0.007	0	26.7	30.5	74.4	99	109	0	37	38
2015	12	11	12	2	22	0.61	-0.115	3.875	0.01	0.007	0	26.7	30.1	74.8	99	109	0	37	39
2015	12	11	12	12	22	0.633	-0.128	3.875	0.01	0.007	0	26.7	30.1	74	99	108	0	37	38
2015	12	11	12	22	22	0.61	-0.121	3.871	0.01	0.007	0	26.2	30.5	75.7	98	109	0	37	38
2015	12	11	12	32	22	0.63	-0.141	3.875	0.01	0.007	0	26.7	30.5	63.2	99	109	0	37	38
2015	12	11	12	42	22	0.643	-0.125	3.875	0.013	0.01	0	26.7	30.5	72.2	99	109	0	37	38
2015	12	11	12	52	22	0.604	-0.141	3.875	0.01	0.007	0	27.1	31	66.7	100	110	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	13	2	22	0.646	-0.135	3.875	0.01	0.007	0	26.2	30.1	72.7	98	108	0	37	38
2015	12	11	13	12	22	0.64	-0.164	3.875	0.01	0.007	0	29.7	33.1	70.1	105	115	0	36	38
2015	12	11	13	22	22	0.65	-0.085	3.875	0.01	0.007	0	28.4	31.8	54.6	103	112	0	37	38
2015	12	11	13	32	22	0.669	-0.105	3.875	0.01	0.007	0	27.5	31.4	58	101	111	0	37	38
2015	12	11	13	42	22	0.705	-0.098	3.875	0.013	0.01	0	28.8	31.4	52.9	104	111	0	37	38
2015	12	11	13	52	22	0.696	-0.121	3.871	0.01	0.007	0	32.7	36.5	51.6	114	123	0	38	38
2015	12	11	14	2	22	0.63	-0.098	3.871	0.013	0.01	0	36.5	40	51.2	122	131	0	37	38
2015	12	11	14	12	22	0.679	-0.121	3.875	0.01	0.007	0	35.3	38.7	52.5	119	128	0	37	38
2015	12	11	14	22	22	0.653	-0.105	3.871	0.01	0.007	0	33.5	36.5	52.9	115	124	0	37	39
2015	12	11	14	32	22	0.692	-0.043	3.875	0.01	0.007	0	32.3	35.7	52.5	112	121	0	37	38
2015	12	11	14	42	22	0.673	-0.125	3.875	0.013	0.01	0	31.4	35.3	54.2	110	120	0	37	38
2015	12	11	14	52	22	0.682	-0.092	3.875	0.01	0.007	0	31.8	34.4	52.9	110	119	0	36	39
2015	12	11	15	2	22	0.643	-0.108	3.875	0.01	0.007	0	30.5	33.5	53.3	108	116	0	37	38
2015	12	11	15	12	22	0.679	-0.092	3.878	0.01	0.007	0	29.7	33.1	54.2	106	115	0	37	38
2015	12	11	15	22	22	0.663	-0.125	3.878	0.01	0.007	0	29.2	32.7	54.6	105	113	0	37	37
2015	12	11	15	32	22	0.659	-0.112	3.875	0.01	0.007	0	28.8	31.8	54.6	104	112	0	37	38
2015	12	11	15	42	22	0.666	-0.112	3.875	0.01	0.007	0	28	31.4	55	102	111	0	37	38
2015	12	11	15	52	22	0.636	-0.131	3.875	0.01	0.007	0	27.5	31.4	58.5	101	110	0	37	37
2015	12	11	16	2	22	0.666	-0.085	3.878	0.01	0.007	0	28	31.4	55.9	101	110	0	36	37
2015	12	11	16	12	22	0.689	-0.118	3.878	0.01	0.007	0	27.1	30.5	56.8	100	109	0	37	38
2015	12	11	16	22	22	0.692	-0.092	3.878	0.01	0.007	0	27.5	31	58	101	110	0	37	38
2015	12	11	16	32	22	0.659	-0.108	3.878	0.013	0.01	0	27.5	31	56.3	101	110	0	37	38
2015	12	11	16	42	22	0.646	-0.108	3.878	0.01	0.007	0	27.5	31	58.5	101	110	0	37	38
2015	12	11	16	52	22	0.643	-0.108	3.878	0.01	0.007	0	27.5	31	60.6	101	110	0	37	38
2015	12	11	17	2	22	0.666	-0.108	3.878	0.01	0.007	0	27.5	31	61.9	101	110	0	37	38
2015	12	11	17	12	22	0.64	-0.105	3.878	0.01	0.007	0	27.5	31	59.8	101	110	0	37	38
2015	12	11	17	22	22	0.679	-0.138	3.878	0.01	0.007	0	27.5	31	58.9	101	110	0	37	38
2015	12	11	17	32	22	0.597	-0.108	3.878	0.01	0.007	0	27.5	31.4	59.8	102	111	0	38	38
2015	12	11	17	42	22	0.633	-0.135	3.878	0.013	0.01	0	28	31.8	62.8	102	112	0	37	38
2015	12	11	17	52	22	0.623	-0.095	3.878	0.013	0.01	0	28	31.8	68.4	102	112	0	37	38
2015	12	11	18	2	22	0.627	-0.154	3.878	0.01	0.007	0	28	31.8	67.5	102	112	0	37	38
2015	12	11	18	12	22	0.614	-0.115	3.878	0.01	0.007	0	27.5	31	72.2	101	111	0	37	39
2015	12	11	18	22	22	0.643	-0.112	3.878	0.01	0.007	0	28.4	32.3	73.5	102	112	0	36	37
2015	12	11	18	32	22	0.636	-0.108	3.878	0.013	0.01	0	27.5	31.4	71.8	101	111	0	37	38
2015	12	11	18	42	22	0.63	-0.115	3.878	0.016	0.013	0	27.5	31.8	74.4	101	112	0	37	38
2015	12	11	18	52	22	0.633	-0.148	3.878	0.013	0.01	0	27.5	31.4	70.5	101	111	0	37	38
2015	12	11	19	2	22	0.653	-0.118	3.881	0.01	0.007	0	27.1	31.4	64.9	100	111	0	37	38
2015	12	11	19	12	22	0.65	-0.112	3.881	0.01	0.007	0	27.5	31.4	75.3	101	111	0	37	38
2015	12	11	19	22	22	0.623	-0.128	3.881	0.01	0.007	0	28	31.8	77.4	101	111	0	36	37
2015	12	11	19	32	22	0.659	-0.154	3.881	0.01	0.007	0	27.5	31.4	77.8	101	111	0	37	38
2015	12	11	19	42	22	0.617	-0.121	3.881	0.01	0.007	0	27.1	31.4	77.4	101	111	0	38	38
2015	12	11	19	52	22	0.686	-0.128	3.881	0.01	0.007	0	27.5	31.4	77	101	111	0	37	38
2015	12	11	20	2	22	0.643	-0.112	3.881	0.01	0.007	0	27.5	31.4	77	101	111	0	37	38
2015	12	11	20	12	22	0.646	-0.125	3.881	0.01	0.007	0	27.5	31.4	74.4	101	111	0	37	38
2015	12	11	20	22	22	0.653	-0.135	3.881	0.01	0.007	0	28	32.7	75.3	102	113	0	37	37
2015	12	11	20	32	22	0.63	-0.141	3.881	0.01	0.007	0	28.4	32.3	76.5	103	113	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	20	42	22	0.643	-0.144	3.881	0.01	0.007	0	28	31	74.4	102	111	0	37	39
2015	12	11	20	52	22	0.65	-0.131	3.881	0.01	0.007	0	28	31.8	67.1	102	112	0	37	38
2015	12	11	21	2	22	0.64	-0.138	3.885	0.016	0.013	0	28	31.8	74.8	102	112	0	37	38
2015	12	11	21	12	22	0.633	-0.138	3.885	0.01	0.007	0	28.4	32.3	66.2	103	113	0	37	38
2015	12	11	21	22	22	0.643	-0.135	3.888	0.01	0.007	0	28	31.8	58.5	102	112	0	37	38
2015	12	11	21	32	22	0.627	-0.121	3.885	0.01	0.007	0	29.2	33.5	59.3	106	116	0	38	38
2015	12	11	21	42	22	0.659	-0.112	3.885	0.01	0.007	0	28.8	32.3	61.1	104	113	0	37	38
2015	12	11	21	52	22	0.643	-0.121	3.885	0.01	0.007	0	28	31.8	62.8	103	112	0	38	38
2015	12	11	22	2	22	0.646	-0.167	3.885	0.016	0.013	0	28	32.3	71.8	102	112	0	37	37
2015	12	11	22	12	22	0.627	-0.151	3.885	0.01	0.007	0	28	32.3	71.8	103	113	0	38	38
2015	12	11	22	22	22	0.643	-0.148	3.885	0.01	0.007	0	28	31.8	74.8	102	112	0	37	38
2015	12	11	22	32	22	0.643	-0.112	3.885	0.01	0.007	0	28.4	31.8	73.5	103	113	0	37	39
2015	12	11	22	42	22	0.65	-0.095	3.885	0.01	0.007	0	28	32.3	74.4	102	113	0	37	38
2015	12	11	22	52	22	0.666	-0.128	3.888	0.013	0.01	0	28	32.3	74.8	102	112	0	37	37
2015	12	11	23	2	22	0.65	-0.131	3.885	0.01	0.007	0	28	32.3	71.4	103	113	0	38	38
2015	12	11	23	12	22	0.653	-0.102	3.888	0.01	0.007	0	28.4	32.3	74.8	103	113	0	37	38
2015	12	11	23	22	22	0.679	-0.144	3.888	0.01	0.007	0	27.1	31.4	74.8	101	111	0	38	38
2015	12	11	23	32	22	0.633	-0.138	3.888	0.013	0.01	0	28.4	32.3	75.3	102	112	0	36	37
2015	12	11	23	42	22	0.623	-0.118	3.888	0.016	0.013	0	28.4	32.3	74.8	103	113	0	37	38
2015	12	11	23	52	22	0.676	-0.121	3.888	0.013	0.01	0	27.5	31.8	74.4	101	112	0	37	38
2015	12	12	0	2	22	0.656	-0.135	3.888	0.01	0.007	0	28.4	31.8	74.4	102	112	0	36	38
2015	12	12	0	12	22	0.63	-0.125	3.888	0.013	0.01	0	28	31.4	74.4	102	112	0	37	39
2015	12	12	0	22	22	0.643	-0.135	3.888	0.01	0.007	0	27.5	31.8	74	101	112	0	37	38
2015	12	12	0	32	22	0.614	-0.141	3.888	0.01	0.007	0	28	31.8	73.5	102	112	0	37	38
2015	12	12	0	42	22	0.666	-0.108	3.891	0.01	0.007	0	28	32.3	74	102	113	0	37	38
2015	12	12	0	52	22	0.636	-0.141	3.891	0.01	0.007	0	28	31.4	72.7	102	112	0	37	39
2015	12	12	1	2	22	0.63	-0.131	3.891	0.01	0.007	0	28.4	31.8	72.7	102	112	0	36	38
2015	12	12	1	12	22	0.614	-0.131	3.891	0.01	0.007	0	28.4	31.4	73.5	102	112	0	36	39
2015	12	12	1	22	22	0.64	-0.121	3.891	0.013	0.01	0	28	31.4	73.5	102	112	0	37	39
2015	12	12	1	32	22	0.643	-0.128	3.894	0.01	0.007	0	28	31.8	68.4	102	112	0	37	38
2015	12	12	1	42	22	0.633	-0.118	3.898	0.01	0.007	0	28	31.8	67.9	102	112	0	37	38
2015	12	12	1	52	22	0.633	-0.095	3.898	0.01	0.007	0	28	31.4	70.1	102	112	0	37	39
2015	12	12	2	2	22	0.653	-0.128	3.898	0.01	0.007	0	28	31.8	67.5	102	112	0	37	38
2015	12	12	2	12	22	0.666	-0.131	3.901	0.01	0.007	0	27.5	31.8	72.7	101	111	0	37	37
2015	12	12	2	22	22	0.64	-0.102	3.901	0.01	0.007	0	28	31.8	69.2	102	112	0	37	38
2015	12	12	2	32	22	0.643	-0.128	3.901	0.01	0.007	0	27.5	31.8	74	101	112	0	37	38
2015	12	12	2	42	22	0.614	-0.108	3.904	0.01	0.007	0	27.1	31.8	74.8	101	112	0	38	38
2015	12	12	2	52	22	0.64	-0.112	3.901	0.01	0.007	0	28	31.8	74.8	102	112	0	37	38
2015	12	12	3	2	22	0.646	-0.125	3.904	0.016	0.013	0	28	31.8	71	102	112	0	37	38
2015	12	12	3	12	22	0.659	-0.144	3.904	0.01	0.007	0	27.5	31.8	73.5	101	111	0	37	37
2015	12	12	3	22	22	0.643	-0.128	3.904	0.016	0.013	0	28	31.8	65.4	102	111	0	37	37
2015	12	12	3	32	22	0.62	-0.131	3.904	0.01	0.007	0	27.5	31	64.9	101	111	0	37	39
2015	12	12	3	42	22	0.61	-0.112	3.904	0.01	0.007	0	27.5	31.8	74.8	101	112	0	37	38
2015	12	12	3	52	22	0.666	-0.157	3.904	0.01	0.007	0	27.5	31.8	76.5	101	112	0	37	38
2015	12	12	4	2	22	0.653	-0.128	3.904	0.01	0.007	0	27.1	31	77.4	100	110	0	37	38
2015	12	12	4	12	22	0.65	-0.138	3.904	0.013	0.01	0	27.5	31	77	101	110	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	4	22	22	0.636	-0.112	3.904	0.01	0.007	0	27.5	31.4	77	101	111	0	37	38
2015	12	12	4	32	22	0.636	-0.112	3.904	0.01	0.007	0	27.5	31.4	77.4	100	111	0	36	38
2015	12	12	4	42	22	0.614	-0.135	3.904	0.01	0.007	0	27.5	31	76.5	101	111	0	37	39
2015	12	12	4	52	22	0.65	-0.141	3.907	0.01	0.007	0	28.8	32.7	76.5	104	114	0	37	38
2015	12	12	5	2	22	0.64	-0.125	3.907	0.01	0.007	0	28	32.3	73.5	102	113	0	37	38
2015	12	12	5	12	22	0.636	-0.105	3.907	0.01	0.007	0	28	31.8	71.4	102	112	0	37	38
2015	12	12	5	22	22	0.65	-0.141	3.907	0.01	0.007	0	28	31.8	76.5	103	112	0	38	38
2015	12	12	5	32	22	0.682	-0.151	3.907	0.01	0.007	0	27.5	31.4	63.2	102	111	0	38	38
2015	12	12	5	42	22	0.63	-0.125	3.907	0.01	0.007	0	28	31.8	61.9	102	112	0	37	38
2015	12	12	5	52	22	0.614	-0.157	3.907	0.01	0.007	0	28	32.3	76.5	102	113	0	37	38
2015	12	12	6	2	22	0.607	-0.112	3.907	0.01	0.007	0	29.2	33.1	71.4	105	115	0	37	38
2015	12	12	6	12	22	0.656	-0.115	3.907	0.01	0.007	0	31	34.8	74.4	109	119	0	37	38
2015	12	12	6	22	22	0.636	-0.138	3.907	0.013	0.01	0	33.1	37	77.8	114	124	0	37	38
2015	12	12	6	32	22	0.659	-0.105	3.907	0.01	0.007	0	28.8	32.7	74.8	104	114	0	37	38
2015	12	12	6	42	22	0.643	-0.092	3.907	0.01	0.007	0	28.4	32.7	77.8	103	113	0	37	37
2015	12	12	6	52	22	0.646	-0.108	3.907	0.01	0.007	0	28	31.8	77.4	102	112	0	37	38
2015	12	12	7	2	22	0.636	-0.118	3.907	0.01	0.007	0	28.4	32.7	75.7	103	113	0	37	37
2015	12	12	7	12	22	0.62	-0.108	3.907	0.01	0.007	0	27.5	31.8	69.7	101	111	0	37	37
2015	12	12	7	22	22	0.636	-0.148	3.911	0.013	0.01	0	27.5	31.4	73.5	101	111	0	37	38
2015	12	12	7	32	22	0.623	-0.125	3.911	0.01	0.007	0	27.1	31	75.7	100	110	0	37	38
2015	12	12	7	42	22	0.663	-0.098	3.911	0.01	0.007	0	26.7	31	74.8	100	110	0	38	38
2015	12	12	7	52	22	0.627	-0.131	3.911	0.01	0.007	0	27.5	31.4	74	101	111	0	37	38
2015	12	12	8	2	22	0.633	-0.131	3.911	0.01	0.007	0	27.1	31	71.8	100	110	0	37	38
2015	12	12	8	12	22	0.682	-0.135	3.911	0.013	0.01	0	27.1	30.1	58.9	100	109	0	37	39
2015	12	12	8	22	22	0.617	-0.118	3.914	0.01	0.007	0	27.1	30.5	56.8	100	109	0	37	38
2015	12	12	8	32	22	0.676	-0.118	3.914	0.01	0.007	0	27.1	30.1	57.2	100	109	0	37	39
2015	12	12	8	42	22	0.679	-0.118	3.914	0.01	0.007	0	27.5	31	56.3	101	110	0	37	38
2015	12	12	8	52	22	0.663	-0.082	3.914	0.016	0.013	0	26.7	30.5	55.9	100	109	0	38	38
2015	12	12	9	2	22	0.64	-0.092	3.914	0.01	0.007	0	28.4	31.4	53.8	103	112	0	37	39
2015	12	12	9	12	22	0.705	-0.095	3.917	0.01	0.007	0	28	30.5	52.9	102	110	0	37	39
2015	12	12	9	22	22	0.686	-0.154	3.917	0.01	0.007	0	28	31.4	53.3	102	111	0	37	38
2015	12	12	9	32	22	0.636	-0.072	3.917	0.01	0.007	0	28	31.8	52.9	103	112	0	38	38
2015	12	12	9	42	22	0.679	-0.075	3.917	0.01	0.007	0	28.4	31.4	51.6	103	112	0	37	39
2015	12	12	9	52	22	0.669	-0.075	3.921	0.01	0.007	0	29.7	32.7	51.2	106	114	0	37	38
2015	12	12	10	2	22	0.666	-0.125	3.921	0.01	0.007	0	30.1	33.5	51.2	107	116	0	37	38
2015	12	12	10	12	22	0.653	-0.079	3.921	0.01	0.007	0	29.7	32.7	50.7	106	114	0	37	38
2015	12	12	10	22	22	0.699	-0.141	3.921	0.01	0.007	0	28.8	32.7	53.8	104	114	0	37	38
2015	12	12	10	32	22	0.656	-0.089	3.921	0.01	0.007	0	28.4	31.8	52.5	104	112	0	38	38
2015	12	12	10	42	22	0.636	-0.098	3.921	0.01	0.007	0	28.8	31.8	53.8	103	112	0	36	38
2015	12	12	10	52	22	0.696	-0.089	3.921	0.01	0.007	0	28.4	31.4	55.5	103	111	0	37	38
2015	12	12	11	2	22	0.643	-0.115	3.924	0.01	0.007	0	28.4	31.4	52	102	111	0	36	38
2015	12	12	11	12	22	0.656	-0.105	3.924	0.013	0.01	0	28.4	31.4	54.6	103	111	0	37	38
2015	12	12	11	22	22	0.696	-0.105	3.924	0.01	0.007	0	28	30.5	55.9	102	110	0	37	39
2015	12	12	11	32	22	0.673	-0.125	3.924	0.01	0.007	0	27.1	30.5	53.8	100	109	0	37	38
2015	12	12	11	42	22	0.709	-0.121	3.924	0.01	0.007	0	27.1	30.5	55.5	100	109	0	37	38
2015	12	12	11	52	22	0.656	-0.125	3.924	0.013	0.01	0	27.1	31	55.9	100	109	0	37	37

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	12	2	22	0.686	-0.102	3.924	0.01	0.007	0	27.1	29.7	54.2	100	108	0	37	39
2015	12	12	12	12	22	0.696	-0.108	3.924	0.01	0.007	0	27.1	30.5	55.5	100	109	0	37	38
2015	12	12	12	22	22	0.653	-0.125	3.924	0.013	0.01	0	26.7	30.5	56.3	99	109	0	37	38
2015	12	12	12	32	22	0.63	-0.118	3.924	0.01	0.007	0	26.7	30.1	55.9	99	108	0	37	38
2015	12	12	12	42	22	0.633	-0.102	3.924	0.01	0.007	0	27.5	30.5	57.2	100	109	0	36	38
2015	12	12	12	52	22	0.62	-0.148	3.924	0.013	0.01	0	26.7	30.5	64.9	99	109	0	37	38
2015	12	12	13	2	22	0.679	-0.125	3.924	0.01	0.007	0	26.2	30.1	57.6	99	108	0	38	38
2015	12	12	13	12	22	0.63	-0.105	3.924	0.01	0.007	0	26.2	30.1	62.4	98	108	0	37	38
2015	12	12	13	22	22	0.673	-0.075	3.924	0.01	0.007	0	26.7	30.1	57.2	99	108	0	37	38
2015	12	12	13	32	22	0.607	-0.148	3.924	0.01	0.007	0	25.8	30.1	58.9	98	108	0	38	38
2015	12	12	13	42	22	0.614	-0.118	3.921	0.01	0.007	0	25.8	29.7	72.2	97	107	0	37	38
2015	12	12	13	52	22	0.653	-0.108	3.924	0.01	0.007	0	26.7	30.1	56.8	99	108	0	37	38
2015	12	12	14	2	22	0.643	-0.118	3.921	0.013	0.01	0	26.2	30.1	71	99	108	0	38	38
2015	12	12	14	12	22	0.653	-0.118	3.921	0.01	0.007	0	26.7	30.1	61.1	99	108	0	37	38
2015	12	12	14	22	22	0.65	-0.102	3.921	0.01	0.007	0	26.7	30.1	57.6	99	107	0	37	37
2015	12	12	14	32	22	0.659	-0.118	3.921	0.01	0.007	0	26.7	29.7	60.2	99	107	0	37	38
2015	12	12	14	42	22	0.643	-0.121	3.921	0.01	0.007	0	25.8	29.2	76.1	97	107	0	37	39
2015	12	12	14	52	22	0.643	-0.108	3.921	0.01	0.007	0	25.8	29.7	73.1	97	107	0	37	38
2015	12	12	15	2	22	0.636	-0.144	3.921	0.013	0.01	0	25.8	29.7	76.5	97	107	0	37	38
2015	12	12	15	12	22	0.646	-0.135	3.917	0.01	0.007	0	25.4	29.7	77	97	107	0	38	38
2015	12	12	15	22	22	0.627	-0.154	3.917	0.01	0.007	0	25.8	30.5	75.7	97	108	0	37	37
2015	12	12	15	32	22	0.623	-0.148	3.917	0.01	0.007	0	26.2	29.7	75.7	97	107	0	36	38
2015	12	12	15	42	22	0.633	-0.144	3.917	0.01	0.007	0	25.8	29.7	69.7	97	107	0	37	38
2015	12	12	15	52	22	0.64	-0.118	3.917	0.01	0.007	0	26.2	30.1	76.1	98	108	0	37	38
2015	12	12	16	2	22	0.643	-0.128	3.921	0.01	0.007	0	25.4	28.8	76.5	96	106	0	37	39
2015	12	12	16	12	22	0.643	-0.112	3.917	0.01	0.007	0	25.8	29.7	77.4	97	107	0	37	38
2015	12	12	16	22	22	0.653	-0.121	3.917	0.01	0.007	0	25.8	30.1	76.5	97	108	0	37	38
2015	12	12	16	32	22	0.653	-0.118	3.917	0.01	0.007	0	25.4	29.7	76.5	97	107	0	38	38
2015	12	12	16	42	22	0.65	-0.115	3.917	0.01	0.007	0	26.2	29.2	76.5	97	107	0	36	39
2015	12	12	16	52	22	0.653	-0.138	3.921	0.01	0.007	0	25.8	29.7	76.5	97	107	0	37	38
2015	12	12	17	2	22	0.633	-0.085	3.921	0.01	0.007	0	25.8	29.7	76.1	97	107	0	37	38
2015	12	12	17	12	22	0.62	-0.115	3.921	0.01	0.007	0	25.4	30.1	76.5	97	108	0	38	38
2015	12	12	17	22	22	0.643	-0.135	3.921	0.01	0.007	0	27.1	30.5	76.5	99	109	0	36	38
2015	12	12	17	32	22	0.643	-0.118	3.921	0.01	0.007	0	26.2	29.7	76.5	98	108	0	37	39
2015	12	12	17	42	22	0.65	-0.141	3.921	0.01	0.007	0	25.8	30.1	75.7	97	108	0	37	38
2015	12	12	17	52	22	0.656	-0.118	3.921	0.01	0.007	0	26.2	29.7	76.1	98	108	0	37	39
2015	12	12	18	2	22	0.646	-0.141	3.921	0.01	0.007	0	25.8	30.5	76.1	97	108	0	37	37
2015	12	12	18	12	22	0.653	-0.128	3.921	0.01	0.007	0	26.2	30.1	76.1	98	108	0	37	38
2015	12	12	18	22	22	0.666	-0.105	3.921	0.01	0.007	0	25.8	29.7	76.1	97	107	0	37	38
2015	12	12	18	32	22	0.636	-0.112	3.921	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	12	18	42	22	0.636	-0.118	3.921	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	12	18	52	22	0.64	-0.125	3.921	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	12	19	2	22	0.65	-0.148	3.921	0.01	0.007	0	25.8	30.5	75.7	97	108	0	37	37
2015	12	12	19	12	22	0.63	-0.115	3.921	0.01	0.007	0	26.7	30.5	75.3	99	109	0	37	38
2015	12	12	19	22	22	0.627	-0.135	3.921	0.01	0.007	0	26.7	30.1	75.3	98	108	0	36	38
2015	12	12	19	32	22	0.636	-0.112	3.921	0.01	0.007	0	26.2	30.1	75.3	98	108	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	19	42	22	0.63	-0.157	3.921	0.01	0.007	0	26.2	30.1	75.3	98	108	0	37	38
2015	12	12	19	52	22	0.64	-0.118	3.921	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	12	20	2	22	0.607	-0.118	3.924	0.01	0.007	0	26.7	30.5	75.3	99	109	0	37	38
2015	12	12	20	12	22	0.653	-0.105	3.924	0.01	0.007	0	27.1	31	74.8	100	110	0	37	38
2015	12	12	20	22	22	0.659	-0.121	3.924	0.01	0.007	0	27.5	31.4	74	101	111	0	37	38
2015	12	12	20	32	22	0.65	-0.112	3.924	0.01	0.007	0	28.4	32.3	74.4	103	113	0	37	38
2015	12	12	20	42	22	0.65	-0.121	3.924	0.01	0.007	0	27.1	31	74.4	100	110	0	37	38
2015	12	12	20	52	22	0.663	-0.121	3.924	0.013	0.01	0	26.7	30.1	74.4	99	108	0	37	38
2015	12	12	21	2	22	0.633	-0.102	3.924	0.01	0.007	0	26.7	30.5	74.4	99	109	0	37	38
2015	12	12	21	12	22	0.633	-0.105	3.924	0.01	0.007	0	26.2	30.5	74.8	99	109	0	38	38
2015	12	12	21	22	22	0.656	-0.148	3.924	0.01	0.007	0	26.2	30.5	74	98	109	0	37	38
2015	12	12	21	32	22	0.65	-0.108	3.924	0.01	0.007	0	26.2	30.5	74	98	109	0	37	38
2015	12	12	21	42	22	0.643	-0.144	3.924	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	12	21	52	22	0.676	-0.141	3.924	0.01	0.007	0	26.2	30.5	73.5	98	108	0	37	37
2015	12	12	22	2	22	0.64	-0.151	3.927	0.01	0.007	0	26.2	30.1	74.4	98	108	0	37	38
2015	12	12	22	12	22	0.62	-0.115	3.927	0.02	0.016	0	26.2	30.1	73.5	98	108	0	37	38
2015	12	12	22	22	22	0.636	-0.121	3.93	0.01	0.007	0	25.8	29.7	74	97	107	0	37	38
2015	12	12	22	32	22	0.636	-0.141	3.93	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	12	22	42	22	0.653	-0.128	3.934	0.01	0.007	0	26.2	30.1	74	98	108	0	37	38
2015	12	12	22	52	22	0.669	-0.121	3.934	0.01	0.007	0	25.8	29.7	73.5	97	107	0	37	38
2015	12	12	23	2	22	0.607	-0.102	3.934	0.01	0.007	0	25.8	30.1	74	97	108	0	37	38
2015	12	12	23	12	22	0.614	-0.115	3.934	0.01	0.007	0	25.8	29.2	74.4	97	107	0	37	39
2015	12	12	23	22	22	0.669	-0.128	3.934	0.013	0.01	0	25.4	29.2	74.4	97	107	0	38	39
2015	12	12	23	32	22	0.646	-0.125	3.937	0.01	0.007	0	26.2	30.1	74.8	98	108	0	37	38
2015	12	12	23	42	22	0.666	-0.131	3.937	0.01	0.007	0	25.4	29.7	75.3	97	108	0	38	39
2015	12	12	23	52	22	0.62	-0.125	3.934	0.01	0.007	0	25.8	30.1	74.8	97	108	0	37	38
2015	12	13	0	2	22	0.646	-0.089	3.937	0.01	0.007	0	26.2	30.5	75.3	98	109	0	37	38
2015	12	13	0	12	22	0.646	-0.131	3.937	0.01	0.007	0	25.8	30.1	75.3	97	108	0	37	38
2015	12	13	0	22	22	0.646	-0.118	3.937	0.01	0.007	0	26.2	30.1	75.3	97	108	0	36	38
2015	12	13	0	32	22	0.656	-0.148	3.937	0.01	0.007	0	25.4	29.2	75.3	97	107	0	38	39
2015	12	13	0	42	22	0.643	-0.105	3.937	0.01	0.007	0	26.2	30.1	76.1	98	108	0	37	38
2015	12	13	0	52	22	0.663	-0.141	3.937	0.01	0.007	0	25.8	30.1	75.7	97	107	0	37	37
2015	12	13	1	2	22	0.643	-0.128	3.937	0.01	0.007	0	25.4	30.1	76.5	97	108	0	38	38
2015	12	13	1	12	22	0.63	-0.135	3.937	0.01	0.007	0	26.7	30.1	76.1	98	108	0	36	38
2015	12	13	1	22	22	0.633	-0.138	3.937	0.01	0.007	0	26.2	30.1	76.5	98	108	0	37	38
2015	12	13	1	32	22	0.653	-0.154	3.937	0.01	0.007	0	25.4	29.2	76.5	97	107	0	38	39
2015	12	13	1	42	22	0.623	-0.121	3.937	0.01	0.007	0	25.4	30.1	77	97	108	0	38	38
2015	12	13	1	52	22	0.633	-0.131	3.937	0.01	0.007	0	25.8	30.1	77	97	108	0	37	38
2015	12	13	2	2	22	0.63	-0.151	3.937	0.01	0.007	0	26.2	30.1	77	97	108	0	36	38
2015	12	13	2	12	22	0.646	-0.118	3.937	0.01	0.007	0	25.8	30.1	77	97	108	0	37	38
2015	12	13	2	22	22	0.623	-0.135	3.937	0.01	0.007	0	26.2	30.1	77.4	98	108	0	37	38
2015	12	13	2	32	22	0.614	-0.108	3.937	0.01	0.007	0	26.2	29.7	77.8	97	107	0	36	38
2015	12	13	2	42	22	0.656	-0.125	3.937	0.01	0.007	0	25.8	29.7	77.8	97	107	0	37	38
2015	12	13	2	52	22	0.646	-0.138	3.94	0.01	0.007	0	26.2	29.7	77.8	97	107	0	36	38
2015	12	13	3	2	22	0.633	-0.141	3.94	0.01	0.007	0	24.9	29.7	77.8	96	107	0	38	38
2015	12	13	3	12	22	0.64	-0.148	3.94	0.01	0.007	0	25.8	30.1	77.4	97	108	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	3	22	22	0.61	-0.112	3.94	0.013	0.01	0	25.8	29.7	77.8	97	107	0	37	38
2015	12	13	3	32	22	0.669	-0.138	3.94	0.01	0.007	0	25.4	30.1	78.3	97	108	0	38	38
2015	12	13	3	42	22	0.63	-0.105	3.94	0.01	0.007	0	25.4	30.1	78.3	97	108	0	38	38
2015	12	13	3	52	22	0.673	-0.115	3.94	0.01	0.007	0	26.2	29.7	78.3	98	107	0	37	38
2015	12	13	4	2	22	0.65	-0.141	3.94	0.01	0.007	0	25.8	29.7	78.3	97	107	0	37	38
2015	12	13	4	12	22	0.627	-0.121	3.94	0.013	0.01	0	25.4	29.7	78.3	97	107	0	38	38
2015	12	13	4	22	22	0.63	-0.138	3.94	0.01	0.007	0	25.8	29.7	71.8	97	107	0	37	38
2015	12	13	4	32	22	0.617	-0.131	3.94	0.013	0.01	0	27.5	31.4	78.3	101	111	0	37	38
2015	12	13	4	42	22	0.659	-0.141	3.94	0.01	0.007	0	28	31.8	77.8	103	113	0	38	39
2015	12	13	4	52	22	0.636	-0.138	3.94	0.01	0.007	0	25.4	28.8	78.3	96	106	0	37	39
2015	12	13	5	2	22	0.643	-0.118	3.94	0.01	0.007	0	24.9	29.7	78.7	96	107	0	38	38
2015	12	13	5	12	22	0.65	-0.157	3.94	0.01	0.007	0	25.4	28.8	77.4	96	106	0	37	39
2015	12	13	5	22	22	0.643	-0.105	3.94	0.01	0.007	0	26.2	30.1	78.3	98	108	0	37	38
2015	12	13	5	32	22	0.643	-0.138	3.94	0.01	0.007	0	27.5	31.8	77.8	102	112	0	38	38
2015	12	13	5	42	22	0.65	-0.125	3.94	0.01	0.007	0	27.5	31.4	77.8	101	111	0	37	38
2015	12	13	5	52	22	0.656	-0.128	3.94	0.01	0.007	0	31.4	34.8	77.4	110	120	0	37	39
2015	12	13	6	2	22	0.643	-0.108	3.94	0.01	0.007	0	30.5	34.4	78.3	108	118	0	37	38
2015	12	13	6	12	22	0.646	-0.118	3.94	0.01	0.007	0	29.7	33.5	77.8	106	117	0	37	39
2015	12	13	6	22	22	0.646	-0.144	3.94	0.01	0.007	0	26.2	31	77.4	99	110	0	38	38
2015	12	13	6	32	22	0.646	-0.128	3.94	0.01	0.007	0	25.8	30.1	77.8	97	108	0	37	38
2015	12	13	6	42	22	0.646	-0.148	3.94	0.01	0.007	0	25.8	29.2	73.5	97	107	0	37	39
2015	12	13	6	52	22	0.643	-0.115	3.94	0.01	0.007	0	25.8	30.1	77.4	97	108	0	37	38
2015	12	13	7	2	22	0.65	-0.115	3.94	0.01	0.007	0	25.4	29.7	75.7	97	107	0	38	38
2015	12	13	7	12	22	0.65	-0.135	3.94	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	13	7	22	22	0.627	-0.118	3.94	0.01	0.007	0	25.4	29.2	77.4	96	106	0	37	38
2015	12	13	7	32	22	0.63	-0.108	3.94	0.013	0.01	0	24.9	28.8	72.2	95	105	0	37	38
2015	12	13	7	42	22	0.62	-0.121	3.94	0.01	0.007	0	24.9	28.8	77.8	96	106	0	38	39
2015	12	13	7	52	22	0.617	-0.125	3.94	0.01	0.007	0	25.4	29.2	74.4	96	106	0	37	38
2015	12	13	8	2	22	0.633	-0.125	3.94	0.01	0.007	0	25.4	29.2	77	96	106	0	37	38
2015	12	13	8	12	22	0.656	-0.125	3.944	0.01	0.007	0	24.9	28.8	77.4	95	105	0	37	38
2015	12	13	8	22	22	0.61	-0.112	3.944	0.01	0.007	0	24.9	28.8	76.1	95	105	0	37	38
2015	12	13	8	32	22	0.64	-0.125	3.944	0.01	0.007	0	24.9	28.4	77.4	95	104	0	37	38
2015	12	13	8	42	22	0.604	-0.141	3.944	0.01	0.007	0	24.9	28.8	77.4	95	105	0	37	38
2015	12	13	8	52	22	0.64	-0.141	3.944	0.01	0.007	0	24.9	28.8	72.2	95	105	0	37	38
2015	12	13	9	2	22	0.62	-0.121	3.944	0.01	0.007	0	24.9	28.4	77.4	95	105	0	37	39
2015	12	13	9	12	22	0.643	-0.115	3.944	0.01	0.007	0	24.9	28.8	77.4	95	105	0	37	38
2015	12	13	9	22	22	0.643	-0.118	3.944	0.01	0.007	0	24.5	28.4	67.5	95	104	0	38	38
2015	12	13	9	32	22	0.656	-0.141	3.947	0.01	0.007	0	25.4	29.2	75.7	96	106	0	37	38
2015	12	13	9	42	22	0.646	-0.148	3.947	0.013	0.01	0	24.5	28.4	76.5	94	104	0	37	38
2015	12	13	9	52	22	0.633	-0.125	3.947	0.01	0.007	0	23.6	28.8	75.7	93	104	0	38	37
2015	12	13	10	2	22	0.64	-0.125	3.947	0.016	0.013	0	24.5	28.4	77.4	94	104	0	37	38
2015	12	13	10	12	22	0.643	-0.131	3.947	0.01	0.007	0	24.5	28.4	65.4	94	104	0	37	38
2015	12	13	10	22	22	0.63	-0.135	3.947	0.01	0.007	0	24.5	28.4	77	94	104	0	37	38
2015	12	13	10	32	22	0.646	-0.112	3.947	0.01	0.007	0	24.1	28.4	76.5	94	104	0	38	38
2015	12	13	10	42	22	0.646	-0.118	3.947	0.01	0.007	0	23.6	27.5	69.2	93	103	0	38	39
2015	12	13	10	52	22	0.607	-0.098	3.95	0.01	0.007	0	24.1	28.4	72.2	94	104	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	11	2	22	0.659	-0.128	3.95	0.01	0.007	0	24.1	28	74	94	103	0	38	38
2015	12	13	11	12	22	0.646	-0.148	3.95	0.01	0.007	0	24.5	28	58	94	103	0	37	38
2015	12	13	11	22	22	0.679	-0.121	3.947	0.01	0.007	0	24.1	28	58.9	94	103	0	38	38
2015	12	13	11	32	22	0.62	-0.138	3.947	0.01	0.007	0	24.5	27.5	56.8	94	103	0	37	39
2015	12	13	11	42	22	0.646	-0.118	3.95	0.01	0.007	0	24.5	28.4	70.5	94	104	0	37	38
2015	12	13	11	52	22	0.643	-0.154	3.95	0.01	0.007	0	24.9	28.4	65.4	95	105	0	37	39
2015	12	13	12	2	22	0.646	-0.148	3.947	0.01	0.007	0	24.9	28.4	65.4	95	104	0	37	38
2015	12	13	12	12	22	0.61	-0.128	3.95	0.013	0.01	0	24.9	28.4	57.2	95	104	0	37	38
2015	12	13	12	22	22	0.623	-0.125	3.95	0.016	0.013	0	24.5	28	62.8	94	104	0	37	39
2015	12	13	12	32	22	0.656	-0.157	3.95	0.01	0.007	0	24.5	28	53.8	94	103	0	37	38
2015	12	13	12	42	22	0.627	-0.128	3.95	0.01	0.007	0	24.9	29.2	54.2	95	106	0	37	38
2015	12	13	12	52	22	0.614	-0.108	3.947	0.01	0.007	0	24.9	28.8	66.7	95	105	0	37	38
2015	12	13	13	2	22	0.64	-0.125	3.947	0.01	0.007	0	24.9	28.8	62.4	95	105	0	37	38
2015	12	13	13	12	22	0.627	-0.144	3.947	0.01	0.007	0	24.5	28.4	61.1	95	105	0	38	39
2015	12	13	13	22	22	0.643	-0.144	3.947	0.013	0.01	0	24.9	28.8	76.1	95	105	0	37	38
2015	12	13	13	32	22	0.656	-0.144	3.944	0.01	0.007	0	24.5	28	61.9	94	103	0	37	38
2015	12	13	13	42	22	0.64	-0.115	3.944	0.01	0.007	0	24.9	28.8	65.8	95	105	0	37	38
2015	12	13	13	52	22	0.633	-0.171	3.947	0.016	0.013	0	24.5	28	54.6	95	104	0	38	39
2015	12	13	14	2	22	0.617	-0.161	3.947	0.01	0.007	0	26.2	29.7	52	98	108	0	37	39
2015	12	13	14	12	22	0.64	-0.125	3.947	0.01	0.007	0	31.8	35.7	50.7	111	121	0	37	38
2015	12	13	14	22	22	0.643	-0.144	3.947	0.01	0.007	0	32.3	36.5	48.6	112	123	0	37	38
2015	12	13	14	32	22	0.656	-0.131	3.947	0.01	0.007	0	29.7	33.1	59.3	106	116	0	37	39
2015	12	13	14	42	22	0.604	-0.118	3.947	0.01	0.007	0	29.2	32.3	51.2	105	114	0	37	39
2015	12	13	14	52	22	0.62	-0.131	3.947	0.013	0.01	0	32.7	36.5	49.9	113	123	0	37	38
2015	12	13	15	2	22	0.64	-0.144	3.947	0.01	0.007	0	33.1	37.4	50.3	115	125	0	38	38
2015	12	13	15	12	22	0.64	-0.167	3.947	0.01	0.007	0	33.5	36.1	49.9	115	122	0	37	38
2015	12	13	15	22	22	0.62	-0.118	3.95	0.013	0.01	0	31	34.4	51.6	109	118	0	37	38
2015	12	13	15	32	22	0.656	-0.138	3.95	0.01	0.007	0	30.1	34	51.2	107	117	0	37	38
2015	12	13	15	42	22	0.643	-0.148	3.947	0.01	0.007	0	29.7	33.1	63.6	106	115	0	37	38
2015	12	13	15	52	22	0.64	-0.157	3.947	0.01	0.007	0	28.8	32.7	71.8	104	114	0	37	38
2015	12	13	16	2	22	0.679	-0.138	3.947	0.01	0.007	0	28	31.8	68.8	103	112	0	38	38
2015	12	13	16	12	22	0.659	-0.144	3.944	0.013	0.01	0	28.4	31.8	67.9	103	113	0	37	39
2015	12	13	16	22	22	0.673	-0.118	3.947	0.01	0.007	0	28.8	31.8	68.4	104	113	0	37	39
2015	12	13	16	32	22	0.636	-0.128	3.947	0.01	0.007	0	29.7	32.7	54.2	106	114	0	37	38
2015	12	13	16	42	22	0.679	-0.148	3.947	0.01	0.007	0	33.5	37.8	64.9	116	126	0	38	38
2015	12	13	16	52	22	0.663	-0.118	3.947	0.01	0.007	0	36.5	40	59.3	122	132	0	37	39
2015	12	13	17	2	22	0.64	-0.089	3.947	0.01	0.007	0	36.1	39.6	63.2	121	131	0	37	39
2015	12	13	17	12	22	0.676	-0.115	3.947	0.01	0.007	0	34.4	38.7	65.8	118	128	0	38	38
2015	12	13	17	22	22	0.686	-0.062	3.95	0.01	0.007	0	34	37.8	54.6	117	126	0	38	38
2015	12	13	17	32	22	0.659	-0.098	3.947	0.013	0.01	0	34	37	66.2	116	125	0	37	39
2015	12	13	17	42	22	0.63	-0.095	3.947	0.016	0.013	0	32.3	36.1	65.4	112	122	0	37	38
2015	12	13	17	52	22	0.653	-0.105	3.947	0.01	0.007	0	31.8	35.3	66.2	111	121	0	37	39
2015	12	13	18	2	22	0.663	-0.102	3.947	0.01	0.007	0	31	34.8	69.2	109	119	0	37	38
2015	12	13	18	12	22	0.659	-0.115	3.95	0.01	0.007	0	29.7	33.1	74.8	107	116	0	38	39
2015	12	13	18	22	22	0.682	-0.118	3.95	0.01	0.007	0	29.2	33.1	61.1	105	115	0	37	38
2015	12	13	18	32	22	0.643	-0.108	3.95	0.01	0.007	0	28.4	32.7	56.8	104	114	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	18	42	22	0.659	-0.121	3.95	0.01	0.007	0	28.4	32.3	70.1	103	113	0	37	38
2015	12	13	18	52	22	0.63	-0.105	3.95	0.01	0.007	0	27.5	32.3	74.8	102	113	0	38	38
2015	12	13	19	2	22	0.633	-0.131	3.95	0.01	0.007	0	28.4	31.4	74.8	102	112	0	36	39
2015	12	13	19	12	22	0.656	-0.105	3.95	0.01	0.007	0	28	32.3	74.8	103	113	0	38	38
2015	12	13	19	22	22	0.64	-0.092	3.947	0.01	0.007	0	27.5	31.4	74.8	102	111	0	38	38
2015	12	13	19	32	22	0.643	-0.128	3.947	0.01	0.007	0	27.5	31.4	71.8	101	111	0	37	38
2015	12	13	19	42	22	0.689	-0.112	3.953	0.01	0.007	0	28.4	31.4	53.3	103	112	0	37	39
2015	12	13	19	52	22	0.63	-0.108	3.95	0.01	0.007	0	28	31.4	57.6	102	111	0	37	38
2015	12	13	20	2	22	0.643	-0.085	3.953	0.013	0.01	0	28	30.5	53.8	102	110	0	37	39
2015	12	13	20	12	22	0.682	-0.098	3.953	0.01	0.007	0	28	31.8	51.6	103	112	0	38	38
2015	12	13	20	22	22	0.712	-0.082	3.953	0.01	0.007	0	28.4	32.3	52.5	103	113	0	37	38
2015	12	13	20	32	22	0.656	-0.151	3.95	0.01	0.007	0	27.5	31.4	70.1	101	111	0	37	38
2015	12	13	20	42	22	0.659	-0.125	3.95	0.01	0.007	0	27.5	31	75.7	101	111	0	37	39
2015	12	13	20	52	22	0.653	-0.128	3.95	0.01	0.007	0	27.1	31	75.3	100	110	0	37	38
2015	12	13	21	2	22	0.656	-0.108	3.95	0.01	0.007	0	26.7	30.1	75.3	99	109	0	37	39
2015	12	13	21	12	22	0.65	-0.141	3.95	0.01	0.007	0	26.7	30.5	75.7	99	109	0	37	38
2015	12	13	21	22	22	0.659	-0.089	3.95	0.01	0.007	0	27.1	31	75.3	100	110	0	37	38
2015	12	13	21	32	22	0.63	-0.092	3.95	0.01	0.007	0	26.2	30.1	75.7	98	108	0	37	38
2015	12	13	21	42	22	0.63	-0.141	3.95	0.01	0.007	0	26.2	30.1	76.1	97	108	0	36	38
2015	12	13	21	52	22	0.65	-0.135	3.95	0.01	0.007	0	26.2	29.7	75.7	98	107	0	37	38
2015	12	13	22	2	22	0.646	-0.102	3.95	0.01	0.007	0	26.7	31	75.7	100	110	0	38	38
2015	12	13	22	12	22	0.636	-0.118	3.95	0.01	0.007	0	26.2	30.5	74.4	99	109	0	38	38
2015	12	13	22	22	22	0.64	-0.118	3.95	0.01	0.007	0	25.8	29.7	74.8	97	107	0	37	38
2015	12	13	22	32	22	0.63	-0.092	3.95	0.01	0.007	0	26.2	29.7	72.2	98	108	0	37	39
2015	12	13	22	42	22	0.643	-0.102	3.95	0.01	0.007	0	25.4	29.2	74.8	96	106	0	37	38
2015	12	13	22	52	22	0.65	-0.125	3.95	0.01	0.007	0	25.8	29.7	74.8	97	107	0	37	38
2015	12	13	23	2	22	0.65	-0.141	3.95	0.013	0.01	0	25.8	29.2	74.8	97	106	0	37	38
2015	12	13	23	12	22	0.63	-0.118	3.95	0.01	0.007	0	25.4	29.2	75.3	96	106	0	37	38
2015	12	13	23	22	22	0.659	-0.115	3.95	0.01	0.007	0	24.9	29.2	74.8	96	106	0	38	38
2015	12	13	23	32	22	0.65	-0.105	3.95	0.01	0.007	0	26.2	29.7	74.8	98	108	0	37	39
2015	12	13	23	42	22	0.633	-0.105	3.95	0.01	0.007	0	25.4	29.2	72.7	97	107	0	38	39
2015	12	13	23	52	22	0.659	-0.144	3.95	0.01	0.007	0	25.4	28.8	69.2	96	105	0	37	38
2015	12	14	0	2	22	0.689	-0.138	3.95	0.016	0.013	0	25.4	28.8	62.4	96	105	0	37	38
2015	12	14	0	12	22	0.643	-0.112	3.95	0.01	0.007	0	24.9	28.8	71.8	95	105	0	37	38
2015	12	14	0	22	22	0.659	-0.131	3.95	0.01	0.007	0	24.9	28.4	74.4	95	105	0	37	39
2015	12	14	0	32	22	0.653	-0.121	3.95	0.01	0.007	0	24.5	28.8	73.5	95	105	0	38	38
2015	12	14	0	42	22	0.656	-0.118	3.95	0.01	0.007	0	24.5	28.4	73.5	95	105	0	38	39
2015	12	14	0	52	22	0.659	-0.108	3.953	0.013	0.01	0	24.9	28.4	61.9	95	105	0	37	39
2015	12	14	1	2	22	0.656	-0.154	3.95	0.01	0.007	0	24.5	28.8	64.1	95	105	0	38	38
2015	12	14	1	12	22	0.682	-0.135	3.953	0.01	0.007	0	24.5	28.4	55.9	95	104	0	38	38
2015	12	14	1	22	22	0.666	-0.089	3.957	0.01	0.007	0	25.4	28.8	54.6	97	105	0	38	38
2015	12	14	1	32	22	0.633	-0.089	3.953	0.01	0.007	0	24.9	28.8	57.6	96	105	0	38	38
2015	12	14	1	42	22	0.712	-0.108	3.953	0.01	0.007	0	25.8	28.8	54.6	97	105	0	37	38
2015	12	14	1	52	22	0.663	-0.079	3.957	0.016	0.013	0	26.2	28.8	52.9	98	106	0	37	39
2015	12	14	2	2	22	0.676	-0.131	3.957	0.01	0.007	0	26.7	29.7	53.8	99	107	0	37	38
2015	12	14	2	12	22	0.623	-0.105	3.957	0.01	0.007	0	26.7	30.1	53.8	99	108	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	2	22	22	0.656	-0.118	3.953	0.013	0.01	0	25.4	29.2	55.5	97	106	0	38	38
2015	12	14	2	32	22	0.679	-0.112	3.957	0.01	0.007	0	25.4	28.4	53.3	97	105	0	38	39
2015	12	14	2	42	22	0.679	-0.085	3.96	0.01	0.007	0	25.8	29.2	53.3	97	106	0	37	38
2015	12	14	2	52	22	0.682	-0.092	3.957	0.01	0.007	0	26.2	29.2	51.6	98	106	0	37	38
2015	12	14	3	2	22	0.696	-0.112	3.96	0.01	0.007	0	26.2	29.2	53.3	98	106	0	37	38
2015	12	14	3	12	22	0.663	-0.105	3.957	0.01	0.007	0	25.4	28.8	55	97	105	0	38	38
2015	12	14	3	22	22	0.669	-0.072	3.957	0.01	0.007	0	26.2	28.4	54.2	98	105	0	37	39
2015	12	14	3	32	22	0.656	-0.105	3.957	0.01	0.007	0	25.4	29.2	56.8	97	106	0	38	38
2015	12	14	3	42	22	0.666	-0.144	3.957	0.01	0.007	0	25.4	28.4	55.5	97	105	0	38	39
2015	12	14	3	52	22	0.659	-0.135	3.957	0.01	0.007	0	25.4	28.8	57.2	96	105	0	37	38
2015	12	14	4	2	22	0.676	-0.128	3.957	0.01	0.007	0	25.8	28.8	54.6	97	105	0	37	38
2015	12	14	4	12	22	0.646	-0.075	3.957	0.01	0.007	0	25.8	28.8	54.6	97	105	0	37	38
2015	12	14	4	22	22	0.686	-0.098	3.957	0.01	0.007	0	24.9	28.4	55.5	96	104	0	38	38
2015	12	14	4	32	22	0.656	-0.098	3.957	0.01	0.007	0	25.4	28.8	55	97	105	0	38	38
2015	12	14	4	42	22	0.666	-0.141	3.96	0.01	0.007	0	24.9	28.4	57.6	95	104	0	37	38
2015	12	14	4	52	22	0.627	-0.135	3.96	0.01	0.007	0	24.5	28	61.1	95	104	0	38	39
2015	12	14	5	2	22	0.666	-0.151	3.96	0.01	0.007	0	24.5	28	64.5	94	103	0	37	38
2015	12	14	5	12	22	0.692	-0.135	3.96	0.01	0.007	0	24.1	27.5	70.5	93	103	0	37	39
2015	12	14	5	22	22	0.666	-0.105	3.96	0.013	0.01	0	24.5	27.5	64.1	94	103	0	37	39
2015	12	14	5	32	22	0.627	-0.154	3.957	0.01	0.007	0	24.5	28	60.6	94	103	0	37	38
2015	12	14	5	42	22	0.65	-0.141	3.96	0.013	0.01	0	24.1	28	58	94	103	0	38	38
2015	12	14	5	52	22	0.666	-0.138	3.96	0.01	0.007	0	24.5	28	64.1	94	103	0	37	38
2015	12	14	6	2	22	0.646	-0.131	3.96	0.01	0.007	0	23.6	28	66.7	93	103	0	38	38
2015	12	14	6	12	22	0.64	-0.138	3.96	0.01	0.007	0	26.7	29.7	63.6	99	108	0	37	39
2015	12	14	6	22	22	0.614	-0.115	3.96	0.01	0.007	0	24.5	28.4	68.8	95	105	0	38	39
2015	12	14	6	32	22	0.653	-0.121	3.96	0.01	0.007	0	23.6	28	70.5	93	103	0	38	38
2015	12	14	6	42	22	0.676	-0.092	3.963	0.013	0.01	0	24.5	28	52	95	103	0	38	38
2015	12	14	6	52	22	0.646	-0.118	3.96	0.01	0.007	0	24.1	28	54.2	94	103	0	38	38
2015	12	14	7	2	22	0.676	-0.157	3.96	0.01	0.007	0	24.9	28.4	58	95	104	0	37	38
2015	12	14	7	12	22	0.63	-0.115	3.96	0.01	0.007	0	24.5	28.4	64.9	94	104	0	37	38
2015	12	14	7	22	22	0.636	-0.105	3.96	0.01	0.007	0	24.5	28.4	62.8	94	104	0	37	38
2015	12	14	7	32	22	0.633	-0.131	3.96	0.01	0.007	0	23.6	28	62.8	93	103	0	38	38
2015	12	14	7	42	22	0.633	-0.118	3.96	0.01	0.007	0	24.5	28.4	59.3	95	104	0	38	38
2015	12	14	7	52	22	0.705	-0.075	3.96	0.01	0.007	0	25.4	28.4	50.7	96	104	0	37	38
2015	12	14	8	2	22	0.738	-0.092	3.96	0.01	0.007	0	27.1	30.5	50.7	101	109	0	38	38
2015	12	14	8	12	22	0.686	-0.082	3.96	0.01	0.007	0	29.2	32.3	50.3	106	114	0	38	39
2015	12	14	8	22	22	0.679	-0.115	3.963	0.013	0.01	0	31.8	34.8	48.6	112	120	0	38	39
2015	12	14	8	32	22	0.692	-0.095	3.96	0.01	0.007	0	33.1	35.7	50.3	114	122	0	37	39
2015	12	14	8	42	22	0.712	-0.118	3.96	0.01	0.007	0	31	34.4	50.3	110	119	0	38	39
2015	12	14	8	52	22	0.725	-0.105	3.963	0.013	0.01	0	37	40	49	122	131	0	36	38
2015	12	14	9	2	22	0.692	-0.102	3.967	0.013	0.01	0	31.8	34.8	51.2	111	119	0	37	38
2015	12	14	9	12	22	0.659	-0.079	3.967	0.01	0.007	0	32.7	35.3	49.5	112	120	0	36	38
2015	12	14	9	22	22	0.682	-0.092	3.967	0.01	0.007	0	31	34.4	51.2	109	118	0	37	38
2015	12	14	9	32	22	0.653	-0.079	3.967	0.01	0.007	0	33.1	36.5	49.9	114	123	0	37	38
2015	12	14	9	42	22	0.722	-0.115	3.963	0.01	0.007	0	31.8	34.8	49	111	119	0	37	38
2015	12	14	9	52	22	0.686	-0.066	3.967	0.01	0.007	0	31.8	35.7	50.7	112	121	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	10	2	22	0.722	-0.085	3.967	0.01	0.007	0	32.7	35.3	51.6	113	121	0	37	39
2015	12	14	10	12	22	0.722	-0.089	3.97	0.01	0.007	0	32.3	35.3	52	112	120	0	37	38
2015	12	14	10	22	22	0.702	-0.105	3.967	0.01	0.007	0	32.7	36.1	48.6	114	122	0	38	38
2015	12	14	10	32	22	0.715	-0.128	3.97	0.016	0.013	0	32.7	36.1	49.5	114	122	0	38	38
2015	12	14	10	42	22	0.699	-0.105	3.967	0.01	0.007	0	33.1	35.7	49.9	114	122	0	37	39
2015	12	14	10	52	22	0.702	-0.098	3.967	0.013	0.01	0	33.1	36.5	51.2	115	123	0	38	38
2015	12	14	11	2	22	0.686	-0.066	3.967	0.013	0.01	0	32.3	35.7	49.9	112	121	0	37	38
2015	12	14	11	12	22	0.735	-0.072	3.97	0.01	0.007	0	31.4	34.4	51.2	110	118	0	37	38
2015	12	14	11	22	22	0.696	-0.066	3.967	0.01	0.007	0	31.8	34.8	51.2	111	119	0	37	38
2015	12	14	11	32	22	0.732	-0.085	3.967	0.01	0.007	0	31.4	34.8	49.9	111	119	0	38	38
2015	12	14	11	42	22	0.692	-0.098	3.973	0.01	0.007	0	31.4	34.4	49.9	110	118	0	37	38
2015	12	14	11	52	22	0.689	-0.105	3.97	0.01	0.007	0	32.3	34.8	50.3	112	120	0	37	39
2015	12	14	12	2	22	0.702	-0.082	3.97	0.01	0.007	0	32.3	34.8	49.9	112	119	0	37	38
2015	12	14	12	12	22	0.696	-0.092	3.97	0.01	0.007	0	31	34.8	50.3	110	119	0	38	38
2015	12	14	12	22	22	0.719	-0.098	3.973	0.01	0.007	0	31.4	34.4	50.7	110	118	0	37	38
2015	12	14	12	32	22	0.686	-0.082	3.973	0.013	0.01	0	31.4	34	50.3	110	118	0	37	39
2015	12	14	12	42	22	0.735	-0.108	3.97	0.01	0.007	0	30.5	32.7	50.3	108	115	0	37	39
2015	12	14	12	52	22	0.705	-0.079	3.967	0.013	0.01	0	30.5	34	49.9	108	117	0	37	38
2015	12	14	13	2	22	0.692	-0.079	3.97	0.01	0.007	0	30.5	33.1	51.6	108	116	0	37	39
2015	12	14	13	12	22	0.722	-0.092	3.973	0.01	0.007	0	32.7	36.1	51.2	114	122	0	38	38
2015	12	14	13	22	22	0.732	-0.115	3.97	0.01	0.007	0	31.4	34.8	50.3	111	119	0	38	38
2015	12	14	13	32	22	0.715	-0.066	3.967	0.01	0.007	0	31.4	34.4	49.9	110	118	0	37	38
2015	12	14	13	42	22	0.689	-0.112	3.97	0.01	0.007	0	30.1	33.1	51.2	107	116	0	37	39
2015	12	14	13	52	22	0.682	-0.089	3.97	0.01	0.007	0	29.7	31.8	50.7	106	113	0	37	39
2015	12	14	14	2	22	0.686	-0.092	3.97	0.01	0.007	0	29.2	32.3	52.5	105	113	0	37	38
2015	12	14	14	12	22	0.722	-0.079	3.967	0.01	0.007	0	28.4	31.4	50.7	104	112	0	38	39
2015	12	14	14	22	22	0.673	-0.102	3.967	0.013	0.01	0	28.8	31.8	50.7	104	112	0	37	38
2015	12	14	14	32	22	0.686	-0.105	3.963	0.01	0.007	0	28	31.4	50.7	102	111	0	37	38
2015	12	14	14	42	22	0.709	-0.059	3.967	0.01	0.007	0	28	30.5	52	103	110	0	38	39
2015	12	14	14	52	22	0.709	-0.108	3.967	0.01	0.007	0	29.2	31.8	51.2	105	112	0	37	38
2015	12	14	15	2	22	0.689	-0.075	3.967	0.01	0.007	0	29.7	32.7	50.7	106	114	0	37	38
2015	12	14	15	12	22	0.728	-0.102	3.963	0.01	0.007	0	29.2	32.3	51.6	105	113	0	37	38
2015	12	14	15	22	22	0.709	-0.128	3.963	0.013	0.01	0	29.2	32.3	50.7	106	113	0	38	38
2015	12	14	15	32	22	0.719	-0.118	3.963	0.01	0.007	0	28.8	31.4	51.6	104	112	0	37	39
2015	12	14	15	42	22	0.719	-0.105	3.963	0.01	0.007	0	28.8	32.3	50.7	105	112	0	38	37
2015	12	14	15	52	22	0.686	-0.075	3.963	0.01	0.007	0	28.8	31.4	52	105	112	0	38	39
2015	12	14	16	2	22	0.692	-0.085	3.963	0.01	0.007	0	28	31.4	52	103	111	0	38	38
2015	12	14	16	12	22	0.699	-0.128	3.963	0.01	0.007	0	27.1	30.1	52.9	100	108	0	37	38
2015	12	14	16	22	22	0.686	-0.072	3.963	0.01	0.007	0	27.1	29.7	50.7	100	108	0	37	39
2015	12	14	16	32	22	0.699	-0.085	3.963	0.01	0.007	0	27.1	29.7	51.6	100	107	0	37	38
2015	12	14	16	42	22	0.725	-0.102	3.96	0.01	0.007	0	27.1	29.7	49.9	100	107	0	37	38
2015	12	14	16	52	22	0.705	-0.115	3.96	0.01	0.007	0	27.5	30.1	47.3	101	108	0	37	38
2015	12	14	17	2	22	0.663	-0.092	3.96	0.01	0.007	0	27.1	30.1	50.3	100	109	0	37	39
2015	12	14	17	12	22	0.696	-0.062	3.963	0.01	0.007	0	27.1	30.1	51.2	100	108	0	37	38
2015	12	14	17	22	22	0.666	-0.102	3.96	0.01	0.007	0	26.7	29.2	51.2	99	107	0	37	39
2015	12	14	17	32	22	0.686	-0.102	3.963	0.01	0.007	0	26.7	29.2	50.7	99	107	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	17	42	22	0.699	-0.105	3.96	0.01	0.007	0	26.2	29.2	51.6	98	106	0	37	38
2015	12	14	17	52	22	0.65	-0.092	3.963	0.01	0.007	0	25.8	29.2	50.3	98	106	0	38	38
2015	12	14	18	2	22	0.663	-0.085	3.963	0.01	0.007	0	25.8	29.2	51.6	98	106	0	38	38
2015	12	14	18	12	22	0.712	-0.115	3.963	0.01	0.007	0	25.8	28.8	52	97	106	0	37	39
2015	12	14	18	22	22	0.705	-0.092	3.963	0.01	0.007	0	25.8	28.8	52	97	105	0	37	38
2015	12	14	18	32	22	0.682	-0.079	3.96	0.01	0.007	0	25.8	28.8	50.3	97	105	0	37	38
2015	12	14	18	42	22	0.692	-0.066	3.96	0.01	0.007	0	25.8	28.8	49.5	98	106	0	38	39
2015	12	14	18	52	22	0.679	-0.102	3.96	0.01	0.007	0	26.2	29.2	52	98	107	0	37	39
2015	12	14	19	2	22	0.659	-0.092	3.963	0.01	0.007	0	25.4	28.8	55.9	97	105	0	38	38
2015	12	14	19	12	22	0.673	-0.112	3.963	0.01	0.007	0	25.8	28.8	54.2	97	105	0	37	38
2015	12	14	19	22	22	0.64	-0.115	3.963	0.01	0.007	0	25.4	28.4	54.2	96	104	0	37	38
2015	12	14	19	32	22	0.699	-0.115	3.963	0.01	0.007	0	24.9	28	54.6	96	104	0	38	39
2015	12	14	19	42	22	0.646	-0.138	3.963	0.01	0.007	0	30.1	34	58.9	107	117	0	37	38
2015	12	14	19	52	22	0.659	-0.167	3.963	0.013	0.01	0	25.4	29.2	59.8	97	106	0	38	38
2015	12	14	20	2	22	0.686	-0.098	3.963	0.01	0.007	0	24.9	28.8	55	96	105	0	38	38
2015	12	14	20	12	22	0.692	-0.095	3.96	0.01	0.007	0	24.9	28.4	53.8	96	104	0	38	38
2015	12	14	20	22	22	0.676	-0.128	3.963	0.01	0.007	0	24.5	28	56.8	95	104	0	38	39
2015	12	14	20	32	22	0.666	-0.128	3.96	0.01	0.007	0	24.9	27.5	55.9	95	103	0	37	39
2015	12	14	20	42	22	0.669	-0.092	3.96	0.01	0.007	0	25.4	28	51.2	96	104	0	37	39
2015	12	14	20	52	22	0.692	-0.102	3.963	0.01	0.007	0	25.4	28	52	96	103	0	37	38
2015	12	14	21	2	22	0.712	-0.098	3.963	0.01	0.007	0	25.4	28	53.3	96	104	0	37	39
2015	12	14	21	12	22	0.699	-0.105	3.963	0.01	0.007	0	25.4	27.5	53.8	96	103	0	37	39
2015	12	14	21	22	22	0.702	-0.098	3.96	0.013	0.01	0	24.9	28.4	53.3	96	104	0	38	38
2015	12	14	21	32	22	0.64	-0.092	3.963	0.01	0.007	0	25.4	28	53.8	96	104	0	37	39
2015	12	14	21	42	22	0.692	-0.092	3.963	0.01	0.007	0	24.9	27.5	54.2	96	103	0	38	39
2015	12	14	21	52	22	0.653	-0.075	3.96	0.01	0.007	0	24.5	28.4	55.5	95	104	0	38	38
2015	12	14	22	2	22	0.656	-0.112	3.963	0.01	0.007	0	24.1	27.5	55.9	94	103	0	38	39
2015	12	14	22	12	22	0.63	-0.069	3.963	0.013	0.01	0	24.5	27.5	53.8	95	103	0	38	39
2015	12	14	22	22	22	0.673	-0.095	3.963	0.01	0.007	0	24.9	27.5	54.6	95	103	0	37	39
2015	12	14	22	32	22	0.65	-0.108	3.963	0.01	0.007	0	24.5	27.5	57.2	94	102	0	37	38
2015	12	14	22	42	22	0.633	-0.115	3.963	0.01	0.007	0	23.2	27.5	73.5	92	102	0	38	38
2015	12	14	22	52	22	0.633	-0.105	3.963	0.01	0.007	0	23.2	27.5	74.4	92	102	0	38	38
2015	12	14	23	2	22	0.64	-0.125	3.963	0.01	0.007	0	23.6	27.1	74.4	92	102	0	37	39
2015	12	14	23	12	22	0.64	-0.115	3.963	0.01	0.007	0	24.1	27.5	70.5	93	102	0	37	38
2015	12	14	23	22	22	0.636	-0.138	3.963	0.01	0.007	0	24.1	27.5	74	93	102	0	37	38
2015	12	14	23	32	22	0.65	-0.135	3.963	0.01	0.007	0	23.2	26.7	74	91	101	0	37	39
2015	12	14	23	42	22	0.65	-0.141	3.963	0.01	0.007	0	23.6	27.5	74	92	102	0	37	38
2015	12	14	23	52	22	0.659	-0.154	3.963	0.013	0.01	0	23.2	27.5	64.9	92	102	0	38	38
2015	12	15	0	2	22	0.64	-0.131	3.963	0.01	0.007	0	23.6	26.7	61.1	93	101	0	38	39
2015	12	15	0	12	22	0.61	-0.118	3.963	0.01	0.007	0	23.2	27.1	66.2	92	102	0	38	39
2015	12	15	0	22	22	0.676	-0.108	3.963	0.01	0.007	0	24.5	27.1	55	94	102	0	37	39
2015	12	15	0	32	22	0.673	-0.144	3.963	0.01	0.007	0	23.6	27.1	53.3	93	101	0	38	38
2015	12	15	0	42	22	0.663	-0.121	3.963	0.01	0.007	0	24.1	27.1	58.5	93	102	0	37	39
2015	12	15	0	52	22	0.643	-0.089	3.963	0.01	0.007	0	23.6	27.1	53.3	93	101	0	38	38
2015	12	15	1	2	22	0.673	-0.102	3.963	0.01	0.007	0	24.1	27.1	52.9	93	101	0	37	38
2015	12	15	1	12	22	0.62	-0.118	3.963	0.01	0.007	0	23.6	26.7	69.7	92	101	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	1	22	22	0.653	-0.092	3.963	0.01	0.007	0	23.6	27.1	55	93	101	0	38	38
2015	12	15	1	32	22	0.623	-0.131	3.963	0.01	0.007	0	23.6	27.5	53.3	92	101	0	37	37
2015	12	15	1	42	22	0.64	-0.131	3.963	0.01	0.007	0	24.1	27.1	61.5	93	102	0	37	39
2015	12	15	1	52	22	0.64	-0.148	3.963	0.01	0.007	0	22.8	27.1	71.8	91	101	0	38	38
2015	12	15	2	2	22	0.61	-0.105	3.963	0.01	0.007	0	23.2	26.7	75.3	91	101	0	37	39
2015	12	15	2	12	22	0.636	-0.135	3.963	0.01	0.007	0	23.2	26.2	65.8	91	100	0	37	39
2015	12	15	2	22	22	0.64	-0.128	3.963	0.01	0.007	0	23.6	26.7	64.1	92	101	0	37	39
2015	12	15	2	32	22	0.646	-0.112	3.963	0.01	0.007	0	23.2	26.2	64.1	91	100	0	37	39
2015	12	15	2	42	22	0.633	-0.098	3.963	0.01	0.007	0	23.6	26.7	62.4	92	101	0	37	39
2015	12	15	2	52	22	0.666	-0.079	3.963	0.01	0.007	0	23.6	26.7	55.9	93	101	0	38	39
2015	12	15	3	2	22	0.65	-0.095	3.963	0.01	0.007	0	23.6	27.1	55	92	101	0	37	38
2015	12	15	3	12	22	0.689	-0.082	3.963	0.01	0.007	0	23.6	27.1	53.8	93	101	0	38	38
2015	12	15	3	22	22	0.669	-0.089	3.963	0.01	0.007	0	23.6	27.1	55.5	93	101	0	38	38
2015	12	15	3	32	22	0.659	-0.102	3.963	0.01	0.007	0	24.1	27.1	54.6	93	101	0	37	38
2015	12	15	3	42	22	0.689	-0.115	3.963	0.01	0.007	0	23.6	26.7	52.9	93	101	0	38	39
2015	12	15	3	52	22	0.715	-0.075	3.963	0.01	0.007	0	24.1	26.7	50.3	94	101	0	38	39
2015	12	15	4	2	22	0.709	-0.102	3.963	0.01	0.007	0	24.5	27.5	51.2	95	102	0	38	38
2015	12	15	4	12	22	0.686	-0.066	3.963	0.01	0.007	0	25.4	28.4	49.9	96	104	0	37	38
2015	12	15	4	22	22	0.696	-0.092	3.963	0.01	0.007	0	24.9	28	50.3	96	103	0	38	38
2015	12	15	4	32	22	0.699	-0.075	3.963	0.01	0.007	0	24.9	28.4	51.6	96	104	0	38	38
2015	12	15	4	42	22	0.709	-0.108	3.963	0.01	0.007	0	24.9	28	50.3	95	103	0	37	38
2015	12	15	4	52	22	0.659	-0.062	3.963	0.01	0.007	0	25.8	28.8	51.2	97	105	0	37	38
2015	12	15	5	2	22	0.65	-0.105	3.963	0.01	0.007	0	24.5	28	52.5	95	104	0	38	39
2015	12	15	5	12	22	0.689	-0.092	3.963	0.01	0.007	0	25.4	28	52.5	96	104	0	37	39
2015	12	15	5	22	22	0.636	-0.115	3.963	0.01	0.007	0	28.8	32.3	61.9	105	114	0	38	39
2015	12	15	5	32	22	0.636	-0.108	3.963	0.013	0.01	0	27.1	31.4	65.8	101	112	0	38	39
2015	12	15	5	42	22	0.653	-0.128	3.963	0.01	0.007	0	25.4	28.4	59.3	96	105	0	37	39
2015	12	15	5	52	22	0.673	-0.108	3.963	0.01	0.007	0	24.9	28.4	57.6	96	104	0	38	38
2015	12	15	6	2	22	0.676	-0.105	3.963	0.01	0.007	0	24.1	26.7	58	93	101	0	37	39
2015	12	15	6	12	22	0.636	-0.144	3.963	0.01	0.007	0	23.2	26.7	64.9	92	101	0	38	39
2015	12	15	6	22	22	0.646	-0.066	3.963	0.01	0.007	0	23.6	27.1	56.8	93	101	0	38	38
2015	12	15	6	32	22	0.663	-0.072	3.963	0.01	0.007	0	23.6	27.1	56.3	93	101	0	38	38
2015	12	15	6	42	22	0.696	-0.128	3.963	0.013	0.01	0	24.1	27.1	56.3	93	102	0	37	39
2015	12	15	6	52	22	0.676	-0.102	3.963	0.01	0.007	0	23.6	27.5	54.6	93	102	0	38	38
2015	12	15	7	2	22	0.64	-0.112	3.963	0.01	0.007	0	24.1	27.1	57.2	93	102	0	37	39
2015	12	15	7	12	22	0.643	-0.105	3.963	0.01	0.007	0	23.2	26.7	60.2	92	101	0	38	39
2015	12	15	7	22	22	0.643	-0.115	3.963	0.01	0.007	0	23.2	26.7	60.6	91	101	0	37	39
2015	12	15	7	32	22	0.669	-0.082	3.963	0.01	0.007	0	23.2	26.7	54.6	92	100	0	38	38
2015	12	15	7	42	22	0.607	-0.118	3.963	0.01	0.007	0	23.6	26.7	61.5	92	100	0	37	38
2015	12	15	7	52	22	0.659	-0.092	3.967	0.01	0.007	0	23.2	27.1	53.8	92	101	0	38	38
2015	12	15	8	2	22	0.666	-0.105	3.967	0.01	0.007	0	24.1	26.7	55.5	93	101	0	37	39
2015	12	15	8	12	22	0.709	-0.128	3.967	0.01	0.007	0	23.2	26.7	52	92	101	0	38	39
2015	12	15	8	22	22	0.696	-0.118	3.967	0.01	0.007	0	24.1	27.1	52	93	101	0	37	38
2015	12	15	8	32	22	0.656	-0.115	3.967	0.01	0.007	0	24.1	27.1	52	93	101	0	37	38
2015	12	15	8	42	22	0.712	-0.075	3.97	0.01	0.007	0	24.5	27.1	52	94	101	0	37	38
2015	12	15	8	52	22	0.715	-0.082	3.967	0.01	0.007	0	24.5	27.1	51.2	95	102	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	9	2	22	0.686	-0.075	3.97	0.01	0.007	0	24.9	27.1	52.5	95	102	0	37	39
2015	12	15	9	12	22	0.659	-0.112	3.967	0.01	0.007	0	24.9	28	51.6	96	104	0	38	39
2015	12	15	9	22	22	0.65	-0.062	3.97	0.013	0.01	0	25.4	28.4	53.8	97	104	0	38	38
2015	12	15	9	32	22	0.741	-0.102	3.97	0.01	0.007	0	26.7	29.2	50.7	100	107	0	38	39
2015	12	15	9	42	22	0.712	-0.105	3.967	0.01	0.007	0	29.7	32.3	50.3	106	114	0	37	39
2015	12	15	9	52	22	0.699	-0.115	3.967	0.01	0.007	0	31.8	34.8	50.7	111	119	0	37	38
2015	12	15	10	2	22	0.741	-0.125	3.97	0.01	0.007	0	32.3	35.7	49.5	113	121	0	38	38
2015	12	15	10	12	22	0.663	-0.112	3.97	0.01	0.007	0	34.4	37.8	49.9	117	126	0	37	38
2015	12	15	10	22	22	0.682	-0.105	3.97	0.01	0.007	0	35.7	39.6	49.5	121	130	0	38	38
2015	12	15	10	32	22	0.673	-0.095	3.97	0.01	0.007	0	35.3	38.7	51.2	120	129	0	38	39
2015	12	15	10	42	22	0.643	-0.079	3.973	0.01	0.007	0	37	39.6	49.5	123	131	0	37	39
2015	12	15	10	52	22	0.646	-0.075	3.973	0.01	0.007	0	36.1	39.6	49.5	122	131	0	38	39
2015	12	15	11	2	22	0.666	-0.069	3.973	0.013	0.01	0	36.5	40	46.9	123	131	0	38	38
2015	12	15	11	12	22	0.676	-0.095	3.973	0.01	0.007	0	36.5	40	49.9	123	132	0	38	39
2015	12	15	11	22	22	0.689	-0.089	3.973	0.01	0.007	0	36.5	39.6	50.3	122	131	0	37	39
2015	12	15	11	32	22	0.692	-0.105	3.973	0.01	0.007	0	36.1	39.1	49.9	121	130	0	37	39
2015	12	15	11	42	22	0.682	-0.105	3.973	0.016	0.013	0	34.8	38.3	49	119	127	0	38	38
2015	12	15	11	52	22	0.663	-0.095	3.973	0.01	0.007	0	34.4	37.8	49	118	127	0	38	39
2015	12	15	12	2	22	0.663	-0.128	3.973	0.013	0.01	0	33.1	36.5	49.9	115	124	0	38	39
2015	12	15	12	12	22	0.656	-0.033	3.97	0.01	0.007	0	33.1	35.7	51.6	115	122	0	38	39
2015	12	15	12	22	22	0.702	-0.089	3.97	0.01	0.007	0	33.1	37	50.3	115	124	0	38	38
2015	12	15	12	32	22	0.702	-0.098	3.973	0.01	0.007	0	33.5	36.5	51.2	115	124	0	37	39
2015	12	15	12	42	22	0.679	-0.102	3.973	0.013	0.01	0	31	34.8	51.2	110	119	0	38	38
2015	12	15	12	52	22	0.702	-0.075	3.97	0.01	0.007	0	31.4	34.4	49.9	110	118	0	37	38
2015	12	15	13	2	22	0.686	-0.121	3.97	0.016	0.013	0	31	34.4	50.3	109	118	0	37	38
2015	12	15	13	12	22	0.666	-0.095	3.973	0.013	0.01	0	30.1	33.1	51.6	108	116	0	38	39
2015	12	15	13	22	22	0.669	-0.089	3.973	0.01	0.007	0	29.7	32.7	52.5	106	114	0	37	38
2015	12	15	13	32	22	0.699	-0.089	3.97	0.01	0.007	0	29.2	32.7	50.7	106	114	0	38	38
2015	12	15	13	42	22	0.702	-0.092	3.97	0.01	0.007	0	28.4	31.8	49.9	104	112	0	38	38
2015	12	15	13	52	22	0.686	-0.098	3.97	0.01	0.007	0	28.8	31	52.5	103	111	0	36	39
2015	12	15	14	2	22	0.663	-0.102	3.97	0.01	0.007	0	27.5	31	52.5	102	111	0	38	39
2015	12	15	14	12	22	0.699	-0.089	3.97	0.01	0.007	0	27.1	30.1	49.5	101	109	0	38	39
2015	12	15	14	22	22	0.705	-0.062	3.967	0.01	0.007	0	28.4	31.4	51.2	103	111	0	37	38
2015	12	15	14	32	22	0.686	-0.089	3.967	0.01	0.007	0	28	31	51.2	102	110	0	37	38
2015	12	15	14	42	22	0.692	-0.095	3.967	0.01	0.007	0	27.5	30.1	50.3	101	109	0	37	39
2015	12	15	14	52	22	0.715	-0.062	3.967	0.01	0.007	0	27.5	31	51.2	102	110	0	38	38
2015	12	15	15	2	22	0.653	-0.089	3.963	0.01	0.007	0	27.1	30.1	52	101	109	0	38	39
2015	12	15	15	12	22	0.709	-0.112	3.963	0.01	0.007	0	27.1	30.1	51.6	101	109	0	38	39
2015	12	15	15	22	22	0.673	-0.089	3.963	0.01	0.007	0	26.7	30.1	51.6	100	109	0	38	39
2015	12	15	15	32	22	0.659	-0.089	3.963	0.01	0.007	0	26.7	29.7	54.6	99	107	0	37	38
2015	12	15	15	42	22	0.686	-0.085	3.963	0.013	0.01	0	26.2	29.2	52.9	99	106	0	38	38
2015	12	15	15	52	22	0.669	-0.102	3.963	0.01	0.007	0	25.8	28.4	52.9	98	105	0	38	39
2015	12	15	16	2	22	0.686	-0.131	3.963	0.01	0.007	0	24.5	27.5	54.6	95	103	0	38	39
2015	12	15	16	12	22	0.676	-0.112	3.963	0.01	0.007	0	24.9	28.4	55.5	95	104	0	37	38
2015	12	15	16	22	22	0.653	-0.108	3.963	0.013	0.01	0	24.5	27.5	55.5	95	103	0	38	39
2015	12	15	16	32	22	0.709	-0.125	3.963	0.01	0.007	0	24.5	27.5	54.6	95	102	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	16	42	22	0.679	-0.118	3.96	0.01	0.007	0	24.1	27.1	52.5	94	102	0	38	39
2015	12	15	16	52	22	0.696	-0.082	3.963	0.01	0.007	0	24.5	27.5	52.9	94	102	0	37	38
2015	12	15	17	2	22	0.696	-0.092	3.96	0.01	0.007	0	24.9	28	51.6	96	103	0	38	38
2015	12	15	17	12	22	0.682	-0.082	3.957	0.013	0.01	0	25.4	28	50.7	96	104	0	37	39
2015	12	15	17	22	22	0.679	-0.115	3.96	0.01	0.007	0	24.9	28	51.2	96	104	0	38	39
2015	12	15	17	32	22	0.663	-0.092	3.96	0.01	0.007	0	25.4	28.4	50.7	97	105	0	38	39
2015	12	15	17	42	22	0.643	-0.098	3.96	0.01	0.007	0	24.9	28.4	48.6	96	104	0	38	38
2015	12	15	17	52	22	0.666	-0.079	3.963	0.01	0.007	0	24.9	28	51.2	96	104	0	38	39
2015	12	15	18	2	22	0.682	-0.075	3.96	0.013	0.01	0	25.4	28.8	49.9	97	105	0	38	38
2015	12	15	18	12	22	0.669	-0.056	3.96	0.01	0.007	0	26.2	29.2	50.7	98	106	0	37	38
2015	12	15	18	22	22	0.676	-0.095	3.96	0.01	0.007	0	25.4	28.4	50.3	97	105	0	38	39
2015	12	15	18	32	22	0.686	-0.075	3.96	0.01	0.007	0	25.8	28	49.9	97	104	0	37	39
2015	12	15	18	42	22	0.646	-0.151	3.96	0.01	0.007	0	24.1	27.5	57.6	93	103	0	37	39
2015	12	15	18	52	22	0.643	-0.138	3.96	0.01	0.007	0	24.1	27.1	64.5	93	102	0	37	39
2015	12	15	19	2	22	0.676	-0.131	3.96	0.01	0.007	0	24.9	28	56.3	95	104	0	37	39
2015	12	15	19	12	22	0.656	-0.092	3.96	0.01	0.007	0	24.9	28	53.8	96	104	0	38	39
2015	12	15	19	22	22	0.659	-0.095	3.96	0.01	0.007	0	24.5	28	51.6	95	103	0	38	38
2015	12	15	19	32	22	0.669	-0.098	3.96	0.01	0.007	0	24.9	28.4	52	96	104	0	38	38
2015	12	15	19	42	22	0.656	-0.085	3.96	0.01	0.007	0	25.8	28.4	52.9	97	105	0	37	39
2015	12	15	19	52	22	0.65	-0.128	3.96	0.01	0.007	0	24.5	28.4	57.6	95	104	0	38	38
2015	12	15	20	2	22	0.653	-0.164	3.96	0.01	0.007	0	24.9	28.4	66.2	95	104	0	37	38
2015	12	15	20	12	22	0.63	-0.102	3.96	0.01	0.007	0	25.4	28	56.3	96	104	0	37	39
2015	12	15	20	22	22	0.636	-0.098	3.96	0.01	0.007	0	25.4	28.4	54.6	96	105	0	37	39
2015	12	15	20	32	22	0.656	-0.151	3.96	0.01	0.007	0	24.1	27.5	60.6	94	103	0	38	39
2015	12	15	20	42	22	0.653	-0.115	3.96	0.01	0.007	0	24.5	27.5	57.2	94	102	0	37	38
2015	12	15	20	52	22	0.656	-0.125	3.96	0.01	0.007	0	23.6	27.1	60.2	93	102	0	38	39
2015	12	15	21	2	22	0.673	-0.108	3.96	0.01	0.007	0	23.6	26.7	52	93	101	0	38	39
2015	12	15	21	12	22	0.702	-0.079	3.96	0.01	0.007	0	24.1	26.7	52	93	101	0	37	39
2015	12	15	21	22	22	0.712	-0.085	3.96	0.01	0.007	0	23.6	27.1	51.6	93	101	0	38	38
2015	12	15	21	32	22	0.689	-0.082	3.96	0.01	0.007	0	23.6	27.1	51.2	93	101	0	38	38
2015	12	15	21	42	22	0.689	-0.102	3.96	0.01	0.007	0	23.6	26.7	52	93	101	0	38	39
2015	12	15	21	52	22	0.696	-0.118	3.957	0.01	0.007	0	24.1	27.5	50.3	94	102	0	38	38
2015	12	15	22	2	22	0.702	-0.095	3.957	0.01	0.007	0	24.9	28	50.3	96	103	0	38	38
2015	12	15	22	12	22	0.676	-0.075	3.963	0.013	0.01	0	24.9	27.5	49.9	95	103	0	37	39
2015	12	15	22	22	22	0.692	-0.085	3.96	0.01	0.007	0	25.4	28.4	49	97	105	0	38	39
2015	12	15	22	32	22	0.722	-0.075	3.96	0.01	0.007	0	25.8	28	49.9	97	104	0	37	39
2015	12	15	22	42	22	0.663	-0.108	3.96	0.01	0.007	0	24.5	28	51.2	95	103	0	38	38
2015	12	15	22	52	22	0.653	-0.135	3.96	0.01	0.007	0	24.1	28	55.5	94	103	0	38	38
2015	12	15	23	2	22	0.663	-0.115	3.96	0.01	0.007	0	24.1	27.1	53.8	93	102	0	37	39
2015	12	15	23	12	22	0.676	-0.089	3.96	0.01	0.007	0	24.1	27.1	51.2	94	101	0	38	38
2015	12	15	23	22	22	0.656	-0.075	3.957	0.01	0.007	0	24.1	27.5	50.7	94	102	0	38	38
2015	12	15	23	32	22	0.669	-0.049	3.96	0.01	0.007	0	24.1	27.1	49.5	94	102	0	38	39
2015	12	15	23	42	22	0.709	-0.098	3.96	0.01	0.007	0	24.5	27.5	50.7	95	103	0	38	39
2015	12	15	23	52	22	0.719	-0.089	3.96	0.01	0.007	0	27.5	30.1	50.7	101	109	0	37	39
2015	12	16	0	2	22	0.725	-0.108	3.96	0.01	0.007	0	25.4	28.4	49	97	105	0	38	39
2015	12	16	0	12	22	0.669	-0.095	3.96	0.01	0.007	0	27.1	30.1	50.7	101	109	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	0	22	22	0.669	-0.072	3.96	0.01	0.007	0	26.7	30.1	49.9	100	108	0	38	38
2015	12	16	0	32	22	0.614	-0.128	3.96	0.01	0.007	0	25.8	29.2	61.5	97	107	0	37	39
2015	12	16	0	42	22	0.656	-0.141	3.96	0.01	0.007	0	24.9	28.8	73.1	96	106	0	38	39
2015	12	16	0	52	22	0.617	-0.144	3.96	0.01	0.007	0	24.9	28.4	58	96	105	0	38	39
2015	12	16	1	2	22	0.653	-0.135	3.96	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	16	1	12	22	0.65	-0.157	3.96	0.01	0.007	0	24.1	27.5	76.5	93	103	0	37	39
2015	12	16	1	22	22	0.673	-0.138	3.96	0.01	0.007	0	23.2	26.7	64.5	92	101	0	38	39
2015	12	16	1	32	22	0.64	-0.154	3.96	0.01	0.007	0	34.8	38.7	72.7	118	129	0	37	39
2015	12	16	1	42	22	0.653	-0.164	3.96	0.01	0.007	0	25.4	28.8	61.5	97	106	0	38	39
2015	12	16	1	52	22	0.653	-0.161	3.96	0.01	0.007	0	23.2	26.7	57.6	92	100	0	38	38
2015	12	16	2	2	22	0.653	-0.144	3.96	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	16	2	12	22	0.614	-0.161	3.96	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	16	2	22	22	0.64	-0.141	3.96	0.01	0.007	0	23.6	28	69.7	93	103	0	38	38
2015	12	16	2	32	22	0.666	-0.131	3.96	0.01	0.007	0	26.2	29.7	75.3	99	108	0	38	39
2015	12	16	2	42	22	0.659	-0.184	3.96	0.01	0.007	0	27.5	31.4	76.1	101	111	0	37	38
2015	12	16	2	52	22	0.65	-0.105	3.96	0.01	0.007	0	24.5	28.8	76.1	95	105	0	38	38
2015	12	16	3	2	22	0.666	-0.138	3.96	0.01	0.007	0	22.8	27.1	76.5	91	101	0	38	38
2015	12	16	3	12	22	0.646	-0.125	3.96	0.01	0.007	0	23.6	28	61.5	93	103	0	38	38
2015	12	16	3	22	22	0.663	-0.157	3.96	0.01	0.007	0	23.2	27.1	76.5	91	101	0	37	38
2015	12	16	3	32	22	0.63	-0.128	3.96	0.01	0.007	0	23.2	27.5	76.5	92	102	0	38	38
2015	12	16	3	42	22	0.62	-0.125	3.96	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	16	3	52	22	0.633	-0.115	3.96	0.013	0.01	0	22.8	26.2	72.7	91	100	0	38	39
2015	12	16	4	2	22	0.653	-0.128	3.957	0.01	0.007	0	30.5	33.5	70.5	109	117	0	38	39
2015	12	16	4	12	22	0.62	-0.144	3.96	0.013	0.01	0	32.3	35.3	76.5	112	122	0	37	40
2015	12	16	4	22	22	0.65	-0.148	3.957	0.01	0.007	0	36.5	40	73.1	122	132	0	37	39
2015	12	16	4	32	22	0.623	-0.148	3.957	0.01	0.007	0	34.4	38.7	76.5	118	129	0	38	39
2015	12	16	4	42	22	0.633	-0.121	3.96	0.01	0.007	0	30.5	34	76.5	109	118	0	38	39
2015	12	16	4	52	22	0.653	-0.108	3.957	0.01	0.007	0	29.7	34	76.5	107	118	0	38	39
2015	12	16	5	2	22	0.663	-0.125	3.96	0.01	0.007	0	25.8	29.7	77	98	108	0	38	39
2015	12	16	5	12	22	0.623	-0.125	3.957	0.01	0.007	0	24.1	28.4	76.1	95	105	0	39	39
2015	12	16	5	22	22	0.62	-0.144	3.957	0.013	0.01	0	24.5	28.4	76.5	95	105	0	38	39
2015	12	16	5	32	22	0.617	-0.141	3.957	0.01	0.007	0	26.2	30.1	76.5	98	108	0	37	38
2015	12	16	5	42	22	0.663	-0.151	3.957	0.01	0.007	0	26.2	30.1	76.1	99	109	0	38	39
2015	12	16	5	52	22	0.636	-0.121	3.957	0.01	0.007	0	25.4	29.2	76.5	97	107	0	38	39
2015	12	16	6	2	22	0.646	-0.092	3.957	0.01	0.007	0	30.5	34.8	75.7	109	119	0	38	38
2015	12	16	6	12	22	0.646	-0.102	3.957	0.01	0.007	0	24.9	28.4	75.7	96	105	0	38	39
2015	12	16	6	22	22	0.636	-0.108	3.957	0.01	0.007	0	23.6	27.5	75.7	93	103	0	38	39
2015	12	16	6	32	22	0.636	-0.121	3.957	0.01	0.007	0	23.2	27.5	76.1	92	102	0	38	38
2015	12	16	6	42	22	0.65	-0.138	3.957	0.01	0.007	0	22.8	26.7	68.8	91	101	0	38	39
2015	12	16	6	52	22	0.65	-0.112	3.957	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	16	7	2	22	0.636	-0.112	3.957	0.01	0.007	0	22.8	26.2	75.7	91	100	0	38	39
2015	12	16	7	12	22	0.614	-0.128	3.957	0.01	0.007	0	22.4	26.2	71.8	90	100	0	38	39
2015	12	16	7	22	22	0.623	-0.125	3.957	0.013	0.01	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	16	7	32	22	0.643	-0.115	3.96	0.013	0.01	0	22.8	26.2	75.3	90	100	0	37	39
2015	12	16	7	42	22	0.627	-0.148	3.957	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	16	7	52	22	0.653	-0.131	3.957	0.01	0.007	0	22.4	26.7	75.7	90	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	8	2	22	0.627	-0.112	3.957	0.01	0.007	0	22.4	26.2	75.7	90	100	0	38	39
2015	12	16	8	12	22	0.643	-0.148	3.957	0.01	0.007	0	21.9	26.2	75.3	90	100	0	39	39
2015	12	16	8	22	22	0.623	-0.131	3.96	0.013	0.01	0	22.8	26.2	75.7	91	100	0	38	39
2015	12	16	8	32	22	0.636	-0.125	3.957	0.01	0.007	0	22.4	26.7	70.5	90	100	0	38	38
2015	12	16	8	42	22	0.614	-0.125	3.96	0.01	0.007	0	22.8	27.1	74	91	102	0	38	39
2015	12	16	8	52	22	0.633	-0.121	3.96	0.013	0.01	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	16	9	2	22	0.633	-0.095	3.96	0.01	0.007	0	22.8	26.7	75.7	91	100	0	38	38
2015	12	16	9	12	22	0.656	-0.125	3.96	0.01	0.007	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	16	9	22	22	0.623	-0.102	3.96	0.01	0.007	0	22.8	26.7	75.3	90	100	0	37	38
2015	12	16	9	32	22	0.62	-0.115	3.96	0.01	0.007	0	22.4	26.7	74.4	90	100	0	38	38
2015	12	16	9	42	22	0.65	-0.148	3.96	0.01	0.007	0	22.4	25.8	75.3	89	99	0	37	39
2015	12	16	9	52	22	0.633	-0.157	3.963	0.01	0.007	0	21.9	25.8	73.5	89	99	0	38	39
2015	12	16	10	2	22	0.623	-0.167	3.963	0.01	0.007	0	22.4	26.7	74.4	90	100	0	38	38
2015	12	16	10	12	22	0.64	-0.121	3.96	0.01	0.007	0	22.4	25.8	70.1	90	99	0	38	39
2015	12	16	10	22	22	0.65	-0.115	3.963	0.013	0.01	0	22.4	26.7	75.3	89	100	0	37	38
2015	12	16	10	32	22	0.623	-0.131	3.963	0.01	0.007	0	22.4	26.2	67.1	90	100	0	38	39
2015	12	16	10	42	22	0.581	-0.121	3.963	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	16	10	52	22	0.64	-0.118	3.963	0.01	0.007	0	21.9	25.8	71.4	89	99	0	38	39
2015	12	16	11	2	22	0.614	-0.128	3.963	0.013	0.01	0	22.8	25.8	63.6	90	99	0	37	39
2015	12	16	11	12	22	0.63	-0.115	3.963	0.013	0.01	0	22.4	25.8	71.8	90	99	0	38	39
2015	12	16	11	22	22	0.627	-0.125	3.963	0.01	0.007	0	21.9	25.8	75.7	89	99	0	38	39
2015	12	16	11	32	22	0.646	-0.144	3.963	0.013	0.01	0	22.4	25.8	74.4	89	99	0	37	39
2015	12	16	11	42	22	0.643	-0.138	3.963	0.01	0.007	0	21.9	25.8	75.7	89	99	0	38	39
2015	12	16	11	52	22	0.643	-0.128	3.963	0.01	0.007	0	22.4	26.2	75.7	89	99	0	37	38
2015	12	16	12	2	22	0.64	-0.135	3.963	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	16	12	12	22	0.604	-0.131	3.963	0.01	0.007	0	22.4	25.8	76.5	89	99	0	37	39
2015	12	16	12	22	22	0.617	-0.135	3.963	0.01	0.007	0	21.9	25.8	68.8	89	98	0	38	38
2015	12	16	12	32	22	0.63	-0.125	3.963	0.01	0.007	0	21.9	25.8	71	89	98	0	38	38
2015	12	16	12	42	22	0.597	-0.121	3.963	0.01	0.007	0	21.9	25.8	74.8	89	99	0	38	39
2015	12	16	12	52	22	0.636	-0.135	3.963	0.013	0.01	0	21.9	25.8	72.7	89	99	0	38	39
2015	12	16	13	2	22	0.62	-0.125	3.963	0.013	0.01	0	22.8	25.8	73.1	89	99	0	36	39
2015	12	16	13	12	22	0.63	-0.141	3.963	0.01	0.007	0	22.4	26.7	76.1	90	100	0	38	38
2015	12	16	13	22	22	0.627	-0.128	3.963	0.01	0.007	0	21.9	26.2	74	89	100	0	38	39
2015	12	16	13	32	22	0.604	-0.102	3.963	0.01	0.007	0	22.4	25.8	76.1	89	99	0	37	39
2015	12	16	13	42	22	0.604	-0.144	3.963	0.01	0.007	0	22.8	26.7	76.1	90	100	0	37	38
2015	12	16	13	52	22	0.614	-0.115	3.963	0.01	0.007	0	22.4	25.8	59.8	90	99	0	38	39
2015	12	16	14	2	22	0.604	-0.115	3.96	0.01	0.007	0	22.4	25.8	74	89	99	0	37	39
2015	12	16	14	12	22	0.627	-0.125	3.96	0.01	0.007	0	22.4	25.4	76.1	89	98	0	37	39
2015	12	16	14	22	22	0.614	-0.138	3.96	0.01	0.007	0	21.9	25.4	74	89	98	0	38	39
2015	12	16	14	32	22	0.61	-0.125	3.96	0.01	0.007	0	22.8	25.8	71	90	99	0	37	39
2015	12	16	14	42	22	0.65	-0.144	3.96	0.01	0.007	0	21.5	25.4	69.7	88	98	0	38	39
2015	12	16	14	52	22	0.594	-0.115	3.96	0.01	0.007	0	22.4	26.2	76.1	90	100	0	38	39
2015	12	16	15	2	22	0.623	-0.125	3.96	0.01	0.007	0	22.8	26.2	76.1	90	100	0	37	39
2015	12	16	15	12	22	0.617	-0.112	3.957	0.01	0.007	0	23.2	26.2	74.8	91	100	0	37	39
2015	12	16	15	22	22	0.61	-0.108	3.957	0.01	0.007	0	21.9	25.8	72.7	89	99	0	38	39
2015	12	16	15	32	22	0.63	-0.144	3.957	0.013	0.01	0	22.8	26.2	65.8	91	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	15	42	22	0.656	-0.108	3.957	0.013	0.01	0	22.4	26.2	72.2	90	99	0	38	38
2015	12	16	15	52	22	0.623	-0.141	3.957	0.013	0.01	0	21.5	25.4	70.1	87	98	0	37	39
2015	12	16	16	2	22	0.63	-0.125	3.957	0.01	0.007	0	21.1	24.9	76.1	87	97	0	38	39
2015	12	16	16	12	22	0.614	-0.128	3.957	0.01	0.007	0	21.1	24.9	75.3	87	97	0	38	39
2015	12	16	16	22	22	0.63	-0.141	3.957	0.01	0.007	0	21.5	25.8	75.7	88	98	0	38	38
2015	12	16	16	32	22	0.64	-0.118	3.957	0.01	0.007	0	21.9	25.8	75.7	88	98	0	37	38
2015	12	16	16	42	22	0.646	-0.121	3.957	0.01	0.007	0	21.5	25.4	76.1	88	98	0	38	39
2015	12	16	16	52	22	0.577	-0.102	3.957	0.01	0.007	0	21.5	25.4	76.5	88	98	0	38	39
2015	12	16	17	2	22	0.62	-0.144	3.957	0.016	0.013	0	24.1	28	76.5	94	104	0	38	39
2015	12	16	17	12	22	0.607	-0.112	3.957	0.01	0.007	0	21.9	25.4	76.1	88	98	0	37	39
2015	12	16	17	22	22	0.636	-0.102	3.957	0.01	0.007	0	21.5	25.4	76.1	88	98	0	38	39
2015	12	16	17	32	22	0.617	-0.121	3.957	0.01	0.007	0	21.9	25.4	76.1	89	98	0	38	39
2015	12	16	17	42	22	0.62	-0.135	3.957	0.01	0.007	0	21.9	25.4	75.7	88	98	0	37	39
2015	12	16	17	52	22	0.614	-0.135	3.957	0.013	0.01	0	21.9	26.2	76.1	89	99	0	38	38
2015	12	16	18	2	22	0.623	-0.115	3.957	0.01	0.007	0	22.4	25.4	76.1	89	98	0	37	39
2015	12	16	18	12	22	0.623	-0.128	3.957	0.01	0.007	0	21.1	25.4	74.4	88	98	0	39	39
2015	12	16	18	22	22	0.633	-0.128	3.957	0.01	0.007	0	27.5	32.3	75.7	102	113	0	38	38
2015	12	16	18	32	22	0.646	-0.125	3.957	0.01	0.007	0	22.8	27.1	75.7	91	101	0	38	38
2015	12	16	18	42	22	0.617	-0.112	3.957	0.01	0.007	0	21.9	25.8	75.7	89	99	0	38	39
2015	12	16	18	52	22	0.633	-0.138	3.957	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	16	19	2	22	0.65	-0.108	3.957	0.01	0.007	0	21.9	25.4	76.1	88	98	0	37	39
2015	12	16	19	12	22	0.617	-0.128	3.957	0.01	0.007	0	21.9	25.8	76.1	89	98	0	38	38
2015	12	16	19	22	22	0.61	-0.112	3.957	0.01	0.007	0	21.5	25.8	75.7	88	98	0	38	38
2015	12	16	19	32	22	0.63	-0.125	3.957	0.01	0.007	0	21.5	25.4	75.7	88	98	0	38	39
2015	12	16	19	42	22	0.623	-0.144	3.957	0.01	0.007	0	21.1	24.9	75.3	87	97	0	38	39
2015	12	16	19	52	22	0.61	-0.131	3.953	0.01	0.007	0	21.5	25.4	75.7	88	98	0	38	39
2015	12	16	20	2	22	0.597	-0.108	3.957	0.01	0.007	0	21.5	25.8	76.1	88	98	0	38	38
2015	12	16	20	12	22	0.633	-0.118	3.957	0.01	0.007	0	21.5	25.8	76.1	88	98	0	38	38
2015	12	16	20	22	22	0.63	-0.125	3.957	0.01	0.007	0	23.2	27.1	75.3	92	102	0	38	39
2015	12	16	20	32	22	0.633	-0.118	3.957	0.01	0.007	0	21.9	25.4	75.3	88	97	0	37	38
2015	12	16	20	42	22	0.62	-0.138	3.957	0.01	0.007	0	21.9	24.9	75.7	88	98	0	37	40
2015	12	16	20	52	22	0.627	-0.121	3.953	0.01	0.007	0	21.5	25.4	75.3	88	98	0	38	39
2015	12	16	21	2	22	0.607	-0.125	3.953	0.01	0.007	0	22.4	25.8	75.7	90	99	0	38	39
2015	12	16	21	12	22	0.6	-0.141	3.953	0.013	0.01	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	16	21	22	22	0.62	-0.128	3.957	0.01	0.007	0	21.1	25.4	75.7	87	97	0	38	38
2015	12	16	21	32	22	0.61	-0.112	3.953	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	16	21	42	22	0.62	-0.121	3.953	0.013	0.01	0	21.1	24.9	74.8	87	97	0	38	39
2015	12	16	21	52	22	0.633	-0.151	3.957	0.01	0.007	0	21.1	24.9	75.7	87	97	0	38	39
2015	12	16	22	2	22	0.614	-0.138	3.953	0.01	0.007	0	21.9	24.9	75.3	88	97	0	37	39
2015	12	16	22	12	22	0.62	-0.118	3.957	0.01	0.007	0	21.1	25.4	75.3	87	97	0	38	38
2015	12	16	22	22	22	0.627	-0.121	3.953	0.01	0.007	0	21.1	25.4	75.3	87	97	0	38	38
2015	12	16	22	32	22	0.659	-0.125	3.953	0.01	0.007	0	21.5	25.4	75.3	87	97	0	37	38
2015	12	16	22	42	22	0.587	-0.135	3.953	0.01	0.007	0	21.1	24.9	74.8	87	97	0	38	39
2015	12	16	22	52	22	0.607	-0.128	3.953	0.01	0.007	0	21.5	25.4	74.8	87	97	0	37	38
2015	12	16	23	2	22	0.633	-0.098	3.953	0.013	0.01	0	21.1	24.9	74.8	87	97	0	38	39
2015	12	16	23	12	22	0.62	-0.115	3.953	0.01	0.007	0	20.6	24.5	74.8	86	96	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	23	22	22	0.633	-0.115	3.953	0.016	0.013	0	20.6	24.9	74.8	87	97	0	39	39
2015	12	16	23	32	22	0.627	-0.128	3.953	0.01	0.007	0	21.1	24.9	74.4	88	97	0	39	39
2015	12	16	23	42	22	0.617	-0.112	3.953	0.01	0.007	0	21.1	24.9	74.8	87	97	0	38	39
2015	12	16	23	52	22	0.64	-0.125	3.953	0.01	0.007	0	21.1	24.9	74.8	87	97	0	38	39
2015	12	17	0	2	22	0.627	-0.089	3.953	0.013	0.01	0	21.1	24.5	74.4	87	96	0	38	39
2015	12	17	0	12	22	0.61	-0.131	3.953	0.01	0.007	0	21.5	25.4	74.4	88	98	0	38	39
2015	12	17	0	22	22	0.633	-0.128	3.953	0.01	0.007	0	21.5	25.4	74	88	97	0	38	38
2015	12	17	0	32	22	0.646	-0.115	3.953	0.01	0.007	0	21.9	24.9	74.4	88	97	0	37	39
2015	12	17	0	42	22	0.643	-0.121	3.953	0.01	0.007	0	21.1	24.9	74.4	87	97	0	38	39
2015	12	17	0	52	22	0.636	-0.105	3.953	0.01	0.007	0	21.1	24.9	74.4	87	97	0	38	39
2015	12	17	1	2	22	0.643	-0.112	3.953	0.01	0.007	0	21.1	24.9	74	87	97	0	38	39
2015	12	17	1	12	22	0.623	-0.154	3.953	0.01	0.007	0	21.1	24.5	74.4	87	96	0	38	39
2015	12	17	1	22	22	0.643	-0.128	3.953	0.01	0.007	0	21.1	24.9	73.5	87	97	0	38	39
2015	12	17	1	32	22	0.627	-0.135	3.953	0.01	0.007	0	21.1	24.9	73.5	87	97	0	38	39
2015	12	17	1	42	22	0.656	-0.125	3.953	0.01	0.007	0	21.1	24.5	73.5	87	96	0	38	39
2015	12	17	1	52	22	0.669	-0.138	3.953	0.01	0.007	0	21.1	24.1	74	86	96	0	37	40
2015	12	17	2	2	22	0.617	-0.115	3.953	0.01	0.007	0	21.1	25.4	73.5	87	97	0	38	38
2015	12	17	2	12	22	0.656	-0.138	3.953	0.01	0.007	0	21.1	25.4	73.1	87	97	0	38	38
2015	12	17	2	22	22	0.64	-0.138	3.953	0.01	0.007	0	21.1	24.5	74	87	96	0	38	39
2015	12	17	2	32	22	0.607	-0.128	3.953	0.01	0.007	0	21.5	24.9	74	88	97	0	38	39
2015	12	17	2	42	22	0.643	-0.144	3.953	0.01	0.007	0	21.1	24.5	73.1	87	96	0	38	39
2015	12	17	2	52	22	0.627	-0.141	3.953	0.01	0.007	0	21.5	24.5	73.1	87	96	0	37	39
2015	12	17	3	2	22	0.627	-0.128	3.953	0.01	0.007	0	20.6	24.5	73.1	86	96	0	38	39
2015	12	17	3	12	22	0.653	-0.125	3.953	0.01	0.007	0	21.1	24.5	73.5	87	96	0	38	39
2015	12	17	3	22	22	0.627	-0.128	3.953	0.01	0.007	0	20.6	24.5	73.1	86	96	0	38	39
2015	12	17	3	32	22	0.6	-0.089	3.953	0.01	0.007	0	21.5	24.9	73.5	87	97	0	37	39
2015	12	17	3	42	22	0.636	-0.115	3.95	0.01	0.007	0	21.1	24.9	73.1	87	97	0	38	39
2015	12	17	3	52	22	0.636	-0.151	3.953	0.01	0.007	0	21.1	24.9	72.2	87	97	0	38	39
2015	12	17	4	2	22	0.627	-0.115	3.95	0.01	0.007	0	22.8	27.1	73.1	91	102	0	38	39
2015	12	17	4	12	22	0.627	-0.112	3.95	0.01	0.007	0	21.9	25.4	72.7	88	98	0	37	39
2015	12	17	4	22	22	0.653	-0.115	3.95	0.01	0.007	0	21.9	25.8	73.5	89	99	0	38	39
2015	12	17	4	32	22	0.62	-0.112	3.953	0.01	0.007	0	21.9	25.8	73.1	89	99	0	38	39
2015	12	17	4	42	22	0.636	-0.125	3.95	0.013	0.01	0	24.1	27.5	72.2	93	103	0	37	39
2015	12	17	4	52	22	0.669	-0.144	3.95	0.013	0.01	0	29.2	33.1	72.7	106	116	0	38	39
2015	12	17	5	2	22	0.646	-0.105	3.95	0.013	0.01	0	30.1	34	73.1	108	118	0	38	39
2015	12	17	5	12	22	0.673	-0.121	3.95	0.01	0.007	0	25.8	29.2	72.7	98	107	0	38	39
2015	12	17	5	22	22	0.673	-0.151	3.95	0.01	0.007	0	27.1	31	72.2	101	111	0	38	39
2015	12	17	5	32	22	0.663	-0.151	3.95	0.013	0.01	0	24.9	28.4	72.7	96	105	0	38	39
2015	12	17	5	42	22	0.659	-0.125	3.95	0.01	0.007	0	27.1	31	72.7	101	111	0	38	39
2015	12	17	5	52	22	0.659	-0.112	3.95	0.01	0.007	0	22.4	25.8	72.7	90	100	0	38	40
2015	12	17	6	2	22	0.64	-0.138	3.95	0.01	0.007	0	24.5	27.5	72.7	94	104	0	37	40
2015	12	17	6	12	22	0.604	-0.131	3.95	0.013	0.01	0	22.8	25.8	72.7	90	99	0	37	39
2015	12	17	6	22	22	0.62	-0.131	3.95	0.01	0.007	0	21.9	25.4	72.7	89	98	0	38	39
2015	12	17	6	32	22	0.633	-0.125	3.95	0.01	0.007	0	21.9	25.4	72.7	89	98	0	38	39
2015	12	17	6	42	22	0.617	-0.135	3.95	0.01	0.007	0	22.4	25.4	72.7	89	98	0	37	39
2015	12	17	6	52	22	0.636	-0.151	3.95	0.013	0.01	0	21.9	25.8	73.5	89	99	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	7	2	22	0.636	-0.125	3.95	0.01	0.007	0	22.4	25.8	72.7	90	99	0	38	39
2015	12	17	7	12	22	0.643	-0.144	3.95	0.01	0.007	0	21.9	25.4	72.7	89	98	0	38	39
2015	12	17	7	22	22	0.627	-0.138	3.95	0.01	0.007	0	21.9	25.8	72.7	89	99	0	38	39
2015	12	17	7	32	22	0.64	-0.151	3.947	0.01	0.007	0	21.9	25.4	72.7	89	98	0	38	39
2015	12	17	7	42	22	0.659	-0.125	3.947	0.01	0.007	0	21.9	25.8	72.7	89	98	0	38	38
2015	12	17	7	52	22	0.659	-0.118	3.947	0.01	0.007	0	22.4	25.4	72.7	89	98	0	37	39
2015	12	17	8	2	22	0.636	-0.135	3.947	0.01	0.007	0	22.4	25.8	72.7	90	99	0	38	39
2015	12	17	8	12	22	0.646	-0.115	3.947	0.01	0.007	0	22.4	25.8	73.1	89	99	0	37	39
2015	12	17	8	22	22	0.617	-0.135	3.947	0.013	0.01	0	22.4	25.8	67.5	90	99	0	38	39
2015	12	17	8	32	22	0.63	-0.148	3.947	0.01	0.007	0	22.8	25.8	73.1	91	100	0	38	40
2015	12	17	8	42	22	0.636	-0.125	3.95	0.01	0.007	0	21.9	25.8	73.5	90	99	0	39	39
2015	12	17	8	52	22	0.623	-0.135	3.947	0.01	0.007	0	21.9	25.8	74	90	99	0	39	39
2015	12	17	9	2	22	0.607	-0.135	3.947	0.01	0.007	0	21.9	26.2	73.5	90	100	0	39	39
2015	12	17	9	12	22	0.614	-0.121	3.95	0.013	0.01	0	21.9	25.8	74	89	99	0	38	39
2015	12	17	9	22	22	0.604	-0.135	3.95	0.01	0.007	0	22.8	25.8	74	90	99	0	37	39
2015	12	17	9	32	22	0.617	-0.118	3.95	0.01	0.007	0	21.9	25.8	74.4	89	99	0	38	39
2015	12	17	9	42	22	0.64	-0.105	3.95	0.01	0.007	0	21.9	25.8	74	89	99	0	38	39
2015	12	17	9	52	22	0.627	-0.138	3.95	0.01	0.007	0	22.4	25.4	74.8	90	99	0	38	40
2015	12	17	10	2	22	0.62	-0.125	3.95	0.01	0.007	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	17	10	12	22	0.63	-0.108	3.95	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	17	10	22	22	0.614	-0.135	3.95	0.01	0.007	0	21.9	25.8	74.8	89	99	0	38	39
2015	12	17	10	32	22	0.63	-0.112	3.95	0.013	0.01	0	21.9	25.8	74.4	89	99	0	38	39
2015	12	17	10	42	22	0.617	-0.105	3.95	0.01	0.007	0	21.9	26.2	74.8	89	99	0	38	38
2015	12	17	10	52	22	0.6	-0.131	3.95	0.013	0.01	0	21.9	26.2	74.8	89	99	0	38	38
2015	12	17	11	2	22	0.617	-0.115	3.95	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	17	11	12	22	0.591	-0.135	3.95	0.01	0.007	0	21.9	25.8	63.6	89	98	0	38	38
2015	12	17	11	22	22	0.646	-0.148	3.95	0.01	0.007	0	22.4	25.4	74.4	89	98	0	37	39
2015	12	17	11	32	22	0.607	-0.128	3.95	0.01	0.007	0	21.9	25.4	71.8	89	98	0	38	39
2015	12	17	11	42	22	0.623	-0.092	3.95	0.013	0.01	0	21.9	25.4	74.4	89	98	0	38	39
2015	12	17	11	52	22	0.604	-0.128	3.95	0.01	0.007	0	22.4	25.8	72.2	89	99	0	37	39
2015	12	17	12	2	22	0.643	-0.125	3.95	0.01	0.007	0	21.9	25.8	75.3	88	99	0	37	39
2015	12	17	12	12	22	0.64	-0.112	3.95	0.01	0.007	0	21.5	25.4	74.8	88	98	0	38	39
2015	12	17	12	22	22	0.65	-0.135	3.95	0.01	0.007	0	21.5	25.4	76.1	88	98	0	38	39
2015	12	17	12	32	22	0.617	-0.128	3.95	0.01	0.007	0	21.5	25.4	74.8	88	98	0	38	39
2015	12	17	12	42	22	0.604	-0.125	3.95	0.01	0.007	0	22.4	25.4	76.1	89	98	0	37	39
2015	12	17	12	52	22	0.656	-0.125	3.947	0.01	0.007	0	21.5	25.4	75.7	88	98	0	38	39
2015	12	17	13	2	22	0.63	-0.121	3.947	0.01	0.007	0	21.5	25.4	71.4	88	98	0	38	39
2015	12	17	13	12	22	0.633	-0.118	3.947	0.01	0.007	0	21.9	25.4	74.4	88	98	0	37	39
2015	12	17	13	22	22	0.63	-0.128	3.947	0.01	0.007	0	21.5	25.4	74.4	88	98	0	38	39
2015	12	17	13	32	22	0.623	-0.108	3.947	0.01	0.007	0	21.5	24.5	74.8	88	97	0	38	40
2015	12	17	13	42	22	0.623	-0.128	3.947	0.01	0.007	0	21.5	24.9	65.4	88	97	0	38	39
2015	12	17	13	52	22	0.62	-0.121	3.947	0.01	0.007	0	21.5	25.4	74.8	88	98	0	38	39
2015	12	17	14	2	22	0.61	-0.115	3.947	0.01	0.007	0	21.1	24.9	75.7	87	97	0	38	39
2015	12	17	14	12	22	0.604	-0.141	3.944	0.01	0.007	0	21.5	25.4	74.4	88	98	0	38	39
2015	12	17	14	22	22	0.604	-0.092	3.947	0.01	0.007	0	21.5	25.4	75.3	88	98	0	38	39
2015	12	17	14	32	22	0.643	-0.125	3.944	0.01	0.007	0	21.5	25.4	76.1	88	98	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	14	42	22	0.614	-0.115	3.944	0.01	0.007	0	21.5	25.4	65.8	88	98	0	38	39
2015	12	17	14	52	22	0.614	-0.131	3.944	0.01	0.007	0	21.5	25.4	71.8	88	98	0	38	39
2015	12	17	15	2	22	0.636	-0.105	3.944	0.01	0.007	0	21.9	25.4	76.5	88	97	0	37	38
2015	12	17	15	12	22	0.63	-0.141	3.94	0.013	0.01	0	21.5	24.9	74	88	97	0	38	39
2015	12	17	15	22	22	0.627	-0.112	3.94	0.01	0.007	0	21.5	24.9	74	88	97	0	38	39
2015	12	17	15	32	22	0.636	-0.131	3.94	0.01	0.007	0	21.5	25.4	76.5	88	98	0	38	39
2015	12	17	15	42	22	0.636	-0.112	3.94	0.01	0.007	0	21.5	25.4	76.5	88	98	0	38	39
2015	12	17	15	52	22	0.617	-0.118	3.94	0.01	0.007	0	21.5	24.9	76.5	88	98	0	38	40
2015	12	17	16	2	22	0.64	-0.138	3.94	0.01	0.007	0	20.6	24.5	75.7	86	96	0	38	39
2015	12	17	16	12	22	0.623	-0.118	3.94	0.01	0.007	0	21.5	24.5	74	87	96	0	37	39
2015	12	17	16	22	22	0.636	-0.112	3.94	0.013	0.01	0	21.1	24.9	76.1	87	97	0	38	39
2015	12	17	16	32	22	0.653	-0.138	3.94	0.01	0.007	0	20.6	24.5	76.5	87	96	0	39	39
2015	12	17	16	42	22	0.623	-0.108	3.937	0.01	0.007	0	21.1	24.5	75.7	87	96	0	38	39
2015	12	17	16	52	22	0.62	-0.115	3.94	0.01	0.007	0	21.1	24.5	77	87	96	0	38	39
2015	12	17	17	2	22	0.64	-0.112	3.94	0.01	0.007	0	21.1	24.9	76.5	87	97	0	38	39
2015	12	17	17	12	22	0.63	-0.141	3.937	0.01	0.007	0	21.1	24.9	76.1	87	97	0	38	39
2015	12	17	17	22	22	0.627	-0.112	3.937	0.01	0.007	0	21.1	24.9	76.5	87	97	0	38	39
2015	12	17	17	32	22	0.627	-0.138	3.94	0.01	0.007	0	21.1	24.9	77	87	97	0	38	39
2015	12	17	17	42	22	0.643	-0.112	3.937	0.01	0.007	0	21.1	24.9	77	87	97	0	38	39
2015	12	17	17	52	22	0.627	-0.108	3.937	0.01	0.007	0	21.5	25.4	76.5	88	97	0	38	38
2015	12	17	18	2	22	0.63	-0.131	3.937	0.01	0.007	0	22.8	26.2	76.5	91	100	0	38	39
2015	12	17	18	12	22	0.617	-0.115	3.937	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	17	18	22	22	0.617	-0.115	3.937	0.01	0.007	0	21.9	25.8	77	89	98	0	38	38
2015	12	17	18	32	22	0.64	-0.138	3.937	0.01	0.007	0	21.1	24.5	77	87	97	0	38	40
2015	12	17	18	42	22	0.636	-0.135	3.937	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	17	18	52	22	0.62	-0.121	3.937	0.01	0.007	0	37	41.3	74.4	124	135	0	38	39
2015	12	17	19	2	22	0.65	-0.121	3.937	0.01	0.007	0	31	34	77	110	118	0	38	39
2015	12	17	19	12	22	0.61	-0.138	3.937	0.01	0.007	0	30.5	34.4	77	109	118	0	38	38
2015	12	17	19	22	22	0.636	-0.141	3.937	0.01	0.007	0	25.4	29.2	77	97	107	0	38	39
2015	12	17	19	32	22	0.61	-0.141	3.937	0.01	0.007	0	24.1	27.5	77	93	103	0	37	39
2015	12	17	19	42	22	0.64	-0.121	3.937	0.01	0.007	0	21.9	26.2	77.4	90	101	0	39	40
2015	12	17	19	52	22	0.617	-0.135	3.937	0.01	0.007	0	24.5	28.4	77.4	95	105	0	38	39
2015	12	17	20	2	22	0.627	-0.164	3.937	0.01	0.007	0	25.4	28.8	77.8	97	107	0	38	40
2015	12	17	20	12	22	0.614	-0.131	3.937	0.01	0.007	0	22.8	27.1	77.8	92	102	0	39	39
2015	12	17	20	22	22	0.65	-0.174	3.937	0.01	0.007	0	21.9	25.8	77.4	89	99	0	38	39
2015	12	17	20	32	22	0.614	-0.157	3.937	0.01	0.007	0	21.5	25.8	77	89	99	0	39	39
2015	12	17	20	42	22	0.65	-0.157	3.937	0.013	0.01	0	24.9	28.8	77	96	106	0	38	39
2015	12	17	20	52	22	0.623	-0.128	3.937	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	17	21	2	22	0.62	-0.148	3.937	0.01	0.007	0	21.9	25.8	77	89	99	0	38	39
2015	12	17	21	12	22	0.617	-0.138	3.937	0.01	0.007	0	21.5	25.8	77	89	99	0	39	39
2015	12	17	21	22	22	0.6	-0.121	3.937	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	17	21	32	22	0.614	-0.148	3.937	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	17	21	42	22	0.633	-0.161	3.937	0.013	0.01	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	17	21	52	22	0.643	-0.161	3.937	0.016	0.013	0	25.4	29.2	76.1	97	107	0	38	39
2015	12	17	22	2	22	0.62	-0.125	3.937	0.016	0.013	0	26.2	29.7	77	98	109	0	37	40
2015	12	17	22	12	22	0.646	-0.151	3.937	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	22	22	22	0.627	-0.112	3.934	0.01	0.007	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	17	22	32	22	0.636	-0.161	3.934	0.01	0.007	0	23.2	27.5	77	93	103	0	39	39
2015	12	17	22	42	22	0.62	-0.151	3.934	0.01	0.007	0	23.6	28.4	77	94	105	0	39	39
2015	12	17	22	52	22	0.6	-0.138	3.934	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	17	23	2	22	0.65	-0.148	3.934	0.013	0.01	0	23.6	27.1	77	93	102	0	38	39
2015	12	17	23	12	22	0.623	-0.112	3.934	0.01	0.007	0	25.4	29.7	77	97	108	0	38	39
2015	12	17	23	22	22	0.623	-0.108	3.934	0.01	0.007	0	24.9	29.2	77	96	107	0	38	39
2015	12	17	23	32	22	0.636	-0.138	3.934	0.01	0.007	0	22.8	27.1	77	91	101	0	38	38
2015	12	17	23	42	22	0.65	-0.112	3.934	0.013	0.01	0	28	31.8	77	104	114	0	39	40
2015	12	17	23	52	22	0.646	-0.138	3.934	0.013	0.01	0	28	31.8	77.4	103	113	0	38	39
2015	12	18	0	2	22	0.646	-0.154	3.934	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	18	0	12	22	0.636	-0.135	3.934	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	18	0	22	22	0.643	-0.135	3.934	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	18	0	32	22	0.63	-0.115	3.934	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	18	0	42	22	0.591	-0.144	3.934	0.01	0.007	0	24.1	27.5	77.4	94	103	0	38	39
2015	12	18	0	52	22	0.64	-0.157	3.934	0.01	0.007	0	22.8	26.7	77	92	102	0	39	40
2015	12	18	1	2	22	0.636	-0.138	3.934	0.01	0.007	0	22.4	25.8	77	90	100	0	38	40
2015	12	18	1	12	22	0.63	-0.151	3.934	0.01	0.007	0	25.8	29.7	77	98	108	0	38	39
2015	12	18	1	22	22	0.659	-0.131	3.93	0.01	0.007	0	30.1	34	77	108	118	0	38	39
2015	12	18	1	32	22	0.643	-0.171	3.93	0.01	0.007	0	31	34.8	76.5	110	120	0	38	39
2015	12	18	1	42	22	0.64	-0.131	3.93	0.013	0.01	0	28.8	33.1	77	106	116	0	39	39
2015	12	18	1	52	22	0.633	-0.144	3.93	0.01	0.007	0	24.5	28.4	77.4	95	105	0	38	39
2015	12	18	2	2	22	0.653	-0.148	3.93	0.01	0.007	0	24.1	27.5	77	94	103	0	38	39
2015	12	18	2	12	22	0.614	-0.115	3.93	0.01	0.007	0	23.6	27.5	77.4	93	103	0	38	39
2015	12	18	2	22	22	0.62	-0.151	3.93	0.01	0.007	0	24.5	28.4	77	95	105	0	38	39
2015	12	18	2	32	22	0.617	-0.144	3.93	0.01	0.007	0	24.1	28.4	77	94	105	0	38	39
2015	12	18	2	42	22	0.65	-0.138	3.93	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	18	2	52	22	0.653	-0.148	3.93	0.01	0.007	0	24.1	28	76.5	95	104	0	39	39
2015	12	18	3	2	22	0.627	-0.144	3.93	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	18	3	12	22	0.61	-0.151	3.93	0.01	0.007	0	24.1	27.5	77	94	103	0	38	39
2015	12	18	3	22	22	0.643	-0.151	3.93	0.01	0.007	0	24.1	28	77	94	104	0	38	39
2015	12	18	3	32	22	0.594	-0.138	3.93	0.01	0.007	0	24.1	27.5	77	94	104	0	38	40
2015	12	18	3	42	22	0.633	-0.151	3.93	0.013	0.01	0	25.4	29.2	77	97	107	0	38	39
2015	12	18	3	52	22	0.643	-0.157	3.93	0.01	0.007	0	28	31.4	77	103	112	0	38	39
2015	12	18	4	2	22	0.623	-0.125	3.93	0.01	0.007	0	24.9	28.4	76.5	97	106	0	39	40
2015	12	18	4	12	22	0.607	-0.154	3.93	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	18	4	22	22	0.623	-0.125	3.93	0.01	0.007	0	29.7	33.5	76.5	107	117	0	38	39
2015	12	18	4	32	22	0.653	-0.144	3.93	0.013	0.01	0	32.3	35.7	77	113	123	0	38	40
2015	12	18	4	42	22	0.646	-0.125	3.93	0.01	0.007	0	30.1	33.5	77	107	117	0	37	39
2015	12	18	4	52	22	0.627	-0.135	3.93	0.01	0.007	0	24.1	27.5	77	94	103	0	38	39
2015	12	18	5	2	22	0.6	-0.128	3.93	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	18	5	12	22	0.63	-0.138	3.93	0.01	0.007	0	23.6	26.7	77	93	102	0	38	40
2015	12	18	5	22	22	0.61	-0.131	3.93	0.013	0.01	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	18	5	32	22	0.62	-0.151	3.93	0.013	0.01	0	22.8	25.8	77	91	100	0	38	40
2015	12	18	5	42	22	0.633	-0.138	3.93	0.01	0.007	0	23.2	26.2	77.4	91	100	0	37	39
2015	12	18	5	52	22	0.627	-0.151	3.93	0.01	0.007	0	22.4	25.8	77.4	90	100	0	38	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	6	2	22	0.656	-0.144	3.93	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	18	6	12	22	0.63	-0.138	3.93	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	18	6	22	22	0.614	-0.131	3.93	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	18	6	32	22	0.656	-0.148	3.93	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	18	6	42	22	0.604	-0.115	3.93	0.01	0.007	0	22.4	26.2	76.1	90	100	0	38	39
2015	12	18	6	52	22	0.62	-0.135	3.934	0.01	0.007	0	22.4	26.2	76.1	90	100	0	38	39
2015	12	18	7	2	22	0.617	-0.144	3.934	0.013	0.01	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	18	7	12	22	0.643	-0.174	3.93	0.01	0.007	0	21.9	25.4	76.1	89	98	0	38	39
2015	12	18	7	22	22	0.633	-0.121	3.93	0.01	0.007	0	21.9	25.8	76.5	89	99	0	38	39
2015	12	18	7	32	22	0.633	-0.138	3.93	0.01	0.007	0	21.9	25.8	77	89	99	0	38	39
2015	12	18	7	42	22	0.65	-0.125	3.934	0.01	0.007	0	21.9	26.2	76.5	90	100	0	39	39
2015	12	18	7	52	22	0.61	-0.151	3.934	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	18	8	2	22	0.63	-0.138	3.934	0.01	0.007	0	22.4	25.8	76.5	90	100	0	38	40
2015	12	18	8	12	22	0.604	-0.125	3.934	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	18	8	22	22	0.617	-0.135	3.934	0.01	0.007	0	22.8	26.2	77.4	90	100	0	37	39
2015	12	18	8	32	22	0.627	-0.171	3.934	0.013	0.01	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	18	8	42	22	0.643	-0.144	3.934	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	18	8	52	22	0.636	-0.138	3.934	0.01	0.007	0	23.2	27.1	77	92	101	0	38	38
2015	12	18	9	2	22	0.636	-0.138	3.934	0.013	0.01	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	18	9	12	22	0.643	-0.138	3.934	0.013	0.01	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	18	9	22	22	0.636	-0.138	3.934	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	18	9	32	22	0.64	-0.138	3.934	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	18	9	42	22	0.636	-0.121	3.934	0.01	0.007	0	23.2	26.7	76.1	92	102	0	38	40
2015	12	18	9	52	22	0.656	-0.121	3.934	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	18	10	2	22	0.627	-0.125	3.934	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	18	10	12	22	0.617	-0.105	3.934	0.01	0.007	0	23.2	27.1	76.1	92	102	0	38	39
2015	12	18	10	22	22	0.659	-0.102	3.934	0.01	0.007	0	23.2	26.7	75.3	92	101	0	38	39
2015	12	18	10	32	22	0.643	-0.135	3.937	0.01	0.007	0	23.2	26.7	76.1	91	101	0	37	39
2015	12	18	10	42	22	0.62	-0.141	3.937	0.013	0.01	0	22.8	26.7	75.7	91	101	0	38	39
2015	12	18	10	52	22	0.623	-0.125	3.937	0.01	0.007	0	22.8	26.2	75.7	91	100	0	38	39
2015	12	18	11	2	22	0.617	-0.128	3.937	0.01	0.007	0	22.8	26.2	75.3	90	100	0	37	39
2015	12	18	11	12	22	0.63	-0.138	3.937	0.01	0.007	0	21.9	26.2	75.7	90	100	0	39	39
2015	12	18	11	22	22	0.617	-0.138	3.937	0.01	0.007	0	22.4	25.8	74	90	100	0	38	40
2015	12	18	11	32	22	0.627	-0.121	3.937	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	18	11	42	22	0.63	-0.151	3.937	0.01	0.007	0	21.9	25.8	74.8	90	99	0	39	39
2015	12	18	11	52	22	0.627	-0.141	3.937	0.01	0.007	0	22.4	25.8	75.3	90	99	0	38	39
2015	12	18	12	2	22	0.63	-0.135	3.937	0.01	0.007	0	22.8	25.8	68.8	90	99	0	37	39
2015	12	18	12	12	22	0.64	-0.112	3.937	0.01	0.007	0	22.8	26.2	68.4	90	100	0	37	39
2015	12	18	12	22	22	0.627	-0.138	3.934	0.01	0.007	0	22.4	25.8	57.6	90	99	0	38	39
2015	12	18	12	32	22	0.63	-0.118	3.934	0.01	0.007	0	22.4	26.2	58	90	100	0	38	39
2015	12	18	12	42	22	0.587	-0.128	3.934	0.01	0.007	0	22.4	26.2	72.2	90	100	0	38	39
2015	12	18	12	52	22	0.656	-0.135	3.934	0.01	0.007	0	22.4	26.2	58.9	90	100	0	38	39
2015	12	18	13	2	22	0.636	-0.167	3.93	0.01	0.007	0	22.4	26.2	56.8	90	100	0	38	39
2015	12	18	13	12	22	0.597	-0.115	3.934	0.01	0.007	0	22.8	26.2	58	91	100	0	38	39
2015	12	18	13	22	22	0.643	-0.135	3.93	0.01	0.007	0	22.4	25.8	52.5	90	99	0	38	39
2015	12	18	13	32	22	0.614	-0.128	3.934	0.01	0.007	0	22.8	26.7	52.5	91	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	13	42	22	0.659	-0.128	3.934	0.01	0.007	0	22.4	25.8	52.5	90	99	0	38	39
2015	12	18	13	52	22	0.61	-0.148	3.93	0.01	0.007	0	21.9	26.2	52.9	90	100	0	39	39
2015	12	18	14	2	22	0.604	-0.138	3.93	0.01	0.007	0	22.8	26.2	54.2	90	100	0	37	39
2015	12	18	14	12	22	0.61	-0.138	3.93	0.01	0.007	0	22.8	26.7	52.5	91	101	0	38	39
2015	12	18	14	22	22	0.633	-0.154	3.93	0.01	0.007	0	22.8	26.2	51.2	91	100	0	38	39
2015	12	18	14	32	22	0.61	-0.131	3.93	0.01	0.007	0	22.4	25.8	51.2	90	99	0	38	39
2015	12	18	14	42	22	0.6	-0.138	3.934	0.01	0.007	0	22.4	26.2	50.7	90	100	0	38	39
2015	12	18	14	52	22	0.617	-0.138	3.93	0.01	0.007	0	22.4	26.2	52.9	90	99	0	38	38
2015	12	18	15	2	22	0.623	-0.125	3.927	0.01	0.007	0	22.8	26.2	52.5	91	100	0	38	39
2015	12	18	15	12	22	0.604	-0.148	3.927	0.01	0.007	0	22.8	26.7	50.3	91	101	0	38	39
2015	12	18	15	22	22	0.643	-0.144	3.924	0.013	0.01	0	22.8	26.7	50.7	91	101	0	38	39
2015	12	18	15	32	22	0.627	-0.144	3.927	0.01	0.007	0	22.4	26.2	52	91	100	0	39	39
2015	12	18	15	42	22	0.636	-0.102	3.927	0.01	0.007	0	22.8	26.7	58.5	91	101	0	38	39
2015	12	18	15	52	22	0.636	-0.135	3.927	0.016	0.013	0	22.4	26.7	57.6	91	101	0	39	39
2015	12	18	16	2	22	0.636	-0.148	3.927	0.01	0.007	0	22.4	25.8	72.2	90	99	0	38	39
2015	12	18	16	12	22	0.597	-0.125	3.927	0.01	0.007	0	22.8	25.8	75.3	90	99	0	37	39
2015	12	18	16	22	22	0.62	-0.131	3.927	0.01	0.007	0	21.9	26.2	75.3	89	99	0	38	38
2015	12	18	16	32	22	0.607	-0.151	3.927	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	18	16	42	22	0.627	-0.144	3.927	0.01	0.007	0	21.9	26.2	74.8	90	99	0	39	38
2015	12	18	16	52	22	0.607	-0.151	3.927	0.01	0.007	0	22.4	25.8	75.7	90	99	0	38	39
2015	12	18	17	2	22	0.627	-0.135	3.927	0.01	0.007	0	21.9	25.4	75.7	89	99	0	38	40
2015	12	18	17	12	22	0.656	-0.157	3.927	0.013	0.01	0	21.9	25.8	75.7	90	99	0	39	39
2015	12	18	17	22	22	0.62	-0.128	3.927	0.01	0.007	0	21.9	25.8	75.7	90	99	0	39	39
2015	12	18	17	32	22	0.636	-0.135	3.927	0.01	0.007	0	22.4	26.2	75.7	90	100	0	38	39
2015	12	18	17	42	22	0.636	-0.138	3.927	0.01	0.007	0	21.9	26.2	76.1	90	100	0	39	39
2015	12	18	17	52	22	0.604	-0.157	3.927	0.01	0.007	0	22.4	26.2	75.7	91	100	0	39	39
2015	12	18	18	2	22	0.61	-0.098	3.927	0.01	0.007	0	23.6	27.1	75.7	93	102	0	38	39
2015	12	18	18	12	22	0.65	-0.131	3.927	0.01	0.007	0	31.8	35.7	75.7	112	122	0	38	39
2015	12	18	18	22	22	0.643	-0.128	3.927	0.01	0.007	0	28	31.8	75.7	103	113	0	38	39
2015	12	18	18	32	22	0.64	-0.138	3.927	0.01	0.007	0	25.4	29.2	76.1	97	107	0	38	39
2015	12	18	18	42	22	0.636	-0.144	3.927	0.01	0.007	0	24.5	28.4	76.5	95	105	0	38	39
2015	12	18	18	52	22	0.65	-0.148	3.927	0.01	0.007	0	22.4	26.2	76.5	91	100	0	39	39
2015	12	18	19	2	22	0.62	-0.141	3.927	0.01	0.007	0	22.4	25.8	76.1	90	99	0	38	39
2015	12	18	19	12	22	0.6	-0.112	3.927	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	18	19	22	22	0.65	-0.125	3.927	0.01	0.007	0	24.1	28	76.5	95	104	0	39	39
2015	12	18	19	32	22	0.63	-0.141	3.927	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	18	19	42	22	0.64	-0.141	3.927	0.01	0.007	0	23.6	28	77	93	103	0	38	38
2015	12	18	19	52	22	0.61	-0.125	3.93	0.01	0.007	0	23.6	27.5	77	94	104	0	39	40
2015	12	18	20	2	22	0.633	-0.131	3.927	0.01	0.007	0	24.9	28.4	76.5	96	105	0	38	39
2015	12	18	20	12	22	0.646	-0.131	3.93	0.01	0.007	0	23.6	27.1	77	93	103	0	38	40
2015	12	18	20	22	22	0.62	-0.131	3.93	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	18	20	32	22	0.63	-0.125	3.93	0.01	0.007	0	24.1	28	76.5	94	103	0	38	38
2015	12	18	20	42	22	0.646	-0.125	3.93	0.01	0.007	0	24.1	27.5	76.5	94	104	0	38	40
2015	12	18	20	52	22	0.64	-0.161	3.93	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	18	21	2	22	0.64	-0.141	3.93	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	18	21	12	22	0.633	-0.108	3.93	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	21	22	22	0.643	-0.138	3.93	0.01	0.007	0	22.4	26.2	77	91	100	0	39	39
2015	12	18	21	32	22	0.63	-0.131	3.93	0.01	0.007	0	22.4	26.2	76.5	90	99	0	38	38
2015	12	18	21	42	22	0.627	-0.135	3.93	0.01	0.007	0	22.8	26.2	77	90	100	0	37	39
2015	12	18	21	52	22	0.666	-0.151	3.93	0.013	0.01	0	33.1	36.5	76.5	115	124	0	38	39
2015	12	18	22	2	22	0.659	-0.138	3.934	0.01	0.007	0	40.9	45.6	76.1	134	145	0	39	39
2015	12	18	22	12	22	0.623	-0.148	3.93	0.01	0.007	0	29.7	33.5	77	107	117	0	38	39
2015	12	18	22	22	22	0.643	-0.135	3.934	0.01	0.007	0	29.2	33.1	77	106	116	0	38	39
2015	12	18	22	32	22	0.64	-0.115	3.934	0.01	0.007	0	25.4	28.8	76.1	96	106	0	37	39
2015	12	18	22	42	22	0.633	-0.151	3.934	0.013	0.01	0	23.6	27.1	77	93	102	0	38	39
2015	12	18	22	52	22	0.627	-0.138	3.934	0.01	0.007	0	22.8	26.2	77	91	101	0	38	40
2015	12	18	23	2	22	0.62	-0.138	3.934	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	18	23	12	22	0.64	-0.148	3.934	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	18	23	22	22	0.656	-0.138	3.934	0.01	0.007	0	26.2	30.1	77	99	109	0	38	39
2015	12	18	23	32	22	0.669	-0.125	3.934	0.01	0.007	0	34	37	76.5	117	125	0	38	39
2015	12	18	23	42	22	0.659	-0.128	3.934	0.01	0.007	0	28.8	32.7	76.5	105	115	0	38	39
2015	12	18	23	52	22	0.633	-0.121	3.934	0.01	0.007	0	26.7	30.5	76.5	101	110	0	39	39
2015	12	19	0	2	22	0.65	-0.131	3.934	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	19	0	12	22	0.627	-0.118	3.934	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	19	0	22	22	0.646	-0.138	3.934	0.013	0.01	0	24.5	28.4	76.1	95	105	0	38	39
2015	12	19	0	32	22	0.633	-0.138	3.934	0.01	0.007	0	24.1	28	76.5	94	104	0	38	39
2015	12	19	0	42	22	0.643	-0.138	3.934	0.01	0.007	0	24.5	28	76.5	95	104	0	38	39
2015	12	19	0	52	22	0.643	-0.154	3.934	0.01	0.007	0	23.6	27.1	76.1	93	102	0	38	39
2015	12	19	1	2	22	0.614	-0.121	3.934	0.013	0.01	0	25.4	29.2	76.1	97	107	0	38	39
2015	12	19	1	12	22	0.63	-0.115	3.934	0.01	0.007	0	25.8	29.7	76.1	98	108	0	38	39
2015	12	19	1	22	22	0.62	-0.138	3.934	0.01	0.007	0	23.6	28	76.1	94	104	0	39	39
2015	12	19	1	32	22	0.633	-0.125	3.934	0.01	0.007	0	24.1	28	76.1	94	104	0	38	39
2015	12	19	1	42	22	0.646	-0.144	3.934	0.01	0.007	0	26.2	30.5	76.1	99	110	0	38	39
2015	12	19	1	52	22	0.669	-0.154	3.934	0.01	0.007	0	25.4	28.4	76.1	97	106	0	38	40
2015	12	19	2	2	22	0.633	-0.128	3.934	0.01	0.007	0	24.1	27.5	75.7	94	103	0	38	39
2015	12	19	2	12	22	0.614	-0.138	3.934	0.013	0.01	0	22.8	26.7	75.7	91	101	0	38	39
2015	12	19	2	22	22	0.62	-0.128	3.934	0.01	0.007	0	22.8	26.2	76.5	91	101	0	38	40
2015	12	19	2	32	22	0.63	-0.138	3.934	0.01	0.007	0	27.5	31.8	76.1	103	113	0	39	39
2015	12	19	2	42	22	0.656	-0.148	3.934	0.01	0.007	0	28.8	33.1	75.3	106	116	0	39	39
2015	12	19	2	52	22	0.646	-0.108	3.934	0.01	0.007	0	30.5	34.4	75.7	109	119	0	38	39
2015	12	19	3	2	22	0.656	-0.121	3.934	0.01	0.007	0	28.8	32.7	76.1	105	115	0	38	39
2015	12	19	3	12	22	0.633	-0.138	3.937	0.01	0.007	0	25.4	29.2	75.7	97	107	0	38	39
2015	12	19	3	22	22	0.581	-0.082	3.937	0.01	0.007	0	22.8	27.1	75.7	91	102	0	38	39
2015	12	19	3	32	22	0.6	-0.102	3.934	0.01	0.007	0	23.2	28	75.7	92	105	0	38	40
2015	12	19	3	42	22	0.659	-0.138	3.937	0.01	0.007	0	24.9	28.4	75.7	96	105	0	38	39
2015	12	19	3	52	22	0.64	-0.112	3.937	0.01	0.007	0	24.1	28	76.1	94	104	0	38	39
2015	12	19	4	2	22	0.64	-0.115	3.937	0.01	0.007	0	27.5	31.4	75.7	102	112	0	38	39
2015	12	19	4	12	22	0.656	-0.105	3.937	0.01	0.007	0	31	34.8	74.8	110	120	0	38	39
2015	12	19	4	22	22	0.65	-0.148	3.937	0.01	0.007	0	25.4	29.2	73.5	97	107	0	38	39
2015	12	19	4	32	22	0.623	-0.115	3.937	0.01	0.007	0	23.6	27.5	75.3	93	103	0	38	39
2015	12	19	4	42	22	0.643	-0.135	3.937	0.01	0.007	0	23.6	27.5	75.3	93	103	0	38	39
2015	12	19	4	52	22	0.643	-0.135	3.937	0.01	0.007	0	24.1	28	75.7	94	104	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	5	2	22	0.597	-0.125	3.937	0.01	0.007	0	22.8	26.7	75.3	91	101	0	38	39
2015	12	19	5	12	22	0.614	-0.138	3.937	0.01	0.007	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	19	5	22	22	0.646	-0.115	3.937	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	19	5	32	22	0.636	-0.151	3.937	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	19	5	42	22	0.62	-0.141	3.937	0.01	0.007	0	22.8	26.2	75.3	91	100	0	38	39
2015	12	19	5	52	22	0.617	-0.138	3.937	0.01	0.007	0	22.4	26.7	75.3	90	101	0	38	39
2015	12	19	6	2	22	0.607	-0.128	3.937	0.01	0.007	0	21.9	25.8	74.8	89	99	0	38	39
2015	12	19	6	12	22	0.62	-0.157	3.94	0.01	0.007	0	21.9	25.8	74.8	89	99	0	38	39
2015	12	19	6	22	22	0.623	-0.131	3.937	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	19	6	32	22	0.6	-0.128	3.937	0.01	0.007	0	22.4	26.2	75.3	90	100	0	38	39
2015	12	19	6	42	22	0.62	-0.154	3.94	0.01	0.007	0	22.8	26.2	71.8	90	100	0	37	39
2015	12	19	6	52	22	0.623	-0.148	3.937	0.01	0.007	0	22.8	26.2	73.1	91	100	0	38	39
2015	12	19	7	2	22	0.633	-0.144	3.94	0.01	0.007	0	21.9	25.8	73.1	89	99	0	38	39
2015	12	19	7	12	22	0.63	-0.138	3.94	0.01	0.007	0	21.9	25.4	71.4	89	99	0	38	40
2015	12	19	7	22	22	0.63	-0.141	3.94	0.01	0.007	0	22.4	25.8	72.7	90	100	0	38	40
2015	12	19	7	32	22	0.659	-0.138	3.94	0.013	0.01	0	22.4	25.8	73.5	90	99	0	38	39
2015	12	19	7	42	22	0.633	-0.148	3.94	0.01	0.007	0	22.4	26.2	70.5	90	100	0	38	39
2015	12	19	7	52	22	0.61	-0.138	3.94	0.01	0.007	0	22.4	25.8	71.8	90	99	0	38	39
2015	12	19	8	2	22	0.604	-0.131	3.94	0.013	0.01	0	22.8	25.8	68.4	91	100	0	38	40
2015	12	19	8	12	22	0.617	-0.128	3.94	0.01	0.007	0	21.9	25.8	72.2	90	99	0	39	39
2015	12	19	8	22	22	0.62	-0.141	3.937	0.01	0.007	0	23.2	27.1	67.9	93	102	0	39	39
2015	12	19	8	32	22	0.607	-0.115	3.944	0.01	0.007	0	22.8	26.7	73.5	91	101	0	38	39
2015	12	19	8	42	22	0.591	-0.128	3.944	0.01	0.007	0	23.6	28	71.8	93	103	0	38	38
2015	12	19	8	52	22	0.61	-0.138	3.94	0.01	0.007	0	22.8	25.8	70.1	90	99	0	37	39
2015	12	19	9	2	22	0.633	-0.138	3.944	0.01	0.007	0	22.8	26.7	72.2	91	101	0	38	39
2015	12	19	9	12	22	0.614	-0.154	3.94	0.013	0.01	0	22.4	26.2	73.1	90	100	0	38	39
2015	12	19	9	22	22	0.62	-0.131	3.944	0.01	0.007	0	21.9	26.2	71.8	90	100	0	39	39
2015	12	19	9	32	22	0.623	-0.138	3.944	0.01	0.007	0	22.4	25.8	71	90	99	0	38	39
2015	12	19	9	42	22	0.633	-0.144	3.944	0.01	0.007	0	22.8	26.7	71.8	91	100	0	38	38
2015	12	19	9	52	22	0.659	-0.154	3.944	0.01	0.007	0	21.9	25.8	71	89	99	0	38	39
2015	12	19	10	2	22	0.614	-0.098	3.944	0.01	0.007	0	21.9	25.8	75.3	89	99	0	38	39
2015	12	19	10	12	22	0.614	-0.167	3.944	0.01	0.007	0	21.9	26.7	75.3	90	101	0	39	39
2015	12	19	10	22	22	0.656	-0.121	3.944	0.01	0.007	0	22.4	25.8	74.8	90	100	0	38	40
2015	12	19	10	32	22	0.636	-0.141	3.944	0.01	0.007	0	21.9	25.8	75.7	89	99	0	38	39
2015	12	19	10	42	22	0.6	-0.125	3.944	0.01	0.007	0	22.4	26.7	76.1	90	101	0	38	39
2015	12	19	10	52	22	0.627	-0.131	3.944	0.01	0.007	0	22.4	26.2	76.1	90	99	0	38	38
2015	12	19	11	2	22	0.6	-0.184	3.944	0.01	0.007	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	19	11	12	22	0.63	-0.102	3.944	0.01	0.007	0	22.8	27.1	75.7	91	102	0	38	39
2015	12	19	11	22	22	0.643	-0.138	3.944	0.01	0.007	0	22.8	26.7	76.5	91	102	0	38	40
2015	12	19	11	32	22	0.627	-0.151	3.944	0.013	0.01	0	22.8	26.7	76.1	91	101	0	38	39
2015	12	19	11	42	22	0.646	-0.138	3.944	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	19	11	52	22	0.607	-0.118	3.94	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	19	12	2	22	0.627	-0.135	3.94	0.013	0.01	0	22.8	26.2	77	91	101	0	38	40
2015	12	19	12	12	22	0.61	-0.102	3.937	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	19	12	22	22	0.6	-0.121	3.937	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	19	12	32	22	0.653	-0.154	3.937	0.013	0.01	0	22.8	26.7	71.4	91	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	12	42	22	0.61	-0.131	3.94	0.01	0.007	0	23.2	27.1	76.1	92	101	0	38	38
2015	12	19	12	52	22	0.65	-0.128	3.94	0.01	0.007	0	22.8	27.1	77	92	102	0	39	39
2015	12	19	13	2	22	0.653	-0.121	3.94	0.01	0.007	0	22.8	26.2	77	90	100	0	37	39
2015	12	19	13	12	22	0.62	-0.115	3.94	0.01	0.007	0	22.8	27.1	77	91	102	0	38	39
2015	12	19	13	22	22	0.62	-0.102	3.94	0.01	0.007	0	22.8	26.2	76.5	91	101	0	38	40
2015	12	19	13	32	22	0.636	-0.115	3.94	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	19	13	42	22	0.623	-0.108	3.94	0.01	0.007	0	23.6	27.5	77	93	102	0	38	38
2015	12	19	13	52	22	0.61	-0.151	3.937	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	19	14	2	22	0.643	-0.144	3.937	0.01	0.007	0	22.4	26.2	77	91	100	0	39	39
2015	12	19	14	12	22	0.643	-0.112	3.937	0.01	0.007	0	23.2	26.2	76.1	92	101	0	38	40
2015	12	19	14	22	22	0.63	-0.141	3.934	0.01	0.007	0	22.4	26.2	76.5	90	100	0	38	39
2015	12	19	14	32	22	0.627	-0.112	3.937	0.01	0.007	0	23.2	26.7	75.7	92	101	0	38	39
2015	12	19	14	42	22	0.617	-0.138	3.937	0.01	0.007	0	25.4	28.8	77.4	96	106	0	37	39
2015	12	19	14	52	22	0.6	-0.125	3.934	0.01	0.007	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	19	15	2	22	0.633	-0.135	3.934	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	19	15	12	22	0.623	-0.121	3.934	0.01	0.007	0	22.8	26.7	67.5	91	101	0	38	39
2015	12	19	15	22	22	0.607	-0.125	3.934	0.01	0.007	0	22.4	25.4	76.5	90	99	0	38	40
2015	12	19	15	32	22	0.643	-0.118	3.934	0.01	0.007	0	21.5	25.8	77.4	89	99	0	39	39
2015	12	19	15	42	22	0.646	-0.131	3.934	0.01	0.007	0	21.9	25.8	77	89	99	0	38	39
2015	12	19	15	52	22	0.646	-0.128	3.934	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	19	16	2	22	0.61	-0.115	3.934	0.01	0.007	0	21.9	25.8	77.4	89	99	0	38	39
2015	12	19	16	12	22	0.633	-0.128	3.934	0.01	0.007	0	21.5	25.4	77	89	99	0	39	40
2015	12	19	16	22	22	0.627	-0.154	3.934	0.01	0.007	0	26.7	30.5	76.5	100	110	0	38	39
2015	12	19	16	32	22	0.666	-0.131	3.934	0.01	0.007	0	28.4	33.1	76.5	105	115	0	39	38
2015	12	19	16	42	22	0.653	-0.164	3.93	0.01	0.007	0	24.9	29.2	77	97	107	0	39	39
2015	12	19	16	52	22	0.659	-0.125	3.93	0.01	0.007	0	25.4	29.7	76.5	97	108	0	38	39
2015	12	19	17	2	22	0.62	-0.128	3.934	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	19	17	12	22	0.65	-0.125	3.934	0.01	0.007	0	23.6	27.5	75.7	93	103	0	38	39
2015	12	19	17	22	22	0.62	-0.125	3.934	0.01	0.007	0	24.1	28	76.5	94	104	0	38	39
2015	12	19	17	32	22	0.636	-0.161	3.93	0.01	0.007	0	24.5	28.4	76.1	95	105	0	38	39
2015	12	19	17	42	22	0.65	-0.138	3.93	0.013	0.01	0	26.2	29.7	75.7	99	108	0	38	39
2015	12	19	17	52	22	0.64	-0.138	3.93	0.013	0.01	0	28.4	32.3	76.1	104	114	0	38	39
2015	12	19	18	2	22	0.65	-0.138	3.93	0.01	0.007	0	25.8	30.5	77	99	110	0	39	39
2015	12	19	18	12	22	0.63	-0.115	3.93	0.01	0.007	0	24.1	27.5	77	94	103	0	38	39
2015	12	19	18	22	22	0.679	-0.135	3.93	0.01	0.007	0	37	40.9	76.5	124	133	0	38	38
2015	12	19	18	32	22	0.64	-0.121	3.934	0.016	0.013	0	27.5	31.4	77	102	112	0	38	39
2015	12	19	18	42	22	0.633	-0.144	3.93	0.01	0.007	0	27.5	31.4	76.5	102	112	0	38	39
2015	12	19	18	52	22	0.64	-0.121	3.934	0.01	0.007	0	26.2	30.1	77.4	99	109	0	38	39
2015	12	19	19	2	22	0.663	-0.174	3.93	0.013	0.01	0	26.7	30.1	77	100	109	0	38	39
2015	12	19	19	12	22	0.643	-0.144	3.93	0.01	0.007	0	24.5	28.4	76.5	95	105	0	38	39
2015	12	19	19	22	22	0.643	-0.135	3.934	0.01	0.007	0	24.1	28	77	94	104	0	38	39
2015	12	19	19	32	22	0.63	-0.151	3.934	0.01	0.007	0	24.9	29.2	76.5	96	107	0	38	39
2015	12	19	19	42	22	0.643	-0.135	3.93	0.013	0.01	0	24.5	28	77	95	104	0	38	39
2015	12	19	19	52	22	0.623	-0.141	3.934	0.01	0.007	0	26.7	31.4	76.5	101	112	0	39	39
2015	12	19	20	2	22	0.627	-0.125	3.93	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	19	20	12	22	0.65	-0.141	3.93	0.01	0.007	0	25.8	29.2	77.4	97	107	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	20	22	22	0.643	-0.138	3.934	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	19	20	32	22	0.64	-0.121	3.93	0.01	0.007	0	23.6	27.1	76.5	93	103	0	38	40
2015	12	19	20	42	22	0.627	-0.154	3.93	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	19	20	52	22	0.65	-0.121	3.93	0.01	0.007	0	26.2	30.1	76.5	99	109	0	38	39
2015	12	19	21	2	22	0.633	-0.108	3.93	0.016	0.013	0	23.6	28	76.1	93	104	0	38	39
2015	12	19	21	12	22	0.627	-0.128	3.93	0.01	0.007	0	24.9	28.8	76.1	96	106	0	38	39
2015	12	19	21	22	22	0.62	-0.131	3.93	0.01	0.007	0	26.7	30.5	76.5	100	110	0	38	39
2015	12	19	21	32	22	0.646	-0.125	3.93	0.01	0.007	0	25.4	29.7	77	97	108	0	38	39
2015	12	19	21	42	22	0.636	-0.161	3.93	0.01	0.007	0	24.1	28	76.5	94	104	0	38	39
2015	12	19	21	52	22	0.65	-0.125	3.93	0.01	0.007	0	23.2	27.1	77.4	92	102	0	38	39
2015	12	19	22	2	22	0.63	-0.121	3.934	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	19	22	12	22	0.663	-0.154	3.934	0.01	0.007	0	24.9	28.8	76.5	96	106	0	38	39
2015	12	19	22	22	22	0.653	-0.138	3.93	0.01	0.007	0	26.2	30.1	76.1	99	109	0	38	39
2015	12	19	22	32	22	0.65	-0.138	3.93	0.01	0.007	0	25.8	29.7	76.5	98	108	0	38	39
2015	12	19	22	42	22	0.633	-0.135	3.93	0.01	0.007	0	23.6	27.5	76.5	93	103	0	38	39
2015	12	19	22	52	22	0.607	-0.128	3.93	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	19	23	2	22	0.627	-0.128	3.93	0.01	0.007	0	23.6	27.1	76.5	92	102	0	37	39
2015	12	19	23	12	22	0.604	-0.131	3.93	0.013	0.01	0	21.5	25.8	76.5	89	99	0	39	39
2015	12	19	23	22	22	0.61	-0.115	3.934	0.013	0.01	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	19	23	32	22	0.623	-0.131	3.93	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	19	23	42	22	0.633	-0.115	3.93	0.01	0.007	0	24.5	28	76.5	95	105	0	38	40
2015	12	19	23	52	22	0.653	-0.154	3.93	0.01	0.007	0	28.4	33.1	77	105	116	0	39	39
2015	12	20	0	2	22	0.633	-0.138	3.93	0.01	0.007	0	22.8	26.7	77.4	92	102	0	39	40
2015	12	20	0	12	22	0.633	-0.121	3.93	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	20	0	22	22	0.623	-0.112	3.93	0.01	0.007	0	22.8	26.2	77	91	101	0	38	40
2015	12	20	0	32	22	0.627	-0.125	3.93	0.01	0.007	0	22.8	27.1	76.5	91	101	0	38	38
2015	12	20	0	42	22	0.63	-0.125	3.93	0.01	0.007	0	25.4	29.7	76.5	97	108	0	38	39
2015	12	20	0	52	22	0.669	-0.148	3.93	0.01	0.007	0	22.8	26.2	77	91	101	0	38	40
2015	12	20	1	2	22	0.633	-0.115	3.93	0.01	0.007	0	24.5	29.2	76.1	96	107	0	39	39
2015	12	20	1	12	22	0.643	-0.138	3.93	0.01	0.007	0	25.4	29.2	77.4	97	107	0	38	39
2015	12	20	1	22	22	0.607	-0.128	3.93	0.01	0.007	0	23.6	27.5	77	93	103	0	38	39
2015	12	20	1	32	22	0.63	-0.151	3.93	0.01	0.007	0	22.4	26.7	77	91	101	0	39	39
2015	12	20	1	42	22	0.64	-0.131	3.93	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	20	1	52	22	0.623	-0.112	3.93	0.01	0.007	0	23.2	27.1	77	92	103	0	38	40
2015	12	20	2	2	22	0.62	-0.125	3.93	0.01	0.007	0	23.2	27.5	76.5	92	103	0	38	39
2015	12	20	2	12	22	0.636	-0.128	3.93	0.01	0.007	0	22.8	26.7	76.5	91	101	0	38	39
2015	12	20	2	22	22	0.561	-0.203	3.93	0.01	0.007	0	23.2	27.1	77	92	102	0	38	39
2015	12	20	2	32	22	0.6	-0.112	3.93	0.01	0.007	0	24.9	27.1	77	96	103	0	38	40
2015	12	20	2	42	22	0.6	-0.135	3.93	0.01	0.007	0	23.2	27.1	76.5	92	102	0	38	39
2015	12	20	2	52	22	0.643	-0.138	3.93	0.01	0.007	0	24.1	28	77	94	105	0	38	40
2015	12	20	3	2	22	0.643	-0.112	3.93	0.01	0.007	0	25.8	30.1	76.5	99	109	0	39	39
2015	12	20	3	12	22	0.64	-0.131	3.93	0.01	0.007	0	28.8	33.1	76.5	106	116	0	39	39
2015	12	20	3	22	22	0.659	-0.128	3.93	0.01	0.007	0	39.6	43.4	71.4	130	141	0	38	40
2015	12	20	3	32	22	0.646	-0.125	3.934	0.01	0.007	0	26.7	31	75.7	101	111	0	39	39
2015	12	20	3	42	22	0.643	-0.125	3.934	0.01	0.007	0	24.9	29.2	75.3	96	107	0	38	39
2015	12	20	3	52	22	0.643	-0.118	3.937	0.01	0.007	0	22.8	26.7	72.7	92	102	0	39	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	4	2	22	0.663	-0.135	3.94	0.01	0.007	0	28	31.4	62.4	103	112	0	38	39
2015	12	20	4	12	22	0.627	-0.144	3.937	0.01	0.007	0	27.1	31	64.5	101	111	0	38	39
2015	12	20	4	22	22	0.65	-0.161	3.94	0.01	0.007	0	27.5	31	67.1	102	112	0	38	40
2015	12	20	4	32	22	0.62	-0.167	3.94	0.01	0.007	0	25.8	30.1	58.9	99	109	0	39	39
2015	12	20	4	42	22	0.584	-0.108	3.937	0.01	0.007	0	23.6	27.5	74	93	102	0	38	38
2015	12	20	4	52	22	0.587	-0.148	3.937	0.01	0.007	0	23.2	25.8	77	92	100	0	38	40
2015	12	20	5	2	22	0.581	-0.177	3.937	0.01	0.007	0	23.6	26.2	67.1	93	101	0	38	40
2015	12	20	5	12	22	0.561	-0.194	3.937	0.01	0.007	0	23.2	25.8	73.5	92	99	0	38	39
2015	12	20	5	22	22	0.62	-0.128	3.94	0.01	0.007	0	23.6	26.2	73.1	93	100	0	38	39
2015	12	20	5	32	22	0.617	-0.112	3.937	0.01	0.007	0	22.8	25.4	70.1	91	99	0	38	40
2015	12	20	5	42	22	0.538	-0.164	3.937	0.01	0.007	0	23.2	26.2	67.5	92	100	0	38	39
2015	12	20	5	52	22	0.505	-0.167	3.937	0.01	0.007	0	23.6	26.2	71	93	100	0	38	39
2015	12	20	6	2	22	0.584	-0.026	3.937	0.01	0.007	0	23.6	26.7	70.5	93	101	0	38	39
2015	12	20	6	12	22	0.531	-0.125	3.94	0.01	0.007	0	22.8	26.7	69.2	92	101	0	39	39
2015	12	20	6	22	22	0.43	-0.072	3.937	0.01	0.007	0	23.6	26.2	77.4	93	100	0	38	39
2015	12	20	6	32	22	0.633	-0.131	3.94	0.01	0.007	0	23.6	26.2	69.7	93	101	0	38	40
2015	12	20	6	42	22	0.443	-0.197	3.937	0.01	0.007	0	22.8	26.7	72.7	92	101	0	39	39
2015	12	20	6	52	22	0.502	-0.197	3.937	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	20	7	2	22	0.489	-0.089	3.94	0.01	0.007	0	23.2	27.1	73.5	93	102	0	39	39
2015	12	20	7	12	22	0.361	-0.367	3.937	0.01	0.007	0	24.1	27.1	74	94	102	0	38	39
2015	12	20	7	22	22	0.433	-0.256	3.937	0.01	0.007	0	24.1	26.7	71.8	94	102	0	38	40
2015	12	20	7	32	22	0.509	0.003	3.937	0.01	0.007	0	24.1	27.1	62.8	94	102	0	38	39
2015	12	20	7	42	22	0.568	-0.059	3.94	0.01	0.007	0	24.5	27.5	74.4	95	103	0	38	39
2015	12	20	7	52	22	0.308	-0.246	3.94	0.01	0.007	0	24.1	27.5	71	94	103	0	38	39
2015	12	20	8	2	22	0.407	-0.282	3.944	0.01	0.007	0	24.5	27.5	66.2	95	104	0	38	40
2015	12	20	8	12	22	0.597	-0.112	3.94	0.013	0.01	0	24.5	28	71.4	95	104	0	38	39
2015	12	20	8	22	22	0.673	-0.308	3.94	0.01	0.007	0	25.4	26.7	67.9	96	102	0	37	40
2015	12	20	8	32	22	0.554	-0.128	3.94	0.013	0.01	0	23.6	27.5	70.1	94	103	0	39	39
2015	12	20	8	42	22	0.902	-0.043	3.94	0.01	0.007	0	24.5	27.5	76.5	95	103	0	38	39
2015	12	20	8	52	22	0.443	-0.253	3.94	0.01	0.007	0	24.1	27.1	79.1	94	103	0	38	40
2015	12	20	9	2	22	0.446	0.174	3.94	0.01	0.007	0	24.1	28.8	77.8	94	106	0	38	39
2015	12	20	9	12	22	0.696	-0.338	3.944	0.01	0.007	0	23.6	27.1	82.6	93	102	0	38	39
2015	12	20	9	22	22	0.495	-0.062	3.944	0.01	0.007	0	24.5	28.4	80	95	105	0	38	39
2015	12	20	9	32	22	0.676	-0.026	3.94	0.016	0.016	0	24.9	27.5	80	96	103	0	38	39
2015	12	20	9	42	22	0.492	-0.223	3.937	0.01	0.007	0	24.5	27.1	76.1	95	103	0	38	40
2015	12	20	9	52	22	0.472	-0.509	3.937	0.01	0.007	0	25.8	27.5	71.8	98	103	0	38	39
2015	12	20	10	2	22	0.482	-0.213	3.947	0.01	0.007	0	24.5	27.5	75.7	95	103	0	38	39
2015	12	20	10	12	22	0.633	-0.256	3.944	0.01	0.007	0	25.4	27.5	80.4	96	103	0	37	39
2015	12	20	10	22	22	0.413	-0.308	3.94	0.01	0.007	0	24.5	28	80.4	95	104	0	38	39
2015	12	20	10	32	22	0.364	-0.2	3.94	0.01	0.007	0	24.5	27.1	80	95	102	0	38	39
2015	12	20	10	42	22	0.358	-0.217	3.94	0.016	0.016	0	24.5	28	77	95	104	0	38	39
2015	12	20	10	52	22	0.512	-0.066	3.937	0.01	0.007	0	25.4	27.5	66.7	96	103	0	37	39
2015	12	20	11	2	22	0.459	-0.41	3.94	0.01	0.007	0	24.9	28.4	65.8	96	105	0	38	39
2015	12	20	11	12	22	0.44	-0.272	3.944	0.01	0.007	0	24.9	27.5	66.2	96	103	0	38	39
2015	12	20	11	22	22	0.541	-0.217	3.934	0.01	0.007	0	25.4	25.4	73.5	97	98	0	38	39
2015	12	20	11	32	22	0.472	-0.289	3.93	0.01	0.007	0	25.4	24.9	73.1	97	97	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	11	42	22	0.433	-0.328	3.927	0.01	0.007	0	24.5	24.9	73.1	95	97	0	38	39
2015	12	20	11	52	22	0.673	-0.089	3.927	0.01	0.007	0	27.1	26.7	73.1	101	101	0	38	39
2015	12	20	12	2	22	0.692	-0.079	3.93	0.01	0.007	0	25.8	25.4	73.1	98	98	0	38	39
2015	12	20	12	12	22	0.653	-0.102	3.93	0.01	0.007	0	24.9	25.4	73.1	97	98	0	39	39
2015	12	20	12	22	22	0.43	-0.295	3.927	0.013	0.01	0	25.4	25.4	72.7	96	98	0	37	39
2015	12	20	12	32	22	0.712	-0.056	3.927	0.01	0.007	0	24.9	25.4	72.2	96	98	0	38	39
2015	12	20	12	42	22	0.653	-0.112	3.93	0.01	0.007	0	24.5	24.9	72.2	96	97	0	39	39
2015	12	20	12	52	22	0.44	-0.282	3.927	0.01	0.007	0	24.9	24.9	72.2	96	97	0	38	39
2015	12	20	13	2	22	0.636	-0.148	3.927	0.01	0.007	0	25.4	25.4	73.1	96	97	0	37	38
2015	12	20	13	12	22	0.43	-0.315	3.927	0.01	0.007	0	25.4	25.4	72.7	97	98	0	38	39
2015	12	20	13	22	22	0.482	-0.249	3.927	0.01	0.007	0	25.4	24.9	72.7	97	97	0	38	39
2015	12	20	13	32	22	0.456	-0.308	3.927	0.01	0.007	0	25.4	24.9	72.7	97	97	0	38	39
2015	12	20	13	42	22	0.62	-0.148	3.927	0.01	0.007	0	21.9	25.4	72.2	89	98	0	38	39
2015	12	20	13	52	22	0.61	-0.138	3.924	0.01	0.007	0	21.5	24.9	72.7	88	97	0	38	39
2015	12	20	14	2	22	0.6	-0.131	3.924	0.01	0.007	0	21.5	24.9	72.7	88	97	0	38	39
2015	12	20	14	12	22	0.63	-0.131	3.921	0.01	0.007	0	21.5	25.4	72.7	88	98	0	38	39
2015	12	20	14	22	22	0.581	-0.151	3.917	0.01	0.007	0	21.5	24.9	72.2	88	97	0	38	39
2015	12	20	14	32	22	0.614	-0.135	3.917	0.01	0.007	0	21.9	25.4	73.1	89	98	0	38	39
2015	12	20	14	42	22	0.614	-0.135	3.914	0.01	0.007	0	21.9	25.4	71.8	89	98	0	38	39
2015	12	20	14	52	22	0.636	-0.131	3.914	0.01	0.007	0	21.5	25.4	73.5	88	97	0	38	38
2015	12	20	15	2	22	0.623	-0.151	3.911	0.01	0.007	0	21.1	24.9	73.5	87	97	0	38	39
2015	12	20	15	12	22	0.636	-0.154	3.911	0.01	0.007	0	21.1	24.5	73.1	87	96	0	38	39
2015	12	20	15	22	22	0.646	-0.112	3.907	0.01	0.007	0	21.5	25.4	73.1	88	98	0	38	39
2015	12	20	15	32	22	0.604	-0.157	3.907	0.01	0.007	0	21.1	24.9	74	87	97	0	38	39
2015	12	20	15	42	22	0.587	-0.125	3.907	0.01	0.007	0	21.1	24.9	68.4	88	97	0	39	39
2015	12	20	15	52	22	0.623	-0.148	3.907	0.01	0.007	0	21.1	24.9	64.1	87	97	0	38	39
2015	12	20	16	2	22	0.64	-0.161	3.907	0.01	0.007	0	21.1	24.5	73.1	87	97	0	38	40
2015	12	20	16	12	22	0.627	-0.151	3.907	0.01	0.007	0	21.5	24.9	74	88	97	0	38	39
2015	12	20	16	22	22	0.633	-0.144	3.907	0.01	0.007	0	21.1	24.5	73.5	87	97	0	38	40
2015	12	20	16	32	22	0.61	-0.138	3.907	0.01	0.007	0	21.5	24.9	73.5	88	97	0	38	39
2015	12	20	16	42	22	0.623	-0.151	3.907	0.01	0.007	0	21.1	24.9	73.5	87	97	0	38	39
2015	12	20	16	52	22	0.607	-0.125	3.907	0.01	0.007	0	21.9	25.4	74	89	98	0	38	39
2015	12	20	17	2	22	0.61	-0.118	3.904	0.01	0.007	0	21.1	24.9	74	87	97	0	38	39
2015	12	20	17	12	22	0.597	-0.138	3.904	0.01	0.007	0	21.5	25.4	74	88	98	0	38	39
2015	12	20	17	22	22	0.636	-0.161	3.907	0.01	0.007	0	21.1	25.4	74	88	98	0	39	39
2015	12	20	17	32	22	0.646	-0.125	3.904	0.01	0.007	0	21.5	24.9	74.4	88	97	0	38	39
2015	12	20	17	42	22	0.62	-0.167	3.907	0.01	0.007	0	21.5	24.9	74	88	97	0	38	39
2015	12	20	17	52	22	0.61	-0.151	3.904	0.01	0.007	0	21.5	25.4	74.4	88	98	0	38	39
2015	12	20	18	2	22	0.607	-0.167	3.904	0.01	0.007	0	21.5	24.9	74.4	88	97	0	38	39
2015	12	20	18	12	22	0.61	-0.131	3.904	0.01	0.007	0	22.4	25.8	74	91	100	0	39	40
2015	12	20	18	22	22	0.63	-0.138	3.904	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	20	18	32	22	0.633	-0.151	3.907	0.01	0.007	0	23.6	27.5	74.4	93	103	0	38	39
2015	12	20	18	42	22	0.633	-0.151	3.904	0.013	0.01	0	25.8	29.2	74.4	98	108	0	38	40
2015	12	20	18	52	22	0.627	-0.118	3.904	0.01	0.007	0	26.2	30.1	74.8	99	109	0	38	39
2015	12	20	19	2	22	0.617	-0.135	3.904	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	20	19	12	22	0.617	-0.144	3.904	0.01	0.007	0	22.4	25.4	74.8	90	98	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	19	22	22	0.646	-0.141	3.904	0.01	0.007	0	21.9	25.4	74.8	89	98	0	38	39
2015	12	20	19	32	22	0.617	-0.161	3.904	0.01	0.007	0	22.4	25.8	74.4	90	100	0	38	40
2015	12	20	19	42	22	0.65	-0.138	3.904	0.01	0.007	0	21.9	26.2	74.8	89	99	0	38	38
2015	12	20	19	52	22	0.633	-0.138	3.904	0.01	0.007	0	21.9	25.4	74.8	89	98	0	38	39
2015	12	20	20	2	22	0.636	-0.151	3.904	0.01	0.007	0	21.9	24.9	74.8	89	97	0	38	39
2015	12	20	20	12	22	0.633	-0.131	3.904	0.01	0.007	0	25.8	29.2	74.4	99	108	0	39	40
2015	12	20	20	22	22	0.597	-0.138	3.904	0.01	0.007	0	23.6	27.1	74.4	93	102	0	38	39
2015	12	20	20	32	22	0.627	-0.144	3.904	0.01	0.007	0	22.8	26.7	74.8	92	101	0	39	39
2015	12	20	20	42	22	0.659	-0.151	3.904	0.01	0.007	0	22.8	26.2	74.8	91	100	0	38	39
2015	12	20	20	52	22	0.617	-0.118	3.904	0.01	0.007	0	22.4	25.4	74.8	90	98	0	38	39
2015	12	20	21	2	22	0.623	-0.161	3.904	0.01	0.007	0	23.2	27.1	74.4	92	102	0	38	39
2015	12	20	21	12	22	0.627	-0.151	3.904	0.01	0.007	0	27.5	31.4	74.8	102	112	0	38	39
2015	12	20	21	22	22	0.633	-0.135	3.904	0.01	0.007	0	24.1	27.5	74.8	94	103	0	38	39
2015	12	20	21	32	22	0.64	-0.157	3.904	0.01	0.007	0	22.8	26.7	74.8	91	101	0	38	39
2015	12	20	21	42	22	0.669	-0.125	3.904	0.01	0.007	0	22.4	25.8	74	90	99	0	38	39
2015	12	20	21	52	22	0.571	-0.187	3.904	0.01	0.007	0	22.4	25.8	74.4	91	99	0	39	39
2015	12	20	22	2	22	0.581	-0.184	3.904	0.01	0.007	0	23.2	25.4	74.4	92	98	0	38	39
2015	12	20	22	12	22	0.528	-0.226	3.904	0.01	0.007	0	24.1	25.4	74.4	94	98	0	38	39
2015	12	20	22	22	22	0.577	-0.21	3.904	0.01	0.007	0	25.4	28	74.4	97	104	0	38	39
2015	12	20	22	32	22	0.499	-0.246	3.904	0.01	0.007	0	26.7	29.2	74.8	100	106	0	38	38
2015	12	20	22	42	22	0.643	-0.092	3.904	0.01	0.007	0	28.4	30.5	74	104	110	0	38	39
2015	12	20	22	52	22	0.574	-0.164	3.904	0.01	0.007	0	25.8	27.1	74.4	98	102	0	38	39
2015	12	20	23	2	22	0.522	-0.233	3.904	0.01	0.007	0	24.9	25.8	73.1	96	100	0	38	40
2015	12	20	23	12	22	0.577	-0.138	3.904	0.01	0.007	0	25.8	26.7	74	98	101	0	38	39
2015	12	20	23	22	22	0.646	-0.112	3.904	0.01	0.007	0	25.8	26.7	74	98	102	0	38	40
2015	12	20	23	32	22	0.558	-0.217	3.904	0.013	0.01	0	25.8	26.7	74	98	102	0	38	40
2015	12	20	23	42	22	0.535	-0.23	3.904	0.01	0.007	0	26.7	27.5	74	100	103	0	38	39
2015	12	20	23	52	22	0.571	-0.157	3.904	0.01	0.007	0	25.8	26.7	74	98	101	0	38	39
2015	12	21	0	2	22	0.551	-0.19	3.904	0.016	0.013	0	25.8	25.8	74	98	99	0	38	39
2015	12	21	0	12	22	0.554	-0.21	3.904	0.01	0.007	0	31.4	31.8	73.1	111	114	0	38	40
2015	12	21	0	22	22	0.554	-0.249	3.904	0.01	0.007	0	29.2	30.5	72.2	106	110	0	38	39
2015	12	21	0	32	22	0.466	-0.115	3.904	0.01	0.007	0	25.8	26.7	72.2	98	101	0	38	39
2015	12	21	0	42	22	0.545	-0.177	3.907	0.01	0.007	0	25.4	26.2	71.4	97	100	0	38	39
2015	12	21	0	52	22	0.581	-0.177	3.907	0.01	0.007	0	25.4	26.7	71.4	97	101	0	38	39
2015	12	21	1	2	22	0.548	-0.207	3.907	0.013	0.01	0	25.8	27.1	71.4	98	102	0	38	39
2015	12	21	1	12	22	0.472	-0.194	3.907	0.01	0.007	0	26.2	27.1	67.9	99	103	0	38	40
2015	12	21	1	22	22	0.531	-0.174	3.904	0.013	0.01	0	25.4	27.1	66.7	97	102	0	38	39
2015	12	21	1	32	22	0.525	-0.105	3.904	0.01	0.007	0	24.9	27.1	67.5	96	102	0	38	39
2015	12	21	1	42	22	0.495	-0.226	3.904	0.01	0.007	0	25.8	27.1	67.5	98	103	0	38	40
2015	12	21	1	52	22	0.482	-0.184	3.907	0.01	0.007	0	26.2	28.4	67.9	99	105	0	38	39
2015	12	21	2	2	22	0.643	-0.23	3.907	0.01	0.007	0	25.8	28	68.8	98	104	0	38	39
2015	12	21	2	12	22	0.551	-0.138	3.907	0.01	0.007	0	25.4	28	68.4	97	103	0	38	38
2015	12	21	2	22	22	0.509	-0.167	3.907	0.01	0.007	0	25.8	28	68.8	98	104	0	38	39
2015	12	21	2	32	22	0.62	-0.118	3.907	0.01	0.007	0	24.5	29.2	69.2	96	108	0	39	40
2015	12	21	2	42	22	0.594	-0.059	3.907	0.01	0.007	0	24.5	29.2	69.7	96	108	0	39	40
2015	12	21	2	52	22	0.512	-0.039	3.907	0.01	0.007	0	23.2	28.4	69.2	93	105	0	39	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	3	2	22	0.607	-0.098	3.907	0.01	0.007	0	29.7	34	69.2	107	118	0	38	39
2015	12	21	3	12	22	0.558	-0.075	3.907	0.01	0.007	0	28.4	32.3	69.7	104	115	0	38	40
2015	12	21	3	22	22	0.591	-0.075	3.907	0.01	0.007	0	23.6	28.4	70.1	93	105	0	38	39
2015	12	21	3	32	22	0.646	-0.112	3.907	0.01	0.007	0	34	38.3	69.7	117	128	0	38	39
2015	12	21	3	42	22	0.61	-0.082	3.907	0.01	0.007	0	24.9	29.7	70.5	96	109	0	38	40
2015	12	21	3	52	22	0.646	-0.135	3.907	0.01	0.007	0	24.9	28.4	68.8	95	105	0	37	39
2015	12	21	4	2	22	0.643	-0.144	3.907	0.01	0.007	0	25.8	29.7	68.8	98	108	0	38	39
2015	12	21	4	12	22	0.623	-0.141	3.907	0.01	0.007	0	23.6	27.5	67.9	93	103	0	38	39
2015	12	21	4	22	22	0.61	-0.138	3.911	0.01	0.007	0	21.9	26.2	68.4	90	100	0	39	39
2015	12	21	4	32	22	0.617	-0.125	3.911	0.01	0.007	0	22.4	26.2	67.5	90	100	0	38	39
2015	12	21	4	42	22	0.63	-0.131	3.914	0.01	0.007	0	21.5	25.8	68.8	89	99	0	39	39
2015	12	21	4	52	22	0.62	-0.151	3.914	0.01	0.007	0	21.9	25.4	68.8	89	99	0	38	40
2015	12	21	5	2	22	0.6	-0.164	3.917	0.01	0.007	0	21.9	25.4	69.7	89	98	0	38	39
2015	12	21	5	12	22	0.564	-0.187	3.917	0.01	0.007	0	21.9	25.4	68.4	89	98	0	38	39
2015	12	21	5	22	22	0.571	-0.141	3.921	0.01	0.007	0	22.4	25.4	67.9	89	98	0	37	39
2015	12	21	5	32	22	0.568	-0.164	3.921	0.01	0.007	0	21.9	25.4	68.8	89	98	0	38	39
2015	12	21	5	42	22	0.551	-0.131	3.921	0.01	0.007	0	21.5	25.4	69.2	89	98	0	39	39
2015	12	21	5	52	22	0.492	-0.19	3.921	0.01	0.007	0	21.9	25.8	69.2	89	99	0	38	39
2015	12	21	6	2	22	0.581	-0.148	3.921	0.01	0.007	0	22.4	25.4	69.2	90	98	0	38	39
2015	12	21	6	12	22	0.509	-0.217	3.921	0.01	0.007	0	22.4	25.4	69.7	90	99	0	38	40
2015	12	21	6	22	22	0.499	-0.236	3.924	0.01	0.007	0	22.8	26.2	69.7	91	99	0	38	38
2015	12	21	6	32	22	0.591	-0.125	3.924	0.013	0.01	0	22.4	25.8	69.7	90	100	0	38	40
2015	12	21	6	42	22	0.531	-0.194	3.924	0.01	0.007	0	22.4	26.7	71	91	101	0	39	39
2015	12	21	6	52	22	0.643	-0.213	3.924	0.01	0.007	0	21.9	26.7	71	90	101	0	39	39
2015	12	21	7	2	22	0.541	0.115	3.924	0.01	0.007	0	22.8	27.1	70.5	91	102	0	38	39
2015	12	21	7	12	22	0.659	-0.082	3.927	0.01	0.007	0	22.8	26.2	71.4	91	100	0	38	39
2015	12	21	7	22	22	0.325	-0.157	3.927	0.01	0.007	0	22.4	26.2	70.1	90	100	0	38	39
2015	12	21	7	32	22	0.486	-0.092	3.93	0.01	0.007	0	23.6	26.2	71	93	100	0	38	39
2015	12	21	7	42	22	0.571	-0.138	3.93	0.01	0.007	0	23.6	25.8	71.4	94	99	0	39	39
2015	12	21	7	52	22	0.525	-0.043	3.934	0.01	0.007	0	24.1	27.1	68.8	93	102	0	37	39
2015	12	21	8	2	22	0.518	-0.167	3.934	0.013	0.01	0	23.2	26.7	71.4	92	101	0	38	39
2015	12	21	8	12	22	0.509	-0.131	3.934	0.01	0.007	0	23.6	26.7	67.5	93	101	0	38	39
2015	12	21	8	22	22	0.351	0	3.934	0.01	0.007	0	23.2	26.2	70.1	93	100	0	39	39
2015	12	21	8	32	22	0.554	-0.098	3.937	0.01	0.007	0	24.1	27.1	61.1	94	102	0	38	39
2015	12	21	8	42	22	0.659	-0.138	3.937	0.01	0.007	0	24.5	27.1	64.5	95	102	0	38	39
2015	12	21	8	52	22	0.561	-0.138	3.94	0.01	0.007	0	24.5	27.1	67.1	95	102	0	38	39
2015	12	21	9	2	22	0.344	0.039	3.944	0.01	0.007	0	24.1	27.5	65.4	95	103	0	39	39
2015	12	21	9	12	22	0.4	-0.112	3.94	0.01	0.007	0	24.5	27.1	68.4	95	103	0	38	40
2015	12	21	9	22	22	0.722	-0.079	3.944	0.01	0.007	0	23.6	26.2	66.7	93	101	0	38	40
2015	12	21	9	32	22	0.764	-0.479	3.94	0.01	0.007	0	24.1	26.7	64.5	94	101	0	38	39
2015	12	21	9	42	22	0.856	-0.246	3.94	0.01	0.007	0	24.1	26.7	59.8	94	101	0	38	39
2015	12	21	9	52	22	0.676	-0.276	3.94	0.01	0.007	0	23.6	27.5	64.1	94	103	0	39	39
2015	12	21	10	2	22	0.505	-0.262	3.94	0.01	0.007	0	24.1	26.7	65.4	94	101	0	38	39
2015	12	21	10	12	22	0.85	-0.164	3.94	0.01	0.007	0	24.1	28	67.1	94	104	0	38	39
2015	12	21	10	22	22	0.525	0.108	3.944	0.01	0.007	0	23.6	27.1	66.2	94	102	0	39	39
2015	12	21	10	32	22	0.449	-0.03	3.944	0.01	0.007	0	24.5	26.7	58.9	95	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	10	42	22	0.302	0.108	3.944	0.01	0.007	0	24.1	27.5	64.5	94	103	0	38	39
2015	12	21	10	52	22	0.522	-0.213	3.944	0.01	0.007	0	23.6	26.7	64.9	94	101	0	39	39
2015	12	21	11	2	22	0.515	-0.013	3.947	0.01	0.007	0	23.2	26.7	61.9	93	101	0	39	39
2015	12	21	11	12	22	0.676	-0.089	3.944	0.01	0.007	0	24.5	27.1	61.9	95	102	0	38	39
2015	12	21	11	22	22	0.489	-0.18	3.944	0.01	0.007	0	23.6	27.5	62.8	93	104	0	38	40
2015	12	21	11	32	22	0.476	-0.22	3.944	0.01	0.007	0	24.5	27.1	61.5	95	102	0	38	39
2015	12	21	11	42	22	0.354	-0.052	3.944	0.01	0.007	0	23.6	27.5	64.5	94	102	0	39	38
2015	12	21	11	52	22	0.449	-0.177	3.94	0.01	0.007	0	24.9	28	67.9	95	103	0	37	38
2015	12	21	12	2	22	0.476	-0.154	3.937	0.01	0.007	0	24.5	28.8	68.8	95	105	0	38	38
2015	12	21	12	12	22	0.449	-0.03	3.937	0.01	0.007	0	28	32.7	72.7	103	115	0	38	39
2015	12	21	12	22	22	0.479	-0.164	3.937	0.013	0.01	0	24.9	28.4	74.8	96	105	0	38	39
2015	12	21	12	32	22	0.591	-0.315	3.934	0.01	0.007	0	25.8	30.1	74	99	109	0	39	39
2015	12	21	12	42	22	0.715	-0.312	3.934	0.01	0.007	0	26.2	29.2	74.8	99	107	0	38	39
2015	12	21	12	52	22	0.535	-0.062	3.934	0.013	0.01	0	24.9	28.4	74.8	96	105	0	38	39
2015	12	21	13	2	22	0.469	-0.217	3.93	0.01	0.007	0	25.4	28	74.4	97	104	0	38	39
2015	12	21	13	12	22	0.646	-0.177	3.93	0.01	0.007	0	24.5	25.8	75.3	94	100	0	37	40
2015	12	21	13	22	22	0.666	-0.095	3.93	0.01	0.007	0	24.5	25.8	74.8	94	99	0	37	39
2015	12	21	13	32	22	0.574	-0.144	3.93	0.01	0.007	0	24.1	25.4	74.8	94	98	0	38	39
2015	12	21	13	42	22	0.705	-0.072	3.93	0.01	0.007	0	24.5	26.2	75.7	95	100	0	38	39
2015	12	21	13	52	22	0.489	-0.253	3.93	0.01	0.007	0	24.1	25.8	74.4	94	99	0	38	39
2015	12	21	14	2	22	0.43	-0.341	3.93	0.01	0.007	0	24.5	26.7	74.4	95	101	0	38	39
2015	12	21	14	12	22	0.617	-0.144	3.93	0.01	0.007	0	24.5	26.2	75.7	95	100	0	38	39
2015	12	21	14	22	22	0.554	-0.24	3.93	0.01	0.007	0	23.6	25.4	75.3	94	99	0	39	40
2015	12	21	14	32	22	0.515	-0.285	3.93	0.01	0.007	0	23.6	25.4	75.7	93	98	0	38	39
2015	12	21	14	42	22	0.561	-0.217	3.93	0.01	0.007	0	24.1	26.2	75.7	94	100	0	38	39
2015	12	21	14	52	22	0.374	-0.387	3.93	0.01	0.007	0	23.2	24.9	75.3	93	98	0	39	40
2015	12	21	15	2	22	0.463	-0.308	3.93	0.01	0.007	0	23.6	25.4	74.8	93	98	0	38	39
2015	12	21	15	12	22	0.528	-0.249	3.927	0.01	0.007	0	23.6	25.8	75.3	93	99	0	38	39
2015	12	21	15	22	22	0.489	-0.308	3.93	0.01	0.007	0	24.1	26.7	75.3	95	101	0	39	39
2015	12	21	15	32	22	0.646	-0.164	3.927	0.01	0.007	0	24.1	26.2	75.7	94	100	0	38	39
2015	12	21	15	42	22	0.525	-0.246	3.927	0.01	0.007	0	24.1	27.1	74.8	95	101	0	39	38
2015	12	21	15	52	22	0.554	-0.246	3.927	0.01	0.007	0	23.6	25.4	74.4	93	99	0	38	40
2015	12	21	16	2	22	0.623	-0.112	3.927	0.01	0.007	0	23.6	25.4	74	93	98	0	38	39
2015	12	21	16	12	22	0.449	-0.312	3.927	0.01	0.007	0	23.6	25.8	74.4	93	99	0	38	39
2015	12	21	16	22	22	0.44	-0.292	3.927	0.01	0.007	0	23.6	25.8	74.8	93	99	0	38	39
2015	12	21	16	32	22	0.581	-0.2	3.927	0.01	0.007	0	23.2	25.4	75.3	92	98	0	38	39
2015	12	21	16	42	22	0.61	-0.187	3.927	0.01	0.007	0	23.2	25.4	75.7	92	98	0	38	39
2015	12	21	16	52	22	0.554	-0.223	3.927	0.01	0.007	0	23.2	25.8	76.1	92	98	0	38	38
2015	12	21	17	2	22	0.597	-0.21	3.927	0.01	0.007	0	24.1	25.8	76.1	94	99	0	38	39
2015	12	21	17	12	22	0.61	-0.141	3.927	0.01	0.007	0	28	30.1	75.7	102	109	0	37	39
2015	12	21	17	22	22	0.591	-0.174	3.927	0.01	0.007	0	27.5	30.1	75.3	102	109	0	38	39
2015	12	21	17	32	22	0.538	-0.24	3.927	0.01	0.007	0	24.9	28	76.1	97	104	0	39	39
2015	12	21	17	42	22	0.61	-0.171	3.927	0.013	0.01	0	26.7	29.7	76.1	100	108	0	38	39
2015	12	21	17	52	22	0.656	-0.154	3.927	0.01	0.007	0	29.2	32.3	76.1	106	114	0	38	39
2015	12	21	18	2	22	0.594	-0.24	3.93	0.01	0.007	0	27.5	30.1	75.7	101	109	0	37	39
2015	12	21	18	12	22	0.515	-0.256	3.927	0.01	0.007	0	26.2	28.4	76.5	99	105	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	18	22	22	0.636	-0.128	3.93	0.01	0.007	0	28.4	31	75.7	104	111	0	38	39
2015	12	21	18	32	22	0.594	-0.21	3.93	0.01	0.007	0	25.4	28	76.5	97	103	0	38	38
2015	12	21	18	42	22	0.587	-0.24	3.93	0.013	0.01	0	24.5	26.7	76.1	95	101	0	38	39
2015	12	21	18	52	22	0.545	-0.24	3.93	0.013	0.01	0	24.5	26.2	76.5	95	101	0	38	40
2015	12	21	19	2	22	0.486	-0.328	3.93	0.01	0.007	0	25.4	27.1	76.5	96	102	0	37	39
2015	12	21	19	12	22	0.535	-0.256	3.93	0.01	0.007	0	24.9	26.7	76.5	96	101	0	38	39
2015	12	21	19	22	22	0.663	-0.128	3.93	0.01	0.007	0	24.9	27.1	77	96	102	0	38	39
2015	12	21	19	32	22	0.653	-0.138	3.93	0.01	0.007	0	25.4	27.1	76.1	97	102	0	38	39
2015	12	21	19	42	22	0.587	-0.226	3.93	0.01	0.007	0	25.8	28	76.5	98	104	0	38	39
2015	12	21	19	52	22	0.666	-0.141	3.93	0.01	0.007	0	24.9	27.1	76.5	96	102	0	38	39
2015	12	21	20	2	22	0.541	-0.22	3.93	0.01	0.007	0	25.8	27.1	76.5	97	102	0	37	39
2015	12	21	20	12	22	0.558	-0.194	3.93	0.01	0.007	0	25.4	27.1	76.1	97	102	0	38	39
2015	12	21	20	22	22	0.548	-0.213	3.93	0.01	0.007	0	25.4	27.5	76.5	97	103	0	38	39
2015	12	21	20	32	22	0.535	-0.272	3.93	0.01	0.007	0	24.9	27.5	76.1	97	103	0	39	39
2015	12	21	20	42	22	0.538	-0.233	3.93	0.01	0.007	0	24.9	26.7	76.5	96	101	0	38	39
2015	12	21	20	52	22	0.633	-0.187	3.93	0.013	0.01	0	25.4	27.5	76.5	97	103	0	38	39
2015	12	21	21	2	22	0.63	-0.187	3.93	0.01	0.007	0	26.2	28	76.5	98	104	0	37	39
2015	12	21	21	12	22	0.551	-0.226	3.93	0.01	0.007	0	25.4	27.5	75.3	97	103	0	38	39
2015	12	21	21	22	22	0.61	-0.197	3.93	0.01	0.007	0	26.2	28	76.5	99	104	0	38	39
2015	12	21	21	32	22	0.545	-0.246	3.93	0.01	0.007	0	25.8	28	77	98	104	0	38	39
2015	12	21	21	42	22	0.597	-0.148	3.93	0.01	0.007	0	25.4	27.5	77	97	104	0	38	40
2015	12	21	21	52	22	0.581	-0.217	3.93	0.016	0.013	0	24.5	26.7	76.5	95	101	0	38	39
2015	12	21	22	2	22	0.525	-0.23	3.93	0.01	0.007	0	24.5	27.1	77	95	102	0	38	39
2015	12	21	22	12	22	0.64	-0.174	3.93	0.01	0.007	0	24.1	26.2	76.5	94	100	0	38	39
2015	12	21	22	22	22	0.597	-0.187	3.934	0.01	0.007	0	24.5	26.2	77	95	101	0	38	40
2015	12	21	22	32	22	0.591	-0.226	3.934	0.01	0.007	0	24.5	26.7	77.4	95	101	0	38	39
2015	12	21	22	42	22	0.607	-0.2	3.934	0.01	0.007	0	24.9	27.1	76.5	96	102	0	38	39
2015	12	21	22	52	22	0.571	-0.236	3.934	0.01	0.007	0	25.4	28	76.5	97	103	0	38	38
2015	12	21	23	2	22	0.568	-0.194	3.934	0.01	0.007	0	25.8	28.4	77	98	105	0	38	39
2015	12	21	23	12	22	0.646	-0.157	3.934	0.01	0.007	0	25.4	28	76.1	97	104	0	38	39
2015	12	21	23	22	22	0.607	-0.217	3.934	0.01	0.007	0	24.5	27.1	74	95	103	0	38	40
2015	12	21	23	32	22	0.571	-0.167	3.934	0.013	0.01	0	24.9	28	76.5	96	104	0	38	39
2015	12	21	23	42	22	0.604	-0.2	3.934	0.01	0.007	0	25.8	28.8	73.5	98	106	0	38	39
2015	12	21	23	52	22	0.6	-0.2	3.934	0.01	0.007	0	25.4	28	76.1	97	105	0	38	40
2015	12	22	0	2	22	0.62	-0.171	3.934	0.01	0.007	0	26.7	30.1	76.5	101	110	0	39	40
2015	12	22	0	12	22	0.581	-0.164	3.934	0.01	0.007	0	26.2	28.8	77	99	107	0	38	40
2015	12	22	0	22	22	0.594	-0.2	3.934	0.01	0.007	0	26.7	29.2	76.5	100	107	0	38	39
2015	12	22	0	32	22	0.614	-0.184	3.934	0.01	0.007	0	25.8	28.8	76.5	98	106	0	38	39
2015	12	22	0	42	22	0.584	-0.2	3.934	0.01	0.007	0	25.4	28.8	76.5	97	106	0	38	39
2015	12	22	0	52	22	0.522	-0.207	3.934	0.01	0.007	0	24.9	28.4	77	97	105	0	39	39
2015	12	22	1	2	22	0.65	-0.112	3.934	0.01	0.007	0	24.5	28.4	77	96	105	0	39	39
2015	12	22	1	12	22	0.633	-0.174	3.934	0.01	0.007	0	25.4	28.4	76.1	96	105	0	37	39
2015	12	22	1	22	22	0.597	-0.164	3.934	0.01	0.007	0	25.8	29.2	77	98	107	0	38	39
2015	12	22	1	32	22	0.584	-0.151	3.934	0.01	0.007	0	26.2	29.7	76.5	99	108	0	38	39
2015	12	22	1	42	22	0.6	-0.187	3.934	0.01	0.007	0	25.4	28.4	76.5	97	105	0	38	39
2015	12	22	1	52	22	0.62	-0.167	3.934	0.01	0.007	0	25.8	28.8	76.5	98	106	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	2	2	22	0.61	-0.164	3.934	0.01	0.007	0	25.4	29.2	77	97	107	0	38	39
2015	12	22	2	12	22	0.61	-0.164	3.934	0.01	0.007	0	25.4	29.2	74.8	97	107	0	38	39
2015	12	22	2	22	22	0.643	-0.164	3.937	0.016	0.013	0	25.4	28.8	76.5	97	106	0	38	39
2015	12	22	2	32	22	0.61	-0.19	3.934	0.01	0.007	0	24.9	28.4	77	96	105	0	38	39
2015	12	22	2	42	22	0.63	-0.161	3.934	0.013	0.01	0	25.4	28.4	76.5	97	105	0	38	39
2015	12	22	2	52	22	0.63	-0.148	3.934	0.01	0.007	0	25.8	29.2	75.7	98	107	0	38	39
2015	12	22	3	2	22	0.65	-0.135	3.934	0.01	0.007	0	28	31.4	76.5	103	112	0	38	39
2015	12	22	3	12	22	0.61	-0.161	3.937	0.01	0.007	0	26.2	29.2	77.4	99	108	0	38	40
2015	12	22	3	22	22	0.623	-0.098	3.934	0.01	0.007	0	27.5	31.4	77	102	112	0	38	39
2015	12	22	3	32	22	0.62	-0.18	3.937	0.013	0.01	0	25.4	28.4	76.5	97	105	0	38	39
2015	12	22	3	42	22	0.63	-0.174	3.934	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	22	3	52	22	0.614	-0.167	3.937	0.01	0.007	0	25.4	28.8	77.4	97	105	0	38	38
2015	12	22	4	2	22	0.623	-0.151	3.937	0.01	0.007	0	25.8	29.2	76.5	98	107	0	38	39
2015	12	22	4	12	22	0.636	-0.174	3.937	0.01	0.007	0	26.2	29.2	76.1	98	107	0	37	39
2015	12	22	4	22	22	0.63	-0.157	3.937	0.01	0.007	0	25.4	29.2	75.7	97	107	0	38	39
2015	12	22	4	32	22	0.633	-0.174	3.937	0.01	0.007	0	26.2	30.1	70.1	99	109	0	38	39
2015	12	22	4	42	22	0.61	-0.151	3.937	0.01	0.007	0	24.9	27.5	76.5	96	104	0	38	40
2015	12	22	4	52	22	0.604	-0.148	3.937	0.01	0.007	0	24.5	28	77	95	104	0	38	39
2015	12	22	5	2	22	0.61	-0.174	3.937	0.01	0.007	0	23.6	27.5	76.5	93	102	0	38	38
2015	12	22	5	12	22	0.627	-0.164	3.937	0.01	0.007	0	24.9	28.4	75.7	96	105	0	38	39
2015	12	22	5	22	22	0.646	-0.148	3.937	0.01	0.007	0	24.5	26.7	70.1	94	102	0	37	40
2015	12	22	5	32	22	0.597	-0.151	3.937	0.01	0.007	0	24.1	27.1	76.5	94	102	0	38	39
2015	12	22	5	42	22	0.587	-0.151	3.937	0.01	0.007	0	24.5	28.4	76.1	95	104	0	38	38
2015	12	22	5	52	22	0.63	-0.177	3.937	0.01	0.007	0	23.6	26.7	75.7	92	101	0	37	39
2015	12	22	6	2	22	0.614	-0.174	3.937	0.01	0.007	0	23.6	27.1	77	93	102	0	38	39
2015	12	22	6	12	22	0.591	-0.135	3.937	0.01	0.007	0	24.5	28	76.5	96	104	0	39	39
2015	12	22	6	22	22	0.61	-0.174	3.937	0.01	0.007	0	23.2	26.2	77	92	100	0	38	39
2015	12	22	6	32	22	0.617	-0.164	3.937	0.01	0.007	0	23.6	26.7	77	92	101	0	37	39
2015	12	22	6	42	22	0.63	-0.177	3.937	0.01	0.007	0	24.1	27.5	77	94	102	0	38	38
2015	12	22	6	52	22	0.62	-0.174	3.937	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	22	7	2	22	0.594	-0.184	3.937	0.01	0.007	0	23.6	26.7	77	93	101	0	38	39
2015	12	22	7	12	22	0.6	-0.154	3.937	0.01	0.007	0	23.2	26.2	77.4	92	100	0	38	39
2015	12	22	7	22	22	0.594	-0.167	3.937	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	22	7	32	22	0.61	-0.164	3.937	0.01	0.007	0	22.4	26.2	77.4	90	99	0	38	38
2015	12	22	7	42	22	0.62	-0.174	3.937	0.01	0.007	0	23.2	26.2	77	92	100	0	38	39
2015	12	22	7	52	22	0.627	-0.161	3.937	0.01	0.007	0	22.8	25.8	76.1	91	99	0	38	39
2015	12	22	8	2	22	0.6	-0.164	3.94	0.01	0.007	0	22.4	26.2	76.5	91	100	0	39	39
2015	12	22	8	12	22	0.61	-0.187	3.94	0.01	0.007	0	21.9	25.4	77	90	98	0	39	39
2015	12	22	8	22	22	0.614	-0.177	3.94	0.01	0.007	0	23.6	25.8	77	92	99	0	37	39
2015	12	22	8	32	22	0.594	-0.174	3.94	0.013	0.01	0	22.8	25.8	74.8	91	99	0	38	39
2015	12	22	8	42	22	0.594	-0.167	3.94	0.01	0.007	0	22.4	25.4	76.1	90	98	0	38	39
2015	12	22	8	52	22	0.61	-0.157	3.94	0.01	0.007	0	22.8	25.8	76.5	91	99	0	38	39
2015	12	22	9	2	22	0.63	-0.167	3.94	0.01	0.007	0	22.4	25.8	77.8	90	99	0	38	39
2015	12	22	9	12	22	0.614	-0.203	3.944	0.01	0.007	0	22.8	26.2	77	91	99	0	38	38
2015	12	22	9	22	22	0.597	-0.154	3.944	0.01	0.007	0	23.2	25.8	76.5	91	99	0	37	39
2015	12	22	9	32	22	0.64	-0.18	3.944	0.01	0.007	0	22.4	25.8	64.5	90	99	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	9	42	22	0.61	-0.148	3.944	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	22	9	52	22	0.6	-0.167	3.944	0.01	0.007	0	22.4	25.8	71.4	90	99	0	38	39
2015	12	22	10	2	22	0.591	-0.131	3.947	0.01	0.007	0	23.2	26.2	77.8	92	100	0	38	39
2015	12	22	10	12	22	0.617	-0.138	3.947	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	22	10	22	22	0.607	-0.151	3.944	0.01	0.007	0	22.8	26.2	75.7	91	100	0	38	39
2015	12	22	10	32	22	0.636	-0.115	3.947	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	22	10	42	22	0.656	-0.115	3.947	0.01	0.007	0	24.1	26.7	77.4	93	101	0	37	39
2015	12	22	10	52	22	0.633	-0.148	3.947	0.01	0.007	0	23.2	27.1	75.7	92	102	0	38	39
2015	12	22	11	2	22	0.63	-0.151	3.95	0.01	0.007	0	24.1	27.1	76.1	94	102	0	38	39
2015	12	22	11	12	22	0.633	-0.138	3.95	0.013	0.01	0	23.6	27.1	68.4	93	102	0	38	39
2015	12	22	11	22	22	0.623	-0.164	3.95	0.01	0.007	0	24.1	27.1	77.4	94	102	0	38	39
2015	12	22	11	32	22	0.65	-0.138	3.95	0.013	0.01	0	23.6	27.1	69.7	93	102	0	38	39
2015	12	22	11	42	22	0.623	-0.144	3.95	0.01	0.007	0	24.1	28	58.5	94	104	0	38	39
2015	12	22	11	52	22	0.633	-0.148	3.947	0.01	0.007	0	24.1	27.1	67.5	94	103	0	38	40
2015	12	22	12	2	22	0.623	-0.128	3.95	0.01	0.007	0	24.5	28	67.9	95	104	0	38	39
2015	12	22	12	12	22	0.643	-0.138	3.95	0.01	0.007	0	24.1	28	75.3	94	104	0	38	39
2015	12	22	12	22	22	0.65	-0.115	3.947	0.01	0.007	0	25.8	29.2	76.5	98	107	0	38	39
2015	12	22	12	32	22	0.63	-0.144	3.947	0.01	0.007	0	24.9	28.4	76.1	96	105	0	38	39
2015	12	22	12	42	22	0.636	-0.148	3.947	0.01	0.007	0	24.5	27.5	75.7	95	103	0	38	39
2015	12	22	12	52	22	0.604	-0.125	3.947	0.01	0.007	0	24.1	28	75.3	94	103	0	38	38
2015	12	22	13	2	22	0.623	-0.128	3.947	0.016	0.013	0	24.5	28	75.7	95	104	0	38	39
2015	12	22	13	12	22	0.604	-0.125	3.947	0.01	0.007	0	24.9	28	75.7	96	104	0	38	39
2015	12	22	13	22	22	0.673	-0.144	3.947	0.01	0.007	0	24.5	28	76.1	94	104	0	37	39
2015	12	22	13	32	22	0.623	-0.125	3.947	0.01	0.007	0	24.9	28.4	74.8	96	105	0	38	39
2015	12	22	13	42	22	0.61	-0.141	3.944	0.01	0.007	0	24.5	28.4	73.1	96	105	0	39	39
2015	12	22	13	52	22	0.643	-0.121	3.944	0.01	0.007	0	25.8	28.4	74.4	97	105	0	37	39
2015	12	22	14	2	22	0.63	-0.154	3.94	0.01	0.007	0	24.5	28	74.8	95	104	0	38	39
2015	12	22	14	12	22	0.623	-0.161	3.94	0.01	0.007	0	24.1	28	74.4	94	103	0	38	38
2015	12	22	14	22	22	0.62	-0.138	3.94	0.01	0.007	0	23.6	27.1	74.4	93	102	0	38	39
2015	12	22	14	32	22	0.636	-0.138	3.937	0.013	0.01	0	23.6	27.1	70.1	93	102	0	38	39
2015	12	22	14	42	22	0.643	-0.138	3.937	0.01	0.007	0	24.5	28.4	62.8	95	105	0	38	39
2015	12	22	14	52	22	0.627	-0.128	3.937	0.01	0.007	0	25.4	29.2	70.1	97	107	0	38	39
2015	12	22	15	2	22	0.62	-0.108	3.937	0.013	0.01	0	25.4	28.8	61.5	97	106	0	38	39
2015	12	22	15	12	22	0.643	-0.148	3.937	0.01	0.007	0	26.2	30.1	61.1	99	109	0	38	39
2015	12	22	15	22	22	0.656	-0.128	3.94	0.013	0.01	0	26.7	30.5	73.5	100	110	0	38	39
2015	12	22	15	32	22	0.633	-0.154	3.937	0.01	0.007	0	24.9	28.8	72.7	96	106	0	38	39
2015	12	22	15	42	22	0.64	-0.138	3.94	0.01	0.007	0	24.9	28.4	71.8	95	105	0	37	39
2015	12	22	15	52	22	0.633	-0.115	3.94	0.013	0.01	0	24.9	28	63.2	95	104	0	37	39
2015	12	22	16	2	22	0.673	-0.141	3.937	0.01	0.007	0	24.5	28.4	61.5	95	105	0	38	39
2015	12	22	16	12	22	0.61	-0.141	3.937	0.01	0.007	0	24.5	28.4	64.5	95	105	0	38	39
2015	12	22	16	22	22	0.643	-0.184	3.937	0.01	0.007	0	24.1	27.5	73.1	94	104	0	38	40
2015	12	22	16	32	22	0.623	-0.115	3.937	0.016	0.016	0	24.5	28	64.9	95	104	0	38	39
2015	12	22	16	42	22	0.627	-0.157	3.94	0.01	0.007	0	24.5	28.4	72.7	95	105	0	38	39
2015	12	22	16	52	22	0.643	-0.157	3.937	0.01	0.007	0	24.1	27.5	73.5	94	103	0	38	39
2015	12	22	17	2	22	0.594	-0.167	3.937	0.01	0.007	0	24.5	28	72.2	95	104	0	38	39
2015	12	22	17	12	22	0.636	-0.125	3.94	0.01	0.007	0	24.1	27.5	73.5	94	103	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	17	22	22	0.64	-0.144	3.937	0.01	0.007	0	25.4	29.2	74	97	107	0	38	39
2015	12	22	17	32	22	0.61	-0.154	3.94	0.01	0.007	0	26.2	29.7	73.5	99	108	0	38	39
2015	12	22	17	42	22	0.656	-0.128	3.937	0.01	0.007	0	24.9	28.4	67.5	96	105	0	38	39
2015	12	22	17	52	22	0.646	-0.151	3.94	0.01	0.007	0	24.5	28.4	73.1	95	105	0	38	39
2015	12	22	18	2	22	0.653	-0.125	3.937	0.013	0.01	0	25.8	28.8	55.5	98	107	0	38	40
2015	12	22	18	12	22	0.643	-0.138	3.937	0.01	0.007	0	25.8	29.7	69.2	98	108	0	38	39
2015	12	22	18	22	22	0.6	-0.121	3.937	0.01	0.007	0	26.2	29.7	72.2	99	108	0	38	39
2015	12	22	18	32	22	0.623	-0.128	3.937	0.01	0.007	0	24.9	28.8	71.4	96	106	0	38	39
2015	12	22	18	42	22	0.614	-0.138	3.937	0.01	0.007	0	24.9	28.8	72.2	96	106	0	38	39
2015	12	22	18	52	22	0.594	-0.125	3.94	0.013	0.01	0	24.9	28.4	72.7	96	105	0	38	39
2015	12	22	19	2	22	0.633	-0.144	3.94	0.01	0.007	0	34.4	38.3	72.2	118	128	0	38	39
2015	12	22	19	12	22	0.623	-0.131	3.937	0.01	0.007	0	25.4	28.8	73.1	96	106	0	37	39
2015	12	22	19	22	22	0.607	-0.128	3.94	0.01	0.007	0	24.9	28.4	73.1	96	105	0	38	39
2015	12	22	19	32	22	0.597	-0.115	3.94	0.01	0.007	0	24.1	28	73.5	94	103	0	38	38
2015	12	22	19	42	22	0.636	-0.141	3.94	0.01	0.007	0	24.1	27.5	74	94	103	0	38	39
2015	12	22	19	52	22	0.61	-0.151	3.94	0.01	0.007	0	25.4	28.8	73.5	97	106	0	38	39
2015	12	22	20	2	22	0.623	-0.151	3.94	0.01	0.007	0	31.4	35.3	72.2	111	121	0	38	39
2015	12	22	20	12	22	0.623	-0.128	3.94	0.01	0.007	0	27.1	30.1	72.2	100	109	0	37	39
2015	12	22	20	22	22	0.607	-0.128	3.937	0.01	0.007	0	24.1	28	71.8	94	103	0	38	38
2015	12	22	20	32	22	0.646	-0.144	3.94	0.01	0.007	0	24.1	27.1	73.5	94	102	0	38	39
2015	12	22	20	42	22	0.61	-0.131	3.94	0.01	0.007	0	23.6	27.1	73.5	93	102	0	38	39
2015	12	22	20	52	22	0.64	-0.164	3.94	0.01	0.007	0	23.2	26.2	73.1	91	100	0	37	39
2015	12	22	21	2	22	0.627	-0.121	3.94	0.01	0.007	0	23.2	26.7	73.5	92	101	0	38	39
2015	12	22	21	12	22	0.61	-0.135	3.94	0.013	0.01	0	23.6	26.7	73.1	92	101	0	37	39
2015	12	22	21	22	22	0.614	-0.154	3.94	0.01	0.007	0	23.6	26.2	73.5	92	100	0	37	39
2015	12	22	21	32	22	0.623	-0.141	3.944	0.01	0.007	0	23.2	26.7	73.1	92	100	0	38	38
2015	12	22	21	42	22	0.6	-0.141	3.94	0.01	0.007	0	23.2	26.7	73.5	92	100	0	38	38
2015	12	22	21	52	22	0.63	-0.128	3.94	0.01	0.007	0	22.8	27.1	73.1	91	101	0	38	38
2015	12	22	22	2	22	0.63	-0.125	3.944	0.01	0.007	0	23.2	26.2	74	92	100	0	38	39
2015	12	22	22	12	22	0.64	-0.141	3.944	0.01	0.007	0	23.6	26.7	73.5	92	100	0	37	38
2015	12	22	22	22	22	0.643	-0.148	3.944	0.01	0.007	0	22.8	26.2	73.5	91	100	0	38	39
2015	12	22	22	32	22	0.627	-0.115	3.94	0.01	0.007	0	23.2	26.2	74	92	100	0	38	39
2015	12	22	22	42	22	0.61	-0.135	3.944	0.01	0.007	0	22.8	25.8	73.5	91	100	0	38	40
2015	12	22	22	52	22	0.64	-0.144	3.94	0.01	0.007	0	23.2	26.2	73.5	92	100	0	38	39
2015	12	22	23	2	22	0.64	-0.141	3.944	0.01	0.007	0	23.2	26.7	73.1	92	101	0	38	39
2015	12	22	23	12	22	0.623	-0.144	3.944	0.01	0.007	0	23.6	27.1	73.5	93	102	0	38	39
2015	12	22	23	22	22	0.633	-0.112	3.944	0.01	0.007	0	23.2	27.1	73.1	92	101	0	38	38
2015	12	22	23	32	22	0.636	-0.102	3.944	0.01	0.007	0	22.8	26.2	74	91	100	0	38	39
2015	12	22	23	42	22	0.63	-0.144	3.944	0.01	0.007	0	23.2	27.1	73.5	92	101	0	38	38
2015	12	22	23	52	22	0.63	-0.144	3.944	0.01	0.007	0	23.2	26.7	74	92	101	0	38	39
2015	12	23	0	2	22	0.62	-0.118	3.944	0.01	0.007	0	23.2	26.7	74.4	92	101	0	38	39
2015	12	23	0	12	22	0.64	-0.141	3.944	0.01	0.007	0	23.2	27.1	74.4	92	101	0	38	38
2015	12	23	0	22	22	0.623	-0.141	3.944	0.01	0.007	0	23.6	27.1	74	93	102	0	38	39
2015	12	23	0	32	22	0.62	-0.128	3.944	0.01	0.007	0	24.1	26.7	74.4	93	101	0	37	39
2015	12	23	0	42	22	0.597	-0.131	3.944	0.01	0.007	0	23.6	27.1	74	93	102	0	38	39
2015	12	23	0	52	22	0.623	-0.118	3.944	0.01	0.007	0	22.8	26.2	74	91	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	1	2	22	0.653	-0.125	3.944	0.01	0.007	0	24.1	26.7	74.4	93	101	0	37	39
2015	12	23	1	12	22	0.597	-0.115	3.944	0.01	0.007	0	23.2	26.7	74.8	92	100	0	38	38
2015	12	23	1	22	22	0.63	-0.135	3.944	0.01	0.007	0	23.6	26.2	74.4	92	100	0	37	39
2015	12	23	1	32	22	0.64	-0.131	3.944	0.01	0.007	0	24.5	27.5	74.4	95	103	0	38	39
2015	12	23	1	42	22	0.617	-0.112	3.944	0.01	0.007	0	24.1	27.1	74.8	93	102	0	37	39
2015	12	23	1	52	22	0.65	-0.151	3.944	0.01	0.007	0	23.2	26.7	74.4	92	101	0	38	39
2015	12	23	2	2	22	0.653	-0.135	3.944	0.01	0.007	0	24.1	27.1	74.4	94	102	0	38	39
2015	12	23	2	12	22	0.646	-0.144	3.944	0.013	0.01	0	27.1	31	74.8	101	110	0	38	38
2015	12	23	2	22	22	0.643	-0.154	3.944	0.01	0.007	0	23.6	27.1	75.3	93	102	0	38	39
2015	12	23	2	32	22	0.594	-0.115	3.947	0.01	0.007	0	23.6	26.7	75.3	92	101	0	37	39
2015	12	23	2	42	22	0.63	-0.135	3.944	0.01	0.007	0	24.5	28	74.4	95	104	0	38	39
2015	12	23	2	52	22	0.623	-0.138	3.944	0.01	0.007	0	24.1	27.1	74.8	93	102	0	37	39
2015	12	23	3	2	22	0.646	-0.135	3.947	0.01	0.007	0	23.2	27.5	75.7	93	102	0	39	38
2015	12	23	3	12	22	0.617	-0.121	3.947	0.01	0.007	0	24.9	28	75.7	96	104	0	38	39
2015	12	23	3	22	22	0.653	-0.135	3.947	0.01	0.007	0	27.1	30.1	75.3	101	109	0	38	39
2015	12	23	3	32	22	0.673	-0.141	3.947	0.01	0.007	0	33.1	37	73.1	115	125	0	38	39
2015	12	23	3	42	22	0.614	-0.141	3.947	0.01	0.007	0	31	34.4	75.7	110	119	0	38	39
2015	12	23	3	52	22	0.633	-0.141	3.947	0.01	0.007	0	25.4	28.8	75.7	97	106	0	38	39
2015	12	23	4	2	22	0.614	-0.141	3.947	0.01	0.007	0	24.1	26.7	75.7	93	101	0	37	39
2015	12	23	4	12	22	0.64	-0.144	3.947	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	23	4	22	22	0.646	-0.128	3.947	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	23	4	32	22	0.653	-0.135	3.947	0.01	0.007	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	23	4	42	22	0.614	-0.154	3.947	0.01	0.007	0	23.6	26.7	76.5	93	101	0	38	39
2015	12	23	4	52	22	0.656	-0.164	3.947	0.01	0.007	0	23.2	26.2	76.5	92	100	0	38	39
2015	12	23	5	2	22	0.63	-0.125	3.95	0.01	0.007	0	24.1	27.1	76.5	93	101	0	37	38
2015	12	23	5	12	22	0.627	-0.141	3.947	0.01	0.007	0	23.2	26.2	77	92	100	0	38	39
2015	12	23	5	22	22	0.62	-0.118	3.95	0.01	0.007	0	23.2	26.2	77	92	100	0	38	39
2015	12	23	5	32	22	0.604	-0.135	3.95	0.01	0.007	0	23.2	26.2	76.1	92	100	0	38	39
2015	12	23	5	42	22	0.627	-0.115	3.95	0.01	0.007	0	23.6	26.2	77	92	100	0	37	39
2015	12	23	5	52	22	0.636	-0.108	3.95	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	23	6	2	22	0.643	-0.167	3.95	0.01	0.007	0	22.8	26.2	77	91	99	0	38	38
2015	12	23	6	12	22	0.636	-0.144	3.95	0.01	0.007	0	22.8	25.8	77	91	99	0	38	39
2015	12	23	6	22	22	0.643	-0.157	3.95	0.01	0.007	0	23.6	25.8	77.4	92	99	0	37	39
2015	12	23	6	32	22	0.64	-0.128	3.95	0.01	0.007	0	22.8	25.8	77.8	91	99	0	38	39
2015	12	23	6	42	22	0.617	-0.131	3.95	0.01	0.007	0	23.2	26.7	77.4	92	100	0	38	38
2015	12	23	6	52	22	0.643	-0.154	3.95	0.01	0.007	0	23.2	25.8	77.8	92	99	0	38	39
2015	12	23	7	2	22	0.646	-0.144	3.95	0.01	0.007	0	23.2	26.2	77.4	92	100	0	38	39
2015	12	23	7	12	22	0.636	-0.157	3.95	0.01	0.007	0	22.8	25.8	77.8	91	99	0	38	39
2015	12	23	7	22	22	0.636	-0.112	3.95	0.01	0.007	0	23.2	26.7	77.8	92	100	0	38	38
2015	12	23	7	32	22	0.63	-0.125	3.95	0.01	0.007	0	23.2	26.7	77.8	92	100	0	38	38
2015	12	23	7	42	22	0.643	-0.148	3.95	0.01	0.007	0	23.6	26.7	77.8	92	100	0	37	38
2015	12	23	7	52	22	0.617	-0.128	3.953	0.01	0.007	0	23.2	26.2	77.8	92	100	0	38	39
2015	12	23	8	2	22	0.62	-0.141	3.953	0.01	0.007	0	23.6	26.2	77.8	93	100	0	38	39
2015	12	23	8	12	22	0.646	-0.151	3.953	0.013	0.01	0	24.1	26.7	77.4	93	100	0	37	38
2015	12	23	8	22	22	0.643	-0.148	3.953	0.01	0.007	0	23.2	26.2	73.5	92	100	0	38	39
2015	12	23	8	32	22	0.653	-0.102	3.953	0.01	0.007	0	22.8	26.2	56.3	91	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	8	42	22	0.65	-0.141	3.953	0.01	0.007	0	22.8	26.2	59.8	91	100	0	38	39
2015	12	23	8	52	22	0.627	-0.118	3.957	0.01	0.007	0	23.6	26.7	66.2	93	101	0	38	39
2015	12	23	9	2	22	0.679	-0.089	3.957	0.01	0.007	0	23.2	26.7	57.6	92	101	0	38	39
2015	12	23	9	12	22	0.696	-0.112	3.957	0.01	0.007	0	24.1	26.7	53.8	93	101	0	37	39
2015	12	23	9	22	22	0.669	-0.115	3.957	0.01	0.007	0	23.2	26.7	55.9	92	100	0	38	38
2015	12	23	9	32	22	0.659	-0.121	3.957	0.01	0.007	0	23.6	26.2	58.9	92	100	0	37	39
2015	12	23	9	42	22	0.659	-0.128	3.96	0.01	0.007	0	24.1	27.1	60.6	93	102	0	37	39
2015	12	23	9	52	22	0.676	-0.115	3.957	0.01	0.007	0	23.6	27.1	55.5	93	102	0	38	39
2015	12	23	10	2	22	0.676	-0.105	3.957	0.01	0.007	0	23.2	26.7	52.5	92	101	0	38	39
2015	12	23	10	12	22	0.636	-0.135	3.957	0.013	0.01	0	22.8	26.7	57.2	91	101	0	38	39
2015	12	23	10	22	22	0.623	-0.112	3.957	0.01	0.007	0	23.2	26.2	64.9	91	100	0	37	39
2015	12	23	10	32	22	0.597	-0.18	3.904	0.01	0.007	0	25.4	28	67.5	97	104	0	38	39
2015	12	23	10	42	22	0.548	-0.171	3.835	0.01	0.007	0	26.7	28.8	55.5	100	106	0	38	39
2015	12	23	10	52	22	0.531	-0.187	3.845	0.01	0.007	0	27.1	29.2	62.4	101	107	0	38	39
2015	12	23	11	2	22	0.554	-0.171	3.848	0.01	0.007	0	28	29.2	66.7	102	107	0	37	39
2015	12	23	11	12	22	0.643	-0.167	3.957	0.01	0.007	0	28	31	51.6	103	111	0	38	39
2015	12	23	11	22	22	0.65	-0.154	3.957	0.01	0.007	0	27.5	30.5	55	102	110	0	38	39
2015	12	23	11	32	22	0.643	-0.18	3.957	0.01	0.007	0	25.8	28.4	54.6	97	105	0	37	39
2015	12	23	11	42	22	0.64	-0.148	3.957	0.01	0.007	0	26.2	29.2	53.8	98	106	0	37	38
2015	12	23	11	52	22	0.64	-0.167	3.957	0.01	0.007	0	24.9	28	51.6	96	104	0	38	39
2015	12	23	12	2	22	0.64	-0.121	3.957	0.013	0.01	0	31.8	35.3	52	112	121	0	38	39
2015	12	23	12	12	22	0.636	-0.144	3.957	0.01	0.007	0	26.7	29.7	50.7	100	107	0	38	38
2015	12	23	12	22	22	0.62	-0.151	3.957	0.01	0.007	0	25.8	28.4	55	97	105	0	37	39
2015	12	23	12	32	22	0.643	-0.187	3.957	0.013	0.01	0	24.9	27.5	58.5	95	103	0	37	39
2015	12	23	12	42	22	0.587	-0.2	3.957	0.01	0.007	0	24.9	27.5	65.4	95	102	0	37	38
2015	12	23	12	52	22	0.6	-0.177	3.957	0.01	0.007	0	24.9	27.1	64.9	95	102	0	37	39
2015	12	23	13	2	22	0.6	-0.151	3.957	0.01	0.007	0	24.5	27.1	58.5	94	102	0	37	39
2015	12	23	13	12	22	0.614	-0.118	3.957	0.01	0.007	0	24.1	27.5	55.5	94	102	0	38	38
2015	12	23	13	22	22	0.604	-0.174	3.957	0.01	0.007	0	24.5	26.7	58.5	94	101	0	37	39
2015	12	23	13	32	22	0.581	-0.184	3.957	0.01	0.007	0	24.9	27.1	73.5	95	101	0	37	38
2015	12	23	13	42	22	0.587	-0.174	3.953	0.01	0.007	0	24.1	27.1	67.9	94	101	0	38	38
2015	12	23	13	52	22	0.594	-0.184	3.953	0.01	0.007	0	24.5	27.1	69.7	95	102	0	38	39
2015	12	23	14	2	22	0.607	-0.19	3.953	0.01	0.007	0	25.4	28	71.4	96	103	0	37	38
2015	12	23	14	12	22	0.594	-0.184	3.953	0.01	0.007	0	24.5	27.1	60.2	94	102	0	37	39
2015	12	23	14	22	22	0.577	-0.171	3.953	0.01	0.007	0	24.5	27.1	61.5	95	102	0	38	39
2015	12	23	14	32	22	0.617	-0.174	3.95	0.01	0.007	0	24.1	26.7	56.3	93	101	0	37	39
2015	12	23	14	42	22	0.581	-0.184	3.953	0.01	0.007	0	24.9	27.5	67.9	95	102	0	37	38
2015	12	23	14	52	22	0.636	-0.171	3.95	0.01	0.007	0	24.9	27.1	54.6	95	102	0	37	39
2015	12	23	15	2	22	0.607	-0.207	3.953	0.01	0.007	0	24.1	27.1	69.2	94	101	0	38	38
2015	12	23	15	12	22	0.604	-0.174	3.95	0.01	0.007	0	24.1	27.1	61.1	94	102	0	38	39
2015	12	23	15	22	22	0.617	-0.18	3.95	0.01	0.007	0	23.6	26.7	55.9	93	100	0	38	38
2015	12	23	15	32	22	0.6	-0.213	3.95	0.01	0.007	0	24.1	26.7	69.7	93	100	0	37	38
2015	12	23	15	42	22	0.577	-0.184	3.95	0.013	0.01	0	24.1	26.2	70.5	94	100	0	38	39
2015	12	23	15	52	22	0.604	-0.167	3.95	0.01	0.007	0	24.5	27.1	61.1	95	102	0	38	39
2015	12	23	16	2	22	0.62	-0.151	3.95	0.01	0.007	0	24.1	27.5	54.2	94	102	0	38	38
2015	12	23	16	12	22	0.63	-0.174	3.95	0.01	0.007	0	25.4	29.2	61.9	97	106	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	16	22	22	0.617	-0.217	3.95	0.01	0.007	0	24.5	27.1	74	95	102	0	38	39
2015	12	23	16	32	22	0.584	-0.144	3.95	0.01	0.007	0	24.1	26.2	74	94	100	0	38	39
2015	12	23	16	42	22	0.604	-0.167	3.95	0.01	0.007	0	23.6	26.7	74	93	100	0	38	38
2015	12	23	16	52	22	0.604	-0.167	3.95	0.01	0.007	0	24.1	27.1	74.4	94	101	0	38	38
2015	12	23	17	2	22	0.61	-0.167	3.95	0.01	0.007	0	24.1	26.2	73.1	94	100	0	38	39
2015	12	23	17	12	22	0.587	-0.184	3.95	0.01	0.007	0	24.1	26.7	74.4	93	100	0	37	38
2015	12	23	17	22	22	0.591	-0.184	3.95	0.01	0.007	0	24.1	26.2	74.8	93	100	0	37	39
2015	12	23	17	32	22	0.62	-0.154	3.953	0.01	0.007	0	25.4	28.8	74.4	97	105	0	38	38
2015	12	23	17	42	22	0.604	-0.167	3.953	0.013	0.01	0	25.4	28.4	74.8	97	105	0	38	39
2015	12	23	17	52	22	0.594	-0.184	3.953	0.01	0.007	0	24.5	28	74.4	95	103	0	38	38
2015	12	23	18	2	22	0.607	-0.167	3.95	0.01	0.007	0	24.9	28	74.4	96	103	0	38	38
2015	12	23	18	12	22	0.597	-0.164	3.95	0.01	0.007	0	26.7	29.2	74.4	99	107	0	37	39
2015	12	23	18	22	22	0.617	-0.18	3.953	0.013	0.01	0	25.8	28.8	74	98	106	0	38	39
2015	12	23	18	32	22	0.643	-0.131	3.953	0.01	0.007	0	25.4	28.4	74.4	96	104	0	37	38
2015	12	23	18	42	22	0.604	-0.167	3.953	0.01	0.007	0	26.2	29.2	74.8	99	107	0	38	39
2015	12	23	18	52	22	0.61	-0.167	3.953	0.01	0.007	0	24.5	27.5	73.1	95	103	0	38	39
2015	12	23	19	2	22	0.604	-0.174	3.953	0.01	0.007	0	24.9	27.5	73.1	95	103	0	37	39
2015	12	23	19	12	22	0.6	-0.171	3.953	0.01	0.007	0	24.5	28	64.1	95	103	0	38	38
2015	12	23	19	22	22	0.63	-0.167	3.953	0.01	0.007	0	24.9	28.4	53.8	95	104	0	37	38
2015	12	23	19	32	22	0.633	-0.174	3.953	0.01	0.007	0	24.9	28.8	54.2	96	105	0	38	38
2015	12	23	19	42	22	0.617	-0.177	3.953	0.013	0.01	0	25.4	29.2	58.9	97	106	0	38	38
2015	12	23	19	52	22	0.636	-0.135	3.953	0.01	0.007	0	26.2	28.8	55	98	106	0	37	39
2015	12	23	20	2	22	0.64	-0.131	3.953	0.01	0.007	0	25.4	28.8	53.3	97	106	0	38	39
2015	12	23	20	12	22	0.604	-0.128	3.953	0.01	0.007	0	26.2	29.7	54.6	98	107	0	37	38
2015	12	23	20	22	22	0.636	-0.197	3.953	0.01	0.007	0	25.8	29.2	65.4	98	107	0	38	39
2015	12	23	20	32	22	0.594	-0.151	3.953	0.01	0.007	0	24.9	28	69.2	96	104	0	38	39
2015	12	23	20	42	22	0.607	-0.157	3.953	0.01	0.007	0	25.4	28.4	75.7	96	104	0	37	38
2015	12	23	20	52	22	0.643	-0.177	3.957	0.01	0.007	0	24.1	27.1	76.5	94	102	0	38	39
2015	12	23	21	2	22	0.623	-0.167	3.957	0.013	0.01	0	24.1	27.5	75.7	94	102	0	38	38
2015	12	23	21	12	22	0.643	-0.154	3.953	0.01	0.007	0	24.9	27.5	53.3	95	103	0	37	39
2015	12	23	21	22	22	0.643	-0.151	3.953	0.013	0.01	0	24.9	28.4	53.3	96	105	0	38	39
2015	12	23	21	32	22	0.653	-0.144	3.953	0.01	0.007	0	24.9	28	55	96	104	0	38	39
2015	12	23	21	42	22	0.64	-0.154	3.957	0.013	0.01	0	25.4	28.8	60.6	97	106	0	38	39
2015	12	23	21	52	22	0.62	-0.148	3.957	0.01	0.007	0	27.5	31.4	66.7	102	112	0	38	39
2015	12	23	22	2	22	0.61	-0.144	3.957	0.01	0.007	0	26.2	29.7	67.9	98	107	0	37	38
2015	12	23	22	12	22	0.594	-0.171	3.957	0.01	0.007	0	25.8	29.2	76.1	97	106	0	37	38
2015	12	23	22	22	22	0.623	-0.148	3.957	0.01	0.007	0	25.8	29.2	76.5	98	107	0	38	39
2015	12	23	22	32	22	0.61	-0.161	3.957	0.01	0.007	0	25.4	28.8	77	96	105	0	37	38
2015	12	23	22	42	22	0.594	-0.141	3.957	0.01	0.007	0	24.9	28.4	76.5	95	104	0	37	38
2015	12	23	22	52	22	0.617	-0.164	3.957	0.01	0.007	0	24.5	28	76.1	95	104	0	38	39
2015	12	23	23	2	22	0.604	-0.141	3.957	0.01	0.007	0	24.9	28	77	95	104	0	37	39
2015	12	23	23	12	22	0.627	-0.135	3.957	0.01	0.007	0	25.4	28.8	77	96	105	0	37	38
2015	12	23	23	22	22	0.561	-0.138	3.96	0.013	0.01	0	24.5	28.4	77.4	95	104	0	38	38
2015	12	23	23	32	22	0.62	-0.157	3.957	0.01	0.007	0	24.1	28	77	94	103	0	38	38
2015	12	23	23	42	22	0.591	-0.171	3.957	0.01	0.007	0	24.5	28.4	77.4	95	104	0	38	38
2015	12	23	23	52	22	0.636	-0.194	3.96	0.01	0.007	0	25.4	28.4	77	96	104	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	0	2	22	0.62	-0.138	3.96	0.01	0.007	0	27.5	31	77.4	102	111	0	38	39
2015	12	24	0	12	22	0.627	-0.161	3.96	0.01	0.007	0	25.8	28.8	77	97	106	0	37	39
2015	12	24	0	22	22	0.604	-0.154	3.96	0.01	0.007	0	24.5	27.5	77.8	95	103	0	38	39
2015	12	24	0	32	22	0.584	-0.171	3.96	0.01	0.007	0	24.9	28	77.8	95	104	0	37	39
2015	12	24	0	42	22	0.617	-0.154	3.96	0.01	0.007	0	24.5	27.5	71.4	95	103	0	38	39
2015	12	24	0	52	22	0.617	-0.161	3.96	0.016	0.013	0	24.1	27.5	77.8	94	103	0	38	39
2015	12	24	1	2	22	0.6	-0.167	3.96	0.01	0.007	0	24.9	27.5	78.3	95	103	0	37	39
2015	12	24	1	12	22	0.623	-0.167	3.96	0.01	0.007	0	25.4	28.4	77.8	96	104	0	37	38
2015	12	24	1	22	22	0.623	-0.148	3.96	0.01	0.007	0	24.9	28	77.8	96	104	0	38	39
2015	12	24	1	32	22	0.62	-0.167	3.96	0.01	0.007	0	24.9	28	78.3	95	103	0	37	38
2015	12	24	1	42	22	0.617	-0.167	3.96	0.01	0.007	0	24.9	28.4	78.3	95	104	0	37	38
2015	12	24	1	52	22	0.597	-0.19	3.96	0.01	0.007	0	24.5	28	78.3	95	104	0	38	39
2015	12	24	2	2	22	0.63	-0.161	3.96	0.01	0.007	0	24.9	28.4	78.3	96	104	0	38	38
2015	12	24	2	12	22	0.627	-0.203	3.96	0.01	0.007	0	24.9	28	77.8	95	103	0	37	38
2015	12	24	2	22	22	0.614	-0.148	3.96	0.01	0.007	0	24.5	28	78.3	95	104	0	38	39
2015	12	24	2	32	22	0.63	-0.157	3.96	0.01	0.007	0	25.8	28.8	77.4	98	106	0	38	39
2015	12	24	2	42	22	0.656	-0.135	3.96	0.013	0.01	0	34.8	38.3	77	119	128	0	38	39
2015	12	24	2	52	22	0.63	-0.164	3.96	0.01	0.007	0	30.5	34.4	77.8	109	118	0	38	38
2015	12	24	3	2	22	0.63	-0.138	3.96	0.01	0.007	0	31.8	35.3	77.8	111	121	0	37	39
2015	12	24	3	12	22	0.656	-0.161	3.96	0.01	0.007	0	27.1	30.5	75.7	101	110	0	38	39
2015	12	24	3	22	22	0.604	-0.131	3.96	0.01	0.007	0	26.2	29.2	76.5	98	107	0	37	39
2015	12	24	3	32	22	0.61	-0.171	3.96	0.01	0.007	0	27.1	31	71.8	101	110	0	38	38
2015	12	24	3	42	22	0.643	-0.141	3.96	0.01	0.007	0	27.1	30.5	71.8	101	110	0	38	39
2015	12	24	3	52	22	0.646	-0.171	3.96	0.01	0.007	0	25.4	29.2	62.8	97	107	0	38	39
2015	12	24	4	2	22	0.653	-0.171	3.96	0.01	0.007	0	24.9	28.8	61.5	95	105	0	37	38
2015	12	24	4	12	22	0.63	-0.151	3.96	0.01	0.007	0	26.7	30.1	68.8	99	109	0	37	39
2015	12	24	4	22	22	0.594	-0.167	3.96	0.01	0.007	0	27.1	31.4	60.6	101	112	0	38	39
2015	12	24	4	32	22	0.587	-0.128	3.96	0.01	0.007	0	27.5	31.4	75.7	102	112	0	38	39
2015	12	24	4	42	22	0.617	-0.18	3.96	0.01	0.007	0	24.9	28.8	58.9	96	106	0	38	39
2015	12	24	4	52	22	0.62	-0.154	3.96	0.01	0.007	0	25.4	28.8	77.4	96	105	0	37	38
2015	12	24	5	2	22	0.6	-0.144	3.96	0.01	0.007	0	24.9	28	77.4	95	104	0	37	39
2015	12	24	5	12	22	0.604	-0.167	3.96	0.013	0.01	0	24.9	28	77.4	96	104	0	38	39
2015	12	24	5	22	22	0.643	-0.157	3.96	0.01	0.007	0	26.2	29.7	77	98	107	0	37	38
2015	12	24	5	32	22	0.607	-0.174	3.963	0.013	0.01	0	24.5	27.5	77.4	95	103	0	38	39
2015	12	24	5	42	22	0.6	-0.177	3.963	0.01	0.007	0	24.9	27.5	77.4	95	103	0	37	39
2015	12	24	5	52	22	0.623	-0.164	3.96	0.01	0.007	0	24.1	27.5	77.4	94	102	0	38	38
2015	12	24	6	2	22	0.6	-0.19	3.96	0.01	0.007	0	24.1	28	77	94	103	0	38	38
2015	12	24	6	12	22	0.587	-0.157	3.96	0.01	0.007	0	24.9	27.5	77.4	95	103	0	37	39
2015	12	24	6	22	22	0.61	-0.177	3.963	0.01	0.007	0	24.5	27.1	77.4	94	102	0	37	39
2015	12	24	6	32	22	0.614	-0.197	3.963	0.01	0.007	0	24.5	27.5	77.4	94	102	0	37	38
2015	12	24	6	42	22	0.581	-0.154	3.963	0.01	0.007	0	24.5	27.5	74	94	103	0	37	39
2015	12	24	6	52	22	0.63	-0.171	3.963	0.01	0.007	0	24.1	26.7	77.4	94	101	0	38	39
2015	12	24	7	2	22	0.604	-0.187	3.963	0.01	0.007	0	24.1	27.5	77	94	102	0	38	38
2015	12	24	7	12	22	0.587	-0.157	3.963	0.01	0.007	0	24.5	27.5	75.7	95	103	0	38	39
2015	12	24	7	22	22	0.587	-0.19	3.963	0.01	0.007	0	24.5	27.5	77.4	94	102	0	37	38
2015	12	24	7	32	22	0.597	-0.174	3.963	0.01	0.007	0	24.1	27.1	77.4	94	102	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	7	42	22	0.614	-0.148	3.963	0.013	0.01	0	23.6	27.1	74.8	93	102	0	38	39
2015	12	24	7	52	22	0.574	-0.151	3.963	0.01	0.007	0	24.9	27.1	77.4	95	102	0	37	39
2015	12	24	8	2	22	0.63	-0.194	3.963	0.01	0.007	0	24.5	27.5	77.4	95	103	0	38	39
2015	12	24	8	12	22	0.62	-0.144	3.963	0.013	0.01	0	24.5	27.5	77	95	102	0	38	38
2015	12	24	8	22	22	0.61	-0.197	3.963	0.01	0.007	0	24.1	27.1	74.4	94	102	0	38	39
2015	12	24	8	32	22	0.584	-0.184	3.967	0.01	0.007	0	24.5	27.1	69.2	94	102	0	37	39
2015	12	24	8	42	22	0.594	-0.184	3.967	0.01	0.007	0	24.5	27.5	76.5	95	102	0	38	38
2015	12	24	8	52	22	0.614	-0.2	3.967	0.01	0.007	0	23.6	26.7	68.8	93	101	0	38	39
2015	12	24	9	2	22	0.607	-0.184	3.967	0.01	0.007	0	24.5	27.5	75.3	95	103	0	38	39
2015	12	24	9	12	22	0.604	-0.187	3.967	0.01	0.007	0	24.5	27.5	67.5	94	102	0	37	38
2015	12	24	9	22	22	0.617	-0.18	3.967	0.01	0.007	0	24.5	27.1	54.6	94	102	0	37	39
2015	12	24	9	32	22	0.607	-0.194	3.97	0.01	0.007	0	24.1	27.5	54.2	94	102	0	38	38
2015	12	24	9	42	22	0.587	-0.2	3.97	0.01	0.007	0	24.1	27.5	54.6	93	103	0	37	39
2015	12	24	9	52	22	0.594	-0.141	3.97	0.013	0.01	0	24.5	28	61.5	94	104	0	37	39
2015	12	24	10	2	22	0.617	-0.18	3.97	0.01	0.007	0	24.1	27.1	66.7	93	102	0	37	39
2015	12	24	10	12	22	0.607	-0.154	3.97	0.01	0.007	0	24.1	27.1	67.5	94	102	0	38	39
2015	12	24	10	22	22	0.617	-0.187	3.97	0.01	0.007	0	24.5	27.5	75.3	95	102	0	38	38
2015	12	24	10	32	22	0.669	-0.141	3.973	0.01	0.007	0	24.9	27.5	55	96	103	0	38	39
2015	12	24	10	42	22	0.689	-0.151	3.97	0.01	0.007	0	27.5	29.7	54.2	101	108	0	37	39
2015	12	24	10	52	22	0.646	-0.141	3.973	0.01	0.007	0	28.4	31.4	55	104	112	0	38	39
2015	12	24	11	2	22	0.659	-0.128	3.973	0.016	0.013	0	28	31	50.7	103	111	0	38	39
2015	12	24	11	12	22	0.653	-0.128	3.973	0.01	0.007	0	26.7	29.7	52.9	100	108	0	38	39
2015	12	24	11	22	22	0.666	-0.154	3.976	0.013	0.01	0	26.7	29.2	51.2	99	106	0	37	38
2015	12	24	11	32	22	0.623	-0.121	3.973	0.01	0.007	0	27.1	29.7	55.9	100	108	0	37	39
2015	12	24	11	42	22	0.659	-0.174	3.973	0.01	0.007	0	25.8	28.8	58.5	97	106	0	37	39
2015	12	24	11	52	22	0.669	-0.141	3.973	0.01	0.007	0	26.7	29.7	53.8	100	107	0	38	38
2015	12	24	12	2	22	0.682	-0.115	3.973	0.01	0.007	0	29.7	32.3	52	106	114	0	37	39
2015	12	24	12	12	22	0.62	-0.138	3.973	0.01	0.007	0	27.1	30.5	58.9	101	110	0	38	39
2015	12	24	12	22	22	0.623	-0.141	3.976	0.01	0.007	0	26.7	29.7	50.3	100	108	0	38	39
2015	12	24	12	32	22	0.646	-0.207	3.973	0.01	0.007	0	25.4	29.2	61.5	97	106	0	38	38
2015	12	24	12	42	22	0.61	-0.167	3.973	0.01	0.007	0	25.4	28.8	59.3	97	106	0	38	39
2015	12	24	12	52	22	0.623	-0.164	3.973	0.01	0.007	0	25.8	28.8	61.1	97	105	0	37	38
2015	12	24	13	2	22	0.62	-0.18	3.973	0.01	0.007	0	24.5	27.5	75.3	95	103	0	38	39
2015	12	24	13	12	22	0.607	-0.18	3.973	0.013	0.01	0	25.4	28	62.8	96	104	0	37	39
2015	12	24	13	22	22	0.617	-0.151	3.973	0.01	0.007	0	25.8	28.4	52.5	97	105	0	37	39
2015	12	24	13	32	22	0.607	-0.167	3.97	0.01	0.007	0	25.8	29.2	74.4	97	106	0	37	38
2015	12	24	13	42	22	0.62	-0.164	3.97	0.01	0.007	0	24.9	28.4	64.5	96	105	0	38	39
2015	12	24	13	52	22	0.636	-0.18	3.97	0.01	0.007	0	26.7	30.1	56.3	99	108	0	37	38
2015	12	24	14	2	22	0.643	-0.125	3.973	0.013	0.01	0	34	37.4	52	116	125	0	37	38
2015	12	24	14	12	22	0.627	-0.118	3.97	0.01	0.007	0	29.7	32.7	60.6	106	115	0	37	39
2015	12	24	14	22	22	0.643	-0.135	3.97	0.013	0.01	0	28.4	31.8	54.2	104	113	0	38	39
2015	12	24	14	32	22	0.63	-0.138	3.97	0.013	0.01	0	27.5	31.4	59.8	102	112	0	38	39
2015	12	24	14	42	22	0.636	-0.161	3.97	0.01	0.007	0	29.2	32.3	58.5	105	114	0	37	39
2015	12	24	14	52	22	0.64	-0.138	3.967	0.01	0.007	0	31	35.3	55.5	110	120	0	38	38
2015	12	24	15	2	22	0.633	-0.141	3.97	0.013	0.01	0	29.7	33.5	65.8	107	116	0	38	38
2015	12	24	15	12	22	0.646	-0.141	3.97	0.01	0.007	0	29.2	32.7	53.8	105	114	0	37	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	15	22	22	0.646	-0.148	3.97	0.01	0.007	0	28	31.4	55.9	102	111	0	37	38
2015	12	24	15	32	22	0.676	-0.128	3.97	0.01	0.007	0	27.5	31	54.2	101	110	0	37	38
2015	12	24	15	42	22	0.646	-0.144	3.97	0.01	0.007	0	26.7	30.5	55.9	100	109	0	38	38
2015	12	24	15	52	22	0.656	-0.121	3.97	0.01	0.007	0	27.5	31	54.2	101	110	0	37	38
2015	12	24	16	2	22	0.666	-0.157	3.97	0.01	0.007	0	28	31.4	53.8	102	111	0	37	38
2015	12	24	16	12	22	0.656	-0.141	3.97	0.01	0.007	0	26.7	29.7	53.8	99	108	0	37	39
2015	12	24	16	22	22	0.607	-0.151	3.97	0.01	0.007	0	26.7	30.1	54.6	99	109	0	37	39
2015	12	24	16	32	22	0.669	-0.108	3.967	0.01	0.007	0	27.1	29.7	55	101	108	0	38	39
2015	12	24	16	42	22	0.65	-0.148	3.967	0.01	0.007	0	27.5	30.5	61.5	101	110	0	37	39
2015	12	24	16	52	22	0.656	-0.161	3.97	0.01	0.007	0	26.2	29.7	63.6	98	107	0	37	38
2015	12	24	17	2	22	0.62	-0.148	3.97	0.01	0.007	0	25.8	29.2	76.1	97	106	0	37	38
2015	12	24	17	12	22	0.636	-0.177	3.97	0.01	0.007	0	25.4	28.4	77.4	97	105	0	38	39
2015	12	24	17	22	22	0.623	-0.171	3.97	0.01	0.007	0	24.5	28.4	77.4	95	104	0	38	38
2015	12	24	17	32	22	0.61	-0.177	3.967	0.01	0.007	0	24.5	28	73.5	95	104	0	38	39
2015	12	24	17	42	22	0.623	-0.164	3.97	0.01	0.007	0	26.2	29.2	77	98	107	0	37	39
2015	12	24	17	52	22	0.617	-0.18	3.97	0.01	0.007	0	25.8	29.7	77.4	98	107	0	38	38
2015	12	24	18	2	22	0.63	-0.157	3.97	0.01	0.007	0	25.4	28.4	57.6	96	105	0	37	39
2015	12	24	18	12	22	0.64	-0.157	3.97	0.01	0.007	0	27.5	31.4	60.2	102	112	0	38	39
2015	12	24	18	22	22	0.61	-0.197	3.967	0.01	0.007	0	25.8	28.8	67.9	98	106	0	38	39
2015	12	24	18	32	22	0.617	-0.177	3.967	0.01	0.007	0	24.9	28.8	65.8	96	105	0	38	38
2015	12	24	18	42	22	0.627	-0.108	3.97	0.016	0.016	0	25.4	28.8	52.9	97	105	0	38	38
2015	12	24	18	52	22	0.659	-0.128	3.97	0.01	0.007	0	25.8	28.8	53.8	98	106	0	38	39
2015	12	24	19	2	22	0.633	-0.125	3.97	0.01	0.007	0	25.8	29.2	49.9	98	106	0	38	38
2015	12	24	19	12	22	0.64	-0.157	3.97	0.01	0.007	0	27.1	31.4	52	101	110	0	38	37
2015	12	24	19	22	22	0.669	-0.141	3.973	0.013	0.01	0	28.8	31.8	49.9	104	113	0	37	39
2015	12	24	19	32	22	0.679	-0.118	3.973	0.01	0.007	0	29.2	32.3	48.2	106	114	0	38	39
2015	12	24	19	42	22	0.666	-0.138	3.967	0.01	0.007	0	31	34.4	47.7	110	119	0	38	39
2015	12	24	19	52	22	0.627	-0.135	3.967	0.01	0.007	0	31.4	34.4	49.5	110	119	0	37	39
2015	12	24	20	2	22	0.614	-0.118	3.967	0.01	0.007	0	31	34.4	55	109	119	0	37	39
2015	12	24	20	12	22	0.614	-0.131	3.967	0.01	0.007	0	29.7	34.4	66.2	107	118	0	38	38
2015	12	24	20	22	22	0.623	-0.138	3.97	0.01	0.007	0	29.2	33.1	65.8	106	116	0	38	39
2015	12	24	20	32	22	0.653	-0.154	3.97	0.013	0.01	0	28.4	32.7	60.2	104	114	0	38	38
2015	12	24	20	42	22	0.63	-0.128	3.97	0.01	0.007	0	29.2	33.1	67.1	105	115	0	37	38
2015	12	24	20	52	22	0.643	-0.135	3.97	0.01	0.007	0	28.8	32.3	60.6	104	114	0	37	39
2015	12	24	21	2	22	0.643	-0.171	3.97	0.01	0.007	0	27.5	31	77.4	102	111	0	38	39
2015	12	24	21	12	22	0.597	-0.174	3.97	0.01	0.007	0	27.1	31	76.1	101	110	0	38	38
2015	12	24	21	22	22	0.63	-0.148	3.97	0.01	0.007	0	28.8	32.7	70.1	105	114	0	38	38
2015	12	24	21	32	22	0.61	-0.144	3.97	0.01	0.007	0	30.1	34.4	75.7	107	118	0	37	38
2015	12	24	21	42	22	0.607	-0.161	3.97	0.01	0.007	0	27.5	31	75.3	102	111	0	38	39
2015	12	24	21	52	22	0.584	-0.141	3.97	0.01	0.007	0	28.8	32.7	78.3	105	114	0	38	38
2015	12	24	22	2	22	0.623	-0.157	3.97	0.01	0.007	0	27.1	31	78.3	101	110	0	38	38
2015	12	24	22	12	22	0.594	-0.171	3.97	0.01	0.007	0	26.7	30.5	77.8	99	109	0	37	38
2015	12	24	22	22	22	0.614	-0.157	3.97	0.01	0.007	0	26.7	29.7	77.8	99	108	0	37	39
2015	12	24	22	32	22	0.633	-0.141	3.97	0.01	0.007	0	25.4	28.8	72.2	97	106	0	38	39
2015	12	24	22	42	22	0.62	-0.148	3.97	0.01	0.007	0	29.2	33.1	76.5	106	116	0	38	39
2015	12	24	22	52	22	0.64	-0.148	3.97	0.01	0.007	0	30.1	34.8	76.5	108	119	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	23	2	22	0.617	-0.167	3.97	0.01	0.007	0	28.8	33.1	77.8	105	115	0	38	38
2015	12	24	23	12	22	0.614	-0.19	3.97	0.01	0.007	0	27.1	30.5	77.8	100	110	0	37	39
2015	12	24	23	22	22	0.636	-0.131	3.97	0.013	0.01	0	27.1	30.1	77.4	100	109	0	37	39
2015	12	24	23	32	22	0.614	-0.171	3.97	0.013	0.01	0	26.7	29.7	77	99	108	0	37	39
2015	12	24	23	42	22	0.623	-0.164	3.97	0.01	0.007	0	26.2	29.7	76.5	98	107	0	37	38
2015	12	24	23	52	22	0.633	-0.174	3.97	0.01	0.007	0	25.8	29.2	77.4	97	106	0	37	38
2015	12	25	0	2	22	0.61	-0.18	3.97	0.01	0.007	0	25.4	28.4	77.4	97	105	0	38	39
2015	12	25	0	12	22	0.6	-0.171	3.97	0.01	0.007	0	24.9	28.8	77.4	96	105	0	38	38
2015	12	25	0	22	22	0.63	-0.154	3.97	0.01	0.007	0	24.9	28.4	77.4	96	105	0	38	39
2015	12	25	0	32	22	0.607	-0.177	3.97	0.01	0.007	0	24.9	28	77	96	104	0	38	39
2015	12	25	0	42	22	0.617	-0.184	3.97	0.01	0.007	0	24.9	28.4	77.8	96	104	0	38	38
2015	12	25	0	52	22	0.61	-0.151	3.97	0.013	0.01	0	25.4	28.4	77.4	97	105	0	38	39
2015	12	25	1	2	22	0.617	-0.177	3.97	0.01	0.007	0	24.5	27.5	77.4	95	103	0	38	39
2015	12	25	1	12	22	0.61	-0.187	3.97	0.01	0.007	0	24.1	27.1	77.4	94	102	0	38	39
2015	12	25	1	22	22	0.594	-0.203	3.97	0.01	0.007	0	25.4	28	77	96	104	0	37	39
2015	12	25	1	32	22	0.614	-0.184	3.97	0.01	0.007	0	24.5	27.5	77	95	103	0	38	39
2015	12	25	1	42	22	0.607	-0.174	3.97	0.016	0.013	0	24.9	28	76.1	95	103	0	37	38
2015	12	25	1	52	22	0.577	-0.203	3.97	0.01	0.007	0	24.1	27.1	77	94	102	0	38	39
2015	12	25	2	2	22	0.617	-0.2	3.967	0.01	0.007	0	25.4	28.4	77.4	96	104	0	37	38
2015	12	25	2	12	22	0.597	-0.19	3.97	0.01	0.007	0	24.5	28.4	77.4	95	104	0	38	38
2015	12	25	2	22	22	0.594	-0.177	3.97	0.01	0.007	0	24.9	27.5	77.4	95	103	0	37	39
2015	12	25	2	32	22	0.581	-0.207	3.967	0.01	0.007	0	24.9	27.5	77	95	103	0	37	39
2015	12	25	2	42	22	0.607	-0.184	3.967	0.01	0.007	0	24.5	27.5	77	95	103	0	38	39
2015	12	25	2	52	22	0.577	-0.19	3.967	0.01	0.007	0	24.5	27.5	77.4	94	103	0	37	39
2015	12	25	3	2	22	0.594	-0.177	3.967	0.01	0.007	0	24.1	28	77	94	103	0	38	38
2015	12	25	3	12	22	0.587	-0.184	3.967	0.013	0.01	0	25.4	28.8	77.4	96	105	0	37	38
2015	12	25	3	22	22	0.607	-0.19	3.967	0.01	0.007	0	26.2	30.1	77.4	99	109	0	38	39
2015	12	25	3	32	22	0.62	-0.194	3.97	0.01	0.007	0	35.7	38.7	75.7	121	129	0	38	39
2015	12	25	3	42	22	0.62	-0.187	3.97	0.013	0.01	0	37.4	41.7	76.1	125	135	0	38	38
2015	12	25	3	52	22	0.633	-0.18	3.967	0.01	0.007	0	33.5	37.8	77	115	126	0	37	38
2015	12	25	4	2	22	0.607	-0.157	3.97	0.01	0.007	0	31	34.4	77.8	110	119	0	38	39
2015	12	25	4	12	22	0.604	-0.187	3.967	0.013	0.01	0	28.8	32.7	77	105	114	0	38	38
2015	12	25	4	22	22	0.587	-0.18	3.967	0.01	0.007	0	27.5	30.5	77	102	110	0	38	39
2015	12	25	4	32	22	0.646	-0.177	3.967	0.01	0.007	0	28.4	31.4	77	104	113	0	38	40
2015	12	25	4	42	22	0.61	-0.207	3.967	0.01	0.007	0	25.4	29.2	77	97	106	0	38	38
2015	12	25	4	52	22	0.633	-0.21	3.967	0.01	0.007	0	24.9	28.4	76.1	95	105	0	37	39
2015	12	25	5	2	22	0.63	-0.194	3.967	0.01	0.007	0	28	31.4	76.1	103	112	0	38	39
2015	12	25	5	12	22	0.597	-0.184	3.967	0.01	0.007	0	25.4	29.2	75.7	97	106	0	38	38
2015	12	25	5	22	22	0.574	-0.194	3.967	0.01	0.007	0	24.5	28	76.1	95	104	0	38	39
2015	12	25	5	32	22	0.591	-0.187	3.967	0.013	0.01	0	24.5	28	73.5	95	104	0	38	39
2015	12	25	5	42	22	0.604	-0.177	3.967	0.01	0.007	0	24.5	28	71.4	94	103	0	37	38
2015	12	25	5	52	22	0.6	-0.167	3.967	0.01	0.007	0	24.1	28	64.1	94	103	0	38	38
2015	12	25	6	2	22	0.594	-0.177	3.967	0.01	0.007	0	24.1	27.5	72.7	94	102	0	38	38
2015	12	25	6	12	22	0.604	-0.187	3.967	0.01	0.007	0	24.9	28	76.1	95	103	0	37	38
2015	12	25	6	22	22	0.591	-0.19	3.967	0.01	0.007	0	24.1	28	76.5	94	103	0	38	38
2015	12	25	6	32	22	0.614	-0.19	3.967	0.01	0.007	0	23.6	27.1	73.1	93	102	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	6	42	22	0.594	-0.184	3.967	0.01	0.007	0	23.6	27.1	51.6	93	102	0	38	39
2015	12	25	6	52	22	0.591	-0.19	3.967	0.01	0.007	0	24.5	28	75.3	95	103	0	38	38
2015	12	25	7	2	22	0.607	-0.194	3.967	0.01	0.007	0	23.6	26.7	74.4	93	101	0	38	39
2015	12	25	7	12	22	0.584	-0.22	3.967	0.013	0.01	0	23.6	27.1	75.7	93	101	0	38	38
2015	12	25	7	22	22	0.627	-0.2	3.967	0.01	0.007	0	24.5	27.5	76.1	94	102	0	37	38
2015	12	25	7	32	22	0.617	-0.207	3.967	0.01	0.007	0	24.5	27.1	76.5	94	102	0	37	39
2015	12	25	7	42	22	0.604	-0.174	3.967	0.01	0.007	0	24.1	27.1	76.5	93	101	0	37	38
2015	12	25	7	52	22	0.587	-0.223	3.967	0.013	0.01	0	24.5	26.7	77	94	101	0	37	39
2015	12	25	8	2	22	0.571	-0.19	3.967	0.01	0.007	0	24.1	27.1	76.5	94	102	0	38	39
2015	12	25	8	12	22	0.61	-0.194	3.967	0.01	0.007	0	24.5	27.5	76.5	94	102	0	37	38
2015	12	25	8	22	22	0.587	-0.19	3.967	0.01	0.007	0	24.1	27.1	76.5	94	102	0	38	39
2015	12	25	8	32	22	0.614	-0.207	3.967	0.01	0.007	0	24.1	27.1	76.5	94	101	0	38	38
2015	12	25	8	42	22	0.594	-0.213	3.967	0.013	0.01	0	24.1	27.5	77	94	102	0	38	38
2015	12	25	8	52	22	0.591	-0.207	3.97	0.013	0.01	0	24.1	27.5	77.4	94	102	0	38	38
2015	12	25	9	2	22	0.591	-0.207	3.967	0.01	0.007	0	24.5	27.1	76.5	95	102	0	38	39
2015	12	25	9	12	22	0.558	-0.184	3.97	0.01	0.007	0	24.9	27.1	76.1	95	102	0	37	39
2015	12	25	9	22	22	0.561	-0.2	3.97	0.01	0.007	0	24.5	28	72.2	94	102	0	37	37
2015	12	25	9	32	22	0.551	-0.207	3.97	0.01	0.007	0	24.5	27.1	77	95	102	0	38	39
2015	12	25	9	42	22	0.574	-0.213	3.97	0.01	0.007	0	24.9	27.1	77	95	102	0	37	39
2015	12	25	9	52	22	0.558	-0.223	3.97	0.01	0.007	0	24.9	27.5	77	96	102	0	38	38
2015	12	25	10	2	22	0.587	-0.217	3.97	0.01	0.007	0	24.9	27.5	77.4	95	102	0	37	38
2015	12	25	10	12	22	0.597	-0.226	3.97	0.01	0.007	0	24.1	27.1	77	94	101	0	38	38
2015	12	25	10	22	22	0.587	-0.233	3.97	0.01	0.007	0	24.5	27.1	77.4	94	101	0	37	38
2015	12	25	10	32	22	0.6	-0.207	3.97	0.01	0.007	0	24.1	27.5	77	94	102	0	38	38
2015	12	25	10	42	22	0.581	-0.21	3.973	0.01	0.007	0	24.1	26.7	77	94	101	0	38	39
2015	12	25	10	52	22	0.558	-0.246	3.973	0.01	0.007	0	23.6	26.7	75.7	93	101	0	38	39
2015	12	25	11	2	22	0.591	-0.226	3.973	0.01	0.007	0	24.1	27.1	77.4	94	102	0	38	39
2015	12	25	11	12	22	0.574	-0.223	3.973	0.01	0.007	0	24.1	27.1	77	93	101	0	37	38
2015	12	25	11	22	22	0.581	-0.217	3.973	0.01	0.007	0	24.1	26.2	77.8	93	100	0	37	39
2015	12	25	11	32	22	0.558	-0.203	3.973	0.01	0.007	0	24.5	26.7	76.1	94	101	0	37	39
2015	12	25	11	42	22	0.571	-0.207	3.973	0.01	0.007	0	23.6	27.1	76.1	94	101	0	39	38
2015	12	25	11	52	22	0.541	-0.207	3.973	0.01	0.007	0	24.1	26.2	77	93	100	0	37	39
2015	12	25	12	2	22	0.551	-0.233	3.973	0.01	0.007	0	24.1	26.7	77	94	101	0	38	39
2015	12	25	12	12	22	0.591	-0.226	3.973	0.013	0.01	0	23.6	27.1	77.8	93	101	0	38	38
2015	12	25	12	22	22	0.617	-0.144	3.973	0.01	0.007	0	23.6	26.2	54.6	93	100	0	38	39
2015	12	25	12	32	22	0.643	-0.167	3.973	0.01	0.007	0	24.5	27.1	52	94	101	0	37	38
2015	12	25	12	42	22	0.656	-0.112	3.973	0.01	0.007	0	25.4	27.5	51.6	96	103	0	37	39
2015	12	25	12	52	22	0.64	-0.138	3.973	0.01	0.007	0	25.8	27.5	53.3	97	103	0	37	39
2015	12	25	13	2	22	0.673	-0.141	3.97	0.01	0.007	0	25.4	28.4	50.7	97	104	0	38	38
2015	12	25	13	12	22	0.633	-0.154	3.97	0.01	0.007	0	25.4	28.4	52.9	97	105	0	38	39
2015	12	25	13	22	22	0.61	-0.141	3.973	0.01	0.007	0	24.9	28.4	53.3	96	104	0	38	38
2015	12	25	13	32	22	0.636	-0.157	3.97	0.01	0.007	0	25.4	27.5	52	96	103	0	37	39
2015	12	25	13	42	22	0.636	-0.154	3.97	0.01	0.007	0	25.4	27.5	52.5	96	103	0	37	39
2015	12	25	13	52	22	0.656	-0.161	3.97	0.01	0.007	0	24.9	27.5	52.9	95	102	0	37	38
2015	12	25	14	2	22	0.61	-0.125	3.97	0.01	0.007	0	24.5	27.1	52	94	102	0	37	39
2015	12	25	14	12	22	0.659	-0.135	3.967	0.01	0.007	0	24.5	27.5	51.2	95	102	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	14	22	22	0.656	-0.157	3.967	0.013	0.01	0	24.9	28	49.9	96	103	0	38	38
2015	12	25	14	32	22	0.659	-0.128	3.967	0.01	0.007	0	25.4	28	51.2	97	103	0	38	38
2015	12	25	14	42	22	0.65	-0.164	3.967	0.01	0.007	0	24.9	28	52.5	96	103	0	38	38
2015	12	25	14	52	22	0.643	-0.141	3.963	0.01	0.007	0	24.9	27.1	49.9	96	102	0	38	39
2015	12	25	15	2	22	0.643	-0.138	3.967	0.01	0.007	0	24.5	27.1	50.3	94	102	0	37	39
2015	12	25	15	12	22	0.666	-0.164	3.963	0.01	0.007	0	25.4	27.5	50.7	96	102	0	37	38
2015	12	25	15	22	22	0.673	-0.164	3.963	0.01	0.007	0	24.9	27.5	52.9	96	102	0	38	38
2015	12	25	15	32	22	0.633	-0.141	3.963	0.01	0.007	0	24.9	26.7	53.3	95	101	0	37	39
2015	12	25	15	42	22	0.597	-0.144	3.963	0.013	0.01	0	23.6	26.7	55.5	93	101	0	38	39
2015	12	25	15	52	22	0.591	-0.177	3.963	0.01	0.007	0	23.2	26.2	63.6	92	100	0	38	39
2015	12	25	16	2	22	0.594	-0.187	3.963	0.01	0.007	0	23.2	26.2	73.5	92	100	0	38	39
2015	12	25	16	12	22	0.577	-0.197	3.963	0.01	0.007	0	23.6	26.7	75.3	92	100	0	37	38
2015	12	25	16	22	22	0.591	-0.194	3.963	0.01	0.007	0	24.1	26.2	77	93	100	0	37	39
2015	12	25	16	32	22	0.64	-0.121	3.963	0.01	0.007	0	23.6	25.8	52	93	99	0	38	39
2015	12	25	16	42	22	0.656	-0.148	3.96	0.013	0.01	0	23.2	26.7	54.6	92	100	0	38	38
2015	12	25	16	52	22	0.63	-0.141	3.96	0.013	0.01	0	23.2	26.2	53.8	92	100	0	38	39
2015	12	25	17	2	22	0.591	-0.164	3.96	0.01	0.007	0	24.1	27.1	67.5	93	102	0	37	39
2015	12	25	17	12	22	0.577	-0.22	3.96	0.01	0.007	0	23.6	26.7	75.7	92	100	0	37	38
2015	12	25	17	22	22	0.597	-0.2	3.96	0.01	0.007	0	24.1	25.8	77	93	99	0	37	39
2015	12	25	17	32	22	0.61	-0.22	3.96	0.01	0.007	0	23.6	26.7	78.7	93	100	0	38	38
2015	12	25	17	42	22	0.6	-0.19	3.96	0.01	0.007	0	27.1	30.5	77.8	101	110	0	38	39
2015	12	25	17	52	22	0.574	-0.19	3.96	0.01	0.007	0	25.4	28.8	72.7	97	106	0	38	39
2015	12	25	18	2	22	0.65	-0.131	3.96	0.013	0.01	0	24.9	28.4	52.5	96	104	0	38	38
2015	12	25	18	12	22	0.623	-0.164	3.96	0.01	0.007	0	24.9	27.5	51.6	96	103	0	38	39
2015	12	25	18	22	22	0.653	-0.128	3.957	0.01	0.007	0	24.5	28	52.5	95	104	0	38	39
2015	12	25	18	32	22	0.636	-0.144	3.96	0.01	0.007	0	24.5	27.5	50.7	95	102	0	38	38
2015	12	25	18	42	22	0.594	-0.102	3.957	0.01	0.007	0	24.1	28	52	94	103	0	38	38
2015	12	25	18	52	22	0.653	-0.148	3.957	0.01	0.007	0	25.8	28	50.3	97	104	0	37	39
2015	12	25	19	2	22	0.692	-0.138	3.957	0.01	0.007	0	25.8	28	49	97	104	0	37	39
2015	12	25	19	12	22	0.669	-0.141	3.957	0.01	0.007	0	26.7	29.2	49.9	100	106	0	38	38
2015	12	25	19	22	22	0.659	-0.148	3.957	0.01	0.007	0	28	31	48.6	103	110	0	38	38
2015	12	25	19	32	22	0.656	-0.125	3.957	0.01	0.007	0	28	31	49.5	103	111	0	38	39
2015	12	25	19	42	22	0.643	-0.115	3.957	0.01	0.007	0	28	31.4	49.9	103	112	0	38	39
2015	12	25	19	52	22	0.679	-0.141	3.957	0.013	0.01	0	27.5	31	50.7	102	110	0	38	38
2015	12	25	20	2	22	0.679	-0.151	3.96	0.01	0.007	0	27.5	29.7	48.6	101	108	0	37	39
2015	12	25	20	12	22	0.669	-0.105	3.957	0.01	0.007	0	27.1	30.5	48.6	101	110	0	38	39
2015	12	25	20	22	22	0.696	-0.105	3.957	0.01	0.007	0	28.4	31	49.9	103	110	0	37	38
2015	12	25	20	32	22	0.617	-0.089	3.957	0.01	0.007	0	27.5	30.1	49.5	102	109	0	38	39
2015	12	25	20	42	22	0.656	-0.128	3.957	0.01	0.007	0	25.8	28.8	51.6	98	106	0	38	39
2015	12	25	20	52	22	0.673	-0.171	3.957	0.01	0.007	0	25.4	28.8	52.9	96	105	0	37	38
2015	12	25	21	2	22	0.636	-0.177	3.957	0.01	0.007	0	25.4	28.4	55.9	96	105	0	37	39
2015	12	25	21	12	22	0.61	-0.187	3.957	0.01	0.007	0	25.4	28.8	78.3	96	105	0	37	38
2015	12	25	21	22	22	0.614	-0.18	3.957	0.013	0.01	0	24.5	27.5	78.7	95	103	0	38	39
2015	12	25	21	32	22	0.656	-0.154	3.957	0.01	0.007	0	24.9	28	51.6	96	104	0	38	39
2015	12	25	21	42	22	0.63	-0.141	3.957	0.01	0.007	0	24.1	27.1	57.2	94	102	0	38	39
2015	12	25	21	52	22	0.643	-0.141	3.957	0.01	0.007	0	23.6	27.5	53.3	94	102	0	39	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	22	2	22	0.617	-0.154	3.957	0.01	0.007	0	24.1	27.1	57.6	93	101	0	37	38
2015	12	25	22	12	22	0.64	-0.177	3.957	0.01	0.007	0	24.1	27.1	51.6	94	102	0	38	39
2015	12	25	22	22	22	0.617	-0.154	3.957	0.01	0.007	0	23.6	26.7	59.8	93	101	0	38	39
2015	12	25	22	32	22	0.617	-0.154	3.957	0.01	0.007	0	23.6	27.1	55	92	101	0	37	38
2015	12	25	22	42	22	0.63	-0.128	3.957	0.01	0.007	0	23.6	26.7	54.2	93	101	0	38	39
2015	12	25	22	52	22	0.607	-0.141	3.957	0.01	0.007	0	25.4	29.2	56.8	97	107	0	38	39
2015	12	25	23	2	22	0.666	-0.128	3.957	0.01	0.007	0	30.1	34	52.5	108	118	0	38	39
2015	12	25	23	12	22	0.581	-0.174	3.957	0.013	0.01	0	26.7	30.1	71	100	109	0	38	39
2015	12	25	23	22	22	0.614	-0.18	3.957	0.01	0.007	0	25.8	29.2	76.1	97	106	0	37	38
2015	12	25	23	32	22	0.663	-0.125	3.953	0.01	0.007	0	24.5	27.5	51.2	95	103	0	38	39
2015	12	25	23	42	22	0.656	-0.171	3.953	0.01	0.007	0	24.5	27.5	55	95	103	0	38	39
2015	12	25	23	52	22	0.663	-0.154	3.953	0.013	0.01	0	24.9	28	50.7	95	103	0	37	38
2015	12	26	0	2	22	0.63	-0.128	3.953	0.01	0.007	0	24.5	27.5	52	94	103	0	37	39
2015	12	26	0	12	22	0.617	-0.141	3.953	0.01	0.007	0	24.1	27.1	52	94	102	0	38	39
2015	12	26	0	22	22	0.646	-0.125	3.953	0.01	0.007	0	24.9	27.1	52.5	95	102	0	37	39
2015	12	26	0	32	22	0.65	-0.131	3.953	0.01	0.007	0	26.2	29.2	55.5	98	107	0	37	39
2015	12	26	0	42	22	0.646	-0.135	3.953	0.01	0.007	0	24.5	28	50.7	95	103	0	38	38
2015	12	26	0	52	22	0.633	-0.174	3.953	0.01	0.007	0	24.1	27.1	58.5	94	102	0	38	39
2015	12	26	1	2	22	0.666	-0.154	3.953	0.01	0.007	0	24.1	27.1	55.5	94	102	0	38	39
2015	12	26	1	12	22	0.604	-0.18	3.953	0.01	0.007	0	23.6	27.1	73.5	93	102	0	38	39
2015	12	26	1	22	22	0.62	-0.171	3.953	0.01	0.007	0	24.5	27.5	76.5	94	103	0	37	39
2015	12	26	1	32	22	0.587	-0.157	3.953	0.01	0.007	0	23.6	27.5	57.2	93	102	0	38	38
2015	12	26	1	42	22	0.61	-0.18	3.953	0.013	0.01	0	23.2	27.1	64.9	92	101	0	38	38
2015	12	26	1	52	22	0.64	-0.148	3.95	0.01	0.007	0	23.2	26.2	54.2	92	100	0	38	39
2015	12	26	2	2	22	0.607	-0.148	3.953	0.01	0.007	0	22.8	26.7	67.9	91	100	0	38	38
2015	12	26	2	12	22	0.6	-0.194	3.95	0.01	0.007	0	23.2	26.7	65.4	92	101	0	38	39
2015	12	26	2	22	22	0.627	-0.19	3.95	0.01	0.007	0	24.1	27.1	74.8	93	102	0	37	39
2015	12	26	2	32	22	0.607	-0.18	3.95	0.01	0.007	0	23.2	26.7	74.8	92	101	0	38	39
2015	12	26	2	42	22	0.594	-0.154	3.95	0.01	0.007	0	23.6	26.7	75.7	93	101	0	38	39
2015	12	26	2	52	22	0.623	-0.164	3.95	0.01	0.007	0	23.6	27.1	70.1	93	101	0	38	38
2015	12	26	3	2	22	0.594	-0.151	3.95	0.01	0.007	0	23.2	26.7	61.1	92	101	0	38	39
2015	12	26	3	12	22	0.646	-0.128	3.95	0.013	0.01	0	23.6	26.2	52	93	100	0	38	39
2015	12	26	3	22	22	0.663	-0.141	3.947	0.01	0.007	0	23.6	26.7	52	92	100	0	37	38
2015	12	26	3	32	22	0.61	-0.154	3.95	0.01	0.007	0	23.6	27.1	55	92	101	0	37	38
2015	12	26	3	42	22	0.663	-0.141	3.95	0.01	0.007	0	24.1	27.1	53.8	93	101	0	37	38
2015	12	26	3	52	22	0.617	-0.148	3.947	0.01	0.007	0	23.6	26.7	55.5	93	101	0	38	39
2015	12	26	4	2	22	0.63	-0.151	3.95	0.01	0.007	0	24.1	26.7	52.5	93	101	0	37	39
2015	12	26	4	12	22	0.63	-0.18	3.947	0.01	0.007	0	22.8	26.2	59.3	91	100	0	38	39
2015	12	26	4	22	22	0.64	-0.164	3.947	0.01	0.007	0	25.8	28.8	55	97	106	0	37	39
2015	12	26	4	32	22	0.64	-0.131	3.947	0.013	0.01	0	24.5	27.1	53.3	94	102	0	37	39
2015	12	26	4	42	22	0.666	-0.128	3.947	0.01	0.007	0	24.1	27.1	53.8	94	102	0	38	39
2015	12	26	4	52	22	0.653	-0.141	3.947	0.01	0.007	0	24.5	27.5	53.8	95	103	0	38	39
2015	12	26	5	2	22	0.676	-0.112	3.947	0.01	0.007	0	25.8	28.8	53.3	98	106	0	38	39
2015	12	26	5	12	22	0.656	-0.135	3.947	0.01	0.007	0	25.4	28	51.6	96	104	0	37	39
2015	12	26	5	22	22	0.676	-0.115	3.947	0.01	0.007	0	24.1	26.7	52	94	101	0	38	39
2015	12	26	5	32	22	0.604	-0.125	3.947	0.01	0.007	0	23.6	26.7	51.6	93	101	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	5	42	22	0.633	-0.141	3.947	0.01	0.007	0	23.2	26.2	52	92	99	0	38	38
2015	12	26	5	52	22	0.633	-0.138	3.947	0.01	0.007	0	22.8	25.8	50.3	91	99	0	38	39
2015	12	26	6	2	22	0.65	-0.164	3.944	0.01	0.007	0	22.8	26.2	52.5	91	99	0	38	38
2015	12	26	6	12	22	0.643	-0.138	3.947	0.01	0.007	0	23.2	25.8	50.7	91	99	0	37	39
2015	12	26	6	22	22	0.653	-0.125	3.944	0.01	0.007	0	24.1	26.7	49.9	93	100	0	37	38
2015	12	26	6	32	22	0.587	-0.128	3.947	0.01	0.007	0	23.2	26.2	50.3	92	100	0	38	39
2015	12	26	6	42	22	0.636	-0.164	3.944	0.01	0.007	0	23.2	25.8	50.3	91	99	0	37	39
2015	12	26	6	52	22	0.623	-0.141	3.944	0.013	0.01	0	23.2	25.8	49	92	99	0	38	39
2015	12	26	7	2	22	0.636	-0.148	3.947	0.01	0.007	0	23.6	26.2	49.9	92	100	0	37	39
2015	12	26	7	12	22	0.65	-0.148	3.947	0.01	0.007	0	23.2	26.2	51.2	91	99	0	37	38
2015	12	26	7	22	22	0.669	-0.131	3.944	0.01	0.007	0	22.8	25.8	50.7	91	99	0	38	39
2015	12	26	7	32	22	0.646	-0.144	3.944	0.01	0.007	0	22.8	25.8	50.7	91	99	0	38	39
2015	12	26	7	42	22	0.64	-0.144	3.944	0.01	0.007	0	22.8	25.4	51.2	91	98	0	38	39
2015	12	26	7	52	22	0.65	-0.141	3.947	0.01	0.007	0	23.6	25.4	51.6	92	99	0	37	40
2015	12	26	8	2	22	0.636	-0.148	3.944	0.01	0.007	0	23.6	26.7	53.8	93	100	0	38	38
2015	12	26	8	12	22	0.663	-0.121	3.944	0.01	0.007	0	24.1	27.1	49.9	94	101	0	38	38
2015	12	26	8	22	22	0.673	-0.144	3.944	0.01	0.007	0	24.5	27.1	50.3	94	101	0	37	38
2015	12	26	8	32	22	0.62	-0.135	3.944	0.01	0.007	0	24.9	28	50.7	97	104	0	39	39
2015	12	26	8	42	22	0.663	-0.164	3.944	0.01	0.007	0	24.5	27.5	50.3	96	103	0	39	39
2015	12	26	8	52	22	0.682	-0.144	3.944	0.01	0.007	0	24.9	28	49	96	103	0	38	38
2015	12	26	9	2	22	0.663	-0.131	3.944	0.01	0.007	0	26.2	29.2	49	99	106	0	38	38
2015	12	26	9	12	22	0.666	-0.154	3.947	0.01	0.007	0	27.1	29.2	49.5	100	106	0	37	38
2015	12	26	9	22	22	0.646	-0.141	3.947	0.013	0.01	0	27.1	29.7	49.9	101	108	0	38	39
2015	12	26	9	32	22	0.64	-0.141	3.947	0.01	0.007	0	27.5	30.5	50.7	102	109	0	38	38
2015	12	26	9	42	22	0.636	-0.118	3.947	0.01	0.007	0	28	30.5	49.9	102	109	0	37	38
2015	12	26	9	52	22	0.676	-0.131	3.944	0.013	0.01	0	28.8	31.4	48.6	104	111	0	37	38
2015	12	26	10	2	22	0.63	-0.098	3.947	0.01	0.007	0	29.7	33.1	50.7	107	115	0	38	38
2015	12	26	10	12	22	0.676	-0.148	3.947	0.01	0.007	0	32.3	34.8	48.6	112	120	0	37	39
2015	12	26	10	22	22	0.699	-0.102	3.944	0.01	0.007	0	31	34.4	49	110	118	0	38	38
2015	12	26	10	32	22	0.617	-0.135	3.95	0.01	0.007	0	31	34	51.2	110	118	0	38	39
2015	12	26	10	42	22	0.63	-0.092	3.947	0.01	0.007	0	31.4	34.8	49	111	120	0	38	39
2015	12	26	10	52	22	0.659	-0.128	3.947	0.01	0.007	0	31	33.1	47.3	109	116	0	37	39
2015	12	26	11	2	22	0.65	-0.095	3.947	0.01	0.007	0	31.4	34.4	50.3	111	119	0	38	39
2015	12	26	11	12	22	0.666	-0.135	3.944	0.01	0.007	0	29.2	32.3	48.2	106	114	0	38	39
2015	12	26	11	22	22	0.64	-0.121	3.95	0.01	0.007	0	28.8	31.8	50.7	104	113	0	37	39
2015	12	26	11	32	22	0.656	-0.131	3.95	0.01	0.007	0	27.5	30.5	49	102	110	0	38	39
2015	12	26	11	42	22	0.663	-0.141	3.947	0.016	0.013	0	27.5	30.1	48.6	101	108	0	37	38
2015	12	26	11	52	22	0.689	-0.115	3.947	0.01	0.007	0	27.5	30.1	49.5	101	108	0	37	38
2015	12	26	12	2	22	0.659	-0.128	3.95	0.01	0.007	0	27.5	29.7	49.5	101	108	0	37	39
2015	12	26	12	12	22	0.646	-0.089	3.947	0.01	0.007	0	27.1	29.7	49.5	101	108	0	38	39
2015	12	26	12	22	22	0.666	-0.128	3.947	0.01	0.007	0	27.1	29.2	49	100	107	0	37	39
2015	12	26	12	32	22	0.673	-0.177	3.95	0.01	0.007	0	26.7	28.8	50.3	100	106	0	38	39
2015	12	26	12	42	22	0.656	-0.138	3.95	0.01	0.007	0	25.8	28.8	48.2	98	106	0	38	39
2015	12	26	12	52	22	0.636	-0.141	3.947	0.01	0.007	0	25.8	28.4	52	98	105	0	38	39
2015	12	26	13	2	22	0.643	-0.108	3.944	0.01	0.007	0	25.8	28.4	49.9	98	105	0	38	39
2015	12	26	13	12	22	0.617	-0.125	3.944	0.01	0.007	0	25.8	28.4	49.9	98	105	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	13	22	22	0.65	-0.161	3.944	0.01	0.007	0	26.2	28	50.7	98	104	0	37	39
2015	12	26	13	32	22	0.659	-0.121	3.94	0.01	0.007	0	26.2	28.4	49.9	98	104	0	37	38
2015	12	26	13	42	22	0.666	-0.125	3.944	0.01	0.007	0	25.8	28.4	49.5	97	104	0	37	38
2015	12	26	13	52	22	0.646	-0.128	3.94	0.01	0.007	0	25.4	27.5	48.6	97	103	0	38	39
2015	12	26	14	2	22	0.653	-0.135	3.944	0.01	0.007	0	24.9	27.1	49.9	96	102	0	38	39
2015	12	26	14	12	22	0.636	-0.125	3.944	0.01	0.007	0	24.9	27.5	50.3	96	102	0	38	38
2015	12	26	14	22	22	0.614	-0.105	3.94	0.01	0.007	0	24.9	27.1	50.3	95	102	0	37	39
2015	12	26	14	32	22	0.627	-0.121	3.94	0.01	0.007	0	24.5	26.7	50.3	94	101	0	37	39
2015	12	26	14	42	22	0.64	-0.141	3.937	0.013	0.01	0	24.5	27.1	49.5	95	102	0	38	39
2015	12	26	14	52	22	0.6	-0.098	3.937	0.01	0.007	0	25.4	27.5	49	96	102	0	37	38
2015	12	26	15	2	22	0.63	-0.125	3.94	0.01	0.007	0	24.9	27.1	49	95	101	0	37	38
2015	12	26	15	12	22	0.676	-0.115	3.937	0.01	0.007	0	24.9	26.7	49.5	95	101	0	37	39
2015	12	26	15	22	22	0.643	-0.138	3.937	0.01	0.007	0	24.5	26.7	49.9	95	101	0	38	39
2015	12	26	15	32	22	0.63	-0.171	3.937	0.01	0.007	0	24.5	26.7	48.6	94	101	0	37	39
2015	12	26	15	42	22	0.64	-0.135	3.934	0.01	0.007	0	24.5	27.1	49.9	95	102	0	38	39
2015	12	26	15	52	22	0.646	-0.161	3.937	0.01	0.007	0	24.1	26.2	50.7	94	100	0	38	39
2015	12	26	16	2	22	0.653	-0.125	3.937	0.01	0.007	0	23.6	26.2	49.5	93	100	0	38	39
2015	12	26	16	12	22	0.643	-0.125	3.934	0.01	0.007	0	23.2	26.2	51.2	92	100	0	38	39
2015	12	26	16	22	22	0.627	-0.177	3.934	0.01	0.007	0	22.8	25.8	50.3	91	99	0	38	39
2015	12	26	16	32	22	0.584	-0.128	3.934	0.01	0.007	0	23.2	25.8	52.5	91	99	0	37	39
2015	12	26	16	42	22	0.659	-0.131	3.934	0.013	0.01	0	23.6	25.4	51.2	92	98	0	37	39
2015	12	26	16	52	22	0.65	-0.171	3.934	0.01	0.007	0	23.2	25.4	50.7	91	98	0	37	39
2015	12	26	17	2	22	0.623	-0.131	3.93	0.01	0.007	0	23.6	26.2	52.5	93	100	0	38	39
2015	12	26	17	12	22	0.63	-0.141	3.93	0.01	0.007	0	23.2	26.7	50.3	92	100	0	38	38
2015	12	26	17	22	22	0.633	-0.154	3.934	0.01	0.007	0	23.6	26.2	49.9	93	100	0	38	39
2015	12	26	17	32	22	0.61	-0.115	3.934	0.01	0.007	0	24.5	26.7	49.5	94	101	0	37	39
2015	12	26	17	42	22	0.627	-0.164	3.93	0.01	0.007	0	23.2	25.8	49.9	92	99	0	38	39
2015	12	26	17	52	22	0.607	-0.141	3.93	0.01	0.007	0	23.6	26.2	50.7	93	100	0	38	39
2015	12	26	18	2	22	0.623	-0.154	3.93	0.01	0.007	0	23.2	26.2	49	92	99	0	38	38
2015	12	26	18	12	22	0.61	-0.128	3.93	0.01	0.007	0	23.6	26.2	51.2	93	100	0	38	39
2015	12	26	18	22	22	0.623	-0.121	3.93	0.013	0.01	0	23.6	25.8	52	92	99	0	37	39
2015	12	26	18	32	22	0.659	-0.151	3.93	0.013	0.01	0	24.1	27.1	50.3	94	101	0	38	38
2015	12	26	18	42	22	0.627	-0.138	3.927	0.01	0.007	0	30.5	34.4	49.5	110	119	0	39	39
2015	12	26	18	52	22	0.646	-0.125	3.927	0.01	0.007	0	31.8	35.7	51.2	112	121	0	38	38
2015	12	26	19	2	22	0.65	-0.151	3.93	0.01	0.007	0	26.2	28.8	49.5	99	106	0	38	39
2015	12	26	19	12	22	0.65	-0.105	3.93	0.01	0.007	0	25.4	28	50.3	97	104	0	38	39
2015	12	26	19	22	22	0.636	-0.148	3.927	0.01	0.007	0	24.5	27.1	49.9	95	102	0	38	39
2015	12	26	19	32	22	0.646	-0.151	3.927	0.01	0.007	0	24.5	27.5	50.7	95	103	0	38	39
2015	12	26	19	42	22	0.62	-0.128	3.927	0.01	0.007	0	24.9	27.5	49.9	95	103	0	37	39
2015	12	26	19	52	22	0.65	-0.125	3.927	0.01	0.007	0	24.9	28	52.5	96	104	0	38	39
2015	12	26	20	2	22	0.646	-0.121	3.927	0.01	0.007	0	24.9	26.7	49.9	95	101	0	37	39
2015	12	26	20	12	22	0.659	-0.144	3.927	0.01	0.007	0	24.9	27.5	49.5	96	102	0	38	38
2015	12	26	20	22	22	0.666	-0.125	3.927	0.01	0.007	0	24.9	27.5	49.9	96	103	0	38	39
2015	12	26	20	32	22	0.643	-0.125	3.927	0.01	0.007	0	24.5	28	50.7	95	103	0	38	38
2015	12	26	20	42	22	0.663	-0.151	3.927	0.01	0.007	0	24.9	27.5	50.3	95	102	0	37	38
2015	12	26	20	52	22	0.659	-0.157	3.927	0.01	0.007	0	24.5	27.5	48.6	96	103	0	39	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	21	2	22	0.669	-0.167	3.927	0.013	0.01	0	24.5	27.5	50.7	95	102	0	38	38
2015	12	26	21	12	22	0.656	-0.154	3.927	0.01	0.007	0	24.5	27.1	50.3	94	102	0	37	39
2015	12	26	21	22	22	0.646	-0.141	3.924	0.01	0.007	0	24.1	26.7	52.9	94	101	0	38	39
2015	12	26	21	32	22	0.61	-0.194	3.924	0.01	0.007	0	23.2	26.7	60.2	92	101	0	38	39
2015	12	26	21	42	22	0.617	-0.154	3.921	0.01	0.007	0	23.6	26.7	54.6	93	101	0	38	39
2015	12	26	21	52	22	0.577	-0.177	3.921	0.01	0.007	0	23.2	26.7	69.2	92	101	0	38	39
2015	12	26	22	2	22	0.656	-0.135	3.924	0.013	0.01	0	24.5	27.1	52.5	94	101	0	37	38
2015	12	26	22	12	22	0.62	-0.151	3.927	0.01	0.007	0	23.6	26.2	50.3	93	100	0	38	39
2015	12	26	22	22	22	0.617	-0.138	3.924	0.01	0.007	0	24.1	27.1	51.2	94	102	0	38	39
2015	12	26	22	32	22	0.61	-0.118	3.924	0.01	0.007	0	23.2	26.7	47.7	93	101	0	39	39
2015	12	26	22	42	22	0.679	-0.141	3.921	0.01	0.007	0	24.5	27.1	51.2	94	101	0	37	38
2015	12	26	22	52	22	0.604	-0.135	3.921	0.01	0.007	0	24.9	27.1	52	96	103	0	38	40
2015	12	26	23	2	22	0.65	-0.141	3.921	0.01	0.007	0	24.1	27.1	52	94	101	0	38	38
2015	12	26	23	12	22	0.597	-0.151	3.921	0.013	0.01	0	23.6	26.7	55	93	101	0	38	39
2015	12	26	23	22	22	0.646	-0.115	3.921	0.01	0.007	0	24.1	26.7	52.9	93	101	0	37	39
2015	12	26	23	32	22	0.581	-0.174	3.921	0.01	0.007	0	23.2	26.2	61.9	92	100	0	38	39
2015	12	26	23	42	22	0.571	-0.194	3.921	0.016	0.013	0	23.2	26.7	64.5	92	101	0	38	39
2015	12	26	23	52	22	0.591	-0.174	3.921	0.01	0.007	0	23.6	27.5	76.5	94	103	0	39	39
2015	12	27	0	2	22	0.6	-0.164	3.921	0.013	0.01	0	24.1	27.1	76.1	93	102	0	37	39
2015	12	27	0	12	22	0.587	-0.177	3.921	0.01	0.007	0	24.1	27.5	77.4	94	103	0	38	39
2015	12	27	0	22	22	0.587	-0.177	3.921	0.01	0.007	0	23.6	27.1	77.4	93	102	0	38	39
2015	12	27	0	32	22	0.597	-0.164	3.921	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	27	0	42	22	0.617	-0.184	3.917	0.01	0.007	0	22.8	26.2	77.8	91	100	0	38	39
2015	12	27	0	52	22	0.614	-0.154	3.921	0.01	0.007	0	22.8	25.8	77.4	91	99	0	38	39
2015	12	27	1	2	22	0.594	-0.161	3.921	0.01	0.007	0	22.4	26.2	77	90	99	0	38	38
2015	12	27	1	12	22	0.604	-0.154	3.921	0.01	0.007	0	22.8	26.7	77	91	100	0	38	38
2015	12	27	1	22	22	0.587	-0.167	3.917	0.01	0.007	0	23.2	26.2	77.4	91	100	0	37	39
2015	12	27	1	32	22	0.607	-0.177	3.917	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	27	1	42	22	0.607	-0.171	3.917	0.01	0.007	0	22.8	25.4	76.1	91	98	0	38	39
2015	12	27	1	52	22	0.63	-0.177	3.917	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	27	2	2	22	0.65	-0.154	3.917	0.01	0.007	0	37.4	41.7	77.4	125	136	0	38	39
2015	12	27	2	12	22	0.581	-0.131	3.917	0.01	0.007	0	28.8	32.3	77	104	114	0	37	39
2015	12	27	2	22	22	0.62	-0.151	3.917	0.01	0.007	0	25.8	29.7	77.8	98	107	0	38	38
2015	12	27	2	32	22	0.604	-0.177	3.917	0.01	0.007	0	24.5	28	75.7	95	104	0	38	39
2015	12	27	2	42	22	0.623	-0.128	3.917	0.01	0.007	0	28	31.8	77	103	113	0	38	39
2015	12	27	2	52	22	0.643	-0.174	3.917	0.01	0.007	0	25.4	28.8	77	97	106	0	38	39
2015	12	27	3	2	22	0.61	-0.121	3.917	0.013	0.01	0	24.9	28.4	77.4	96	105	0	38	39
2015	12	27	3	12	22	0.6	-0.167	3.917	0.01	0.007	0	24.1	27.5	77	93	102	0	37	38
2015	12	27	3	22	22	0.594	-0.151	3.917	0.01	0.007	0	23.2	27.1	77.4	93	102	0	39	39
2015	12	27	3	32	22	0.581	-0.161	3.914	0.01	0.007	0	23.6	26.7	77	93	101	0	38	39
2015	12	27	3	42	22	0.594	-0.148	3.914	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	27	3	52	22	0.633	-0.171	3.914	0.01	0.007	0	22.8	26.2	77.4	91	100	0	38	39
2015	12	27	4	2	22	0.623	-0.151	3.914	0.01	0.007	0	23.2	26.2	77.4	92	100	0	38	39
2015	12	27	4	12	22	0.614	-0.151	3.914	0.013	0.01	0	22.4	25.8	77	90	99	0	38	39
2015	12	27	4	22	22	0.62	-0.164	3.914	0.01	0.007	0	24.9	28.4	77	96	105	0	38	39
2015	12	27	4	32	22	0.643	-0.141	3.914	0.013	0.01	0	24.1	28	77	94	103	0	38	38

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	4	42	22	0.594	-0.148	3.914	0.01	0.007	0	23.2	26.7	76.5	92	101	0	38	39
2015	12	27	4	52	22	0.617	-0.131	3.914	0.01	0.007	0	26.2	30.1	77.4	98	109	0	37	39
2015	12	27	5	2	22	0.666	-0.138	3.914	0.01	0.007	0	27.5	31	77	101	111	0	37	39
2015	12	27	5	12	22	0.653	-0.161	3.911	0.01	0.007	0	27.1	31	77	101	111	0	38	39
2015	12	27	5	22	22	0.617	-0.164	3.911	0.01	0.007	0	25.4	28.8	77	97	105	0	38	38
2015	12	27	5	32	22	0.591	-0.164	3.911	0.013	0.01	0	23.6	26.7	76.5	92	101	0	37	39
2015	12	27	5	42	22	0.623	-0.144	3.911	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	27	5	52	22	0.604	-0.157	3.911	0.01	0.007	0	22.8	25.4	77	91	99	0	38	40
2015	12	27	6	2	22	0.604	-0.164	3.911	0.013	0.01	0	22.8	25.8	77.4	91	99	0	38	39
2015	12	27	6	12	22	0.623	-0.187	3.911	0.01	0.007	0	22.4	24.9	77	90	97	0	38	39
2015	12	27	6	22	22	0.591	-0.161	3.911	0.01	0.007	0	21.9	25.4	77.4	89	98	0	38	39
2015	12	27	6	32	22	0.62	-0.174	3.911	0.013	0.01	0	21.9	25.4	77	89	98	0	38	39
2015	12	27	6	42	22	0.617	-0.148	3.911	0.013	0.01	0	21.9	25.4	77.4	89	98	0	38	39
2015	12	27	6	52	22	0.617	-0.161	3.911	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	27	7	2	22	0.614	-0.148	3.907	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	27	7	12	22	0.614	-0.167	3.907	0.01	0.007	0	22.4	25.4	77.8	90	98	0	38	39
2015	12	27	7	22	22	0.61	-0.184	3.907	0.01	0.007	0	22.4	25.4	77.4	89	98	0	37	39
2015	12	27	7	32	22	0.623	-0.161	3.907	0.016	0.013	0	21.9	24.5	77	89	97	0	38	40
2015	12	27	7	42	22	0.607	-0.187	3.907	0.013	0.01	0	22.4	25.4	77	89	98	0	37	39
2015	12	27	7	52	22	0.6	-0.177	3.907	0.01	0.007	0	22.4	24.9	76.5	90	98	0	38	40
2015	12	27	8	2	22	0.623	-0.184	3.907	0.01	0.007	0	22.4	25.8	77	90	99	0	38	39
2015	12	27	8	12	22	0.6	-0.151	3.907	0.01	0.007	0	22.8	25.8	77.4	91	99	0	38	39
2015	12	27	8	22	22	0.614	-0.151	3.907	0.01	0.007	0	22.8	25.8	76.5	91	99	0	38	39
2015	12	27	8	32	22	0.561	-0.171	3.907	0.01	0.007	0	22.8	25.8	77.8	91	99	0	38	39
2015	12	27	8	42	22	0.6	-0.148	3.907	0.01	0.007	0	23.2	25.8	77.8	91	99	0	37	39
2015	12	27	8	52	22	0.591	-0.164	3.907	0.01	0.007	0	22.4	26.2	78.3	91	100	0	39	39
2015	12	27	9	2	22	0.63	-0.177	3.907	0.01	0.007	0	22.8	25.8	77.8	91	99	0	38	39
2015	12	27	9	12	22	0.591	-0.184	3.907	0.013	0.01	0	22.8	25.4	77.8	90	98	0	37	39
2015	12	27	9	22	22	0.577	-0.174	3.911	0.01	0.007	0	22.4	25.4	77.4	90	98	0	38	39
2015	12	27	9	32	22	0.571	-0.19	3.907	0.01	0.007	0	22.8	25.4	77.8	90	98	0	37	39
2015	12	27	9	42	22	0.577	-0.184	3.911	0.013	0.01	0	22.8	25.4	77.8	91	98	0	38	39
2015	12	27	9	52	22	0.591	-0.194	3.911	0.01	0.007	0	22.4	25.4	77.8	90	98	0	38	39
2015	12	27	10	2	22	0.587	-0.187	3.911	0.01	0.007	0	22.4	25.4	77.8	90	98	0	38	39
2015	12	27	10	12	22	0.61	-0.174	3.911	0.01	0.007	0	22.4	25.4	78.3	90	98	0	38	39
2015	12	27	10	22	22	0.591	-0.157	3.911	0.01	0.007	0	22.4	25.4	77.8	90	98	0	38	39
2015	12	27	10	32	22	0.591	-0.18	3.911	0.01	0.007	0	21.9	25.4	78.3	89	98	0	38	39
2015	12	27	10	42	22	0.6	-0.194	3.911	0.01	0.007	0	21.5	25.4	77.8	89	98	0	39	39
2015	12	27	10	52	22	0.607	-0.164	3.911	0.01	0.007	0	22.4	25.4	77.4	90	98	0	38	39
2015	12	27	11	2	22	0.584	-0.174	3.911	0.01	0.007	0	21.9	25.4	77	89	98	0	38	39
2015	12	27	11	12	22	0.558	-0.167	3.914	0.01	0.007	0	22.8	25.4	78.3	91	98	0	38	39
2015	12	27	11	22	22	0.607	-0.171	3.911	0.01	0.007	0	21.9	24.9	78.3	89	97	0	38	39
2015	12	27	11	32	22	0.604	-0.151	3.911	0.01	0.007	0	21.9	25.4	77.8	89	98	0	38	39
2015	12	27	11	42	22	0.581	-0.194	3.911	0.01	0.007	0	22.4	24.9	63.2	90	98	0	38	40
2015	12	27	11	52	22	0.568	-0.19	3.911	0.01	0.007	0	22.8	26.2	67.9	91	99	0	38	38
2015	12	27	12	2	22	0.561	-0.187	3.911	0.01	0.007	0	23.2	26.2	69.2	91	99	0	37	38
2015	12	27	12	12	22	0.568	-0.19	3.911	0.01	0.007	0	22.4	25.4	62.4	90	98	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	12	22	22	0.577	-0.203	3.911	0.01	0.007	0	22.8	25.8	53.3	91	99	0	38	39
2015	12	27	12	32	22	0.591	-0.18	3.911	0.01	0.007	0	22.4	25.8	54.2	90	98	0	38	38
2015	12	27	12	42	22	0.581	-0.207	3.911	0.01	0.007	0	22.4	25.8	55	90	98	0	38	38
2015	12	27	12	52	22	0.594	-0.171	3.911	0.01	0.007	0	23.2	26.2	58	92	100	0	38	39
2015	12	27	13	2	22	0.597	-0.18	3.911	0.016	0.013	0	23.2	26.7	58.9	92	101	0	38	39
2015	12	27	13	12	22	0.584	-0.167	3.907	0.01	0.007	0	22.8	25.8	54.6	91	99	0	38	39
2015	12	27	13	22	22	0.548	-0.194	3.907	0.01	0.007	0	22.4	25.8	53.3	90	98	0	38	38
2015	12	27	13	32	22	0.61	-0.2	3.907	0.01	0.007	0	21.9	24.9	58.5	89	97	0	38	39
2015	12	27	13	42	22	0.577	-0.167	3.907	0.01	0.007	0	22.4	25.4	51.2	90	98	0	38	39
2015	12	27	13	52	22	0.564	-0.19	3.904	0.01	0.007	0	22.4	25.8	48.2	90	99	0	38	39
2015	12	27	14	2	22	0.564	-0.154	3.907	0.01	0.007	0	22.8	25.8	48.2	91	99	0	38	39
2015	12	27	14	12	22	0.554	-0.171	3.904	0.01	0.007	0	23.2	26.2	46	92	100	0	38	39
2015	12	27	14	22	22	0.581	-0.18	3.907	0.01	0.007	0	23.2	26.7	51.2	92	100	0	38	38
2015	12	27	14	32	22	0.568	-0.141	3.904	0.01	0.007	0	22.8	25.8	50.7	91	98	0	38	38
2015	12	27	14	42	22	0.581	-0.174	3.904	0.01	0.007	0	22.8	25.8	49.5	90	99	0	37	39
2015	12	27	14	52	22	0.564	-0.164	3.904	0.01	0.007	0	22.8	25.8	52	91	99	0	38	39
2015	12	27	15	2	22	0.571	-0.187	3.904	0.01	0.007	0	22.8	25.4	52.5	90	98	0	37	39
2015	12	27	15	12	22	0.571	-0.213	3.904	0.01	0.007	0	22.4	25.4	51.6	90	98	0	38	39
2015	12	27	15	22	22	0.577	-0.187	3.901	0.01	0.007	0	22.4	25.4	54.2	90	98	0	38	39
2015	12	27	15	32	22	0.548	-0.167	3.901	0.01	0.007	0	22.8	25.4	50.3	90	98	0	37	39
2015	12	27	15	42	22	0.568	-0.167	3.901	0.01	0.007	0	22.4	25.4	51.6	90	98	0	38	39
2015	12	27	15	52	22	0.551	-0.19	3.901	0.01	0.007	0	21.9	24.9	54.6	89	97	0	38	39
2015	12	27	16	2	22	0.607	-0.187	3.901	0.01	0.007	0	21.1	24.1	67.1	87	95	0	38	39
2015	12	27	16	12	22	0.591	-0.19	3.901	0.01	0.007	0	21.5	24.5	77	88	96	0	38	39
2015	12	27	16	22	22	0.614	-0.207	3.901	0.01	0.007	0	21.1	24.9	77.4	87	96	0	38	38
2015	12	27	16	32	22	0.607	-0.19	3.901	0.01	0.007	0	21.5	24.5	77.8	88	96	0	38	39
2015	12	27	16	42	22	0.64	-0.174	3.901	0.01	0.007	0	21.5	24.5	77.4	88	96	0	38	39
2015	12	27	16	52	22	0.594	-0.184	3.901	0.013	0.01	0	21.9	24.9	77.4	89	97	0	38	39
2015	12	27	17	2	22	0.614	-0.197	3.901	0.01	0.007	0	21.9	24.9	77.4	89	97	0	38	39
2015	12	27	17	12	22	0.627	-0.174	3.901	0.01	0.007	0	21.1	24.5	77	87	96	0	38	39
2015	12	27	17	22	22	0.597	-0.177	3.901	0.01	0.007	0	21.5	24.5	77.8	88	96	0	38	39
2015	12	27	17	32	22	0.604	-0.164	3.901	0.01	0.007	0	21.5	24.9	77	88	97	0	38	39
2015	12	27	17	42	22	0.614	-0.164	3.898	0.01	0.007	0	21.5	24.9	77	88	97	0	38	39
2015	12	27	17	52	22	0.604	-0.171	3.901	0.01	0.007	0	21.9	24.9	77	89	97	0	38	39
2015	12	27	18	2	22	0.627	-0.164	3.901	0.01	0.007	0	21.9	25.4	77.4	89	98	0	38	39
2015	12	27	18	12	22	0.587	-0.171	3.898	0.01	0.007	0	21.9	24.9	76.5	88	96	0	37	38
2015	12	27	18	22	22	0.6	-0.164	3.898	0.01	0.007	0	21.5	24.9	77	88	96	0	38	38
2015	12	27	18	32	22	0.591	-0.171	3.898	0.01	0.007	0	22.4	25.8	76.5	90	99	0	38	39
2015	12	27	18	42	22	0.627	-0.187	3.898	0.01	0.007	0	22.4	24.9	76.5	90	98	0	38	40
2015	12	27	18	52	22	0.627	-0.161	3.898	0.01	0.007	0	21.5	24.5	76.1	88	96	0	38	39
2015	12	27	19	2	22	0.61	-0.194	3.898	0.01	0.007	0	21.9	24.9	76.1	89	97	0	38	39
2015	12	27	19	12	22	0.61	-0.151	3.898	0.01	0.007	0	22.8	25.8	76.1	91	99	0	38	39
2015	12	27	19	22	22	0.62	-0.2	3.898	0.01	0.007	0	21.5	24.9	76.5	88	97	0	38	39
2015	12	27	19	32	22	0.604	-0.157	3.898	0.01	0.007	0	21.9	25.4	76.1	89	98	0	38	39
2015	12	27	19	42	22	0.633	-0.138	3.898	0.01	0.007	0	29.2	32.7	74	105	115	0	37	39
2015	12	27	19	52	22	0.62	-0.125	3.898	0.01	0.007	0	28.4	32.3	76.1	104	114	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	20	2	22	0.614	-0.2	3.894	0.01	0.007	0	22.4	25.4	71	90	98	0	38	39
2015	12	27	20	12	22	0.623	-0.151	3.898	0.01	0.007	0	21.5	25.4	76.1	89	98	0	39	39
2015	12	27	20	22	22	0.607	-0.154	3.898	0.01	0.007	0	23.2	26.7	75.7	92	101	0	38	39
2015	12	27	20	32	22	0.614	-0.171	3.898	0.013	0.01	0	22.4	25.4	75.7	89	98	0	37	39
2015	12	27	20	42	22	0.577	-0.164	3.894	0.01	0.007	0	21.5	25.4	75.7	89	98	0	39	39
2015	12	27	20	52	22	0.6	-0.184	3.894	0.01	0.007	0	28	31	75.3	103	111	0	38	39
2015	12	27	21	2	22	0.61	-0.148	3.894	0.01	0.007	0	24.9	28.4	75.7	96	105	0	38	39
2015	12	27	21	12	22	0.591	-0.144	3.894	0.01	0.007	0	22.4	25.8	75.3	91	100	0	39	40
2015	12	27	21	22	22	0.581	-0.18	3.894	0.01	0.007	0	21.5	24.9	75.7	88	97	0	38	39
2015	12	27	21	32	22	0.617	-0.2	3.894	0.01	0.007	0	21.5	24.5	76.1	88	97	0	38	40
2015	12	27	21	42	22	0.548	-0.157	3.894	0.01	0.007	0	21.9	25.4	75.7	89	98	0	38	39
2015	12	27	21	52	22	0.594	-0.2	3.894	0.01	0.007	0	22.4	25.4	75.3	89	98	0	37	39
2015	12	27	22	2	22	0.617	-0.19	3.894	0.01	0.007	0	22.4	25.4	75.3	90	98	0	38	39
2015	12	27	22	12	22	0.558	-0.141	3.894	0.01	0.007	0	22.4	25.4	75.3	90	98	0	38	39
2015	12	27	22	22	22	0.617	-0.187	3.894	0.01	0.007	0	21.9	24.9	74.8	89	97	0	38	39
2015	12	27	22	32	22	0.591	-0.197	3.891	0.01	0.007	0	21.9	24.9	75.3	89	97	0	38	39
2015	12	27	22	42	22	0.597	-0.177	3.891	0.01	0.007	0	22.4	25.8	74.8	90	99	0	38	39
2015	12	27	22	52	22	0.6	-0.167	3.891	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	27	23	2	22	0.591	-0.135	3.891	0.01	0.007	0	22.8	26.7	74.4	91	101	0	38	39
2015	12	27	23	12	22	0.633	-0.154	3.891	0.01	0.007	0	24.9	28	74.4	95	104	0	37	39
2015	12	27	23	22	22	0.61	-0.177	3.891	0.01	0.007	0	31	34.8	74	110	120	0	38	39
2015	12	27	23	32	22	0.64	-0.148	3.891	0.01	0.007	0	28.4	31.4	75.3	104	112	0	38	39
2015	12	27	23	42	22	0.604	-0.157	3.891	0.01	0.007	0	25.4	29.2	74.8	97	107	0	38	39
2015	12	27	23	52	22	0.6	-0.154	3.891	0.01	0.007	0	26.2	30.1	74.8	99	109	0	38	39
2015	12	28	0	2	22	0.6	-0.18	3.891	0.016	0.013	0	24.9	27.5	74.4	96	104	0	38	40
2015	12	28	0	12	22	0.574	-0.161	3.891	0.01	0.007	0	25.8	29.2	74.4	98	107	0	38	39
2015	12	28	0	22	22	0.627	-0.154	3.891	0.01	0.007	0	25.8	29.2	74.4	98	107	0	38	39
2015	12	28	0	32	22	0.591	-0.19	3.891	0.01	0.007	0	24.9	28	74.8	96	104	0	38	39
2015	12	28	0	42	22	0.614	-0.164	3.888	0.01	0.007	0	23.2	26.7	74.8	93	101	0	39	39
2015	12	28	0	52	22	0.597	-0.174	3.888	0.01	0.007	0	23.6	27.1	74.4	93	102	0	38	39
2015	12	28	1	2	22	0.577	-0.194	3.888	0.01	0.007	0	22.8	26.2	74.4	91	100	0	38	39
2015	12	28	1	12	22	0.61	-0.167	3.888	0.016	0.013	0	23.2	25.8	74.8	91	99	0	37	39
2015	12	28	1	22	22	0.607	-0.194	3.888	0.01	0.007	0	23.2	26.2	74	92	100	0	38	39
2015	12	28	1	32	22	0.607	-0.197	3.888	0.01	0.007	0	22.8	26.7	74	91	100	0	38	38
2015	12	28	1	42	22	0.607	-0.19	3.885	0.01	0.007	0	26.2	29.2	74	99	107	0	38	39
2015	12	28	1	52	22	0.614	-0.187	3.885	0.01	0.007	0	24.1	27.1	74	94	103	0	38	40
2015	12	28	2	2	22	0.597	-0.18	3.885	0.01	0.007	0	23.2	27.1	74	93	102	0	39	39
2015	12	28	2	12	22	0.591	-0.174	3.885	0.01	0.007	0	24.1	28	73.5	95	104	0	39	39
2015	12	28	2	22	22	0.574	-0.144	3.885	0.01	0.007	0	26.2	30.1	74	99	109	0	38	39
2015	12	28	2	32	22	0.587	-0.177	3.885	0.01	0.007	0	24.5	28.4	74	95	105	0	38	39
2015	12	28	2	42	22	0.614	-0.184	3.881	0.01	0.007	0	24.5	27.5	73.5	94	103	0	37	39
2015	12	28	2	52	22	0.6	-0.171	3.881	0.01	0.007	0	26.7	30.1	73.1	100	109	0	38	39
2015	12	28	3	2	22	0.607	-0.187	3.885	0.01	0.007	0	26.2	29.7	73.5	99	108	0	38	39
2015	12	28	3	12	22	0.62	-0.184	3.881	0.01	0.007	0	26.2	29.7	73.5	99	108	0	38	39
2015	12	28	3	22	22	0.571	-0.2	3.881	0.01	0.007	0	24.5	27.1	73.5	95	102	0	38	39
2015	12	28	3	32	22	0.551	-0.174	3.881	0.01	0.007	0	26.7	28.8	73.1	100	106	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	3	42	22	0.584	-0.194	3.881	0.01	0.007	0	27.1	28.8	74	101	106	0	38	39
2015	12	28	3	52	22	0.604	-0.184	3.878	0.01	0.007	0	25.8	28.4	73.1	98	105	0	38	39
2015	12	28	4	2	22	0.571	-0.2	3.875	0.01	0.007	0	27.1	29.2	73.1	101	107	0	38	39
2015	12	28	4	12	22	0.551	-0.19	3.875	0.01	0.007	0	26.2	28.4	73.5	99	105	0	38	39
2015	12	28	4	22	22	0.581	-0.19	3.878	0.01	0.007	0	25.8	28	73.5	98	104	0	38	39
2015	12	28	4	32	22	0.581	-0.161	3.875	0.01	0.007	0	27.5	30.1	72.2	102	109	0	38	39
2015	12	28	4	42	22	0.584	-0.187	3.875	0.01	0.007	0	26.2	28.8	73.1	99	106	0	38	39
2015	12	28	4	52	22	0.614	-0.174	3.878	0.013	0.01	0	25.4	28	74	97	104	0	38	39
2015	12	28	5	2	22	0.591	-0.174	3.875	0.01	0.007	0	24.9	27.5	72.7	96	103	0	38	39
2015	12	28	5	12	22	0.61	-0.148	3.875	0.01	0.007	0	26.7	29.2	73.1	100	107	0	38	39
2015	12	28	5	22	22	0.581	-0.213	3.875	0.01	0.007	0	24.9	27.1	73.5	96	102	0	38	39
2015	12	28	5	32	22	0.554	-0.203	3.875	0.01	0.007	0	25.8	27.1	73.5	98	102	0	38	39
2015	12	28	5	42	22	0.554	-0.207	3.875	0.01	0.007	0	25.4	27.1	73.5	97	102	0	38	39
2015	12	28	5	52	22	0.568	-0.207	3.875	0.01	0.007	0	24.5	26.7	73.5	96	101	0	39	39
2015	12	28	6	2	22	0.591	-0.21	3.875	0.01	0.007	0	24.9	26.7	74	96	101	0	38	39
2015	12	28	6	12	22	0.574	-0.177	3.875	0.01	0.007	0	24.5	26.7	73.1	96	101	0	39	39
2015	12	28	6	22	22	0.541	-0.226	3.875	0.01	0.007	0	25.4	26.7	73.5	97	101	0	38	39
2015	12	28	6	32	22	0.604	-0.187	3.871	0.01	0.007	0	25.4	26.2	74	97	100	0	38	39
2015	12	28	6	42	22	0.574	-0.19	3.875	0.01	0.007	0	24.9	26.2	73.5	97	100	0	39	39
2015	12	28	6	52	22	0.587	-0.22	3.875	0.01	0.007	0	24.5	25.4	73.1	95	99	0	38	40
2015	12	28	7	2	22	0.587	-0.177	3.875	0.01	0.007	0	24.5	26.2	73.5	96	100	0	39	39
2015	12	28	7	12	22	0.597	-0.194	3.875	0.01	0.007	0	25.4	26.7	72.7	97	101	0	38	39
2015	12	28	7	22	22	0.607	-0.184	3.871	0.013	0.01	0	24.9	26.2	73.1	96	100	0	38	39
2015	12	28	7	32	22	0.607	-0.2	3.875	0.01	0.007	0	25.8	26.7	73.1	98	101	0	38	39
2015	12	28	7	42	22	0.591	-0.223	3.871	0.01	0.007	0	24.9	26.2	74	96	100	0	38	39
2015	12	28	7	52	22	0.571	-0.213	3.875	0.01	0.007	0	25.4	26.7	74	97	101	0	38	39
2015	12	28	8	2	22	0.568	-0.174	3.871	0.01	0.007	0	24.9	26.7	74.4	97	101	0	39	39
2015	12	28	8	12	22	0.564	-0.207	3.871	0.01	0.007	0	25.8	26.2	71	98	101	0	38	40
2015	12	28	8	22	22	0.587	-0.213	3.871	0.01	0.007	0	25.8	26.7	74.8	98	101	0	38	39
2015	12	28	8	32	22	0.561	-0.2	3.871	0.01	0.007	0	25.8	26.7	74	98	101	0	38	39
2015	12	28	8	42	22	0.584	-0.223	3.871	0.01	0.007	0	26.2	27.1	75.3	99	102	0	38	39
2015	12	28	8	52	22	0.587	-0.194	3.871	0.01	0.007	0	25.8	26.2	75.3	98	101	0	38	40
2015	12	28	9	2	22	0.564	-0.203	3.871	0.013	0.01	0	26.2	26.7	75.3	99	101	0	38	39
2015	12	28	9	12	22	0.558	-0.223	3.871	0.01	0.007	0	26.7	27.1	73.1	100	102	0	38	39
2015	12	28	9	22	22	0.554	-0.213	3.871	0.01	0.007	0	25.8	26.7	61.1	98	101	0	38	39
2015	12	28	9	32	22	0.548	-0.23	3.871	0.01	0.007	0	25.8	26.7	68.4	98	101	0	38	39
2015	12	28	9	42	22	0.561	-0.207	3.871	0.01	0.007	0	24.5	27.1	63.2	96	102	0	39	39
2015	12	28	9	52	22	0.531	-0.249	3.875	0.01	0.007	0	25.8	26.7	66.2	98	101	0	38	39
2015	12	28	10	2	22	0.594	-0.194	3.875	0.01	0.007	0	24.5	27.1	61.1	95	102	0	38	39
2015	12	28	10	12	22	0.594	-0.174	3.878	0.01	0.007	0	24.9	27.5	65.4	96	103	0	38	39
2015	12	28	10	22	22	0.564	-0.187	3.878	0.013	0.01	0	24.1	26.7	61.1	94	101	0	38	39
2015	12	28	10	32	22	0.62	-0.157	3.875	0.01	0.007	0	23.2	26.7	59.8	92	101	0	38	39
2015	12	28	10	42	22	0.574	-0.151	3.875	0.01	0.007	0	23.2	27.1	56.3	93	102	0	39	39
2015	12	28	10	52	22	0.61	-0.157	3.875	0.01	0.007	0	23.2	27.1	55.5	93	102	0	39	39
2015	12	28	11	2	22	0.604	-0.164	3.875	0.01	0.007	0	23.2	26.7	56.8	92	101	0	38	39
2015	12	28	11	12	22	0.607	-0.125	3.871	0.01	0.007	0	22.4	26.7	58.5	91	101	0	39	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	11	22	22	0.617	-0.154	3.871	0.01	0.007	0	22.8	26.7	62.8	91	101	0	38	39
2015	12	28	11	32	22	0.61	-0.151	3.871	0.01	0.007	0	23.2	26.7	77.4	92	101	0	38	39
2015	12	28	11	42	22	0.65	-0.154	3.868	0.01	0.007	0	23.2	26.7	77	92	102	0	38	40
2015	12	28	11	52	22	0.64	-0.148	3.871	0.01	0.007	0	23.2	26.7	76.1	92	101	0	38	39
2015	12	28	12	2	22	0.627	-0.144	3.868	0.01	0.007	0	23.6	27.1	74	92	102	0	37	39
2015	12	28	12	12	22	0.614	-0.131	3.868	0.01	0.007	0	23.2	26.7	77	92	101	0	38	39
2015	12	28	12	22	22	0.597	-0.154	3.868	0.01	0.007	0	23.6	27.5	68.8	93	103	0	38	39
2015	12	28	12	32	22	0.623	-0.144	3.868	0.01	0.007	0	22.8	27.1	72.2	92	102	0	39	39
2015	12	28	12	42	22	0.64	-0.157	3.868	0.01	0.007	0	22.8	26.7	77	91	101	0	38	39
2015	12	28	12	52	22	0.646	-0.167	3.868	0.01	0.007	0	23.2	26.7	69.2	92	101	0	38	39
2015	12	28	13	2	22	0.656	-0.148	3.868	0.01	0.007	0	22.8	26.2	77	91	100	0	38	39
2015	12	28	13	12	22	0.614	-0.141	3.865	0.01	0.007	0	22.4	26.7	77.8	91	101	0	39	39
2015	12	28	13	22	22	0.666	-0.121	3.865	0.01	0.007	0	22.8	26.7	77.4	91	101	0	38	39
2015	12	28	13	32	22	0.636	-0.161	3.865	0.01	0.007	0	23.2	26.7	77.4	92	102	0	38	40
2015	12	28	13	42	22	0.61	-0.138	3.862	0.01	0.007	0	24.5	28	77	95	105	0	38	40
2015	12	28	13	52	22	0.65	-0.151	3.865	0.01	0.007	0	23.2	27.5	76.1	92	102	0	38	38
2015	12	28	14	2	22	0.636	-0.125	3.865	0.01	0.007	0	23.6	27.5	77.4	93	102	0	38	38
2015	12	28	14	12	22	0.643	-0.151	3.865	0.01	0.007	0	22.8	26.2	77.4	91	101	0	38	40
2015	12	28	14	22	22	0.627	-0.154	3.865	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	28	14	32	22	0.623	-0.157	3.862	0.01	0.007	0	21.9	26.2	77	90	100	0	39	39
2015	12	28	14	42	22	0.623	-0.151	3.862	0.01	0.007	0	22.4	26.2	77	90	100	0	38	39
2015	12	28	14	52	22	0.646	-0.154	3.862	0.01	0.007	0	22.4	25.8	77.4	90	99	0	38	39
2015	12	28	15	2	22	0.607	-0.154	3.862	0.01	0.007	0	22.8	26.2	70.1	91	100	0	38	39
2015	12	28	15	12	22	0.659	-0.148	3.862	0.01	0.007	0	24.1	27.1	57.6	94	103	0	38	40
2015	12	28	15	22	22	0.61	-0.161	3.862	0.01	0.007	0	23.2	27.1	68.8	92	102	0	38	39
2015	12	28	15	32	22	0.673	-0.075	3.862	0.01	0.007	0	24.1	27.1	55.5	94	102	0	38	39
2015	12	28	15	42	22	0.673	-0.082	3.862	0.01	0.007	0	24.5	27.1	55.5	94	102	0	37	39
2015	12	28	15	52	22	0.62	-0.161	3.862	0.01	0.007	0	22.8	26.2	68.8	91	100	0	38	39
2015	12	28	16	2	22	0.627	-0.151	3.862	0.01	0.007	0	22.4	26.2	68.8	90	100	0	38	39
2015	12	28	16	12	22	0.614	-0.148	3.862	0.01	0.007	0	22.8	26.2	64.1	91	100	0	38	39
2015	12	28	16	22	22	0.643	-0.157	3.862	0.01	0.007	0	24.1	27.5	71	93	102	0	37	38
2015	12	28	16	32	22	0.63	-0.157	3.862	0.01	0.007	0	23.6	27.1	76.5	93	103	0	38	40
2015	12	28	16	42	22	0.653	-0.164	3.862	0.01	0.007	0	24.1	27.5	76.5	94	103	0	38	39
2015	12	28	16	52	22	0.656	-0.161	3.862	0.01	0.007	0	24.1	27.5	75.3	94	103	0	38	39
2015	12	28	17	2	22	0.65	-0.148	3.862	0.01	0.007	0	24.1	28.4	76.5	94	105	0	38	39
2015	12	28	17	12	22	0.633	-0.174	3.862	0.01	0.007	0	24.9	28.8	77	96	106	0	38	39
2015	12	28	17	22	22	0.597	-0.157	3.862	0.01	0.007	0	24.1	28	77.4	94	104	0	38	39
2015	12	28	17	32	22	0.62	-0.131	3.862	0.013	0.01	0	22.8	27.1	77.8	92	102	0	39	39
2015	12	28	17	42	22	0.607	-0.174	3.862	0.013	0.01	0	22.8	26.7	77.8	91	101	0	38	39
2015	12	28	17	52	22	0.623	-0.141	3.862	0.013	0.01	0	22.8	26.2	77.4	91	101	0	38	40
2015	12	28	18	2	22	0.63	-0.161	3.862	0.01	0.007	0	22.4	26.2	77.4	90	100	0	38	39
2015	12	28	18	12	22	0.61	-0.118	3.862	0.01	0.007	0	22.4	26.2	77.8	90	100	0	38	39
2015	12	28	18	22	22	0.636	-0.151	3.858	0.01	0.007	0	22.4	26.2	77.8	90	100	0	38	39
2015	12	28	18	32	22	0.63	-0.148	3.858	0.01	0.007	0	22.4	25.8	77.4	90	100	0	38	40
2015	12	28	18	42	22	0.653	-0.138	3.858	0.01	0.007	0	24.9	28.8	77.8	96	106	0	38	39
2015	12	28	18	52	22	0.63	-0.138	3.858	0.01	0.007	0	23.2	26.7	78.3	91	101	0	37	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	19	2	22	0.633	-0.135	3.858	0.01	0.007	0	21.9	26.2	78.3	90	100	0	39	39
2015	12	28	19	12	22	0.614	-0.157	3.858	0.01	0.007	0	22.4	26.2	77.8	91	100	0	39	39
2015	12	28	19	22	22	0.62	-0.131	3.858	0.013	0.01	0	22.8	26.2	77.8	91	100	0	38	39
2015	12	28	19	32	22	0.581	-0.154	3.858	0.01	0.007	0	23.6	27.1	77.8	93	102	0	38	39
2015	12	28	19	42	22	0.63	-0.177	3.858	0.01	0.007	0	22.8	26.2	78.3	91	100	0	38	39
2015	12	28	19	52	22	0.581	-0.141	3.858	0.01	0.007	0	22.8	26.7	77.8	91	101	0	38	39
2015	12	28	20	2	22	0.597	-0.167	3.858	0.01	0.007	0	23.2	26.7	78.3	93	101	0	39	39
2015	12	28	20	12	22	0.594	-0.184	3.858	0.01	0.007	0	23.6	27.1	78.3	93	102	0	38	39
2015	12	28	20	22	22	0.554	-0.2	3.858	0.01	0.007	0	24.1	26.7	78.3	94	101	0	38	39
2015	12	28	20	32	22	0.577	-0.2	3.858	0.01	0.007	0	26.7	29.2	78.7	100	107	0	38	39
2015	12	28	20	42	22	0.604	-0.203	3.858	0.01	0.007	0	24.5	27.5	78.3	95	103	0	38	39
2015	12	28	20	52	22	0.581	-0.184	3.858	0.01	0.007	0	24.9	28	78.3	96	104	0	38	39
2015	12	28	21	2	22	0.607	-0.18	3.858	0.01	0.007	0	24.1	26.2	78.3	94	101	0	38	40
2015	12	28	21	12	22	0.623	-0.203	3.858	0.01	0.007	0	28.4	31	78.3	104	111	0	38	39
2015	12	28	21	22	22	0.594	-0.203	3.858	0.013	0.01	0	26.7	29.2	78.3	101	107	0	39	39
2015	12	28	21	32	22	0.604	-0.197	3.858	0.01	0.007	0	25.4	27.1	77.8	96	103	0	37	40
2015	12	28	21	42	22	0.574	-0.213	3.858	0.016	0.013	0	26.2	28.4	77.8	99	105	0	38	39
2015	12	28	21	52	22	0.607	-0.167	3.858	0.01	0.007	0	25.8	27.5	78.3	98	103	0	38	39
2015	12	28	22	2	22	0.554	-0.23	3.858	0.01	0.007	0	25.8	28.8	77.8	99	106	0	39	39
2015	12	28	22	12	22	0.62	-0.18	3.858	0.01	0.007	0	25.4	26.7	77.8	97	101	0	38	39
2015	12	28	22	22	22	0.587	-0.2	3.858	0.01	0.007	0	24.9	27.1	77.4	96	103	0	38	40
2015	12	28	22	32	22	0.574	-0.18	3.848	0.01	0.007	0	24.5	26.7	73.5	95	101	0	38	39
2015	12	28	22	42	22	0.551	-0.184	3.855	0.016	0.013	0	24.5	26.2	73.5	95	100	0	38	39
2015	12	28	22	52	22	0.584	-0.207	3.858	0.01	0.007	0	24.5	26.2	70.1	96	101	0	39	40
2015	12	28	23	2	22	0.581	-0.207	3.858	0.01	0.007	0	24.5	26.2	70.5	95	100	0	38	39
2015	12	28	23	12	22	0.594	-0.197	3.858	0.01	0.007	0	24.5	25.8	71	95	99	0	38	39
2015	12	28	23	22	22	0.577	-0.22	3.855	0.01	0.007	0	25.4	27.5	72.2	97	103	0	38	39
2015	12	28	23	32	22	0.554	-0.233	3.852	0.01	0.007	0	25.8	28.4	74	99	105	0	39	39
2015	12	28	23	42	22	0.531	-0.226	3.852	0.01	0.007	0	24.9	26.2	75.3	96	101	0	38	40
2015	12	28	23	52	22	0.564	-0.2	3.855	0.01	0.007	0	26.2	27.5	76.5	99	103	0	38	39
2015	12	29	0	2	22	0.568	-0.187	3.852	0.016	0.013	0	24.9	27.1	75.3	97	101	0	39	38
2015	12	29	0	12	22	0.531	-0.148	3.855	0.016	0.013	0	24.9	27.5	73.5	96	103	0	38	39
2015	12	29	0	22	22	0.486	-0.187	3.858	0.01	0.007	0	25.8	28	66.2	98	105	0	38	40
2015	12	29	0	32	22	0.512	-0.164	3.852	0.01	0.007	0	27.1	30.5	68.8	101	110	0	38	39
2015	12	29	0	42	22	0.541	-0.2	3.842	0.013	0.01	0	28.8	28.8	58.9	105	106	0	38	39
2015	12	29	0	52	22	0.581	-0.18	3.858	0.013	0.01	0	28	27.5	72.2	103	103	0	38	39
2015	12	29	1	2	22	0.627	-0.154	3.858	0.01	0.007	0	27.5	26.7	76.5	102	101	0	38	39
2015	12	29	1	12	22	0.607	-0.184	3.858	0.01	0.007	0	27.5	26.2	76.5	102	100	0	38	39
2015	12	29	1	22	22	0.614	-0.177	3.858	0.01	0.007	0	27.1	25.8	69.2	102	99	0	39	39
2015	12	29	1	32	22	0.548	-0.253	3.858	0.01	0.007	0	27.5	25.8	69.2	102	100	0	38	40
2015	12	29	1	42	22	0.515	-0.253	3.858	0.01	0.007	0	27.1	25.8	75.7	102	100	0	39	40
2015	12	29	1	52	22	0.482	-0.282	3.858	0.01	0.007	0	27.5	25.8	76.5	102	99	0	38	39
2015	12	29	2	2	22	0.656	-0.112	3.858	0.01	0.007	0	28.8	27.5	77.8	105	103	0	38	39
2015	12	29	2	12	22	0.587	-0.22	3.858	0.01	0.007	0	27.5	25.8	77.8	102	99	0	38	39
2015	12	29	2	22	22	0.528	-0.269	3.855	0.01	0.007	0	32.3	31.8	72.7	113	113	0	38	39
2015	12	29	2	32	22	0.545	-0.21	3.858	0.01	0.007	0	31	29.7	80	110	109	0	38	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	2	42	22	0.558	-0.233	3.858	0.01	0.007	0	28.8	28	64.9	105	104	0	38	39
2015	12	29	2	52	22	0.6	-0.187	3.842	0.01	0.007	0	28.4	27.1	57.6	104	102	0	38	39
2015	12	29	3	2	22	0.574	-0.213	3.829	0.013	0.01	0	28	26.7	58.5	103	101	0	38	39
2015	12	29	3	12	22	0.633	-0.125	3.845	0.01	0.007	0	28.4	26.7	75.3	104	101	0	38	39
2015	12	29	3	22	22	0.584	-0.161	3.858	0.01	0.007	0	28.8	28	75.3	106	104	0	39	39
2015	12	29	3	32	22	0.594	-0.167	3.858	0.01	0.007	0	28.8	28	75.3	105	105	0	38	40
2015	12	29	3	42	22	0.571	-0.089	3.858	0.01	0.007	0	29.2	29.2	75.3	106	107	0	38	39
2015	12	29	3	52	22	0.505	-0.217	3.858	0.01	0.007	0	30.5	31.4	75.7	110	112	0	39	39
2015	12	29	4	2	22	0.528	-0.102	3.855	0.01	0.007	0	28.4	28	75.3	104	104	0	38	39
2015	12	29	4	12	22	0.505	-0.138	3.858	0.01	0.007	0	29.7	29.7	74.8	107	108	0	38	39
2015	12	29	4	22	22	0.397	-0.249	3.858	0.01	0.007	0	28.8	28	74	105	105	0	38	40
2015	12	29	4	32	22	0.538	-0.171	3.855	0.01	0.007	0	29.2	28.4	75.3	106	105	0	38	39
2015	12	29	4	42	22	0.581	-0.082	3.858	0.013	0.01	0	33.5	33.1	72.7	116	116	0	38	39
2015	12	29	4	52	22	0.646	-0.085	3.858	0.01	0.007	0	32.3	32.7	76.1	113	115	0	38	39
2015	12	29	5	2	22	0.551	-0.174	3.858	0.01	0.007	0	29.2	29.2	74.4	106	107	0	38	39
2015	12	29	5	12	22	0.525	-0.184	3.858	0.01	0.007	0	27.5	27.5	73.5	102	103	0	38	39
2015	12	29	5	22	22	0.528	-0.217	3.858	0.01	0.007	0	26.7	28	74.4	101	103	0	39	38
2015	12	29	5	32	22	0.535	-0.167	3.858	0.01	0.007	0	27.1	27.1	72.2	101	103	0	38	40
2015	12	29	5	42	22	0.538	-0.154	3.862	0.01	0.007	0	27.5	27.5	69.2	102	103	0	38	39
2015	12	29	5	52	22	0.499	-0.194	3.865	0.01	0.007	0	27.1	27.1	69.7	101	102	0	38	39
2015	12	29	6	2	22	0.495	-0.19	3.868	0.01	0.007	0	27.5	28	63.6	102	104	0	38	39
2015	12	29	6	12	22	0.335	-0.338	3.871	0.01	0.007	0	27.1	27.5	62.8	101	103	0	38	39
2015	12	29	6	22	22	0.42	-0.282	3.871	0.013	0.01	0	27.5	27.5	56.3	102	104	0	38	40
2015	12	29	6	32	22	0.335	-0.246	3.868	0.01	0.007	0	28.4	27.5	61.9	104	103	0	38	39
2015	12	29	6	42	22	0.413	-0.295	3.858	0.01	0.007	0	27.5	27.5	59.3	102	103	0	38	39
2015	12	29	6	52	22	0.528	-0.24	3.868	0.01	0.007	0	28	28	59.8	103	104	0	38	39
2015	12	29	7	2	22	0.495	-0.226	3.865	0.01	0.007	0	28	27.5	64.9	103	103	0	38	39
2015	12	29	7	12	22	0.551	-0.213	3.868	0.01	0.007	0	28	28	52.9	103	104	0	38	39
2015	12	29	7	22	22	0.535	-0.203	3.871	0.01	0.007	0	27.5	28	61.5	102	104	0	38	39
2015	12	29	7	32	22	0.62	-0.207	3.868	0.01	0.007	0	27.1	27.5	61.9	101	103	0	38	39
2015	12	29	7	42	22	0.584	-0.089	3.868	0.01	0.007	0	27.1	27.5	66.2	102	103	0	39	39
2015	12	29	7	52	22	0.509	-0.026	3.868	0.01	0.007	0	27.1	28	70.5	101	104	0	38	39
2015	12	29	8	2	22	0.417	-0.112	3.868	0.01	0.007	0	27.5	28	67.9	102	104	0	38	39
2015	12	29	8	12	22	0.531	-0.151	3.871	0.01	0.007	0	27.5	28	69.7	102	104	0	38	39
2015	12	29	8	22	22	0.636	-0.066	3.871	0.01	0.007	0	28	28.4	62.8	103	105	0	38	39
2015	12	29	8	32	22	0.541	-0.22	3.868	0.01	0.007	0	27.5	27.5	64.5	102	104	0	38	40
2015	12	29	8	42	22	0.466	-0.282	3.865	0.01	0.007	0	27.5	28.4	70.5	102	105	0	38	39
2015	12	29	8	52	22	0.43	-0.161	3.871	0.01	0.007	0	27.5	28.4	71.4	103	105	0	39	39
2015	12	29	9	2	22	0.538	-0.171	3.868	0.01	0.007	0	27.5	28.8	66.7	103	106	0	39	39
2015	12	29	9	12	22	0.446	-0.243	3.871	0.01	0.007	0	28	28.8	63.2	103	106	0	38	39
2015	12	29	9	22	22	0.512	-0.164	3.865	0.01	0.007	0	28	28.4	67.9	103	105	0	38	39
2015	12	29	9	32	22	0.528	-0.154	3.865	0.01	0.007	0	27.5	28	70.5	102	105	0	38	40
2015	12	29	9	42	22	0.492	-0.151	3.865	0.01	0.007	0	27.5	28.4	71	102	105	0	38	39
2015	12	29	9	52	22	0.463	-0.21	3.865	0.01	0.007	0	27.1	28.4	71.4	101	105	0	38	39
2015	12	29	10	2	22	0.479	-0.154	3.862	0.01	0.007	0	27.1	28.8	68.4	101	106	0	38	39
2015	12	29	10	12	22	0.541	-0.157	3.855	0.01	0.007	0	26.7	28.4	68.8	100	105	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	10	22	22	0.525	-0.167	3.848	0.01	0.007	0	27.1	28.8	70.1	101	105	0	38	38
2015	12	29	10	32	22	0.495	-0.138	3.842	0.01	0.007	0	26.7	28.4	66.2	100	105	0	38	39
2015	12	29	10	42	22	0.518	-0.135	3.822	0.01	0.007	0	27.5	28.8	69.2	102	106	0	38	39
2015	12	29	10	52	22	0.502	-0.18	3.799	0.01	0.007	0	27.5	28.4	52	102	105	0	38	39
2015	12	29	11	2	22	0.64	-0.135	3.868	0.01	0.007	0	25.4	26.7	53.8	97	101	0	38	39
2015	12	29	11	12	22	0.554	-0.24	3.868	0.01	0.007	0	24.9	26.2	60.2	96	100	0	38	39
2015	12	29	11	22	22	0.587	-0.2	3.868	0.01	0.007	0	24.5	26.7	56.3	96	101	0	39	39
2015	12	29	11	32	22	0.538	-0.22	3.868	0.01	0.007	0	24.9	26.7	65.8	96	101	0	38	39
2015	12	29	11	42	22	0.571	-0.23	3.868	0.01	0.007	0	25.4	26.2	64.5	96	100	0	37	39
2015	12	29	11	52	22	0.541	-0.23	3.868	0.01	0.007	0	24.5	25.8	66.2	95	99	0	38	39
2015	12	29	12	2	22	0.538	-0.203	3.868	0.01	0.007	0	24.5	26.2	70.5	96	100	0	39	39
2015	12	29	12	12	22	0.545	-0.207	3.868	0.01	0.007	0	24.9	26.2	71	96	100	0	38	39
2015	12	29	12	22	22	0.564	-0.207	3.868	0.01	0.007	0	24.9	26.7	72.2	96	100	0	38	38
2015	12	29	12	32	22	0.525	-0.2	3.868	0.013	0.01	0	24.5	26.2	71	95	100	0	38	39
2015	12	29	12	42	22	0.558	-0.22	3.865	0.01	0.007	0	24.5	25.8	77	95	99	0	38	39
2015	12	29	12	52	22	0.584	-0.217	3.868	0.01	0.007	0	24.1	25.8	75.7	95	99	0	39	39
2015	12	29	13	2	22	0.584	-0.217	3.865	0.01	0.007	0	24.9	26.2	75.3	95	99	0	37	38
2015	12	29	13	12	22	0.551	-0.203	3.865	0.01	0.007	0	24.9	25.8	76.1	95	99	0	37	39
2015	12	29	13	22	22	0.561	-0.23	3.865	0.01	0.007	0	24.1	25.8	77.8	94	99	0	38	39
2015	12	29	13	32	22	0.587	-0.19	3.865	0.01	0.007	0	24.5	26.2	76.5	95	100	0	38	39
2015	12	29	13	42	22	0.584	-0.203	3.865	0.013	0.01	0	24.1	26.2	76.1	94	100	0	38	39
2015	12	29	13	52	22	0.564	-0.197	3.865	0.01	0.007	0	24.1	26.2	77.8	94	100	0	38	39
2015	12	29	14	2	22	0.548	-0.19	3.865	0.01	0.007	0	24.5	26.7	75.7	95	100	0	38	38
2015	12	29	14	12	22	0.561	-0.22	3.862	0.01	0.007	0	24.1	26.2	77.8	94	100	0	38	39
2015	12	29	14	22	22	0.591	-0.19	3.862	0.013	0.01	0	24.1	26.2	77	94	100	0	38	39
2015	12	29	14	32	22	0.574	-0.207	3.862	0.01	0.007	0	24.5	27.1	77.4	95	102	0	38	39
2015	12	29	14	42	22	0.574	-0.203	3.862	0.01	0.007	0	25.4	28	77.4	97	104	0	38	39
2015	12	29	14	52	22	0.6	-0.197	3.862	0.01	0.007	0	24.5	27.1	77.4	95	102	0	38	39
2015	12	29	15	2	22	0.584	-0.217	3.862	0.01	0.007	0	24.5	26.7	77.8	94	101	0	37	39
2015	12	29	15	12	22	0.581	-0.203	3.862	0.016	0.013	0	23.6	26.2	77.8	93	100	0	38	39
2015	12	29	15	22	22	0.594	-0.2	3.858	0.01	0.007	0	23.6	26.2	78.3	93	100	0	38	39
2015	12	29	15	32	22	0.591	-0.223	3.858	0.01	0.007	0	23.6	26.2	77.8	93	100	0	38	39
2015	12	29	15	42	22	0.604	-0.21	3.858	0.01	0.007	0	23.6	26.2	77.8	93	101	0	38	40
2015	12	29	15	52	22	0.587	-0.213	3.858	0.01	0.007	0	23.6	26.2	77.8	93	100	0	38	39
2015	12	29	16	2	22	0.604	-0.2	3.858	0.01	0.007	0	23.2	26.2	77.8	92	100	0	38	39
2015	12	29	16	12	22	0.577	-0.21	3.858	0.01	0.007	0	23.2	26.2	77.4	92	100	0	38	39
2015	12	29	16	22	22	0.581	-0.19	3.858	0.01	0.007	0	23.2	25.8	77.4	92	99	0	38	39
2015	12	29	16	32	22	0.591	-0.226	3.858	0.01	0.007	0	22.8	25.8	77.8	91	99	0	38	39
2015	12	29	16	42	22	0.584	-0.174	3.858	0.01	0.007	0	23.2	25.8	77	92	99	0	38	39
2015	12	29	16	52	22	0.607	-0.203	3.855	0.01	0.007	0	22.8	25.8	77.4	91	99	0	38	39
2015	12	29	17	2	22	0.584	-0.203	3.855	0.01	0.007	0	22.8	25.8	77.4	91	99	0	38	39
2015	12	29	17	12	22	0.587	-0.21	3.855	0.01	0.007	0	22.8	25.4	77.4	91	99	0	38	40
2015	12	29	17	22	22	0.554	-0.19	3.855	0.01	0.007	0	23.2	26.2	77.8	92	100	0	38	39
2015	12	29	17	32	22	0.571	-0.177	3.855	0.01	0.007	0	24.1	27.1	77.4	94	102	0	38	39
2015	12	29	17	42	22	0.597	-0.161	3.855	0.013	0.01	0	25.8	28.4	77.4	98	106	0	38	40
2015	12	29	17	52	22	0.61	-0.2	3.855	0.01	0.007	0	23.2	26.2	77.4	92	100	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	18	2	22	0.614	-0.174	3.855	0.01	0.007	0	30.1	33.1	76.5	108	116	0	38	39
2015	12	29	18	12	22	0.64	-0.184	3.855	0.016	0.013	0	40	43.9	76.5	131	141	0	38	39
2015	12	29	18	22	22	0.587	-0.2	3.855	0.01	0.007	0	24.9	27.1	77	97	102	0	39	39
2015	12	29	18	32	22	0.581	-0.2	3.855	0.01	0.007	0	25.8	27.5	77.4	98	103	0	38	39
2015	12	29	18	42	22	0.561	-0.23	3.855	0.01	0.007	0	25.4	26.7	77	97	101	0	38	39
2015	12	29	18	52	22	0.525	-0.292	3.855	0.01	0.007	0	25.4	25.8	77.4	97	99	0	38	39
2015	12	29	19	2	22	0.597	-0.167	3.855	0.01	0.007	0	27.1	29.7	76.5	101	108	0	38	39
2015	12	29	19	12	22	0.509	-0.308	3.855	0.01	0.007	0	27.5	29.2	77	102	107	0	38	39
2015	12	29	19	22	22	0.548	-0.177	3.855	0.01	0.007	0	29.2	31.8	76.5	107	113	0	39	39
2015	12	29	19	32	22	0.525	-0.302	3.855	0.01	0.007	0	28.4	29.7	77.4	104	109	0	38	40
2015	12	29	19	42	22	0.548	-0.226	3.855	0.01	0.007	0	28.4	30.5	77.4	104	110	0	38	39
2015	12	29	19	52	22	0.646	-0.082	3.855	0.01	0.007	0	26.7	28.4	77	101	106	0	39	40
2015	12	29	20	2	22	0.558	-0.24	3.855	0.01	0.007	0	25.4	26.7	77	97	101	0	38	39
2015	12	29	20	12	22	0.597	-0.203	3.855	0.01	0.007	0	24.9	26.7	75.7	96	101	0	38	39
2015	12	29	20	22	22	0.551	-0.21	3.855	0.01	0.007	0	24.5	26.2	76.1	95	100	0	38	39
2015	12	29	20	32	22	0.663	-0.082	3.855	0.01	0.007	0	24.5	26.2	74.4	95	100	0	38	39
2015	12	29	20	42	22	0.554	-0.197	3.855	0.013	0.01	0	24.5	26.7	73.5	95	101	0	38	39
2015	12	29	20	52	22	0.581	-0.187	3.855	0.01	0.007	0	25.4	26.7	73.5	97	101	0	38	39
2015	12	29	21	2	22	0.538	-0.177	3.855	0.013	0.01	0	27.1	28.8	75.3	102	107	0	39	40
2015	12	29	21	12	22	0.568	-0.213	3.855	0.01	0.007	0	28.8	30.5	74.8	105	110	0	38	39
2015	12	29	21	22	22	0.377	-0.246	3.855	0.01	0.007	0	28	30.1	74	103	110	0	38	40
2015	12	29	21	32	22	0.505	-0.203	3.855	0.01	0.007	0	27.5	29.7	74.4	102	108	0	38	39
2015	12	29	21	42	22	0.518	-0.131	3.855	0.01	0.007	0	27.5	29.7	74.4	103	108	0	39	39
2015	12	29	21	52	22	0.63	-0.177	3.855	0.01	0.007	0	28	29.7	74.8	103	108	0	38	39
2015	12	29	22	2	22	0.584	-0.207	3.858	0.01	0.007	0	28.8	31.4	75.3	105	112	0	38	39
2015	12	29	22	12	22	0.577	-0.272	3.858	0.01	0.007	0	29.2	31.8	76.1	106	114	0	38	40
2015	12	29	22	22	22	0.459	-0.341	3.858	0.01	0.007	0	28.4	30.5	77.8	104	110	0	38	39
2015	12	29	22	32	22	0.719	-0.089	3.858	0.013	0.01	0	27.5	29.2	76.1	102	107	0	38	39
2015	12	29	22	42	22	0.512	-0.177	3.858	0.01	0.007	0	28.4	30.5	77.8	104	110	0	38	39
2015	12	29	22	52	22	0.607	-0.036	3.858	0.013	0.01	0	30.5	31.8	77.4	109	113	0	38	39
2015	12	29	23	2	22	0.594	-0.194	3.858	0.01	0.007	0	29.7	30.5	77.4	107	110	0	38	39
2015	12	29	23	12	22	0.696	-0.033	3.858	0.01	0.007	0	31.4	33.5	77.8	111	117	0	38	39
2015	12	29	23	22	22	0.643	-0.161	3.858	0.01	0.007	0	29.7	31.4	77	108	113	0	39	40
2015	12	29	23	32	22	0.486	-0.112	3.858	0.016	0.013	0	30.1	31.8	77	108	113	0	38	39
2015	12	29	23	42	22	0.531	-0.151	3.862	0.01	0.007	0	30.1	32.3	79.6	108	115	0	38	40
2015	12	29	23	52	22	0.584	-0.043	3.862	0.01	0.007	0	28.8	31	74	105	111	0	38	39
2015	12	30	0	2	22	0.594	-0.164	3.862	0.01	0.007	0	27.5	29.7	77.8	102	108	0	38	39
2015	12	30	0	12	22	0.518	-0.23	3.865	0.01	0.007	0	28	29.2	64.9	102	107	0	37	39
2015	12	30	0	22	22	0.62	-0.125	3.865	0.01	0.007	0	27.1	28.4	68.8	101	106	0	38	40
2015	12	30	0	32	22	0.433	-0.213	3.868	0.01	0.007	0	26.7	28	61.1	100	105	0	38	40
2015	12	30	0	42	22	0.551	-0.203	3.862	0.01	0.007	0	31.4	30.5	77	111	111	0	38	40
2015	12	30	0	52	22	0.482	-0.141	3.862	0.01	0.007	0	33.5	33.5	62.4	116	117	0	38	39
2015	12	30	1	2	22	0.564	-0.125	3.858	0.01	0.007	0	32.3	31.8	77.4	113	113	0	38	39
2015	12	30	1	12	22	0.564	-0.243	3.862	0.01	0.007	0	29.7	29.2	75.7	107	107	0	38	39
2015	12	30	1	22	22	0.692	-0.207	3.862	0.01	0.007	0	30.1	29.2	79.6	108	107	0	38	39
2015	12	30	1	32	22	0.669	-0.249	3.865	0.01	0.007	0	29.7	29.7	67.1	107	108	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	1	42	22	0.433	-0.128	3.865	0.013	0.01	0	29.7	30.1	64.1	107	109	0	38	39
2015	12	30	1	52	22	0.568	-0.233	3.865	0.01	0.007	0	30.1	29.7	64.9	108	108	0	38	39
2015	12	30	2	2	22	0.479	-0.138	3.862	0.01	0.007	0	30.5	30.1	77	109	109	0	38	39
2015	12	30	2	12	22	0.61	-0.269	3.868	0.01	0.007	0	29.7	29.2	67.5	107	108	0	38	40
2015	12	30	2	22	22	0.512	-0.112	3.865	0.01	0.007	0	29.2	28.8	70.5	106	106	0	38	39
2015	12	30	2	32	22	0.535	-0.236	3.868	0.01	0.007	0	29.7	29.7	63.2	107	108	0	38	39
2015	12	30	2	42	22	0.486	-0.112	3.865	0.01	0.007	0	34.8	34.4	75.7	119	120	0	38	40
2015	12	30	2	52	22	0.623	-0.236	3.868	0.013	0.01	0	30.1	30.1	74.4	108	109	0	38	39
2015	12	30	3	2	22	0.512	-0.18	3.868	0.01	0.007	0	31	31.8	72.2	111	112	0	39	38
2015	12	30	3	12	22	0.554	-0.276	3.868	0.013	0.01	0	41.3	42.6	77.4	134	138	0	38	39
2015	12	30	3	22	22	0.564	-0.19	3.868	0.013	0.01	0	41.3	43	71.4	134	138	0	38	38
2015	12	30	3	32	22	0.558	-0.177	3.865	0.01	0.007	0	31.8	32.3	84.3	112	114	0	38	39
2015	12	30	3	42	22	0.666	-0.246	3.871	0.01	0.007	0	31	31.8	73.5	111	113	0	39	39
2015	12	30	3	52	22	0.495	-0.161	3.868	0.01	0.007	0	35.3	35.3	82.6	119	122	0	37	40
2015	12	30	4	2	22	0.6	-0.289	3.865	0.01	0.007	0	30.5	31	80	109	111	0	38	39
2015	12	30	4	12	22	0.581	-0.266	3.862	0.01	0.007	0	37.8	38.7	85.6	126	129	0	38	39
2015	12	30	4	22	22	0.574	-0.128	3.868	0.01	0.007	0	29.7	29.7	85.1	107	109	0	38	40
2015	12	30	4	32	22	0.669	-0.249	3.868	0.01	0.007	0	29.7	30.5	86.9	107	110	0	38	39
2015	12	30	4	42	22	0.371	0.039	3.871	0.01	0.007	0	28.4	29.2	83.8	105	107	0	39	39
2015	12	30	4	52	22	0.499	-0.131	3.871	0.013	0.01	0	28.4	29.2	84.3	104	106	0	38	38
2015	12	30	5	2	22	0.479	-0.112	3.868	0.01	0.007	0	28.8	28.4	83.4	106	105	0	39	39
2015	12	30	5	12	22	0.64	-0.308	3.868	0.013	0.01	0	30.1	30.1	81.7	108	110	0	38	40
2015	12	30	5	22	22	0.656	-0.394	3.868	0.01	0.007	0	28.4	28.4	83.4	104	105	0	38	39
2015	12	30	5	32	22	0.587	-0.282	3.868	0.01	0.007	0	28.4	28.4	83.8	103	105	0	37	39
2015	12	30	5	42	22	0.666	-0.272	3.868	0.01	0.007	0	28	28.4	84.3	103	105	0	38	39
2015	12	30	5	52	22	0.607	-0.381	3.868	0.013	0.01	0	28	28.4	85.1	104	105	0	39	39
2015	12	30	6	2	22	0.6	-0.269	3.875	0.01	0.007	0	27.5	28	77.4	102	104	0	38	39
2015	12	30	6	12	22	0.528	-0.299	3.868	0.01	0.007	0	28	28	86	103	104	0	38	39
2015	12	30	6	22	22	0.531	-0.197	3.871	0.01	0.007	0	28	27.5	74	103	103	0	38	39
2015	12	30	6	32	22	0.502	-0.075	3.868	0.01	0.007	0	28.4	27.5	87.7	104	103	0	38	39
2015	12	30	6	42	22	0.417	0.01	3.865	0.01	0.007	0	28	27.1	82.1	103	103	0	38	40
2015	12	30	6	52	22	0.463	-0.131	3.871	0.01	0.007	0	28	27.5	89.4	103	103	0	38	39
2015	12	30	7	2	22	0.42	-0.236	3.868	0.01	0.007	0	28.4	28	86.4	103	104	0	37	39
2015	12	30	7	12	22	0.476	-0.144	3.868	0.01	0.007	0	28.4	27.1	91.6	104	103	0	38	40
2015	12	30	7	22	22	0.338	-0.112	3.868	0.013	0.01	0	28.8	27.1	91.2	104	103	0	37	40
2015	12	30	7	32	22	0.581	-0.272	3.868	0.01	0.007	0	28.4	28.4	-15.5	104	105	0	38	39
2015	12	30	7	42	22	0.604	-0.269	3.865	0.01	0.007	0	28	28	-13.3	104	105	0	39	40
2015	12	30	7	52	22	0.633	-0.282	3.868	0.013	0.01	0	28.4	28.4	-14.2	104	105	0	38	39
2015	12	30	8	2	22	0.417	-0.052	3.865	0.01	0.007	0	28.4	28	-8.2	104	105	0	38	40
2015	12	30	8	12	22	0.518	-0.18	3.865	0.01	0.007	0	29.7	30.1	-8.6	107	109	0	38	39
2015	12	30	8	22	22	0.443	-0.075	3.871	0.01	0.007	0	28.8	30.1	-12.5	105	109	0	38	39
2015	12	30	8	32	22	0.561	-0.141	3.865	0.01	0.007	0	28.8	28.8	-9.5	105	107	0	38	40
2015	12	30	8	42	22	0.522	-0.118	3.862	0.01	0.007	0	26.7	28.8	-10.8	100	106	0	38	39
2015	12	30	8	52	22	0.535	-0.148	3.868	0.01	0.007	0	25.8	28.8	-11.6	98	106	0	38	39
2015	12	30	9	2	22	0.81	-0.203	3.868	0.016	0.013	0	26.2	29.2	-11.6	99	107	0	38	39
2015	12	30	9	12	22	0.85	-0.164	3.868	0.01	0.007	0	25.4	29.2	-9.9	97	107	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	9	22	22	0.692	-0.292	3.871	0.01	0.007	0	25.4	28.8	-9	97	106	0	38	39
2015	12	30	9	32	22	0.587	-0.328	3.868	0.01	0.007	0	26.2	29.2	-8.6	99	107	0	38	39
2015	12	30	9	42	22	0.6	-0.243	3.865	0.01	0.007	0	26.2	29.2	-10.8	99	107	0	38	39
2015	12	30	9	52	22	0.604	-0.108	3.868	0.01	0.007	0	25.8	28.8	-12.5	98	106	0	38	39
2015	12	30	10	2	22	0.377	-0.141	3.865	0.01	0.007	0	26.2	28.8	-14.2	99	107	0	38	40
2015	12	30	10	12	22	0.561	-0.154	3.865	0.01	0.007	0	26.2	29.2	-11.6	99	107	0	38	39
2015	12	30	10	22	22	0.331	-0.154	3.868	0.01	0.007	0	26.7	29.2	-10.3	100	107	0	38	39
2015	12	30	10	32	22	0.571	-0.23	3.865	0.01	0.007	0	26.7	28	90.7	100	106	0	38	41
2015	12	30	10	42	22	0.469	-0.105	3.855	0.01	0.007	0	26.7	28.8	79.1	100	107	0	38	40
2015	12	30	10	52	22	0.666	0.052	3.855	0.01	0.007	0	27.5	30.5	70.1	102	110	0	38	39
2015	12	30	11	2	22	0.653	-0.171	3.855	0.013	0.01	0	28.8	31	82.6	105	111	0	38	39
2015	12	30	11	12	22	0.551	-0.236	3.862	0.01	0.007	0	27.1	28.4	74	101	106	0	38	40
2015	12	30	11	22	22	0.715	-0.223	3.862	0.01	0.007	0	27.1	28.8	69.2	101	107	0	38	40
2015	12	30	11	32	22	0.653	-0.062	3.858	0.01	0.007	0	26.2	29.2	72.2	100	107	0	39	39
2015	12	30	11	42	22	0.564	-0.187	3.862	0.01	0.007	0	27.1	29.2	67.9	101	107	0	38	39
2015	12	30	11	52	22	0.495	-0.226	3.868	0.01	0.007	0	26.7	29.2	74	100	106	0	38	38
2015	12	30	12	2	22	0.315	-0.295	3.865	0.01	0.007	0	27.1	28.8	73.5	101	106	0	38	39
2015	12	30	12	12	22	0.64	-0.203	3.858	0.01	0.007	0	27.1	29.7	74.8	101	108	0	38	39
2015	12	30	12	22	22	0.453	-0.262	3.862	0.01	0.007	0	26.2	28.4	71.8	99	106	0	38	40
2015	12	30	12	32	22	0.466	-0.056	3.858	0.01	0.007	0	25.8	28.8	78.3	98	106	0	38	39
2015	12	30	12	42	22	0.528	-0.292	3.865	0.01	0.007	0	26.2	28.4	76.1	100	105	0	39	39
2015	12	30	12	52	22	0.653	-0.433	3.862	0.01	0.007	0	27.1	29.7	68.8	101	108	0	38	39
2015	12	30	13	2	22	0.853	-0.161	3.862	0.01	0.007	0	26.7	29.2	78.3	100	107	0	38	39
2015	12	30	13	12	22	0.679	-0.18	3.858	0.013	0.01	0	26.7	28.8	77.4	100	106	0	38	39
2015	12	30	13	22	22	0.476	-0.18	3.852	0.01	0.007	0	26.7	28.4	67.9	101	106	0	39	40
2015	12	30	13	32	22	0.472	-0.41	3.852	0.01	0.007	0	27.1	28.4	61.1	101	105	0	38	39
2015	12	30	13	42	22	0.417	-0.272	3.858	0.01	0.007	0	27.5	28.8	74.8	102	106	0	38	39
2015	12	30	13	52	22	0.427	-0.279	3.855	0.016	0.013	0	27.5	28.4	69.7	102	105	0	38	39
2015	12	30	14	2	22	0.568	-0.174	3.855	0.01	0.007	0	27.1	28.8	64.9	101	106	0	38	39
2015	12	30	14	12	22	0.528	-0.217	3.868	0.01	0.007	0	28.4	26.2	68.8	105	100	0	39	39
2015	12	30	14	33	46	0.643	-0.144	3.865	0.013	0.01	0	26.7	30.5	77	100	110	0	38	39
2015	12	30	14	43	46	0.636	-0.18	3.865	0.01	0.007	0	26.7	30.1	75.7	100	109	0	38	39
2015	12	30	14	53	46	0.666	-0.141	3.865	0.01	0.007	0	26.7	30.1	77.4	100	110	0	38	40
2015	12	30	15	3	46	0.633	-0.138	3.862	0.013	0.01	0	26.7	30.5	77.8	100	110	0	38	39
2015	12	30	15	13	46	0.63	-0.151	3.862	0.013	0.01	0	26.7	30.5	77.8	100	110	0	38	39
2015	12	30	15	23	46	0.636	-0.151	3.858	0.016	0.016	0	26.7	30.5	77.4	100	110	0	38	39
2015	12	30	15	33	46	0.64	-0.131	3.862	0.016	0.013	0	26.2	30.1	77.8	100	110	0	39	40
2015	12	30	15	43	46	0.577	-0.157	3.858	0.01	0.007	0	27.1	30.5	77.8	101	110	0	38	39
2015	12	30	15	53	46	0.633	-0.112	3.858	0.013	0.01	0	27.5	30.5	78.3	102	110	0	38	39
2015	12	30	16	3	46	0.659	-0.128	3.858	0.013	0.01	0	26.7	30.5	77	101	110	0	39	39
2015	12	30	16	13	46	0.63	-0.161	3.858	0.01	0.007	0	27.5	31.4	77	103	112	0	39	39
2015	12	30	16	23	46	0.646	-0.174	3.858	0.013	0.01	0	27.1	30.5	77.8	101	110	0	38	39
2015	12	30	16	33	46	0.656	-0.148	3.858	0.016	0.013	0	26.7	30.1	77.8	100	109	0	38	39
2015	12	30	16	43	46	0.636	-0.161	3.858	0.013	0.01	0	26.2	29.7	77	100	109	0	39	40
2015	12	30	16	53	46	0.659	-0.128	3.858	0.01	0.007	0	26.7	30.1	78.3	100	109	0	38	39
2015	12	30	17	3	46	0.61	-0.161	3.858	0.013	0.01	0	26.7	29.7	78.3	100	109	0	38	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	17	13	46	0.653	-0.148	3.855	0.013	0.01	0	27.1	31	73.5	101	110	0	38	38
2015	12	30	17	23	46	0.623	-0.138	3.858	0.01	0.007	0	27.5	26.2	76.1	102	100	0	38	39
2015	12	30	17	33	46	0.659	-0.125	3.862	0.01	0.007	0	27.1	30.5	62.4	101	110	0	38	39
2015	12	30	17	43	46	0.479	-0.282	3.862	0.01	0.007	0	27.5	26.2	62.8	102	100	0	38	39
2015	12	30	17	53	46	0.63	-0.131	3.858	0.013	0.01	0	31.4	35.3	55	111	121	0	38	39
2015	12	30	18	3	46	0.653	-0.161	3.858	0.016	0.013	0	27.1	31	72.2	102	111	0	39	39
2015	12	30	18	13	46	0.646	-0.174	3.862	0.013	0.01	0	27.1	30.5	66.7	101	110	0	38	39
2015	12	30	18	23	46	0.62	-0.161	3.862	0.016	0.013	0	26.7	30.1	71.8	101	110	0	39	40
2015	12	30	18	33	46	0.633	-0.157	3.858	0.013	0.01	0	27.1	30.5	76.5	101	110	0	38	39
2015	12	30	18	43	46	0.64	-0.125	3.862	0.01	0.007	0	30.5	34	86	109	118	0	38	39
2015	12	30	18	53	46	0.636	-0.174	3.855	0.013	0.01	0	28.4	32.3	77.8	104	114	0	38	39
2015	12	30	19	3	46	0.656	-0.138	3.855	0.013	0.01	0	29.2	32.3	77.8	105	114	0	37	39
2015	12	30	19	13	46	0.643	-0.161	3.855	0.01	0.007	0	28.8	32.7	77.8	105	115	0	38	39
2015	12	30	19	23	46	0.604	-0.121	3.855	0.013	0.01	0	29.2	32.3	78.3	106	115	0	38	40
2015	12	30	19	33	46	0.538	-0.24	3.855	0.01	0.007	0	29.2	27.1	79.1	106	102	0	38	39
2015	12	30	19	43	46	0.63	-0.148	3.858	0.013	0.01	0	28	31.4	78.7	103	112	0	38	39
2015	12	30	19	53	46	0.63	-0.138	3.858	0.013	0.01	0	27.5	31.8	77.8	103	112	0	39	38
2015	12	30	20	3	46	0.62	-0.157	3.862	0.01	0.007	0	27.1	30.5	62.8	101	111	0	38	40
2015	12	30	20	13	46	0.623	-0.148	3.862	0.013	0.01	0	27.1	30.5	70.1	101	111	0	38	40
2015	12	30	20	23	46	0.643	-0.138	3.865	0.013	0.01	0	26.7	30.1	65.4	100	109	0	38	39
2015	12	30	20	33	46	0.663	-0.121	3.865	0.016	0.013	0	26.2	29.7	67.5	100	109	0	39	40
2015	12	30	20	43	46	0.636	-0.138	3.862	0.013	0.01	0	27.1	30.5	76.5	101	110	0	38	39
2015	12	30	20	53	46	0.63	-0.151	3.865	0.016	0.013	0	26.2	30.1	74	100	109	0	39	39
2015	12	30	21	3	46	0.62	-0.138	3.862	0.01	0.007	0	26.2	30.1	81.7	100	109	0	39	39
2015	12	30	21	13	46	0.656	-0.171	3.862	0.013	0.01	0	26.7	30.5	79.1	101	110	0	39	39
2015	12	30	21	23	46	0.594	-0.151	3.858	0.016	0.013	0	33.1	35.7	76.1	115	123	0	38	40
2015	12	30	21	33	46	0.63	-0.151	3.871	0.01	0.007	0	30.5	30.1	63.2	109	109	0	38	39
2015	12	30	21	43	46	0.666	-0.167	3.865	0.013	0.01	0	27.5	31.4	75.3	103	112	0	39	39
2015	12	30	21	53	46	0.63	-0.167	3.865	0.016	0.013	0	27.5	30.5	69.2	102	110	0	38	39
2015	12	30	22	3	46	0.643	-0.138	3.865	0.016	0.013	0	31	34.8	67.1	110	120	0	38	39
2015	12	30	22	13	46	0.656	-0.174	3.862	0.013	0.01	0	29.2	32.7	78.3	106	115	0	38	39
2015	12	30	22	23	46	0.64	-0.148	3.865	0.013	0.01	0	29.2	32.7	66.7	106	115	0	38	39
2015	12	30	22	33	46	0.643	-0.161	3.858	0.013	0.01	0	28.4	31.4	74.4	104	113	0	38	40
2015	12	30	22	43	46	0.623	-0.151	3.865	0.013	0.01	0	27.5	31	77	102	111	0	38	39
2015	12	30	22	53	46	0.65	-0.194	3.858	0.013	0.01	0	27.1	30.5	83	101	110	0	38	39
2015	12	30	23	3	46	0.64	-0.141	3.865	0.01	0.007	0	27.5	30.5	73.5	101	110	0	37	39
2015	12	30	23	13	46	0.696	-0.128	3.865	0.013	0.01	0	26.2	30.1	74.8	100	109	0	39	39
2015	12	30	23	23	46	0.63	-0.141	3.862	0.01	0.007	0	28.8	31.8	82.1	105	114	0	38	40
2015	12	30	23	33	46	0.65	-0.135	3.865	0.016	0.013	0	28.4	31.8	86.9	104	113	0	38	39
2015	12	30	23	43	46	0.666	-0.125	3.862	0.016	0.013	0	28	31.4	77.8	103	112	0	38	39
2015	12	30	23	53	46	0.627	-0.128	3.865	0.013	0.01	0	27.5	31.4	85.1	102	112	0	38	39
2015	12	31	0	3	46	0.64	-0.161	3.862	0.016	0.013	0	27.5	31	79.1	102	111	0	38	39
2015	12	31	0	13	46	0.643	-0.157	3.865	0.016	0.013	0	28	31.4	74.8	103	112	0	38	39
2015	12	31	0	23	46	0.633	-0.148	3.862	0.013	0.01	0	27.5	30.5	92	102	111	0	38	40
2015	12	31	0	33	46	0.643	-0.135	3.862	0.016	0.016	0	28.8	32.7	71.4	106	115	0	39	39
2015	12	31	0	43	46	0.63	-0.154	3.862	0.01	0.007	0	29.7	33.1	92	107	116	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	0	53	46	0.64	-0.121	3.862	0.013	0.01	0	28.4	31.8	72.7	104	113	0	38	39
2015	12	31	1	3	46	0.604	-0.148	3.862	0.016	0.016	0	27.5	31	85.1	103	112	0	39	40
2015	12	31	1	13	46	0.653	-0.144	3.858	0.013	0.01	0	28	31.8	89.9	104	113	0	39	39
2015	12	31	1	23	46	0.673	-0.18	3.862	0.016	0.013	0	27.5	31.4	72.2	102	112	0	38	39
2015	12	31	1	33	46	0.61	-0.138	3.862	0.013	0.01	0	28	31.4	91.6	103	112	0	38	39
2015	12	31	1	43	46	0.653	-0.144	3.862	0.013	0.01	0	28	31.4	88.6	103	112	0	38	39
2015	12	31	1	53	46	0.653	-0.177	3.862	0.016	0.013	0	28	31.4	84.7	103	112	0	38	39
2015	12	31	2	3	46	0.653	-0.167	3.862	0.013	0.01	0	29.2	32.7	-14.2	105	115	0	37	39
2015	12	31	2	13	46	0.63	-0.138	3.862	0.013	0.01	0	28.8	32.3	82.6	105	114	0	38	39
2015	12	31	2	23	46	0.643	-0.141	3.858	0.016	0.016	0	28	31.8	-16.8	104	114	0	39	40
2015	12	31	2	33	46	0.636	-0.151	3.865	0.013	0.01	0	34	37.4	91.2	117	127	0	38	40
2015	12	31	2	43	46	0.643	-0.144	3.858	0.013	0.01	0	31.4	35.3	88.6	112	121	0	39	39
2015	12	31	2	53	46	0.64	-0.161	3.862	0.016	0.013	0	29.2	32.7	-11.6	106	115	0	38	39
2015	12	31	3	3	46	0.63	-0.135	3.858	0.013	0.01	0	29.7	33.1	89	107	116	0	38	39
2015	12	31	3	13	46	0.627	-0.154	3.858	0.01	0.007	0	28	31.4	0	103	113	0	38	40
2015	12	31	3	23	46	0.653	-0.161	3.862	0.01	0.007	0	27.5	31	-14.2	102	111	0	38	39
2015	12	31	3	33	46	0.594	-0.135	3.858	0.016	0.013	0	30.1	33.5	91.6	108	117	0	38	39
2015	12	31	3	43	46	0.643	-0.151	3.862	0.013	0.01	0	31.8	35.7	-12.5	113	122	0	39	39
2015	12	31	3	53	46	0.682	-0.148	3.862	0.013	0.01	0	31.4	35.7	-15.9	112	122	0	39	39
2015	12	31	4	3	46	0.62	-0.144	3.858	0.013	0.01	0	31.4	35.3	-16.3	112	121	0	39	39
2015	12	31	4	13	46	0.653	-0.174	3.862	0.013	0.01	0	31	34.8	-10.3	110	120	0	38	39
2015	12	31	4	23	46	0.646	-0.164	3.855	0.013	0.01	0	28.8	31.8	0	105	114	0	38	40
2015	12	31	4	33	46	0.669	-0.148	3.858	0.02	0.016	0	29.2	32.7	-11.6	106	115	0	38	39
2015	12	31	4	43	46	0.6	-0.138	3.858	0.013	0.01	0	28.4	32.3	-15.5	104	114	0	38	39
2015	12	31	4	53	46	0.659	-0.131	3.855	0.013	0.01	0	29.2	33.1	-14.6	106	116	0	38	39
2015	12	31	5	3	46	0.646	-0.144	3.862	0.013	0.01	0	28	32.3	-8.6	104	114	0	39	39
2015	12	31	5	13	46	0.659	-0.141	3.855	0.013	0.01	0	27.1	31	-14.2	101	111	0	38	39
2015	12	31	5	23	46	0.653	-0.154	3.855	0.013	0.01	0	27.1	31	-10.8	101	111	0	38	39
2015	12	31	5	33	46	0.653	-0.135	3.858	0.01	0.007	0	27.5	31	-12.9	102	111	0	38	39
2015	12	31	5	43	46	0.656	-0.174	3.855	0.013	0.01	0	26.7	30.1	-13.3	101	110	0	39	40
2015	12	31	5	53	46	0.62	-0.128	3.858	0.01	0.007	0	27.1	30.5	-8.6	101	111	0	38	40
2015	12	31	6	3	46	0.696	-0.161	3.855	0.016	0.013	0	27.1	30.1	-12	101	110	0	38	40
2015	12	31	6	13	46	0.627	-0.118	3.855	0.013	0.01	0	27.5	31	-8.6	102	111	0	38	39
2015	12	31	6	23	46	0.673	-0.161	3.858	0.016	0.013	0	27.5	31.4	-10.3	102	112	0	38	39
2015	12	31	6	33	46	0.627	-0.151	3.855	0.016	0.013	0	27.5	31	-12.5	102	111	0	38	39
2015	12	31	6	43	46	0.673	-0.128	3.858	0.01	0.007	0	27.1	30.5	-9	101	110	0	38	39
2015	12	31	6	53	46	0.643	-0.141	3.855	0.016	0.013	0	27.1	30.5	-8.2	101	110	0	38	39
2015	12	31	7	3	46	0.63	-0.151	3.855	0.013	0.01	0	27.5	30.5	-10.3	102	110	0	38	39
2015	12	31	7	13	46	0.676	-0.135	3.858	0.016	0.016	0	27.1	30.1	-11.2	101	110	0	38	40
2015	12	31	7	23	46	0.623	-0.151	3.855	0.016	0.013	0	27.1	30.1	-11.2	101	110	0	38	40
2015	12	31	7	33	46	0.653	-0.138	3.858	0.013	0.01	0	27.1	31	-5.2	101	111	0	38	39
2015	12	31	7	43	46	0.636	-0.151	3.858	0.013	0.01	0	27.1	30.5	-4.7	101	110	0	38	39
2015	12	31	7	53	46	0.63	-0.131	3.855	0.01	0.007	0	27.1	30.5	-9.5	101	110	0	38	39
2015	12	31	8	3	46	0.646	-0.095	3.862	0.01	0.007	0	28	30.5	-4.7	102	110	0	37	39
2015	12	31	8	13	46	0.643	-0.112	3.862	0.016	0.013	0	27.1	31	-5.6	102	111	0	39	39
2015	12	31	8	23	46	0.673	-0.148	3.858	0.016	0.013	0	27.5	31	-9	102	111	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	8	33	46	0.614	-0.174	3.858	0.01	0.007	0	28	31	-9	102	111	0	37	39
2015	12	31	8	43	46	0.673	-0.184	3.862	0.01	0.007	0	27.5	31	-7.3	102	111	0	38	39
2015	12	31	8	53	46	0.646	-0.151	3.862	0.01	0.007	0	27.5	31.4	-9	103	112	0	39	39
2015	12	31	9	3	46	0.666	-0.161	3.862	0.013	0.01	0	28	31.4	-9.9	103	111	0	38	38
2015	12	31	9	13	46	0.659	-0.128	3.862	0.016	0.013	0	28.4	31.4	-8.2	104	113	0	38	40
2015	12	31	9	23	46	0.643	-0.138	3.862	0.013	0.01	0	28	31	-8.6	103	112	0	38	40
2015	12	31	9	33	46	0.636	-0.138	3.858	0.013	0.01	0	27.1	31.4	-9.5	102	112	0	39	39
2015	12	31	9	43	46	0.65	-0.151	3.862	0.013	0.01	0	27.1	31	-9.5	102	111	0	39	39
2015	12	31	9	53	46	0.623	-0.161	3.858	0.01	0.007	0	28	31	-15.5	103	111	0	38	39
2015	12	31	10	3	46	0.65	-0.151	3.858	0.01	0.007	0	28	31.4	-15.5	103	112	0	38	39
2015	12	31	10	13	46	0.659	-0.151	3.855	0.01	0.007	0	27.1	31	92.5	102	111	0	39	39
2015	12	31	10	23	46	0.607	-0.144	3.852	0.016	0.013	0	28	31.4	0	103	112	0	38	39
2015	12	31	10	33	46	0.689	-0.128	3.855	0.016	0.013	0	27.5	31	85.1	102	111	0	38	39
2015	12	31	10	43	46	0.653	-0.118	3.848	0.013	0.01	0	27.5	31	88.6	102	111	0	38	39
2015	12	31	10	53	46	0.646	-0.148	3.842	0.016	0.013	0	27.5	31	91.2	102	111	0	38	39
2015	12	31	11	3	46	0.64	-0.148	3.842	0.013	0.01	0	27.5	31	88.2	102	111	0	38	39
2015	12	31	11	13	46	0.623	-0.102	3.842	0.013	0.01	0	28	31	85.6	103	112	0	38	40
2015	12	31	11	23	46	0.623	-0.151	3.845	0.01	0.007	0	27.5	31	83.8	102	111	0	38	39
2015	12	31	11	33	46	0.633	-0.171	3.839	0.016	0.013	0	28.4	31	82.6	103	111	0	37	39
2015	12	31	11	43	46	0.633	-0.184	3.842	0.016	0.013	0	27.5	31	78.7	102	111	0	38	39
2015	12	31	11	53	46	0.636	-0.148	3.845	0.013	0.01	0	27.5	31	77.8	102	111	0	38	39
2015	12	31	12	3	46	0.62	-0.138	3.842	0.013	0.01	0	27.1	30.5	76.5	101	111	0	38	40
2015	12	31	12	13	46	0.643	-0.151	3.848	0.016	0.013	0	27.5	31	80	102	111	0	38	39
2015	12	31	12	23	46	0.61	-0.144	3.839	0.01	0.007	0	28	30.5	74.4	102	111	0	37	40
2015	12	31	12	33	46	0.623	-0.141	3.842	0.013	0.01	0	27.1	31	76.5	102	111	0	39	39
2015	12	31	12	43	46	0.669	-0.171	3.845	0.016	0.013	0	27.1	31	73.5	101	111	0	38	39
2015	12	31	12	53	46	0.659	-0.177	3.845	0.016	0.013	0	27.5	31	71.8	102	111	0	38	39
2015	12	31	13	3	46	0.653	-0.154	3.848	0.01	0.007	0	27.1	31	76.1	102	110	0	39	38
2015	12	31	13	13	46	0.627	-0.135	3.842	0.01	0.007	0	28	31.4	71	103	112	0	38	39
2015	12	31	13	23	46	0.65	-0.167	3.842	0.013	0.01	0	27.1	30.5	74	101	110	0	38	39
2015	12	31	13	33	46	0.64	-0.184	3.842	0.013	0.01	0	27.5	31	70.5	102	111	0	38	39
2015	12	31	13	43	46	0.65	-0.128	3.848	0.016	0.016	0	27.5	30.5	63.6	102	110	0	38	39
2015	12	31	13	53	46	0.643	-0.151	3.845	0.016	0.016	0	27.5	31	61.9	102	111	0	38	39
2015	12	31	14	3	46	0.643	-0.135	3.845	0.016	0.013	0	27.5	31	67.9	102	111	0	38	39
2015	12	31	14	13	46	0.636	-0.148	3.848	0.016	0.016	0	27.1	31	70.5	101	111	0	38	39
2015	12	31	14	23	46	0.617	-0.144	3.845	0.013	0.01	0	27.1	31	73.1	102	111	0	39	39
2015	12	31	14	33	46	0.643	-0.164	3.842	0.016	0.016	0	27.1	31	69.2	101	111	0	38	39
2015	12	31	14	43	46	0.62	-0.154	3.845	0.01	0.007	0	27.5	31	68.8	102	111	0	38	39
2015	12	31	14	53	46	0.653	-0.135	3.852	0.013	0.01	0	27.1	30.5	69.7	101	110	0	38	39
2015	12	31	15	3	46	0.633	-0.148	3.842	0.013	0.01	0	27.5	30.5	67.5	102	111	0	38	40
2015	12	31	15	13	46	0.61	-0.154	3.845	0.013	0.01	0	27.1	30.5	69.7	101	110	0	38	39
2015	12	31	15	23	46	0.633	-0.161	3.842	0.013	0.01	0	27.1	30.5	67.9	101	110	0	38	39
2015	12	31	15	33	46	0.669	-0.102	3.842	0.01	0.007	0	27.1	31	67.1	101	111	0	38	39
2015	12	31	15	43	46	0.64	-0.125	3.852	0.013	0.01	0	27.5	31	69.2	102	111	0	38	39
2015	12	31	15	53	46	0.633	-0.161	3.852	0.013	0.01	0	29.7	33.1	66.2	108	117	0	39	40
2015	12	31	16	3	46	0.689	-0.121	3.842	0.013	0.01	0	28.4	31.8	65.8	104	113	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	16	13	46	0.62	-0.151	3.858	0.016	0.016	0	27.1	30.5	69.7	102	111	0	39	40
2015	12	31	16	23	46	0.627	-0.151	3.855	0.016	0.013	0	27.1	31	76.1	101	111	0	38	39
2015	12	31	16	33	46	0.607	-0.151	3.855	0.016	0.013	0	26.7	31	80	101	111	0	39	39
2015	12	31	16	43	46	0.63	-0.144	3.852	0.016	0.013	0	26.2	30.1	89.4	100	109	0	39	39
2015	12	31	16	53	46	0.614	-0.151	3.842	0.016	0.013	0	27.1	30.1	84.7	101	110	0	38	40
2015	12	31	17	3	46	0.636	-0.128	3.845	0.016	0.016	0	27.1	30.1	75.3	101	109	0	38	39
2015	12	31	17	13	46	0.65	-0.151	3.848	0.01	0.007	0	26.2	31	79.6	100	110	0	39	38
2015	12	31	17	23	46	0.636	-0.164	3.855	0.013	0.01	0	26.7	29.7	90.7	100	109	0	38	40
2015	12	31	17	33	46	0.63	-0.125	3.848	0.013	0.01	0	26.7	30.5	91.2	101	110	0	39	39
2015	12	31	17	43	46	0.607	-0.138	3.839	0.016	0.013	0	27.1	31	81.3	101	111	0	38	39
2015	12	31	17	53	46	0.63	-0.144	3.842	0.013	0.01	0	27.5	31.8	80.8	103	113	0	39	39
2015	12	31	18	3	46	0.65	-0.167	3.855	0.013	0.01	0	26.7	31	84.7	101	111	0	39	39
2015	12	31	18	13	46	0.643	-0.115	3.845	0.01	0.007	0	28.4	32.3	-15.9	104	114	0	38	39
2015	12	31	18	23	46	0.656	-0.148	3.842	0.01	0.007	0	28.8	32.3	83	105	115	0	38	40
2015	12	31	18	33	46	0.679	-0.154	3.848	0.016	0.016	0	28.8	31.4	81.3	104	112	0	37	39
2015	12	31	18	43	46	0.627	-0.151	3.855	0.013	0.01	0	27.5	31.4	88.2	102	112	0	38	39
2015	12	31	18	53	46	0.666	-0.141	3.842	0.016	0.013	0	27.5	31	-15.9	102	111	0	38	39
2015	12	31	19	3	46	0.659	-0.167	3.839	0.016	0.013	0	27.1	30.5	81.7	101	110	0	38	39
2015	12	31	19	13	46	0.663	-0.138	3.852	0.016	0.013	0	28.4	32.3	82.1	104	114	0	38	39
2015	12	31	19	23	46	0.636	-0.151	3.855	0.016	0.013	0	28	31.8	-14.2	104	113	0	39	39
2015	12	31	19	33	46	0.62	-0.141	3.839	0.013	0.01	0	28	31.8	89.4	103	113	0	38	39
2015	12	31	19	43	46	0.643	-0.138	3.842	0.013	0.01	0	27.5	31.4	86	102	111	0	38	38
2015	12	31	19	53	46	0.646	-0.128	3.858	0.013	0.01	0	27.5	30.5	85.1	102	111	0	38	40
2015	12	31	20	3	46	0.636	-0.151	3.845	0.013	0.01	0	28.4	31.4	-14.2	103	112	0	37	39
2015	12	31	20	13	46	0.643	-0.112	3.839	0.016	0.016	0	28	31	85.1	103	112	0	38	40
2015	12	31	20	23	46	0.643	-0.164	3.842	0.01	0.007	0	27.5	31	86	102	112	0	38	40
2015	12	31	20	33	46	0.646	-0.171	3.852	0.016	0.013	0	27.5	31	-14.6	101	111	0	37	39
2015	12	31	20	43	46	0.62	-0.141	3.839	0.013	0.01	0	27.5	31	89	102	111	0	38	39
2015	12	31	20	53	46	0.663	-0.135	3.839	0.013	0.01	0	28.4	31.4	88.6	104	112	0	38	39
2015	12	31	21	3	46	0.656	-0.148	3.848	0.01	0.007	0	28.8	32.3	-16.3	105	114	0	38	39
2015	12	31	21	13	46	0.64	-0.121	3.835	0.01	0.007	0	33.5	36.5	92	115	124	0	37	39
2015	12	31	21	23	46	0.669	-0.144	3.839	0.016	0.013	0	30.5	34.8	89	110	120	0	39	39
2015	12	31	21	33	46	0.676	-0.148	3.845	0.013	0.01	0	28.4	31.8	91.2	104	113	0	38	39
2015	12	31	21	43	46	0.594	-0.167	3.839	0.01	0.007	0	28	31.8	90.3	103	113	0	38	39
2015	12	31	21	53	46	0.62	-0.138	3.839	0.013	0.01	0	27.5	31	88.6	102	111	0	38	39
2015	12	31	22	3	46	0.679	-0.18	3.842	0.016	0.013	0	28	31.4	-15.1	103	112	0	38	39
2015	12	31	22	13	46	0.643	-0.131	3.839	0.013	0.01	0	27.1	31.8	90.3	102	112	0	39	38
2015	12	31	22	23	46	0.63	-0.128	3.839	0.01	0.007	0	27.5	31.4	87.3	102	111	0	38	38
2015	12	31	22	33	46	0.623	-0.174	3.842	0.016	0.013	0	27.5	31	91.2	102	111	0	38	39
2015	12	31	22	43	46	0.666	-0.135	3.835	0.016	0.016	0	29.7	33.5	90.7	108	117	0	39	39
2015	12	31	22	53	46	0.656	-0.121	3.839	0.013	0.01	0	28.4	32.3	88.6	104	114	0	38	39
2015	12	31	23	3	46	0.643	-0.135	3.842	0.016	0.013	0	28	31.8	-15.5	103	113	0	38	39
2015	12	31	23	13	46	0.62	-0.151	3.839	0.016	0.013	0	27.5	30.5	89.9	102	111	0	38	40
2015	12	31	23	23	46	0.656	-0.105	3.839	0.013	0.01	0	31.8	35.7	90.3	112	123	0	38	40
2015	12	31	23	33	46	0.65	-0.105	3.845	0.01	0.007	0	35.7	39.1	-15.9	121	130	0	38	39
2015	12	31	23	43	46	0.63	-0.131	3.839	0.016	0.016	0	29.7	33.5	0	107	117	0	38	39

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	23	53	46	0.65	-0.138	3.839	0.016	0.013	0	28.8	31.8	88.2	105	114	0	38	40

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	0	2	22	39	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	1	0	12	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	1	0	22	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	1	0	32	22	40	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	1	0	42	22	40	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	1	0	52	22	39	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	1	1	2	22	39	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	1	1	12	22	40	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	1	1	22	22	40	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	1	1	32	22	39	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	1	1	42	22	39	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	1	1	52	22	40	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	1	2	2	22	40	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	1	2	12	22	40	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	1	2	22	22	40	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	1	2	32	22	40	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	1	2	42	22	39	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	1	2	52	22	40	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	1	3	2	22	39	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	1	3	12	22	39	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	1	3	22	22	40	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	1	3	32	22	40	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	1	3	42	22	39	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	1	3	52	22	39	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	1	4	2	22	39	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	1	4	12	22	39	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	1	4	22	22	40	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	1	4	32	22	40	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	1	4	42	22	40	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	1	4	52	22	40	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	1	5	2	22	40	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	1	5	12	22	40	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	1	5	22	22	40	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	1	5	32	22	40	0	0	0	0	0	0	0	32.2	0	0	11.6
2015	12	1	5	42	22	40	0	0	0	0	0	0	0	32.18	0	0	11.6
2015	12	1	5	52	22	39	0	0	0	0	0	0	0	32.16	0	0	11.6
2015	12	1	6	2	22	40	0	0	0	0	0	0	0	32.14	0	0	11.6
2015	12	1	6	12	22	40	0	0	0	0	0	0	0	32.14	0	0	11.6
2015	12	1	6	22	22	40	0	0	0	0	0	0	0	32.13	0	0	11.6
2015	12	1	6	32	22	40	0	0	0	0	0	0	0	32.13	0	0	11.6
2015	12	1	6	42	22	39	0	0	0	0	0	0	0	32.13	0	0	11.6
2015	12	1	6	52	22	40	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	1	7	2	22	39	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	1	7	12	22	39	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	1	7	22	22	40	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	1	7	32	22	40	0	0	0	0	0	0	0	32.13	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	7	42	22	40	0	0	0	0	0	0	0	32.2	0	0	12.8
2015	12	1	7	52	22	39	0	0	0	0	0	0	0	32.23	0	0	13.4
2015	12	1	8	2	22	40	0	0	0	0	0	0	0	32.27	0	0	13.6
2015	12	1	8	12	22	40	0	0	0	0	0	0	0	32.34	0	0	13.6
2015	12	1	8	22	22	40	0	0	0	0	0	0	0	32.4	0	0	14
2015	12	1	8	32	22	40	0	0	0	0	0	0	0	32.49	0	0	14.2
2015	12	1	8	42	22	40	0	0	0	0	0	0	0	32.54	0	0	14.2
2015	12	1	8	52	22	39	0	0	0	0	0	0	0	32.59	0	0	14
2015	12	1	9	2	22	40	0	0	0	0	0	0	0	32.67	0	0	14
2015	12	1	9	12	22	40	0	0	0	0	0	0	0	32.74	0	0	14
2015	12	1	9	22	22	39	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	1	9	32	22	40	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	1	9	42	22	39	0	0	0	0	0	0	0	32.94	0	0	14
2015	12	1	9	52	22	40	0	0	0	0	0	0	0	33.01	0	0	14
2015	12	1	10	2	22	40	0	0	0	0	0	0	0	33.08	0	0	14
2015	12	1	10	12	22	39	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	1	10	22	22	40	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	1	10	32	22	40	0	0	0	0	0	0	0	33.19	0	0	13.8
2015	12	1	10	42	22	40	0	0	0	0	0	0	0	33.28	0	0	13.8
2015	12	1	10	52	22	39	0	0	0	0	0	0	0	33.28	0	0	13.8
2015	12	1	11	2	22	39	0	0	0	0	0	0	0	33.35	0	0	13.8
2015	12	1	11	12	22	40	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	1	11	22	22	39	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	1	11	32	22	40	0	0	0	0	0	0	0	33.37	0	0	13.8
2015	12	1	11	42	22	40	0	0	0	0	0	0	0	33.4	0	0	13.8
2015	12	1	11	52	22	40	0	0	0	0	0	0	0	33.42	0	0	13.8
2015	12	1	12	2	22	40	0	0	0	0	0	0	0	33.35	0	0	13.8
2015	12	1	12	12	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	1	12	22	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	1	12	32	22	40	0	0	0	0	0	0	0	33.49	0	0	13.8
2015	12	1	12	42	22	40	0	0	0	0	0	0	0	33.49	0	0	13.8
2015	12	1	12	52	22	40	0	0	0	0	0	0	0	33.49	0	0	13.8
2015	12	1	13	2	22	39	0	0	0	0	0	0	0	33.44	0	0	13.6
2015	12	1	13	12	22	39	0	0	0	0	0	0	0	33.44	0	0	13.6
2015	12	1	13	22	22	40	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	1	13	32	22	40	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	1	13	42	22	40	0	0	0	0	0	0	0	33.35	0	0	13.6
2015	12	1	13	52	22	40	0	0	0	0	0	0	0	33.28	0	0	13.6
2015	12	1	14	2	22	40	0	0	0	0	0	0	0	33.21	0	0	13.6
2015	12	1	14	12	22	40	0	0	0	0	0	0	0	33.15	0	0	13.6
2015	12	1	14	22	22	40	0	0	0	0	0	0	0	33.12	0	0	13.6
2015	12	1	14	32	22	40	0	0	0	0	0	0	0	33.06	0	0	13.6
2015	12	1	14	42	22	40	0	0	0	0	0	0	0	33.01	0	0	13.6
2015	12	1	14	52	22	40	0	0	0	0	0	0	0	32.88	0	0	13.6
2015	12	1	15	2	22	40	0	0	0	0	0	0	0	32.7	0	0	13.6
2015	12	1	15	12	22	40	0	0	0	0	0	0	0	32.65	0	0	13.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	15	22	22	39	0	0	0	0	0	0	0	32.65	0	0	13.6
2015	12	1	15	32	22	40	0	0	0	0	0	0	0	32.63	0	0	13.6
2015	12	1	15	42	22	40	0	0	0	0	0	0	0	32.63	0	0	13.6
2015	12	1	15	52	22	40	0	0	0	0	0	0	0	32.63	0	0	13.4
2015	12	1	16	2	22	40	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	1	16	12	22	40	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	1	16	22	22	39	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	1	16	32	22	40	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	1	16	42	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	16	52	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	17	2	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	17	12	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	17	22	22	40	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	1	17	32	22	40	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	1	17	42	22	39	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	1	17	52	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	18	2	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	18	12	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	18	22	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	1	18	32	22	40	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	1	18	42	22	39	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	1	18	52	22	39	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	19	2	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	19	12	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	19	22	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	19	32	22	39	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	19	42	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	19	52	22	39	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	20	2	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	20	12	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	20	22	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	20	32	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	20	42	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	20	52	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	21	2	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	21	12	22	39	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	1	21	22	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	21	32	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	21	42	22	39	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	1	21	52	22	39	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	1	22	2	22	40	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	1	22	12	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	1	22	22	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	1	22	32	22	39	0	0	0	0	0	0	0	32.54	0	0	12
2015	12	1	22	42	22	40	0	0	0	0	0	0	0	32.52	0	0	12
2015	12	1	22	52	22	39	0	0	0	0	0	0	0	32.52	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	23	2	22	39	0	0	0	0	0	0	0	32.5	0	0	12
2015	12	1	23	12	22	40	0	0	0	0	0	0	0	32.5	0	0	12
2015	12	1	23	22	22	39	0	0	0	0	0	0	0	32.47	0	0	12
2015	12	1	23	32	22	40	0	0	0	0	0	0	0	32.45	0	0	12
2015	12	1	23	42	22	39	0	0	0	0	0	0	0	32.43	0	0	12
2015	12	1	23	52	22	40	0	0	0	0	0	0	0	32.41	0	0	12
2015	12	2	0	2	22	39	0	0	0	0	0	0	0	32.41	0	0	12
2015	12	2	0	12	22	39	0	0	0	0	0	0	0	32.4	0	0	12
2015	12	2	0	22	22	40	0	0	0	0	0	0	0	32.38	0	0	12
2015	12	2	0	32	22	40	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	2	0	42	22	40	0	0	0	0	0	0	0	32.32	0	0	12
2015	12	2	0	52	22	39	0	0	0	0	0	0	0	32.32	0	0	12
2015	12	2	1	2	22	39	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	2	1	12	22	40	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	2	1	22	22	40	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	2	1	32	22	39	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	2	1	42	22	40	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	2	1	52	22	40	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	2	2	2	22	40	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	2	2	12	22	39	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	2	2	22	22	40	0	0	0	0	0	0	0	32.2	0	0	11.8
2015	12	2	2	32	22	39	0	0	0	0	0	0	0	32.2	0	0	11.8
2015	12	2	2	42	22	40	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	2	2	52	22	40	0	0	0	0	0	0	0	32.16	0	0	11.8
2015	12	2	3	2	22	39	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	2	3	12	22	39	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	2	3	22	22	40	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	2	3	32	22	39	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	2	3	42	22	40	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	2	3	52	22	39	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	2	4	2	22	40	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	2	4	12	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	2	4	22	22	40	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	2	4	32	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	2	4	42	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	2	4	52	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	2	5	2	22	40	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	2	5	12	22	40	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	2	5	22	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	2	5	32	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	2	5	42	22	41	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	2	5	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	2	6	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	2	6	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	2	6	22	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	2	6	32	22	40	0	0	0	0	0	0	0	32	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	6	42	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	2	6	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	2	7	2	22	39	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	2	7	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	2	7	22	22	39	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	2	7	32	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	2	7	42	22	40	0	0	0	0	0	0	0	32.11	0	0	12.8
2015	12	2	7	52	22	40	0	0	0	0	0	0	0	32.18	0	0	13.2
2015	12	2	8	2	22	40	0	0	0	0	0	0	0	32.23	0	0	13.4
2015	12	2	8	12	22	39	0	0	0	0	0	0	0	32.29	0	0	13.4
2015	12	2	8	22	22	39	0	0	0	0	0	0	0	32.36	0	0	13.6
2015	12	2	8	32	22	40	0	0	0	0	0	0	0	32.43	0	0	13.8
2015	12	2	8	42	22	40	0	0	0	0	0	0	0	32.47	0	0	14
2015	12	2	8	52	22	40	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	2	9	2	22	40	0	0	0	0	0	0	0	32.63	0	0	14
2015	12	2	9	12	22	40	0	0	0	0	0	0	0	32.68	0	0	14
2015	12	2	9	22	22	40	0	0	0	0	0	0	0	32.74	0	0	14
2015	12	2	9	32	22	40	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	2	9	42	22	40	0	0	0	0	0	0	0	32.92	0	0	13.8
2015	12	2	9	52	22	40	0	0	0	0	0	0	0	32.99	0	0	13.8
2015	12	2	10	2	22	40	0	0	0	0	0	0	0	33.1	0	0	13.8
2015	12	2	10	12	22	40	0	0	0	0	0	0	0	33.03	0	0	13.8
2015	12	2	10	22	22	40	0	0	0	0	0	0	0	33.12	0	0	13.8
2015	12	2	10	32	22	40	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	2	10	42	22	39	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	2	10	52	22	39	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	2	11	2	22	39	0	0	0	0	0	0	0	33.35	0	0	13.8
2015	12	2	11	12	22	40	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	2	11	22	22	40	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	2	11	32	22	39	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	2	11	42	22	40	0	0	0	0	0	0	0	33.28	0	0	13.8
2015	12	2	11	52	22	39	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	2	12	2	22	40	0	0	0	0	0	0	0	33.19	0	0	13.6
2015	12	2	12	12	22	40	0	0	0	0	0	0	0	33.19	0	0	13.6
2015	12	2	12	22	22	40	0	0	0	0	0	0	0	33.1	0	0	13.6
2015	12	2	12	32	22	39	0	0	0	0	0	0	0	33.17	0	0	13.6
2015	12	2	12	42	22	40	0	0	0	0	0	0	0	33.21	0	0	13.6
2015	12	2	12	52	22	40	0	0	0	0	0	0	0	32.99	0	0	13.6
2015	12	2	13	2	22	40	0	0	0	0	0	0	0	33.04	0	0	13.6
2015	12	2	13	12	22	40	0	0	0	0	0	0	0	33.1	0	0	13.6
2015	12	2	13	22	22	39	0	0	0	0	0	0	0	33.08	0	0	13.6
2015	12	2	13	32	22	39	0	0	0	0	0	0	0	33.01	0	0	13.6
2015	12	2	13	42	22	40	0	0	0	0	0	0	0	32.92	0	0	13.6
2015	12	2	13	52	22	39	0	0	0	0	0	0	0	32.9	0	0	13.6
2015	12	2	14	2	22	40	0	0	0	0	0	0	0	32.86	0	0	13.6
2015	12	2	14	12	22	40	0	0	0	0	0	0	0	32.94	0	0	13.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	14	22	22	40	0	0	0	0	0	0	0	32.94	0	0	13.6
2015	12	2	14	32	22	40	0	0	0	0	0	0	0	32.94	0	0	13.4
2015	12	2	14	42	22	39	0	0	0	0	0	0	0	32.86	0	0	13.6
2015	12	2	14	52	22	40	0	0	0	0	0	0	0	32.79	0	0	13.6
2015	12	2	15	2	22	40	0	0	0	0	0	0	0	32.77	0	0	13.6
2015	12	2	15	12	22	39	0	0	0	0	0	0	0	32.76	0	0	13.8
2015	12	2	15	22	22	40	0	0	0	0	0	0	0	32.74	0	0	13.8
2015	12	2	15	32	22	40	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	2	15	42	22	40	0	0	0	0	0	0	0	32.7	0	0	13.6
2015	12	2	15	52	22	40	0	0	0	0	0	0	0	32.68	0	0	12.4
2015	12	2	16	2	22	40	0	0	0	0	0	0	0	32.67	0	0	12.2
2015	12	2	16	12	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	16	22	22	40	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	2	16	32	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	16	42	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	16	52	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	17	2	22	39	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	17	12	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	17	22	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	17	32	22	40	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	2	17	42	22	40	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	2	17	52	22	40	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	2	18	2	22	40	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	2	18	12	22	40	0	0	0	0	0	0	0	32.67	0	0	12.2
2015	12	2	18	22	22	40	0	0	0	0	0	0	0	32.68	0	0	12.2
2015	12	2	18	32	22	39	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	2	18	42	22	40	0	0	0	0	0	0	0	32.7	0	0	12.2
2015	12	2	18	52	22	39	0	0	0	0	0	0	0	32.7	0	0	12.2
2015	12	2	19	2	22	39	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	2	19	12	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	2	19	22	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	2	19	32	22	39	0	0	0	0	0	0	0	32.76	0	0	12
2015	12	2	19	42	22	40	0	0	0	0	0	0	0	32.76	0	0	12
2015	12	2	19	52	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	20	2	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	20	12	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	20	22	22	39	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	20	32	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	20	42	22	39	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	20	52	22	39	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	21	2	22	39	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	21	12	22	40	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	21	22	22	39	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	21	32	22	40	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	21	42	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	21	52	22	40	0	0	0	0	0	0	0	32.79	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	22	2	22	40	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	22	12	22	40	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	22	22	22	39	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	2	22	32	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	22	42	22	39	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	22	52	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	23	2	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	23	12	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	23	22	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	2	23	32	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	23	42	22	39	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	2	23	52	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	3	0	2	22	40	0	0	0	0	0	0	0	32.76	0	0	12
2015	12	3	0	12	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	3	0	22	22	40	0	0	0	0	0	0	0	32.76	0	0	12
2015	12	3	0	32	22	40	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	3	0	42	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	3	0	52	22	40	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	3	1	2	22	40	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	3	1	12	22	40	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	3	1	22	22	40	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	3	1	32	22	40	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	3	1	42	22	39	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	3	1	52	22	40	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	3	2	2	22	39	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	3	2	12	22	39	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	3	2	22	22	40	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	3	2	32	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	3	2	42	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	3	2	52	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	3	3	2	22	40	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	3	3	12	22	41	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	3	3	22	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	3	3	32	22	39	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	3	3	42	22	40	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	3	3	52	22	40	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	3	4	2	22	40	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	4	12	22	40	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	4	22	22	39	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	4	32	22	39	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	4	42	22	40	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	4	52	22	39	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	3	5	2	22	40	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	3	5	12	22	39	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	3	5	22	22	40	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	3	5	32	22	40	0	0	0	0	0	0	0	32.61	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	5	42	22	39	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	3	5	52	22	40	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	3	6	2	22	39	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	6	12	22	39	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	6	22	22	39	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	6	32	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	6	42	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	6	52	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	7	2	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	7	12	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	7	22	22	40	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	3	7	32	22	40	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	3	7	42	22	40	0	0	0	0	0	0	0	32.65	0	0	12.4
2015	12	3	7	52	22	40	0	0	0	0	0	0	0	32.67	0	0	12.8
2015	12	3	8	2	22	40	0	0	0	0	0	0	0	32.67	0	0	12.8
2015	12	3	8	12	22	40	0	0	0	0	0	0	0	32.76	0	0	13.2
2015	12	3	8	22	22	40	0	0	0	0	0	0	0	32.86	0	0	13.4
2015	12	3	8	32	22	39	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	3	8	42	22	40	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	3	8	52	22	39	0	0	0	0	0	0	0	32.94	0	0	13.8
2015	12	3	9	2	22	40	0	0	0	0	0	0	0	33.12	0	0	14
2015	12	3	9	12	22	39	0	0	0	0	0	0	0	33.15	0	0	13.8
2015	12	3	9	22	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	3	9	32	22	40	0	0	0	0	0	0	0	33.22	0	0	13.8
2015	12	3	9	42	22	40	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	3	9	52	22	40	0	0	0	0	0	0	0	33.44	0	0	13.8
2015	12	3	10	2	22	40	0	0	0	0	0	0	0	33.4	0	0	13.8
2015	12	3	10	12	22	40	0	0	0	0	0	0	0	33.57	0	0	13.8
2015	12	3	10	22	22	40	0	0	0	0	0	0	0	33.4	0	0	13.4
2015	12	3	10	32	22	40	0	0	0	0	0	0	0	33.6	0	0	13.8
2015	12	3	10	42	22	39	0	0	0	0	0	0	0	33.55	0	0	13.8
2015	12	3	10	52	22	40	0	0	0	0	0	0	0	33.31	0	0	13.6
2015	12	3	11	2	22	39	0	0	0	0	0	0	0	33.55	0	0	13.8
2015	12	3	11	12	22	40	0	0	0	0	0	0	0	33.78	0	0	13.8
2015	12	3	11	22	22	39	0	0	0	0	0	0	0	33.67	0	0	13.8
2015	12	3	11	32	22	40	0	0	0	0	0	0	0	33.93	0	0	13.8
2015	12	3	11	42	22	40	0	0	0	0	0	0	0	33.78	0	0	13.8
2015	12	3	11	52	22	39	0	0	0	0	0	0	0	33.93	0	0	13.8
2015	12	3	12	2	22	39	0	0	0	0	0	0	0	34.02	0	0	13.8
2015	12	3	12	12	22	39	0	0	0	0	0	0	0	34.07	0	0	13.8
2015	12	3	12	22	22	39	0	0	0	0	0	0	0	34.05	0	0	13.8
2015	12	3	12	32	22	40	0	0	0	0	0	0	0	34.05	0	0	13.8
2015	12	3	12	42	22	40	0	0	0	0	0	0	0	34.11	0	0	13.8
2015	12	3	12	52	22	39	0	0	0	0	0	0	0	34	0	0	13.6
2015	12	3	13	2	22	40	0	0	0	0	0	0	0	33.75	0	0	13.6
2015	12	3	13	12	22	40	0	0	0	0	0	0	0	33.87	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	13	22	22	39	0	0	0	0	0	0	0	33.98	0	0	13.8
2015	12	3	13	32	22	39	0	0	0	0	0	0	0	33.84	0	0	13.6
2015	12	3	13	42	22	40	0	0	0	0	0	0	0	33.91	0	0	13.6
2015	12	3	13	52	22	40	0	0	0	0	0	0	0	33.94	0	0	13.6
2015	12	3	14	2	22	40	0	0	0	0	0	0	0	33.89	0	0	13.6
2015	12	3	14	12	22	39	0	0	0	0	0	0	0	33.91	0	0	13.6
2015	12	3	14	22	22	39	0	0	0	0	0	0	0	33.85	0	0	13.6
2015	12	3	14	32	22	40	0	0	0	0	0	0	0	33.8	0	0	13.6
2015	12	3	14	42	22	40	0	0	0	0	0	0	0	33.76	0	0	13.6
2015	12	3	14	52	22	39	0	0	0	0	0	0	0	33.64	0	0	13.6
2015	12	3	15	2	22	40	0	0	0	0	0	0	0	33.49	0	0	13.6
2015	12	3	15	12	22	40	0	0	0	0	0	0	0	33.46	0	0	13.6
2015	12	3	15	22	22	40	0	0	0	0	0	0	0	33.42	0	0	12.4
2015	12	3	15	32	22	40	0	0	0	0	0	0	0	33.42	0	0	12.4
2015	12	3	15	42	22	39	0	0	0	0	0	0	0	33.42	0	0	12.4
2015	12	3	15	52	22	40	0	0	0	0	0	0	0	33.4	0	0	12.2
2015	12	3	16	2	22	40	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	16	12	22	40	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	16	22	22	40	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	16	32	22	39	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	16	42	22	40	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	16	52	22	39	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	17	2	22	40	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	17	12	22	40	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	17	22	22	40	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	3	17	32	22	39	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	17	42	22	39	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	17	52	22	39	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	18	2	22	40	0	0	0	0	0	0	0	33.39	0	0	12.2
2015	12	3	18	12	22	40	0	0	0	0	0	0	0	33.4	0	0	12.2
2015	12	3	18	22	22	40	0	0	0	0	0	0	0	33.42	0	0	12.2
2015	12	3	18	32	22	39	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	3	18	42	22	40	0	0	0	0	0	0	0	33.44	0	0	12.2
2015	12	3	18	52	22	40	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	3	19	2	22	40	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	3	19	12	22	40	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	3	19	22	22	39	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	3	19	32	22	40	0	0	0	0	0	0	0	33.48	0	0	12
2015	12	3	19	42	22	40	0	0	0	0	0	0	0	33.48	0	0	12
2015	12	3	19	52	22	39	0	0	0	0	0	0	0	33.49	0	0	12
2015	12	3	20	2	22	40	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	3	20	12	22	40	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	3	20	22	22	39	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	3	20	32	22	39	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	3	20	42	22	40	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	3	20	52	22	39	0	0	0	0	0	0	0	33.57	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	21	2	22	40	0	0	0	0	0	0	0	33.58	0	0	12
2015	12	3	21	12	22	39	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	3	21	22	22	40	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	3	21	32	22	40	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	3	21	42	22	40	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	3	21	52	22	40	0	0	0	0	0	0	0	33.66	0	0	12
2015	12	3	22	2	22	39	0	0	0	0	0	0	0	33.66	0	0	12
2015	12	3	22	12	22	40	0	0	0	0	0	0	0	33.67	0	0	12
2015	12	3	22	22	22	40	0	0	0	0	0	0	0	33.67	0	0	12
2015	12	3	22	32	22	40	0	0	0	0	0	0	0	33.69	0	0	12
2015	12	3	22	42	22	40	0	0	0	0	0	0	0	33.71	0	0	12
2015	12	3	22	52	22	39	0	0	0	0	0	0	0	33.71	0	0	12
2015	12	3	23	2	22	39	0	0	0	0	0	0	0	33.73	0	0	12
2015	12	3	23	12	22	39	0	0	0	0	0	0	0	33.73	0	0	12
2015	12	3	23	22	22	40	0	0	0	0	0	0	0	33.75	0	0	12
2015	12	3	23	32	22	40	0	0	0	0	0	0	0	33.76	0	0	12
2015	12	3	23	42	22	39	0	0	0	0	0	0	0	33.78	0	0	12
2015	12	3	23	52	22	40	0	0	0	0	0	0	0	33.8	0	0	12
2015	12	4	0	2	22	40	0	0	0	0	0	0	0	33.8	0	0	12
2015	12	4	0	12	22	40	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	4	0	22	22	40	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	4	0	32	22	40	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	4	0	42	22	39	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	4	0	52	22	39	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	4	1	2	22	39	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	4	1	12	22	40	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	4	1	22	22	38	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	4	1	32	22	40	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	4	1	42	22	39	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	4	1	52	22	39	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	4	2	2	22	39	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	4	2	12	22	39	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	4	2	22	22	40	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	4	2	32	22	40	0	0	0	0	0	0	0	33.93	0	0	12
2015	12	4	2	42	22	39	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	4	2	52	22	39	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	4	3	2	22	40	0	0	0	0	0	0	0	33.93	0	0	12
2015	12	4	3	12	22	40	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	4	3	22	22	40	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	4	3	32	22	40	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	4	3	42	22	40	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	4	3	52	22	39	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	4	4	2	22	39	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	4	4	12	22	40	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	4	4	22	22	40	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	4	4	32	22	39	0	0	0	0	0	0	0	33.98	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	4	42	22	40	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	4	4	52	22	40	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	4	5	2	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	5	12	22	39	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	4	5	22	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	5	32	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	5	42	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	5	52	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	2	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	12	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	22	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	32	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	42	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	6	52	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	7	2	22	39	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	4	7	12	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	7	22	22	40	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	4	7	32	22	39	0	0	0	0	0	0	0	34.03	0	0	12
2015	12	4	7	42	22	40	0	0	0	0	0	0	0	34.09	0	0	12.6
2015	12	4	7	52	22	40	0	0	0	0	0	0	0	34.14	0	0	12.8
2015	12	4	8	2	22	40	0	0	0	0	0	0	0	34.18	0	0	13
2015	12	4	8	12	22	39	0	0	0	0	0	0	0	34.23	0	0	13.2
2015	12	4	8	22	22	39	0	0	0	0	0	0	0	34.3	0	0	13.2
2015	12	4	8	32	22	40	0	0	0	0	0	0	0	34.36	0	0	13.2
2015	12	4	8	42	22	39	0	0	0	0	0	0	0	34.45	0	0	13.4
2015	12	4	8	52	22	40	0	0	0	0	0	0	0	34.5	0	0	13.6
2015	12	4	9	2	22	39	0	0	0	0	0	0	0	34.59	0	0	13.8
2015	12	4	9	12	22	40	0	0	0	0	0	0	0	34.66	0	0	13.8
2015	12	4	9	22	22	39	0	0	0	0	0	0	0	34.72	0	0	13.8
2015	12	4	9	32	22	39	0	0	0	0	0	0	0	34.79	0	0	13.8
2015	12	4	9	42	22	39	0	0	0	0	0	0	0	34.88	0	0	13.8
2015	12	4	9	52	22	39	0	0	0	0	0	0	0	34.95	0	0	13.8
2015	12	4	10	2	22	40	0	0	0	0	0	0	0	35.04	0	0	13.8
2015	12	4	10	12	22	40	0	0	0	0	0	0	0	35.1	0	0	13.8
2015	12	4	10	22	22	39	0	0	0	0	0	0	0	35.19	0	0	13.8
2015	12	4	10	32	22	39	0	0	0	0	0	0	0	35.24	0	0	13.8
2015	12	4	10	42	22	39	0	0	0	0	0	0	0	35.28	0	0	13.8
2015	12	4	10	52	22	39	0	0	0	0	0	0	0	35.37	0	0	13.8
2015	12	4	11	2	22	39	0	0	0	0	0	0	0	35.35	0	0	13.8
2015	12	4	11	12	22	39	0	0	0	0	0	0	0	35.42	0	0	13.8
2015	12	4	11	22	22	39	0	0	0	0	0	0	0	35.46	0	0	13.8
2015	12	4	11	32	22	39	0	0	0	0	0	0	0	35.44	0	0	13.6
2015	12	4	11	42	22	39	0	0	0	0	0	0	0	35.46	0	0	13.6
2015	12	4	11	52	22	40	0	0	0	0	0	0	0	35.53	0	0	13.6
2015	12	4	12	2	22	39	0	0	0	0	0	0	0	35.6	0	0	13.6
2015	12	4	12	12	22	39	0	0	0	0	0	0	0	35.62	0	0	13.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	12	22	22	40	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	4	12	32	22	40	0	0	0	0	0	0	0	35.67	0	0	13.6
2015	12	4	12	42	22	39	0	0	0	0	0	0	0	35.62	0	0	13.6
2015	12	4	12	52	22	39	0	0	0	0	0	0	0	35.62	0	0	13.6
2015	12	4	13	2	22	39	0	0	0	0	0	0	0	35.65	0	0	13.6
2015	12	4	13	12	22	39	0	0	0	0	0	0	0	35.65	0	0	13.6
2015	12	4	13	22	22	39	0	0	0	0	0	0	0	35.62	0	0	13.6
2015	12	4	13	32	22	40	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	4	13	42	22	38	0	0	0	0	0	0	0	35.62	0	0	13.6
2015	12	4	13	52	22	39	0	0	0	0	0	0	0	35.6	0	0	13.6
2015	12	4	14	2	22	39	0	0	0	0	0	0	0	35.55	0	0	13.6
2015	12	4	14	12	22	39	0	0	0	0	0	0	0	35.53	0	0	13.6
2015	12	4	14	22	22	39	0	0	0	0	0	0	0	35.51	0	0	13.6
2015	12	4	14	32	22	40	0	0	0	0	0	0	0	35.47	0	0	13.6
2015	12	4	14	42	22	39	0	0	0	0	0	0	0	35.44	0	0	13.6
2015	12	4	14	52	22	39	0	0	0	0	0	0	0	35.35	0	0	13.6
2015	12	4	15	2	22	39	0	0	0	0	0	0	0	35.22	0	0	13.6
2015	12	4	15	12	22	39	0	0	0	0	0	0	0	35.19	0	0	13.4
2015	12	4	15	22	22	40	0	0	0	0	0	0	0	35.19	0	0	13.4
2015	12	4	15	32	22	39	0	0	0	0	0	0	0	35.19	0	0	13.4
2015	12	4	15	42	22	39	0	0	0	0	0	0	0	35.19	0	0	13.6
2015	12	4	15	52	22	40	0	0	0	0	0	0	0	35.19	0	0	13.4
2015	12	4	16	2	22	40	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	16	12	22	39	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	4	16	22	22	39	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	16	32	22	39	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	16	42	22	39	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	16	52	22	40	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	17	2	22	40	0	0	0	0	0	0	0	35.19	0	0	12.2
2015	12	4	17	12	22	39	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	4	17	22	22	40	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	4	17	32	22	39	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	4	17	42	22	40	0	0	0	0	0	0	0	35.22	0	0	12.2
2015	12	4	17	52	22	39	0	0	0	0	0	0	0	35.22	0	0	12.2
2015	12	4	18	2	22	39	0	0	0	0	0	0	0	35.24	0	0	12.2
2015	12	4	18	12	22	39	0	0	0	0	0	0	0	35.26	0	0	12.2
2015	12	4	18	22	22	40	0	0	0	0	0	0	0	35.26	0	0	12.2
2015	12	4	18	32	22	40	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	4	18	42	22	40	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	4	18	52	22	40	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	4	19	2	22	39	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	4	19	12	22	40	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	4	19	22	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	4	19	32	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	4	19	42	22	40	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	4	19	52	22	39	0	0	0	0	0	0	0	35.37	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	20	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	4	20	12	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	4	20	22	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	4	20	32	22	40	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	4	20	42	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	20	52	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	21	2	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	21	12	22	40	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	21	22	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	21	32	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	21	42	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	21	52	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	22	2	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	22	12	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	22	22	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	22	32	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	22	42	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	22	52	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	4	23	2	22	40	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	23	12	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	4	23	22	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	4	23	32	22	40	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	4	23	42	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	4	23	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	0	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	0	12	22	38	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	0	22	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	0	32	22	39	0	0	0	0	0	0	0	35.33	0	0	11.8
2015	12	5	0	42	22	38	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	5	0	52	22	40	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	5	1	2	22	40	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	5	1	12	22	40	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	5	1	22	22	39	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	5	1	32	22	39	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	5	1	42	22	39	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	5	1	52	22	39	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	5	2	2	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	5	2	12	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	5	2	22	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	5	2	32	22	40	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	5	2	42	22	40	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	5	2	52	22	40	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	5	3	2	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	5	3	12	22	39	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	5	3	22	22	40	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	5	3	32	22	39	0	0	0	0	0	0	0	35.11	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	3	42	22	40	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	5	3	52	22	40	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	5	4	2	22	39	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	5	4	12	22	39	0	0	0	0	0	0	0	35.04	0	0	11.8
2015	12	5	4	22	22	40	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	5	4	32	22	39	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	5	4	42	22	40	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	5	4	52	22	39	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	5	5	2	22	40	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	5	5	12	22	40	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	5	5	22	22	39	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	5	5	32	22	40	0	0	0	0	0	0	0	34.92	0	0	11.8
2015	12	5	5	42	22	40	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	5	5	52	22	39	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	5	6	2	22	39	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	5	6	12	22	39	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	5	6	22	22	39	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	5	6	32	22	39	0	0	0	0	0	0	0	34.83	0	0	11.6
2015	12	5	6	42	22	39	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	5	6	52	22	39	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	5	7	2	22	40	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	5	7	12	22	39	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	5	7	22	22	39	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	5	7	32	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	5	7	42	22	40	0	0	0	0	0	0	0	34.79	0	0	12.6
2015	12	5	7	52	22	39	0	0	0	0	0	0	0	34.83	0	0	13
2015	12	5	8	2	22	39	0	0	0	0	0	0	0	34.81	0	0	13
2015	12	5	8	12	22	39	0	0	0	0	0	0	0	34.9	0	0	13.4
2015	12	5	8	22	22	39	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	5	8	32	22	39	0	0	0	0	0	0	0	34.95	0	0	13.2
2015	12	5	8	42	22	39	0	0	0	0	0	0	0	35.04	0	0	14.2
2015	12	5	8	52	22	40	0	0	0	0	0	0	0	35.02	0	0	13
2015	12	5	9	2	22	39	0	0	0	0	0	0	0	35.13	0	0	14
2015	12	5	9	12	22	39	0	0	0	0	0	0	0	35.28	0	0	14
2015	12	5	9	22	22	39	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	5	9	32	22	40	0	0	0	0	0	0	0	35.38	0	0	14
2015	12	5	9	42	22	40	0	0	0	0	0	0	0	35.29	0	0	14
2015	12	5	9	52	22	40	0	0	0	0	0	0	0	35.53	0	0	14
2015	12	5	10	2	22	39	0	0	0	0	0	0	0	35.58	0	0	13.8
2015	12	5	10	12	22	39	0	0	0	0	0	0	0	35.6	0	0	13.8
2015	12	5	10	22	22	39	0	0	0	0	0	0	0	35.64	0	0	13.8
2015	12	5	10	32	22	40	0	0	0	0	0	0	0	35.51	0	0	13.8
2015	12	5	10	42	22	40	0	0	0	0	0	0	0	35.76	0	0	13.8
2015	12	5	10	52	22	39	0	0	0	0	0	0	0	35.83	0	0	13.8
2015	12	5	11	2	22	40	0	0	0	0	0	0	0	35.47	0	0	13.8
2015	12	5	11	12	22	39	0	0	0	0	0	0	0	35.78	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	11	22	22	39	0	0	0	0	0	0	0	35.85	0	0	13.8
2015	12	5	11	32	22	39	0	0	0	0	0	0	0	36	0	0	13.8
2015	12	5	11	42	22	39	0	0	0	0	0	0	0	35.76	0	0	13.8
2015	12	5	11	52	22	40	0	0	0	0	0	0	0	36	0	0	13.8
2015	12	5	12	2	22	39	0	0	0	0	0	0	0	35.91	0	0	13.6
2015	12	5	12	12	22	39	0	0	0	0	0	0	0	35.91	0	0	13.6
2015	12	5	12	22	22	39	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	5	12	32	22	40	0	0	0	0	0	0	0	35.87	0	0	13.6
2015	12	5	12	42	22	39	0	0	0	0	0	0	0	35.8	0	0	13.6
2015	12	5	12	52	22	40	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	5	13	2	22	39	0	0	0	0	0	0	0	35.65	0	0	13.6
2015	12	5	13	12	22	39	0	0	0	0	0	0	0	35.94	0	0	13.6
2015	12	5	13	22	22	39	0	0	0	0	0	0	0	35.92	0	0	13.6
2015	12	5	13	32	22	40	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	5	13	42	22	40	0	0	0	0	0	0	0	35.92	0	0	13.6
2015	12	5	13	52	22	39	0	0	0	0	0	0	0	35.89	0	0	13.6
2015	12	5	14	2	22	40	0	0	0	0	0	0	0	35.82	0	0	13.6
2015	12	5	14	12	22	39	0	0	0	0	0	0	0	35.78	0	0	13.6
2015	12	5	14	22	22	40	0	0	0	0	0	0	0	35.76	0	0	13.6
2015	12	5	14	32	22	39	0	0	0	0	0	0	0	35.65	0	0	13.6
2015	12	5	14	42	22	40	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	5	14	52	22	39	0	0	0	0	0	0	0	35.58	0	0	13.6
2015	12	5	15	2	22	39	0	0	0	0	0	0	0	35.46	0	0	13.6
2015	12	5	15	12	22	39	0	0	0	0	0	0	0	35.42	0	0	13.6
2015	12	5	15	22	22	40	0	0	0	0	0	0	0	35.4	0	0	13.6
2015	12	5	15	32	22	39	0	0	0	0	0	0	0	35.38	0	0	13.6
2015	12	5	15	42	22	40	0	0	0	0	0	0	0	35.37	0	0	13.2
2015	12	5	15	52	22	40	0	0	0	0	0	0	0	35.37	0	0	12.4
2015	12	5	16	2	22	40	0	0	0	0	0	0	0	35.35	0	0	12.4
2015	12	5	16	12	22	39	0	0	0	0	0	0	0	35.33	0	0	12.2
2015	12	5	16	22	22	39	0	0	0	0	0	0	0	35.33	0	0	12.2
2015	12	5	16	32	22	39	0	0	0	0	0	0	0	35.31	0	0	12.2
2015	12	5	16	42	22	39	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	5	16	52	22	39	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	5	17	2	22	40	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	5	17	12	22	39	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	17	22	22	39	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	5	17	32	22	39	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	17	42	22	39	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	17	52	22	40	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	18	2	22	39	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	18	12	22	39	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	18	22	22	40	0	0	0	0	0	0	0	35.28	0	0	12.2
2015	12	5	18	32	22	39	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	5	18	42	22	39	0	0	0	0	0	0	0	35.29	0	0	12.2
2015	12	5	18	52	22	40	0	0	0	0	0	0	0	35.29	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	19	2	22	40	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	5	19	12	22	39	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	5	19	22	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	5	19	32	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	5	19	42	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	19	52	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	20	2	22	40	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	20	12	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	5	20	22	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	5	20	32	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	20	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	20	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	21	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	21	12	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	21	22	22	38	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	21	32	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	5	21	42	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	5	21	52	22	40	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	22	2	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	5	22	12	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	22	22	22	40	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	22	32	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	22	42	22	40	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	22	52	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	5	23	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	23	12	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	23	22	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	5	23	32	22	40	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	5	23	42	22	40	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	5	23	52	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	0	2	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	0	12	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	0	22	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	0	32	22	39	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	6	0	42	22	39	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	6	0	52	22	39	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	6	1	2	22	40	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	6	1	12	22	39	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	6	1	22	22	39	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	6	1	32	22	39	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	6	1	42	22	39	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	6	1	52	22	39	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	6	2	2	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	6	2	12	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	6	2	22	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	6	2	32	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	2	42	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	6	2	52	22	39	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	6	3	2	22	39	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	6	3	12	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	6	3	22	22	40	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	6	3	32	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	6	3	42	22	39	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	6	3	52	22	39	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	6	4	2	22	39	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	6	4	12	22	39	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	6	4	22	22	39	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	6	4	32	22	39	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	6	4	42	22	39	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	6	4	52	22	40	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	6	5	2	22	39	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	6	5	12	22	39	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	6	5	22	22	39	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	6	5	32	22	39	0	0	0	0	0	0	0	35.04	0	0	11.8
2015	12	6	5	42	22	39	0	0	0	0	0	0	0	35.04	0	0	11.8
2015	12	6	5	52	22	39	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	6	6	2	22	39	0	0	0	0	0	0	0	35.01	0	0	11.8
2015	12	6	6	12	22	39	0	0	0	0	0	0	0	35.01	0	0	11.8
2015	12	6	6	22	22	40	0	0	0	0	0	0	0	35.01	0	0	11.8
2015	12	6	6	32	22	40	0	0	0	0	0	0	0	34.99	0	0	11.6
2015	12	6	6	42	22	40	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	6	6	52	22	40	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	6	7	2	22	39	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	6	7	12	22	40	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	6	7	22	22	39	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	6	7	32	22	39	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	6	7	42	22	40	0	0	0	0	0	0	0	35.01	0	0	12.2
2015	12	6	7	52	22	39	0	0	0	0	0	0	0	35.02	0	0	12.6
2015	12	6	8	2	22	40	0	0	0	0	0	0	0	35.06	0	0	13
2015	12	6	8	12	22	39	0	0	0	0	0	0	0	35.1	0	0	13.2
2015	12	6	8	22	22	39	0	0	0	0	0	0	0	35.13	0	0	13.4
2015	12	6	8	32	22	39	0	0	0	0	0	0	0	35.26	0	0	13.6
2015	12	6	8	42	22	40	0	0	0	0	0	0	0	35.33	0	0	14
2015	12	6	8	52	22	40	0	0	0	0	0	0	0	35.42	0	0	14
2015	12	6	9	2	22	39	0	0	0	0	0	0	0	35.46	0	0	14
2015	12	6	9	12	22	40	0	0	0	0	0	0	0	35.4	0	0	14
2015	12	6	9	22	22	39	0	0	0	0	0	0	0	35.56	0	0	14
2015	12	6	9	32	22	39	0	0	0	0	0	0	0	35.69	0	0	14
2015	12	6	9	42	22	39	0	0	0	0	0	0	0	35.73	0	0	14
2015	12	6	9	52	22	40	0	0	0	0	0	0	0	35.76	0	0	14
2015	12	6	10	2	22	40	0	0	0	0	0	0	0	36	0	0	13.8
2015	12	6	10	12	22	40	0	0	0	0	0	0	0	35.74	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	10	22	22	40	0	0	0	0	0	0	0	35.56	0	0	13
2015	12	6	10	32	22	39	0	0	0	0	0	0	0	35.49	0	0	13
2015	12	6	10	42	22	39	0	0	0	0	0	0	0	35.56	0	0	13.8
2015	12	6	10	52	22	39	0	0	0	0	0	0	0	35.65	0	0	13.8
2015	12	6	11	2	22	40	0	0	0	0	0	0	0	35.74	0	0	13.8
2015	12	6	11	12	22	39	0	0	0	0	0	0	0	35.83	0	0	13.8
2015	12	6	11	22	22	39	0	0	0	0	0	0	0	36	0	0	13.8
2015	12	6	11	32	22	40	0	0	0	0	0	0	0	35.78	0	0	13.8
2015	12	6	11	42	22	39	0	0	0	0	0	0	0	35.73	0	0	13.8
2015	12	6	11	52	22	39	0	0	0	0	0	0	0	35.78	0	0	13.8
2015	12	6	12	2	22	39	0	0	0	0	0	0	0	36.07	0	0	13.8
2015	12	6	12	12	22	39	0	0	0	0	0	0	0	36.16	0	0	13.8
2015	12	6	12	22	22	39	0	0	0	0	0	0	0	35.8	0	0	13.8
2015	12	6	12	32	22	40	0	0	0	0	0	0	0	35.83	0	0	13.8
2015	12	6	12	42	22	39	0	0	0	0	0	0	0	35.89	0	0	13.8
2015	12	6	12	52	22	39	0	0	0	0	0	0	0	36.05	0	0	13.8
2015	12	6	13	2	22	39	0	0	0	0	0	0	0	36.16	0	0	13.8
2015	12	6	13	12	22	39	0	0	0	0	0	0	0	36.16	0	0	13.8
2015	12	6	13	22	22	39	0	0	0	0	0	0	0	36.14	0	0	13.8
2015	12	6	13	32	22	40	0	0	0	0	0	0	0	36.1	0	0	13.8
2015	12	6	13	42	22	39	0	0	0	0	0	0	0	36.07	0	0	13.8
2015	12	6	13	52	22	39	0	0	0	0	0	0	0	36.07	0	0	13.6
2015	12	6	14	2	22	39	0	0	0	0	0	0	0	36	0	0	13.6
2015	12	6	14	12	22	40	0	0	0	0	0	0	0	35.98	0	0	13.6
2015	12	6	14	22	22	39	0	0	0	0	0	0	0	35.94	0	0	13.6
2015	12	6	14	32	22	40	0	0	0	0	0	0	0	35.89	0	0	13.6
2015	12	6	14	42	22	39	0	0	0	0	0	0	0	35.83	0	0	13.6
2015	12	6	14	52	22	39	0	0	0	0	0	0	0	35.73	0	0	13.6
2015	12	6	15	2	22	40	0	0	0	0	0	0	0	35.58	0	0	13.6
2015	12	6	15	12	22	39	0	0	0	0	0	0	0	35.53	0	0	13.6
2015	12	6	15	22	22	40	0	0	0	0	0	0	0	35.49	0	0	12.6
2015	12	6	15	32	22	39	0	0	0	0	0	0	0	35.47	0	0	12.4
2015	12	6	15	42	22	39	0	0	0	0	0	0	0	35.47	0	0	13.4
2015	12	6	15	52	22	39	0	0	0	0	0	0	0	35.46	0	0	12.4
2015	12	6	16	2	22	39	0	0	0	0	0	0	0	35.46	0	0	12.2
2015	12	6	16	12	22	40	0	0	0	0	0	0	0	35.44	0	0	12.2
2015	12	6	16	22	22	40	0	0	0	0	0	0	0	35.4	0	0	12.2
2015	12	6	16	32	22	39	0	0	0	0	0	0	0	35.4	0	0	12.2
2015	12	6	16	42	22	40	0	0	0	0	0	0	0	35.38	0	0	12.2
2015	12	6	16	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12.2
2015	12	6	17	2	22	39	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	17	12	22	39	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	17	22	22	40	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	17	32	22	40	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	17	42	22	39	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	17	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	18	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12.2
2015	12	6	18	12	22	40	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	18	22	22	39	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	18	32	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	18	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12.2
2015	12	6	18	52	22	39	0	0	0	0	0	0	0	35.37	0	0	12.2
2015	12	6	19	2	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	19	12	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	19	22	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	19	32	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	19	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	19	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	20	2	22	38	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	20	12	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	20	22	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	20	32	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	20	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	20	52	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	2	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	12	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	22	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	32	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	6	21	52	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	22	2	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	22	12	22	40	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	22	22	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	6	22	32	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	22	42	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	22	52	22	39	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	23	2	22	40	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	6	23	12	22	40	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	23	22	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	23	32	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	23	42	22	40	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	6	23	52	22	39	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	7	0	2	22	39	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	7	0	12	22	40	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	7	0	22	22	39	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	7	0	32	22	39	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	7	0	42	22	39	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	7	0	52	22	39	0	0	0	0	0	0	0	35.28	0	0	12
2015	12	7	1	2	22	39	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	7	1	12	22	40	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	7	1	22	22	39	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	7	1	32	22	39	0	0	0	0	0	0	0	35.26	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	1	42	22	39	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	7	1	52	22	40	0	0	0	0	0	0	0	35.24	0	0	12
2015	12	7	2	2	22	40	0	0	0	0	0	0	0	35.24	0	0	11.8
2015	12	7	2	12	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	2	22	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	2	32	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	2	42	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	2	52	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	3	2	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	3	12	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	3	22	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	3	32	22	40	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	3	42	22	39	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	7	3	52	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	2	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	12	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	22	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	32	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	42	22	40	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	4	52	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	7	5	2	22	39	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	7	5	12	22	39	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	7	5	22	22	39	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	7	5	32	22	40	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	7	5	42	22	39	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	7	5	52	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	2	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	12	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	22	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	32	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	42	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	6	52	22	40	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	7	2	22	40	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	7	12	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	7	22	22	39	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	7	7	32	22	39	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	7	7	42	22	39	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	7	7	52	22	39	0	0	0	0	0	0	0	35.22	0	0	12.6
2015	12	7	8	2	22	40	0	0	0	0	0	0	0	35.28	0	0	12.8
2015	12	7	8	12	22	39	0	0	0	0	0	0	0	35.37	0	0	13.2
2015	12	7	8	22	22	39	0	0	0	0	0	0	0	35.46	0	0	13.4
2015	12	7	8	32	22	39	0	0	0	0	0	0	0	35.53	0	0	13.4
2015	12	7	8	42	22	40	0	0	0	0	0	0	0	35.53	0	0	13.4
2015	12	7	8	52	22	40	0	0	0	0	0	0	0	35.56	0	0	13.2
2015	12	7	9	2	22	39	0	0	0	0	0	0	0	35.67	0	0	13.4
2015	12	7	9	12	22	40	0	0	0	0	0	0	0	35.76	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	9	22	22	40	0	0	0	0	0	0	0	35.83	0	0	14
2015	12	7	9	32	22	39	0	0	0	0	0	0	0	35.92	0	0	13.8
2015	12	7	9	42	22	39	0	0	0	0	0	0	0	36.09	0	0	13.8
2015	12	7	9	52	22	39	0	0	0	0	0	0	0	36.09	0	0	13.8
2015	12	7	10	2	22	40	0	0	0	0	0	0	0	36.05	0	0	13.8
2015	12	7	10	12	22	39	0	0	0	0	0	0	0	36.03	0	0	13.8
2015	12	7	10	22	22	39	0	0	0	0	0	0	0	36.01	0	0	13.8
2015	12	7	10	32	22	39	0	0	0	0	0	0	0	36.21	0	0	13.8
2015	12	7	10	42	22	39	0	0	0	0	0	0	0	36.14	0	0	13.8
2015	12	7	10	52	22	40	0	0	0	0	0	0	0	36.18	0	0	13.8
2015	12	7	11	2	22	39	0	0	0	0	0	0	0	36.43	0	0	13.8
2015	12	7	11	12	22	39	0	0	0	0	0	0	0	36.41	0	0	13.8
2015	12	7	11	22	22	39	0	0	0	0	0	0	0	36.28	0	0	13.8
2015	12	7	11	32	22	40	0	0	0	0	0	0	0	36.23	0	0	13.8
2015	12	7	11	42	22	39	0	0	0	0	0	0	0	36.28	0	0	13.6
2015	12	7	11	52	22	39	0	0	0	0	0	0	0	36.16	0	0	13.6
2015	12	7	12	2	22	40	0	0	0	0	0	0	0	36.07	0	0	13.6
2015	12	7	12	12	22	39	0	0	0	0	0	0	0	36.41	0	0	13.6
2015	12	7	12	22	22	39	0	0	0	0	0	0	0	36.45	0	0	13.6
2015	12	7	12	32	22	39	0	0	0	0	0	0	0	36.57	0	0	13.6
2015	12	7	12	42	22	39	0	0	0	0	0	0	0	36.36	0	0	13.6
2015	12	7	12	52	22	39	0	0	0	0	0	0	0	36.25	0	0	13.6
2015	12	7	13	2	22	39	0	0	0	0	0	0	0	36.37	0	0	13.6
2015	12	7	13	12	22	39	0	0	0	0	0	0	0	36.48	0	0	13.6
2015	12	7	13	22	22	39	0	0	0	0	0	0	0	36.43	0	0	13.6
2015	12	7	13	32	22	39	0	0	0	0	0	0	0	36.48	0	0	13.6
2015	12	7	13	42	22	39	0	0	0	0	0	0	0	36.34	0	0	13.6
2015	12	7	13	52	22	39	0	0	0	0	0	0	0	36.27	0	0	13.6
2015	12	7	14	2	22	39	0	0	0	0	0	0	0	36.19	0	0	13.6
2015	12	7	14	12	22	40	0	0	0	0	0	0	0	36.21	0	0	13.6
2015	12	7	14	22	22	39	0	0	0	0	0	0	0	36.16	0	0	13.6
2015	12	7	14	32	22	39	0	0	0	0	0	0	0	36.07	0	0	13.6
2015	12	7	14	42	22	39	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	7	14	52	22	40	0	0	0	0	0	0	0	36	0	0	13.6
2015	12	7	15	2	22	39	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	7	15	12	22	39	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	7	15	22	22	39	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	7	15	32	22	40	0	0	0	0	0	0	0	35.92	0	0	13.2
2015	12	7	15	42	22	39	0	0	0	0	0	0	0	35.91	0	0	12.6
2015	12	7	15	52	22	39	0	0	0	0	0	0	0	35.89	0	0	12.4
2015	12	7	16	2	22	39	0	0	0	0	0	0	0	35.85	0	0	12.2
2015	12	7	16	12	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	16	22	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	16	32	22	40	0	0	0	0	0	0	0	35.82	0	0	12.2
2015	12	7	16	42	22	39	0	0	0	0	0	0	0	35.82	0	0	12.2
2015	12	7	16	52	22	40	0	0	0	0	0	0	0	35.82	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	17	2	22	39	0	0	0	0	0	0	0	35.82	0	0	12.2
2015	12	7	17	12	22	40	0	0	0	0	0	0	0	35.82	0	0	12.2
2015	12	7	17	22	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	17	32	22	40	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	17	42	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	17	52	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	7	18	2	22	39	0	0	0	0	0	0	0	35.85	0	0	12.2
2015	12	7	18	12	22	39	0	0	0	0	0	0	0	35.85	0	0	12.2
2015	12	7	18	22	22	39	0	0	0	0	0	0	0	35.87	0	0	12.2
2015	12	7	18	32	22	39	0	0	0	0	0	0	0	35.89	0	0	12.2
2015	12	7	18	42	22	39	0	0	0	0	0	0	0	35.89	0	0	12.2
2015	12	7	18	52	22	39	0	0	0	0	0	0	0	35.91	0	0	12.2
2015	12	7	19	2	22	39	0	0	0	0	0	0	0	35.91	0	0	12.2
2015	12	7	19	12	22	39	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	7	19	22	22	40	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	7	19	32	22	39	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	7	19	42	22	39	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	7	19	52	22	39	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	7	20	2	22	39	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	7	20	12	22	39	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	7	20	22	22	39	0	0	0	0	0	0	0	36	0	0	12
2015	12	7	20	32	22	40	0	0	0	0	0	0	0	36	0	0	12
2015	12	7	20	42	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	7	20	52	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	7	21	2	22	40	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	7	21	12	22	39	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	7	21	22	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	21	32	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	21	42	22	39	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	7	21	52	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	22	2	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	22	12	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	22	22	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	22	32	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	22	42	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	22	52	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	23	2	22	40	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	23	12	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	23	22	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	7	23	32	22	40	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	23	42	22	40	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	7	23	52	22	40	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	8	0	2	22	39	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	8	0	12	22	40	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	8	0	22	22	40	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	8	0	32	22	39	0	0	0	0	0	0	0	36.01	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	0	42	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	8	0	52	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	8	1	2	22	39	0	0	0	0	0	0	0	36	0	0	12
2015	12	8	1	12	22	40	0	0	0	0	0	0	0	36	0	0	12
2015	12	8	1	22	22	39	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	8	1	32	22	39	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	8	1	42	22	39	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	8	1	52	22	39	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	8	2	2	22	39	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	8	2	12	22	39	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	8	2	22	22	40	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	8	2	32	22	39	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	8	2	42	22	38	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	8	2	52	22	40	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	8	3	2	22	40	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	8	3	12	22	39	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	8	3	22	22	39	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	8	3	32	22	39	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	8	3	42	22	39	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	8	3	52	22	39	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	8	4	2	22	39	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	8	4	12	22	39	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	8	4	22	22	40	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	8	4	32	22	39	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	8	4	42	22	39	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	8	4	52	22	39	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	8	5	2	22	40	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	8	5	12	22	39	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	8	5	22	22	40	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	8	5	32	22	39	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	8	5	42	22	40	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	8	5	52	22	40	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	8	6	2	22	39	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	8	6	12	22	39	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	8	6	22	22	39	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	8	6	32	22	39	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	8	6	42	22	39	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	8	6	52	22	39	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	8	7	2	22	40	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	8	7	12	22	39	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	8	7	22	22	39	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	8	7	32	22	40	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	8	7	42	22	39	0	0	0	0	0	0	0	35.76	0	0	12.2
2015	12	8	7	52	22	39	0	0	0	0	0	0	0	35.82	0	0	12.8
2015	12	8	8	2	22	40	0	0	0	0	0	0	0	35.83	0	0	12.8
2015	12	8	8	12	22	40	0	0	0	0	0	0	0	35.87	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	8	22	22	40	0	0	0	0	0	0	0	35.98	0	0	13.2
2015	12	8	8	32	22	39	0	0	0	0	0	0	0	36.03	0	0	13
2015	12	8	8	42	22	39	0	0	0	0	0	0	0	36.09	0	0	13.2
2015	12	8	8	52	22	39	0	0	0	0	0	0	0	36.09	0	0	13
2015	12	8	9	2	22	39	0	0	0	0	0	0	0	36.18	0	0	13.2
2015	12	8	9	12	22	39	0	0	0	0	0	0	0	36.27	0	0	13.4
2015	12	8	9	22	22	39	0	0	0	0	0	0	0	36.28	0	0	13.4
2015	12	8	9	32	22	39	0	0	0	0	0	0	0	36.3	0	0	13.2
2015	12	8	9	42	22	39	0	0	0	0	0	0	0	36.32	0	0	13.4
2015	12	8	9	52	22	39	0	0	0	0	0	0	0	36.41	0	0	13.8
2015	12	8	10	2	22	40	0	0	0	0	0	0	0	36.45	0	0	13.8
2015	12	8	10	12	22	40	0	0	0	0	0	0	0	36.48	0	0	13.8
2015	12	8	10	22	22	40	0	0	0	0	0	0	0	36.54	0	0	13.8
2015	12	8	10	32	22	40	0	0	0	0	0	0	0	36.54	0	0	13.8
2015	12	8	10	42	22	39	0	0	0	0	0	0	0	36.7	0	0	13.8
2015	12	8	10	52	22	39	0	0	0	0	0	0	0	36.81	0	0	13.8
2015	12	8	11	2	22	39	0	0	0	0	0	0	0	36.88	0	0	13.8
2015	12	8	11	12	22	39	0	0	0	0	0	0	0	36.9	0	0	13.8
2015	12	8	11	22	22	39	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	8	11	32	22	40	0	0	0	0	0	0	0	37.04	0	0	13.6
2015	12	8	11	42	22	39	0	0	0	0	0	0	0	36.82	0	0	13.6
2015	12	8	11	52	22	39	0	0	0	0	0	0	0	36.55	0	0	13.6
2015	12	8	12	2	22	39	0	0	0	0	0	0	0	36.5	0	0	13.6
2015	12	8	12	12	22	39	0	0	0	0	0	0	0	36.45	0	0	13.6
2015	12	8	12	22	22	39	0	0	0	0	0	0	0	36.61	0	0	13.6
2015	12	8	12	32	22	39	0	0	0	0	0	0	0	36.7	0	0	13.6
2015	12	8	12	42	22	39	0	0	0	0	0	0	0	36.7	0	0	13.6
2015	12	8	12	52	22	40	0	0	0	0	0	0	0	36.68	0	0	13.6
2015	12	8	13	2	22	39	0	0	0	0	0	0	0	36.66	0	0	13.6
2015	12	8	13	12	22	39	0	0	0	0	0	0	0	36.63	0	0	13.6
2015	12	8	13	22	22	40	0	0	0	0	0	0	0	36.61	0	0	13.6
2015	12	8	13	32	22	39	0	0	0	0	0	0	0	36.73	0	0	13.6
2015	12	8	13	42	22	39	0	0	0	0	0	0	0	36.7	0	0	13.6
2015	12	8	13	52	22	39	0	0	0	0	0	0	0	36.61	0	0	13.6
2015	12	8	14	2	22	40	0	0	0	0	0	0	0	36.54	0	0	13.6
2015	12	8	14	12	22	39	0	0	0	0	0	0	0	36.5	0	0	13.6
2015	12	8	14	22	22	39	0	0	0	0	0	0	0	36.43	0	0	13.6
2015	12	8	14	32	22	39	0	0	0	0	0	0	0	36.39	0	0	13.4
2015	12	8	14	42	22	39	0	0	0	0	0	0	0	36.36	0	0	13.4
2015	12	8	14	52	22	39	0	0	0	0	0	0	0	36.3	0	0	13
2015	12	8	15	2	22	39	0	0	0	0	0	0	0	36.3	0	0	13
2015	12	8	15	12	22	39	0	0	0	0	0	0	0	36.28	0	0	12.6
2015	12	8	15	22	22	39	0	0	0	0	0	0	0	36.27	0	0	12.4
2015	12	8	15	32	22	40	0	0	0	0	0	0	0	36.25	0	0	12.4
2015	12	8	15	42	22	39	0	0	0	0	0	0	0	36.23	0	0	12.4
2015	12	8	15	52	22	39	0	0	0	0	0	0	0	36.21	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	16	2	22	39	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	8	16	12	22	39	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	8	16	22	22	39	0	0	0	0	0	0	0	36.18	0	0	12.2
2015	12	8	16	32	22	39	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	8	16	42	22	39	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	8	16	52	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	8	17	2	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	8	17	12	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	8	17	22	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	8	17	32	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	8	17	42	22	39	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	8	17	52	22	39	0	0	0	0	0	0	0	36.18	0	0	12.2
2015	12	8	18	2	22	39	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	8	18	12	22	39	0	0	0	0	0	0	0	36.18	0	0	12.2
2015	12	8	18	22	22	39	0	0	0	0	0	0	0	36.18	0	0	12.2
2015	12	8	18	32	22	40	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	8	18	42	22	38	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	8	18	52	22	39	0	0	0	0	0	0	0	36.19	0	0	12.2
2015	12	8	19	2	22	39	0	0	0	0	0	0	0	36.21	0	0	12.2
2015	12	8	19	12	22	40	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	8	19	22	22	39	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	8	19	32	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	8	19	42	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	8	19	52	22	40	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	8	20	2	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	8	20	12	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	8	20	22	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	8	20	32	22	40	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	8	20	42	22	40	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	8	20	52	22	38	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	8	21	2	22	39	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	21	12	22	39	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	8	21	22	22	39	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	21	32	22	39	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	21	42	22	40	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	21	52	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	22	2	22	38	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	22	12	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	22	22	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	22	32	22	39	0	0	0	0	0	0	0	36.36	0	0	12
2015	12	8	22	42	22	40	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	22	52	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	23	2	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	23	12	22	40	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	23	22	22	39	0	0	0	0	0	0	0	36.34	0	0	12
2015	12	8	23	32	22	39	0	0	0	0	0	0	0	36.32	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	23	42	22	39	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	8	23	52	22	39	0	0	0	0	0	0	0	36.32	0	0	12
2015	12	9	0	2	22	40	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	9	0	12	22	39	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	9	0	22	22	40	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	9	0	32	22	39	0	0	0	0	0	0	0	36.3	0	0	12
2015	12	9	0	42	22	40	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	9	0	52	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	9	1	2	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	9	1	12	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	9	1	22	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	9	1	32	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	9	1	42	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	9	1	52	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	9	2	2	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	9	2	12	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	9	2	22	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	9	2	32	22	39	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	9	2	42	22	39	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	9	2	52	22	39	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	9	3	2	22	39	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	9	3	12	22	39	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	3	22	22	39	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	3	32	22	39	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	3	42	22	39	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	3	52	22	39	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	4	2	22	40	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	4	12	22	40	0	0	0	0	0	0	0	36.23	0	0	11.8
2015	12	9	4	22	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	4	32	22	40	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	4	42	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	4	52	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	5	2	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	9	5	12	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	5	22	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	5	32	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	5	42	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	5	52	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	9	6	2	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	9	6	12	22	40	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	9	6	22	22	40	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	9	6	32	22	39	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	9	6	42	22	40	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	9	6	52	22	39	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	9	7	2	22	40	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	9	7	12	22	39	0	0	0	0	0	0	0	36.18	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	7	22	22	38	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	9	7	32	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	9	7	42	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	9	7	52	22	40	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	8	2	22	39	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	9	8	12	22	40	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	9	8	22	22	39	0	0	0	0	0	0	0	36.25	0	0	12.2
2015	12	9	8	32	22	39	0	0	0	0	0	0	0	36.36	0	0	12.6
2015	12	9	8	42	22	39	0	0	0	0	0	0	0	36.43	0	0	13
2015	12	9	8	52	22	39	0	0	0	0	0	0	0	36.52	0	0	13.2
2015	12	9	9	2	22	39	0	0	0	0	0	0	0	36.54	0	0	13
2015	12	9	9	12	22	39	0	0	0	0	0	0	0	36.55	0	0	13
2015	12	9	9	22	22	39	0	0	0	0	0	0	0	36.64	0	0	13.4
2015	12	9	9	32	22	39	0	0	0	0	0	0	0	36.81	0	0	13.8
2015	12	9	9	42	22	39	0	0	0	0	0	0	0	36.9	0	0	14
2015	12	9	9	52	22	39	0	0	0	0	0	0	0	36.86	0	0	14
2015	12	9	10	2	22	39	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	9	10	12	22	39	0	0	0	0	0	0	0	37.02	0	0	13.8
2015	12	9	10	22	22	39	0	0	0	0	0	0	0	37.08	0	0	13.8
2015	12	9	10	32	22	39	0	0	0	0	0	0	0	37.08	0	0	13.8
2015	12	9	10	42	22	39	0	0	0	0	0	0	0	37.09	0	0	13.8
2015	12	9	10	52	22	39	0	0	0	0	0	0	0	37.11	0	0	13.8
2015	12	9	11	2	22	39	0	0	0	0	0	0	0	37.27	0	0	13.8
2015	12	9	11	12	22	39	0	0	0	0	0	0	0	37.47	0	0	13.8
2015	12	9	11	22	22	39	0	0	0	0	0	0	0	37.56	0	0	13.8
2015	12	9	11	32	22	40	0	0	0	0	0	0	0	37.49	0	0	13.8
2015	12	9	11	42	22	39	0	0	0	0	0	0	0	37.56	0	0	13.8
2015	12	9	11	52	22	39	0	0	0	0	0	0	0	37.45	0	0	13.6
2015	12	9	12	2	22	39	0	0	0	0	0	0	0	37.58	0	0	13.6
2015	12	9	12	12	22	39	0	0	0	0	0	0	0	37.53	0	0	13.6
2015	12	9	12	22	22	39	0	0	0	0	0	0	0	37.51	0	0	13.6
2015	12	9	12	32	22	39	0	0	0	0	0	0	0	37.47	0	0	13.6
2015	12	9	12	42	22	39	0	0	0	0	0	0	0	37.71	0	0	13.6
2015	12	9	12	52	22	39	0	0	0	0	0	0	0	37.83	0	0	13.6
2015	12	9	13	2	22	39	0	0	0	0	0	0	0	37.81	0	0	13.6
2015	12	9	13	12	22	38	0	0	0	0	0	0	0	37.78	0	0	13.6
2015	12	9	13	22	22	39	0	0	0	0	0	0	0	37.8	0	0	13.6
2015	12	9	13	32	22	39	0	0	0	0	0	0	0	37.78	0	0	13.6
2015	12	9	13	42	22	40	0	0	0	0	0	0	0	37.74	0	0	13.4
2015	12	9	13	52	22	39	0	0	0	0	0	0	0	37.69	0	0	13.4
2015	12	9	14	2	22	39	0	0	0	0	0	0	0	37.65	0	0	13.4
2015	12	9	14	12	22	39	0	0	0	0	0	0	0	37.62	0	0	13.4
2015	12	9	14	22	22	39	0	0	0	0	0	0	0	37.54	0	0	13.4
2015	12	9	14	32	22	40	0	0	0	0	0	0	0	37.45	0	0	13.4
2015	12	9	14	42	22	39	0	0	0	0	0	0	0	37.4	0	0	13.4
2015	12	9	14	52	22	39	0	0	0	0	0	0	0	37.29	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	15	2	22	39	0	0	0	0	0	0	0	37.17	0	0	13.4
2015	12	9	15	12	22	39	0	0	0	0	0	0	0	37.08	0	0	13.4
2015	12	9	15	22	22	39	0	0	0	0	0	0	0	37.02	0	0	13.4
2015	12	9	15	32	22	38	0	0	0	0	0	0	0	37	0	0	13
2015	12	9	15	42	22	39	0	0	0	0	0	0	0	36.97	0	0	13.2
2015	12	9	15	52	22	38	0	0	0	0	0	0	0	36.93	0	0	12.4
2015	12	9	16	2	22	39	0	0	0	0	0	0	0	36.93	0	0	12.4
2015	12	9	16	12	22	39	0	0	0	0	0	0	0	36.91	0	0	12.2
2015	12	9	16	22	22	39	0	0	0	0	0	0	0	36.9	0	0	12.2
2015	12	9	16	32	22	39	0	0	0	0	0	0	0	36.86	0	0	12.2
2015	12	9	16	42	22	39	0	0	0	0	0	0	0	36.84	0	0	12.2
2015	12	9	16	52	22	39	0	0	0	0	0	0	0	36.84	0	0	12.2
2015	12	9	17	2	22	39	0	0	0	0	0	0	0	36.86	0	0	12.2
2015	12	9	17	12	22	39	0	0	0	0	0	0	0	36.84	0	0	12.2
2015	12	9	17	22	22	40	0	0	0	0	0	0	0	36.86	0	0	12.2
2015	12	9	17	32	22	39	0	0	0	0	0	0	0	36.88	0	0	12.2
2015	12	9	17	42	22	40	0	0	0	0	0	0	0	36.88	0	0	12.2
2015	12	9	17	52	22	39	0	0	0	0	0	0	0	36.9	0	0	12.2
2015	12	9	18	2	22	39	0	0	0	0	0	0	0	36.9	0	0	12.2
2015	12	9	18	12	22	39	0	0	0	0	0	0	0	36.91	0	0	12.2
2015	12	9	18	22	22	39	0	0	0	0	0	0	0	36.91	0	0	12.2
2015	12	9	18	32	22	39	0	0	0	0	0	0	0	36.93	0	0	12.2
2015	12	9	18	42	22	40	0	0	0	0	0	0	0	36.93	0	0	12.2
2015	12	9	18	52	22	39	0	0	0	0	0	0	0	36.95	0	0	12.2
2015	12	9	19	2	22	39	0	0	0	0	0	0	0	36.97	0	0	12.2
2015	12	9	19	12	22	39	0	0	0	0	0	0	0	36.97	0	0	12.2
2015	12	9	19	22	22	39	0	0	0	0	0	0	0	36.99	0	0	12.2
2015	12	9	19	32	22	39	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	9	19	42	22	39	0	0	0	0	0	0	0	37	0	0	12
2015	12	9	19	52	22	40	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	9	20	2	22	39	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	9	20	12	22	39	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	9	20	22	22	40	0	0	0	0	0	0	0	37.06	0	0	12
2015	12	9	20	32	22	39	0	0	0	0	0	0	0	37.06	0	0	12
2015	12	9	20	42	22	39	0	0	0	0	0	0	0	37.08	0	0	12
2015	12	9	20	52	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	9	21	2	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	9	21	12	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	9	21	22	22	40	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	9	21	32	22	39	0	0	0	0	0	0	0	37.13	0	0	12
2015	12	9	21	42	22	39	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	9	21	52	22	40	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	9	22	2	22	39	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	9	22	12	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	9	22	22	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	9	22	32	22	40	0	0	0	0	0	0	0	37.18	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	22	42	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	22	52	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	2	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	12	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	22	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	32	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	42	22	39	0	0	0	0	0	0	0	37.18	0	0	12
2015	12	9	23	52	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	10	0	2	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	10	0	12	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	10	0	22	22	39	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	10	0	32	22	38	0	0	0	0	0	0	0	37.17	0	0	12
2015	12	10	0	42	22	40	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	10	0	52	22	39	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	10	1	2	22	39	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	10	1	12	22	39	0	0	0	0	0	0	0	37.15	0	0	12
2015	12	10	1	22	22	39	0	0	0	0	0	0	0	37.13	0	0	12
2015	12	10	1	32	22	39	0	0	0	0	0	0	0	37.13	0	0	12
2015	12	10	1	42	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	10	1	52	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	10	2	2	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	10	2	12	22	40	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	10	2	22	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	10	2	32	22	40	0	0	0	0	0	0	0	37.09	0	0	11.8
2015	12	10	2	42	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	10	2	52	22	39	0	0	0	0	0	0	0	37.08	0	0	12
2015	12	10	3	2	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	10	3	12	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	3	22	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	3	32	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	3	42	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	3	52	22	40	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	4	2	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	4	12	22	39	0	0	0	0	0	0	0	37.06	0	0	11.8
2015	12	10	4	22	22	39	0	0	0	0	0	0	0	37.08	0	0	11.8
2015	12	10	4	32	22	39	0	0	0	0	0	0	0	37.06	0	0	11.8
2015	12	10	4	42	22	39	0	0	0	0	0	0	0	37.06	0	0	11.8
2015	12	10	4	52	22	39	0	0	0	0	0	0	0	37.06	0	0	11.8
2015	12	10	5	2	22	39	0	0	0	0	0	0	0	37.02	0	0	11.8
2015	12	10	5	12	22	39	0	0	0	0	0	0	0	37.02	0	0	11.8
2015	12	10	5	22	22	40	0	0	0	0	0	0	0	37.02	0	0	11.8
2015	12	10	5	32	22	40	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	10	5	42	22	39	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	10	5	52	22	39	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	10	6	2	22	40	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	10	6	12	22	39	0	0	0	0	0	0	0	36.99	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	6	22	22	39	0	0	0	0	0	0	0	36.97	0	0	11.8
2015	12	10	6	32	22	39	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	10	6	42	22	39	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	10	6	52	22	40	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	10	7	2	22	38	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	10	7	12	22	39	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	10	7	22	22	39	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	10	7	32	22	39	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	10	7	42	22	39	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	10	7	52	22	39	0	0	0	0	0	0	0	37.06	0	0	12.2
2015	12	10	8	2	22	39	0	0	0	0	0	0	0	37.08	0	0	12.2
2015	12	10	8	12	22	39	0	0	0	0	0	0	0	37.09	0	0	12.2
2015	12	10	8	22	22	40	0	0	0	0	0	0	0	37.13	0	0	12.4
2015	12	10	8	32	22	39	0	0	0	0	0	0	0	37.17	0	0	12.4
2015	12	10	8	42	22	39	0	0	0	0	0	0	0	37.26	0	0	12.6
2015	12	10	8	52	22	40	0	0	0	0	0	0	0	37.35	0	0	12.8
2015	12	10	9	2	22	39	0	0	0	0	0	0	0	37.26	0	0	12.6
2015	12	10	9	12	22	40	0	0	0	0	0	0	0	37.22	0	0	12.4
2015	12	10	9	22	22	39	0	0	0	0	0	0	0	37.22	0	0	12.4
2015	12	10	9	32	22	39	0	0	0	0	0	0	0	37.29	0	0	12.6
2015	12	10	9	42	22	39	0	0	0	0	0	0	0	37.47	0	0	13
2015	12	10	9	52	22	40	0	0	0	0	0	0	0	37.62	0	0	13
2015	12	10	10	2	22	39	0	0	0	0	0	0	0	37.53	0	0	12.8
2015	12	10	10	12	22	39	0	0	0	0	0	0	0	37.47	0	0	12.6
2015	12	10	10	22	22	39	0	0	0	0	0	0	0	37.4	0	0	12.6
2015	12	10	10	32	22	39	0	0	0	0	0	0	0	37.38	0	0	12.4
2015	12	10	10	42	22	39	0	0	0	0	0	0	0	37.4	0	0	12.4
2015	12	10	10	52	22	39	0	0	0	0	0	0	0	37.44	0	0	12.4
2015	12	10	11	2	22	39	0	0	0	0	0	0	0	37.47	0	0	12.6
2015	12	10	11	12	22	39	0	0	0	0	0	0	0	37.51	0	0	12.6
2015	12	10	11	22	22	39	0	0	0	0	0	0	0	37.54	0	0	12.6
2015	12	10	11	32	22	39	0	0	0	0	0	0	0	37.54	0	0	12.6
2015	12	10	11	42	22	38	0	0	0	0	0	0	0	37.58	0	0	12.6
2015	12	10	11	52	22	40	0	0	0	0	0	0	0	37.58	0	0	12.6
2015	12	10	12	2	22	39	0	0	0	0	0	0	0	37.6	0	0	12.6
2015	12	10	12	12	22	39	0	0	0	0	0	0	0	37.63	0	0	12.6
2015	12	10	12	22	22	39	0	0	0	0	0	0	0	37.72	0	0	12.6
2015	12	10	12	32	22	39	0	0	0	0	0	0	0	37.71	0	0	12.4
2015	12	10	12	42	22	39	0	0	0	0	0	0	0	37.67	0	0	12.4
2015	12	10	12	52	22	39	0	0	0	0	0	0	0	37.6	0	0	12.4
2015	12	10	13	2	22	39	0	0	0	0	0	0	0	37.63	0	0	12.4
2015	12	10	13	12	22	39	0	0	0	0	0	0	0	37.69	0	0	12.4
2015	12	10	13	22	22	39	0	0	0	0	0	0	0	37.71	0	0	12.4
2015	12	10	13	32	22	39	0	0	0	0	0	0	0	37.72	0	0	12.4
2015	12	10	13	42	22	39	0	0	0	0	0	0	0	37.71	0	0	12.4
2015	12	10	13	52	22	39	0	0	0	0	0	0	0	37.72	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	14	2	22	39	0	0	0	0	0	0	0	37.76	0	0	12.4
2015	12	10	14	12	22	39	0	0	0	0	0	0	0	37.78	0	0	12.4
2015	12	10	14	22	22	39	0	0	0	0	0	0	0	37.81	0	0	12.4
2015	12	10	14	32	22	40	0	0	0	0	0	0	0	37.81	0	0	12.4
2015	12	10	14	42	22	39	0	0	0	0	0	0	0	37.8	0	0	12.2
2015	12	10	14	52	22	39	0	0	0	0	0	0	0	37.81	0	0	12.2
2015	12	10	15	2	22	39	0	0	0	0	0	0	0	37.8	0	0	12.2
2015	12	10	15	12	22	39	0	0	0	0	0	0	0	37.76	0	0	12.2
2015	12	10	15	22	22	39	0	0	0	0	0	0	0	37.78	0	0	12.2
2015	12	10	15	32	22	39	0	0	0	0	0	0	0	37.8	0	0	12.2
2015	12	10	15	42	22	39	0	0	0	0	0	0	0	37.81	0	0	12.2
2015	12	10	15	52	22	39	0	0	0	0	0	0	0	37.83	0	0	12.2
2015	12	10	16	2	22	39	0	0	0	0	0	0	0	37.83	0	0	12.2
2015	12	10	16	12	22	39	0	0	0	0	0	0	0	37.83	0	0	12.2
2015	12	10	16	22	22	38	0	0	0	0	0	0	0	37.83	0	0	12.2
2015	12	10	16	32	22	38	0	0	0	0	0	0	0	37.83	0	0	12
2015	12	10	16	42	22	39	0	0	0	0	0	0	0	37.85	0	0	12
2015	12	10	16	52	22	39	0	0	0	0	0	0	0	37.87	0	0	12
2015	12	10	17	2	22	39	0	0	0	0	0	0	0	37.89	0	0	12
2015	12	10	17	12	22	39	0	0	0	0	0	0	0	37.89	0	0	12
2015	12	10	17	22	22	39	0	0	0	0	0	0	0	37.9	0	0	12
2015	12	10	17	32	22	39	0	0	0	0	0	0	0	37.92	0	0	12
2015	12	10	17	42	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	10	17	52	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	10	18	2	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	10	18	12	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	10	18	22	22	40	0	0	0	0	0	0	0	38.01	0	0	12
2015	12	10	18	32	22	39	0	0	0	0	0	0	0	38.03	0	0	12
2015	12	10	18	42	22	39	0	0	0	0	0	0	0	38.05	0	0	12
2015	12	10	18	52	22	39	0	0	0	0	0	0	0	38.07	0	0	12
2015	12	10	19	2	22	38	0	0	0	0	0	0	0	38.07	0	0	12
2015	12	10	19	12	22	39	0	0	0	0	0	0	0	38.08	0	0	12
2015	12	10	19	22	22	39	0	0	0	0	0	0	0	38.1	0	0	12
2015	12	10	19	32	22	39	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	10	19	42	22	39	0	0	0	0	0	0	0	38.14	0	0	12
2015	12	10	19	52	22	39	0	0	0	0	0	0	0	38.16	0	0	11.8
2015	12	10	20	2	22	39	0	0	0	0	0	0	0	38.17	0	0	11.8
2015	12	10	20	12	22	39	0	0	0	0	0	0	0	38.17	0	0	11.8
2015	12	10	20	22	22	39	0	0	0	0	0	0	0	38.19	0	0	11.8
2015	12	10	20	32	22	39	0	0	0	0	0	0	0	38.21	0	0	11.8
2015	12	10	20	42	22	40	0	0	0	0	0	0	0	38.23	0	0	11.8
2015	12	10	20	52	22	39	0	0	0	0	0	0	0	38.23	0	0	11.8
2015	12	10	21	2	22	39	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	10	21	12	22	39	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	10	21	22	22	39	0	0	0	0	0	0	0	38.26	0	0	11.8
2015	12	10	21	32	22	39	0	0	0	0	0	0	0	38.28	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	21	42	22	39	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	10	21	52	22	39	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	10	22	2	22	39	0	0	0	0	0	0	0	38.32	0	0	11.8
2015	12	10	22	12	22	39	0	0	0	0	0	0	0	38.34	0	0	11.8
2015	12	10	22	22	22	39	0	0	0	0	0	0	0	38.34	0	0	11.8
2015	12	10	22	32	22	39	0	0	0	0	0	0	0	38.37	0	0	11.8
2015	12	10	22	42	22	39	0	0	0	0	0	0	0	38.37	0	0	11.8
2015	12	10	22	52	22	39	0	0	0	0	0	0	0	38.37	0	0	11.8
2015	12	10	23	2	22	39	0	0	0	0	0	0	0	38.39	0	0	11.8
2015	12	10	23	12	22	40	0	0	0	0	0	0	0	38.39	0	0	11.8
2015	12	10	23	22	22	40	0	0	0	0	0	0	0	38.41	0	0	11.8
2015	12	10	23	32	22	39	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	10	23	42	22	39	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	10	23	52	22	39	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	11	0	2	22	39	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	11	0	12	22	39	0	0	0	0	0	0	0	38.44	0	0	11.8
2015	12	11	0	22	22	39	0	0	0	0	0	0	0	38.46	0	0	11.8
2015	12	11	0	32	22	39	0	0	0	0	0	0	0	38.44	0	0	11.8
2015	12	11	0	42	22	39	0	0	0	0	0	0	0	38.46	0	0	11.8
2015	12	11	0	52	22	39	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	11	1	2	22	39	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	11	1	12	22	39	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	11	1	22	22	39	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	11	1	32	22	39	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	11	1	42	22	39	0	0	0	0	0	0	0	38.52	0	0	11.8
2015	12	11	1	52	22	39	0	0	0	0	0	0	0	38.52	0	0	11.8
2015	12	11	2	2	22	39	0	0	0	0	0	0	0	38.52	0	0	11.8
2015	12	11	2	12	22	39	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	11	2	22	22	39	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	11	2	32	22	38	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	11	2	42	22	39	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	11	2	52	22	39	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	11	3	2	22	38	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	11	3	12	22	39	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	11	3	22	22	39	0	0	0	0	0	0	0	38.57	0	0	11.8
2015	12	11	3	32	22	39	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	11	3	42	22	39	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	11	3	52	22	39	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	11	4	2	22	39	0	0	0	0	0	0	0	38.59	0	0	11.8
2015	12	11	4	12	22	40	0	0	0	0	0	0	0	38.61	0	0	11.8
2015	12	11	4	22	22	39	0	0	0	0	0	0	0	38.61	0	0	11.8
2015	12	11	4	32	22	39	0	0	0	0	0	0	0	38.61	0	0	11.8
2015	12	11	4	42	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	4	52	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	5	2	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	5	12	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	5	22	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	5	32	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	5	42	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	5	52	22	39	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	11	6	2	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	6	12	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	6	22	22	39	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	11	6	32	22	38	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	6	42	22	39	0	0	0	0	0	0	0	38.62	0	0	11.8
2015	12	11	6	52	22	39	0	0	0	0	0	0	0	38.64	0	0	11.8
2015	12	11	7	2	22	39	0	0	0	0	0	0	0	38.66	0	0	11.8
2015	12	11	7	12	22	39	0	0	0	0	0	0	0	38.66	0	0	11.8
2015	12	11	7	22	22	38	0	0	0	0	0	0	0	38.7	0	0	11.8
2015	12	11	7	32	22	39	0	0	0	0	0	0	0	38.7	0	0	11.8
2015	12	11	7	42	22	39	0	0	0	0	0	0	0	38.71	0	0	11.8
2015	12	11	7	52	22	39	0	0	0	0	0	0	0	38.75	0	0	11.8
2015	12	11	8	2	22	38	0	0	0	0	0	0	0	38.84	0	0	12.2
2015	12	11	8	12	22	39	0	0	0	0	0	0	0	38.91	0	0	12.4
2015	12	11	8	22	22	39	0	0	0	0	0	0	0	38.89	0	0	12.4
2015	12	11	8	32	22	39	0	0	0	0	0	0	0	39.02	0	0	12.8
2015	12	11	8	42	22	38	0	0	0	0	0	0	0	39.11	0	0	13.2
2015	12	11	8	52	22	39	0	0	0	0	0	0	0	39.22	0	0	13
2015	12	11	9	2	22	39	0	0	0	0	0	0	0	39.29	0	0	13.2
2015	12	11	9	12	22	39	0	0	0	0	0	0	0	39.36	0	0	13.2
2015	12	11	9	22	22	39	0	0	0	0	0	0	0	39.43	0	0	13.2
2015	12	11	9	32	22	39	0	0	0	0	0	0	0	39.49	0	0	13.2
2015	12	11	9	42	22	39	0	0	0	0	0	0	0	39.58	0	0	13.2
2015	12	11	9	52	22	39	0	0	0	0	0	0	0	39.67	0	0	13.4
2015	12	11	10	2	22	40	0	0	0	0	0	0	0	39.74	0	0	13.6
2015	12	11	10	12	22	39	0	0	0	0	0	0	0	39.78	0	0	13.6
2015	12	11	10	22	22	39	0	0	0	0	0	0	0	39.83	0	0	13.8
2015	12	11	10	32	22	38	0	0	0	0	0	0	0	39.96	0	0	13.6
2015	12	11	10	42	22	39	0	0	0	0	0	0	0	39.92	0	0	13.6
2015	12	11	10	52	22	39	0	0	0	0	0	0	0	39.65	0	0	12.8
2015	12	11	11	2	22	39	0	0	0	0	0	0	0	39.6	0	0	13.6
2015	12	11	11	12	22	39	0	0	0	0	0	0	0	39.94	0	0	13.6
2015	12	11	11	22	22	38	0	0	0	0	0	0	0	39.97	0	0	13.8
2015	12	11	11	32	22	38	0	0	0	0	0	0	0	39.99	0	0	13.4
2015	12	11	11	42	22	39	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	11	11	52	22	38	0	0	0	0	0	0	0	40.21	0	0	13.8
2015	12	11	12	2	22	39	0	0	0	0	0	0	0	40.26	0	0	13.8
2015	12	11	12	12	22	39	0	0	0	0	0	0	0	40.28	0	0	13.8
2015	12	11	12	22	22	38	0	0	0	0	0	0	0	39.99	0	0	13.6
2015	12	11	12	32	22	39	0	0	0	0	0	0	0	40.28	0	0	13.8
2015	12	11	12	42	22	39	0	0	0	0	0	0	0	40.35	0	0	13.8
2015	12	11	12	52	22	39	0	0	0	0	0	0	0	40.35	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	13	2	22	39	0	0	0	0	0	0	0	40.39	0	0	13.6
2015	12	11	13	12	22	39	0	0	0	0	0	0	0	40.28	0	0	13.6
2015	12	11	13	22	22	39	0	0	0	0	0	0	0	40.26	0	0	13.6
2015	12	11	13	32	22	39	0	0	0	0	0	0	0	40.21	0	0	13.6
2015	12	11	13	42	22	38	0	0	0	0	0	0	0	40.15	0	0	13.8
2015	12	11	13	52	22	39	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	11	14	2	22	39	0	0	0	0	0	0	0	40.06	0	0	13.8
2015	12	11	14	12	22	39	0	0	0	0	0	0	0	40.03	0	0	13.8
2015	12	11	14	22	22	39	0	0	0	0	0	0	0	39.83	0	0	13.8
2015	12	11	14	32	22	38	0	0	0	0	0	0	0	39.76	0	0	13.6
2015	12	11	14	42	22	39	0	0	0	0	0	0	0	39.74	0	0	13.8
2015	12	11	14	52	22	39	0	0	0	0	0	0	0	39.72	0	0	13.8
2015	12	11	15	2	22	39	0	0	0	0	0	0	0	39.7	0	0	13.8
2015	12	11	15	12	22	38	0	0	0	0	0	0	0	39.67	0	0	14
2015	12	11	15	22	22	39	0	0	0	0	0	0	0	39.65	0	0	14
2015	12	11	15	32	22	38	0	0	0	0	0	0	0	39.61	0	0	13.6
2015	12	11	15	42	22	39	0	0	0	0	0	0	0	39.58	0	0	12.6
2015	12	11	15	52	22	39	0	0	0	0	0	0	0	39.54	0	0	12.4
2015	12	11	16	2	22	39	0	0	0	0	0	0	0	39.52	0	0	12.4
2015	12	11	16	12	22	38	0	0	0	0	0	0	0	39.52	0	0	12.2
2015	12	11	16	22	22	39	0	0	0	0	0	0	0	39.51	0	0	12.2
2015	12	11	16	32	22	38	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	16	42	22	39	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	16	52	22	39	0	0	0	0	0	0	0	39.47	0	0	12.2
2015	12	11	17	2	22	38	0	0	0	0	0	0	0	39.47	0	0	12.2
2015	12	11	17	12	22	39	0	0	0	0	0	0	0	39.47	0	0	12.2
2015	12	11	17	22	22	38	0	0	0	0	0	0	0	39.47	0	0	12.2
2015	12	11	17	32	22	39	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	17	42	22	38	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	17	52	22	39	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	18	2	22	38	0	0	0	0	0	0	0	39.49	0	0	12.2
2015	12	11	18	12	22	40	0	0	0	0	0	0	0	39.51	0	0	12.2
2015	12	11	18	22	22	39	0	0	0	0	0	0	0	39.51	0	0	12.2
2015	12	11	18	32	22	39	0	0	0	0	0	0	0	39.52	0	0	12.2
2015	12	11	18	42	22	39	0	0	0	0	0	0	0	39.54	0	0	12.2
2015	12	11	18	52	22	39	0	0	0	0	0	0	0	39.54	0	0	12.2
2015	12	11	19	2	22	39	0	0	0	0	0	0	0	39.54	0	0	12.2
2015	12	11	19	12	22	39	0	0	0	0	0	0	0	39.56	0	0	12.2
2015	12	11	19	22	22	39	0	0	0	0	0	0	0	39.58	0	0	12.2
2015	12	11	19	32	22	39	0	0	0	0	0	0	0	39.58	0	0	12
2015	12	11	19	42	22	39	0	0	0	0	0	0	0	39.58	0	0	12
2015	12	11	19	52	22	39	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	11	20	2	22	38	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	11	20	12	22	39	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	11	20	22	22	39	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	11	20	32	22	38	0	0	0	0	0	0	0	39.61	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	20	42	22	39	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	11	20	52	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	2	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	12	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	22	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	32	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	42	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	21	52	22	39	0	0	0	0	0	0	0	39.65	0	0	12
2015	12	11	22	2	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	22	12	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	22	22	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	22	32	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	22	42	22	39	0	0	0	0	0	0	0	39.63	0	0	12
2015	12	11	22	52	22	39	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	11	23	2	22	39	0	0	0	0	0	0	0	39.61	0	0	12
2015	12	11	23	12	22	39	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	11	23	22	22	39	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	11	23	32	22	38	0	0	0	0	0	0	0	39.6	0	0	12
2015	12	11	23	42	22	39	0	0	0	0	0	0	0	39.58	0	0	12
2015	12	11	23	52	22	39	0	0	0	0	0	0	0	39.56	0	0	12
2015	12	12	0	2	22	39	0	0	0	0	0	0	0	39.56	0	0	12
2015	12	12	0	12	22	39	0	0	0	0	0	0	0	39.54	0	0	12
2015	12	12	0	22	22	39	0	0	0	0	0	0	0	39.52	0	0	12
2015	12	12	0	32	22	39	0	0	0	0	0	0	0	39.51	0	0	12
2015	12	12	0	42	22	38	0	0	0	0	0	0	0	39.49	0	0	12
2015	12	12	0	52	22	38	0	0	0	0	0	0	0	39.47	0	0	12
2015	12	12	1	2	22	39	0	0	0	0	0	0	0	39.45	0	0	12
2015	12	12	1	12	22	39	0	0	0	0	0	0	0	39.45	0	0	12
2015	12	12	1	22	22	38	0	0	0	0	0	0	0	39.42	0	0	12
2015	12	12	1	32	22	39	0	0	0	0	0	0	0	39.42	0	0	12
2015	12	12	1	42	22	39	0	0	0	0	0	0	0	39.38	0	0	12
2015	12	12	1	52	22	39	0	0	0	0	0	0	0	39.36	0	0	12
2015	12	12	2	2	22	39	0	0	0	0	0	0	0	39.36	0	0	12
2015	12	12	2	12	22	39	0	0	0	0	0	0	0	39.33	0	0	12
2015	12	12	2	22	22	38	0	0	0	0	0	0	0	39.33	0	0	12
2015	12	12	2	32	22	39	0	0	0	0	0	0	0	39.31	0	0	12
2015	12	12	2	42	22	39	0	0	0	0	0	0	0	39.27	0	0	12
2015	12	12	2	52	22	39	0	0	0	0	0	0	0	39.27	0	0	12
2015	12	12	3	2	22	39	0	0	0	0	0	0	0	39.24	0	0	12
2015	12	12	3	12	22	39	0	0	0	0	0	0	0	39.22	0	0	12
2015	12	12	3	22	22	38	0	0	0	0	0	0	0	39.22	0	0	12
2015	12	12	3	32	22	39	0	0	0	0	0	0	0	39.2	0	0	12
2015	12	12	3	42	22	39	0	0	0	0	0	0	0	39.16	0	0	12
2015	12	12	3	52	22	39	0	0	0	0	0	0	0	39.16	0	0	12
2015	12	12	4	2	22	38	0	0	0	0	0	0	0	39.15	0	0	12
2015	12	12	4	12	22	39	0	0	0	0	0	0	0	39.13	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	4	22	22	39	0	0	0	0	0	0	0	39.09	0	0	12
2015	12	12	4	32	22	39	0	0	0	0	0	0	0	39.07	0	0	12
2015	12	12	4	42	22	39	0	0	0	0	0	0	0	39.06	0	0	12
2015	12	12	4	52	22	39	0	0	0	0	0	0	0	39.04	0	0	12
2015	12	12	5	2	22	39	0	0	0	0	0	0	0	39.02	0	0	12
2015	12	12	5	12	22	39	0	0	0	0	0	0	0	39	0	0	12
2015	12	12	5	22	22	39	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	12	5	32	22	39	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	12	5	42	22	39	0	0	0	0	0	0	0	38.95	0	0	12
2015	12	12	5	52	22	39	0	0	0	0	0	0	0	38.93	0	0	12
2015	12	12	6	2	22	39	0	0	0	0	0	0	0	38.91	0	0	12
2015	12	12	6	12	22	39	0	0	0	0	0	0	0	38.89	0	0	12
2015	12	12	6	22	22	39	0	0	0	0	0	0	0	38.89	0	0	12
2015	12	12	6	32	22	40	0	0	0	0	0	0	0	38.88	0	0	12
2015	12	12	6	42	22	39	0	0	0	0	0	0	0	38.86	0	0	12
2015	12	12	6	52	22	39	0	0	0	0	0	0	0	38.86	0	0	12
2015	12	12	7	2	22	40	0	0	0	0	0	0	0	38.84	0	0	12
2015	12	12	7	12	22	39	0	0	0	0	0	0	0	38.84	0	0	12
2015	12	12	7	22	22	39	0	0	0	0	0	0	0	38.84	0	0	12
2015	12	12	7	32	22	38	0	0	0	0	0	0	0	38.84	0	0	12
2015	12	12	7	42	22	38	0	0	0	0	0	0	0	38.86	0	0	12.4
2015	12	12	7	52	22	38	0	0	0	0	0	0	0	38.89	0	0	12.6
2015	12	12	8	2	22	39	0	0	0	0	0	0	0	38.93	0	0	12.8
2015	12	12	8	12	22	39	0	0	0	0	0	0	0	38.98	0	0	13
2015	12	12	8	22	22	39	0	0	0	0	0	0	0	39.02	0	0	13
2015	12	12	8	32	22	39	0	0	0	0	0	0	0	39.11	0	0	13.2
2015	12	12	8	42	22	39	0	0	0	0	0	0	0	39.16	0	0	13.4
2015	12	12	8	52	22	39	0	0	0	0	0	0	0	39.2	0	0	13.6
2015	12	12	9	2	22	39	0	0	0	0	0	0	0	39.27	0	0	14
2015	12	12	9	12	22	39	0	0	0	0	0	0	0	39.33	0	0	14
2015	12	12	9	22	22	39	0	0	0	0	0	0	0	39.4	0	0	14
2015	12	12	9	32	22	39	0	0	0	0	0	0	0	39.45	0	0	14
2015	12	12	9	42	22	39	0	0	0	0	0	0	0	39.52	0	0	14
2015	12	12	9	52	22	39	0	0	0	0	0	0	0	39.58	0	0	14
2015	12	12	10	2	22	39	0	0	0	0	0	0	0	39.63	0	0	14
2015	12	12	10	12	22	39	0	0	0	0	0	0	0	39.7	0	0	14
2015	12	12	10	22	22	39	0	0	0	0	0	0	0	39.74	0	0	14
2015	12	12	10	32	22	39	0	0	0	0	0	0	0	39.78	0	0	14
2015	12	12	10	42	22	38	0	0	0	0	0	0	0	39.85	0	0	14
2015	12	12	10	52	22	38	0	0	0	0	0	0	0	39.87	0	0	14
2015	12	12	11	2	22	39	0	0	0	0	0	0	0	39.9	0	0	14
2015	12	12	11	12	22	39	0	0	0	0	0	0	0	39.96	0	0	14
2015	12	12	11	22	22	39	0	0	0	0	0	0	0	40.01	0	0	14
2015	12	12	11	32	22	39	0	0	0	0	0	0	0	40.03	0	0	14
2015	12	12	11	42	22	38	0	0	0	0	0	0	0	40.06	0	0	14
2015	12	12	11	52	22	39	0	0	0	0	0	0	0	40.05	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	12	2	22	38	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	12	12	12	22	39	0	0	0	0	0	0	0	40.06	0	0	13.8
2015	12	12	12	22	22	39	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	12	12	32	22	39	0	0	0	0	0	0	0	40.1	0	0	13.8
2015	12	12	12	42	22	39	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	12	12	52	22	39	0	0	0	0	0	0	0	40.1	0	0	13.8
2015	12	12	13	2	22	39	0	0	0	0	0	0	0	40.08	0	0	13.8
2015	12	12	13	12	22	38	0	0	0	0	0	0	0	40.05	0	0	13.8
2015	12	12	13	22	22	39	0	0	0	0	0	0	0	40.03	0	0	13.8
2015	12	12	13	32	22	39	0	0	0	0	0	0	0	39.97	0	0	13.8
2015	12	12	13	42	22	39	0	0	0	0	0	0	0	39.94	0	0	13.8
2015	12	12	13	52	22	38	0	0	0	0	0	0	0	39.92	0	0	13.8
2015	12	12	14	2	22	38	0	0	0	0	0	0	0	39.85	0	0	13.8
2015	12	12	14	12	22	39	0	0	0	0	0	0	0	39.81	0	0	13.8
2015	12	12	14	22	22	39	0	0	0	0	0	0	0	39.78	0	0	13.8
2015	12	12	14	32	22	40	0	0	0	0	0	0	0	39.7	0	0	13.8
2015	12	12	14	42	22	39	0	0	0	0	0	0	0	39.65	0	0	13.8
2015	12	12	14	52	22	39	0	0	0	0	0	0	0	39.6	0	0	13.8
2015	12	12	15	2	22	39	0	0	0	0	0	0	0	39.47	0	0	13.8
2015	12	12	15	12	22	39	0	0	0	0	0	0	0	39.34	0	0	13.8
2015	12	12	15	22	22	39	0	0	0	0	0	0	0	39.31	0	0	13.8
2015	12	12	15	32	22	39	0	0	0	0	0	0	0	39.29	0	0	13.4
2015	12	12	15	42	22	39	0	0	0	0	0	0	0	39.27	0	0	12.4
2015	12	12	15	52	22	39	0	0	0	0	0	0	0	39.25	0	0	13.8
2015	12	12	16	2	22	39	0	0	0	0	0	0	0	39.25	0	0	12.2
2015	12	12	16	12	22	38	0	0	0	0	0	0	0	39.22	0	0	12.2
2015	12	12	16	22	22	39	0	0	0	0	0	0	0	39.22	0	0	12.2
2015	12	12	16	32	22	39	0	0	0	0	0	0	0	39.2	0	0	12.2
2015	12	12	16	42	22	39	0	0	0	0	0	0	0	39.2	0	0	12.2
2015	12	12	16	52	22	39	0	0	0	0	0	0	0	39.18	0	0	12.2
2015	12	12	17	2	22	39	0	0	0	0	0	0	0	39.18	0	0	12.2
2015	12	12	17	12	22	39	0	0	0	0	0	0	0	39.18	0	0	12.2
2015	12	12	17	22	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	17	32	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	17	42	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	17	52	22	39	0	0	0	0	0	0	0	39.18	0	0	12.2
2015	12	12	18	2	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	18	12	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	18	22	22	38	0	0	0	0	0	0	0	39.18	0	0	12.2
2015	12	12	18	32	22	39	0	0	0	0	0	0	0	39.16	0	0	12
2015	12	12	18	42	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	18	52	22	39	0	0	0	0	0	0	0	39.16	0	0	12.2
2015	12	12	19	2	22	39	0	0	0	0	0	0	0	39.16	0	0	12
2015	12	12	19	12	22	39	0	0	0	0	0	0	0	39.16	0	0	12
2015	12	12	19	22	22	39	0	0	0	0	0	0	0	39.15	0	0	12
2015	12	12	19	32	22	39	0	0	0	0	0	0	0	39.13	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	19	42	22	39	0	0	0	0	0	0	0	39.13	0	0	12
2015	12	12	19	52	22	39	0	0	0	0	0	0	0	39.15	0	0	12
2015	12	12	20	2	22	38	0	0	0	0	0	0	0	39.13	0	0	12
2015	12	12	20	12	22	39	0	0	0	0	0	0	0	39.11	0	0	12
2015	12	12	20	22	22	38	0	0	0	0	0	0	0	39.11	0	0	12
2015	12	12	20	32	22	39	0	0	0	0	0	0	0	39.09	0	0	12
2015	12	12	20	42	22	39	0	0	0	0	0	0	0	39.09	0	0	12
2015	12	12	20	52	22	39	0	0	0	0	0	0	0	39.07	0	0	12
2015	12	12	21	2	22	39	0	0	0	0	0	0	0	39.07	0	0	12
2015	12	12	21	12	22	38	0	0	0	0	0	0	0	39.07	0	0	12
2015	12	12	21	22	22	39	0	0	0	0	0	0	0	39.06	0	0	12
2015	12	12	21	32	22	39	0	0	0	0	0	0	0	39.04	0	0	12
2015	12	12	21	42	22	39	0	0	0	0	0	0	0	39.02	0	0	12
2015	12	12	21	52	22	39	0	0	0	0	0	0	0	39	0	0	12
2015	12	12	22	2	22	38	0	0	0	0	0	0	0	39	0	0	12
2015	12	12	22	12	22	39	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	12	22	22	22	39	0	0	0	0	0	0	0	38.97	0	0	12
2015	12	12	22	32	22	39	0	0	0	0	0	0	0	38.95	0	0	12
2015	12	12	22	42	22	39	0	0	0	0	0	0	0	38.93	0	0	12
2015	12	12	22	52	22	40	0	0	0	0	0	0	0	38.91	0	0	12
2015	12	12	23	2	22	39	0	0	0	0	0	0	0	38.88	0	0	12
2015	12	12	23	12	22	39	0	0	0	0	0	0	0	38.86	0	0	12
2015	12	12	23	22	22	39	0	0	0	0	0	0	0	38.84	0	0	12
2015	12	12	23	32	22	39	0	0	0	0	0	0	0	38.82	0	0	12
2015	12	12	23	42	22	38	0	0	0	0	0	0	0	38.8	0	0	12
2015	12	12	23	52	22	39	0	0	0	0	0	0	0	38.79	0	0	12
2015	12	13	0	2	22	39	0	0	0	0	0	0	0	38.75	0	0	12
2015	12	13	0	12	22	39	0	0	0	0	0	0	0	38.73	0	0	12
2015	12	13	0	22	22	39	0	0	0	0	0	0	0	38.71	0	0	12
2015	12	13	0	32	22	39	0	0	0	0	0	0	0	38.7	0	0	12
2015	12	13	0	42	22	39	0	0	0	0	0	0	0	38.66	0	0	12
2015	12	13	0	52	22	39	0	0	0	0	0	0	0	38.64	0	0	12
2015	12	13	1	2	22	38	0	0	0	0	0	0	0	38.62	0	0	12
2015	12	13	1	12	22	39	0	0	0	0	0	0	0	38.61	0	0	12
2015	12	13	1	22	22	39	0	0	0	0	0	0	0	38.59	0	0	12
2015	12	13	1	32	22	39	0	0	0	0	0	0	0	38.55	0	0	11.8
2015	12	13	1	42	22	39	0	0	0	0	0	0	0	38.53	0	0	11.8
2015	12	13	1	52	22	39	0	0	0	0	0	0	0	38.52	0	0	11.8
2015	12	13	2	2	22	39	0	0	0	0	0	0	0	38.5	0	0	11.8
2015	12	13	2	12	22	39	0	0	0	0	0	0	0	38.48	0	0	11.8
2015	12	13	2	22	22	39	0	0	0	0	0	0	0	38.44	0	0	11.8
2015	12	13	2	32	22	38	0	0	0	0	0	0	0	38.43	0	0	11.8
2015	12	13	2	42	22	39	0	0	0	0	0	0	0	38.41	0	0	11.8
2015	12	13	2	52	22	39	0	0	0	0	0	0	0	38.39	0	0	11.8
2015	12	13	3	2	22	39	0	0	0	0	0	0	0	38.35	0	0	11.8
2015	12	13	3	12	22	40	0	0	0	0	0	0	0	38.34	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	3	22	22	39	0	0	0	0	0	0	0	38.3	0	0	11.8
2015	12	13	3	32	22	39	0	0	0	0	0	0	0	38.28	0	0	11.8
2015	12	13	3	42	22	39	0	0	0	0	0	0	0	38.26	0	0	11.8
2015	12	13	3	52	22	39	0	0	0	0	0	0	0	38.25	0	0	11.8
2015	12	13	4	2	22	39	0	0	0	0	0	0	0	38.23	0	0	11.8
2015	12	13	4	12	22	39	0	0	0	0	0	0	0	38.19	0	0	11.8
2015	12	13	4	22	22	39	0	0	0	0	0	0	0	38.17	0	0	11.8
2015	12	13	4	32	22	39	0	0	0	0	0	0	0	38.16	0	0	11.8
2015	12	13	4	42	22	39	0	0	0	0	0	0	0	38.12	0	0	11.8
2015	12	13	4	52	22	39	0	0	0	0	0	0	0	38.1	0	0	11.8
2015	12	13	5	2	22	39	0	0	0	0	0	0	0	38.07	0	0	11.8
2015	12	13	5	12	22	39	0	0	0	0	0	0	0	38.03	0	0	11.8
2015	12	13	5	22	22	39	0	0	0	0	0	0	0	38.01	0	0	11.8
2015	12	13	5	32	22	39	0	0	0	0	0	0	0	37.99	0	0	11.8
2015	12	13	5	42	22	39	0	0	0	0	0	0	0	37.96	0	0	11.8
2015	12	13	5	52	22	39	0	0	0	0	0	0	0	37.94	0	0	11.8
2015	12	13	6	2	22	39	0	0	0	0	0	0	0	37.92	0	0	11.8
2015	12	13	6	12	22	39	0	0	0	0	0	0	0	37.89	0	0	11.8
2015	12	13	6	22	22	39	0	0	0	0	0	0	0	37.85	0	0	11.8
2015	12	13	6	32	22	39	0	0	0	0	0	0	0	37.83	0	0	11.8
2015	12	13	6	42	22	40	0	0	0	0	0	0	0	37.81	0	0	11.8
2015	12	13	6	52	22	39	0	0	0	0	0	0	0	37.8	0	0	11.8
2015	12	13	7	2	22	39	0	0	0	0	0	0	0	37.76	0	0	11.8
2015	12	13	7	12	22	39	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	13	7	22	22	39	0	0	0	0	0	0	0	37.72	0	0	11.8
2015	12	13	7	32	22	39	0	0	0	0	0	0	0	37.71	0	0	11.8
2015	12	13	7	42	22	39	0	0	0	0	0	0	0	37.72	0	0	12.2
2015	12	13	7	52	22	38	0	0	0	0	0	0	0	37.74	0	0	12.8
2015	12	13	8	2	22	39	0	0	0	0	0	0	0	37.78	0	0	13
2015	12	13	8	12	22	39	0	0	0	0	0	0	0	37.8	0	0	13.2
2015	12	13	8	22	22	39	0	0	0	0	0	0	0	37.85	0	0	13.4
2015	12	13	8	32	22	39	0	0	0	0	0	0	0	37.9	0	0	13.6
2015	12	13	8	42	22	39	0	0	0	0	0	0	0	37.96	0	0	14
2015	12	13	8	52	22	39	0	0	0	0	0	0	0	38.03	0	0	14
2015	12	13	9	2	22	39	0	0	0	0	0	0	0	38.08	0	0	14
2015	12	13	9	12	22	39	0	0	0	0	0	0	0	38.17	0	0	14
2015	12	13	9	22	22	39	0	0	0	0	0	0	0	38.19	0	0	14
2015	12	13	9	32	22	39	0	0	0	0	0	0	0	38.23	0	0	14
2015	12	13	9	42	22	39	0	0	0	0	0	0	0	38.34	0	0	14
2015	12	13	9	52	22	40	0	0	0	0	0	0	0	38.32	0	0	13.8
2015	12	13	10	2	22	39	0	0	0	0	0	0	0	38.35	0	0	13.8
2015	12	13	10	12	22	39	0	0	0	0	0	0	0	38.46	0	0	13.8
2015	12	13	10	22	22	38	0	0	0	0	0	0	0	38.44	0	0	13.8
2015	12	13	10	32	22	39	0	0	0	0	0	0	0	38.37	0	0	13.8
2015	12	13	10	42	22	39	0	0	0	0	0	0	0	38.61	0	0	13.8
2015	12	13	10	52	22	39	0	0	0	0	0	0	0	38.66	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	11	2	22	39	0	0	0	0	0	0	0	38.79	0	0	13.8
2015	12	13	11	12	22	38	0	0	0	0	0	0	0	38.61	0	0	13.8
2015	12	13	11	22	22	39	0	0	0	0	0	0	0	38.52	0	0	13.8
2015	12	13	11	32	22	39	0	0	0	0	0	0	0	38.61	0	0	13.8
2015	12	13	11	42	22	38	0	0	0	0	0	0	0	38.7	0	0	13.8
2015	12	13	11	52	22	39	0	0	0	0	0	0	0	38.77	0	0	13.8
2015	12	13	12	2	22	39	0	0	0	0	0	0	0	38.7	0	0	13.8
2015	12	13	12	12	22	39	0	0	0	0	0	0	0	38.79	0	0	13.8
2015	12	13	12	22	22	38	0	0	0	0	0	0	0	38.7	0	0	13.8
2015	12	13	12	32	22	40	0	0	0	0	0	0	0	38.62	0	0	13.8
2015	12	13	12	42	22	39	0	0	0	0	0	0	0	38.43	0	0	13.6
2015	12	13	12	52	22	38	0	0	0	0	0	0	0	38.3	0	0	13.8
2015	12	13	13	2	22	39	0	0	0	0	0	0	0	38.23	0	0	13.6
2015	12	13	13	12	22	39	0	0	0	0	0	0	0	38.14	0	0	12.8
2015	12	13	13	22	22	39	0	0	0	0	0	0	0	38.08	0	0	12.6
2015	12	13	13	32	22	39	0	0	0	0	0	0	0	38.01	0	0	12.4
2015	12	13	13	42	22	39	0	0	0	0	0	0	0	37.96	0	0	12.4
2015	12	13	13	52	22	38	0	0	0	0	0	0	0	37.92	0	0	12.4
2015	12	13	14	2	22	39	0	0	0	0	0	0	0	37.89	0	0	12.2
2015	12	13	14	12	22	39	0	0	0	0	0	0	0	37.89	0	0	12.2
2015	12	13	14	22	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	14	32	22	38	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	14	42	22	40	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	14	52	22	39	0	0	0	0	0	0	0	37.89	0	0	12.2
2015	12	13	15	2	22	39	0	0	0	0	0	0	0	37.89	0	0	12.2
2015	12	13	15	12	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	15	22	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	15	32	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	15	42	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	15	52	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	2	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	12	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	22	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	32	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	42	22	39	0	0	0	0	0	0	0	37.9	0	0	12.2
2015	12	13	16	52	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	17	2	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	17	12	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	17	22	22	39	0	0	0	0	0	0	0	37.92	0	0	12.2
2015	12	13	17	32	22	39	0	0	0	0	0	0	0	37.92	0	0	12
2015	12	13	17	42	22	39	0	0	0	0	0	0	0	37.94	0	0	12.2
2015	12	13	17	52	22	39	0	0	0	0	0	0	0	37.94	0	0	12.2
2015	12	13	18	2	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	13	18	12	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	18	22	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	13	18	32	22	38	0	0	0	0	0	0	0	37.96	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	18	42	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	18	52	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	19	2	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	19	12	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	19	22	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	19	32	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	19	42	22	40	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	19	52	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	20	2	22	38	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	20	12	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	20	22	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	20	32	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	20	42	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	20	52	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	21	2	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	21	12	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	21	22	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	21	32	22	39	0	0	0	0	0	0	0	37.99	0	0	12
2015	12	13	21	42	22	38	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	21	52	22	39	0	0	0	0	0	0	0	37.98	0	0	12
2015	12	13	22	2	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	22	12	22	39	0	0	0	0	0	0	0	37.96	0	0	12
2015	12	13	22	22	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	13	22	32	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	13	22	42	22	39	0	0	0	0	0	0	0	37.94	0	0	12
2015	12	13	22	52	22	39	0	0	0	0	0	0	0	37.92	0	0	12
2015	12	13	23	2	22	40	0	0	0	0	0	0	0	37.9	0	0	12
2015	12	13	23	12	22	39	0	0	0	0	0	0	0	37.89	0	0	12
2015	12	13	23	22	22	40	0	0	0	0	0	0	0	37.89	0	0	12
2015	12	13	23	32	22	39	0	0	0	0	0	0	0	37.89	0	0	12
2015	12	13	23	42	22	39	0	0	0	0	0	0	0	37.85	0	0	12
2015	12	13	23	52	22	40	0	0	0	0	0	0	0	37.85	0	0	12
2015	12	14	0	2	22	39	0	0	0	0	0	0	0	37.83	0	0	12
2015	12	14	0	12	22	39	0	0	0	0	0	0	0	37.83	0	0	12
2015	12	14	0	22	22	39	0	0	0	0	0	0	0	37.81	0	0	12
2015	12	14	0	32	22	39	0	0	0	0	0	0	0	37.81	0	0	11.8
2015	12	14	0	42	22	39	0	0	0	0	0	0	0	37.8	0	0	12
2015	12	14	0	52	22	39	0	0	0	0	0	0	0	37.8	0	0	12
2015	12	14	1	2	22	39	0	0	0	0	0	0	0	37.78	0	0	11.8
2015	12	14	1	12	22	39	0	0	0	0	0	0	0	37.76	0	0	11.8
2015	12	14	1	22	22	39	0	0	0	0	0	0	0	37.76	0	0	11.8
2015	12	14	1	32	22	39	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	14	1	42	22	39	0	0	0	0	0	0	0	37.74	0	0	11.8
2015	12	14	1	52	22	39	0	0	0	0	0	0	0	37.72	0	0	11.8
2015	12	14	2	2	22	39	0	0	0	0	0	0	0	37.71	0	0	11.8
2015	12	14	2	12	22	39	0	0	0	0	0	0	0	37.71	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	2	22	22	39	0	0	0	0	0	0	0	37.69	0	0	11.8
2015	12	14	2	32	22	39	0	0	0	0	0	0	0	37.67	0	0	11.8
2015	12	14	2	42	22	39	0	0	0	0	0	0	0	37.65	0	0	11.8
2015	12	14	2	52	22	39	0	0	0	0	0	0	0	37.63	0	0	11.8
2015	12	14	3	2	22	38	0	0	0	0	0	0	0	37.63	0	0	11.8
2015	12	14	3	12	22	39	0	0	0	0	0	0	0	37.63	0	0	11.8
2015	12	14	3	22	22	39	0	0	0	0	0	0	0	37.62	0	0	11.8
2015	12	14	3	32	22	39	0	0	0	0	0	0	0	37.6	0	0	11.8
2015	12	14	3	42	22	39	0	0	0	0	0	0	0	37.6	0	0	11.8
2015	12	14	3	52	22	38	0	0	0	0	0	0	0	37.58	0	0	11.8
2015	12	14	4	2	22	39	0	0	0	0	0	0	0	37.56	0	0	11.8
2015	12	14	4	12	22	39	0	0	0	0	0	0	0	37.56	0	0	11.8
2015	12	14	4	22	22	39	0	0	0	0	0	0	0	37.54	0	0	11.8
2015	12	14	4	32	22	39	0	0	0	0	0	0	0	37.54	0	0	11.8
2015	12	14	4	42	22	39	0	0	0	0	0	0	0	37.54	0	0	11.8
2015	12	14	4	52	22	38	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	14	5	2	22	40	0	0	0	0	0	0	0	37.53	0	0	11.8
2015	12	14	5	12	22	39	0	0	0	0	0	0	0	37.51	0	0	11.8
2015	12	14	5	22	22	39	0	0	0	0	0	0	0	37.51	0	0	11.8
2015	12	14	5	32	22	39	0	0	0	0	0	0	0	37.49	0	0	11.8
2015	12	14	5	42	22	39	0	0	0	0	0	0	0	37.49	0	0	11.8
2015	12	14	5	52	22	40	0	0	0	0	0	0	0	37.49	0	0	11.8
2015	12	14	6	2	22	39	0	0	0	0	0	0	0	37.47	0	0	11.8
2015	12	14	6	12	22	39	0	0	0	0	0	0	0	37.45	0	0	11.8
2015	12	14	6	22	22	40	0	0	0	0	0	0	0	37.44	0	0	11.8
2015	12	14	6	32	22	39	0	0	0	0	0	0	0	37.44	0	0	11.8
2015	12	14	6	42	22	39	0	0	0	0	0	0	0	37.42	0	0	11.8
2015	12	14	6	52	22	39	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	14	7	2	22	39	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	14	7	12	22	39	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	14	7	22	22	38	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	14	7	32	22	39	0	0	0	0	0	0	0	37.4	0	0	11.8
2015	12	14	7	42	22	39	0	0	0	0	0	0	0	37.44	0	0	12.2
2015	12	14	7	52	22	39	0	0	0	0	0	0	0	37.47	0	0	12.6
2015	12	14	8	2	22	40	0	0	0	0	0	0	0	37.49	0	0	12.8
2015	12	14	8	12	22	39	0	0	0	0	0	0	0	37.54	0	0	13
2015	12	14	8	22	22	39	0	0	0	0	0	0	0	37.58	0	0	13
2015	12	14	8	32	22	39	0	0	0	0	0	0	0	37.62	0	0	13
2015	12	14	8	42	22	39	0	0	0	0	0	0	0	37.67	0	0	13.2
2015	12	14	8	52	22	39	0	0	0	0	0	0	0	37.72	0	0	13.4
2015	12	14	9	2	22	38	0	0	0	0	0	0	0	37.76	0	0	13.6
2015	12	14	9	12	22	39	0	0	0	0	0	0	0	37.85	0	0	14
2015	12	14	9	22	22	39	0	0	0	0	0	0	0	37.89	0	0	14
2015	12	14	9	32	22	39	0	0	0	0	0	0	0	37.94	0	0	14
2015	12	14	9	42	22	39	0	0	0	0	0	0	0	37.98	0	0	14
2015	12	14	9	52	22	39	0	0	0	0	0	0	0	38.01	0	0	14

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	10	2	22	38	0	0	0	0	0	0	0	38.08	0	0	14
2015	12	14	10	12	22	38	0	0	0	0	0	0	0	38.12	0	0	14
2015	12	14	10	22	22	39	0	0	0	0	0	0	0	38.17	0	0	14
2015	12	14	10	32	22	38	0	0	0	0	0	0	0	38.23	0	0	14
2015	12	14	10	42	22	38	0	0	0	0	0	0	0	38.23	0	0	14
2015	12	14	10	52	22	39	0	0	0	0	0	0	0	38.3	0	0	14
2015	12	14	11	2	22	39	0	0	0	0	0	0	0	38.32	0	0	14
2015	12	14	11	12	22	38	0	0	0	0	0	0	0	38.35	0	0	14
2015	12	14	11	22	22	39	0	0	0	0	0	0	0	38.37	0	0	14
2015	12	14	11	32	22	39	0	0	0	0	0	0	0	38.43	0	0	14
2015	12	14	11	42	22	39	0	0	0	0	0	0	0	38.43	0	0	14
2015	12	14	11	52	22	39	0	0	0	0	0	0	0	38.41	0	0	14
2015	12	14	12	2	22	39	0	0	0	0	0	0	0	38.44	0	0	14
2015	12	14	12	12	22	39	0	0	0	0	0	0	0	38.41	0	0	14
2015	12	14	12	22	22	38	0	0	0	0	0	0	0	38.41	0	0	14
2015	12	14	12	32	22	40	0	0	0	0	0	0	0	38.39	0	0	14
2015	12	14	12	42	22	39	0	0	0	0	0	0	0	38.41	0	0	14
2015	12	14	12	52	22	39	0	0	0	0	0	0	0	38.35	0	0	14
2015	12	14	13	2	22	39	0	0	0	0	0	0	0	38.32	0	0	14
2015	12	14	13	12	22	39	0	0	0	0	0	0	0	38.26	0	0	14
2015	12	14	13	22	22	39	0	0	0	0	0	0	0	38.19	0	0	14
2015	12	14	13	32	22	39	0	0	0	0	0	0	0	38.16	0	0	14
2015	12	14	13	42	22	39	0	0	0	0	0	0	0	38.14	0	0	14
2015	12	14	13	52	22	39	0	0	0	0	0	0	0	38.08	0	0	14
2015	12	14	14	2	22	39	0	0	0	0	0	0	0	38.05	0	0	14
2015	12	14	14	12	22	39	0	0	0	0	0	0	0	37.99	0	0	14
2015	12	14	14	22	22	39	0	0	0	0	0	0	0	37.94	0	0	14
2015	12	14	14	32	22	39	0	0	0	0	0	0	0	37.89	0	0	14
2015	12	14	14	42	22	39	0	0	0	0	0	0	0	37.83	0	0	14
2015	12	14	14	52	22	39	0	0	0	0	0	0	0	37.72	0	0	14
2015	12	14	15	2	22	39	0	0	0	0	0	0	0	37.6	0	0	14
2015	12	14	15	12	22	39	0	0	0	0	0	0	0	37.49	0	0	14
2015	12	14	15	22	22	39	0	0	0	0	0	0	0	37.42	0	0	14
2015	12	14	15	32	22	39	0	0	0	0	0	0	0	37.4	0	0	13.8
2015	12	14	15	42	22	39	0	0	0	0	0	0	0	37.36	0	0	14
2015	12	14	15	52	22	39	0	0	0	0	0	0	0	37.35	0	0	14
2015	12	14	16	2	22	39	0	0	0	0	0	0	0	37.33	0	0	12.2
2015	12	14	16	12	22	39	0	0	0	0	0	0	0	37.29	0	0	12.2
2015	12	14	16	22	22	39	0	0	0	0	0	0	0	37.27	0	0	12.2
2015	12	14	16	32	22	39	0	0	0	0	0	0	0	37.26	0	0	12.2
2015	12	14	16	42	22	40	0	0	0	0	0	0	0	37.22	0	0	12.2
2015	12	14	16	52	22	39	0	0	0	0	0	0	0	37.2	0	0	12.2
2015	12	14	17	2	22	39	0	0	0	0	0	0	0	37.18	0	0	12.2
2015	12	14	17	12	22	39	0	0	0	0	0	0	0	37.17	0	0	12.2
2015	12	14	17	22	22	39	0	0	0	0	0	0	0	37.18	0	0	12.2
2015	12	14	17	32	22	39	0	0	0	0	0	0	0	37.15	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	17	42	22	39	0	0	0	0	0	0	0	37.15	0	0	12.2
2015	12	14	17	52	22	39	0	0	0	0	0	0	0	37.15	0	0	12.2
2015	12	14	18	2	22	39	0	0	0	0	0	0	0	37.15	0	0	12.2
2015	12	14	18	12	22	39	0	0	0	0	0	0	0	37.13	0	0	12.2
2015	12	14	18	22	22	39	0	0	0	0	0	0	0	37.13	0	0	12.2
2015	12	14	18	32	22	39	0	0	0	0	0	0	0	37.13	0	0	12
2015	12	14	18	42	22	40	0	0	0	0	0	0	0	37.11	0	0	12.2
2015	12	14	18	52	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	2	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	12	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	22	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	32	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	42	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	19	52	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	20	2	22	39	0	0	0	0	0	0	0	37.13	0	0	12
2015	12	14	20	12	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	20	22	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	14	20	32	22	39	0	0	0	0	0	0	0	37.11	0	0	12
2015	12	14	20	42	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	14	20	52	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	14	21	2	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	14	21	12	22	39	0	0	0	0	0	0	0	37.08	0	0	12
2015	12	14	21	22	22	39	0	0	0	0	0	0	0	37.09	0	0	12
2015	12	14	21	32	22	39	0	0	0	0	0	0	0	37.08	0	0	12
2015	12	14	21	42	22	39	0	0	0	0	0	0	0	37.06	0	0	12
2015	12	14	21	52	22	39	0	0	0	0	0	0	0	37.06	0	0	12
2015	12	14	22	2	22	39	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	14	22	12	22	39	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	14	22	22	22	39	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	14	22	32	22	39	0	0	0	0	0	0	0	37	0	0	12
2015	12	14	22	42	22	39	0	0	0	0	0	0	0	37	0	0	12
2015	12	14	22	52	22	39	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	14	23	2	22	39	0	0	0	0	0	0	0	36.97	0	0	12
2015	12	14	23	12	22	39	0	0	0	0	0	0	0	36.95	0	0	12
2015	12	14	23	22	22	39	0	0	0	0	0	0	0	36.93	0	0	12
2015	12	14	23	32	22	39	0	0	0	0	0	0	0	36.91	0	0	12
2015	12	14	23	42	22	40	0	0	0	0	0	0	0	36.9	0	0	12
2015	12	14	23	52	22	39	0	0	0	0	0	0	0	36.88	0	0	12
2015	12	15	0	2	22	40	0	0	0	0	0	0	0	36.86	0	0	12
2015	12	15	0	12	22	40	0	0	0	0	0	0	0	36.84	0	0	12
2015	12	15	0	22	22	40	0	0	0	0	0	0	0	36.82	0	0	12
2015	12	15	0	32	22	39	0	0	0	0	0	0	0	36.81	0	0	12
2015	12	15	0	42	22	39	0	0	0	0	0	0	0	36.77	0	0	12
2015	12	15	0	52	22	38	0	0	0	0	0	0	0	36.75	0	0	12
2015	12	15	1	2	22	39	0	0	0	0	0	0	0	36.73	0	0	12
2015	12	15	1	12	22	39	0	0	0	0	0	0	0	36.72	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	1	22	22	39	0	0	0	0	0	0	0	36.68	0	0	12
2015	12	15	1	32	22	40	0	0	0	0	0	0	0	36.64	0	0	12
2015	12	15	1	42	22	40	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	15	1	52	22	39	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	15	2	2	22	39	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	15	2	12	22	39	0	0	0	0	0	0	0	36.57	0	0	12
2015	12	15	2	22	22	40	0	0	0	0	0	0	0	36.54	0	0	12
2015	12	15	2	32	22	40	0	0	0	0	0	0	0	36.52	0	0	12
2015	12	15	2	42	22	39	0	0	0	0	0	0	0	36.5	0	0	12
2015	12	15	2	52	22	39	0	0	0	0	0	0	0	36.46	0	0	12
2015	12	15	3	2	22	39	0	0	0	0	0	0	0	36.45	0	0	12
2015	12	15	3	12	22	39	0	0	0	0	0	0	0	36.43	0	0	12
2015	12	15	3	22	22	39	0	0	0	0	0	0	0	36.39	0	0	12
2015	12	15	3	32	22	39	0	0	0	0	0	0	0	36.36	0	0	11.8
2015	12	15	3	42	22	39	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	15	3	52	22	39	0	0	0	0	0	0	0	36.32	0	0	11.8
2015	12	15	4	2	22	39	0	0	0	0	0	0	0	36.28	0	0	11.8
2015	12	15	4	12	22	39	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	15	4	22	22	39	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	15	4	32	22	40	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	15	4	42	22	39	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	15	4	52	22	39	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	15	5	2	22	39	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	15	5	12	22	40	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	15	5	22	22	39	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	15	5	32	22	40	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	15	5	42	22	40	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	15	5	52	22	40	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	15	6	2	22	38	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	15	6	12	22	39	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	15	6	22	22	39	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	15	6	32	22	39	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	15	6	42	22	38	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	15	6	52	22	39	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	15	7	2	22	40	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	15	7	12	22	39	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	15	7	22	22	40	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	15	7	32	22	40	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	15	7	42	22	40	0	0	0	0	0	0	0	35.87	0	0	12.2
2015	12	15	7	52	22	39	0	0	0	0	0	0	0	35.91	0	0	12.6
2015	12	15	8	2	22	39	0	0	0	0	0	0	0	35.96	0	0	13
2015	12	15	8	12	22	39	0	0	0	0	0	0	0	36	0	0	13
2015	12	15	8	22	22	39	0	0	0	0	0	0	0	36.03	0	0	13.2
2015	12	15	8	32	22	40	0	0	0	0	0	0	0	36.09	0	0	13.2
2015	12	15	8	42	22	39	0	0	0	0	0	0	0	36.16	0	0	13.4
2015	12	15	8	52	22	40	0	0	0	0	0	0	0	36.21	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	9	2	22	39	0	0	0	0	0	0	0	36.25	0	0	14.2
2015	12	15	9	12	22	39	0	0	0	0	0	0	0	36.3	0	0	14.2
2015	12	15	9	22	22	39	0	0	0	0	0	0	0	36.36	0	0	14.2
2015	12	15	9	32	22	39	0	0	0	0	0	0	0	36.43	0	0	14
2015	12	15	9	42	22	39	0	0	0	0	0	0	0	36.46	0	0	14.2
2015	12	15	9	52	22	40	0	0	0	0	0	0	0	36.48	0	0	14.2
2015	12	15	10	2	22	39	0	0	0	0	0	0	0	36.5	0	0	14.2
2015	12	15	10	12	22	40	0	0	0	0	0	0	0	36.59	0	0	14.2
2015	12	15	10	22	22	39	0	0	0	0	0	0	0	36.61	0	0	14.2
2015	12	15	10	32	22	39	0	0	0	0	0	0	0	36.61	0	0	14.2
2015	12	15	10	42	22	40	0	0	0	0	0	0	0	36.64	0	0	14.2
2015	12	15	10	52	22	39	0	0	0	0	0	0	0	36.72	0	0	14.2
2015	12	15	11	2	22	39	0	0	0	0	0	0	0	36.7	0	0	14.2
2015	12	15	11	12	22	39	0	0	0	0	0	0	0	36.73	0	0	14.2
2015	12	15	11	22	22	39	0	0	0	0	0	0	0	36.75	0	0	14.2
2015	12	15	11	32	22	39	0	0	0	0	0	0	0	36.77	0	0	14
2015	12	15	11	42	22	39	0	0	0	0	0	0	0	36.81	0	0	14
2015	12	15	11	52	22	39	0	0	0	0	0	0	0	36.81	0	0	14
2015	12	15	12	2	22	39	0	0	0	0	0	0	0	36.82	0	0	14
2015	12	15	12	12	22	39	0	0	0	0	0	0	0	36.82	0	0	14
2015	12	15	12	22	22	39	0	0	0	0	0	0	0	36.79	0	0	14
2015	12	15	12	32	22	39	0	0	0	0	0	0	0	36.73	0	0	14
2015	12	15	12	42	22	40	0	0	0	0	0	0	0	36.75	0	0	14
2015	12	15	12	52	22	39	0	0	0	0	0	0	0	36.75	0	0	14
2015	12	15	13	2	22	40	0	0	0	0	0	0	0	36.72	0	0	14
2015	12	15	13	12	22	39	0	0	0	0	0	0	0	36.7	0	0	14
2015	12	15	13	22	22	39	0	0	0	0	0	0	0	36.66	0	0	14
2015	12	15	13	32	22	39	0	0	0	0	0	0	0	36.61	0	0	14
2015	12	15	13	42	22	39	0	0	0	0	0	0	0	36.55	0	0	14
2015	12	15	13	52	22	39	0	0	0	0	0	0	0	36.52	0	0	14
2015	12	15	14	2	22	39	0	0	0	0	0	0	0	36.45	0	0	14
2015	12	15	14	12	22	40	0	0	0	0	0	0	0	36.41	0	0	14
2015	12	15	14	22	22	39	0	0	0	0	0	0	0	36.34	0	0	14
2015	12	15	14	32	22	39	0	0	0	0	0	0	0	36.28	0	0	14
2015	12	15	14	42	22	39	0	0	0	0	0	0	0	36.23	0	0	14
2015	12	15	14	52	22	39	0	0	0	0	0	0	0	36.14	0	0	14
2015	12	15	15	2	22	39	0	0	0	0	0	0	0	36.03	0	0	14
2015	12	15	15	12	22	39	0	0	0	0	0	0	0	35.89	0	0	14
2015	12	15	15	22	22	39	0	0	0	0	0	0	0	35.83	0	0	14
2015	12	15	15	32	22	39	0	0	0	0	0	0	0	35.82	0	0	14
2015	12	15	15	42	22	39	0	0	0	0	0	0	0	35.8	0	0	14
2015	12	15	15	52	22	39	0	0	0	0	0	0	0	35.76	0	0	14
2015	12	15	16	2	22	39	0	0	0	0	0	0	0	35.74	0	0	12.2
2015	12	15	16	12	22	39	0	0	0	0	0	0	0	35.73	0	0	12.2
2015	12	15	16	22	22	40	0	0	0	0	0	0	0	35.71	0	0	12.2
2015	12	15	16	32	22	39	0	0	0	0	0	0	0	35.69	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	16	42	22	39	0	0	0	0	0	0	0	35.67	0	0	12.2
2015	12	15	16	52	22	38	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	15	17	2	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	17	12	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	17	22	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	17	32	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	17	42	22	40	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	17	52	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	18	2	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	15	18	12	22	40	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	15	18	22	22	39	0	0	0	0	0	0	0	35.67	0	0	12.2
2015	12	15	18	32	22	40	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	18	42	22	39	0	0	0	0	0	0	0	35.67	0	0	12.2
2015	12	15	18	52	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	2	22	40	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	12	22	40	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	22	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	32	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	42	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	19	52	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	20	2	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	20	12	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	20	22	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	20	32	22	40	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	20	42	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	20	52	22	40	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	21	2	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	21	12	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	21	22	22	39	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	15	21	32	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	21	42	22	39	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	15	21	52	22	39	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	22	2	22	39	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	22	12	22	39	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	22	22	22	39	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	22	32	22	39	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	15	22	42	22	40	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	15	22	52	22	40	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	15	23	2	22	39	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	15	23	12	22	40	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	15	23	22	22	39	0	0	0	0	0	0	0	35.62	0	0	12
2015	12	15	23	32	22	40	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	15	23	42	22	40	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	15	23	52	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	16	0	2	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	16	0	12	22	40	0	0	0	0	0	0	0	35.53	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	0	22	22	40	0	0	0	0	0	0	0	35.51	0	0	12
2015	12	16	0	32	22	40	0	0	0	0	0	0	0	35.49	0	0	12
2015	12	16	0	42	22	39	0	0	0	0	0	0	0	35.49	0	0	12
2015	12	16	0	52	22	39	0	0	0	0	0	0	0	35.47	0	0	12
2015	12	16	1	2	22	39	0	0	0	0	0	0	0	35.47	0	0	12
2015	12	16	1	12	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	16	1	22	22	39	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	16	1	32	22	40	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	16	1	42	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	16	1	52	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	16	2	2	22	40	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	16	2	12	22	39	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	16	2	22	22	40	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	16	2	32	22	40	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	16	2	42	22	39	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	16	2	52	22	40	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	16	3	2	22	40	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	16	3	12	22	39	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	16	3	22	22	39	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	16	3	32	22	40	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	16	3	42	22	39	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	16	3	52	22	40	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	16	4	2	22	39	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	16	4	12	22	39	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	16	4	22	22	39	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	16	4	32	22	39	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	16	4	42	22	39	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	16	4	52	22	40	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	16	5	2	22	39	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	16	5	12	22	40	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	16	5	22	22	39	0	0	0	0	0	0	0	34.84	0	0	11.8
2015	12	16	5	32	22	40	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	16	5	42	22	40	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	16	5	52	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	16	6	2	22	40	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	16	6	12	22	40	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	16	6	22	22	39	0	0	0	0	0	0	0	34.66	0	0	11.8
2015	12	16	6	32	22	39	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	16	6	42	22	40	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	16	6	52	22	40	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	16	7	2	22	39	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	16	7	12	22	39	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	16	7	22	22	40	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	16	7	32	22	40	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	16	7	42	22	40	0	0	0	0	0	0	0	34.47	0	0	12.2
2015	12	16	7	52	22	39	0	0	0	0	0	0	0	34.45	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	8	2	22	39	0	0	0	0	0	0	0	34.41	0	0	12.4
2015	12	16	8	12	22	40	0	0	0	0	0	0	0	34.47	0	0	13
2015	12	16	8	22	22	39	0	0	0	0	0	0	0	34.5	0	0	13.4
2015	12	16	8	32	22	39	0	0	0	0	0	0	0	34.56	0	0	13.8
2015	12	16	8	42	22	40	0	0	0	0	0	0	0	34.59	0	0	14.2
2015	12	16	8	52	22	40	0	0	0	0	0	0	0	34.63	0	0	14.2
2015	12	16	9	2	22	39	0	0	0	0	0	0	0	34.68	0	0	14.2
2015	12	16	9	12	22	39	0	0	0	0	0	0	0	34.74	0	0	14.2
2015	12	16	9	22	22	39	0	0	0	0	0	0	0	34.81	0	0	14
2015	12	16	9	32	22	40	0	0	0	0	0	0	0	34.84	0	0	14
2015	12	16	9	42	22	39	0	0	0	0	0	0	0	34.88	0	0	14
2015	12	16	9	52	22	39	0	0	0	0	0	0	0	34.95	0	0	14
2015	12	16	10	2	22	40	0	0	0	0	0	0	0	34.99	0	0	14
2015	12	16	10	12	22	40	0	0	0	0	0	0	0	35.02	0	0	14
2015	12	16	10	22	22	39	0	0	0	0	0	0	0	35.08	0	0	14
2015	12	16	10	32	22	39	0	0	0	0	0	0	0	35.11	0	0	14
2015	12	16	10	42	22	40	0	0	0	0	0	0	0	35.19	0	0	14
2015	12	16	10	52	22	40	0	0	0	0	0	0	0	35.22	0	0	14
2015	12	16	11	2	22	39	0	0	0	0	0	0	0	35.26	0	0	14
2015	12	16	11	12	22	40	0	0	0	0	0	0	0	35.29	0	0	14
2015	12	16	11	22	22	39	0	0	0	0	0	0	0	35.35	0	0	14
2015	12	16	11	32	22	40	0	0	0	0	0	0	0	35.33	0	0	14
2015	12	16	11	42	22	39	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	16	11	52	22	39	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	16	12	2	22	40	0	0	0	0	0	0	0	35.37	0	0	13.8
2015	12	16	12	12	22	38	0	0	0	0	0	0	0	35.38	0	0	13.8
2015	12	16	12	22	22	40	0	0	0	0	0	0	0	35.4	0	0	13.8
2015	12	16	12	32	22	40	0	0	0	0	0	0	0	35.4	0	0	13.8
2015	12	16	12	42	22	40	0	0	0	0	0	0	0	35.42	0	0	13.8
2015	12	16	12	52	22	39	0	0	0	0	0	0	0	35.37	0	0	13.8
2015	12	16	13	2	22	39	0	0	0	0	0	0	0	35.33	0	0	13.8
2015	12	16	13	12	22	39	0	0	0	0	0	0	0	35.31	0	0	13.8
2015	12	16	13	22	22	39	0	0	0	0	0	0	0	35.33	0	0	13.8
2015	12	16	13	32	22	39	0	0	0	0	0	0	0	35.28	0	0	13.8
2015	12	16	13	42	22	39	0	0	0	0	0	0	0	35.26	0	0	13.8
2015	12	16	13	52	22	39	0	0	0	0	0	0	0	35.22	0	0	13.8
2015	12	16	14	2	22	40	0	0	0	0	0	0	0	35.17	0	0	13.8
2015	12	16	14	12	22	39	0	0	0	0	0	0	0	35.11	0	0	13.8
2015	12	16	14	22	22	40	0	0	0	0	0	0	0	35.1	0	0	13.8
2015	12	16	14	32	22	39	0	0	0	0	0	0	0	35.06	0	0	13.8
2015	12	16	14	42	22	39	0	0	0	0	0	0	0	35.01	0	0	13.8
2015	12	16	14	52	22	39	0	0	0	0	0	0	0	34.93	0	0	13.8
2015	12	16	15	2	22	39	0	0	0	0	0	0	0	34.81	0	0	13.8
2015	12	16	15	12	22	39	0	0	0	0	0	0	0	34.68	0	0	13.8
2015	12	16	15	22	22	39	0	0	0	0	0	0	0	34.63	0	0	13.8
2015	12	16	15	32	22	39	0	0	0	0	0	0	0	34.61	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	15	42	22	40	0	0	0	0	0	0	0	34.59	0	0	13.8
2015	12	16	15	52	22	39	0	0	0	0	0	0	0	34.57	0	0	12.4
2015	12	16	16	2	22	39	0	0	0	0	0	0	0	34.56	0	0	12.4
2015	12	16	16	12	22	39	0	0	0	0	0	0	0	34.54	0	0	12.2
2015	12	16	16	22	22	39	0	0	0	0	0	0	0	34.52	0	0	12.2
2015	12	16	16	32	22	40	0	0	0	0	0	0	0	34.5	0	0	12.2
2015	12	16	16	42	22	39	0	0	0	0	0	0	0	34.48	0	0	12.2
2015	12	16	16	52	22	39	0	0	0	0	0	0	0	34.47	0	0	12.2
2015	12	16	17	2	22	39	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	16	17	12	22	39	0	0	0	0	0	0	0	34.43	0	0	12.2
2015	12	16	17	22	22	39	0	0	0	0	0	0	0	34.41	0	0	12.2
2015	12	16	17	32	22	39	0	0	0	0	0	0	0	34.39	0	0	12.2
2015	12	16	17	42	22	40	0	0	0	0	0	0	0	34.38	0	0	12.2
2015	12	16	17	52	22	39	0	0	0	0	0	0	0	34.38	0	0	12.2
2015	12	16	18	2	22	39	0	0	0	0	0	0	0	34.36	0	0	12.2
2015	12	16	18	12	22	39	0	0	0	0	0	0	0	34.34	0	0	12.2
2015	12	16	18	22	22	40	0	0	0	0	0	0	0	34.34	0	0	12.2
2015	12	16	18	32	22	40	0	0	0	0	0	0	0	34.32	0	0	12
2015	12	16	18	42	22	40	0	0	0	0	0	0	0	34.32	0	0	12.2
2015	12	16	18	52	22	40	0	0	0	0	0	0	0	34.3	0	0	12
2015	12	16	19	2	22	39	0	0	0	0	0	0	0	34.29	0	0	12
2015	12	16	19	12	22	39	0	0	0	0	0	0	0	34.29	0	0	12
2015	12	16	19	22	22	40	0	0	0	0	0	0	0	34.27	0	0	12
2015	12	16	19	32	22	40	0	0	0	0	0	0	0	34.25	0	0	12
2015	12	16	19	42	22	40	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	16	19	52	22	39	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	16	20	2	22	39	0	0	0	0	0	0	0	34.2	0	0	12
2015	12	16	20	12	22	39	0	0	0	0	0	0	0	34.18	0	0	12
2015	12	16	20	22	22	40	0	0	0	0	0	0	0	34.16	0	0	12
2015	12	16	20	32	22	40	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	16	20	42	22	39	0	0	0	0	0	0	0	34.11	0	0	12
2015	12	16	20	52	22	40	0	0	0	0	0	0	0	34.11	0	0	12
2015	12	16	21	2	22	39	0	0	0	0	0	0	0	34.09	0	0	12
2015	12	16	21	12	22	40	0	0	0	0	0	0	0	34.05	0	0	12
2015	12	16	21	22	22	39	0	0	0	0	0	0	0	34.03	0	0	12
2015	12	16	21	32	22	39	0	0	0	0	0	0	0	34.02	0	0	12
2015	12	16	21	42	22	40	0	0	0	0	0	0	0	33.98	0	0	12
2015	12	16	21	52	22	39	0	0	0	0	0	0	0	33.96	0	0	12
2015	12	16	22	2	22	39	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	16	22	12	22	39	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	16	22	22	22	39	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	16	22	32	22	39	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	22	42	22	40	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	16	22	52	22	40	0	0	0	0	0	0	0	33.8	0	0	12
2015	12	16	23	2	22	39	0	0	0	0	0	0	0	33.78	0	0	12
2015	12	16	23	12	22	40	0	0	0	0	0	0	0	33.73	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	23	22	22	39	0	0	0	0	0	0	0	33.71	0	0	12
2015	12	16	23	32	22	40	0	0	0	0	0	0	0	33.69	0	0	12
2015	12	16	23	42	22	39	0	0	0	0	0	0	0	33.66	0	0	12
2015	12	16	23	52	22	39	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	17	0	2	22	40	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	17	0	12	22	39	0	0	0	0	0	0	0	33.57	0	0	12
2015	12	17	0	22	22	40	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	17	0	32	22	39	0	0	0	0	0	0	0	33.49	0	0	11.8
2015	12	17	0	42	22	39	0	0	0	0	0	0	0	33.48	0	0	11.8
2015	12	17	0	52	22	39	0	0	0	0	0	0	0	33.44	0	0	11.8
2015	12	17	1	2	22	40	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	17	1	12	22	39	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	17	1	22	22	40	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	17	1	32	22	40	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	17	1	42	22	40	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	17	1	52	22	39	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	17	2	2	22	39	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	17	2	12	22	40	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	17	2	22	22	39	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	17	2	32	22	39	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	17	2	42	22	40	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	17	2	52	22	40	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	17	3	2	22	40	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	17	3	12	22	39	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	17	3	22	22	40	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	17	3	32	22	39	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	17	3	42	22	40	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	17	3	52	22	40	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	17	4	2	22	40	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	17	4	12	22	40	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	17	4	22	22	39	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	17	4	32	22	39	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	17	4	42	22	40	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	17	4	52	22	40	0	0	0	0	0	0	0	32.77	0	0	11.8
2015	12	17	5	2	22	39	0	0	0	0	0	0	0	32.76	0	0	11.8
2015	12	17	5	12	22	40	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	17	5	22	22	40	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	17	5	32	22	40	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	17	5	42	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	17	5	52	22	40	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	17	6	2	22	40	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	17	6	12	22	40	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	17	6	22	22	40	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	17	6	32	22	40	0	0	0	0	0	0	0	32.54	0	0	11.6
2015	12	17	6	42	22	40	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	17	6	52	22	39	0	0	0	0	0	0	0	32.5	0	0	11.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	7	2	22	40	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	17	7	12	22	40	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	17	7	22	22	40	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	17	7	32	22	40	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	17	7	42	22	40	0	0	0	0	0	0	0	32.45	0	0	12.2
2015	12	17	7	52	22	40	0	0	0	0	0	0	0	32.5	0	0	12.8
2015	12	17	8	2	22	40	0	0	0	0	0	0	0	32.54	0	0	13.2
2015	12	17	8	12	22	40	0	0	0	0	0	0	0	32.56	0	0	13.4
2015	12	17	8	22	22	40	0	0	0	0	0	0	0	32.61	0	0	13.6
2015	12	17	8	32	22	40	0	0	0	0	0	0	0	32.68	0	0	14
2015	12	17	8	42	22	40	0	0	0	0	0	0	0	32.74	0	0	14.2
2015	12	17	8	52	22	40	0	0	0	0	0	0	0	32.81	0	0	14.2
2015	12	17	9	2	22	40	0	0	0	0	0	0	0	32.86	0	0	14.2
2015	12	17	9	12	22	40	0	0	0	0	0	0	0	32.95	0	0	14
2015	12	17	9	22	22	40	0	0	0	0	0	0	0	32.99	0	0	14
2015	12	17	9	32	22	40	0	0	0	0	0	0	0	33.08	0	0	14
2015	12	17	9	42	22	40	0	0	0	0	0	0	0	33.12	0	0	14
2015	12	17	9	52	22	39	0	0	0	0	0	0	0	33.17	0	0	14
2015	12	17	10	2	22	40	0	0	0	0	0	0	0	33.24	0	0	14
2015	12	17	10	12	22	39	0	0	0	0	0	0	0	33.31	0	0	14
2015	12	17	10	22	22	40	0	0	0	0	0	0	0	33.39	0	0	14
2015	12	17	10	32	22	40	0	0	0	0	0	0	0	33.4	0	0	13.8
2015	12	17	10	42	22	40	0	0	0	0	0	0	0	33.49	0	0	13.8
2015	12	17	10	52	22	39	0	0	0	0	0	0	0	33.49	0	0	13.8
2015	12	17	11	2	22	39	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	17	11	12	22	39	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	17	11	22	22	40	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	17	11	32	22	40	0	0	0	0	0	0	0	33.53	0	0	13.8
2015	12	17	11	42	22	39	0	0	0	0	0	0	0	33.37	0	0	13.8
2015	12	17	11	52	22	40	0	0	0	0	0	0	0	33.53	0	0	13.8
2015	12	17	12	2	22	40	0	0	0	0	0	0	0	33.66	0	0	13.8
2015	12	17	12	12	22	40	0	0	0	0	0	0	0	33.62	0	0	13.8
2015	12	17	12	22	22	39	0	0	0	0	0	0	0	33.62	0	0	13.8
2015	12	17	12	32	22	40	0	0	0	0	0	0	0	33.62	0	0	13.8
2015	12	17	12	42	22	39	0	0	0	0	0	0	0	33.6	0	0	13.8
2015	12	17	12	52	22	40	0	0	0	0	0	0	0	33.58	0	0	13.8
2015	12	17	13	2	22	40	0	0	0	0	0	0	0	33.57	0	0	13.8
2015	12	17	13	12	22	39	0	0	0	0	0	0	0	33.55	0	0	13.8
2015	12	17	13	22	22	40	0	0	0	0	0	0	0	33.49	0	0	13.6
2015	12	17	13	32	22	40	0	0	0	0	0	0	0	33.46	0	0	13.6
2015	12	17	13	42	22	40	0	0	0	0	0	0	0	33.42	0	0	13.6
2015	12	17	13	52	22	39	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	17	14	2	22	40	0	0	0	0	0	0	0	33.31	0	0	13.6
2015	12	17	14	12	22	39	0	0	0	0	0	0	0	33.3	0	0	13.6
2015	12	17	14	22	22	40	0	0	0	0	0	0	0	33.3	0	0	13.6
2015	12	17	14	32	22	40	0	0	0	0	0	0	0	33.22	0	0	13.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	14	42	22	40	0	0	0	0	0	0	0	33.15	0	0	13.6
2015	12	17	14	52	22	39	0	0	0	0	0	0	0	33.1	0	0	13.6
2015	12	17	15	2	22	39	0	0	0	0	0	0	0	33.01	0	0	13.6
2015	12	17	15	12	22	39	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	17	15	22	22	40	0	0	0	0	0	0	0	32.76	0	0	13
2015	12	17	15	32	22	39	0	0	0	0	0	0	0	32.74	0	0	13.6
2015	12	17	15	42	22	40	0	0	0	0	0	0	0	32.74	0	0	13.8
2015	12	17	15	52	22	39	0	0	0	0	0	0	0	32.72	0	0	13.8
2015	12	17	16	2	22	40	0	0	0	0	0	0	0	32.7	0	0	12.4
2015	12	17	16	12	22	40	0	0	0	0	0	0	0	32.68	0	0	12.2
2015	12	17	16	22	22	39	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	17	16	32	22	40	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	17	16	42	22	40	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	17	16	52	22	39	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	17	17	2	22	40	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	17	17	12	22	40	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	17	17	22	22	39	0	0	0	0	0	0	0	32.59	0	0	12.2
2015	12	17	17	32	22	39	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	17	42	22	39	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	17	52	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	18	2	22	40	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	17	18	12	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	18	22	22	39	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	18	32	22	39	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	18	42	22	40	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	17	18	52	22	40	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	19	2	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	19	12	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	19	22	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	19	32	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	19	42	22	39	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	19	52	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	20	2	22	39	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	20	12	22	39	0	0	0	0	0	0	0	32.54	0	0	12
2015	12	17	20	22	22	40	0	0	0	0	0	0	0	32.54	0	0	12
2015	12	17	20	32	22	40	0	0	0	0	0	0	0	32.52	0	0	12
2015	12	17	20	42	22	40	0	0	0	0	0	0	0	32.52	0	0	12
2015	12	17	20	52	22	40	0	0	0	0	0	0	0	32.52	0	0	12
2015	12	17	21	2	22	40	0	0	0	0	0	0	0	32.5	0	0	12
2015	12	17	21	12	22	40	0	0	0	0	0	0	0	32.49	0	0	12
2015	12	17	21	22	22	40	0	0	0	0	0	0	0	32.49	0	0	12
2015	12	17	21	32	22	40	0	0	0	0	0	0	0	32.47	0	0	12
2015	12	17	21	42	22	40	0	0	0	0	0	0	0	32.45	0	0	12
2015	12	17	21	52	22	40	0	0	0	0	0	0	0	32.45	0	0	12
2015	12	17	22	2	22	40	0	0	0	0	0	0	0	32.41	0	0	12
2015	12	17	22	12	22	40	0	0	0	0	0	0	0	32.41	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	22	22	22	40	0	0	0	0	0	0	0	32.4	0	0	12
2015	12	17	22	32	22	40	0	0	0	0	0	0	0	32.38	0	0	12
2015	12	17	22	42	22	40	0	0	0	0	0	0	0	32.36	0	0	12
2015	12	17	22	52	22	40	0	0	0	0	0	0	0	32.34	0	0	12
2015	12	17	23	2	22	40	0	0	0	0	0	0	0	32.32	0	0	12
2015	12	17	23	12	22	40	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	17	23	22	22	40	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	17	23	32	22	40	0	0	0	0	0	0	0	32.27	0	0	12
2015	12	17	23	42	22	40	0	0	0	0	0	0	0	32.25	0	0	12
2015	12	17	23	52	22	39	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	18	0	2	22	40	0	0	0	0	0	0	0	32.22	0	0	12
2015	12	18	0	12	22	40	0	0	0	0	0	0	0	32.2	0	0	12
2015	12	18	0	22	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	18	0	32	22	40	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	18	0	42	22	40	0	0	0	0	0	0	0	32.14	0	0	12
2015	12	18	0	52	22	40	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	18	1	2	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	18	1	12	22	40	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	18	1	22	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	18	1	32	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	18	1	42	22	40	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	18	1	52	22	39	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	18	2	2	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	18	2	12	22	39	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	18	2	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	2	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	2	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	2	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	3	2	22	41	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	3	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	3	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	3	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	3	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	3	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	4	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	4	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	4	22	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	4	32	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	4	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	4	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	2	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	22	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	42	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	5	52	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	6	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	6	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	6	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	6	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	6	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	6	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	7	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	18	7	12	22	40	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	18	7	22	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	18	7	32	22	39	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	18	7	42	22	40	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	18	7	52	22	40	0	0	0	0	0	0	0	32.13	0	0	12.8
2015	12	18	8	2	22	40	0	0	0	0	0	0	0	32.2	0	0	13.2
2015	12	18	8	12	22	39	0	0	0	0	0	0	0	32.25	0	0	13.4
2015	12	18	8	22	22	39	0	0	0	0	0	0	0	32.31	0	0	13.6
2015	12	18	8	32	22	39	0	0	0	0	0	0	0	32.38	0	0	14
2015	12	18	8	42	22	40	0	0	0	0	0	0	0	32.47	0	0	14.2
2015	12	18	8	52	22	40	0	0	0	0	0	0	0	32.54	0	0	14.2
2015	12	18	9	2	22	40	0	0	0	0	0	0	0	32.61	0	0	14.2
2015	12	18	9	12	22	40	0	0	0	0	0	0	0	32.68	0	0	14
2015	12	18	9	22	22	39	0	0	0	0	0	0	0	32.77	0	0	14
2015	12	18	9	32	22	40	0	0	0	0	0	0	0	32.86	0	0	14
2015	12	18	9	42	22	40	0	0	0	0	0	0	0	32.92	0	0	14
2015	12	18	9	52	22	40	0	0	0	0	0	0	0	33.01	0	0	14
2015	12	18	10	2	22	39	0	0	0	0	0	0	0	33.06	0	0	14
2015	12	18	10	12	22	40	0	0	0	0	0	0	0	33.12	0	0	14
2015	12	18	10	22	22	40	0	0	0	0	0	0	0	33.17	0	0	14
2015	12	18	10	32	22	39	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	18	10	42	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	18	10	52	22	39	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	18	11	2	22	40	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	18	11	12	22	39	0	0	0	0	0	0	0	33.42	0	0	13.8
2015	12	18	11	22	22	40	0	0	0	0	0	0	0	33.42	0	0	13.8
2015	12	18	11	32	22	40	0	0	0	0	0	0	0	33.44	0	0	13.8
2015	12	18	11	42	22	40	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	18	11	52	22	39	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	18	12	2	22	40	0	0	0	0	0	0	0	33.51	0	0	13.8
2015	12	18	12	12	22	40	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	18	12	22	22	40	0	0	0	0	0	0	0	33.48	0	0	13.8
2015	12	18	12	32	22	40	0	0	0	0	0	0	0	33.42	0	0	13.8
2015	12	18	12	42	22	40	0	0	0	0	0	0	0	33.4	0	0	13.8
2015	12	18	12	52	22	39	0	0	0	0	0	0	0	33.37	0	0	13.8
2015	12	18	13	2	22	40	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	18	13	12	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	18	13	22	22	40	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	18	13	32	22	40	0	0	0	0	0	0	0	33.21	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	13	42	22	39	0	0	0	0	0	0	0	33.15	0	0	13.8
2015	12	18	13	52	22	39	0	0	0	0	0	0	0	33.1	0	0	13.8
2015	12	18	14	2	22	39	0	0	0	0	0	0	0	33.03	0	0	13.8
2015	12	18	14	12	22	39	0	0	0	0	0	0	0	32.95	0	0	13.8
2015	12	18	14	22	22	40	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	18	14	32	22	40	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	18	14	42	22	40	0	0	0	0	0	0	0	32.76	0	0	13.8
2015	12	18	14	52	22	40	0	0	0	0	0	0	0	32.68	0	0	13.8
2015	12	18	15	2	22	40	0	0	0	0	0	0	0	32.56	0	0	13.8
2015	12	18	15	12	22	39	0	0	0	0	0	0	0	32.38	0	0	13.8
2015	12	18	15	22	22	40	0	0	0	0	0	0	0	32.31	0	0	13.8
2015	12	18	15	32	22	40	0	0	0	0	0	0	0	32.25	0	0	13.8
2015	12	18	15	42	22	39	0	0	0	0	0	0	0	32.23	0	0	13.8
2015	12	18	15	52	22	40	0	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	18	16	2	22	40	0	0	0	0	0	0	0	32.18	0	0	12.4
2015	12	18	16	12	22	40	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	18	16	22	22	40	0	0	0	0	0	0	0	32.14	0	0	12.2
2015	12	18	16	32	22	40	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	18	16	42	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	18	16	52	22	39	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	18	17	2	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	18	17	12	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	18	17	22	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	18	17	32	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	18	17	42	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	18	17	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	18	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	18	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	18	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	18	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	18	42	22	39	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	18	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	42	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	19	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	12	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	20	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	21	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	21	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	21	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	21	32	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	21	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	21	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	22	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	22	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	22	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	22	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	22	42	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	22	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	23	2	22	39	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	23	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	23	22	22	39	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	18	23	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	23	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	18	23	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	0	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	0	12	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	0	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	0	32	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	0	42	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	0	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	1	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	1	12	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	1	22	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	19	1	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	1	42	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	19	1	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	22	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	32	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	2	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	2	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	3	52	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	2	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	4	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	5	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	5	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	5	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	5	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	5	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	5	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	6	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	6	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	6	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	6	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	19	6	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	6	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	19	7	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	19	7	12	22	39	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	19	7	22	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	19	7	32	22	40	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	19	7	42	22	40	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	19	7	52	22	40	0	0	0	0	0	0	0	32.14	0	0	12.6
2015	12	19	8	2	22	40	0	0	0	0	0	0	0	32.2	0	0	13
2015	12	19	8	12	22	40	0	0	0	0	0	0	0	32.27	0	0	13.4
2015	12	19	8	22	22	40	0	0	0	0	0	0	0	32.34	0	0	13.6
2015	12	19	8	32	22	40	0	0	0	0	0	0	0	32.45	0	0	14
2015	12	19	8	42	22	40	0	0	0	0	0	0	0	32.52	0	0	14.2
2015	12	19	8	52	22	40	0	0	0	0	0	0	0	32.61	0	0	14.2
2015	12	19	9	2	22	40	0	0	0	0	0	0	0	32.68	0	0	14.2
2015	12	19	9	12	22	39	0	0	0	0	0	0	0	32.72	0	0	14.2
2015	12	19	9	22	22	40	0	0	0	0	0	0	0	32.79	0	0	14.2
2015	12	19	9	32	22	40	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	19	9	42	22	40	0	0	0	0	0	0	0	32.95	0	0	14
2015	12	19	9	52	22	40	0	0	0	0	0	0	0	33.04	0	0	14
2015	12	19	10	2	22	39	0	0	0	0	0	0	0	33.15	0	0	14
2015	12	19	10	12	22	39	0	0	0	0	0	0	0	33.19	0	0	14
2015	12	19	10	22	22	40	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	19	10	32	22	39	0	0	0	0	0	0	0	33.24	0	0	14
2015	12	19	10	42	22	40	0	0	0	0	0	0	0	33.26	0	0	14
2015	12	19	10	52	22	40	0	0	0	0	0	0	0	33.39	0	0	14
2015	12	19	11	2	22	40	0	0	0	0	0	0	0	33.51	0	0	14
2015	12	19	11	12	22	40	0	0	0	0	0	0	0	33.48	0	0	14
2015	12	19	11	22	22	39	0	0	0	0	0	0	0	33.42	0	0	14
2015	12	19	11	32	22	39	0	0	0	0	0	0	0	33.42	0	0	13.8
2015	12	19	11	42	22	40	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	19	11	52	22	40	0	0	0	0	0	0	0	33.13	0	0	13.8
2015	12	19	12	2	22	39	0	0	0	0	0	0	0	32.95	0	0	13.8
2015	12	19	12	12	22	40	0	0	0	0	0	0	0	32.79	0	0	13.8
2015	12	19	12	22	22	40	0	0	0	0	0	0	0	32.72	0	0	13.8
2015	12	19	12	32	22	40	0	0	0	0	0	0	0	32.88	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	12	42	22	40	0	0	0	0	0	0	0	33.04	0	0	13.8
2015	12	19	12	52	22	40	0	0	0	0	0	0	0	33.22	0	0	13.8
2015	12	19	13	2	22	39	0	0	0	0	0	0	0	33.22	0	0	13.8
2015	12	19	13	12	22	40	0	0	0	0	0	0	0	33.15	0	0	13.8
2015	12	19	13	22	22	40	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	19	13	32	22	40	0	0	0	0	0	0	0	33.1	0	0	13.8
2015	12	19	13	42	22	40	0	0	0	0	0	0	0	33.03	0	0	13.8
2015	12	19	13	52	22	40	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	19	14	2	22	40	0	0	0	0	0	0	0	32.72	0	0	13.8
2015	12	19	14	12	22	40	0	0	0	0	0	0	0	32.58	0	0	13.6
2015	12	19	14	22	22	40	0	0	0	0	0	0	0	32.52	0	0	13.8
2015	12	19	14	32	22	40	0	0	0	0	0	0	0	32.52	0	0	13.4
2015	12	19	14	42	22	39	0	0	0	0	0	0	0	32.49	0	0	13.8
2015	12	19	14	52	22	40	0	0	0	0	0	0	0	32.43	0	0	13.2
2015	12	19	15	2	22	40	0	0	0	0	0	0	0	32.32	0	0	12.4
2015	12	19	15	12	22	40	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	19	15	22	22	40	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	19	15	32	22	39	0	0	0	0	0	0	0	32.25	0	0	12.2
2015	12	19	15	42	22	40	0	0	0	0	0	0	0	32.22	0	0	12.2
2015	12	19	15	52	22	40	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	19	16	2	22	39	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	19	16	12	22	39	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	19	16	22	22	40	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	19	16	32	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	19	16	42	22	39	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	19	16	52	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	19	17	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	17	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	17	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	17	32	22	39	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	17	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	17	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	18	2	22	39	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	18	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	18	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	18	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	18	42	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	18	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	19	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	19	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	19	19	22	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	19	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	19	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	19	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	20	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	20	12	22	39	0	0	0	0	0	0	0	32.05	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	20	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	20	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	20	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	20	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	21	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	21	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	21	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	21	32	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	21	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	21	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	22	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	22	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	22	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	22	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	22	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	22	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	23	2	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	23	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	23	22	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	23	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	19	23	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	23	52	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	0	2	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	0	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	0	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	0	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	0	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	0	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	12	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	32	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	1	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	2	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	2	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	2	22	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	2	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	2	42	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	2	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	3	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	3	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	3	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	3	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	3	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	3	52	22	39	0	0	0	0	0	0	0	32	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	4	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	4	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	4	22	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	4	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	4	42	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	4	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	22	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	5	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	6	2	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	20	6	12	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	6	22	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	6	32	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	20	6	42	22	39	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	6	52	22	41	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	7	2	22	41	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	7	12	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	7	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	7	32	22	41	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	20	7	42	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	7	52	22	41	0	0	0	0	0	0	0	32.11	0	0	12.6
2015	12	20	8	2	22	40	0	0	0	0	0	0	0	32.2	0	0	13
2015	12	20	8	12	22	39	0	0	0	0	0	0	0	32.27	0	0	13.2
2015	12	20	8	22	22	40	0	0	0	0	0	0	0	32.32	0	0	13.2
2015	12	20	8	32	22	39	0	0	0	0	0	0	0	32.36	0	0	13
2015	12	20	8	42	22	40	0	0	0	0	0	0	0	32.32	0	0	12.8
2015	12	20	8	52	22	40	0	0	0	0	0	0	0	32.27	0	0	12.6
2015	12	20	9	2	22	39	0	0	0	0	0	0	0	32.54	0	0	14.2
2015	12	20	9	12	22	40	0	0	0	0	0	0	0	32.65	0	0	13.2
2015	12	20	9	22	22	40	0	0	0	0	0	0	0	32.52	0	0	12.8
2015	12	20	9	32	22	40	0	0	0	0	0	0	0	32.5	0	0	13.4
2015	12	20	9	42	22	39	0	0	0	0	0	0	0	32.54	0	0	12.8
2015	12	20	9	52	22	39	0	0	0	0	0	0	0	32.9	0	0	14
2015	12	20	10	2	22	40	0	0	0	0	0	0	0	32.94	0	0	13.4
2015	12	20	10	12	22	41	0	0	0	0	0	0	0	32.79	0	0	13.8
2015	12	20	10	22	22	39	0	0	0	0	0	0	0	32.74	0	0	13
2015	12	20	10	32	22	40	0	0	0	0	0	0	0	32.61	0	0	12.8
2015	12	20	10	42	22	39	0	0	0	0	0	0	0	32.58	0	0	12.8
2015	12	20	10	52	22	39	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	20	11	2	22	40	0	0	0	0	0	0	0	32.97	0	0	14
2015	12	20	11	12	22	39	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	20	11	22	22	40	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	20	11	32	22	40	0	0	0	0	0	0	0	33.19	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	11	42	22	40	0	0	0	0	0	0	0	32.9	0	0	13
2015	12	20	11	52	22	40	0	0	0	0	0	0	0	32.9	0	0	13.6
2015	12	20	12	2	22	40	0	0	0	0	0	0	0	33.15	0	0	13.8
2015	12	20	12	12	22	40	0	0	0	0	0	0	0	33.24	0	0	13.8
2015	12	20	12	22	22	40	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	20	12	32	22	40	0	0	0	0	0	0	0	33.35	0	0	13.8
2015	12	20	12	42	22	40	0	0	0	0	0	0	0	33.44	0	0	13.8
2015	12	20	12	52	22	40	0	0	0	0	0	0	0	33.19	0	0	13.8
2015	12	20	13	2	22	39	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	20	13	12	22	40	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	20	13	22	22	39	0	0	0	0	0	0	0	33.35	0	0	13.8
2015	12	20	13	32	22	40	0	0	0	0	0	0	0	33.21	0	0	13.8
2015	12	20	13	42	22	40	0	0	0	0	0	0	0	33.17	0	0	13.6
2015	12	20	13	52	22	40	0	0	0	0	0	0	0	33.12	0	0	13.6
2015	12	20	14	2	22	39	0	0	0	0	0	0	0	33.03	0	0	13.6
2015	12	20	14	12	22	39	0	0	0	0	0	0	0	32.97	0	0	13.6
2015	12	20	14	22	22	40	0	0	0	0	0	0	0	32.9	0	0	13.6
2015	12	20	14	32	22	39	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	20	14	42	22	39	0	0	0	0	0	0	0	32.77	0	0	13.6
2015	12	20	14	52	22	40	0	0	0	0	0	0	0	32.61	0	0	12.8
2015	12	20	15	2	22	39	0	0	0	0	0	0	0	32.38	0	0	12.4
2015	12	20	15	12	22	40	0	0	0	0	0	0	0	32.29	0	0	12.4
2015	12	20	15	22	22	40	0	0	0	0	0	0	0	32.25	0	0	13.2
2015	12	20	15	32	22	39	0	0	0	0	0	0	0	32.22	0	0	12.4
2015	12	20	15	42	22	40	0	0	0	0	0	0	0	32.2	0	0	12.4
2015	12	20	15	52	22	40	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	20	16	2	22	40	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	20	16	12	22	39	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	20	16	22	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	20	16	32	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	20	16	42	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	20	16	52	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	20	17	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	20	17	12	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	20	17	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	20	17	32	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	20	17	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	20	17	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	20	18	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	20	18	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	20	18	22	22	39	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	20	18	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	18	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	18	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	19	2	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	19	12	22	39	0	0	0	0	0	0	0	32.04	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	19	22	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	19	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	19	42	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	19	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	20	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	20	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	20	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	20	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	20	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	20	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	21	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	21	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	21	22	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	21	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	21	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	21	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	22	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	22	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	22	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	22	32	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	22	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	22	52	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	23	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	23	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	23	22	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	20	23	32	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	20	23	42	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	20	23	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	0	2	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	0	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	0	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	0	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	0	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	0	52	22	41	0	0	0	0	0	0	0	32	0	0	12
2015	12	21	1	2	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	1	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	1	22	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	1	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	1	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	1	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	22	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	2	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	3	2	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	3	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	3	22	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	3	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	3	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	3	52	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	22	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	4	52	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	5	2	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	5	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	5	22	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	5	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	21	5	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	5	52	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	6	2	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	21	6	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	6	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	21	6	32	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	6	42	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	21	6	52	22	39	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	7	2	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	7	12	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	7	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	7	32	22	39	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	21	7	42	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	21	7	52	22	40	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	21	8	2	22	40	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	21	8	12	22	40	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	21	8	22	22	40	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	21	8	32	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	8	42	22	40	0	0	0	0	0	0	0	32.32	0	0	13
2015	12	21	8	52	22	40	0	0	0	0	0	0	0	32.59	0	0	13.8
2015	12	21	9	2	22	40	0	0	0	0	0	0	0	32.65	0	0	13.2
2015	12	21	9	12	22	40	0	0	0	0	0	0	0	32.47	0	0	12.8
2015	12	21	9	22	22	40	0	0	0	0	0	0	0	32.38	0	0	12.6
2015	12	21	9	32	22	40	0	0	0	0	0	0	0	32.36	0	0	12.6
2015	12	21	9	42	22	40	0	0	0	0	0	0	0	32.38	0	0	12.8
2015	12	21	9	52	22	40	0	0	0	0	0	0	0	32.49	0	0	13
2015	12	21	10	2	22	40	0	0	0	0	0	0	0	32.49	0	0	12.8
2015	12	21	10	12	22	40	0	0	0	0	0	0	0	32.54	0	0	13
2015	12	21	10	22	22	39	0	0	0	0	0	0	0	32.59	0	0	13
2015	12	21	10	32	22	40	0	0	0	0	0	0	0	32.65	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	10	42	22	39	0	0	0	0	0	0	0	32.67	0	0	13
2015	12	21	10	52	22	40	0	0	0	0	0	0	0	32.76	0	0	13.2
2015	12	21	11	2	22	40	0	0	0	0	0	0	0	32.74	0	0	13
2015	12	21	11	12	22	40	0	0	0	0	0	0	0	32.67	0	0	12.8
2015	12	21	11	22	22	39	0	0	0	0	0	0	0	32.77	0	0	13.2
2015	12	21	11	32	22	40	0	0	0	0	0	0	0	32.72	0	0	13
2015	12	21	11	42	22	40	0	0	0	0	0	0	0	32.7	0	0	12.8
2015	12	21	11	52	22	39	0	0	0	0	0	0	0	32.68	0	0	12.8
2015	12	21	12	2	22	39	0	0	0	0	0	0	0	32.68	0	0	12.8
2015	12	21	12	12	22	39	0	0	0	0	0	0	0	32.65	0	0	12.8
2015	12	21	12	22	22	40	0	0	0	0	0	0	0	32.61	0	0	12.8
2015	12	21	12	32	22	40	0	0	0	0	0	0	0	32.58	0	0	12.8
2015	12	21	12	42	22	40	0	0	0	0	0	0	0	32.56	0	0	12.8
2015	12	21	12	52	22	39	0	0	0	0	0	0	0	32.56	0	0	12.8
2015	12	21	13	2	22	40	0	0	0	0	0	0	0	32.54	0	0	12.8
2015	12	21	13	12	22	40	0	0	0	0	0	0	0	32.56	0	0	12.8
2015	12	21	13	22	22	40	0	0	0	0	0	0	0	32.54	0	0	12.8
2015	12	21	13	32	22	40	0	0	0	0	0	0	0	32.5	0	0	12.6
2015	12	21	13	42	22	39	0	0	0	0	0	0	0	32.47	0	0	12.6
2015	12	21	13	52	22	40	0	0	0	0	0	0	0	32.59	0	0	13.2
2015	12	21	14	2	22	39	0	0	0	0	0	0	0	32.52	0	0	12.8
2015	12	21	14	12	22	39	0	0	0	0	0	0	0	32.49	0	0	12.6
2015	12	21	14	22	22	40	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	21	14	32	22	40	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	21	14	42	22	39	0	0	0	0	0	0	0	32.41	0	0	12.6
2015	12	21	14	52	22	40	0	0	0	0	0	0	0	32.38	0	0	12.4
2015	12	21	15	2	22	40	0	0	0	0	0	0	0	32.34	0	0	12.4
2015	12	21	15	12	22	40	0	0	0	0	0	0	0	32.31	0	0	12.4
2015	12	21	15	22	22	40	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	15	32	22	39	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	21	15	42	22	40	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	21	15	52	22	40	0	0	0	0	0	0	0	32.22	0	0	12.4
2015	12	21	16	2	22	40	0	0	0	0	0	0	0	32.2	0	0	12.2
2015	12	21	16	12	22	40	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	21	16	22	22	40	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	21	16	32	22	40	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	21	16	42	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	21	16	52	22	39	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	17	2	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	17	12	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	17	22	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	21	17	32	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	17	42	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	17	52	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	21	18	2	22	40	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	18	12	22	40	0	0	0	0	0	0	0	32.09	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	18	22	22	40	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	18	32	22	39	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	18	42	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	18	52	22	40	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	19	2	22	39	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	19	12	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	19	22	22	39	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	19	32	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	19	42	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	19	52	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	20	2	22	40	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	21	20	12	22	40	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	20	22	22	40	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	20	32	22	40	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	20	42	22	40	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	20	52	22	40	0	0	0	0	0	0	0	32.14	0	0	12
2015	12	21	21	2	22	40	0	0	0	0	0	0	0	32.14	0	0	12
2015	12	21	21	12	22	40	0	0	0	0	0	0	0	32.14	0	0	12
2015	12	21	21	22	22	40	0	0	0	0	0	0	0	32.14	0	0	12
2015	12	21	21	32	22	39	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	21	21	42	22	40	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	21	21	52	22	40	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	21	22	2	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	22	12	22	40	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	21	22	22	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	22	32	22	39	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	22	42	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	22	52	22	40	0	0	0	0	0	0	0	32.18	0	0	12
2015	12	21	23	2	22	39	0	0	0	0	0	0	0	32.2	0	0	12
2015	12	21	23	12	22	40	0	0	0	0	0	0	0	32.2	0	0	12
2015	12	21	23	22	22	40	0	0	0	0	0	0	0	32.22	0	0	12
2015	12	21	23	32	22	40	0	0	0	0	0	0	0	32.2	0	0	12
2015	12	21	23	42	22	40	0	0	0	0	0	0	0	32.22	0	0	12
2015	12	21	23	52	22	40	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	22	0	2	22	40	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	22	0	12	22	40	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	22	0	22	22	40	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	22	0	32	22	40	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	22	0	42	22	40	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	22	0	52	22	40	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	22	1	2	22	39	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	22	1	12	22	40	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	22	1	22	22	40	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	22	1	32	22	40	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	22	1	42	22	40	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	22	1	52	22	40	0	0	0	0	0	0	0	32.31	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	2	2	22	39	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	22	2	12	22	40	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	22	2	22	22	40	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	22	2	32	22	40	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	22	2	42	22	40	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	22	2	52	22	40	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	22	3	2	22	40	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	22	3	12	22	39	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	22	3	22	22	39	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	22	3	32	22	40	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	22	3	42	22	39	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	22	3	52	22	39	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	22	4	2	22	40	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	22	4	12	22	40	0	0	0	0	0	0	0	32.45	0	0	11.8
2015	12	22	4	22	22	40	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	22	4	32	22	40	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	22	4	42	22	40	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	22	4	52	22	39	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	22	5	2	22	40	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	22	5	12	22	40	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	22	5	22	22	40	0	0	0	0	0	0	0	32.54	0	0	11.8
2015	12	22	5	32	22	40	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	22	5	42	22	40	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	22	5	52	22	40	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	22	6	2	22	40	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	22	6	12	22	40	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	22	6	22	22	39	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	22	6	32	22	40	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	22	6	42	22	40	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	22	6	52	22	40	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	22	7	2	22	40	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	22	7	12	22	39	0	0	0	0	0	0	0	32.72	0	0	11.8
2015	12	22	7	22	22	40	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	22	7	32	22	39	0	0	0	0	0	0	0	32.77	0	0	11.8
2015	12	22	7	42	22	40	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	22	7	52	22	40	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	22	8	2	22	39	0	0	0	0	0	0	0	32.97	0	0	12.2
2015	12	22	8	12	22	40	0	0	0	0	0	0	0	33.01	0	0	12.2
2015	12	22	8	22	22	40	0	0	0	0	0	0	0	33.04	0	0	12.2
2015	12	22	8	32	22	40	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	22	8	42	22	40	0	0	0	0	0	0	0	33.1	0	0	12.2
2015	12	22	8	52	22	39	0	0	0	0	0	0	0	33.13	0	0	12.2
2015	12	22	9	2	22	39	0	0	0	0	0	0	0	33.21	0	0	12.6
2015	12	22	9	12	22	40	0	0	0	0	0	0	0	33.4	0	0	12.8
2015	12	22	9	22	22	39	0	0	0	0	0	0	0	33.53	0	0	13.2
2015	12	22	9	32	22	39	0	0	0	0	0	0	0	33.6	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	9	42	22	39	0	0	0	0	0	0	0	33.49	0	0	12.6
2015	12	22	9	52	22	40	0	0	0	0	0	0	0	33.53	0	0	12.8
2015	12	22	10	2	22	39	0	0	0	0	0	0	0	33.84	0	0	13.2
2015	12	22	10	12	22	40	0	0	0	0	0	0	0	33.89	0	0	13
2015	12	22	10	22	22	40	0	0	0	0	0	0	0	33.85	0	0	13.2
2015	12	22	10	32	22	40	0	0	0	0	0	0	0	34.09	0	0	13.6
2015	12	22	10	42	22	40	0	0	0	0	0	0	0	34.25	0	0	13.8
2015	12	22	10	52	22	39	0	0	0	0	0	0	0	34.36	0	0	13.8
2015	12	22	11	2	22	40	0	0	0	0	0	0	0	34.48	0	0	13.8
2015	12	22	11	12	22	40	0	0	0	0	0	0	0	34.57	0	0	13.8
2015	12	22	11	22	22	40	0	0	0	0	0	0	0	34.59	0	0	13.8
2015	12	22	11	32	22	40	0	0	0	0	0	0	0	34.63	0	0	13.6
2015	12	22	11	42	22	40	0	0	0	0	0	0	0	34.65	0	0	13.6
2015	12	22	11	52	22	39	0	0	0	0	0	0	0	34.52	0	0	13.6
2015	12	22	12	2	22	39	0	0	0	0	0	0	0	34.65	0	0	13.6
2015	12	22	12	12	22	40	0	0	0	0	0	0	0	34.68	0	0	13.6
2015	12	22	12	22	22	40	0	0	0	0	0	0	0	34.65	0	0	13.6
2015	12	22	12	32	22	40	0	0	0	0	0	0	0	34.68	0	0	13.6
2015	12	22	12	42	22	40	0	0	0	0	0	0	0	34.72	0	0	13.6
2015	12	22	12	52	22	40	0	0	0	0	0	0	0	34.81	0	0	13.6
2015	12	22	13	2	22	40	0	0	0	0	0	0	0	34.74	0	0	13.6
2015	12	22	13	12	22	40	0	0	0	0	0	0	0	34.7	0	0	13.6
2015	12	22	13	22	22	39	0	0	0	0	0	0	0	34.68	0	0	13.6
2015	12	22	13	32	22	39	0	0	0	0	0	0	0	34.7	0	0	13.6
2015	12	22	13	42	22	40	0	0	0	0	0	0	0	34.59	0	0	13.4
2015	12	22	13	52	22	39	0	0	0	0	0	0	0	34.39	0	0	13.4
2015	12	22	14	2	22	39	0	0	0	0	0	0	0	34.36	0	0	13.6
2015	12	22	14	12	22	39	0	0	0	0	0	0	0	34.29	0	0	13.6
2015	12	22	14	22	22	40	0	0	0	0	0	0	0	34.23	0	0	12.6
2015	12	22	14	32	22	39	0	0	0	0	0	0	0	34.18	0	0	13.2
2015	12	22	14	42	22	39	0	0	0	0	0	0	0	34.29	0	0	13.6
2015	12	22	14	52	22	40	0	0	0	0	0	0	0	34.25	0	0	13.6
2015	12	22	15	2	22	40	0	0	0	0	0	0	0	34.25	0	0	13
2015	12	22	15	12	22	39	0	0	0	0	0	0	0	34.2	0	0	12.6
2015	12	22	15	22	22	40	0	0	0	0	0	0	0	34.16	0	0	12.4
2015	12	22	15	32	22	40	0	0	0	0	0	0	0	34.16	0	0	12.4
2015	12	22	15	42	22	40	0	0	0	0	0	0	0	34.14	0	0	12.4
2015	12	22	15	52	22	40	0	0	0	0	0	0	0	34.14	0	0	12.4
2015	12	22	16	2	22	39	0	0	0	0	0	0	0	34.14	0	0	12.2
2015	12	22	16	12	22	39	0	0	0	0	0	0	0	34.16	0	0	12.2
2015	12	22	16	22	22	39	0	0	0	0	0	0	0	34.16	0	0	12.2
2015	12	22	16	32	22	39	0	0	0	0	0	0	0	34.18	0	0	12.2
2015	12	22	16	42	22	40	0	0	0	0	0	0	0	34.18	0	0	12.2
2015	12	22	16	52	22	40	0	0	0	0	0	0	0	34.2	0	0	12.2
2015	12	22	17	2	22	40	0	0	0	0	0	0	0	34.21	0	0	12.2
2015	12	22	17	12	22	40	0	0	0	0	0	0	0	34.23	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	17	22	22	39	0	0	0	0	0	0	0	34.25	0	0	12.2
2015	12	22	17	32	22	40	0	0	0	0	0	0	0	34.27	0	0	12.2
2015	12	22	17	42	22	39	0	0	0	0	0	0	0	34.29	0	0	12.2
2015	12	22	17	52	22	39	0	0	0	0	0	0	0	34.3	0	0	12.2
2015	12	22	18	2	22	39	0	0	0	0	0	0	0	34.32	0	0	12.2
2015	12	22	18	12	22	39	0	0	0	0	0	0	0	34.34	0	0	12.2
2015	12	22	18	22	22	39	0	0	0	0	0	0	0	34.36	0	0	12.2
2015	12	22	18	32	22	40	0	0	0	0	0	0	0	34.39	0	0	12.2
2015	12	22	18	42	22	39	0	0	0	0	0	0	0	34.41	0	0	12.2
2015	12	22	18	52	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	22	19	2	22	40	0	0	0	0	0	0	0	34.47	0	0	12.2
2015	12	22	19	12	22	39	0	0	0	0	0	0	0	34.5	0	0	12.2
2015	12	22	19	22	22	40	0	0	0	0	0	0	0	34.52	0	0	12.2
2015	12	22	19	32	22	39	0	0	0	0	0	0	0	34.54	0	0	12.2
2015	12	22	19	42	22	39	0	0	0	0	0	0	0	34.57	0	0	12.2
2015	12	22	19	52	22	39	0	0	0	0	0	0	0	34.59	0	0	12.2
2015	12	22	20	2	22	40	0	0	0	0	0	0	0	34.63	0	0	12.2
2015	12	22	20	12	22	40	0	0	0	0	0	0	0	34.65	0	0	12.2
2015	12	22	20	22	22	40	0	0	0	0	0	0	0	34.65	0	0	12.2
2015	12	22	20	32	22	39	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	22	20	42	22	39	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	22	20	52	22	40	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	22	21	2	22	39	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	22	21	12	22	39	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	22	21	22	22	40	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	22	21	32	22	40	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	22	21	42	22	40	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	22	21	52	22	40	0	0	0	0	0	0	0	34.81	0	0	12
2015	12	22	22	2	22	39	0	0	0	0	0	0	0	34.81	0	0	12
2015	12	22	22	12	22	40	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	22	22	22	22	40	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	22	22	32	22	39	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	22	22	42	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	22	22	52	22	40	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	22	23	2	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	22	23	12	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	22	23	22	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	22	23	32	22	40	0	0	0	0	0	0	0	34.86	0	0	12
2015	12	22	23	42	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	22	23	52	22	39	0	0	0	0	0	0	0	34.86	0	0	12
2015	12	23	0	2	22	39	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	23	0	12	22	39	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	23	0	22	22	39	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	23	0	32	22	39	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	23	0	42	22	40	0	0	0	0	0	0	0	34.84	0	0	12
2015	12	23	0	52	22	40	0	0	0	0	0	0	0	34.84	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	1	2	22	39	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	23	1	12	22	39	0	0	0	0	0	0	0	34.83	0	0	12
2015	12	23	1	22	22	40	0	0	0	0	0	0	0	34.81	0	0	12
2015	12	23	1	32	22	40	0	0	0	0	0	0	0	34.81	0	0	12
2015	12	23	1	42	22	39	0	0	0	0	0	0	0	34.81	0	0	12
2015	12	23	1	52	22	40	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	23	2	2	22	40	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	23	2	12	22	39	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	2	22	22	39	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	2	32	22	39	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	23	2	42	22	40	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	2	52	22	40	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	23	3	2	22	39	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	3	12	22	39	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	3	22	22	40	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	23	3	32	22	39	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	23	3	42	22	39	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	23	3	52	22	40	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	23	4	2	22	40	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	23	4	12	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	4	22	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	4	32	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	4	42	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	4	52	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	5	2	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	5	12	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	5	22	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	5	32	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	5	42	22	40	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	5	52	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	6	2	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	6	12	22	40	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	6	22	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	6	32	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	6	42	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	6	52	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	7	2	22	39	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	23	7	12	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	7	22	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	23	7	32	22	39	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	23	7	42	22	39	0	0	0	0	0	0	0	34.79	0	0	12
2015	12	23	7	52	22	39	0	0	0	0	0	0	0	34.84	0	0	12.4
2015	12	23	8	2	22	39	0	0	0	0	0	0	0	34.9	0	0	12.8
2015	12	23	8	12	22	40	0	0	0	0	0	0	0	34.95	0	0	13
2015	12	23	8	22	22	39	0	0	0	0	0	0	0	35.01	0	0	13
2015	12	23	8	32	22	39	0	0	0	0	0	0	0	35.1	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	8	42	22	40	0	0	0	0	0	0	0	35.15	0	0	13.2
2015	12	23	8	52	22	40	0	0	0	0	0	0	0	35.24	0	0	13.4
2015	12	23	9	2	22	39	0	0	0	0	0	0	0	35.33	0	0	13.8
2015	12	23	9	12	22	39	0	0	0	0	0	0	0	35.42	0	0	13.8
2015	12	23	9	22	22	39	0	0	0	0	0	0	0	35.49	0	0	13.8
2015	12	23	9	32	22	39	0	0	0	0	0	0	0	35.56	0	0	13.8
2015	12	23	9	42	22	40	0	0	0	0	0	0	0	35.65	0	0	13.8
2015	12	23	9	52	22	39	0	0	0	0	0	0	0	35.73	0	0	13.8
2015	12	23	10	2	22	40	0	0	0	0	0	0	0	35.8	0	0	13.8
2015	12	23	10	12	22	39	0	0	0	0	0	0	0	35.87	0	0	13.8
2015	12	23	10	22	22	39	0	0	0	0	0	0	0	35.94	0	0	13.8
2015	12	23	10	32	22	39	0	0	0	0	0	0	0	36	0	0	13.8
2015	12	23	10	42	22	40	0	0	0	0	0	0	0	35.87	0	0	13.8
2015	12	23	10	52	22	40	0	0	0	0	0	0	0	35.87	0	0	13.8
2015	12	23	11	2	22	39	0	0	0	0	0	0	0	35.92	0	0	13.8
2015	12	23	11	12	22	40	0	0	0	0	0	0	0	36.12	0	0	13.8
2015	12	23	11	22	22	40	0	0	0	0	0	0	0	36.25	0	0	13.8
2015	12	23	11	32	22	40	0	0	0	0	0	0	0	36.28	0	0	13.8
2015	12	23	11	42	22	40	0	0	0	0	0	0	0	36.36	0	0	13.8
2015	12	23	11	52	22	40	0	0	0	0	0	0	0	36.37	0	0	13.8
2015	12	23	12	2	22	39	0	0	0	0	0	0	0	36.39	0	0	13.8
2015	12	23	12	12	22	39	0	0	0	0	0	0	0	36.43	0	0	13.8
2015	12	23	12	22	22	39	0	0	0	0	0	0	0	36.45	0	0	13.8
2015	12	23	12	32	22	39	0	0	0	0	0	0	0	36.5	0	0	13.8
2015	12	23	12	42	22	39	0	0	0	0	0	0	0	36.5	0	0	13.8
2015	12	23	12	52	22	39	0	0	0	0	0	0	0	36.45	0	0	13.6
2015	12	23	13	2	22	40	0	0	0	0	0	0	0	36.46	0	0	13.6
2015	12	23	13	12	22	39	0	0	0	0	0	0	0	36.5	0	0	13.6
2015	12	23	13	22	22	39	0	0	0	0	0	0	0	36.39	0	0	13.6
2015	12	23	13	32	22	40	0	0	0	0	0	0	0	36.43	0	0	13.6
2015	12	23	13	42	22	39	0	0	0	0	0	0	0	36.41	0	0	13.6
2015	12	23	13	52	22	39	0	0	0	0	0	0	0	36.23	0	0	13.6
2015	12	23	14	2	22	39	0	0	0	0	0	0	0	36.27	0	0	13.6
2015	12	23	14	12	22	39	0	0	0	0	0	0	0	36.25	0	0	13.6
2015	12	23	14	22	22	39	0	0	0	0	0	0	0	36.14	0	0	13.6
2015	12	23	14	32	22	39	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	23	14	42	22	39	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	23	14	52	22	39	0	0	0	0	0	0	0	36.01	0	0	13.4
2015	12	23	15	2	22	40	0	0	0	0	0	0	0	35.92	0	0	13.8
2015	12	23	15	12	22	39	0	0	0	0	0	0	0	35.91	0	0	13.6
2015	12	23	15	22	22	40	0	0	0	0	0	0	0	35.87	0	0	12.6
2015	12	23	15	32	22	40	0	0	0	0	0	0	0	35.83	0	0	12.6
2015	12	23	15	42	22	40	0	0	0	0	0	0	0	35.82	0	0	12.4
2015	12	23	15	52	22	40	0	0	0	0	0	0	0	35.8	0	0	13.8
2015	12	23	16	2	22	40	0	0	0	0	0	0	0	35.8	0	0	12.4
2015	12	23	16	12	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	16	22	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	16	32	22	40	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	16	42	22	40	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	16	52	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	17	2	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	17	12	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	17	22	22	39	0	0	0	0	0	0	0	35.78	0	0	12.2
2015	12	23	17	32	22	39	0	0	0	0	0	0	0	35.8	0	0	12.2
2015	12	23	17	42	22	39	0	0	0	0	0	0	0	35.8	0	0	12.2
2015	12	23	17	52	22	39	0	0	0	0	0	0	0	35.8	0	0	12.2
2015	12	23	18	2	22	39	0	0	0	0	0	0	0	35.82	0	0	12.2
2015	12	23	18	12	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	23	18	22	22	39	0	0	0	0	0	0	0	35.83	0	0	12.2
2015	12	23	18	32	22	40	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	23	18	42	22	39	0	0	0	0	0	0	0	35.85	0	0	12.2
2015	12	23	18	52	22	40	0	0	0	0	0	0	0	35.85	0	0	12.2
2015	12	23	19	2	22	40	0	0	0	0	0	0	0	35.87	0	0	12.2
2015	12	23	19	12	22	39	0	0	0	0	0	0	0	35.89	0	0	12.2
2015	12	23	19	22	22	39	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	23	19	32	22	39	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	23	19	42	22	39	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	23	19	52	22	39	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	23	20	2	22	39	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	23	20	12	22	39	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	23	20	22	22	40	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	23	20	32	22	40	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	23	20	42	22	39	0	0	0	0	0	0	0	36	0	0	12
2015	12	23	20	52	22	38	0	0	0	0	0	0	0	36	0	0	12
2015	12	23	21	2	22	39	0	0	0	0	0	0	0	36	0	0	12
2015	12	23	21	12	22	40	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	23	21	22	22	39	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	23	21	32	22	39	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	23	21	42	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	23	21	52	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	23	22	2	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	23	22	12	22	40	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	23	22	22	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	23	22	32	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	22	42	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	22	52	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	23	2	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	23	12	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	23	22	22	39	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	23	23	32	22	40	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	23	23	42	22	39	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	23	23	52	22	40	0	0	0	0	0	0	0	36.07	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	0	2	22	39	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	24	0	12	22	40	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	24	0	22	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	24	0	32	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	24	0	42	22	40	0	0	0	0	0	0	0	36	0	0	12
2015	12	24	0	52	22	39	0	0	0	0	0	0	0	36	0	0	12
2015	12	24	1	2	22	39	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	24	1	12	22	40	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	24	1	22	22	40	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	24	1	32	22	39	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	24	1	42	22	39	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	24	1	52	22	39	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	24	2	2	22	39	0	0	0	0	0	0	0	35.87	0	0	12
2015	12	24	2	12	22	40	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	24	2	22	22	39	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	24	2	32	22	39	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	24	2	42	22	39	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	24	2	52	22	39	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	24	3	2	22	39	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	24	3	12	22	39	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	24	3	22	22	39	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	24	3	32	22	39	0	0	0	0	0	0	0	35.69	0	0	11.8
2015	12	24	3	42	22	39	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	24	3	52	22	40	0	0	0	0	0	0	0	35.65	0	0	11.8
2015	12	24	4	2	22	39	0	0	0	0	0	0	0	35.65	0	0	11.8
2015	12	24	4	12	22	39	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	24	4	22	22	39	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	24	4	32	22	39	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	24	4	42	22	40	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	24	4	52	22	39	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	24	5	2	22	39	0	0	0	0	0	0	0	35.56	0	0	11.8
2015	12	24	5	12	22	39	0	0	0	0	0	0	0	35.56	0	0	11.8
2015	12	24	5	22	22	39	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	24	5	32	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	24	5	42	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	24	5	52	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	24	6	2	22	40	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	24	6	12	22	40	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	24	6	22	22	40	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	24	6	32	22	39	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	24	6	42	22	39	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	24	6	52	22	40	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	24	7	2	22	39	0	0	0	0	0	0	0	35.42	0	0	11.8
2015	12	24	7	12	22	39	0	0	0	0	0	0	0	35.42	0	0	11.8
2015	12	24	7	22	22	39	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	24	7	32	22	39	0	0	0	0	0	0	0	35.4	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	7	42	22	39	0	0	0	0	0	0	0	35.42	0	0	11.8
2015	12	24	7	52	22	39	0	0	0	0	0	0	0	35.44	0	0	12.6
2015	12	24	8	2	22	39	0	0	0	0	0	0	0	35.47	0	0	13
2015	12	24	8	12	22	39	0	0	0	0	0	0	0	35.53	0	0	13.2
2015	12	24	8	22	22	39	0	0	0	0	0	0	0	35.56	0	0	13.4
2015	12	24	8	32	22	40	0	0	0	0	0	0	0	35.64	0	0	13.6
2015	12	24	8	42	22	39	0	0	0	0	0	0	0	35.67	0	0	14.2
2015	12	24	8	52	22	40	0	0	0	0	0	0	0	35.74	0	0	14.2
2015	12	24	9	2	22	39	0	0	0	0	0	0	0	35.82	0	0	14.2
2015	12	24	9	12	22	39	0	0	0	0	0	0	0	35.89	0	0	14.2
2015	12	24	9	22	22	40	0	0	0	0	0	0	0	35.94	0	0	14
2015	12	24	9	32	22	39	0	0	0	0	0	0	0	36.01	0	0	14
2015	12	24	9	42	22	39	0	0	0	0	0	0	0	36.1	0	0	14
2015	12	24	9	52	22	40	0	0	0	0	0	0	0	36.18	0	0	14
2015	12	24	10	2	22	40	0	0	0	0	0	0	0	36.25	0	0	14
2015	12	24	10	12	22	40	0	0	0	0	0	0	0	36.34	0	0	14
2015	12	24	10	22	22	39	0	0	0	0	0	0	0	36.43	0	0	14
2015	12	24	10	32	22	39	0	0	0	0	0	0	0	36.43	0	0	13.8
2015	12	24	10	42	22	40	0	0	0	0	0	0	0	36.48	0	0	13.8
2015	12	24	10	52	22	39	0	0	0	0	0	0	0	36.5	0	0	13.8
2015	12	24	11	2	22	39	0	0	0	0	0	0	0	36.57	0	0	13.8
2015	12	24	11	12	22	40	0	0	0	0	0	0	0	36.66	0	0	13.8
2015	12	24	11	22	22	39	0	0	0	0	0	0	0	36.7	0	0	13.8
2015	12	24	11	32	22	40	0	0	0	0	0	0	0	36.72	0	0	13.8
2015	12	24	11	42	22	39	0	0	0	0	0	0	0	36.73	0	0	13.6
2015	12	24	11	52	22	39	0	0	0	0	0	0	0	36.57	0	0	13.8
2015	12	24	12	2	22	40	0	0	0	0	0	0	0	36.72	0	0	13.8
2015	12	24	12	12	22	40	0	0	0	0	0	0	0	36.72	0	0	13.8
2015	12	24	12	22	22	39	0	0	0	0	0	0	0	36.77	0	0	13.8
2015	12	24	12	32	22	39	0	0	0	0	0	0	0	36.75	0	0	13.8
2015	12	24	12	42	22	39	0	0	0	0	0	0	0	36.7	0	0	13.8
2015	12	24	12	52	22	39	0	0	0	0	0	0	0	36.64	0	0	13.8
2015	12	24	13	2	22	39	0	0	0	0	0	0	0	36.61	0	0	13.8
2015	12	24	13	12	22	39	0	0	0	0	0	0	0	36.52	0	0	13.8
2015	12	24	13	22	22	40	0	0	0	0	0	0	0	36.46	0	0	13.8
2015	12	24	13	32	22	39	0	0	0	0	0	0	0	36.41	0	0	13.6
2015	12	24	13	42	22	39	0	0	0	0	0	0	0	36.34	0	0	13.8
2015	12	24	13	52	22	39	0	0	0	0	0	0	0	36.32	0	0	13.8
2015	12	24	14	2	22	39	0	0	0	0	0	0	0	36.32	0	0	13.8
2015	12	24	14	12	22	39	0	0	0	0	0	0	0	36.28	0	0	13.2
2015	12	24	14	22	22	40	0	0	0	0	0	0	0	36.25	0	0	13.6
2015	12	24	14	32	22	39	0	0	0	0	0	0	0	36.21	0	0	12.6
2015	12	24	14	42	22	39	0	0	0	0	0	0	0	36.19	0	0	12.4
2015	12	24	14	52	22	40	0	0	0	0	0	0	0	36.18	0	0	12.4
2015	12	24	15	2	22	39	0	0	0	0	0	0	0	36.16	0	0	12.4
2015	12	24	15	12	22	39	0	0	0	0	0	0	0	36.16	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	15	22	22	39	0	0	0	0	0	0	0	36.14	0	0	12.4
2015	12	24	15	32	22	39	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	24	15	42	22	40	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	24	15	52	22	39	0	0	0	0	0	0	0	36.12	0	0	12.2
2015	12	24	16	2	22	39	0	0	0	0	0	0	0	36.1	0	0	12.2
2015	12	24	16	12	22	39	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	24	16	22	22	40	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	24	16	32	22	39	0	0	0	0	0	0	0	36.07	0	0	12.2
2015	12	24	16	42	22	40	0	0	0	0	0	0	0	36.07	0	0	12.2
2015	12	24	16	52	22	39	0	0	0	0	0	0	0	36.07	0	0	12.2
2015	12	24	17	2	22	39	0	0	0	0	0	0	0	36.07	0	0	12.2
2015	12	24	17	12	22	39	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	24	17	22	22	39	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	24	17	32	22	39	0	0	0	0	0	0	0	36.09	0	0	12.2
2015	12	24	17	42	22	39	0	0	0	0	0	0	0	36.1	0	0	12.2
2015	12	24	17	52	22	39	0	0	0	0	0	0	0	36.1	0	0	12.2
2015	12	24	18	2	22	39	0	0	0	0	0	0	0	36.1	0	0	12.2
2015	12	24	18	12	22	39	0	0	0	0	0	0	0	36.12	0	0	12.2
2015	12	24	18	22	22	40	0	0	0	0	0	0	0	36.14	0	0	12.2
2015	12	24	18	32	22	39	0	0	0	0	0	0	0	36.14	0	0	12
2015	12	24	18	42	22	40	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	24	18	52	22	39	0	0	0	0	0	0	0	36.16	0	0	12.2
2015	12	24	19	2	22	39	0	0	0	0	0	0	0	36.18	0	0	12.2
2015	12	24	19	12	22	39	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	24	19	22	22	39	0	0	0	0	0	0	0	36.19	0	0	12
2015	12	24	19	32	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	19	42	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	19	52	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	20	2	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	20	12	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	20	22	22	39	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	24	20	32	22	40	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	24	20	42	22	40	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	20	52	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	21	2	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	21	12	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	24	21	22	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	24	21	32	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	21	42	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	24	21	52	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	24	22	2	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	24	22	12	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	24	22	22	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	24	22	32	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	24	22	42	22	39	0	0	0	0	0	0	0	36.28	0	0	12
2015	12	24	22	52	22	40	0	0	0	0	0	0	0	36.27	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	23	2	22	39	0	0	0	0	0	0	0	36.27	0	0	12
2015	12	24	23	12	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	23	22	22	39	0	0	0	0	0	0	0	36.25	0	0	12
2015	12	24	23	32	22	40	0	0	0	0	0	0	0	36.23	0	0	12
2015	12	24	23	42	22	40	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	24	23	52	22	39	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	25	0	2	22	39	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	25	0	12	22	39	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	25	0	22	22	39	0	0	0	0	0	0	0	36.18	0	0	12
2015	12	25	0	32	22	40	0	0	0	0	0	0	0	36.16	0	0	12
2015	12	25	0	42	22	39	0	0	0	0	0	0	0	36.14	0	0	12
2015	12	25	0	52	22	40	0	0	0	0	0	0	0	36.12	0	0	12
2015	12	25	1	2	22	39	0	0	0	0	0	0	0	36.12	0	0	12
2015	12	25	1	12	22	39	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	25	1	22	22	40	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	25	1	32	22	39	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	25	1	42	22	40	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	25	1	52	22	39	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	25	2	2	22	39	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	25	2	12	22	39	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	25	2	22	22	39	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	25	2	32	22	40	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	25	2	42	22	40	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	25	2	52	22	39	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	25	3	2	22	39	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	25	3	12	22	39	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	25	3	22	22	39	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	25	3	32	22	39	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	25	3	42	22	39	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	25	3	52	22	39	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	25	4	2	22	39	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	25	4	12	22	39	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	25	4	22	22	39	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	25	4	32	22	39	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	25	4	42	22	39	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	25	4	52	22	40	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	25	5	2	22	39	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	25	5	12	22	39	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	25	5	22	22	40	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	25	5	32	22	40	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	25	5	42	22	40	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	25	5	52	22	39	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	25	6	2	22	39	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	25	6	12	22	39	0	0	0	0	0	0	0	35.56	0	0	11.8
2015	12	25	6	22	22	40	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	25	6	32	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	6	42	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	25	6	52	22	39	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	25	7	2	22	39	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	25	7	12	22	39	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	25	7	22	22	40	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	25	7	32	22	39	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	25	7	42	22	39	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	25	7	52	22	39	0	0	0	0	0	0	0	35.51	0	0	12.6
2015	12	25	8	2	22	39	0	0	0	0	0	0	0	35.55	0	0	13
2015	12	25	8	12	22	40	0	0	0	0	0	0	0	35.58	0	0	13.2
2015	12	25	8	22	22	40	0	0	0	0	0	0	0	35.62	0	0	13.4
2015	12	25	8	32	22	40	0	0	0	0	0	0	0	35.65	0	0	13.4
2015	12	25	8	42	22	39	0	0	0	0	0	0	0	35.71	0	0	13.8
2015	12	25	8	52	22	39	0	0	0	0	0	0	0	35.78	0	0	14
2015	12	25	9	2	22	39	0	0	0	0	0	0	0	35.83	0	0	14
2015	12	25	9	12	22	39	0	0	0	0	0	0	0	35.92	0	0	14
2015	12	25	9	22	22	41	0	0	0	0	0	0	0	36	0	0	14
2015	12	25	9	32	22	39	0	0	0	0	0	0	0	36.07	0	0	14
2015	12	25	9	42	22	40	0	0	0	0	0	0	0	36.12	0	0	14
2015	12	25	9	52	22	40	0	0	0	0	0	0	0	36.19	0	0	14
2015	12	25	10	2	22	39	0	0	0	0	0	0	0	36.25	0	0	14
2015	12	25	10	12	22	39	0	0	0	0	0	0	0	36.27	0	0	14
2015	12	25	10	22	22	39	0	0	0	0	0	0	0	36.34	0	0	14
2015	12	25	10	32	22	39	0	0	0	0	0	0	0	36.39	0	0	14
2015	12	25	10	42	22	39	0	0	0	0	0	0	0	36.43	0	0	14
2015	12	25	10	52	22	40	0	0	0	0	0	0	0	36.48	0	0	14
2015	12	25	11	2	22	39	0	0	0	0	0	0	0	36.54	0	0	14
2015	12	25	11	12	22	39	0	0	0	0	0	0	0	36.57	0	0	14
2015	12	25	11	22	22	39	0	0	0	0	0	0	0	36.59	0	0	14
2015	12	25	11	32	22	39	0	0	0	0	0	0	0	36.63	0	0	14
2015	12	25	11	42	22	40	0	0	0	0	0	0	0	36.66	0	0	14
2015	12	25	11	52	22	39	0	0	0	0	0	0	0	36.68	0	0	14
2015	12	25	12	2	22	39	0	0	0	0	0	0	0	36.68	0	0	14
2015	12	25	12	12	22	40	0	0	0	0	0	0	0	36.72	0	0	14
2015	12	25	12	22	22	39	0	0	0	0	0	0	0	36.7	0	0	14
2015	12	25	12	32	22	40	0	0	0	0	0	0	0	36.7	0	0	13.8
2015	12	25	12	42	22	39	0	0	0	0	0	0	0	36.66	0	0	14
2015	12	25	12	52	22	39	0	0	0	0	0	0	0	36.64	0	0	14
2015	12	25	13	2	22	39	0	0	0	0	0	0	0	36.66	0	0	14
2015	12	25	13	12	22	39	0	0	0	0	0	0	0	36.63	0	0	14
2015	12	25	13	22	22	39	0	0	0	0	0	0	0	36.61	0	0	14
2015	12	25	13	32	22	40	0	0	0	0	0	0	0	36.57	0	0	13.8
2015	12	25	13	42	22	39	0	0	0	0	0	0	0	36.37	0	0	14
2015	12	25	13	52	22	39	0	0	0	0	0	0	0	36.37	0	0	14
2015	12	25	14	2	22	39	0	0	0	0	0	0	0	36.39	0	0	14
2015	12	25	14	12	22	39	0	0	0	0	0	0	0	36.27	0	0	14

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	14	22	22	39	0	0	0	0	0	0	0	36.18	0	0	14
2015	12	25	14	32	22	40	0	0	0	0	0	0	0	36.12	0	0	13.8
2015	12	25	14	42	22	39	0	0	0	0	0	0	0	36.14	0	0	14
2015	12	25	14	52	22	40	0	0	0	0	0	0	0	36.01	0	0	13.6
2015	12	25	15	2	22	40	0	0	0	0	0	0	0	35.92	0	0	12.6
2015	12	25	15	12	22	39	0	0	0	0	0	0	0	35.91	0	0	14
2015	12	25	15	22	22	39	0	0	0	0	0	0	0	35.89	0	0	14
2015	12	25	15	32	22	39	0	0	0	0	0	0	0	35.83	0	0	13.6
2015	12	25	15	42	22	40	0	0	0	0	0	0	0	35.78	0	0	12.4
2015	12	25	15	52	22	39	0	0	0	0	0	0	0	35.74	0	0	12.2
2015	12	25	16	2	22	39	0	0	0	0	0	0	0	35.73	0	0	12.2
2015	12	25	16	12	22	40	0	0	0	0	0	0	0	35.73	0	0	12.2
2015	12	25	16	22	22	39	0	0	0	0	0	0	0	35.71	0	0	12.2
2015	12	25	16	32	22	40	0	0	0	0	0	0	0	35.69	0	0	12.2
2015	12	25	16	42	22	39	0	0	0	0	0	0	0	35.67	0	0	12.2
2015	12	25	16	52	22	39	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	25	17	2	22	39	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	25	17	12	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	25	17	22	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	25	17	32	22	39	0	0	0	0	0	0	0	35.62	0	0	12.2
2015	12	25	17	42	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	25	17	52	22	40	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	25	18	2	22	39	0	0	0	0	0	0	0	35.64	0	0	12.2
2015	12	25	18	12	22	39	0	0	0	0	0	0	0	35.62	0	0	12.2
2015	12	25	18	22	22	40	0	0	0	0	0	0	0	35.6	0	0	12.2
2015	12	25	18	32	22	39	0	0	0	0	0	0	0	35.62	0	0	12
2015	12	25	18	42	22	39	0	0	0	0	0	0	0	35.62	0	0	12.2
2015	12	25	18	52	22	39	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	25	19	2	22	39	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	25	19	12	22	40	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	25	19	22	22	39	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	25	19	32	22	40	0	0	0	0	0	0	0	35.6	0	0	12
2015	12	25	19	42	22	40	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	25	19	52	22	40	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	25	20	2	22	39	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	25	20	12	22	39	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	25	20	22	22	40	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	20	32	22	40	0	0	0	0	0	0	0	35.58	0	0	12
2015	12	25	20	42	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	20	52	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	21	2	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	21	12	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	21	22	22	39	0	0	0	0	0	0	0	35.56	0	0	12
2015	12	25	21	32	22	39	0	0	0	0	0	0	0	35.55	0	0	12
2015	12	25	21	42	22	40	0	0	0	0	0	0	0	35.55	0	0	12
2015	12	25	21	52	22	39	0	0	0	0	0	0	0	35.55	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	22	2	22	39	0	0	0	0	0	0	0	35.53	0	0	12
2015	12	25	22	12	22	40	0	0	0	0	0	0	0	35.53	0	0	12
2015	12	25	22	22	22	40	0	0	0	0	0	0	0	35.53	0	0	12
2015	12	25	22	32	22	39	0	0	0	0	0	0	0	35.51	0	0	12
2015	12	25	22	42	22	39	0	0	0	0	0	0	0	35.51	0	0	12
2015	12	25	22	52	22	40	0	0	0	0	0	0	0	35.51	0	0	12
2015	12	25	23	2	22	39	0	0	0	0	0	0	0	35.49	0	0	12
2015	12	25	23	12	22	39	0	0	0	0	0	0	0	35.47	0	0	12
2015	12	25	23	22	22	40	0	0	0	0	0	0	0	35.47	0	0	12
2015	12	25	23	32	22	39	0	0	0	0	0	0	0	35.46	0	0	12
2015	12	25	23	42	22	39	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	25	23	52	22	40	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	26	0	2	22	39	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	26	0	12	22	39	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	26	0	22	22	40	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	26	0	32	22	39	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	26	0	42	22	40	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	26	0	52	22	40	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	26	1	2	22	40	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	26	1	12	22	40	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	26	1	22	22	40	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	26	1	32	22	39	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	26	1	42	22	39	0	0	0	0	0	0	0	35.24	0	0	12
2015	12	26	1	52	22	40	0	0	0	0	0	0	0	35.22	0	0	12
2015	12	26	2	2	22	39	0	0	0	0	0	0	0	35.2	0	0	12
2015	12	26	2	12	22	40	0	0	0	0	0	0	0	35.19	0	0	12
2015	12	26	2	22	22	39	0	0	0	0	0	0	0	35.17	0	0	12
2015	12	26	2	32	22	40	0	0	0	0	0	0	0	35.15	0	0	11.8
2015	12	26	2	42	22	39	0	0	0	0	0	0	0	35.13	0	0	12
2015	12	26	2	52	22	40	0	0	0	0	0	0	0	35.11	0	0	12
2015	12	26	3	2	22	39	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	26	3	12	22	40	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	26	3	22	22	39	0	0	0	0	0	0	0	35.04	0	0	11.8
2015	12	26	3	32	22	39	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	26	3	42	22	39	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	26	3	52	22	39	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	26	4	2	22	40	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	26	4	12	22	39	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	26	4	22	22	40	0	0	0	0	0	0	0	34.92	0	0	11.8
2015	12	26	4	32	22	40	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	26	4	42	22	39	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	26	4	52	22	39	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	26	5	2	22	39	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	26	5	12	22	40	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	26	5	22	22	40	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	26	5	32	22	39	0	0	0	0	0	0	0	34.77	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	5	42	22	39	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	26	5	52	22	39	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	26	6	2	22	39	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	26	6	12	22	40	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	26	6	22	22	40	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	26	6	32	22	39	0	0	0	0	0	0	0	34.65	0	0	11.8
2015	12	26	6	42	22	39	0	0	0	0	0	0	0	34.63	0	0	11.8
2015	12	26	6	52	22	40	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	26	7	2	22	39	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	26	7	12	22	39	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	26	7	22	22	40	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	26	7	32	22	39	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	26	7	42	22	40	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	26	7	52	22	40	0	0	0	0	0	0	0	34.57	0	0	12.6
2015	12	26	8	2	22	39	0	0	0	0	0	0	0	34.61	0	0	13
2015	12	26	8	12	22	39	0	0	0	0	0	0	0	34.65	0	0	13.2
2015	12	26	8	22	22	39	0	0	0	0	0	0	0	34.68	0	0	13.2
2015	12	26	8	32	22	39	0	0	0	0	0	0	0	34.72	0	0	13.2
2015	12	26	8	42	22	39	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	26	8	52	22	40	0	0	0	0	0	0	0	34.83	0	0	13.8
2015	12	26	9	2	22	39	0	0	0	0	0	0	0	34.88	0	0	14.2
2015	12	26	9	12	22	39	0	0	0	0	0	0	0	34.92	0	0	14.2
2015	12	26	9	22	22	39	0	0	0	0	0	0	0	34.97	0	0	14.2
2015	12	26	9	32	22	39	0	0	0	0	0	0	0	35.02	0	0	14.2
2015	12	26	9	42	22	40	0	0	0	0	0	0	0	35.04	0	0	14.2
2015	12	26	9	52	22	40	0	0	0	0	0	0	0	35.11	0	0	14.2
2015	12	26	10	2	22	39	0	0	0	0	0	0	0	35.17	0	0	14.2
2015	12	26	10	12	22	40	0	0	0	0	0	0	0	35.2	0	0	14.2
2015	12	26	10	22	22	39	0	0	0	0	0	0	0	35.24	0	0	14.2
2015	12	26	10	32	22	39	0	0	0	0	0	0	0	35.28	0	0	14.2
2015	12	26	10	42	22	40	0	0	0	0	0	0	0	35.33	0	0	14.2
2015	12	26	10	52	22	39	0	0	0	0	0	0	0	35.37	0	0	14.2
2015	12	26	11	2	22	39	0	0	0	0	0	0	0	35.38	0	0	14.2
2015	12	26	11	12	22	39	0	0	0	0	0	0	0	35.44	0	0	14.2
2015	12	26	11	22	22	40	0	0	0	0	0	0	0	35.46	0	0	14
2015	12	26	11	32	22	40	0	0	0	0	0	0	0	35.49	0	0	14
2015	12	26	11	42	22	40	0	0	0	0	0	0	0	35.53	0	0	14
2015	12	26	11	52	22	39	0	0	0	0	0	0	0	35.51	0	0	14
2015	12	26	12	2	22	39	0	0	0	0	0	0	0	35.51	0	0	14
2015	12	26	12	12	22	40	0	0	0	0	0	0	0	35.53	0	0	14
2015	12	26	12	22	22	39	0	0	0	0	0	0	0	35.49	0	0	14
2015	12	26	12	32	22	39	0	0	0	0	0	0	0	35.47	0	0	14
2015	12	26	12	42	22	40	0	0	0	0	0	0	0	35.49	0	0	14
2015	12	26	12	52	22	39	0	0	0	0	0	0	0	35.47	0	0	14
2015	12	26	13	2	22	40	0	0	0	0	0	0	0	35.47	0	0	14
2015	12	26	13	12	22	40	0	0	0	0	0	0	0	35.42	0	0	14

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	13	22	22	39	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	26	13	32	22	39	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	26	13	42	22	40	0	0	0	0	0	0	0	35.29	0	0	14
2015	12	26	13	52	22	40	0	0	0	0	0	0	0	35.28	0	0	14
2015	12	26	14	2	22	39	0	0	0	0	0	0	0	35.22	0	0	14
2015	12	26	14	12	22	40	0	0	0	0	0	0	0	35.17	0	0	14
2015	12	26	14	22	22	39	0	0	0	0	0	0	0	35.11	0	0	14
2015	12	26	14	32	22	39	0	0	0	0	0	0	0	35.08	0	0	14
2015	12	26	14	42	22	40	0	0	0	0	0	0	0	34.99	0	0	14
2015	12	26	14	52	22	40	0	0	0	0	0	0	0	34.95	0	0	14
2015	12	26	15	2	22	40	0	0	0	0	0	0	0	34.86	0	0	14
2015	12	26	15	12	22	40	0	0	0	0	0	0	0	34.72	0	0	14
2015	12	26	15	22	22	39	0	0	0	0	0	0	0	34.65	0	0	14
2015	12	26	15	32	22	40	0	0	0	0	0	0	0	34.61	0	0	13.8
2015	12	26	15	42	22	39	0	0	0	0	0	0	0	34.57	0	0	14
2015	12	26	15	52	22	39	0	0	0	0	0	0	0	34.56	0	0	14
2015	12	26	16	2	22	39	0	0	0	0	0	0	0	34.52	0	0	12.4
2015	12	26	16	12	22	39	0	0	0	0	0	0	0	34.52	0	0	12.2
2015	12	26	16	22	22	40	0	0	0	0	0	0	0	34.5	0	0	12.2
2015	12	26	16	32	22	39	0	0	0	0	0	0	0	34.48	0	0	12.2
2015	12	26	16	42	22	39	0	0	0	0	0	0	0	34.47	0	0	12.2
2015	12	26	16	52	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	17	2	22	39	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	17	12	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	17	22	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	17	32	22	40	0	0	0	0	0	0	0	34.43	0	0	12.2
2015	12	26	17	42	22	40	0	0	0	0	0	0	0	34.43	0	0	12.2
2015	12	26	17	52	22	40	0	0	0	0	0	0	0	34.43	0	0	12.2
2015	12	26	18	2	22	40	0	0	0	0	0	0	0	34.43	0	0	12.2
2015	12	26	18	12	22	39	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	18	22	22	39	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	18	32	22	40	0	0	0	0	0	0	0	34.45	0	0	12
2015	12	26	18	42	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	18	52	22	39	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	19	2	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	19	12	22	40	0	0	0	0	0	0	0	34.45	0	0	12.2
2015	12	26	19	22	22	40	0	0	0	0	0	0	0	34.47	0	0	12
2015	12	26	19	32	22	39	0	0	0	0	0	0	0	34.47	0	0	12
2015	12	26	19	42	22	39	0	0	0	0	0	0	0	34.47	0	0	12
2015	12	26	19	52	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	2	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	12	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	22	22	40	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	32	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	42	22	40	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	20	52	22	40	0	0	0	0	0	0	0	34.48	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	21	2	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	21	12	22	40	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	21	22	22	39	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	21	32	22	40	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	21	42	22	40	0	0	0	0	0	0	0	34.52	0	0	12
2015	12	26	21	52	22	40	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	22	2	22	39	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	22	12	22	40	0	0	0	0	0	0	0	34.52	0	0	12
2015	12	26	22	22	22	39	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	22	32	22	39	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	22	42	22	39	0	0	0	0	0	0	0	34.5	0	0	12
2015	12	26	22	52	22	40	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	23	2	22	39	0	0	0	0	0	0	0	34.48	0	0	12
2015	12	26	23	12	22	39	0	0	0	0	0	0	0	34.47	0	0	12
2015	12	26	23	22	22	39	0	0	0	0	0	0	0	34.45	0	0	12
2015	12	26	23	32	22	39	0	0	0	0	0	0	0	34.45	0	0	12
2015	12	26	23	42	22	40	0	0	0	0	0	0	0	34.45	0	0	12
2015	12	26	23	52	22	40	0	0	0	0	0	0	0	34.43	0	0	12
2015	12	27	0	2	22	40	0	0	0	0	0	0	0	34.43	0	0	12
2015	12	27	0	12	22	39	0	0	0	0	0	0	0	34.41	0	0	12
2015	12	27	0	22	22	40	0	0	0	0	0	0	0	34.41	0	0	12
2015	12	27	0	32	22	40	0	0	0	0	0	0	0	34.38	0	0	12
2015	12	27	0	42	22	39	0	0	0	0	0	0	0	34.38	0	0	12
2015	12	27	0	52	22	39	0	0	0	0	0	0	0	34.34	0	0	12
2015	12	27	1	2	22	40	0	0	0	0	0	0	0	34.32	0	0	12
2015	12	27	1	12	22	40	0	0	0	0	0	0	0	34.3	0	0	12
2015	12	27	1	22	22	39	0	0	0	0	0	0	0	34.27	0	0	12
2015	12	27	1	32	22	39	0	0	0	0	0	0	0	34.25	0	0	12
2015	12	27	1	42	22	40	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	27	1	52	22	39	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	27	2	2	22	39	0	0	0	0	0	0	0	34.2	0	0	12
2015	12	27	2	12	22	40	0	0	0	0	0	0	0	34.16	0	0	12
2015	12	27	2	22	22	39	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	27	2	32	22	39	0	0	0	0	0	0	0	34.11	0	0	11.8
2015	12	27	2	42	22	40	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	27	2	52	22	40	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	27	3	2	22	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	27	3	12	22	40	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	27	3	22	22	39	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	27	3	32	22	40	0	0	0	0	0	0	0	33.93	0	0	11.8
2015	12	27	3	42	22	40	0	0	0	0	0	0	0	33.89	0	0	11.8
2015	12	27	3	52	22	39	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	27	4	2	22	39	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	27	4	12	22	40	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	27	4	22	22	39	0	0	0	0	0	0	0	33.75	0	0	11.8
2015	12	27	4	32	22	40	0	0	0	0	0	0	0	33.71	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	4	42	22	40	0	0	0	0	0	0	0	33.67	0	0	11.8
2015	12	27	4	52	22	39	0	0	0	0	0	0	0	33.66	0	0	11.8
2015	12	27	5	2	22	40	0	0	0	0	0	0	0	33.6	0	0	11.8
2015	12	27	5	12	22	40	0	0	0	0	0	0	0	33.57	0	0	11.8
2015	12	27	5	22	22	40	0	0	0	0	0	0	0	33.53	0	0	11.8
2015	12	27	5	32	22	40	0	0	0	0	0	0	0	33.49	0	0	11.8
2015	12	27	5	42	22	39	0	0	0	0	0	0	0	33.46	0	0	11.8
2015	12	27	5	52	22	40	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	27	6	2	22	39	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	27	6	12	22	40	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	27	6	22	22	39	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	27	6	32	22	40	0	0	0	0	0	0	0	33.28	0	0	11.6
2015	12	27	6	42	22	39	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	27	6	52	22	40	0	0	0	0	0	0	0	33.21	0	0	11.6
2015	12	27	7	2	22	39	0	0	0	0	0	0	0	33.19	0	0	11.6
2015	12	27	7	12	22	39	0	0	0	0	0	0	0	33.15	0	0	11.6
2015	12	27	7	22	22	39	0	0	0	0	0	0	0	33.13	0	0	11.6
2015	12	27	7	32	22	40	0	0	0	0	0	0	0	33.1	0	0	11.6
2015	12	27	7	42	22	40	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	27	7	52	22	40	0	0	0	0	0	0	0	33.08	0	0	12.6
2015	12	27	8	2	22	40	0	0	0	0	0	0	0	33.1	0	0	13.2
2015	12	27	8	12	22	40	0	0	0	0	0	0	0	33.15	0	0	13.4
2015	12	27	8	22	22	40	0	0	0	0	0	0	0	33.19	0	0	13.6
2015	12	27	8	32	22	39	0	0	0	0	0	0	0	33.22	0	0	14.2
2015	12	27	8	42	22	39	0	0	0	0	0	0	0	33.3	0	0	14.2
2015	12	27	8	52	22	39	0	0	0	0	0	0	0	33.33	0	0	14.2
2015	12	27	9	2	22	39	0	0	0	0	0	0	0	33.4	0	0	14.2
2015	12	27	9	12	22	40	0	0	0	0	0	0	0	33.44	0	0	14.2
2015	12	27	9	22	22	40	0	0	0	0	0	0	0	33.51	0	0	14
2015	12	27	9	32	22	39	0	0	0	0	0	0	0	33.58	0	0	14
2015	12	27	9	42	22	39	0	0	0	0	0	0	0	33.66	0	0	14
2015	12	27	9	52	22	40	0	0	0	0	0	0	0	33.71	0	0	14
2015	12	27	10	2	22	40	0	0	0	0	0	0	0	33.78	0	0	14
2015	12	27	10	12	22	39	0	0	0	0	0	0	0	33.87	0	0	14
2015	12	27	10	22	22	40	0	0	0	0	0	0	0	33.91	0	0	14
2015	12	27	10	32	22	39	0	0	0	0	0	0	0	33.82	0	0	14
2015	12	27	10	42	22	40	0	0	0	0	0	0	0	34	0	0	14
2015	12	27	10	52	22	40	0	0	0	0	0	0	0	34.05	0	0	14
2015	12	27	11	2	22	39	0	0	0	0	0	0	0	34.11	0	0	14
2015	12	27	11	12	22	39	0	0	0	0	0	0	0	34.21	0	0	13.8
2015	12	27	11	22	22	39	0	0	0	0	0	0	0	34.03	0	0	13.8
2015	12	27	11	32	22	40	0	0	0	0	0	0	0	34.14	0	0	13.8
2015	12	27	11	42	22	40	0	0	0	0	0	0	0	34.23	0	0	13.8
2015	12	27	11	52	22	40	0	0	0	0	0	0	0	34.27	0	0	13.8
2015	12	27	12	2	22	40	0	0	0	0	0	0	0	34.29	0	0	13.8
2015	12	27	12	12	22	40	0	0	0	0	0	0	0	34.29	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	12	22	22	40	0	0	0	0	0	0	0	34.34	0	0	13.8
2015	12	27	12	32	22	39	0	0	0	0	0	0	0	34.27	0	0	13.8
2015	12	27	12	42	22	40	0	0	0	0	0	0	0	34.27	0	0	13.8
2015	12	27	12	52	22	40	0	0	0	0	0	0	0	34.16	0	0	13.8
2015	12	27	13	2	22	39	0	0	0	0	0	0	0	34.21	0	0	13.8
2015	12	27	13	12	22	40	0	0	0	0	0	0	0	34.02	0	0	13.8
2015	12	27	13	22	22	40	0	0	0	0	0	0	0	33.98	0	0	13.8
2015	12	27	13	32	22	40	0	0	0	0	0	0	0	34.09	0	0	13.8
2015	12	27	13	42	22	40	0	0	0	0	0	0	0	34.12	0	0	13.8
2015	12	27	13	52	22	40	0	0	0	0	0	0	0	34.09	0	0	13.8
2015	12	27	14	2	22	40	0	0	0	0	0	0	0	34.07	0	0	13.8
2015	12	27	14	12	22	40	0	0	0	0	0	0	0	34.07	0	0	13.8
2015	12	27	14	22	22	40	0	0	0	0	0	0	0	34.02	0	0	13.8
2015	12	27	14	32	22	40	0	0	0	0	0	0	0	33.96	0	0	13.8
2015	12	27	14	42	22	39	0	0	0	0	0	0	0	33.93	0	0	13.8
2015	12	27	14	52	22	40	0	0	0	0	0	0	0	33.8	0	0	13.8
2015	12	27	15	2	22	40	0	0	0	0	0	0	0	33.73	0	0	13.8
2015	12	27	15	12	22	40	0	0	0	0	0	0	0	33.62	0	0	13.8
2015	12	27	15	22	22	40	0	0	0	0	0	0	0	33.57	0	0	13.8
2015	12	27	15	32	22	40	0	0	0	0	0	0	0	33.53	0	0	13.8
2015	12	27	15	42	22	39	0	0	0	0	0	0	0	33.51	0	0	13.4
2015	12	27	15	52	22	39	0	0	0	0	0	0	0	33.46	0	0	13.8
2015	12	27	16	2	22	40	0	0	0	0	0	0	0	33.42	0	0	12.4
2015	12	27	16	12	22	40	0	0	0	0	0	0	0	33.4	0	0	12.2
2015	12	27	16	22	22	40	0	0	0	0	0	0	0	33.37	0	0	12.2
2015	12	27	16	32	22	39	0	0	0	0	0	0	0	33.35	0	0	12.2
2015	12	27	16	42	22	40	0	0	0	0	0	0	0	33.33	0	0	12.2
2015	12	27	16	52	22	40	0	0	0	0	0	0	0	33.31	0	0	12.2
2015	12	27	17	2	22	40	0	0	0	0	0	0	0	33.3	0	0	12.2
2015	12	27	17	12	22	40	0	0	0	0	0	0	0	33.3	0	0	12.2
2015	12	27	17	22	22	39	0	0	0	0	0	0	0	33.28	0	0	12.2
2015	12	27	17	32	22	40	0	0	0	0	0	0	0	33.26	0	0	12.2
2015	12	27	17	42	22	40	0	0	0	0	0	0	0	33.26	0	0	12.2
2015	12	27	17	52	22	40	0	0	0	0	0	0	0	33.24	0	0	12.2
2015	12	27	18	2	22	39	0	0	0	0	0	0	0	33.22	0	0	12.2
2015	12	27	18	12	22	40	0	0	0	0	0	0	0	33.22	0	0	12.2
2015	12	27	18	22	22	40	0	0	0	0	0	0	0	33.21	0	0	12.2
2015	12	27	18	32	22	39	0	0	0	0	0	0	0	33.21	0	0	12
2015	12	27	18	42	22	39	0	0	0	0	0	0	0	33.19	0	0	12.2
2015	12	27	18	52	22	40	0	0	0	0	0	0	0	33.19	0	0	12
2015	12	27	19	2	22	40	0	0	0	0	0	0	0	33.19	0	0	12
2015	12	27	19	12	22	40	0	0	0	0	0	0	0	33.17	0	0	12
2015	12	27	19	22	22	39	0	0	0	0	0	0	0	33.15	0	0	12
2015	12	27	19	32	22	40	0	0	0	0	0	0	0	33.15	0	0	12
2015	12	27	19	42	22	40	0	0	0	0	0	0	0	33.13	0	0	12
2015	12	27	19	52	22	39	0	0	0	0	0	0	0	33.13	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	20	2	22	39	0	0	0	0	0	0	0	33.12	0	0	12
2015	12	27	20	12	22	39	0	0	0	0	0	0	0	33.1	0	0	12
2015	12	27	20	22	22	40	0	0	0	0	0	0	0	33.08	0	0	12
2015	12	27	20	32	22	40	0	0	0	0	0	0	0	33.06	0	0	12
2015	12	27	20	42	22	40	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	27	20	52	22	40	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	27	21	2	22	39	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	27	21	12	22	40	0	0	0	0	0	0	0	32.99	0	0	12
2015	12	27	21	22	22	39	0	0	0	0	0	0	0	32.97	0	0	12
2015	12	27	21	32	22	39	0	0	0	0	0	0	0	32.94	0	0	12
2015	12	27	21	42	22	39	0	0	0	0	0	0	0	32.92	0	0	12
2015	12	27	21	52	22	40	0	0	0	0	0	0	0	32.92	0	0	12
2015	12	27	22	2	22	40	0	0	0	0	0	0	0	32.88	0	0	12
2015	12	27	22	12	22	40	0	0	0	0	0	0	0	32.86	0	0	12
2015	12	27	22	22	22	40	0	0	0	0	0	0	0	32.83	0	0	12
2015	12	27	22	32	22	39	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	27	22	42	22	40	0	0	0	0	0	0	0	32.79	0	0	12
2015	12	27	22	52	22	40	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	27	23	2	22	40	0	0	0	0	0	0	0	32.76	0	0	12
2015	12	27	23	12	22	40	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	27	23	22	22	40	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	27	23	32	22	38	0	0	0	0	0	0	0	32.65	0	0	12
2015	12	27	23	42	22	40	0	0	0	0	0	0	0	32.63	0	0	12
2015	12	27	23	52	22	40	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	28	0	2	22	40	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	28	0	12	22	40	0	0	0	0	0	0	0	32.54	0	0	12
2015	12	28	0	22	22	40	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	28	0	32	22	39	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	28	0	42	22	39	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	28	0	52	22	40	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	28	1	2	22	40	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	28	1	12	22	39	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	28	1	22	22	40	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	28	1	32	22	40	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	28	1	42	22	40	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	28	1	52	22	39	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	28	2	2	22	40	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	28	2	12	22	39	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	28	2	22	22	39	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	28	2	32	22	39	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	28	2	42	22	40	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	28	2	52	22	40	0	0	0	0	0	0	0	32.2	0	0	11.8
2015	12	28	3	2	22	40	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	28	3	12	22	40	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	28	3	22	22	40	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	28	3	32	22	40	0	0	0	0	0	0	0	32.14	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	3	42	22	39	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	28	3	52	22	40	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	28	4	2	22	40	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	28	4	12	22	40	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	28	4	22	22	40	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	28	4	32	22	41	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	28	4	42	22	40	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	28	4	52	22	39	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	28	5	2	22	40	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	28	5	12	22	41	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	28	5	22	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	28	5	32	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	28	5	42	22	40	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	28	5	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	28	6	2	22	39	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	28	6	12	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	28	6	22	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	28	6	32	22	39	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	28	6	42	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	28	6	52	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	28	7	2	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	28	7	12	22	40	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	28	7	22	22	40	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	28	7	32	22	40	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	28	7	42	22	40	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	28	7	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.6
2015	12	28	8	2	22	40	0	0	0	0	0	0	0	32.07	0	0	13.2
2015	12	28	8	12	22	39	0	0	0	0	0	0	0	32.09	0	0	13.6
2015	12	28	8	22	22	40	0	0	0	0	0	0	0	32.13	0	0	13.8
2015	12	28	8	32	22	40	0	0	0	0	0	0	0	32.25	0	0	14.2
2015	12	28	8	42	22	40	0	0	0	0	0	0	0	32.27	0	0	14.2
2015	12	28	8	52	22	40	0	0	0	0	0	0	0	32.36	0	0	14.2
2015	12	28	9	2	22	40	0	0	0	0	0	0	0	32.52	0	0	14.2
2015	12	28	9	12	22	40	0	0	0	0	0	0	0	32.59	0	0	14.2
2015	12	28	9	22	22	40	0	0	0	0	0	0	0	32.67	0	0	14.2
2015	12	28	9	32	22	39	0	0	0	0	0	0	0	32.76	0	0	14.2
2015	12	28	9	42	22	40	0	0	0	0	0	0	0	32.81	0	0	14.2
2015	12	28	9	52	22	40	0	0	0	0	0	0	0	32.85	0	0	14
2015	12	28	10	2	22	40	0	0	0	0	0	0	0	32.92	0	0	14
2015	12	28	10	12	22	40	0	0	0	0	0	0	0	32.99	0	0	14
2015	12	28	10	22	22	39	0	0	0	0	0	0	0	33.08	0	0	14
2015	12	28	10	32	22	40	0	0	0	0	0	0	0	33.1	0	0	14
2015	12	28	10	42	22	40	0	0	0	0	0	0	0	33.17	0	0	14
2015	12	28	10	52	22	40	0	0	0	0	0	0	0	33.19	0	0	14
2015	12	28	11	2	22	40	0	0	0	0	0	0	0	33.24	0	0	14
2015	12	28	11	12	22	39	0	0	0	0	0	0	0	33.28	0	0	14

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	11	22	22	40	0	0	0	0	0	0	0	33.42	0	0	14
2015	12	28	11	32	22	40	0	0	0	0	0	0	0	33.21	0	0	13.8
2015	12	28	11	42	22	39	0	0	0	0	0	0	0	32.99	0	0	14
2015	12	28	11	52	22	40	0	0	0	0	0	0	0	33.04	0	0	14
2015	12	28	12	2	22	40	0	0	0	0	0	0	0	33.04	0	0	14
2015	12	28	12	12	22	40	0	0	0	0	0	0	0	32.92	0	0	14
2015	12	28	12	22	22	40	0	0	0	0	0	0	0	32.92	0	0	14
2015	12	28	12	32	22	40	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	28	12	42	22	40	0	0	0	0	0	0	0	32.9	0	0	14
2015	12	28	12	52	22	40	0	0	0	0	0	0	0	32.77	0	0	14
2015	12	28	13	2	22	40	0	0	0	0	0	0	0	32.63	0	0	13.8
2015	12	28	13	12	22	40	0	0	0	0	0	0	0	32.52	0	0	12.6
2015	12	28	13	22	22	40	0	0	0	0	0	0	0	32.43	0	0	12.6
2015	12	28	13	32	22	40	0	0	0	0	0	0	0	32.34	0	0	12.4
2015	12	28	13	42	22	40	0	0	0	0	0	0	0	32.34	0	0	12.8
2015	12	28	13	52	22	40	0	0	0	0	0	0	0	32.52	0	0	14
2015	12	28	14	2	22	40	0	0	0	0	0	0	0	32.54	0	0	14
2015	12	28	14	12	22	40	0	0	0	0	0	0	0	32.47	0	0	13.8
2015	12	28	14	22	22	40	0	0	0	0	0	0	0	32.38	0	0	12.6
2015	12	28	14	32	22	40	0	0	0	0	0	0	0	32.29	0	0	12.4
2015	12	28	14	42	22	40	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	28	14	52	22	39	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	28	15	2	22	40	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	28	15	12	22	39	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	28	15	22	22	39	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	28	15	32	22	40	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	28	15	42	22	40	0	0	0	0	0	0	0	32.22	0	0	12.4
2015	12	28	15	52	22	40	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	28	16	2	22	40	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	28	16	12	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	28	16	22	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	28	16	32	22	39	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	28	16	42	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	28	16	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	28	17	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	28	17	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	28	17	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	28	17	32	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	28	17	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	28	17	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	28	18	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	28	18	12	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	18	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	18	32	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	18	42	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	18	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	19	2	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	19	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	19	22	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	19	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	19	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	19	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	20	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	28	20	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	20	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	20	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	20	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	20	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	21	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	22	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	22	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	22	22	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	28	22	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	22	42	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	22	52	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	23	2	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	23	12	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	23	22	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	23	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	28	23	42	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	28	23	52	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	0	2	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	0	12	22	39	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	0	22	22	39	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	0	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	29	0	42	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	0	52	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	1	2	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	1	12	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	1	22	22	39	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	1	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	1	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	29	1	52	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	2	2	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	2	12	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	2	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	2	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	2	42	22	39	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	2	52	22	45	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	3	2	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	3	12	22	39	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	3	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	3	32	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	3	42	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	3	52	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	4	2	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	4	12	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	4	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	4	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	4	42	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	4	52	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	5	2	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	5	12	22	39	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	5	22	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	5	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	5	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	5	52	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	6	2	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	6	12	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	6	22	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	6	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	29	6	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	6	52	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	7	2	22	39	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	7	12	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	7	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	29	7	32	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	29	7	42	22	40	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	29	7	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12.4
2015	12	29	8	2	22	40	0	0	0	0	0	0	0	32.11	0	0	12.8
2015	12	29	8	12	22	40	0	0	0	0	0	0	0	32.14	0	0	13
2015	12	29	8	22	22	40	0	0	0	0	0	0	0	32.18	0	0	13.2
2015	12	29	8	32	22	40	0	0	0	0	0	0	0	32.23	0	0	13.2
2015	12	29	8	42	22	40	0	0	0	0	0	0	0	32.31	0	0	13.2
2015	12	29	8	52	22	40	0	0	0	0	0	0	0	32.41	0	0	13.4
2015	12	29	9	2	22	40	0	0	0	0	0	0	0	32.59	0	0	13.4
2015	12	29	9	12	22	40	0	0	0	0	0	0	0	32.58	0	0	13.8
2015	12	29	9	22	22	40	0	0	0	0	0	0	0	32.61	0	0	14
2015	12	29	9	32	22	39	0	0	0	0	0	0	0	32.76	0	0	14
2015	12	29	9	42	22	40	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	29	9	52	22	40	0	0	0	0	0	0	0	32.76	0	0	14
2015	12	29	10	2	22	40	0	0	0	0	0	0	0	32.77	0	0	14
2015	12	29	10	12	22	40	0	0	0	0	0	0	0	32.79	0	0	14

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	10	22	22	40	0	0	0	0	0	0	0	32.81	0	0	14
2015	12	29	10	32	22	40	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	29	10	42	22	40	0	0	0	0	0	0	0	32.9	0	0	14
2015	12	29	10	52	22	40	0	0	0	0	0	0	0	32.99	0	0	14
2015	12	29	11	2	22	39	0	0	0	0	0	0	0	33.13	0	0	14
2015	12	29	11	12	22	39	0	0	0	0	0	0	0	33.21	0	0	14
2015	12	29	11	22	22	40	0	0	0	0	0	0	0	33.22	0	0	14
2015	12	29	11	32	22	40	0	0	0	0	0	0	0	33.28	0	0	14
2015	12	29	11	42	22	40	0	0	0	0	0	0	0	33.28	0	0	14
2015	12	29	11	52	22	39	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	29	12	2	22	40	0	0	0	0	0	0	0	33.33	0	0	14
2015	12	29	12	12	22	39	0	0	0	0	0	0	0	33.33	0	0	14
2015	12	29	12	22	22	39	0	0	0	0	0	0	0	33.31	0	0	14
2015	12	29	12	32	22	40	0	0	0	0	0	0	0	33.24	0	0	14
2015	12	29	12	42	22	40	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	29	12	52	22	40	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	29	13	2	22	40	0	0	0	0	0	0	0	33.28	0	0	14
2015	12	29	13	12	22	40	0	0	0	0	0	0	0	33.26	0	0	14
2015	12	29	13	22	22	40	0	0	0	0	0	0	0	33.22	0	0	14
2015	12	29	13	32	22	40	0	0	0	0	0	0	0	33.19	0	0	13.8
2015	12	29	13	42	22	40	0	0	0	0	0	0	0	33.13	0	0	13.8
2015	12	29	13	52	22	39	0	0	0	0	0	0	0	33.1	0	0	13.8
2015	12	29	14	2	22	40	0	0	0	0	0	0	0	33.08	0	0	13.8
2015	12	29	14	12	22	39	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	29	14	22	22	40	0	0	0	0	0	0	0	32.92	0	0	13.8
2015	12	29	14	32	22	40	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	29	14	42	22	40	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	29	14	52	22	40	0	0	0	0	0	0	0	32.72	0	0	13.8
2015	12	29	15	2	22	40	0	0	0	0	0	0	0	32.59	0	0	13.8
2015	12	29	15	12	22	40	0	0	0	0	0	0	0	32.43	0	0	13.8
2015	12	29	15	22	22	40	0	0	0	0	0	0	0	32.34	0	0	13.8
2015	12	29	15	32	22	40	0	0	0	0	0	0	0	32.29	0	0	13.8
2015	12	29	15	42	22	40	0	0	0	0	0	0	0	32.25	0	0	13.8
2015	12	29	15	52	22	40	0	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	29	16	2	22	40	0	0	0	0	0	0	0	32.2	0	0	12.8
2015	12	29	16	12	22	40	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	29	16	22	22	40	0	0	0	0	0	0	0	32.16	0	0	12.2
2015	12	29	16	32	22	39	0	0	0	0	0	0	0	32.14	0	0	12.2
2015	12	29	16	42	22	40	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	29	16	52	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	29	17	2	22	40	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	29	17	12	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	29	17	22	22	39	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	29	17	32	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	29	17	42	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	29	17	52	22	40	0	0	0	0	0	0	0	32.09	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	18	2	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	29	18	12	22	40	0	0	0	0	0	0	0	32.07	0	0	12.2
2015	12	29	18	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	29	18	32	22	40	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	29	18	42	22	40	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	29	18	52	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	2	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	12	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	22	22	40	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	32	22	39	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	42	22	39	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	29	19	52	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	29	20	2	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	29	20	12	22	40	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	29	20	22	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	29	20	32	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	29	20	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	29	20	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	29	21	2	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	29	21	12	22	39	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	29	21	22	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	21	32	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	21	42	22	40	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	29	21	52	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	22	2	22	40	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	22	12	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	22	22	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	22	32	22	39	0	0	0	0	0	0	0	32	0	0	12
2015	12	29	22	42	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	22	52	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	23	2	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	29	23	12	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	23	22	22	40	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	29	23	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	29	23	42	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	29	23	52	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	30	0	2	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	30	0	12	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	30	0	22	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	30	0	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	0	42	22	40	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	30	0	52	22	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	1	2	22	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	1	12	22	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	1	22	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	1	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	1	42	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	1	52	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	2	2	22	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	2	12	22	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	2	22	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	2	32	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	2	42	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	2	52	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	3	2	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	3	12	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	3	22	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	3	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	3	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	3	52	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	4	2	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	4	12	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	4	22	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	4	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	4	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	4	52	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	5	2	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	5	12	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	5	22	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	5	32	22	40	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	30	5	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	5	52	22	39	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	6	2	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	6	12	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	6	22	22	41	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	6	32	22	40	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	30	6	42	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	6	52	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	7	2	22	40	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	30	7	12	22	40	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	30	7	22	22	40	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	30	7	32	22	40	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	30	7	42	22	39	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	30	7	52	22	39	0	0	0	0	0	0	0	32.04	0	0	12.4
2015	12	30	8	2	22	40	0	0	0	0	0	0	0	32.05	0	0	13
2015	12	30	8	12	22	39	0	0	0	0	0	0	0	32.09	0	0	13.4
2015	12	30	8	22	22	40	0	0	0	0	0	0	0	32.14	0	0	13.8
2015	12	30	8	32	22	40	0	0	0	0	0	0	0	32.23	0	0	14.2
2015	12	30	8	42	22	40	0	0	0	0	0	0	0	32.27	0	0	14.2
2015	12	30	8	52	22	40	0	0	0	0	0	0	0	32.38	0	0	14.2
2015	12	30	9	2	22	40	0	0	0	0	0	0	0	32.49	0	0	14.2
2015	12	30	9	12	22	40	0	0	0	0	0	0	0	32.58	0	0	14.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	9	22	22	39	0	0	0	0	0	0	0	32.7	0	0	14.2
2015	12	30	9	32	22	40	0	0	0	0	0	0	0	32.7	0	0	14.2
2015	12	30	9	42	22	40	0	0	0	0	0	0	0	32.74	0	0	14.2
2015	12	30	9	52	22	40	0	0	0	0	0	0	0	32.85	0	0	14.2
2015	12	30	10	2	22	40	0	0	0	0	0	0	0	32.81	0	0	14
2015	12	30	10	12	22	40	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	30	10	22	22	40	0	0	0	0	0	0	0	32.83	0	0	14
2015	12	30	10	32	22	39	0	0	0	0	0	0	0	32.97	0	0	14
2015	12	30	10	42	22	39	0	0	0	0	0	0	0	33.01	0	0	14
2015	12	30	10	52	22	40	0	0	0	0	0	0	0	32.94	0	0	14
2015	12	30	11	2	22	39	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	30	11	12	22	40	0	0	0	0	0	0	0	32.94	0	0	14
2015	12	30	11	22	22	40	0	0	0	0	0	0	0	32.97	0	0	14
2015	12	30	11	32	22	39	0	0	0	0	0	0	0	33.06	0	0	14
2015	12	30	11	42	22	40	0	0	0	0	0	0	0	33.21	0	0	14
2015	12	30	11	52	22	40	0	0	0	0	0	0	0	33.3	0	0	14
2015	12	30	12	2	22	40	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	30	12	12	22	39	0	0	0	0	0	0	0	33.26	0	0	13.8
2015	12	30	12	22	22	40	0	0	0	0	0	0	0	33.12	0	0	13.8
2015	12	30	12	32	22	40	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	30	12	42	22	40	0	0	0	0	0	0	0	33.17	0	0	13.8
2015	12	30	12	52	22	40	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	30	13	2	22	40	0	0	0	0	0	0	0	32.95	0	0	13.8
2015	12	30	13	12	22	40	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	30	13	22	22	40	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	30	13	32	22	40	0	0	0	0	0	0	0	32.97	0	0	13.8
2015	12	30	13	42	22	40	0	0	0	0	0	0	0	32.95	0	0	13.8
2015	12	30	13	52	22	40	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	30	14	2	22	39	0	0	0	0	0	0	0	32.85	0	0	13.8
2015	12	30	14	12	22	39	0	0	0	0	0	0	0	32.58	0	0	13.6
2015	12	30	14	33	46	40	100	0	0	0	0	0	0	32.49	0	0	13.4
2015	12	30	14	43	46	40	84	0	0	0	0	0	0	32.38	0	0	13.6
2015	12	30	14	53	46	40	100	0	0	0	0	0	0	32.32	0	0	13.6
2015	12	30	15	3	46	40	100	0	0	0	0	0	0	32.22	0	0	13.6
2015	12	30	15	13	46	39	100	0	0	0	0	0	0	32.11	0	0	13.6
2015	12	30	15	23	46	40	100	0	0	0	0	0	0	32.04	0	0	13.8
2015	12	30	15	33	46	39	100	0	0	0	0	0	0	32	0	0	13.6
2015	12	30	15	43	46	39	100	0	0	0	0	0	0	31.96	0	0	13.8
2015	12	30	15	53	46	39	62	0	0	0	0	0	0	31.95	0	0	13.8
2015	12	30	16	3	46	40	97	0	0	0	0	0	0	31.95	0	0	13.6
2015	12	30	16	13	46	40	100	0	0	0	0	0	0	31.93	0	0	12.4
2015	12	30	16	23	46	40	58	0	0	0	0	0	0	31.91	0	0	12.2
2015	12	30	16	33	46	40	62	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	30	16	43	46	40	53	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	30	16	53	46	40	79	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	30	17	3	46	40	96	0	0	0	0	0	0	31.89	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	17	13	46	40	53	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	30	17	23	46	40	41	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	30	17	33	46	40	100	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	30	17	43	46	40	23	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	30	17	53	46	40	100	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	3	46	40	100	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	13	46	40	100	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	23	46	41	76	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	33	46	40	66	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	43	46	40	81	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	30	18	53	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	19	3	46	40	100	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	19	13	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	19	23	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	19	33	46	39	12	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	19	43	46	40	71	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	19	53	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	20	3	46	40	96	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	20	13	46	40	93	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	20	23	46	40	60	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	20	33	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	20	43	46	40	94	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	20	53	46	41	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	21	3	46	40	96	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	21	13	46	40	87	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	21	23	46	39	72	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	21	33	46	39	42	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	21	43	46	41	71	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	21	53	46	39	88	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	22	3	46	40	71	0	0	0	0	0	0	31.86	0	0	12
2015	12	30	22	13	46	40	73	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	22	23	46	39	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	22	33	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	22	43	46	40	89	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	22	53	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	3	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	13	46	39	66	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	23	46	40	66	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	33	46	40	100	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	43	46	40	68	0	0	0	0	0	0	31.84	0	0	12
2015	12	30	23	53	46	40	95	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	0	3	46	40	64	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	0	13	46	39	110	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	0	23	46	40	145	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	0	33	46	40	115	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	0	43	46	40	150	0	0	0	0	0	0	31.82	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	0	53	46	40	138	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	1	3	46	40	109	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	1	13	46	40	119	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	31	1	23	46	39	122	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	1	33	46	40	136	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	1	43	46	40	163	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	1	53	46	40	94	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	3	46	40	92	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	13	46	40	133	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	23	46	40	122	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	33	46	40	100	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	43	46	40	147	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	2	53	46	40	161	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	3	46	40	133	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	13	46	39	134	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	23	46	39	100	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	33	46	40	131	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	43	46	39	101	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	3	53	46	39	200	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	3	46	40	169	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	13	46	40	186	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	23	46	40	147	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	33	46	40	126	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	43	46	40	135	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	4	53	46	40	184	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	3	46	40	106	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	13	46	39	105	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	23	46	40	105	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	33	46	40	146	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	43	46	40	198	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	5	53	46	40	57	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	6	3	46	40	150	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	6	13	46	40	148	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	6	23	46	40	110	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	31	6	33	46	39	101	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	6	43	46	40	200	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	6	53	46	40	141	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	7	3	46	40	133	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	7	13	46	40	141	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	7	23	46	40	142	0	0	0	0	0	0	31.84	0	0	11.6
2015	12	31	7	33	46	40	171	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	7	43	46	40	106	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	31	7	53	46	40	112	0	0	0	0	0	0	31.86	0	0	12.4
2015	12	31	8	3	46	40	179	0	0	0	0	0	0	31.89	0	0	13
2015	12	31	8	13	46	40	185	0	0	0	0	0	0	31.91	0	0	13.2
2015	12	31	8	23	46	40	139	0	0	0	0	0	0	31.93	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	8	33	46	39	109	0	0	0	0	0	0	31.95	0	0	13.6
2015	12	31	8	43	46	40	92	0	0	0	0	0	0	31.98	0	0	14
2015	12	31	8	53	46	40	157	0	0	0	0	0	0	32.04	0	0	14.2
2015	12	31	9	3	46	40	153	0	0	0	0	0	0	32.07	0	0	14.2
2015	12	31	9	13	46	40	149	0	0	0	0	0	0	32.09	0	0	14
2015	12	31	9	23	46	40	200	0	0	0	0	0	0	32.09	0	0	14
2015	12	31	9	33	46	40	122	0	0	0	0	0	0	32.13	0	0	14
2015	12	31	9	43	46	39	65	0	0	0	0	0	0	32.14	0	0	14
2015	12	31	9	53	46	40	58	0	0	0	0	0	0	32.14	0	0	14
2015	12	31	10	3	46	39	63	0	0	0	0	0	0	32.18	0	0	14
2015	12	31	10	13	46	40	163	0	0	0	0	0	0	32.2	0	0	14
2015	12	31	10	23	46	40	115	0	0	0	0	0	0	32.27	0	0	14
2015	12	31	10	33	46	40	132	0	0	0	0	0	0	32.29	0	0	14
2015	12	31	10	43	46	41	86	0	0	0	0	0	0	32.31	0	0	14
2015	12	31	10	53	46	40	74	0	0	0	0	0	0	32.31	0	0	14
2015	12	31	11	3	46	40	138	0	0	0	0	0	0	32.32	0	0	14
2015	12	31	11	13	46	40	102	0	0	0	0	0	0	32.34	0	0	14
2015	12	31	11	23	46	40	147	0	0	0	0	0	0	32.34	0	0	14
2015	12	31	11	33	46	40	187	0	0	0	0	0	0	32.31	0	0	14
2015	12	31	11	43	46	40	132	0	0	0	0	0	0	32.36	0	0	14
2015	12	31	11	53	46	40	184	0	0	0	0	0	0	32.36	0	0	14
2015	12	31	12	3	46	40	150	0	0	0	0	0	0	32.38	0	0	14
2015	12	31	12	13	46	40	164	0	0	0	0	0	0	32.36	0	0	14
2015	12	31	12	23	46	40	100	0	0	0	0	0	0	32.38	0	0	14
2015	12	31	12	33	46	40	131	0	0	0	0	0	0	32.36	0	0	13.8
2015	12	31	12	43	46	40	195	0	0	0	0	0	0	32.34	0	0	13.8
2015	12	31	12	53	46	39	200	0	0	0	0	0	0	32.32	0	0	13.8
2015	12	31	13	3	46	40	158	0	0	0	0	0	0	32.32	0	0	13.8
2015	12	31	13	13	46	39	133	0	0	0	0	0	0	32.31	0	0	13.8
2015	12	31	13	23	46	40	178	0	0	0	0	0	0	32.29	0	0	13.8
2015	12	31	13	33	46	39	200	0	0	0	0	0	0	32.29	0	0	13.8
2015	12	31	13	43	46	40	143	0	0	0	0	0	0	32.27	0	0	13.8
2015	12	31	13	53	46	40	135	0	0	0	0	0	0	32.25	0	0	13.8
2015	12	31	14	3	46	40	122	0	0	0	0	0	0	32.23	0	0	13.8
2015	12	31	14	13	46	40	200	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	31	14	23	46	40	200	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	31	14	33	46	39	173	0	0	0	0	0	0	32.16	0	0	13.8
2015	12	31	14	43	46	40	138	0	0	0	0	0	0	32.14	0	0	13.8
2015	12	31	14	53	46	40	200	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	31	15	3	46	40	141	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	31	15	13	46	40	156	0	0	0	0	0	0	32	0	0	13.8
2015	12	31	15	23	46	40	156	0	0	0	0	0	0	31.96	0	0	13.8
2015	12	31	15	33	46	43	155	0	0	0	0	0	0	31.95	0	0	13.8
2015	12	31	15	43	46	41	182	0	0	0	0	0	0	31.93	0	0	13.8
2015	12	31	15	53	46	42	117	0	0	0	0	0	0	31.91	0	0	13.8
2015	12	31	16	3	46	42	200	0	0	0	0	0	0	31.89	0	0	13.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	16	13	46	40	194	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	31	16	23	46	40	152	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	31	16	33	46	40	184	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	31	16	43	46	40	167	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	31	16	53	46	41	148	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	31	17	3	46	40	200	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	31	17	13	46	40	73	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	17	23	46	40	147	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	17	33	46	40	169	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	17	43	46	40	200	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	17	53	46	40	200	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	18	3	46	39	200	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	18	13	46	40	164	0	0	0	0	0	0	31.82	0	0	12.2
2015	12	31	18	23	46	40	200	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	18	33	46	40	164	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	18	43	46	40	108	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	18	53	46	40	135	0	0	0	0	0	0	31.82	0	0	12.2
2015	12	31	19	3	46	40	189	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	31	19	13	46	40	111	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	19	23	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	19	33	46	41	200	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	19	43	46	40	200	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	19	53	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	20	3	46	39	151	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	20	13	46	40	104	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	20	23	46	39	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	20	33	46	40	116	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	20	43	46	40	200	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	20	53	46	40	200	0	0	0	0	0	0	31.84	0	0	12
2015	12	31	21	3	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	21	13	46	39	100	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	21	23	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	21	33	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	21	43	46	40	178	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	21	53	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	3	46	40	151	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	13	46	39	144	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	23	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	33	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	43	46	39	168	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	22	53	46	40	163	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	23	3	46	40	135	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	23	13	46	40	156	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	23	23	46	40	200	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	23	33	46	40	122	0	0	0	0	0	0	31.82	0	0	12
2015	12	31	23	43	46	40	167	0	0	0	0	0	0	31.82	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	23	53	46	40	112	0	0	0	0	0	0	31.82	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	0	2	22	0.3	3.9	0.64	104.2	82.5066	48.6378
2015	12	1	0	12	22	0.3	3.9	0.65	102.2	82.5066	49.9177
2015	12	1	0	22	22	0.3	3.9	0.65	102.3	82.5066	49.4057
2015	12	1	0	32	22	0.3	3.9	0.68	99.5	82.5066	51.9656
2015	12	1	0	42	22	0.3	3.9	0.65	101.1	82.5066	49.4058
2015	12	1	0	52	22	0.3	3.9	0.63	99.2	82.5066	48.8938
2015	12	1	1	2	22	0.3	3.9	0.68	102.3	82.5066	51.4537
2015	12	1	1	12	22	0.3	3.9	0.64	102.2	82.5066	48.6378
2015	12	1	1	22	22	0.3	3.9	0.66	102	82.5066	50.6857
2015	12	1	1	32	22	0.3	3.9	0.64	104.2	82.5066	48.6378
2015	12	1	1	42	22	0.3	3.9	0.65	99.9	82.5066	49.6618
2015	12	1	1	52	22	0.3	3.9	0.65	104.4	82.5066	48.8939
2015	12	1	2	2	22	0.3	3.9	0.64	103.9	82.5066	48.6379
2015	12	1	2	12	22	0.3	3.9	0.66	103.1	82.5066	50.4298
2015	12	1	2	22	22	0.3	3.9	0.64	100.9	82.5066	49.1499
2015	12	1	2	32	22	0.3	3.9	0.67	104.4	82.5066	50.6858
2015	12	1	2	42	22	0.3	3.9	0.66	101.5	82.5066	50.4298
2015	12	1	2	52	22	0.3	3.9	0.65	100.2	82.5066	49.9179
2015	12	1	3	2	22	0.3	3.9	0.64	103	82.5066	48.6379
2015	12	1	3	12	22	0.3	3.9	0.66	103.1	82.5066	50.4299
2015	12	1	3	22	22	0.3	3.9	0.65	101.6	82.5066	49.9179
2015	12	1	3	32	22	0.3	3.9	0.69	102.6	82.5066	52.7338
2015	12	1	3	42	22	0.3	3.9	0.67	103.7	82.5066	50.4299
2015	12	1	3	52	22	0.3	3.9	0.66	103.3	82.5066	49.9179
2015	12	1	4	2	22	0.3	3.9	0.64	104	82.5066	48.126
2015	12	1	4	12	22	0.3	3.9	0.63	101.5	82.5066	47.87
2015	12	1	4	22	22	0.3	3.9	0.66	104.3	82.5066	50.1739
2015	12	1	4	32	22	0.3	3.9	0.66	104.5	82.5066	49.6619
2015	12	1	4	42	22	0.3	3.9	0.65	101.4	82.5066	49.406
2015	12	1	4	52	22	0.3	3.9	0.66	102.9	82.5066	50.4299
2015	12	1	5	2	22	0.3	3.9	0.68	103.3	82.5066	51.9659
2015	12	1	5	12	22	0.3	3.9	0.65	103.6	82.5066	49.662
2015	12	1	5	22	22	0.3	3.9	0.64	101.2	82.4409	49.1094
2015	12	1	5	32	22	0.3	3.9	0.66	104.1	82.4409	49.8767
2015	12	1	5	42	22	0.3	3.9	0.63	104	82.5066	47.3581
2015	12	1	5	52	22	0.3	3.9	0.64	102.5	82.5066	48.3821
2015	12	1	6	2	22	0.3	3.9	0.66	102.4	82.4409	49.8768
2015	12	1	6	12	22	0.3	3.9	0.67	104.6	82.5066	50.942
2015	12	1	6	22	22	0.3	3.9	0.65	101.4	82.4409	49.621
2015	12	1	6	32	22	0.3	3.9	0.66	102.1	82.4409	50.1326
2015	12	1	6	42	22	0.3	3.9	0.64	101.3	82.5066	48.6381
2015	12	1	6	52	22	0.3	3.9	0.67	102.1	82.5066	51.198
2015	12	1	7	2	22	0.3	3.9	0.66	103.3	82.5066	49.918
2015	12	1	7	12	22	0.3	3.9	0.65	101.6	82.5066	49.918
2015	12	1	7	22	22	0.3	3.9	0.67	100.2	82.5066	51.454
2015	12	1	7	32	22	0.3	3.9	0.66	101.8	82.5066	50.43

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	7	42	22	0.3	3.9	0.69	103	82.5066	52.2219
2015	12	1	7	52	22	0.3	3.9	0.65	99.7	82.5066	49.662
2015	12	1	8	2	22	0.3	3.9	0.66	102.3	82.5066	50.6859
2015	12	1	8	12	22	0.3	3.9	0.67	99.9	82.5066	51.4538
2015	12	1	8	22	22	0.3	3.9	0.64	100	82.5066	49.1499
2015	12	1	8	32	22	0.3	3.9	0.63	102.3	82.5722	48.1657
2015	12	1	8	42	22	0.3	3.9	0.65	101.9	82.5722	49.7028
2015	12	1	8	52	22	0.3	3.9	0.65	101.7	82.5722	49.7028
2015	12	1	9	2	22	0.3	3.9	0.64	101.3	82.5722	48.9342
2015	12	1	9	12	22	0.3	3.9	0.64	101.5	82.5722	48.9341
2015	12	1	9	22	22	0.3	3.9	0.66	101.7	82.5722	50.7275
2015	12	1	9	32	22	0.3	3.9	0.65	102.2	82.5722	49.9589
2015	12	1	9	42	22	0.3	3.9	0.65	100.7	82.5722	49.9588
2015	12	1	9	52	22	0.3	3.9	0.64	101.2	82.5722	49.1902
2015	12	1	10	2	22	0.3	3.9	0.68	104.3	82.6378	51.2821
2015	12	1	10	12	22	0.3	3.9	0.66	102.9	82.6378	50.5128
2015	12	1	10	22	22	0.3	3.9	0.64	102.3	82.6378	49.2307
2015	12	1	10	32	22	0.3	3.9	0.65	101.6	82.6378	49.9999
2015	12	1	10	42	22	0.3	3.9	0.65	102.6	82.6378	49.2307
2015	12	1	10	52	22	0.3	3.9	0.66	102.1	82.6378	50.2563
2015	12	1	11	2	22	0.3	3.9	0.63	102.4	82.6378	47.9486
2015	12	1	11	12	22	0.3	3.9	0.66	99.8	82.6378	50.5127
2015	12	1	11	22	22	0.3	3.9	0.62	102.6	82.6378	47.1794
2015	12	1	11	32	22	0.3	3.9	0.64	101.8	82.6378	49.2306
2015	12	1	11	42	22	0.3	3.9	0.64	101.2	82.6378	49.2306
2015	12	1	11	52	22	0.3	3.9	0.66	101	82.6378	50.2562
2015	12	1	12	2	22	0.3	3.9	0.64	102.5	82.6378	48.4614
2015	12	1	12	12	22	0.3	3.9	0.63	102.7	82.6378	47.6922
2015	12	1	12	22	22	0.3	3.9	0.65	104.1	82.6378	48.9743
2015	12	1	12	32	22	0.3	3.9	0.66	99.8	82.7034	50.5543
2015	12	1	12	42	22	0.3	3.9	0.64	101	82.6378	48.9742
2015	12	1	12	52	22	0.3	3.9	0.64	102.3	82.6378	49.2306
2015	12	1	13	2	22	0.3	3.9	0.62	102	82.6378	47.1793
2015	12	1	13	12	22	0.3	3.9	0.64	102.3	82.6378	49.2306
2015	12	1	13	22	22	0.3	3.9	0.65	99.9	82.6378	49.7434
2015	12	1	13	32	22	0.3	3.9	0.65	103.7	82.6378	49.4871
2015	12	1	13	42	22	0.3	3.9	0.64	101.3	82.6378	48.7178
2015	12	1	13	52	22	0.3	3.9	0.67	100.5	82.6378	51.2819
2015	12	1	14	2	22	0.3	3.9	0.64	103	82.6378	48.9743
2015	12	1	14	12	22	0.3	3.9	0.65	102.8	82.6378	49.4871
2015	12	1	14	22	22	0.3	3.9	0.68	100.1	82.5722	52.0083
2015	12	1	14	32	22	0.3	3.9	0.63	100.5	82.5722	48.4216
2015	12	1	14	42	22	0.3	3.9	0.61	101.7	82.5722	46.8844
2015	12	1	14	52	22	0.3	3.9	0.68	100	82.5722	52.2647
2015	12	1	15	2	22	0.3	3.9	0.63	100.8	82.5066	48.1258
2015	12	1	15	12	22	0.3	3.9	0.65	100.8	82.5066	49.6618

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	15	22	22	0.3	3.9	0.66	101	82.5066	50.1737
2015	12	1	15	32	22	0.3	3.9	0.65	101.7	82.5066	49.6618
2015	12	1	15	42	22	0.3	3.9	0.65	102.2	82.5066	49.9178
2015	12	1	15	52	22	0.3	3.9	0.66	99.1	82.5066	51.1977
2015	12	1	16	2	22	0.3	3.9	0.66	101.4	82.5066	50.6857
2015	12	1	16	12	22	0.3	3.9	0.62	101.7	82.5066	47.1019
2015	12	1	16	22	22	0.3	3.9	0.64	100.4	82.5066	48.8938
2015	12	1	16	32	22	0.3	3.9	0.65	99.9	82.5066	49.6618
2015	12	1	16	42	22	0.3	3.9	0.64	102.5	82.5066	48.6378
2015	12	1	16	52	22	0.3	3.9	0.66	100.8	82.5066	50.9417
2015	12	1	17	2	22	0.3	3.9	0.65	101.4	82.5066	49.4058
2015	12	1	17	12	22	0.3	3.9	0.65	101.1	82.5066	49.6618
2015	12	1	17	22	22	0.3	3.9	0.68	100.6	82.5066	52.2217
2015	12	1	17	32	22	0.3	3.9	0.65	103.3	82.5066	49.6618
2015	12	1	17	42	22	0.3	3.9	0.67	100.8	82.5066	51.1977
2015	12	1	17	52	22	0.3	3.9	0.6	100.9	82.5066	46.3339
2015	12	1	18	2	22	0.3	3.9	0.64	103.4	82.5066	48.3819
2015	12	1	18	12	22	0.3	3.9	0.65	100.5	82.5066	49.6618
2015	12	1	18	22	22	0.3	3.9	0.66	104.2	82.5066	49.6618
2015	12	1	18	32	22	0.3	3.9	0.62	100.6	82.5066	47.8699
2015	12	1	18	42	22	0.3	3.9	0.64	100.1	82.5066	48.8938
2015	12	1	18	52	22	0.3	3.9	0.64	106.8	82.5066	47.6139
2015	12	1	19	2	22	0.3	3.9	0.66	100.9	82.5066	50.6857
2015	12	1	19	12	22	0.3	3.9	0.68	102.8	82.5066	51.9657
2015	12	1	19	22	22	0.3	3.9	0.66	103.3	82.5066	49.9178
2015	12	1	19	32	22	0.3	3.9	0.67	101.5	82.5066	51.4537
2015	12	1	19	42	22	0.3	3.9	0.65	101.4	82.5066	49.4058
2015	12	1	19	52	22	0.3	3.9	0.64	101.3	82.5066	48.6378
2015	12	1	20	2	22	0.3	3.9	0.63	103.2	82.5066	48.1259
2015	12	1	20	12	22	0.3	3.9	0.66	103.9	82.5066	49.6618
2015	12	1	20	22	22	0.3	3.9	0.65	98.1	82.5066	50.1738
2015	12	1	20	32	22	0.3	3.9	0.6	102.6	82.5066	45.822
2015	12	1	20	42	22	0.3	3.9	0.64	101	82.5066	48.6378
2015	12	1	20	52	22	0.3	3.9	0.66	103.1	82.5066	50.4298
2015	12	1	21	2	22	0.3	3.9	0.6	100.9	82.5066	46.3339
2015	12	1	21	12	22	0.3	3.9	0.64	101.3	82.5066	48.8938
2015	12	1	21	22	22	0.3	3.9	0.66	100.9	82.5066	50.6857
2015	12	1	21	32	22	0.3	3.9	0.61	104.3	82.5066	46.0779
2015	12	1	21	42	22	0.3	3.9	0.63	102.1	82.5066	47.8699
2015	12	1	21	52	22	0.3	3.9	0.64	101.8	82.5066	49.1498
2015	12	1	22	2	22	0.3	3.9	0.65	102.8	82.5066	49.6618
2015	12	1	22	12	22	0.3	3.9	0.62	100.6	82.5066	47.8699
2015	12	1	22	22	22	0.3	3.9	0.63	101.2	82.5066	47.8699
2015	12	1	22	32	22	0.3	3.9	0.65	100.2	82.5066	49.6618
2015	12	1	22	42	22	0.3	3.9	0.67	103.1	82.5066	50.6858
2015	12	1	22	52	22	0.3	3.9	0.64	102.1	82.5066	48.8939

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	23	2	22	0.3	3.9	0.66	102	82.5066	50.4298
2015	12	1	23	12	22	0.3	3.9	0.64	100.1	82.5066	48.8939
2015	12	1	23	22	22	0.3	3.9	0.63	101.9	82.5066	48.3819
2015	12	1	23	32	22	0.3	3.9	0.64	101.2	82.5066	49.1499
2015	12	1	23	42	22	0.3	3.9	0.61	100.8	82.5066	47.102
2015	12	1	23	52	22	0.3	3.9	0.64	102.4	82.5066	48.8939
2015	12	2	0	2	22	0.3	3.9	0.66	102.4	82.5066	49.9179
2015	12	2	0	12	22	0.3	3.9	0.64	101.8	82.5066	49.1499
2015	12	2	0	22	22	0.3	3.9	0.65	101.7	82.5066	49.6619
2015	12	2	0	32	22	0.3	3.9	0.65	100.5	82.5066	49.6619
2015	12	2	0	42	22	0.3	3.9	0.62	103.5	82.5066	46.846
2015	12	2	0	52	22	0.3	3.9	0.67	105.7	82.5066	50.1739
2015	12	2	1	2	22	0.3	3.9	0.62	100.6	82.5066	47.87
2015	12	2	1	12	22	0.3	3.9	0.66	103.9	82.5066	49.6619
2015	12	2	1	22	22	0.3	3.9	0.65	103.2	82.5066	49.15
2015	12	2	1	32	22	0.3	3.9	0.64	102.5	82.5066	48.382
2015	12	2	1	42	22	0.3	3.9	0.66	102.3	82.5066	50.4299
2015	12	2	1	52	22	0.3	3.9	0.64	101.6	82.5066	48.638
2015	12	2	2	2	22	0.3	3.9	0.65	102.8	82.5066	49.662
2015	12	2	2	12	22	0.3	3.9	0.64	101.3	82.5066	48.638
2015	12	2	2	22	22	0.3	3.9	0.65	101.4	82.5066	49.406
2015	12	2	2	32	22	0.3	3.9	0.63	102.1	82.5066	47.8701
2015	12	2	2	42	22	0.3	3.9	0.66	101.3	82.5066	50.174
2015	12	2	2	52	22	0.3	3.9	0.6	104.2	82.5066	45.5662
2015	12	2	3	2	22	0.3	3.9	0.64	103.7	82.5066	48.3821
2015	12	2	3	12	22	0.3	3.9	0.65	101.1	82.5066	49.406
2015	12	2	3	22	22	0.3	3.9	0.63	101.9	82.5066	48.3821
2015	12	2	3	32	22	0.3	3.9	0.63	104.8	82.5722	47.3972
2015	12	2	3	42	22	0.3	3.9	0.63	102.2	82.5066	48.3821
2015	12	2	3	52	22	0.3	3.9	0.62	101.6	82.5722	47.3972
2015	12	2	4	2	22	0.3	3.9	0.62	100.7	82.5722	47.6534
2015	12	2	4	12	22	0.3	3.9	0.65	103.2	82.5722	49.1907
2015	12	2	4	22	22	0.3	3.9	0.62	102.6	82.5066	46.8462
2015	12	2	4	32	22	0.3	3.9	0.64	100.7	82.5722	48.9345
2015	12	2	4	42	22	0.3	3.9	0.63	101.4	82.5722	48.1659
2015	12	2	4	52	22	0.3	3.9	0.64	100	82.5722	49.4469
2015	12	2	5	2	22	0.3	3.9	0.66	101.3	82.5722	50.2155
2015	12	2	5	12	22	0.3	3.9	0.66	103.2	82.5722	50.2155
2015	12	2	5	22	22	0.3	3.9	0.66	102	82.5722	50.4717
2015	12	2	5	32	22	0.3	3.9	0.61	102	82.5722	46.8849
2015	12	2	5	42	22	0.3	3.9	0.63	104	82.5722	47.3973
2015	12	2	5	52	22	0.3	3.9	0.65	101.1	82.5722	49.4469
2015	12	2	6	2	22	0.3	3.9	0.66	102.3	82.5722	50.7279
2015	12	2	6	12	22	0.3	3.9	0.64	104.3	82.5722	48.4221
2015	12	2	6	22	22	0.3	3.9	0.67	101	82.5722	51.4965
2015	12	2	6	32	22	0.3	3.9	0.66	103.3	82.5722	49.9593

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	6	42	22	0.3	3.9	0.66	102.1	82.5722	50.2155
2015	12	2	6	52	22	0.3	3.9	0.69	102.4	82.5722	52.2651
2015	12	2	7	2	22	0.3	3.9	0.63	101.2	82.6378	47.9492
2015	12	2	7	12	22	0.3	3.9	0.67	102.7	82.6378	51.0262
2015	12	2	7	22	22	0.3	3.9	0.66	100.1	82.6378	50.5134
2015	12	2	7	32	22	0.3	3.9	0.67	102.7	82.6378	51.2826
2015	12	2	7	42	22	0.3	3.9	0.64	100	82.6378	49.4877
2015	12	2	7	52	22	0.3	3.9	0.66	102.4	82.6378	50.0004
2015	12	2	8	2	22	0.3	3.9	0.64	102.4	82.7034	49.0152
2015	12	2	8	12	22	0.3	3.9	0.63	100.2	82.7034	48.5019
2015	12	2	8	22	22	0.3	3.9	0.65	101.1	82.7034	49.785
2015	12	2	8	32	22	0.3	3.9	0.66	100.3	82.7034	50.8114
2015	12	2	8	42	22	0.3	3.9	0.64	103.5	82.7034	49.015
2015	12	2	8	52	22	0.3	3.9	0.64	104	82.7034	48.2451
2015	12	2	9	2	22	0.3	3.9	0.66	102.7	82.7034	50.2981
2015	12	2	9	12	22	0.3	3.9	0.63	103	82.769	47.7712
2015	12	2	9	22	22	0.3	3.9	0.65	103.6	82.769	49.8258
2015	12	2	9	32	22	0.3	3.9	0.61	101.2	82.769	46.7438
2015	12	2	9	42	22	0.3	3.9	0.61	99.9	82.769	47.2574
2015	12	2	9	52	22	0.3	3.9	0.58	100.7	82.769	44.689
2015	12	2	10	2	22	0.3	3.9	0.66	103.1	82.769	50.5961
2015	12	2	10	12	22	0.3	3.9	0.65	103.5	82.769	49.312
2015	12	2	10	22	22	0.3	3.9	0.68	102.3	82.769	51.8803
2015	12	2	10	32	22	0.3	3.9	0.64	100.1	82.769	49.0551
2015	12	2	10	42	22	0.3	3.9	0.66	102.4	82.769	50.0824
2015	12	2	10	52	22	0.3	3.9	0.65	100.8	82.769	49.8255
2015	12	2	11	2	22	0.3	3.9	0.66	103.2	82.8347	50.3806
2015	12	2	11	12	22	0.3	3.9	0.63	102.3	82.769	48.2846
2015	12	2	11	22	22	0.3	3.9	0.66	99.8	82.769	50.596
2015	12	2	11	32	22	0.3	3.9	0.59	100.9	82.769	45.2025
2015	12	2	11	42	22	0.3	3.9	0.62	99.5	82.769	47.7709
2015	12	2	11	52	22	0.3	3.9	0.6	98.7	82.769	46.7435
2015	12	2	12	2	22	0.3	3.9	0.68	100.6	82.769	52.1371
2015	12	2	12	12	22	0.3	3.9	0.66	102.9	82.769	50.5961
2015	12	2	12	22	22	0.3	3.9	0.65	101.3	82.769	50.0825
2015	12	2	12	32	22	0.3	3.9	0.64	100.9	82.769	49.3119
2015	12	2	12	42	22	0.3	3.9	0.64	104.3	82.769	48.5414
2015	12	2	12	52	22	0.3	3.9	0.62	99.4	82.769	48.0278
2015	12	2	13	2	22	0.3	3.9	0.62	102.9	82.769	47.2573
2015	12	2	13	12	22	0.3	3.9	0.63	100.7	82.769	48.7983
2015	12	2	13	22	22	0.3	3.9	0.67	101.9	82.769	51.3666
2015	12	2	13	32	22	0.3	3.9	0.65	101.4	82.769	49.5688
2015	12	2	13	42	22	0.3	3.9	0.65	101.1	82.769	49.8257
2015	12	2	13	52	22	0.3	3.9	0.65	99.6	82.7034	50.0413
2015	12	2	14	2	22	0.3	3.9	0.63	103.5	82.7034	47.9884
2015	12	2	14	12	22	0.3	3.9	0.65	100.2	82.7034	50.0413

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	14	22	22	0.3	3.9	0.66	102.1	82.7034	50.2979
2015	12	2	14	32	22	0.3	3.9	0.65	101	82.769	50.0825
2015	12	2	14	42	22	0.3	3.9	0.6	99.8	82.7034	46.192
2015	12	2	14	52	22	0.3	3.9	0.64	101.5	82.7034	49.0149
2015	12	2	15	2	22	0.3	3.9	0.64	103.6	82.7034	48.7583
2015	12	2	15	12	22	0.3	3.9	0.65	102.8	82.7034	49.7848
2015	12	2	15	22	22	0.3	3.9	0.65	102.2	82.7034	49.7848
2015	12	2	15	32	22	0.3	3.9	0.63	101.2	82.7034	47.9884
2015	12	2	15	42	22	0.3	3.9	0.67	100.8	82.7034	51.3245
2015	12	2	15	52	22	0.3	3.9	0.65	103.2	82.7034	49.2716
2015	12	2	16	2	22	0.3	3.9	0.61	100.5	82.7034	47.2186
2015	12	2	16	12	22	0.3	3.9	0.67	101	82.7034	51.5812
2015	12	2	16	22	22	0.3	3.9	0.67	101.5	82.7034	51.5812
2015	12	2	16	32	22	0.3	3.9	0.63	103.8	82.7034	47.9885
2015	12	2	16	42	22	0.3	3.9	0.68	102.3	82.7034	51.5812
2015	12	2	16	52	22	0.3	3.9	0.69	104.3	82.7034	52.3511
2015	12	2	17	2	22	0.3	3.9	0.63	101.9	82.7034	48.5017
2015	12	2	17	12	22	0.3	3.9	0.65	101.7	82.7034	49.7848
2015	12	2	17	22	22	0.3	3.9	0.66	102.9	82.7034	50.5547
2015	12	2	17	32	22	0.3	3.9	0.64	103	82.7034	48.7583
2015	12	2	17	42	22	0.3	3.9	0.64	102.2	82.769	48.7985
2015	12	2	17	52	22	0.3	3.9	0.63	100.7	82.7034	48.7583
2015	12	2	18	2	22	0.3	3.9	0.64	102.8	82.769	48.5417
2015	12	2	18	12	22	0.3	3.9	0.64	102.5	82.7034	48.7583
2015	12	2	18	22	22	0.3	3.9	0.66	103.8	82.769	50.0827
2015	12	2	18	32	22	0.3	3.9	0.66	102	82.769	50.8532
2015	12	2	18	42	22	0.3	3.9	0.65	101.1	82.769	49.8258
2015	12	2	18	52	22	0.3	3.9	0.64	101.2	82.769	49.3122
2015	12	2	19	2	22	0.3	3.9	0.63	102.1	82.769	48.028
2015	12	2	19	12	22	0.3	3.9	0.65	101.9	82.769	49.8258
2015	12	2	19	22	22	0.3	3.9	0.66	101.1	82.769	50.8531
2015	12	2	19	32	22	0.3	3.9	0.67	102.1	82.769	51.3668
2015	12	2	19	42	22	0.3	3.9	0.63	102.9	82.769	48.028
2015	12	2	19	52	22	0.3	3.9	0.68	103.4	82.769	51.8805
2015	12	2	20	2	22	0.3	3.9	0.66	103	82.769	50.0826
2015	12	2	20	12	22	0.3	3.9	0.67	101.9	82.769	51.11
2015	12	2	20	22	22	0.3	3.9	0.66	100.8	82.769	51.1099
2015	12	2	20	32	22	0.3	3.9	0.68	102.5	82.8347	52.1802
2015	12	2	20	42	22	0.3	3.9	0.64	102.3	82.769	49.3121
2015	12	2	20	52	22	0.3	3.9	0.69	102.4	82.769	52.3941
2015	12	2	21	2	22	0.3	3.9	0.68	102.3	82.769	51.6236
2015	12	2	21	12	22	0.3	3.9	0.67	101.4	82.769	51.1099
2015	12	2	21	22	22	0.3	3.9	0.68	102.6	82.8347	51.9232
2015	12	2	21	32	22	0.3	3.9	0.67	101.6	82.8347	51.152
2015	12	2	21	42	22	0.3	3.9	0.67	103.1	82.8347	50.895
2015	12	2	21	52	22	0.3	3.9	0.65	103.2	82.8347	49.3527

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	22	2	22	0.3	3.9	0.64	98.8	82.8347	49.6097
2015	12	2	22	12	22	0.3	3.9	0.64	102.4	82.8347	49.0957
2015	12	2	22	22	22	0.3	3.9	0.63	102.4	82.9003	48.107
2015	12	2	22	32	22	0.3	3.9	0.66	102.3	82.9003	50.6796
2015	12	2	22	42	22	0.3	3.9	0.62	101.6	82.9659	47.6316
2015	12	2	22	52	22	0.3	3.9	0.63	101.7	82.9003	48.3643
2015	12	2	23	2	22	0.3	3.9	0.65	102	82.9659	49.6914
2015	12	2	23	12	22	0.3	3.9	0.67	102.2	82.9659	51.2362
2015	12	2	23	22	22	0.3	3.9	0.62	102.6	82.9659	47.1167
2015	12	2	23	32	22	0.3	3.9	0.64	101.2	83.0315	49.4745
2015	12	2	23	42	22	0.3	3.9	0.65	104.9	83.0315	49.4745
2015	12	2	23	52	22	0.3	3.9	0.64	102.4	83.0315	49.2168
2015	12	3	0	2	22	0.3	3.9	0.66	104.1	83.0315	50.2476
2015	12	3	0	12	22	0.3	3.9	0.66	99.7	83.0971	51.3204
2015	12	3	0	22	22	0.3	3.9	0.62	102.1	83.0315	47.9284
2015	12	3	0	32	22	0.3	3.9	0.65	103.4	83.0971	49.773
2015	12	3	0	42	22	0.3	3.9	0.63	102.3	83.0971	48.4836
2015	12	3	0	52	22	0.3	3.9	0.64	101	83.0971	48.9994
2015	12	3	1	2	22	0.3	3.9	0.68	102.3	83.0971	52.0941
2015	12	3	1	12	22	0.3	3.9	0.64	102.2	83.0971	48.9994
2015	12	3	1	22	22	0.3	3.9	0.65	102.3	83.0971	49.773
2015	12	3	1	32	22	0.3	3.9	0.65	103.4	83.0971	49.773
2015	12	3	1	42	22	0.3	3.9	0.64	100.1	83.0971	49.2573
2015	12	3	1	52	22	0.3	3.9	0.67	102.1	83.0971	51.5783
2015	12	3	2	2	22	0.3	3.9	0.69	100.5	83.0971	53.1256
2015	12	3	2	12	22	0.3	3.9	0.64	101.5	83.0971	49.2573
2015	12	3	2	22	22	0.3	3.9	0.66	100.9	83.0971	50.8046
2015	12	3	2	32	22	0.3	3.9	0.69	101.3	83.1627	52.9111
2015	12	3	2	42	22	0.3	3.9	0.67	101.8	83.1627	51.8787
2015	12	3	2	52	22	0.3	3.9	0.64	100	83.0971	49.5152
2015	12	3	3	2	22	0.3	3.9	0.64	103.4	83.1627	48.7815
2015	12	3	3	12	22	0.3	3.9	0.63	103.7	83.1627	48.5234
2015	12	3	3	22	22	0.3	3.9	0.68	101.4	83.1627	52.653
2015	12	3	3	32	22	0.3	3.9	0.64	100.1	83.1627	49.2977
2015	12	3	3	42	22	0.3	3.9	0.67	101.8	83.1627	51.8787
2015	12	3	3	52	22	0.3	3.9	0.61	101.7	83.1627	47.2329
2015	12	3	4	2	22	0.3	3.9	0.64	100.3	83.1627	49.5558
2015	12	3	4	12	22	0.3	3.9	0.68	103.3	83.1627	52.3949
2015	12	3	4	22	22	0.3	3.9	0.65	102.2	83.1627	50.072
2015	12	3	4	32	22	0.3	3.9	0.62	102.5	83.1627	47.7491
2015	12	3	4	42	22	0.3	3.9	0.65	101.4	83.1627	50.072
2015	12	3	4	52	22	0.3	3.9	0.65	100.7	83.2284	50.3713
2015	12	3	5	2	22	0.3	3.9	0.63	100.5	83.1627	48.5234
2015	12	3	5	12	22	0.3	3.9	0.65	102.6	83.2284	49.5964
2015	12	3	5	22	22	0.3	3.9	0.64	101.9	83.2284	49.0798
2015	12	3	5	32	22	0.3	3.9	0.69	102.6	83.2284	52.9545

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	5	42	22	0.3	3.9	0.65	101.1	83.2284	49.8547
2015	12	3	5	52	22	0.3	3.9	0.67	102.1	83.2284	51.9212
2015	12	3	6	2	22	0.3	3.9	0.61	104.9	83.2284	46.755
2015	12	3	6	12	22	0.3	3.9	0.62	101.7	83.2284	47.5299
2015	12	3	6	22	22	0.3	3.9	0.66	102	83.2284	51.1463
2015	12	3	6	32	22	0.3	3.9	0.63	103.5	83.2284	48.3049
2015	12	3	6	42	22	0.3	3.9	0.67	104.1	83.2284	51.4046
2015	12	3	6	52	22	0.3	3.9	0.64	100.3	83.2284	49.5964
2015	12	3	7	2	22	0.3	3.9	0.65	101.1	83.2284	49.8547
2015	12	3	7	12	22	0.3	3.9	0.67	103	83.2284	51.6629
2015	12	3	7	22	22	0.3	3.9	0.67	102.1	83.2284	51.6629
2015	12	3	7	32	22	0.3	3.9	0.64	101.3	83.2284	49.3381
2015	12	3	7	42	22	0.3	3.9	0.64	101.3	83.294	49.3785
2015	12	3	7	52	22	0.3	3.9	0.66	100.6	83.2284	51.1463
2015	12	3	8	2	22	0.3	3.9	0.63	102.1	83.294	48.3444
2015	12	3	8	12	22	0.3	3.9	0.64	99.8	83.294	49.3784
2015	12	3	8	22	22	0.3	3.9	0.62	101.4	83.294	47.5687
2015	12	3	8	32	22	0.3	3.9	0.64	103	83.294	49.1198
2015	12	3	8	42	22	0.3	3.9	0.67	102.7	83.294	51.705
2015	12	3	8	52	22	0.3	3.9	0.64	101.6	83.294	49.1198
2015	12	3	9	2	22	0.3	3.9	0.62	101.3	83.3596	48.1249
2015	12	3	9	12	22	0.3	3.9	0.64	100	83.3596	49.9361
2015	12	3	9	22	22	0.3	3.9	0.65	99.9	83.3596	50.4535
2015	12	3	9	32	22	0.3	3.9	0.66	100.6	83.3596	50.971
2015	12	3	9	42	22	0.3	3.9	0.61	100.5	83.3596	47.3486
2015	12	3	9	52	22	0.3	3.9	0.61	100.8	83.3596	47.3486
2015	12	3	10	2	22	0.3	3.9	0.65	101	83.3596	50.4534
2015	12	3	10	12	22	0.3	3.9	0.64	102.2	83.3596	49.1597
2015	12	3	10	22	22	0.3	3.9	0.64	101.5	83.3596	49.6772
2015	12	3	10	32	22	0.3	3.9	0.63	99.6	83.4252	48.9409
2015	12	3	10	42	22	0.3	3.9	0.63	101.4	83.3596	48.6422
2015	12	3	10	52	22	0.3	3.9	0.61	100.5	83.3596	47.6074
2015	12	3	11	2	22	0.3	3.9	0.65	100.8	83.3596	50.1946
2015	12	3	11	12	22	0.3	3.9	0.65	100.1	83.4252	50.7534
2015	12	3	11	22	22	0.3	3.9	0.66	101.5	83.3596	50.9708
2015	12	3	11	32	22	0.3	3.9	0.63	101.7	83.4252	48.9407
2015	12	3	11	42	22	0.3	3.9	0.62	102.5	83.4252	47.905
2015	12	3	11	52	22	0.3	3.9	0.61	102	83.4252	47.3871
2015	12	3	12	2	22	0.3	3.9	0.64	100.6	83.4908	50.0173
2015	12	3	12	12	22	0.3	3.9	0.63	103.5	83.4252	48.6817
2015	12	3	12	22	22	0.3	3.9	0.62	103.1	83.4252	47.9049
2015	12	3	12	32	22	0.3	3.9	0.64	101.6	83.4252	49.1996
2015	12	3	12	42	22	0.3	3.9	0.63	101.1	83.4252	48.6817
2015	12	3	12	52	22	0.3	3.9	0.64	103.7	83.4252	48.9407
2015	12	3	13	2	22	0.3	3.9	0.6	99.7	83.3596	46.831
2015	12	3	13	12	22	0.3	3.9	0.66	104.7	83.4252	50.2355

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	13	22	22	0.3	3.9	0.59	103.5	83.4252	45.3155
2015	12	3	13	32	22	0.3	3.9	0.63	104.3	83.3596	47.8659
2015	12	3	13	42	22	0.3	3.9	0.61	103.6	83.4252	47.1281
2015	12	3	13	52	22	0.3	3.9	0.64	103.6	83.4252	49.1997
2015	12	3	14	2	22	0.3	3.9	0.59	102.4	83.4252	45.8334
2015	12	3	14	12	22	0.3	3.9	0.61	103.1	83.4252	46.6102
2015	12	3	14	22	22	0.3	3.9	0.6	102.5	83.4252	46.6103
2015	12	3	14	32	22	0.3	3.9	0.61	103.4	83.3596	46.831
2015	12	3	14	42	22	0.3	3.9	0.61	104	83.3596	46.831
2015	12	3	14	52	22	0.3	3.9	0.67	101.4	83.3596	51.4883
2015	12	3	15	2	22	0.3	3.9	0.65	101.9	83.3596	50.4534
2015	12	3	15	12	22	0.3	3.9	0.63	101.4	83.3596	48.6423
2015	12	3	15	22	22	0.3	3.9	0.65	101.3	83.3596	50.4534
2015	12	3	15	32	22	0.3	3.9	0.64	102.5	83.3596	49.1597
2015	12	3	15	42	22	0.3	3.9	0.65	102.9	83.3596	49.6772
2015	12	3	15	52	22	0.3	3.9	0.64	101.8	83.3596	49.6772
2015	12	3	16	2	22	0.3	3.9	0.64	102.5	83.3596	49.1598
2015	12	3	16	12	22	0.3	3.9	0.65	104.7	83.3596	49.4185
2015	12	3	16	22	22	0.3	3.9	0.66	101.8	83.3596	50.7122
2015	12	3	16	32	22	0.3	3.9	0.68	103.6	83.3596	52.2646
2015	12	3	16	42	22	0.3	3.9	0.64	101.3	83.3596	49.1598
2015	12	3	16	52	22	0.3	3.9	0.68	102.8	83.3596	52.5233
2015	12	3	17	2	22	0.3	3.9	0.64	102.5	83.3596	48.901
2015	12	3	17	12	22	0.3	3.9	0.64	101.6	83.3596	49.1598
2015	12	3	17	22	22	0.3	3.9	0.65	99.4	83.3596	50.1947
2015	12	3	17	32	22	0.3	3.9	0.66	100.8	83.3596	51.4884
2015	12	3	17	42	22	0.3	3.9	0.65	101.7	83.3596	50.1947
2015	12	3	17	52	22	0.3	3.9	0.66	104.1	83.3596	50.4534
2015	12	3	18	2	22	0.3	3.9	0.64	101	83.3596	49.4185
2015	12	3	18	12	22	0.3	3.9	0.66	101.3	83.3596	50.7122
2015	12	3	18	22	22	0.3	3.9	0.63	103.7	83.3596	48.6423
2015	12	3	18	32	22	0.3	3.9	0.63	101.7	83.3596	48.901
2015	12	3	18	42	22	0.3	3.9	0.67	99.6	83.4252	51.7894
2015	12	3	18	52	22	0.3	3.9	0.64	101.8	83.3596	49.4185
2015	12	3	19	2	22	0.3	3.9	0.61	102.1	83.3596	47.0898
2015	12	3	19	12	22	0.3	3.9	0.64	101	83.3596	49.4185
2015	12	3	19	22	22	0.3	3.9	0.66	100.3	83.3596	51.2296
2015	12	3	19	32	22	0.3	3.9	0.64	101.8	83.3596	49.4185
2015	12	3	19	42	22	0.3	3.9	0.67	101.4	83.3596	51.4883
2015	12	3	19	52	22	0.3	3.9	0.65	100.4	83.4252	50.7536
2015	12	3	20	2	22	0.3	3.9	0.66	100.5	83.3596	51.4883
2015	12	3	20	12	22	0.3	3.9	0.66	102	83.3596	51.2296
2015	12	3	20	22	22	0.3	3.9	0.65	98.9	83.3596	50.9708
2015	12	3	20	32	22	0.3	3.9	0.68	102.2	83.4252	52.5662
2015	12	3	20	42	22	0.3	3.9	0.64	102.4	83.4252	49.4588
2015	12	3	20	52	22	0.3	3.9	0.65	99.9	83.4252	50.2356

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	21	2	22	0.3	3.9	0.66	101	83.4252	50.7535
2015	12	3	21	12	22	0.3	3.9	0.66	104.7	83.4252	50.2356
2015	12	3	21	22	22	0.3	3.9	0.62	100.4	83.4252	48.1641
2015	12	3	21	32	22	0.3	3.9	0.64	101.5	83.4252	49.4588
2015	12	3	21	42	22	0.3	3.9	0.65	101.1	83.4252	50.2356
2015	12	3	21	52	22	0.3	3.9	0.63	101.1	83.4252	48.9409
2015	12	3	22	2	22	0.3	3.9	0.66	101.5	83.4252	50.7535
2015	12	3	22	12	22	0.3	3.9	0.64	100.3	83.4252	49.7177
2015	12	3	22	22	22	0.3	3.9	0.65	101.4	83.4252	49.9766
2015	12	3	22	32	22	0.3	3.9	0.65	101.1	83.4252	50.2356
2015	12	3	22	42	22	0.3	3.9	0.66	102.7	83.4252	50.7535
2015	12	3	22	52	22	0.3	3.9	0.63	102.7	83.4252	48.423
2015	12	3	23	2	22	0.3	3.9	0.62	101.6	83.4252	47.905
2015	12	3	23	12	22	0.3	3.9	0.64	99.7	83.4252	49.9766
2015	12	3	23	22	22	0.3	3.9	0.63	105.3	83.4252	48.164
2015	12	3	23	32	22	0.3	3.9	0.62	103.4	83.4252	47.905
2015	12	3	23	42	22	0.3	3.9	0.68	101.4	83.4252	52.5661
2015	12	3	23	52	22	0.3	3.9	0.64	104.3	83.4252	48.9408
2015	12	4	0	2	22	0.3	3.9	0.67	102.2	83.4252	51.5303
2015	12	4	0	12	22	0.3	3.9	0.65	102.8	83.4252	49.9766
2015	12	4	0	22	22	0.3	3.9	0.65	102.8	83.4252	49.9766
2015	12	4	0	32	22	0.3	3.9	0.67	100.2	83.4252	51.7892
2015	12	4	0	42	22	0.3	3.9	0.63	101.7	83.4252	48.6818
2015	12	4	0	52	22	0.3	3.9	0.66	100.8	83.4252	51.5302
2015	12	4	1	2	22	0.3	3.9	0.67	103.6	83.4252	51.5302
2015	12	4	1	12	22	0.3	3.9	0.65	101.1	83.4252	49.9766
2015	12	4	1	22	22	0.3	3.9	0.64	102.5	83.4908	48.9807
2015	12	4	1	32	22	0.3	3.9	0.64	100.6	83.4252	49.7176
2015	12	4	1	42	22	0.3	3.9	0.64	103	83.4252	49.1997
2015	12	4	1	52	22	0.3	3.9	0.61	99.9	83.4252	47.3871
2015	12	4	2	2	22	0.3	3.9	0.69	105.2	83.4252	52.566
2015	12	4	2	12	22	0.3	3.9	0.64	104	83.4252	48.9408
2015	12	4	2	22	22	0.3	3.9	0.65	102	83.4908	50.0173
2015	12	4	2	32	22	0.3	3.9	0.67	103.9	83.4252	51.2713
2015	12	4	2	42	22	0.3	3.9	0.62	99.8	83.4252	48.1639
2015	12	4	2	52	22	0.3	3.9	0.65	100.5	83.4252	50.4944
2015	12	4	3	2	22	0.3	3.9	0.67	102.7	83.4252	51.7891
2015	12	4	3	12	22	0.3	3.9	0.67	101	83.4908	52.0906
2015	12	4	3	22	22	0.3	3.9	0.66	100.1	83.4908	51.054
2015	12	4	3	32	22	0.3	3.9	0.68	102.8	83.4252	52.307
2015	12	4	3	42	22	0.3	3.9	0.65	102.5	83.4908	50.2765
2015	12	4	3	52	22	0.3	3.9	0.67	104.1	83.4908	51.5723
2015	12	4	4	2	22	0.3	3.9	0.65	103.1	83.4908	50.0173
2015	12	4	4	12	22	0.3	3.9	0.65	103.1	83.4252	49.9765
2015	12	4	4	22	22	0.3	3.9	0.67	99.3	83.4252	52.0481
2015	12	4	4	32	22	0.3	3.9	0.66	102	83.4252	51.2712

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	4	42	22	0.3	3.9	0.65	103.4	83.4252	49.9765
2015	12	4	4	52	22	0.3	3.9	0.64	100.3	83.4252	49.9765
2015	12	4	5	2	22	0.3	3.9	0.64	102.4	83.4908	49.499
2015	12	4	5	12	22	0.3	3.9	0.65	100.8	83.4908	50.2765
2015	12	4	5	22	22	0.3	3.9	0.65	104.2	83.4252	49.9765
2015	12	4	5	32	22	0.3	3.9	0.65	101.1	83.4252	50.2354
2015	12	4	5	42	22	0.3	3.9	0.65	101.4	83.4252	49.9765
2015	12	4	5	52	22	0.3	3.9	0.63	101.9	83.4252	48.9407
2015	12	4	6	2	22	0.3	3.9	0.67	101.9	83.4252	51.5302
2015	12	4	6	12	22	0.3	3.9	0.63	103.5	83.4252	48.6818
2015	12	4	6	22	22	0.3	3.9	0.64	100.4	83.4252	49.4586
2015	12	4	6	32	22	0.3	3.9	0.65	101.7	83.4252	50.2354
2015	12	4	6	42	22	0.3	3.9	0.62	102.5	83.4252	47.9049
2015	12	4	6	52	22	0.3	3.9	0.66	102	83.4252	51.2712
2015	12	4	7	2	22	0.3	3.9	0.64	101.5	83.4252	49.7175
2015	12	4	7	12	22	0.3	3.9	0.62	101.3	83.4252	48.1639
2015	12	4	7	22	22	0.3	3.9	0.63	100.8	83.4252	48.9407
2015	12	4	7	32	22	0.3	3.9	0.64	102.5	83.4252	48.9407
2015	12	4	7	42	22	0.3	3.9	0.63	101.8	83.4252	48.4228
2015	12	4	7	52	22	0.3	3.9	0.63	99.6	83.4252	49.1996
2015	12	4	8	2	22	0.3	3.9	0.65	100.8	83.4252	50.2353
2015	12	4	8	12	22	0.3	3.9	0.66	102	83.4252	51.2711
2015	12	4	8	22	22	0.3	3.9	0.65	102	83.4252	49.9763
2015	12	4	8	32	22	0.3	3.9	0.63	100.7	83.4252	49.1995
2015	12	4	8	42	22	0.3	3.9	0.62	102	83.4252	47.6458
2015	12	4	8	52	22	0.3	3.9	0.65	103.4	83.4252	49.9762
2015	12	4	9	2	22	0.3	3.9	0.67	101.3	83.4252	52.0478
2015	12	4	9	12	22	0.3	3.9	0.64	102.1	83.4252	49.7172
2015	12	4	9	22	22	0.3	3.9	0.6	101.4	83.4252	46.3509
2015	12	4	9	32	22	0.3	3.9	0.65	101.4	83.4252	50.235
2015	12	4	9	42	22	0.3	3.9	0.64	101	83.4252	49.4582
2015	12	4	9	52	22	0.3	3.9	0.65	102.6	83.4252	49.976
2015	12	4	10	2	22	0.3	3.9	0.64	100.7	83.4252	49.4581
2015	12	4	10	12	22	0.3	3.9	0.66	100.5	83.3596	51.4875
2015	12	4	10	22	22	0.3	3.9	0.63	101.5	83.4252	48.4223
2015	12	4	10	32	22	0.3	3.9	0.65	100.7	83.3596	50.4525
2015	12	4	10	42	22	0.3	3.9	0.63	102.6	83.3596	48.6414
2015	12	4	10	52	22	0.3	3.9	0.63	101.7	83.3596	48.6414
2015	12	4	11	2	22	0.3	3.9	0.63	101.8	83.3596	48.3826
2015	12	4	11	12	22	0.3	3.9	0.64	103.1	83.3596	48.9001
2015	12	4	11	22	22	0.3	3.9	0.65	99.9	83.294	50.4112
2015	12	4	11	32	22	0.3	3.9	0.64	101.8	83.2284	49.3367
2015	12	4	11	42	22	0.3	3.9	0.63	100.5	83.2284	48.8201
2015	12	4	11	52	22	0.3	3.9	0.61	102.8	83.2284	46.4953
2015	12	4	12	2	22	0.3	3.9	0.63	102.9	83.2284	48.5617
2015	12	4	12	12	22	0.3	3.9	0.65	103.7	83.2284	49.8533

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	12	22	22	0.3	3.9	0.63	102	83.2284	48.5617
2015	12	4	12	32	22	0.3	3.9	0.6	101.4	83.1627	46.1991
2015	12	4	12	42	22	0.3	3.9	0.65	100.7	83.1627	50.5867
2015	12	4	12	52	22	0.3	3.9	0.63	103.5	83.1627	48.522
2015	12	4	13	2	22	0.3	3.9	0.62	101.5	83.1627	48.0058
2015	12	4	13	12	22	0.3	3.9	0.63	102.3	83.1627	48.522
2015	12	4	13	22	22	0.3	3.9	0.63	102.7	83.1627	48.2639
2015	12	4	13	32	22	0.3	3.9	0.62	101.8	83.1627	48.0058
2015	12	4	13	42	22	0.3	3.9	0.65	103.1	83.1627	49.8125
2015	12	4	13	52	22	0.3	3.9	0.65	102.3	83.0971	49.7716
2015	12	4	14	2	22	0.3	3.9	0.64	103.3	83.0971	48.998
2015	12	4	14	12	22	0.3	3.9	0.66	98.8	83.0971	51.5769
2015	12	4	14	22	22	0.3	3.9	0.64	98.8	83.0971	50.0296
2015	12	4	14	32	22	0.3	3.9	0.66	103	83.0315	50.2462
2015	12	4	14	42	22	0.3	3.9	0.66	103	83.0315	50.2463
2015	12	4	14	52	22	0.3	3.9	0.66	103.6	83.0315	50.2463
2015	12	4	15	2	22	0.3	3.9	0.64	100.3	83.0315	49.4733
2015	12	4	15	12	22	0.3	3.9	0.65	100.7	83.0315	50.5041
2015	12	4	15	22	22	0.3	3.9	0.66	100.4	82.9659	50.7201
2015	12	4	15	32	22	0.3	3.9	0.66	102.4	83.0315	50.2464
2015	12	4	15	42	22	0.3	3.9	0.62	102.3	82.9659	47.373
2015	12	4	15	52	22	0.3	3.9	0.62	100.4	82.9659	47.6305
2015	12	4	16	2	22	0.3	3.9	0.65	101.3	82.9659	50.2051
2015	12	4	16	12	22	0.3	3.9	0.61	99.6	82.9659	47.373
2015	12	4	16	22	22	0.3	3.9	0.62	101.8	82.9659	47.888
2015	12	4	16	32	22	0.3	3.9	0.62	100.3	82.9659	48.1454
2015	12	4	16	42	22	0.3	3.9	0.63	100.5	82.9659	48.6604
2015	12	4	16	52	22	0.3	3.9	0.63	101.7	82.9659	48.4029
2015	12	4	17	2	22	0.3	3.9	0.63	102.7	82.9659	48.1454
2015	12	4	17	12	22	0.3	3.9	0.65	100.5	82.9659	49.9477
2015	12	4	17	22	22	0.3	3.9	0.66	101.8	82.9659	50.7201
2015	12	4	17	32	22	0.3	3.9	0.64	102.1	82.9659	49.1753
2015	12	4	17	42	22	0.3	3.9	0.63	100.1	82.9659	48.9178
2015	12	4	17	52	22	0.3	3.9	0.63	103.3	82.9003	47.8486
2015	12	4	18	2	22	0.3	3.9	0.64	100.3	82.9659	49.4327
2015	12	4	18	12	22	0.3	3.9	0.61	100.2	82.9003	47.0769
2015	12	4	18	22	22	0.3	3.9	0.63	100.8	82.9003	48.6204
2015	12	4	18	32	22	0.3	3.9	0.62	96	82.9003	48.6204
2015	12	4	18	42	22	0.3	3.9	0.65	102.5	82.9003	49.9066
2015	12	4	18	52	22	0.3	3.9	0.66	100	82.9003	50.9356
2015	12	4	19	2	22	0.3	3.9	0.65	101.3	82.9003	50.1638
2015	12	4	19	12	22	0.3	3.9	0.64	101.2	82.9003	49.3921
2015	12	4	19	22	22	0.3	3.9	0.6	99.4	82.9003	46.5623
2015	12	4	19	32	22	0.3	3.9	0.62	101.9	82.9003	47.5913
2015	12	4	19	42	22	0.3	3.9	0.63	103.5	82.9003	48.1058
2015	12	4	19	52	22	0.3	3.9	0.65	101.3	82.9003	50.1638

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	20	2	22	0.3	3.9	0.66	102.4	82.8347	50.1226
2015	12	4	20	12	22	0.3	3.9	0.62	102.6	82.8347	47.0381
2015	12	4	20	22	22	0.3	3.9	0.66	99.5	82.8347	50.6367
2015	12	4	20	32	22	0.3	3.9	0.63	100.5	82.8347	48.5803
2015	12	4	20	42	22	0.3	3.9	0.62	98.8	82.8347	48.3233
2015	12	4	20	52	22	0.3	3.9	0.66	102.7	82.8347	50.1225
2015	12	4	21	2	22	0.3	3.9	0.66	103	82.8347	50.1226
2015	12	4	21	12	22	0.3	3.9	0.61	101.2	82.8347	46.7811
2015	12	4	21	22	22	0.3	3.9	0.66	102	82.8347	50.8937
2015	12	4	21	32	22	0.3	3.9	0.62	100.1	82.769	47.7699
2015	12	4	21	42	22	0.3	3.9	0.63	100.3	82.769	48.2835
2015	12	4	21	52	22	0.3	3.9	0.6	100.7	82.769	46.2289
2015	12	4	22	2	22	0.3	3.9	0.63	100.8	82.769	48.5403
2015	12	4	22	12	22	0.3	3.9	0.64	102.5	82.769	48.7972
2015	12	4	22	22	22	0.3	3.9	0.63	101.4	82.769	48.5403
2015	12	4	22	32	22	0.3	3.9	0.62	101.3	82.769	47.513
2015	12	4	22	42	22	0.3	3.9	0.64	101.6	82.769	48.7972
2015	12	4	22	52	22	0.3	3.9	0.62	99.7	82.7034	47.9872
2015	12	4	23	2	22	0.3	3.9	0.64	102.5	82.7034	48.757
2015	12	4	23	12	22	0.3	3.9	0.59	100.5	82.7034	45.6776
2015	12	4	23	22	22	0.3	3.9	0.64	99.2	82.7034	49.2703
2015	12	4	23	32	22	0.3	3.9	0.67	100.4	82.6378	51.5373
2015	12	4	23	42	22	0.3	3.9	0.64	99.5	82.5722	49.1891
2015	12	4	23	52	22	0.3	3.9	0.64	103	82.5066	48.8925
2015	12	5	0	2	22	0.3	3.9	0.62	100.9	82.5066	47.8686
2015	12	5	0	12	22	0.3	3.9	0.65	100.2	82.5066	49.6604
2015	12	5	0	22	22	0.3	3.9	0.62	101.7	82.4409	47.0617
2015	12	5	0	32	22	0.3	3.9	0.66	103.1	82.4409	50.3868
2015	12	5	0	42	22	0.3	3.9	0.66	102.6	82.4409	50.3868
2015	12	5	0	52	22	0.3	3.9	0.63	99.2	82.4409	48.8521
2015	12	5	1	2	22	0.3	3.9	0.65	99.3	82.4409	49.8752
2015	12	5	1	12	22	0.3	3.9	0.64	99.8	82.3753	49.0673
2015	12	5	1	22	22	0.3	3.9	0.67	102.7	82.3753	50.8562
2015	12	5	1	32	22	0.3	3.6	0.65	102.8	82.3753	49.5784
2015	12	5	1	42	22	0.3	3.9	0.64	101.9	82.3753	48.5562
2015	12	5	1	52	22	0.3	3.9	0.61	99.6	82.3753	47.0229
2015	12	5	2	2	22	0.3	3.9	0.62	99.7	82.3753	47.7896
2015	12	5	2	12	22	0.3	3.9	0.63	100.8	82.3753	48.3007
2015	12	5	2	22	22	0.3	3.9	0.64	101.5	82.3753	48.8118
2015	12	5	2	32	22	0.3	3.9	0.64	100.4	82.3097	48.7714
2015	12	5	2	42	22	0.3	3.9	0.66	104.2	82.3097	49.5375
2015	12	5	2	52	22	0.3	3.9	0.64	100.3	82.3097	49.2821
2015	12	5	3	2	22	0.3	3.9	0.63	98.3	82.3097	48.7714
2015	12	5	3	12	22	0.3	3.9	0.63	100.5	82.3097	48.0054
2015	12	5	3	22	22	0.3	3.9	0.63	103.9	82.3097	47.4947
2015	12	5	3	32	22	0.3	3.9	0.64	101	82.3097	48.7715

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	3	42	22	0.3	3.9	0.64	102.1	82.3097	48.7715
2015	12	5	3	52	22	0.3	3.9	0.65	103.7	82.2441	49.2414
2015	12	5	4	2	22	0.3	3.9	0.66	101.3	82.2441	50.0068
2015	12	5	4	12	22	0.3	3.9	0.64	102.1	82.2441	48.9863
2015	12	5	4	22	22	0.3	3.9	0.62	99.4	82.2441	47.7106
2015	12	5	4	32	22	0.3	3.9	0.65	103.3	82.2441	49.4965
2015	12	5	4	42	22	0.3	3.9	0.62	100.6	82.2441	47.7106
2015	12	5	4	52	22	0.3	3.9	0.63	102.9	82.2441	47.7106
2015	12	5	5	2	22	0.3	3.9	0.65	102.8	82.2441	49.4966
2015	12	5	5	12	22	0.3	3.9	0.65	103.8	82.2441	48.7312
2015	12	5	5	22	22	0.3	3.9	0.63	101.5	82.1785	47.6711
2015	12	5	5	32	22	0.3	3.9	0.6	101.4	82.1785	45.6317
2015	12	5	5	42	22	0.3	3.9	0.61	100.8	82.1785	46.6514
2015	12	5	5	52	22	0.3	3.9	0.64	102.2	82.1785	48.4359
2015	12	5	6	2	22	0.3	3.9	0.61	98.7	82.1785	46.6514
2015	12	5	6	12	22	0.3	3.9	0.66	100	82.1785	50.7302
2015	12	5	6	22	22	0.3	3.9	0.66	103.4	82.1785	50.2204
2015	12	5	6	32	22	0.3	3.9	0.66	100.9	82.1785	50.4753
2015	12	5	6	42	22	0.3	3.9	0.64	102.4	82.1785	48.6908
2015	12	5	6	52	22	0.3	3.9	0.66	102.6	82.1785	50.2204
2015	12	5	7	2	22	0.3	3.9	0.63	99.9	82.1129	48.141
2015	12	5	7	12	22	0.3	3.9	0.58	100.4	82.1129	44.3203
2015	12	5	7	22	22	0.3	3.9	0.64	102.2	82.1129	48.3958
2015	12	5	7	32	22	0.3	3.9	0.64	102.4	82.1129	48.6505
2015	12	5	7	42	22	0.3	3.9	0.6	102.2	82.1129	45.8486
2015	12	5	7	52	22	0.3	3.9	0.61	101.9	82.1129	46.1033
2015	12	5	8	2	22	0.3	3.9	0.65	101.3	82.1129	49.6693
2015	12	5	8	12	22	0.3	3.9	0.61	102	82.1129	46.6127
2015	12	5	8	22	22	0.3	3.9	0.64	101.6	82.1129	48.3957
2015	12	5	8	32	22	0.3	3.9	0.62	99.1	82.1129	47.6315
2015	12	5	8	42	22	0.3	3.9	0.66	101.3	82.1129	49.9239
2015	12	5	8	52	22	0.3	3.9	0.64	98.8	82.1129	49.4145
2015	12	5	9	2	22	0.3	3.9	0.63	101.1	82.1129	47.8862
2015	12	5	9	12	22	0.3	3.9	0.64	99.8	82.1129	48.905
2015	12	5	9	22	22	0.3	3.6	0.62	101.3	82.1129	47.1219
2015	12	5	9	32	22	0.3	3.6	0.67	102.5	82.1785	50.73
2015	12	5	9	42	22	0.3	3.6	0.62	101	82.1129	47.1219
2015	12	5	9	52	22	0.3	3.6	0.64	101	82.1785	48.4356
2015	12	5	10	2	22	0.3	3.6	0.61	101.5	82.1785	46.3962
2015	12	5	10	12	22	0.3	3.6	0.63	103.3	82.1785	47.4158
2015	12	5	10	22	22	0.3	3.6	0.64	104	82.1785	47.9257
2015	12	5	10	32	22	0.3	3.6	0.64	102.1	82.1129	48.6501
2015	12	5	10	42	22	0.3	3.6	0.62	103.4	82.1785	47.1608
2015	12	5	10	52	22	0.3	3.6	0.61	101.7	82.1785	46.651
2015	12	5	11	2	22	0.3	3.6	0.6	99.8	82.1129	45.5936
2015	12	5	11	12	22	0.3	3.6	0.61	101.2	82.1129	46.1029

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	11	22	22	0.3	3.6	0.61	102.8	82.1129	46.1028
2015	12	5	11	32	22	0.3	3.6	0.62	103.7	82.1785	47.1607
2015	12	5	11	42	22	0.3	3.6	0.62	103.1	82.1129	47.1217
2015	12	5	11	52	22	0.3	3.6	0.6	102.7	82.1129	45.0839
2015	12	5	12	2	22	0.3	3.6	0.6	99.8	82.1129	45.5934
2015	12	5	12	12	22	0.3	3.6	0.62	102.4	82.1129	47.3764
2015	12	5	12	22	22	0.3	3.6	0.59	102.5	82.1129	44.8292
2015	12	5	12	32	22	0.3	3.6	0.63	101.2	82.0472	47.5916
2015	12	5	12	42	22	0.3	3.6	0.63	101.4	82.0472	47.8461
2015	12	5	12	52	22	0.3	3.6	0.6	102.2	82.0472	45.8102
2015	12	5	13	2	22	0.3	3.6	0.62	103.5	81.9816	46.535
2015	12	5	13	12	22	0.3	3.6	0.67	104.9	82.0472	49.882
2015	12	5	13	22	22	0.3	3.6	0.62	101	82.0472	47.337
2015	12	5	13	32	22	0.3	3.6	0.65	102.6	81.9816	49.0777
2015	12	5	13	42	22	0.3	3.6	0.65	102.5	81.916	49.291
2015	12	5	13	52	22	0.3	3.6	0.61	105.8	81.916	45.734
2015	12	5	14	2	22	0.3	3.6	0.65	105.7	81.9816	48.8235
2015	12	5	14	12	22	0.3	3.6	0.64	105.5	81.916	47.7666
2015	12	5	14	22	22	0.3	3.6	0.64	103.9	81.8504	48.2346
2015	12	5	14	32	22	0.3	3.6	0.64	105	81.7848	47.4335
2015	12	5	14	42	22	0.3	3.6	0.6	106.2	81.7848	44.3897
2015	12	5	14	52	22	0.3	3.6	0.63	103.7	81.7848	47.6872
2015	12	5	15	2	22	0.3	3.6	0.61	102.8	81.7192	45.8734
2015	12	5	15	12	22	0.3	3.6	0.63	103.2	81.7192	47.6476
2015	12	5	15	22	22	0.3	3.6	0.64	105	81.7192	47.3941
2015	12	5	15	32	22	0.3	3.6	0.61	103.7	81.6535	45.8352
2015	12	5	15	42	22	0.3	3.6	0.62	103.2	81.6535	46.5949
2015	12	5	15	52	22	0.3	3.6	0.65	103.5	81.6535	48.6208
2015	12	5	16	2	22	0.3	3.6	0.6	101.4	81.6535	45.3287
2015	12	5	16	12	22	0.3	3.6	0.6	102.5	81.6535	45.582
2015	12	5	16	22	22	0.3	3.6	0.62	103.2	81.6535	46.3417
2015	12	5	16	32	22	0.3	3.6	0.62	102.3	81.6535	46.5949
2015	12	5	16	42	22	0.3	3.6	0.64	100.6	81.6535	48.6208
2015	12	5	16	52	22	0.3	3.6	0.64	103.9	81.6535	48.1143
2015	12	5	17	2	22	0.3	3.6	0.61	100.2	81.5879	46.303
2015	12	5	17	12	22	0.3	3.6	0.62	99.5	81.5879	46.8091
2015	12	5	17	22	22	0.3	3.6	0.61	101.2	81.5879	46.05
2015	12	5	17	32	22	0.3	3.6	0.64	102.1	81.5879	48.3272
2015	12	5	17	42	22	0.3	3.6	0.63	101.1	81.5879	47.5681
2015	12	5	17	52	22	0.3	3.6	0.64	100.4	81.5879	48.3272
2015	12	5	18	2	22	0.3	3.6	0.64	101.5	81.5879	48.3272
2015	12	5	18	12	22	0.3	3.6	0.63	104.3	81.5879	46.8091
2015	12	5	18	22	22	0.3	3.6	0.62	100.1	81.5879	47.0621
2015	12	5	18	32	22	0.3	3.6	0.62	101.3	81.5879	46.8091
2015	12	5	18	42	22	0.3	3.6	0.65	100.5	81.5223	49.0452
2015	12	5	18	52	22	0.3	3.6	0.62	103.2	81.5223	46.5171

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	19	2	22	0.3	3.6	0.68	100.3	81.5223	51.3205
2015	12	5	19	12	22	0.3	3.6	0.66	104.4	81.5223	49.298
2015	12	5	19	22	22	0.3	3.6	0.62	101	81.5223	47.0227
2015	12	5	19	32	22	0.3	3.6	0.65	101.6	81.5223	49.298
2015	12	5	19	42	22	0.3	3.6	0.64	102.5	81.5223	48.034
2015	12	5	19	52	22	0.3	3.6	0.63	104.1	81.5223	47.2755
2015	12	5	20	2	22	0.3	3.6	0.65	101.4	81.5223	48.7924
2015	12	5	20	12	22	0.3	3.6	0.6	101.3	81.5223	45.5059
2015	12	5	20	22	22	0.3	3.6	0.6	100.9	81.5223	45.7587
2015	12	5	20	32	22	0.3	3.6	0.66	100.9	81.5223	49.8036
2015	12	5	20	42	22	0.3	3.6	0.62	101.3	81.5223	46.7699
2015	12	5	20	52	22	0.3	3.6	0.62	102.2	81.5223	46.7699
2015	12	5	21	2	22	0.3	3.6	0.64	102.1	81.5223	48.2868
2015	12	5	21	12	22	0.3	3.6	0.64	102.1	81.5223	48.2868
2015	12	5	21	22	22	0.3	3.6	0.62	102.2	81.5223	46.7699
2015	12	5	21	32	22	0.3	3.6	0.61	100.5	81.5223	46.5171
2015	12	5	21	42	22	0.3	3.6	0.64	102.8	81.4567	47.7412
2015	12	5	21	52	22	0.3	3.6	0.64	102.1	81.4567	48.499
2015	12	5	22	2	22	0.3	3.6	0.6	100.3	81.4567	45.7204
2015	12	5	22	12	22	0.3	3.6	0.61	101.1	81.4567	46.2256
2015	12	5	22	22	22	0.3	3.6	0.63	104.1	81.4567	47.236
2015	12	5	22	32	22	0.3	3.6	0.64	103.5	81.4567	48.2464
2015	12	5	22	42	22	0.3	3.6	0.63	102	81.4567	47.4886
2015	12	5	22	52	22	0.3	3.6	0.66	102.1	81.4567	49.5094
2015	12	5	23	2	22	0.3	3.6	0.63	100.8	81.4567	47.7412
2015	12	5	23	12	22	0.3	3.6	0.66	100.6	81.4567	50.0146
2015	12	5	23	22	22	0.3	3.6	0.63	100.7	81.4567	47.9938
2015	12	5	23	32	22	0.3	3.6	0.61	104.6	81.4567	45.4678
2015	12	5	23	42	22	0.3	3.6	0.61	98.3	81.4567	46.4782
2015	12	5	23	52	22	0.3	3.6	0.64	102.7	81.4567	48.2464
2015	12	6	0	2	22	0.3	3.6	0.62	103.7	81.4567	46.7308
2015	12	6	0	12	22	0.3	3.6	0.59	101.6	81.4567	44.4574
2015	12	6	0	22	22	0.3	3.6	0.64	101.9	81.4567	47.9938
2015	12	6	0	32	22	0.3	3.6	0.64	100.6	81.4567	48.499
2015	12	6	0	42	22	0.3	3.6	0.64	101.6	81.3911	47.9537
2015	12	6	0	52	22	0.3	3.6	0.59	100	81.3911	44.4203
2015	12	6	1	2	22	0.3	3.6	0.62	104.1	81.3911	46.187
2015	12	6	1	12	22	0.3	3.6	0.63	98.9	81.3911	48.2061
2015	12	6	1	22	22	0.3	3.6	0.6	101	81.3911	45.4298
2015	12	6	1	32	22	0.3	3.6	0.62	100	81.3911	47.1965
2015	12	6	1	42	22	0.3	3.6	0.61	102.1	81.3911	45.9346
2015	12	6	1	52	22	0.3	3.6	0.62	104.1	81.3911	46.187
2015	12	6	2	2	22	0.3	3.6	0.63	101.8	81.3911	47.1965
2015	12	6	2	12	22	0.3	3.6	0.6	103.9	81.3911	44.9251
2015	12	6	2	22	22	0.3	3.6	0.64	103.3	81.3911	48.2061
2015	12	6	2	32	22	0.3	3.6	0.62	99.1	81.3911	47.4489

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	2	42	22	0.3	3.6	0.62	102.3	81.3911	46.4394
2015	12	6	2	52	22	0.3	3.6	0.63	97.2	81.3255	48.1657
2015	12	6	3	2	22	0.3	3.6	0.64	100.3	81.3911	48.4585
2015	12	6	3	12	22	0.3	3.6	0.62	103.7	81.3911	46.6918
2015	12	6	3	22	22	0.3	3.6	0.65	101.6	81.3255	49.1745
2015	12	6	3	32	22	0.3	3.6	0.61	102.8	81.3255	45.644
2015	12	6	3	42	22	0.3	3.6	0.63	101.1	81.3255	47.4092
2015	12	6	3	52	22	0.3	3.6	0.66	103.8	81.3255	49.1745
2015	12	6	4	2	22	0.3	3.6	0.61	99.6	81.3255	46.1484
2015	12	6	4	12	22	0.3	3.6	0.62	100.6	81.3255	47.1571
2015	12	6	4	22	22	0.3	3.6	0.61	103.1	81.3255	45.3918
2015	12	6	4	32	22	0.3	3.6	0.63	102.1	81.3255	47.1571
2015	12	6	4	42	22	0.3	3.6	0.64	101.2	81.3255	48.418
2015	12	6	4	52	22	0.3	3.6	0.62	104	81.3255	46.4005
2015	12	6	5	2	22	0.3	3.6	0.62	100	81.2598	47.1175
2015	12	6	5	12	22	0.3	3.6	0.64	105.1	81.3255	47.6614
2015	12	6	5	22	22	0.3	3.6	0.67	102.4	81.2598	50.3931
2015	12	6	5	32	22	0.3	3.6	0.6	100.4	81.3255	45.1397
2015	12	6	5	42	22	0.3	3.6	0.66	102.6	81.3255	49.6789
2015	12	6	5	52	22	0.3	3.6	0.65	100.2	81.2598	49.1333
2015	12	6	6	2	22	0.3	3.6	0.65	101.3	81.2598	49.1333
2015	12	6	6	12	22	0.3	3.6	0.62	103.7	81.2598	46.6137
2015	12	6	6	22	22	0.3	3.6	0.64	102.5	81.2598	47.8735
2015	12	6	6	32	22	0.3	3.6	0.62	101.5	81.2598	46.8656
2015	12	6	6	42	22	0.3	3.6	0.63	100.8	81.2598	47.6215
2015	12	6	6	52	22	0.3	3.6	0.64	101.5	81.2598	48.1255
2015	12	6	7	2	22	0.3	3.6	0.64	102.5	81.2598	47.8735
2015	12	6	7	12	22	0.3	3.6	0.64	101.8	81.2598	48.1255
2015	12	6	7	22	22	0.3	3.6	0.63	103.2	81.2598	47.1176
2015	12	6	7	32	22	0.3	3.6	0.64	104	81.2598	47.3696
2015	12	6	7	42	22	0.3	3.6	0.63	101.1	81.1942	47.3298
2015	12	6	7	52	22	0.3	3.6	0.64	100.9	81.1942	48.5886
2015	12	6	8	2	22	0.3	3.6	0.63	101.7	81.2598	47.6215
2015	12	6	8	12	22	0.3	3.6	0.63	103.9	81.1942	46.8263
2015	12	6	8	22	22	0.3	3.6	0.64	105.9	81.2598	47.6215
2015	12	6	8	32	22	0.3	3.6	0.65	102.2	81.2598	49.1332
2015	12	6	8	42	22	0.3	3.6	0.64	102.5	81.2598	47.8733
2015	12	6	8	52	22	0.3	3.6	0.61	102.1	81.2598	45.8576
2015	12	6	9	2	22	0.3	3.6	0.62	103.7	81.2598	46.3615
2015	12	6	9	12	22	0.3	3.6	0.62	101.3	81.2598	46.6135
2015	12	6	9	22	22	0.3	3.6	0.62	103.2	81.2598	46.3614
2015	12	6	9	32	22	0.3	3.6	0.59	101.5	81.2598	44.5976
2015	12	6	9	42	22	0.3	3.6	0.63	102.9	81.2598	47.3692
2015	12	6	9	52	22	0.3	3.6	0.63	101.7	81.2598	47.3692
2015	12	6	10	2	22	0.3	3.6	0.58	105.3	81.2598	43.3377
2015	12	6	10	12	22	0.3	3.6	0.62	101.9	81.2598	46.6133

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	10	22	22	0.3	3.6	0.63	104.5	81.2598	46.6134
2015	12	6	10	32	22	0.3	3.6	0.63	104.5	81.1942	46.8261
2015	12	6	10	42	22	0.3	3.6	0.61	104.3	81.1942	45.5673
2015	12	6	10	52	22	0.3	3.6	0.61	105.2	81.1942	45.3155
2015	12	6	11	2	22	0.3	3.6	0.63	103.7	81.1286	47.2897
2015	12	6	11	12	22	0.3	3.6	0.6	103.2	81.1286	45.0258
2015	12	6	11	22	22	0.3	3.6	0.62	104.1	81.1286	46.0319
2015	12	6	11	32	22	0.3	3.6	0.62	102.6	81.1286	46.032
2015	12	6	11	42	22	0.3	3.6	0.63	103.5	81.063	46.9987
2015	12	6	11	52	22	0.3	3.6	0.63	104.8	81.063	46.7473
2015	12	6	12	2	22	0.3	3.6	0.6	103.6	81.1286	44.7742
2015	12	6	12	12	22	0.3	3.6	0.64	102.8	81.1286	47.5411
2015	12	6	12	22	22	0.3	3.6	0.59	104.1	81.1286	44.0197
2015	12	6	12	32	22	0.3	3.6	0.62	105	81.1286	46.032
2015	12	6	12	42	22	0.3	3.6	0.59	103.1	81.1286	44.2712
2015	12	6	12	52	22	0.3	3.6	0.61	104.9	81.1286	45.2773
2015	12	6	13	2	22	0.3	3.6	0.62	104.6	81.1286	46.2834
2015	12	6	13	12	22	0.3	3.6	0.62	105.4	81.1942	45.567
2015	12	6	13	22	22	0.3	3.6	0.63	101.7	81.063	47.5011
2015	12	6	13	32	22	0.3	3.6	0.63	105.1	81.063	46.4958
2015	12	6	13	42	22	0.3	3.6	0.64	100.7	81.063	48.0038
2015	12	6	13	52	22	0.3	3.6	0.65	104.5	81.1286	48.5473
2015	12	6	14	2	22	0.3	3.6	0.63	104.5	81.063	46.7472
2015	12	6	14	12	22	0.3	3.6	0.61	104.3	81.063	45.2393
2015	12	6	14	22	22	0.3	3.6	0.59	104.2	81.063	43.7313
2015	12	6	14	32	22	0.3	3.6	0.62	102.4	80.9974	46.708
2015	12	6	14	42	22	0.3	3.6	0.63	100.3	80.9974	47.2102
2015	12	6	14	52	22	0.3	3.6	0.59	104.5	80.9974	43.6946
2015	12	6	15	2	22	0.3	3.6	0.6	103.7	80.9974	44.448
2015	12	6	15	12	22	0.3	3.6	0.67	103.4	80.9318	49.6797
2015	12	6	15	22	22	0.3	3.6	0.64	105.3	80.9318	46.9197
2015	12	6	15	32	22	0.3	3.6	0.66	102.4	80.9318	48.927
2015	12	6	15	42	22	0.3	3.6	0.62	103.4	80.9318	46.167
2015	12	6	15	52	22	0.3	3.6	0.66	103.3	80.9318	48.927
2015	12	6	16	2	22	0.3	3.6	0.64	103	80.9318	47.9234
2015	12	6	16	12	22	0.3	3.6	0.62	102.4	80.9318	46.6688
2015	12	6	16	22	22	0.3	3.6	0.63	101.7	80.9318	47.1707
2015	12	6	16	32	22	0.3	3.6	0.63	103.5	80.9318	47.1707
2015	12	6	16	42	22	0.3	3.6	0.63	101.7	80.9318	47.1707
2015	12	6	16	52	22	0.3	3.6	0.6	102.1	80.9318	44.6616
2015	12	6	17	2	22	0.3	3.6	0.63	104.7	80.9318	46.9198
2015	12	6	17	12	22	0.3	3.6	0.65	102.3	80.9318	48.4252
2015	12	6	17	22	22	0.3	3.6	0.62	101.7	80.8661	46.1282
2015	12	6	17	32	22	0.3	3.6	0.58	105.1	80.8661	42.8691
2015	12	6	17	42	22	0.3	3.6	0.62	103.2	80.9318	45.9161
2015	12	6	17	52	22	0.3	3.6	0.61	103.4	80.9318	45.4143

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	18	2	22	0.3	3.6	0.63	103.7	80.9318	47.1707
2015	12	6	18	12	22	0.3	3.6	0.63	102.1	80.8661	46.8803
2015	12	6	18	22	22	0.3	3.6	0.66	102.4	80.8661	48.8858
2015	12	6	18	32	22	0.3	3.6	0.63	101.4	80.8661	47.3816
2015	12	6	18	42	22	0.3	3.6	0.64	102.8	80.8661	47.3816
2015	12	6	18	52	22	0.3	3.6	0.63	101.8	80.8661	46.8803
2015	12	6	19	2	22	0.3	3.6	0.62	107	80.8661	45.1254
2015	12	6	19	12	22	0.3	3.6	0.62	103.2	80.8661	45.8775
2015	12	6	19	22	22	0.3	3.6	0.64	101.5	80.8661	47.883
2015	12	6	19	32	22	0.3	3.6	0.61	102.1	80.8661	45.6268
2015	12	6	19	42	22	0.3	3.6	0.66	103.6	80.8661	48.8858
2015	12	6	19	52	22	0.3	3.6	0.62	101.8	80.8661	46.6296
2015	12	6	20	2	22	0.3	3.6	0.6	103.9	80.8661	44.624
2015	12	6	20	12	22	0.3	3.6	0.62	104.7	80.8661	45.8775
2015	12	6	20	22	22	0.3	3.6	0.64	101.5	80.8661	47.883
2015	12	6	20	32	22	0.3	3.6	0.61	103.3	80.8661	45.6268
2015	12	6	20	42	22	0.3	3.6	0.63	106	80.8661	46.3789
2015	12	6	20	52	22	0.3	3.6	0.64	102.8	80.8661	47.6323
2015	12	6	21	2	22	0.3	3.6	0.6	104.5	80.8005	44.5864
2015	12	6	21	12	22	0.3	3.6	0.63	103	80.8661	46.6296
2015	12	6	21	22	22	0.3	3.6	0.64	105	80.8005	46.8407
2015	12	6	21	32	22	0.3	3.6	0.63	101.7	80.8005	47.0912
2015	12	6	21	42	22	0.3	3.6	0.62	104.1	80.8661	45.8775
2015	12	6	21	52	22	0.3	3.6	0.62	102.6	80.8005	46.0893
2015	12	6	22	2	22	0.3	3.6	0.61	104.1	80.8005	44.8368
2015	12	6	22	12	22	0.3	3.6	0.6	101.6	80.8005	45.0873
2015	12	6	22	22	22	0.3	3.6	0.63	102.9	80.8005	46.8407
2015	12	6	22	32	22	0.3	3.6	0.62	105.6	80.8005	45.8388
2015	12	6	22	42	22	0.3	3.6	0.61	105.6	80.8005	44.8369
2015	12	6	22	52	22	0.3	3.6	0.62	104.8	80.8005	45.5883
2015	12	6	23	2	22	0.3	3.6	0.64	101.8	80.8005	47.8427
2015	12	6	23	12	22	0.3	3.6	0.65	105.6	80.8005	47.5922
2015	12	6	23	22	22	0.3	3.6	0.59	100.6	80.8005	44.0854
2015	12	6	23	32	22	0.3	3.6	0.62	100.3	80.8005	46.8407
2015	12	6	23	42	22	0.3	3.6	0.61	103.4	80.8005	45.0873
2015	12	6	23	52	22	0.3	3.6	0.65	104.4	80.8005	47.8427
2015	12	7	0	2	22	0.3	3.6	0.61	105.4	80.8005	44.5864
2015	12	7	0	12	22	0.3	3.6	0.58	103.3	80.8005	43.334
2015	12	7	0	22	22	0.3	3.6	0.63	105.1	80.8005	46.3398
2015	12	7	0	32	22	0.3	3.6	0.61	103.4	80.8005	45.3379
2015	12	7	0	42	22	0.3	3.6	0.65	103.5	80.8005	48.0932
2015	12	7	0	52	22	0.3	3.6	0.64	104.7	80.8005	47.5922
2015	12	7	1	2	22	0.3	3.6	0.64	103.3	80.8005	47.5922
2015	12	7	1	12	22	0.3	3.6	0.63	102.1	80.8005	46.8408
2015	12	7	1	22	22	0.3	3.6	0.63	102.6	80.8005	47.0913
2015	12	7	1	32	22	0.3	3.6	0.63	102.1	80.8005	46.8408

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	1	42	22	0.3	3.6	0.63	102.9	80.8005	46.8408
2015	12	7	1	52	22	0.3	3.6	0.63	101.2	80.8005	46.8408
2015	12	7	2	2	22	0.3	3.6	0.64	103.1	80.8005	47.3418
2015	12	7	2	12	22	0.3	3.6	0.65	105.8	80.8005	47.8427
2015	12	7	2	22	22	0.3	3.6	0.59	102.9	80.7349	43.798
2015	12	7	2	32	22	0.3	3.6	0.64	101	80.7349	47.8024
2015	12	7	2	42	22	0.3	3.6	0.62	101.4	80.7349	46.0504
2015	12	7	2	52	22	0.3	3.6	0.63	102.9	80.7349	47.0515
2015	12	7	3	2	22	0.3	3.6	0.64	103.5	80.8005	47.8427
2015	12	7	3	12	22	0.3	3.6	0.67	102.5	80.7349	49.8046
2015	12	7	3	22	22	0.3	3.6	0.62	101.8	80.8005	46.5903
2015	12	7	3	32	22	0.3	3.6	0.6	106.2	80.8005	44.0855
2015	12	7	3	42	22	0.3	3.6	0.6	101.4	80.7349	44.5488
2015	12	7	3	52	22	0.3	3.6	0.61	100.8	80.7349	46.0504
2015	12	7	4	2	22	0.3	3.6	0.64	102.1	80.7349	48.0527
2015	12	7	4	12	22	0.3	3.6	0.66	103	80.7349	48.8035
2015	12	7	4	22	22	0.3	3.6	0.65	101.4	80.7349	48.3029
2015	12	7	4	32	22	0.3	3.6	0.65	101.9	80.7349	48.8035
2015	12	7	4	42	22	0.3	3.6	0.64	104.9	80.7349	47.0516
2015	12	7	4	52	22	0.3	3.6	0.65	99.3	80.7349	49.0537
2015	12	7	5	2	22	0.3	3.6	0.66	103.6	80.7349	48.8035
2015	12	7	5	12	22	0.3	3.6	0.64	104	80.7349	47.3018
2015	12	7	5	22	22	0.3	3.6	0.61	102.1	80.7349	45.5499
2015	12	7	5	32	22	0.3	3.6	0.61	100.8	80.7349	46.0505
2015	12	7	5	42	22	0.3	3.6	0.65	103.1	80.7349	48.3029
2015	12	7	5	52	22	0.3	3.6	0.64	102.4	80.7349	47.8024
2015	12	7	6	2	22	0.3	3.6	0.65	100.2	80.7349	48.5532
2015	12	7	6	12	22	0.3	3.6	0.62	104	80.7349	46.0505
2015	12	7	6	22	22	0.3	3.6	0.65	100.7	80.7349	48.8035
2015	12	7	6	32	22	0.3	3.6	0.62	103.2	80.7349	45.8002
2015	12	7	6	42	22	0.3	3.6	0.63	103.9	80.7349	46.551
2015	12	7	6	52	22	0.3	3.6	0.64	102.5	80.7349	47.5521
2015	12	7	7	2	22	0.3	3.6	0.63	102.9	80.7349	47.0516
2015	12	7	7	12	22	0.3	3.6	0.64	105.5	80.7349	46.8013
2015	12	7	7	22	22	0.3	3.6	0.63	102	80.7349	47.0516
2015	12	7	7	32	22	0.3	3.6	0.64	102.4	80.7349	47.8024
2015	12	7	7	42	22	0.3	3.6	0.64	104	80.7349	47.3018
2015	12	7	7	52	22	0.3	3.6	0.63	106.2	80.7349	45.8002
2015	12	7	8	2	22	0.3	3.6	0.63	103.8	80.7349	46.8012
2015	12	7	8	12	22	0.3	3.6	0.62	100.9	80.7349	46.8012
2015	12	7	8	22	22	0.3	3.6	0.63	104.5	80.7349	46.3006
2015	12	7	8	32	22	0.3	3.6	0.63	103.7	80.7349	47.0514
2015	12	7	8	42	22	0.3	3.6	0.61	100.8	80.7349	46.0503
2015	12	7	8	52	22	0.3	3.6	0.61	103.4	80.8005	45.0872
2015	12	7	9	2	22	0.3	3.6	0.62	102.3	80.8005	46.0891
2015	12	7	9	12	22	0.3	3.6	0.6	105.8	80.8005	44.3357

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	9	22	22	0.3	3.6	0.65	101.9	80.8005	48.5939
2015	12	7	9	32	22	0.3	3.6	0.63	103.9	80.8005	46.59
2015	12	7	9	42	22	0.3	3.6	0.65	102.3	80.8005	48.3433
2015	12	7	9	52	22	0.3	3.6	0.63	103.3	80.8005	46.5899
2015	12	7	10	2	22	0.3	3.6	0.63	102.9	80.8005	47.0909
2015	12	7	10	12	22	0.3	3.6	0.62	102	80.8005	46.089
2015	12	7	10	22	22	0.3	3.6	0.6	101.7	80.8005	44.8366
2015	12	7	10	32	22	0.3	3.6	0.64	101.9	80.8005	47.5918
2015	12	7	10	42	22	0.3	3.6	0.63	100.8	80.8005	47.3413
2015	12	7	10	52	22	0.3	3.6	0.63	101.9	80.8005	47.3413
2015	12	7	11	2	22	0.3	3.6	0.6	102.3	80.8661	44.8742
2015	12	7	11	12	22	0.3	3.6	0.62	101.9	80.8661	46.3784
2015	12	7	11	22	22	0.3	3.6	0.65	101.7	80.8661	48.6347
2015	12	7	11	32	22	0.3	3.6	0.64	101.9	80.8005	47.5918
2015	12	7	11	42	22	0.3	3.6	0.61	101.2	80.8005	45.3374
2015	12	7	11	52	22	0.3	3.6	0.63	102.9	80.8005	47.0909
2015	12	7	12	2	22	0.3	3.6	0.61	98	80.8005	46.089
2015	12	7	12	12	22	0.3	3.6	0.61	101.2	80.8005	45.3374
2015	12	7	12	22	22	0.3	3.6	0.62	101.3	80.8005	46.3393
2015	12	7	12	32	22	0.3	3.6	0.62	103.5	80.8661	45.8769
2015	12	7	12	42	22	0.3	3.6	0.64	101.5	80.8005	48.0927
2015	12	7	12	52	22	0.3	3.6	0.63	102.1	80.8005	46.8403
2015	12	7	13	2	22	0.3	3.6	0.62	101.1	80.8005	46.0888
2015	12	7	13	12	22	0.3	3.6	0.6	101.7	80.8005	44.5859
2015	12	7	13	22	22	0.3	3.6	0.63	101.9	80.8005	47.3412
2015	12	7	13	32	22	0.3	3.6	0.61	101.2	80.8005	45.3373
2015	12	7	13	42	22	0.3	3.6	0.63	102.7	80.8005	46.5898
2015	12	7	13	52	22	0.3	3.6	0.6	99.7	80.8005	45.3374
2015	12	7	14	2	22	0.3	3.6	0.63	101.9	80.8005	47.3413
2015	12	7	14	12	22	0.3	3.6	0.61	101.5	80.7349	45.5495
2015	12	7	14	22	22	0.3	3.6	0.64	102.5	80.7349	47.3014
2015	12	7	14	32	22	0.3	3.6	0.64	102.1	80.7349	47.802
2015	12	7	14	42	22	0.3	3.6	0.65	102.6	80.7349	48.0523
2015	12	7	14	52	22	0.3	3.6	0.64	103.3	80.7349	47.5517
2015	12	7	15	2	22	0.3	3.6	0.64	100.9	80.7349	48.0523
2015	12	7	15	12	22	0.3	3.6	0.63	102.9	80.6693	47.0115
2015	12	7	15	22	22	0.3	3.6	0.65	102.6	80.6693	48.0117
2015	12	7	15	32	22	0.3	3.6	0.63	100.3	80.6693	47.0115
2015	12	7	15	42	22	0.3	3.6	0.62	101.5	80.6693	46.5114
2015	12	7	15	52	22	0.3	3.6	0.61	101.9	80.6693	45.2611
2015	12	7	16	2	22	0.3	3.6	0.62	101.8	80.6693	46.5114
2015	12	7	16	12	22	0.3	3.6	0.62	102.9	80.6693	46.0113
2015	12	7	16	22	22	0.3	3.6	0.62	100.7	80.6693	46.5114
2015	12	7	16	32	22	0.3	3.6	0.62	100.7	80.6693	46.2614
2015	12	7	16	42	22	0.3	3.6	0.62	101.9	80.6693	46.2614
2015	12	7	16	52	22	0.3	3.6	0.63	101.4	80.6693	47.0115

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	17	2	22	0.3	3.6	0.62	101.3	80.6693	46.2614
2015	12	7	17	12	22	0.3	3.6	0.6	101.3	80.6693	45.011
2015	12	7	17	22	22	0.3	3.6	0.64	101.2	80.6693	48.0118
2015	12	7	17	32	22	0.3	3.6	0.66	101.5	80.6693	49.012
2015	12	7	17	42	22	0.3	3.6	0.65	101.7	80.6037	48.221
2015	12	7	17	52	22	0.3	3.6	0.61	100.5	80.6693	46.0113
2015	12	7	18	2	22	0.3	3.6	0.64	104	80.6037	46.9718
2015	12	7	18	12	22	0.3	3.6	0.61	102.5	80.6037	45.2228
2015	12	7	18	22	22	0.3	3.6	0.62	102.8	80.6037	46.2222
2015	12	7	18	32	22	0.3	3.6	0.64	100.9	80.6037	48.221
2015	12	7	18	42	22	0.3	3.6	0.65	101.6	80.6037	48.7207
2015	12	7	18	52	22	0.3	3.6	0.65	100.1	80.6037	48.9706
2015	12	7	19	2	22	0.3	3.6	0.59	101.9	80.6037	43.9736
2015	12	7	19	12	22	0.3	3.6	0.65	100.5	80.6037	48.4709
2015	12	7	19	22	22	0.3	3.6	0.65	103.7	80.6037	48.221
2015	12	7	19	32	22	0.3	3.6	0.61	103.7	80.6037	45.2228
2015	12	7	19	42	22	0.3	3.6	0.63	103.3	80.6037	46.472
2015	12	7	19	52	22	0.3	3.6	0.63	102.9	80.6037	46.9717
2015	12	7	20	2	22	0.3	3.6	0.68	102.3	80.6037	50.2198
2015	12	7	20	12	22	0.3	3.6	0.63	101.7	80.6037	46.9717
2015	12	7	20	22	22	0.3	3.6	0.61	98.9	80.6037	46.2222
2015	12	7	20	32	22	0.3	3.6	0.61	101.2	80.6037	45.2228
2015	12	7	20	42	22	0.3	3.6	0.6	103.6	80.6037	44.4732
2015	12	7	20	52	22	0.3	3.6	0.59	99.2	80.6037	44.7231
2015	12	7	21	2	22	0.3	3.6	0.65	104.3	80.6037	47.9711
2015	12	7	21	12	22	0.3	3.6	0.63	99.9	80.6037	47.2216
2015	12	7	21	22	22	0.3	3.6	0.63	99.3	80.6037	47.4714
2015	12	7	21	32	22	0.3	3.6	0.61	101.2	80.5381	45.4341
2015	12	7	21	42	22	0.3	3.6	0.64	101.6	80.5381	47.4312
2015	12	7	21	52	22	0.3	3.6	0.64	102.1	80.5381	47.9305
2015	12	7	22	2	22	0.3	3.6	0.64	101.6	80.5381	47.4312
2015	12	7	22	12	22	0.3	3.6	0.65	102.6	80.5381	47.9305
2015	12	7	22	22	22	0.3	3.6	0.61	101.5	80.4724	45.3957
2015	12	7	22	32	22	0.3	3.6	0.59	101.5	80.4724	44.1485
2015	12	7	22	42	22	0.3	3.6	0.63	101.7	80.4724	47.1416
2015	12	7	22	52	22	0.3	3.6	0.63	100.8	80.4724	47.1416
2015	12	7	23	2	22	0.3	3.6	0.6	101.1	80.4724	44.398
2015	12	7	23	12	22	0.3	3.6	0.64	101.5	80.4724	47.6405
2015	12	7	23	22	22	0.3	3.6	0.63	103.5	80.4068	46.6033
2015	12	7	23	32	22	0.3	3.6	0.64	99.5	80.4068	47.6001
2015	12	7	23	42	22	0.3	3.6	0.63	104.1	80.4724	46.6428
2015	12	7	23	52	22	0.3	3.6	0.61	104.3	80.4068	45.108
2015	12	8	0	2	22	0.3	3.6	0.61	103.7	80.4068	45.108
2015	12	8	0	12	22	0.3	3.6	0.64	104	80.4068	47.1017
2015	12	8	0	22	22	0.3	3.6	0.6	100.9	80.4068	45.108
2015	12	8	0	32	22	0.3	3.6	0.63	104.5	80.4068	46.1049

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	0	42	22	0.3	3.6	0.62	99.8	80.4068	46.1049
2015	12	8	0	52	22	0.3	3.6	0.65	102.9	80.3412	47.8088
2015	12	8	1	2	22	0.3	3.6	0.62	101.9	80.4068	46.1049
2015	12	8	1	12	22	0.3	3.6	0.61	102.1	80.3412	45.3188
2015	12	8	1	22	22	0.3	3.6	0.64	103.1	80.3412	47.0618
2015	12	8	1	32	22	0.3	3.6	0.63	101.8	80.3412	46.5638
2015	12	8	1	42	22	0.3	3.6	0.63	101.8	80.3412	46.5638
2015	12	8	1	52	22	0.3	3.6	0.63	101.4	80.3412	47.0618
2015	12	8	2	2	22	0.3	3.6	0.62	101.3	80.3412	46.0658
2015	12	8	2	12	22	0.3	3.6	0.62	103.7	80.3412	46.0658
2015	12	8	2	22	22	0.3	3.6	0.67	104.2	80.3412	49.0539
2015	12	8	2	32	22	0.3	3.6	0.62	101	80.3412	46.0658
2015	12	8	2	42	22	0.3	3.6	0.64	100.9	80.3412	47.8088
2015	12	8	2	52	22	0.3	3.6	0.61	100	80.3412	45.3188
2015	12	8	3	2	22	0.3	3.6	0.6	103.2	80.3412	44.5718
2015	12	8	3	12	22	0.3	3.6	0.63	103.3	80.3412	46.3148
2015	12	8	3	22	22	0.3	3.6	0.63	100.8	80.3412	47.0618
2015	12	8	3	32	22	0.3	3.6	0.64	102.8	80.2756	47.2707
2015	12	8	3	42	22	0.3	3.6	0.62	101.6	80.3412	46.0658
2015	12	8	3	52	22	0.3	3.6	0.62	101	80.2756	46.0267
2015	12	8	4	2	22	0.3	3.6	0.64	103.1	80.3412	47.0618
2015	12	8	4	12	22	0.3	3.6	0.64	100.7	80.2756	47.5195
2015	12	8	4	22	22	0.3	3.6	0.62	102.9	80.2756	45.7779
2015	12	8	4	32	22	0.3	3.6	0.61	101.1	80.2756	45.5292
2015	12	8	4	42	22	0.3	3.6	0.63	101.2	80.3412	46.5639
2015	12	8	4	52	22	0.3	3.6	0.63	103.2	80.2756	46.7731
2015	12	8	5	2	22	0.3	3.6	0.63	101.7	80.2756	46.7731
2015	12	8	5	12	22	0.3	3.6	0.65	103.5	80.2756	47.7683
2015	12	8	5	22	22	0.3	3.6	0.6	100.9	80.2756	45.0316
2015	12	8	5	32	22	0.3	3.6	0.65	101.9	80.2756	48.2659
2015	12	8	5	42	22	0.3	3.6	0.63	101.2	80.2756	46.5244
2015	12	8	5	52	22	0.3	3.6	0.65	102.6	80.2756	48.0171
2015	12	8	6	2	22	0.3	3.6	0.66	105.4	80.2756	48.0171
2015	12	8	6	12	22	0.3	3.6	0.64	100.6	80.2756	47.7683
2015	12	8	6	22	22	0.3	3.6	0.63	102.9	80.2756	46.7732
2015	12	8	6	32	22	0.3	3.6	0.62	101	80.2756	46.0268
2015	12	8	6	42	22	0.3	3.6	0.6	102.5	80.2756	44.7828
2015	12	8	6	52	22	0.3	3.6	0.61	104.9	80.2756	44.7828
2015	12	8	7	2	22	0.3	3.6	0.64	103.7	80.2756	47.022
2015	12	8	7	12	22	0.3	3.6	0.62	101.1	80.2756	45.778
2015	12	8	7	22	22	0.3	3.6	0.63	100.8	80.2756	46.7732
2015	12	8	7	32	22	0.3	3.6	0.63	102.1	80.2756	46.5244
2015	12	8	7	42	22	0.3	3.6	0.6	101.7	80.2756	44.534
2015	12	8	7	52	22	0.3	3.6	0.64	101.5	80.2756	47.5195
2015	12	8	8	2	22	0.3	3.6	0.63	101.2	80.2756	46.5243
2015	12	8	8	12	22	0.3	3.6	0.65	101.4	80.2756	48.0171

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	8	22	22	0.3	3.6	0.64	104.6	80.3412	46.8128
2015	12	8	8	32	22	0.3	3.6	0.64	102.8	80.3412	47.0618
2015	12	8	8	42	22	0.3	3.6	0.65	101.7	80.2756	48.017
2015	12	8	8	52	22	0.3	3.6	0.61	104.1	80.2756	44.5339
2015	12	8	9	2	22	0.3	3.6	0.58	101.8	80.3412	43.0777
2015	12	8	9	12	22	0.3	3.6	0.62	101	80.3412	46.0657
2015	12	8	9	22	22	0.3	3.6	0.61	100.5	80.3412	45.8166
2015	12	8	9	32	22	0.3	3.6	0.6	100	80.3412	45.0696
2015	12	8	9	42	22	0.3	3.6	0.62	100.7	80.3412	46.0656
2015	12	8	9	52	22	0.3	3.6	0.63	101.8	80.3412	46.5636
2015	12	8	10	2	22	0.3	3.6	0.65	103.8	80.3412	47.5596
2015	12	8	10	12	22	0.3	3.6	0.6	100.3	80.3412	45.0695
2015	12	8	10	22	22	0.3	3.6	0.63	103.5	80.3412	46.5635
2015	12	8	10	32	22	0.3	3.6	0.59	98.9	80.3412	44.3225
2015	12	8	10	42	22	0.3	3.6	0.67	102.5	80.3412	49.3025
2015	12	8	10	52	22	0.3	3.6	0.62	102.4	80.4068	46.3537
2015	12	8	11	2	22	0.3	3.6	0.6	102.7	80.4068	44.36
2015	12	8	11	12	22	0.3	3.6	0.66	103.6	80.4068	48.5966
2015	12	8	11	22	22	0.3	3.6	0.61	102.7	80.4068	45.3568
2015	12	8	11	32	22	0.3	3.6	0.65	102.8	80.4068	48.0981
2015	12	8	11	42	22	0.3	3.6	0.62	102.9	80.4068	45.8553
2015	12	8	11	52	22	0.3	3.6	0.61	103	80.3412	45.3185
2015	12	8	12	2	22	0.3	3.6	0.62	101.1	80.3412	45.8165
2015	12	8	12	12	22	0.3	3.6	0.61	100.8	80.3412	45.5676
2015	12	8	12	22	22	0.3	3.6	0.62	102	80.3412	45.8165
2015	12	8	12	32	22	0.3	3.6	0.63	103	80.3412	46.3145
2015	12	8	12	42	22	0.3	3.6	0.62	100.9	80.4068	46.603
2015	12	8	12	52	22	0.3	3.6	0.62	99.8	80.3412	46.0655
2015	12	8	13	2	22	0.3	3.6	0.61	100.2	80.3412	45.5675
2015	12	8	13	12	22	0.3	3.6	0.64	103.9	80.3412	47.3105
2015	12	8	13	22	22	0.3	3.6	0.64	103.6	80.3412	47.3105
2015	12	8	13	32	22	0.3	3.6	0.61	102.8	80.3412	44.8204
2015	12	8	13	42	22	0.3	3.6	0.61	101.2	80.4068	45.3569
2015	12	8	13	52	22	0.3	3.6	0.6	99.5	80.3412	44.8205
2015	12	8	14	2	22	0.3	3.6	0.61	102.3	80.3412	45.5675
2015	12	8	14	12	22	0.3	3.6	0.64	104	80.3412	47.0616
2015	12	8	14	22	22	0.3	3.6	0.61	102.3	80.3412	45.5676
2015	12	8	14	32	22	0.3	3.6	0.62	103.4	80.3412	46.0656
2015	12	8	14	42	22	0.3	3.6	0.62	103.1	80.3412	46.0656
2015	12	8	14	52	22	0.3	3.6	0.64	101.3	80.3412	47.5597
2015	12	8	15	2	22	0.3	3.6	0.58	101.8	80.3412	43.0776
2015	12	8	15	12	22	0.3	3.6	0.64	99.5	80.3412	47.8087
2015	12	8	15	22	22	0.3	3.6	0.61	101.2	80.3412	45.3186
2015	12	8	15	32	22	0.3	3.6	0.65	101.4	80.3412	48.0577
2015	12	8	15	42	22	0.3	3.6	0.62	101.4	80.3412	45.8167
2015	12	8	15	52	22	0.3	3.6	0.61	103.4	80.3412	45.0697

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	16	2	22	0.3	3.6	0.62	103.4	80.3412	46.0657
2015	12	8	16	12	22	0.3	3.6	0.63	101.4	80.3412	47.0617
2015	12	8	16	22	22	0.3	3.6	0.65	102	80.3412	48.0577
2015	12	8	16	32	22	0.3	3.6	0.65	100.7	80.3412	48.5557
2015	12	8	16	42	22	0.3	3.6	0.64	100	80.3412	47.8087
2015	12	8	16	52	22	0.3	3.6	0.62	103.4	80.3412	46.0657
2015	12	8	17	2	22	0.3	3.6	0.65	104.4	80.3412	47.5597
2015	12	8	17	12	22	0.3	3.6	0.62	100.1	80.3412	46.3147
2015	12	8	17	22	22	0.3	3.6	0.63	102	80.3412	46.8127
2015	12	8	17	32	22	0.3	3.6	0.64	102.5	80.3412	47.0617
2015	12	8	17	42	22	0.3	3.6	0.63	103	80.3412	46.3147
2015	12	8	17	52	22	0.3	3.6	0.62	99.1	80.3412	46.8127
2015	12	8	18	2	22	0.3	3.6	0.63	100.7	80.3412	47.3107
2015	12	8	18	12	22	0.3	3.6	0.62	101	80.3412	46.0657
2015	12	8	18	22	22	0.3	3.6	0.62	102	80.3412	45.8167
2015	12	8	18	32	22	0.3	3.6	0.62	99.7	80.3412	46.5637
2015	12	8	18	42	22	0.3	3.6	0.62	102.6	80.3412	45.5677
2015	12	8	18	52	22	0.3	3.6	0.64	104.5	80.3412	47.0617
2015	12	8	19	2	22	0.3	3.6	0.6	103.9	80.3412	44.3227
2015	12	8	19	12	22	0.3	3.6	0.65	101.7	80.3412	48.0577
2015	12	8	19	22	22	0.3	3.6	0.64	102.7	80.3412	47.5597
2015	12	8	19	32	22	0.3	3.6	0.61	102.1	80.3412	45.3187
2015	12	8	19	42	22	0.3	3.6	0.64	105.7	80.3412	47.0617
2015	12	8	19	52	22	0.3	3.6	0.64	101	80.3412	47.3107
2015	12	8	20	2	22	0.3	3.6	0.65	102.8	80.3412	48.0577
2015	12	8	20	12	22	0.3	3.6	0.63	101.8	80.3412	46.5637
2015	12	8	20	22	22	0.3	3.6	0.64	104.6	80.3412	46.8127
2015	12	8	20	32	22	0.3	3.6	0.64	102.5	80.3412	47.0616
2015	12	8	20	42	22	0.3	3.6	0.65	102.3	80.3412	48.0577
2015	12	8	20	52	22	0.3	3.6	0.59	100.2	80.3412	44.3226
2015	12	8	21	2	22	0.3	3.6	0.62	102.2	80.3412	46.0656
2015	12	8	21	12	22	0.3	3.6	0.62	99.4	80.3412	46.5636
2015	12	8	21	22	22	0.3	3.6	0.64	100	80.3412	47.8087
2015	12	8	21	32	22	0.3	3.6	0.61	104	80.3412	45.0696
2015	12	8	21	42	22	0.3	3.6	0.64	102.7	80.4068	47.6
2015	12	8	21	52	22	0.3	3.6	0.64	101.6	80.4068	47.3508
2015	12	8	22	2	22	0.3	3.6	0.64	101.3	80.4068	47.6
2015	12	8	22	12	22	0.3	3.6	0.58	101.4	80.4068	43.1141
2015	12	8	22	22	22	0.3	3.6	0.62	103.2	80.4068	45.8555
2015	12	8	22	32	22	0.3	3.6	0.61	101.7	80.4068	45.6063
2015	12	8	22	42	22	0.3	3.6	0.65	100.7	80.4724	48.6381
2015	12	8	22	52	22	0.3	3.6	0.63	103.2	80.4724	46.8921
2015	12	8	23	2	22	0.3	3.6	0.64	103	80.4724	47.6404
2015	12	8	23	12	22	0.3	3.6	0.62	103.4	80.5381	46.1829
2015	12	8	23	22	22	0.3	3.6	0.6	102.5	80.5381	44.9347
2015	12	8	23	32	22	0.3	3.6	0.63	102.1	80.5381	46.6822

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	23	42	22	0.3	3.6	0.64	104.2	80.5381	47.4311
2015	12	8	23	52	22	0.3	3.6	0.63	99.6	80.5381	47.1815
2015	12	9	0	2	22	0.3	3.6	0.65	103.8	80.6037	47.971
2015	12	9	0	12	22	0.3	3.6	0.62	100.9	80.6037	46.7217
2015	12	9	0	22	22	0.3	3.6	0.62	102.9	80.6037	45.9722
2015	12	9	0	32	22	0.3	3.6	0.64	101.8	80.6037	47.971
2015	12	9	0	42	22	0.3	3.6	0.6	103.2	80.6037	44.7229
2015	12	9	0	52	22	0.3	3.6	0.6	101.1	80.6037	44.4731
2015	12	9	1	2	22	0.3	3.6	0.63	102	80.6037	46.9716
2015	12	9	1	12	22	0.3	3.6	0.6	105.1	80.6037	44.4731
2015	12	9	1	22	22	0.3	3.6	0.62	102.9	80.6693	46.0111
2015	12	9	1	32	22	0.3	3.6	0.62	102.3	80.6693	46.0111
2015	12	9	1	42	22	0.3	3.6	0.64	103.3	80.6693	47.5115
2015	12	9	1	52	22	0.3	3.6	0.62	102.6	80.6693	45.761
2015	12	9	2	2	22	0.3	3.6	0.62	101.1	80.6693	46.0111
2015	12	9	2	12	22	0.3	3.6	0.58	100.7	80.6693	43.5105
2015	12	9	2	22	22	0.3	3.6	0.64	105.5	80.6693	46.7613
2015	12	9	2	32	22	0.3	3.6	0.64	100.9	80.6693	48.0116
2015	12	9	2	42	22	0.3	3.6	0.62	102.2	80.6693	46.2612
2015	12	9	2	52	22	0.3	3.6	0.64	103.5	80.6693	47.7615
2015	12	9	3	2	22	0.3	3.6	0.6	102.6	80.6693	44.7608
2015	12	9	3	12	22	0.3	3.6	0.62	101	80.6693	46.5112
2015	12	9	3	22	22	0.3	3.6	0.65	101.7	80.6693	48.2617
2015	12	9	3	32	22	0.3	3.6	0.65	101.4	80.6693	48.2617
2015	12	9	3	42	22	0.3	3.6	0.63	102.2	80.6693	47.2614
2015	12	9	3	52	22	0.3	3.6	0.63	99.6	80.6693	47.5115
2015	12	9	4	2	22	0.3	3.6	0.63	101.1	80.6693	47.2614
2015	12	9	4	12	22	0.3	3.6	0.64	101.3	80.7349	47.8019
2015	12	9	4	22	22	0.3	3.6	0.67	101.3	80.7349	50.0543
2015	12	9	4	32	22	0.3	3.6	0.62	101.1	80.7349	46.05
2015	12	9	4	42	22	0.3	3.6	0.63	102	80.7349	47.0511
2015	12	9	4	52	22	0.3	3.6	0.59	100.2	80.7349	44.2981
2015	12	9	5	2	22	0.3	3.6	0.61	102.8	80.7349	45.2992
2015	12	9	5	12	22	0.3	3.6	0.62	99.1	80.7349	47.0511
2015	12	9	5	22	22	0.3	3.6	0.63	101.4	80.7349	47.0511
2015	12	9	5	32	22	0.3	3.6	0.66	102.6	80.7349	49.3035
2015	12	9	5	42	22	0.3	3.6	0.63	103	80.7349	46.5505
2015	12	9	5	52	22	0.3	3.6	0.64	103.5	80.7349	47.8019
2015	12	9	6	2	22	0.3	3.6	0.63	103.5	80.7349	46.8008
2015	12	9	6	12	22	0.3	3.6	0.64	104	80.7349	47.3014
2015	12	9	6	22	22	0.3	3.6	0.62	100.4	80.7349	46.3003
2015	12	9	6	32	22	0.3	3.6	0.62	101.5	80.8005	46.5899
2015	12	9	6	42	22	0.3	3.6	0.67	105.3	80.8005	49.3452
2015	12	9	6	52	22	0.3	3.6	0.62	103.4	80.8005	46.3394
2015	12	9	7	2	22	0.3	3.6	0.6	105.5	80.8005	44.3355
2015	12	9	7	12	22	0.3	3.6	0.62	103.9	80.8005	45.5879

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	7	22	22	0.3	3.6	0.61	101.2	80.8005	45.5879
2015	12	9	7	32	22	0.3	3.6	0.64	103.1	80.8005	47.3413
2015	12	9	7	42	22	0.3	3.6	0.64	102.5	80.8005	47.5918
2015	12	9	7	52	22	0.3	3.6	0.64	103.9	80.8005	47.5918
2015	12	9	8	2	22	0.3	3.6	0.64	100.3	80.8005	48.3432
2015	12	9	8	12	22	0.3	3.6	0.62	102.3	80.8005	46.0889
2015	12	9	8	22	22	0.3	3.6	0.66	102.4	80.8005	49.0947
2015	12	9	8	32	22	0.3	3.6	0.65	102.8	80.8661	48.384
2015	12	9	8	42	22	0.3	3.6	0.63	102.7	80.8661	46.8798
2015	12	9	8	52	22	0.3	3.6	0.61	101.2	80.8661	45.6263
2015	12	9	9	2	22	0.3	3.6	0.6	101	80.8661	45.1249
2015	12	9	9	12	22	0.3	3.6	0.62	100.9	80.8661	46.8797
2015	12	9	9	22	22	0.3	3.6	0.63	101.9	80.8661	47.3811
2015	12	9	9	32	22	0.3	3.6	0.64	101.3	80.9318	47.6718
2015	12	9	9	42	22	0.3	3.6	0.64	104.8	80.9318	47.4209
2015	12	9	9	52	22	0.3	3.6	0.63	103.5	80.9318	46.9191
2015	12	9	10	2	22	0.3	3.6	0.62	102	80.9318	46.1663
2015	12	9	10	12	22	0.3	3.6	0.63	101.4	80.9318	47.1699
2015	12	9	10	22	22	0.3	3.6	0.64	104	80.9318	47.4208
2015	12	9	10	32	22	0.3	3.6	0.64	103.6	80.9974	47.7119
2015	12	9	10	42	22	0.3	3.6	0.63	102.7	80.9318	46.6681
2015	12	9	10	52	22	0.3	3.6	0.63	102.7	80.9974	46.7074
2015	12	9	11	2	22	0.3	3.6	0.64	102.4	80.9974	47.9629
2015	12	9	11	12	22	0.3	3.6	0.61	101.8	80.9974	45.7028
2015	12	9	11	22	22	0.3	3.6	0.63	102.1	80.9974	46.9583
2015	12	9	11	32	22	0.3	3.6	0.64	103	80.9974	47.7117
2015	12	9	11	42	22	0.3	3.6	0.62	100.1	81.063	46.4952
2015	12	9	11	52	22	0.3	3.6	0.65	103.4	80.9974	48.4651
2015	12	9	12	2	22	0.3	3.6	0.61	97.4	81.063	46.2439
2015	12	9	12	12	22	0.3	3.6	0.64	103.1	80.9974	47.4606
2015	12	9	12	22	22	0.3	3.6	0.63	102.7	80.9974	46.7072
2015	12	9	12	32	22	0.3	3.6	0.65	103.8	80.9974	48.2139
2015	12	9	12	42	22	0.3	3.6	0.65	101.6	81.063	49.0084
2015	12	9	12	52	22	0.3	3.6	0.65	102.8	81.063	48.757
2015	12	9	13	2	22	0.3	3.6	0.63	104.8	81.063	46.7464
2015	12	9	13	12	22	0.3	3.6	0.6	98.7	81.063	45.7411
2015	12	9	13	22	22	0.3	3.6	0.62	103.4	81.063	46.2438
2015	12	9	13	32	22	0.3	3.6	0.63	102.3	81.063	47.2491
2015	12	9	13	42	22	0.3	3.6	0.64	104	81.063	47.2491
2015	12	9	13	52	22	0.3	3.6	0.64	104	81.063	47.5004
2015	12	9	14	2	22	0.3	3.6	0.64	101.9	81.063	47.7518
2015	12	9	14	12	22	0.3	3.6	0.63	100.8	81.063	47.5005
2015	12	9	14	22	22	0.3	3.6	0.66	102.6	81.063	49.5111
2015	12	9	14	32	22	0.3	3.6	0.63	104.1	81.063	46.9979
2015	12	9	14	42	22	0.3	3.6	0.65	99.6	80.9974	48.9673
2015	12	9	14	52	22	0.3	3.6	0.65	104.1	80.9974	47.9629

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	15	2	22	0.3	3.6	0.62	102.3	81.063	46.244
2015	12	9	15	12	22	0.3	3.6	0.63	103.2	80.9974	47.2097
2015	12	9	15	22	22	0.3	3.6	0.67	103.9	80.9974	49.7208
2015	12	9	15	32	22	0.3	3.6	0.62	103.5	80.9974	45.9541
2015	12	9	15	42	22	0.3	3.6	0.65	103.2	80.9974	48.2142
2015	12	9	15	52	22	0.3	3.6	0.65	103.4	80.9974	48.4653
2015	12	9	16	2	22	0.3	3.6	0.64	102.1	80.9974	47.9631
2015	12	9	16	12	22	0.3	3.6	0.64	104.2	80.9974	47.712
2015	12	9	16	22	22	0.3	3.6	0.63	102.9	80.9974	46.9586
2015	12	9	16	32	22	0.3	3.6	0.63	101.1	80.9974	47.4609
2015	12	9	16	42	22	0.3	3.6	0.66	104.5	80.9974	48.7164
2015	12	9	16	52	22	0.3	3.6	0.65	101.1	80.9974	48.4653
2015	12	9	17	2	22	0.3	3.6	0.63	101.9	80.9974	47.4609
2015	12	9	17	12	22	0.3	3.6	0.61	101.7	80.9974	45.9542
2015	12	9	17	22	22	0.3	3.6	0.68	103.2	80.9974	50.4743
2015	12	9	17	32	22	0.3	3.6	0.6	102.7	80.9974	44.6986
2015	12	9	17	42	22	0.3	3.6	0.63	102.7	80.9974	46.7075
2015	12	9	17	52	22	0.3	3.6	0.68	102	80.9974	50.7254
2015	12	9	18	2	22	0.3	3.6	0.66	102.4	80.9974	48.9675
2015	12	9	18	12	22	0.3	3.6	0.66	101.5	80.9974	49.4698
2015	12	9	18	22	22	0.3	3.6	0.62	100.9	81.063	46.9981
2015	12	9	18	32	22	0.3	3.6	0.64	102.8	81.063	47.7521
2015	12	9	18	42	22	0.3	3.6	0.6	101.4	81.063	44.9875
2015	12	9	18	52	22	0.3	3.6	0.66	103	81.063	49.0087
2015	12	9	19	2	22	0.3	3.6	0.64	101.6	81.063	47.7521
2015	12	9	19	12	22	0.3	3.6	0.6	101.4	81.063	44.9875
2015	12	9	19	22	22	0.3	3.6	0.63	102.1	81.063	46.9981
2015	12	9	19	32	22	0.3	3.6	0.64	100.6	81.063	48.5061
2015	12	9	19	42	22	0.3	3.6	0.63	104.2	81.063	46.7468
2015	12	9	19	52	22	0.3	3.6	0.64	100.4	81.063	48.0034
2015	12	9	20	2	22	0.3	3.6	0.6	105.3	81.063	43.9822
2015	12	9	20	12	22	0.3	3.6	0.64	101.3	81.063	47.7521
2015	12	9	20	22	22	0.3	3.6	0.62	102.1	81.063	46.7467
2015	12	9	20	32	22	0.3	3.6	0.64	101.6	81.1286	47.7922
2015	12	9	20	42	22	0.3	3.6	0.64	100	81.1286	48.2953
2015	12	9	20	52	22	0.3	3.6	0.63	102.9	81.1286	47.2891
2015	12	9	21	2	22	0.3	3.6	0.64	102.5	81.063	47.752
2015	12	9	21	12	22	0.3	3.6	0.62	103.7	81.1286	46.283
2015	12	9	21	22	22	0.3	3.6	0.64	102.5	81.1286	47.7922
2015	12	9	21	32	22	0.3	3.6	0.65	101.4	81.1286	48.7983
2015	12	9	21	42	22	0.3	3.6	0.62	101.3	81.1286	46.786
2015	12	9	21	52	22	0.3	3.6	0.65	101.6	81.1286	49.0499
2015	12	9	22	2	22	0.3	3.6	0.6	104.8	81.1286	44.7737
2015	12	9	22	12	22	0.3	3.6	0.61	103.3	81.1286	45.7799
2015	12	9	22	22	22	0.3	3.6	0.65	102.2	81.1286	49.0498
2015	12	9	22	32	22	0.3	3.6	0.65	99.3	81.1286	49.0498

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	22	42	22	0.3	3.6	0.64	103	81.1286	47.7922
2015	12	9	22	52	22	0.3	3.6	0.64	103.6	81.1942	47.8323
2015	12	9	23	2	22	0.3	3.6	0.62	100.6	81.1942	47.0771
2015	12	9	23	12	22	0.3	3.6	0.59	99.2	81.1942	45.0631
2015	12	9	23	22	22	0.3	3.6	0.63	102	81.1942	47.3288
2015	12	9	23	32	22	0.3	3.6	0.62	102.3	81.1942	46.3218
2015	12	9	23	42	22	0.3	3.6	0.65	102.6	81.1942	48.5876
2015	12	9	23	52	22	0.3	3.6	0.62	103.1	81.1942	46.5736
2015	12	10	0	2	22	0.3	3.6	0.64	103	81.1942	48.0841
2015	12	10	0	12	22	0.3	3.6	0.67	103.2	81.1942	50.3498
2015	12	10	0	22	22	0.3	3.6	0.64	100.7	81.1942	48.0841
2015	12	10	0	32	22	0.3	3.6	0.6	101.3	81.1942	45.3148
2015	12	10	0	42	22	0.3	3.6	0.62	103.8	81.1942	46.0701
2015	12	10	0	52	22	0.3	3.6	0.63	103.3	81.2598	46.8646
2015	12	10	1	2	22	0.3	3.6	0.64	101.8	81.2598	48.1245
2015	12	10	1	12	22	0.3	3.6	0.63	102.4	81.2598	47.1166
2015	12	10	1	22	22	0.3	3.6	0.64	102.3	81.2598	48.3764
2015	12	10	1	32	22	0.3	3.6	0.61	101.7	81.2598	46.1088
2015	12	10	1	42	22	0.3	3.6	0.64	103.4	81.3255	47.6605
2015	12	10	1	52	22	0.3	3.6	0.64	101.8	81.3911	48.4576
2015	12	10	2	2	22	0.3	3.6	0.64	102.5	81.3911	47.7005
2015	12	10	2	12	22	0.3	3.6	0.64	103.1	81.3911	47.7005
2015	12	10	2	22	22	0.3	3.6	0.64	103.4	81.4567	47.7404
2015	12	10	2	32	22	0.3	3.6	0.62	100.6	81.4567	47.2352
2015	12	10	2	42	22	0.3	3.6	0.63	101.7	81.4567	47.7404
2015	12	10	2	52	22	0.3	3.6	0.62	103.2	81.4567	46.4774
2015	12	10	3	2	22	0.3	3.6	0.61	102.4	81.4567	45.9723
2015	12	10	3	12	22	0.3	3.6	0.64	100.4	81.5223	48.286
2015	12	10	3	22	22	0.3	3.6	0.64	101	81.4567	47.993
2015	12	10	3	32	22	0.3	3.6	0.66	100	81.5223	50.0556
2015	12	10	3	42	22	0.3	3.6	0.62	104.2	81.5223	46.0107
2015	12	10	3	52	22	0.3	3.6	0.65	100.1	81.5223	49.55
2015	12	10	4	2	22	0.3	3.6	0.64	100.6	81.5223	48.5388
2015	12	10	4	12	22	0.3	3.6	0.62	98.6	81.5223	47.022
2015	12	10	4	22	22	0.3	3.6	0.64	99.5	81.5223	48.286
2015	12	10	4	32	22	0.3	3.6	0.64	105.5	81.5223	47.2748
2015	12	10	4	42	22	0.3	3.6	0.66	102.9	81.5223	49.8028
2015	12	10	4	52	22	0.3	3.6	0.65	104	81.5223	48.5388
2015	12	10	5	2	22	0.3	3.6	0.63	102.7	81.5879	47.3143
2015	12	10	5	12	22	0.3	3.6	0.63	101.8	81.5879	47.3143
2015	12	10	5	22	22	0.3	3.6	0.64	101.9	81.5879	48.0734
2015	12	10	5	32	22	0.3	3.6	0.61	102.3	81.5879	46.3023
2015	12	10	5	42	22	0.3	3.6	0.64	98.6	81.5879	48.5794
2015	12	10	5	52	22	0.3	3.6	0.65	104.2	81.5879	48.8324
2015	12	10	6	2	22	0.3	3.6	0.63	103.2	81.5879	47.5674
2015	12	10	6	12	22	0.3	3.6	0.63	103.2	81.5879	47.3143

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	6	22	22	0.3	3.6	0.64	99.7	81.5879	48.8325
2015	12	10	6	32	22	0.3	3.6	0.62	99.5	81.6535	47.1007
2015	12	10	6	42	22	0.3	3.6	0.62	102	81.6535	46.5942
2015	12	10	6	52	22	0.3	3.6	0.61	102.8	81.5879	45.5432
2015	12	10	7	2	22	0.3	3.6	0.64	104.3	81.6535	47.6071
2015	12	10	7	12	22	0.3	3.6	0.64	102.3	81.6535	48.62
2015	12	10	7	22	22	0.3	3.6	0.65	102.8	81.6535	49.1265
2015	12	10	7	32	22	0.3	3.6	0.65	102.8	81.6535	49.1265
2015	12	10	7	42	22	0.3	3.6	0.65	99.9	81.6535	49.1264
2015	12	10	7	52	22	0.3	3.6	0.67	103.1	81.6535	50.1394
2015	12	10	8	2	22	0.3	3.6	0.63	101.7	81.6535	47.8603
2015	12	10	8	12	22	0.3	3.6	0.61	101.2	81.6535	45.8344
2015	12	10	8	22	22	0.3	3.6	0.63	100.8	81.7192	47.9002
2015	12	10	8	32	22	0.3	3.6	0.61	104.7	81.7192	45.3658
2015	12	10	8	42	22	0.3	3.6	0.64	103	81.7192	48.407
2015	12	10	8	52	22	0.3	3.6	0.65	100.2	81.7192	49.4208
2015	12	10	9	2	22	0.3	3.6	0.6	101.3	81.7192	45.6192
2015	12	10	9	12	22	0.3	3.6	0.62	101.8	81.7192	47.1399
2015	12	10	9	22	22	0.3	3.6	0.64	102.1	81.7192	48.4071
2015	12	10	9	32	22	0.3	3.6	0.63	102.3	81.7192	47.6467
2015	12	10	9	42	22	0.3	3.6	0.62	100.4	81.7848	47.1791
2015	12	10	9	52	22	0.3	3.6	0.64	100.6	81.7848	48.7009
2015	12	10	10	2	22	0.3	3.6	0.63	100.7	81.7848	48.1936
2015	12	10	10	12	22	0.3	3.6	0.61	99.9	81.7848	46.4181
2015	12	10	10	22	22	0.3	3.6	0.61	102.3	81.7848	46.4181
2015	12	10	10	32	22	0.3	3.6	0.66	102.7	81.7848	49.462
2015	12	10	10	42	22	0.3	3.6	0.63	102.7	81.7848	47.1791
2015	12	10	10	52	22	0.3	3.6	0.63	104.5	81.7848	46.9254
2015	12	10	11	2	22	0.3	3.6	0.6	103	81.7848	44.8962
2015	12	10	11	12	22	0.3	3.6	0.61	101.2	81.7848	46.1644
2015	12	10	11	22	22	0.3	3.6	0.64	103.1	81.7848	47.94
2015	12	10	11	32	22	0.3	3.6	0.63	103.2	81.8504	47.4722
2015	12	10	11	42	22	0.3	3.6	0.61	103.7	81.8504	45.6952
2015	12	10	11	52	22	0.3	3.6	0.67	104.2	81.7848	49.9692
2015	12	10	12	2	22	0.3	3.6	0.67	103.9	81.7848	50.2228
2015	12	10	12	12	22	0.3	3.6	0.63	100.8	81.8504	47.726
2015	12	10	12	22	22	0.3	3.6	0.62	102	81.8504	46.7105
2015	12	10	12	32	22	0.3	3.6	0.63	99.3	81.8504	47.9799
2015	12	10	12	42	22	0.3	3.6	0.66	103.2	81.8504	49.7569
2015	12	10	12	52	22	0.3	3.6	0.62	103.7	81.8504	46.7106
2015	12	10	13	2	22	0.3	3.6	0.65	100.5	81.8504	49.5031
2015	12	10	13	12	22	0.3	3.6	0.66	100.9	81.8504	50.2646
2015	12	10	13	22	22	0.3	3.6	0.63	103.3	81.8504	47.2183
2015	12	10	13	32	22	0.3	3.6	0.63	102.4	81.916	47.5117
2015	12	10	13	42	22	0.3	3.6	0.65	101	81.8504	49.503
2015	12	10	13	52	22	0.3	3.6	0.67	101	81.916	51.0687

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	14	2	22	0.3	3.6	0.62	103.4	81.916	46.7494
2015	12	10	14	12	22	0.3	3.6	0.64	103	81.916	48.2739
2015	12	10	14	22	22	0.3	3.6	0.64	101.9	81.916	48.2739
2015	12	10	14	32	22	0.3	3.6	0.64	101.8	81.9816	48.8226
2015	12	10	14	42	22	0.3	3.6	0.65	99.9	81.916	49.2901
2015	12	10	14	52	22	0.3	3.6	0.64	100	81.916	48.782
2015	12	10	15	2	22	0.3	3.6	0.63	103.5	81.916	47.7657
2015	12	10	15	12	22	0.3	3.6	0.64	98	81.9816	49.0769
2015	12	10	15	22	22	0.3	3.6	0.62	100.4	82.0472	47.3362
2015	12	10	15	32	22	0.3	3.6	0.67	103	81.9816	50.8569
2015	12	10	15	42	22	0.3	3.6	0.64	101.5	81.9816	48.5683
2015	12	10	15	52	22	0.3	3.6	0.66	102	81.9816	50.094
2015	12	10	16	2	22	0.3	3.6	0.6	101.3	81.9816	45.7712
2015	12	10	16	12	22	0.3	3.6	0.64	102.1	81.9816	48.8226
2015	12	10	16	22	22	0.3	3.6	0.65	103.2	81.9816	48.8226
2015	12	10	16	32	22	0.3	3.6	0.65	99.8	81.9816	49.8397
2015	12	10	16	42	22	0.3	3.6	0.63	103.3	82.0472	47.3362
2015	12	10	16	52	22	0.3	3.6	0.6	101.3	81.9816	45.7712
2015	12	10	17	2	22	0.3	3.6	0.65	103.4	82.0472	49.1176
2015	12	10	17	12	22	0.3	3.6	0.63	102.9	82.0472	47.8452
2015	12	10	17	22	22	0.3	3.6	0.66	101.8	82.0472	49.8811
2015	12	10	17	32	22	0.3	3.6	0.64	100.9	82.0472	48.8631
2015	12	10	17	42	22	0.3	3.6	0.61	99.6	82.0472	46.8272
2015	12	10	17	52	22	0.3	3.6	0.63	101.4	82.1129	47.8849
2015	12	10	18	2	22	0.3	3.6	0.64	102.3	82.1785	48.9443
2015	12	10	18	12	22	0.3	3.6	0.6	101.3	82.1129	45.8472
2015	12	10	18	22	22	0.3	3.6	0.67	101.5	82.1129	51.196
2015	12	10	18	32	22	0.3	3.6	0.64	98.9	82.1785	48.9443
2015	12	10	18	42	22	0.3	3.6	0.61	100.5	82.1785	46.65
2015	12	10	18	52	22	0.3	3.6	0.63	99.6	82.1785	48.1795
2015	12	10	19	2	22	0.3	3.6	0.66	103.3	82.2441	49.7502
2015	12	10	19	12	22	0.3	3.6	0.62	102.8	82.3097	47.238
2015	12	10	19	22	22	0.3	3.6	0.64	103.3	82.3097	48.7701
2015	12	10	19	32	22	0.3	3.6	0.64	102.2	82.3753	48.5549
2015	12	10	19	42	22	0.3	3.6	0.62	100.1	82.3753	47.2771
2015	12	10	19	52	22	0.3	3.6	0.63	100	82.3097	48.004
2015	12	10	20	2	22	0.3	3.6	0.62	100.7	82.3753	47.2771
2015	12	10	20	12	22	0.3	3.6	0.59	98	82.3753	45.2327
2015	12	10	20	22	22	0.3	3.9	0.65	101.9	82.4409	49.8739
2015	12	10	20	32	22	0.3	3.9	0.66	101.5	82.4409	50.1296
2015	12	10	20	42	22	0.3	3.9	0.63	98.7	82.4409	48.3393
2015	12	10	20	52	22	0.3	3.9	0.63	99	82.4409	48.3393
2015	12	10	21	2	22	0.3	3.9	0.65	103.8	82.4409	49.1065
2015	12	10	21	12	22	0.3	3.9	0.64	103.3	82.4409	48.8508
2015	12	10	21	22	22	0.3	3.9	0.65	98.9	82.4409	50.3854
2015	12	10	21	32	22	0.3	3.9	0.62	101	82.4409	47.3162

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	21	42	22	0.3	3.9	0.64	102.1	82.5066	49.1471
2015	12	10	21	52	22	0.3	3.9	0.67	99	82.5066	51.9628
2015	12	10	22	2	22	0.3	3.9	0.69	99.2	82.4409	53.4545
2015	12	10	22	12	22	0.3	3.9	0.66	97.1	82.4409	51.1526
2015	12	10	22	22	22	0.3	3.9	0.65	98.1	82.5066	50.427
2015	12	10	22	32	22	0.3	3.9	0.65	98.7	82.5066	49.915
2015	12	10	22	42	22	0.3	3.9	0.64	100.9	82.5066	49.4031
2015	12	10	22	52	22	0.3	3.9	0.67	100.2	82.5066	51.1949
2015	12	10	23	2	22	0.3	3.9	0.68	94.4	82.5066	52.9867
2015	12	10	23	12	22	0.3	3.9	0.64	98	82.5722	49.4439
2015	12	10	23	22	22	0.3	3.9	0.63	102.4	82.5722	47.9067
2015	12	10	23	32	22	0.3	3.9	0.64	102.2	82.5722	48.6753
2015	12	10	23	42	22	0.3	3.9	0.64	101.3	82.5722	48.6753
2015	12	10	23	52	22	0.3	3.9	0.64	101.3	82.6378	48.7155
2015	12	11	0	2	22	0.3	3.9	0.64	99.4	82.6378	49.4846
2015	12	11	0	12	22	0.3	3.9	0.63	102.1	82.6378	47.9463
2015	12	11	0	22	22	0.3	3.9	0.67	102.5	82.6378	51.023
2015	12	11	0	32	22	0.3	3.9	0.64	100.6	82.6378	49.4846
2015	12	11	0	42	22	0.3	3.9	0.67	98.7	82.6378	51.7922
2015	12	11	0	52	22	0.3	3.9	0.64	100.7	82.6378	48.9718
2015	12	11	1	2	22	0.3	3.9	0.71	98	82.6378	54.869
2015	12	11	1	12	22	0.3	3.9	0.63	101.4	82.6378	48.459
2015	12	11	1	22	22	0.3	3.9	0.64	104	82.6378	48.459
2015	12	11	1	32	22	0.3	3.9	0.62	102.2	82.6378	47.4334
2015	12	11	1	42	22	0.3	3.9	0.67	102.1	82.6378	51.5358
2015	12	11	1	52	22	0.3	3.9	0.64	102.5	82.6378	48.459
2015	12	11	2	2	22	0.3	3.9	0.67	101.8	82.7034	51.5783
2015	12	11	2	12	22	0.3	3.9	0.64	99.5	82.7034	49.0122
2015	12	11	2	22	22	0.3	3.9	0.67	99	82.7034	51.5783
2015	12	11	2	32	22	0.3	3.9	0.63	100.4	82.7034	48.7556
2015	12	11	2	42	22	0.3	3.9	0.65	101.7	82.7034	49.5254
2015	12	11	2	52	22	0.3	3.9	0.64	103.1	82.7034	48.499
2015	12	11	3	2	22	0.3	3.9	0.64	102.4	82.7034	49.0122
2015	12	11	3	12	22	0.3	3.9	0.66	100.3	82.7034	51.065
2015	12	11	3	22	22	0.3	3.9	0.67	100.8	82.7034	51.3216
2015	12	11	3	32	22	0.3	3.9	0.63	101.1	82.7034	48.499
2015	12	11	3	42	22	0.3	3.9	0.65	102	82.769	49.5662
2015	12	11	3	52	22	0.3	3.9	0.65	99.4	82.769	49.823
2015	12	11	4	2	22	0.3	3.9	0.65	102	82.769	49.5662
2015	12	11	4	12	22	0.3	3.9	0.65	99.7	82.769	49.823
2015	12	11	4	22	22	0.3	3.9	0.67	102.7	82.769	51.1071
2015	12	11	4	32	22	0.3	3.9	0.65	102.6	82.769	49.5662
2015	12	11	4	42	22	0.3	3.9	0.64	100.9	82.769	49.3094
2015	12	11	4	52	22	0.3	3.9	0.64	101	82.769	49.0525
2015	12	11	5	2	22	0.3	3.9	0.68	102.9	82.769	51.6207
2015	12	11	5	12	22	0.3	3.9	0.64	100.9	82.769	49.5662

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	5	22	22	0.3	3.9	0.65	102.8	82.8347	49.607
2015	12	11	5	32	22	0.3	3.9	0.64	104	82.8347	48.3218
2015	12	11	5	42	22	0.3	3.9	0.65	100.2	82.8347	50.121
2015	12	11	5	52	22	0.3	3.9	0.63	102.1	82.8347	48.0648
2015	12	11	6	2	22	0.3	3.9	0.66	102.9	82.8347	50.6351
2015	12	11	6	12	22	0.3	3.9	0.62	101.3	82.8347	47.5507
2015	12	11	6	22	22	0.3	3.9	0.64	100.9	82.8347	49.35
2015	12	11	6	32	22	0.3	3.9	0.61	104.6	82.8347	46.5226
2015	12	11	6	42	22	0.3	3.9	0.68	99.1	82.8347	52.6914
2015	12	11	6	52	22	0.3	3.9	0.65	99.3	82.9659	50.461
2015	12	11	7	2	22	0.3	3.9	0.67	97.6	83.0315	52.0484
2015	12	11	7	12	22	0.3	3.9	0.67	96.5	83.0315	52.0484
2015	12	11	7	22	22	0.3	3.9	0.68	98.3	83.0315	52.8214
2015	12	11	7	32	22	0.3	3.9	0.63	98.1	82.9659	48.9162
2015	12	11	7	42	22	0.3	3.9	0.63	99.6	82.9659	48.9162
2015	12	11	7	52	22	0.3	3.9	0.64	99.8	82.9003	49.3905
2015	12	11	8	2	22	0.3	3.9	0.62	98.9	82.9659	47.8863
2015	12	11	8	12	22	0.3	3.9	0.66	99.2	83.0971	51.0595
2015	12	11	8	22	22	0.3	3.9	0.64	100.9	82.9659	49.431
2015	12	11	8	32	22	0.3	3.9	0.62	101.9	83.0315	47.6679
2015	12	11	8	42	22	0.3	3.9	0.66	101.4	83.0315	51.0175
2015	12	11	8	52	22	0.3	3.9	0.63	100.7	83.0315	48.9562
2015	12	11	9	2	22	0.3	3.9	0.63	102.1	83.1627	48.2622
2015	12	11	9	12	22	0.3	3.9	0.65	103.6	83.1627	50.0688
2015	12	11	9	22	22	0.3	3.9	0.63	101.8	83.2284	48.3017
2015	12	11	9	32	22	0.3	3.9	0.63	103.6	83.2284	48.0434
2015	12	11	9	42	22	0.3	3.9	0.64	103.3	83.294	49.3752
2015	12	11	9	52	22	0.3	3.9	0.66	101.1	83.294	51.1847
2015	12	11	10	2	22	0.3	3.9	0.65	101.4	83.3596	49.933
2015	12	11	10	12	22	0.3	3.9	0.62	100.1	83.3596	48.1219
2015	12	11	10	22	22	0.3	3.9	0.62	103.8	83.3596	47.3457
2015	12	11	10	32	22	0.3	3.9	0.65	104.4	83.3596	49.4154
2015	12	11	10	42	22	0.3	3.9	0.64	102.7	83.3596	49.4155
2015	12	11	10	52	22	0.3	3.9	0.68	100.3	83.3596	52.7789
2015	12	11	11	2	22	0.3	3.9	0.62	102.8	83.3596	47.8633
2015	12	11	11	12	22	0.3	3.9	0.66	103.8	83.4252	50.4916
2015	12	11	11	22	22	0.3	3.9	0.65	101.1	83.4252	50.2326
2015	12	11	11	32	22	0.3	3.9	0.61	100.2	83.4252	47.3844
2015	12	11	11	42	22	0.3	3.9	0.65	99.8	83.4252	50.7504
2015	12	11	11	52	22	0.3	3.9	0.63	101.1	83.4252	48.9379
2015	12	11	12	2	22	0.3	3.9	0.62	100.7	83.4908	48.2004
2015	12	11	12	12	22	0.3	3.9	0.65	101.4	83.4908	50.0144
2015	12	11	12	22	22	0.3	3.9	0.62	101.3	83.4252	48.1612
2015	12	11	12	32	22	0.3	3.9	0.65	102.6	83.4908	49.7552
2015	12	11	12	42	22	0.3	3.9	0.66	101	83.4908	50.7918
2015	12	11	12	52	22	0.3	3.9	0.62	103.2	83.4908	47.6821

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	13	2	22	0.3	3.9	0.66	101.8	83.4908	51.0509
2015	12	11	13	12	22	0.3	3.9	0.66	104.4	83.4908	50.5326
2015	12	11	13	22	22	0.3	3.9	0.66	97.5	83.4908	51.3101
2015	12	11	13	32	22	0.3	3.9	0.68	98.9	83.4908	52.865
2015	12	11	13	42	22	0.3	3.9	0.71	97.9	83.4908	55.7156
2015	12	11	13	52	22	0.3	3.9	0.71	99.9	83.4252	54.8933
2015	12	11	14	2	22	0.3	3.9	0.64	98.9	83.4252	49.7147
2015	12	11	14	12	22	0.3	3.9	0.69	100.1	83.4908	53.6425
2015	12	11	14	22	22	0.3	3.9	0.66	99.1	83.4252	51.5273
2015	12	11	14	32	22	0.3	3.9	0.69	93.5	83.4908	54.6792
2015	12	11	14	42	22	0.3	3.9	0.68	100.5	83.4908	53.1243
2015	12	11	14	52	22	0.3	3.9	0.69	97.7	83.4908	53.9018
2015	12	11	15	2	22	0.3	3.9	0.65	99.6	83.4908	50.7921
2015	12	11	15	12	22	0.3	3.9	0.69	97.7	83.5564	53.6864
2015	12	11	15	22	22	0.3	3.9	0.67	100.7	83.5564	52.3897
2015	12	11	15	32	22	0.3	3.9	0.67	99.6	83.4908	52.0878
2015	12	11	15	42	22	0.3	3.9	0.68	99.5	83.4908	52.6061
2015	12	11	15	52	22	0.3	3.9	0.65	101.7	83.4908	50.2738
2015	12	11	16	2	22	0.3	3.9	0.67	97.3	83.5564	52.6491
2015	12	11	16	12	22	0.3	3.9	0.7	99.7	83.5564	54.4646
2015	12	11	16	22	22	0.3	3.9	0.7	97.6	83.5564	54.7239
2015	12	11	16	32	22	0.3	3.9	0.67	99.3	83.5564	52.1304
2015	12	11	16	42	22	0.3	3.9	0.66	99.5	83.5564	51.093
2015	12	11	16	52	22	0.3	3.9	0.65	99.6	83.5564	50.8336
2015	12	11	17	2	22	0.3	3.9	0.67	99.2	83.5564	52.6491
2015	12	11	17	12	22	0.3	3.9	0.65	99.3	83.5564	50.5743
2015	12	11	17	22	22	0.3	3.9	0.69	101.5	83.5564	53.6865
2015	12	11	17	32	22	0.3	3.9	0.61	100.3	83.5564	47.2026
2015	12	11	17	42	22	0.3	3.9	0.65	102	83.5564	50.0555
2015	12	11	17	52	22	0.3	3.9	0.63	98.7	83.5564	49.2775
2015	12	11	18	2	22	0.3	3.9	0.65	103.8	83.5564	49.5368
2015	12	11	18	12	22	0.3	3.9	0.62	100.6	83.5564	48.4994
2015	12	11	18	22	22	0.3	3.9	0.65	99.8	83.5564	50.8336
2015	12	11	18	32	22	0.3	3.9	0.65	99.7	83.5564	50.3149
2015	12	11	18	42	22	0.3	3.9	0.64	100.3	83.5564	49.7962
2015	12	11	18	52	22	0.3	3.9	0.65	103.1	83.5564	50.0555
2015	12	11	19	2	22	0.3	3.9	0.66	100.3	83.6221	51.6537
2015	12	11	19	12	22	0.3	3.9	0.66	99.7	83.6221	51.3942
2015	12	11	19	22	22	0.3	3.9	0.64	101.6	83.6221	49.3176
2015	12	11	19	32	22	0.3	3.9	0.68	103.2	83.6221	52.1729
2015	12	11	19	42	22	0.3	3.9	0.63	101.1	83.6221	48.7985
2015	12	11	19	52	22	0.3	3.9	0.7	100.6	83.6221	54.2494
2015	12	11	20	2	22	0.3	3.9	0.65	99.8	83.6221	50.875
2015	12	11	20	12	22	0.3	3.9	0.66	100.9	83.6221	51.1346
2015	12	11	20	22	22	0.3	3.9	0.67	101.6	83.6221	51.6537
2015	12	11	20	32	22	0.3	3.9	0.65	102.6	83.6221	49.8367

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	20	42	22	0.3	3.9	0.66	102.7	83.6221	50.875
2015	12	11	20	52	22	0.3	3.9	0.66	101.4	83.6221	51.3941
2015	12	11	21	2	22	0.3	3.9	0.65	102.2	83.6877	50.6567
2015	12	11	21	12	22	0.3	3.9	0.65	102.3	83.6877	50.1371
2015	12	11	21	22	22	0.3	3.9	0.66	101.8	83.7533	50.9579
2015	12	11	21	32	22	0.3	3.9	0.64	101	83.6877	49.6176
2015	12	11	21	42	22	0.3	3.9	0.67	99.6	83.6877	52.2153
2015	12	11	21	52	22	0.3	3.9	0.65	100.7	83.6877	50.9164
2015	12	11	22	2	22	0.3	3.9	0.67	104.5	83.6877	51.1762
2015	12	11	22	12	22	0.3	3.9	0.64	103.5	83.6877	49.6176
2015	12	11	22	22	22	0.3	3.9	0.66	102.9	83.6877	50.9164
2015	12	11	22	32	22	0.3	3.9	0.65	99.8	83.6877	50.9164
2015	12	11	22	42	22	0.3	3.9	0.66	98.3	83.6877	51.436
2015	12	11	22	52	22	0.3	3.9	0.68	100.9	83.7533	52.7778
2015	12	11	23	2	22	0.3	3.9	0.66	101.4	83.6877	51.436
2015	12	11	23	12	22	0.3	3.9	0.66	98.9	83.7533	51.7379
2015	12	11	23	22	22	0.3	3.9	0.69	102	83.7533	53.8178
2015	12	11	23	32	22	0.3	3.9	0.65	102.3	83.7533	50.1779
2015	12	11	23	42	22	0.3	3.9	0.63	100.7	83.7533	49.398
2015	12	11	23	52	22	0.3	3.9	0.69	100.2	83.7533	53.5578
2015	12	12	0	2	22	0.3	3.9	0.67	101.6	83.7533	51.9979
2015	12	12	0	12	22	0.3	3.9	0.64	101.2	83.7533	49.918
2015	12	12	0	22	22	0.3	3.9	0.66	101.8	83.7533	50.9579
2015	12	12	0	32	22	0.3	3.9	0.63	102.9	83.7533	48.618
2015	12	12	0	42	22	0.3	3.9	0.67	99.2	83.8189	52.8208
2015	12	12	0	52	22	0.3	3.9	0.65	102.5	83.8189	50.479
2015	12	12	1	2	22	0.3	3.9	0.64	101.8	83.8189	49.9586
2015	12	12	1	12	22	0.3	3.9	0.63	102.1	83.8189	48.6576
2015	12	12	1	22	22	0.3	3.9	0.65	100.7	83.8189	50.7392
2015	12	12	1	32	22	0.3	3.9	0.66	101.3	83.8845	51.0409
2015	12	12	1	42	22	0.3	3.9	0.64	100.6	83.9501	50.3005
2015	12	12	1	52	22	0.3	3.9	0.64	98.5	83.9501	50.3005
2015	12	12	2	2	22	0.3	3.9	0.67	101.1	83.9501	51.8643
2015	12	12	2	12	22	0.3	3.9	0.68	101.1	84.0158	52.9497
2015	12	12	2	22	22	0.3	3.9	0.65	99	84.0158	50.863
2015	12	12	2	32	22	0.3	3.9	0.66	101.3	84.0158	51.1239
2015	12	12	2	42	22	0.3	3.9	0.62	100	84.0814	48.8159
2015	12	12	2	52	22	0.3	3.9	0.65	99.9	84.0158	50.863
2015	12	12	3	2	22	0.3	3.9	0.66	100.9	84.0814	51.4264
2015	12	12	3	12	22	0.3	3.9	0.68	102.3	84.0814	52.4706
2015	12	12	3	22	22	0.3	3.9	0.66	101.3	84.0814	51.1654
2015	12	12	3	32	22	0.3	3.9	0.63	101.9	84.0814	49.338
2015	12	12	3	42	22	0.3	3.9	0.62	100.4	84.0814	48.5549
2015	12	12	3	52	22	0.3	3.9	0.68	103.3	84.0814	52.9927
2015	12	12	4	2	22	0.3	3.9	0.67	101.1	84.0814	51.9485
2015	12	12	4	12	22	0.3	3.9	0.66	102	84.0814	51.6875

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	4	22	22	0.3	3.9	0.65	99.9	84.0814	50.6433
2015	12	12	4	32	22	0.3	3.9	0.65	99.9	84.0814	50.6433
2015	12	12	4	42	22	0.3	3.9	0.63	102.4	84.0814	48.816
2015	12	12	4	52	22	0.3	3.9	0.66	102.3	84.147	51.7294
2015	12	12	5	2	22	0.3	3.9	0.65	101	84.147	50.9456
2015	12	12	5	12	22	0.3	3.9	0.65	99.4	84.147	50.6844
2015	12	12	5	22	22	0.3	3.9	0.66	102.3	84.147	51.7295
2015	12	12	5	32	22	0.3	3.9	0.7	102.5	84.147	54.3421
2015	12	12	5	42	22	0.3	3.9	0.64	101.2	84.147	50.1619
2015	12	12	5	52	22	0.3	3.9	0.63	104.4	84.147	48.8556
2015	12	12	6	2	22	0.3	3.9	0.62	100.4	84.147	48.3331
2015	12	12	6	12	22	0.3	3.9	0.67	99.9	84.147	52.252
2015	12	12	6	22	22	0.3	3.9	0.65	102.2	84.147	50.6844
2015	12	12	6	32	22	0.3	3.9	0.67	99	84.147	52.5133
2015	12	12	6	42	22	0.3	3.9	0.65	98.1	84.147	51.207
2015	12	12	6	52	22	0.3	3.9	0.66	99.5	84.147	51.4682
2015	12	12	7	2	22	0.3	3.9	0.65	100.5	84.147	50.6845
2015	12	12	7	12	22	0.3	3.9	0.63	99.9	84.147	49.3782
2015	12	12	7	22	22	0.3	3.9	0.65	103.1	84.2126	50.7255
2015	12	12	7	32	22	0.3	3.9	0.64	101.3	84.2126	49.6796
2015	12	12	7	42	22	0.3	3.9	0.67	98.4	84.2126	52.8173
2015	12	12	7	52	22	0.3	3.9	0.64	101.8	84.2126	49.9411
2015	12	12	8	2	22	0.3	3.9	0.65	101.7	84.2126	50.464
2015	12	12	8	12	22	0.3	3.9	0.7	101.2	84.2126	54.386
2015	12	12	8	22	22	0.3	3.9	0.63	100.8	84.2782	49.1964
2015	12	12	8	32	22	0.3	3.9	0.69	99.9	84.2782	53.9066
2015	12	12	8	42	22	0.3	3.9	0.69	99.9	84.2782	54.1683
2015	12	12	8	52	22	0.3	3.9	0.67	97.1	84.2782	52.8598
2015	12	12	9	2	22	0.3	3.9	0.65	98.2	84.2782	51.028
2015	12	12	9	12	22	0.3	3.9	0.71	97.7	84.3438	56.3071
2015	12	12	9	22	22	0.3	3.9	0.7	102.7	84.3438	54.7357
2015	12	12	9	32	22	0.3	3.9	0.64	96.5	84.3438	50.8073
2015	12	12	9	42	22	0.3	3.9	0.68	96.3	84.3438	54.2119
2015	12	12	9	52	22	0.3	3.9	0.67	96.4	84.4095	53.4693
2015	12	12	10	2	22	0.3	3.9	0.68	100.6	84.4095	53.2072
2015	12	12	10	12	22	0.3	3.9	0.66	96.9	84.4095	52.1587
2015	12	12	10	22	22	0.3	3.9	0.71	101.4	84.4095	55.8282
2015	12	12	10	32	22	0.3	3.9	0.66	97.7	84.4095	52.4208
2015	12	12	10	42	22	0.3	3.9	0.64	98.8	84.4095	50.8481
2015	12	12	10	52	22	0.3	3.9	0.7	97.3	84.4095	55.566
2015	12	12	11	2	22	0.3	3.9	0.65	100.1	84.4751	51.4138
2015	12	12	11	12	22	0.3	3.9	0.66	99.1	84.4751	52.463
2015	12	12	11	22	22	0.3	3.9	0.7	98.6	84.4751	55.6108
2015	12	12	11	32	22	0.3	3.9	0.68	100.5	84.4751	53.7746
2015	12	12	11	42	22	0.3	3.9	0.72	99.7	84.4751	56.66
2015	12	12	11	52	22	0.3	3.9	0.67	100.8	84.4751	52.463

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	12	2	22	0.3	3.9	0.69	98.4	84.4751	54.8238
2015	12	12	12	12	22	0.3	3.9	0.7	98.8	84.4751	55.6107
2015	12	12	12	22	22	0.3	3.9	0.66	100.8	84.4751	52.2006
2015	12	12	12	32	22	0.3	3.9	0.64	100.6	84.4751	50.3644
2015	12	12	12	42	22	0.3	3.9	0.64	99.1	84.4751	50.6268
2015	12	12	12	52	22	0.3	3.9	0.64	103.4	84.4751	49.5775
2015	12	12	13	2	22	0.3	3.9	0.69	100.4	84.4751	54.2992
2015	12	12	13	12	22	0.3	3.9	0.64	99.5	84.4751	50.3645
2015	12	12	13	22	22	0.3	3.9	0.68	96.4	84.4751	53.7746
2015	12	12	13	32	22	0.3	3.9	0.62	103.7	84.4751	48.5283
2015	12	12	13	42	22	0.3	3.9	0.62	100.9	84.4095	49.0134
2015	12	12	13	52	22	0.3	3.9	0.66	99.4	84.4751	52.2007
2015	12	12	14	2	22	0.3	3.9	0.65	100.4	84.4095	51.3724
2015	12	12	14	12	22	0.3	3.9	0.66	100.3	84.4095	52.1587
2015	12	12	14	22	22	0.3	3.9	0.66	98.9	84.4095	51.8966
2015	12	12	14	32	22	0.3	3.9	0.67	100.2	84.4095	52.6829
2015	12	12	14	42	22	0.3	3.9	0.65	100.7	84.4095	51.3724
2015	12	12	14	52	22	0.3	3.9	0.65	99.6	84.4095	51.3725
2015	12	12	15	2	22	0.3	3.9	0.65	102.8	84.4095	50.8483
2015	12	12	15	12	22	0.3	3.9	0.66	101.8	84.3438	51.593
2015	12	12	15	22	22	0.3	3.9	0.65	103.8	84.3438	50.0217
2015	12	12	15	32	22	0.3	3.9	0.64	103.3	84.3438	49.7598
2015	12	12	15	42	22	0.3	3.9	0.65	102.8	84.3438	50.5455
2015	12	12	15	52	22	0.3	3.9	0.65	100.5	84.3438	51.0693
2015	12	12	16	2	22	0.3	3.9	0.66	101.3	84.4095	51.3726
2015	12	12	16	12	22	0.3	3.9	0.65	99.8	84.3438	51.3312
2015	12	12	16	22	22	0.3	3.9	0.66	100.5	84.3438	52.1169
2015	12	12	16	32	22	0.3	3.9	0.66	100.3	84.3438	52.1169
2015	12	12	16	42	22	0.3	3.9	0.66	100	84.3438	51.855
2015	12	12	16	52	22	0.3	3.9	0.67	101.9	84.4095	52.159
2015	12	12	17	2	22	0.3	3.9	0.64	97.7	84.4095	50.5863
2015	12	12	17	12	22	0.3	3.9	0.63	100.5	84.4095	49.5379
2015	12	12	17	22	22	0.3	3.9	0.66	101.8	84.4095	51.3727
2015	12	12	17	32	22	0.3	3.9	0.65	100.4	84.4095	51.3727
2015	12	12	17	42	22	0.3	3.9	0.66	102.3	84.4095	51.8969
2015	12	12	17	52	22	0.3	3.9	0.67	100.2	84.4095	52.4211
2015	12	12	18	2	22	0.3	3.9	0.66	102.3	84.4095	51.6348
2015	12	12	18	12	22	0.3	3.9	0.67	101.1	84.4095	52.159
2015	12	12	18	22	22	0.3	3.9	0.67	99	84.4095	53.2074
2015	12	12	18	32	22	0.3	3.9	0.65	99.9	84.4095	50.8484
2015	12	12	18	42	22	0.3	3.9	0.65	100.5	84.4095	50.8484
2015	12	12	18	52	22	0.3	3.9	0.65	101	84.4095	51.1106
2015	12	12	19	2	22	0.3	3.9	0.67	102.8	84.4095	51.8969
2015	12	12	19	12	22	0.3	3.9	0.64	100.3	84.4095	50.3242
2015	12	12	19	22	22	0.3	3.9	0.64	102.1	84.4095	50.0621
2015	12	12	19	32	22	0.3	3.9	0.65	99.9	84.4095	50.8485

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	19	42	22	0.3	3.9	0.65	104	84.4095	50.3243
2015	12	12	19	52	22	0.3	3.9	0.65	100.5	84.4095	51.1106
2015	12	12	20	2	22	0.3	3.9	0.62	101	84.4751	48.5287
2015	12	12	20	12	22	0.3	3.9	0.66	99.1	84.4751	52.2011
2015	12	12	20	22	22	0.3	3.9	0.67	100.4	84.4751	52.7257
2015	12	12	20	32	22	0.3	3.9	0.66	99.7	84.4751	51.9388
2015	12	12	20	42	22	0.3	3.9	0.66	100.6	84.4751	51.9388
2015	12	12	20	52	22	0.3	3.9	0.67	100.4	84.4751	52.9881
2015	12	12	21	2	22	0.3	3.9	0.64	99.1	84.4751	50.6272
2015	12	12	21	12	22	0.3	3.9	0.64	99.4	84.4751	50.6272
2015	12	12	21	22	22	0.3	3.9	0.67	102.7	84.4751	52.4634
2015	12	12	21	32	22	0.3	3.9	0.66	99.5	84.4751	51.9388
2015	12	12	21	42	22	0.3	3.9	0.66	102.7	84.4751	51.4142
2015	12	12	21	52	22	0.3	3.9	0.69	101.8	84.4751	54.0374
2015	12	12	22	2	22	0.3	3.9	0.66	103.3	84.5407	51.1931
2015	12	12	22	12	22	0.3	3.9	0.63	100.5	84.5407	49.618
2015	12	12	22	22	22	0.3	3.9	0.65	100.8	84.6063	50.9716
2015	12	12	22	32	22	0.3	3.9	0.65	102.5	84.6063	50.9717
2015	12	12	22	42	22	0.3	3.9	0.67	101.1	84.6719	52.3275
2015	12	12	22	52	22	0.3	3.9	0.68	100.3	84.6719	53.6422
2015	12	12	23	2	22	0.3	3.9	0.62	99.5	84.6719	48.6462
2015	12	12	23	12	22	0.3	3.9	0.62	100.6	84.6719	49.1721
2015	12	12	23	22	22	0.3	3.9	0.68	100.8	84.6719	53.6423
2015	12	12	23	32	22	0.3	3.9	0.66	100.9	84.7375	51.8433
2015	12	12	23	42	22	0.3	3.9	0.68	101.1	84.7375	53.4223
2015	12	12	23	52	22	0.3	3.9	0.63	101.4	84.6719	49.698
2015	12	13	0	2	22	0.3	3.9	0.65	97.8	84.7375	51.8433
2015	12	13	0	12	22	0.3	3.9	0.66	101.5	84.7375	51.8433
2015	12	13	0	22	22	0.3	3.9	0.66	100.4	84.7375	51.8433
2015	12	13	0	32	22	0.3	3.9	0.67	102.7	84.7375	52.6328
2015	12	13	0	42	22	0.3	3.9	0.65	99.3	84.7375	51.5802
2015	12	13	0	52	22	0.3	3.9	0.68	102	84.7375	53.1592
2015	12	13	1	2	22	0.3	3.9	0.66	101.3	84.7375	51.5802
2015	12	13	1	12	22	0.3	3.9	0.64	102.1	84.7375	50.5276
2015	12	13	1	22	22	0.3	3.9	0.65	102.3	84.7375	50.7907
2015	12	13	1	32	22	0.3	3.9	0.67	103.3	84.7375	52.3697
2015	12	13	1	42	22	0.3	3.9	0.64	101	84.7375	50.0013
2015	12	13	1	52	22	0.3	3.9	0.65	101.7	84.7375	50.7908
2015	12	13	2	2	22	0.3	3.9	0.65	103.5	84.7375	50.5276
2015	12	13	2	12	22	0.3	3.9	0.66	100.4	84.7375	51.8434
2015	12	13	2	22	22	0.3	3.9	0.64	102.2	84.7375	50.0013
2015	12	13	2	32	22	0.3	3.9	0.62	100	84.7375	49.2118
2015	12	13	2	42	22	0.3	3.9	0.67	100.8	84.7375	52.633
2015	12	13	2	52	22	0.3	3.9	0.66	102	84.8032	51.8852
2015	12	13	3	2	22	0.3	3.9	0.65	102.6	84.8032	50.8317
2015	12	13	3	12	22	0.3	3.9	0.66	103	84.8032	51.3584

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	3	22	22	0.3	3.9	0.62	100.4	84.8032	48.9881
2015	12	13	3	32	22	0.3	3.9	0.68	101.6	84.8032	53.7289
2015	12	13	3	42	22	0.3	3.9	0.64	99.5	84.8032	50.5683
2015	12	13	3	52	22	0.3	3.9	0.68	99.7	84.8032	53.9922
2015	12	13	4	2	22	0.3	3.9	0.66	102.3	84.8032	52.1486
2015	12	13	4	12	22	0.3	3.9	0.64	101	84.8032	50.305
2015	12	13	4	22	22	0.3	3.9	0.64	102.3	84.8032	50.5684
2015	12	13	4	32	22	0.3	3.9	0.63	102	84.8032	49.5149
2015	12	13	4	42	22	0.3	3.9	0.67	102.1	84.8032	52.9388
2015	12	13	4	52	22	0.3	3.9	0.65	102.2	84.8032	51.0952
2015	12	13	5	2	22	0.3	3.9	0.65	100.4	84.8032	51.6219
2015	12	13	5	12	22	0.3	3.9	0.67	103.6	84.8032	52.1487
2015	12	13	5	22	22	0.3	3.9	0.65	99.3	84.8032	51.622
2015	12	13	5	32	22	0.3	3.9	0.66	102.1	84.8032	51.622
2015	12	13	5	42	22	0.3	3.9	0.66	100.9	84.8032	52.1487
2015	12	13	5	52	22	0.3	3.9	0.67	101	84.8032	52.6755
2015	12	13	6	2	22	0.3	3.9	0.65	99.6	84.8032	51.622
2015	12	13	6	12	22	0.3	3.9	0.66	100.4	84.8032	51.8854
2015	12	13	6	22	22	0.3	3.9	0.66	102.6	84.8032	51.8854
2015	12	13	6	32	22	0.3	3.9	0.66	101.2	84.8032	51.8854
2015	12	13	6	42	22	0.3	3.9	0.66	102.9	84.8032	51.8854
2015	12	13	6	52	22	0.3	3.9	0.65	100.1	84.8032	51.6221
2015	12	13	7	2	22	0.3	3.9	0.66	100	84.8032	52.1488
2015	12	13	7	12	22	0.3	3.9	0.66	101.7	84.8032	52.1489
2015	12	13	7	22	22	0.3	3.9	0.64	100.7	84.8032	50.3052
2015	12	13	7	32	22	0.3	3.9	0.64	99.8	84.8032	50.5686
2015	12	13	7	42	22	0.3	3.9	0.63	101.1	84.8032	49.7785
2015	12	13	7	52	22	0.3	3.9	0.63	101.4	84.8032	49.5151
2015	12	13	8	2	22	0.3	3.9	0.65	101.1	84.8032	50.8319
2015	12	13	8	12	22	0.3	3.9	0.67	100.8	84.8688	52.7179
2015	12	13	8	22	22	0.3	3.9	0.62	100.4	84.8688	49.0276
2015	12	13	8	32	22	0.3	3.9	0.65	101	84.8688	51.3999
2015	12	13	8	42	22	0.3	3.9	0.62	103.2	84.8688	48.5004
2015	12	13	8	52	22	0.3	3.9	0.66	102.4	84.8688	51.3998
2015	12	13	9	2	22	0.3	3.9	0.63	101.1	84.8688	49.8183
2015	12	13	9	12	22	0.3	3.9	0.65	100.1	84.8688	51.6634
2015	12	13	9	22	22	0.3	3.9	0.65	100.4	84.8688	51.6633
2015	12	13	9	32	22	0.3	3.9	0.67	102.1	84.9344	52.76
2015	12	13	9	42	22	0.3	3.9	0.66	102.9	84.9344	51.9685
2015	12	13	9	52	22	0.3	3.9	0.65	101.1	84.9344	50.9133
2015	12	13	10	2	22	0.3	3.9	0.65	101	84.9344	51.4409
2015	12	13	10	12	22	0.3	3.9	0.66	101.5	84.9344	51.7047
2015	12	13	10	22	22	0.3	3.9	0.64	102.1	84.9344	50.6495
2015	12	13	10	32	22	0.3	3.9	0.66	99.8	84.9344	51.9685
2015	12	13	10	42	22	0.3	3.9	0.66	100.4	84.9344	51.9684
2015	12	13	10	52	22	0.3	3.9	0.61	99.2	85	48.8419

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	11	2	22	0.3	3.9	0.67	101	85	53.066
2015	12	13	11	12	22	0.3	3.9	0.66	102.9	85	52.0101
2015	12	13	11	22	22	0.3	3.9	0.69	100.1	84.9344	54.6064
2015	12	13	11	32	22	0.3	3.9	0.64	102.5	84.9344	49.858
2015	12	13	11	42	22	0.3	3.9	0.66	100.4	85	52.01
2015	12	13	11	52	22	0.3	3.9	0.66	103.5	85	51.746
2015	12	13	12	2	22	0.3	3.9	0.66	102.9	84.9344	51.9684
2015	12	13	12	12	22	0.3	3.9	0.62	101.8	85	49.1059
2015	12	13	12	22	22	0.3	3.9	0.64	101.3	85	50.162
2015	12	13	12	32	22	0.3	3.9	0.67	103.5	85	52.8021
2015	12	13	12	42	22	0.3	3.9	0.64	101.5	85	50.4261
2015	12	13	12	52	22	0.3	3.9	0.62	100	84.9344	49.3306
2015	12	13	13	2	22	0.3	3.9	0.65	101	84.9344	51.441
2015	12	13	13	12	22	0.3	3.9	0.64	103	84.9344	50.3858
2015	12	13	13	22	22	0.3	3.9	0.66	102.7	84.9344	51.7049
2015	12	13	13	32	22	0.3	3.9	0.67	102.4	84.8688	52.7178
2015	12	13	13	42	22	0.3	3.9	0.65	100.2	84.8688	51.3999
2015	12	13	13	52	22	0.3	3.9	0.66	105.1	84.9344	50.9135
2015	12	13	14	2	22	0.3	3.9	0.64	104.6	84.9344	49.5945
2015	12	13	14	12	22	0.3	3.9	0.65	101	84.9344	51.4411
2015	12	13	14	22	22	0.3	3.9	0.66	102.7	84.9344	51.7049
2015	12	13	14	32	22	0.3	3.9	0.67	101.3	84.9344	52.7601
2015	12	13	14	42	22	0.3	3.9	0.62	101.1	84.9344	48.5393
2015	12	13	14	52	22	0.3	3.9	0.63	101.9	84.9344	49.8583
2015	12	13	15	2	22	0.3	3.9	0.66	102.7	84.9344	51.4411
2015	12	13	15	12	22	0.3	3.9	0.66	104.7	84.9344	51.4411
2015	12	13	15	22	22	0.3	3.9	0.63	100.8	85	49.8983
2015	12	13	15	32	22	0.3	3.9	0.67	101.9	85	52.8024
2015	12	13	15	42	22	0.3	3.9	0.66	102.9	84.9344	51.7049
2015	12	13	15	52	22	0.3	3.9	0.66	103.8	84.9344	51.4411
2015	12	13	16	2	22	0.3	3.9	0.69	101.5	84.9344	54.6067
2015	12	13	16	12	22	0.3	3.9	0.68	102.3	84.8688	52.9814
2015	12	13	16	22	22	0.3	3.9	0.68	100	84.9344	54.0791
2015	12	13	16	32	22	0.3	3.9	0.65	101.4	84.9344	51.1773
2015	12	13	16	42	22	0.3	3.9	0.69	102.3	84.9344	54.6067
2015	12	13	16	52	22	0.3	3.9	0.67	100.1	84.9344	53.2877
2015	12	13	17	2	22	0.3	3.9	0.65	97.9	84.9344	51.4411
2015	12	13	17	12	22	0.3	3.9	0.69	99.6	84.9344	54.3429
2015	12	13	17	22	22	0.3	3.9	0.69	95.2	85	55.1786
2015	12	13	17	32	22	0.3	3.9	0.67	98.5	84.9344	53.0239
2015	12	13	17	42	22	0.3	3.9	0.64	98.6	84.9344	50.6497
2015	12	13	17	52	22	0.3	3.9	0.66	99.1	84.9344	52.4963
2015	12	13	18	2	22	0.3	3.9	0.67	98.7	84.9344	53.2877
2015	12	13	18	12	22	0.3	3.9	0.67	99.9	85	53.0664
2015	12	13	18	22	22	0.3	3.9	0.69	99.8	85	54.9145
2015	12	13	18	32	22	0.3	3.9	0.65	99.6	85	51.7464

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	18	42	22	0.3	3.9	0.67	100.4	85	53.0664
2015	12	13	18	52	22	0.3	3.9	0.64	99.5	85	50.6903
2015	12	13	19	2	22	0.3	3.9	0.65	101.7	85	50.9543
2015	12	13	19	12	22	0.3	3.9	0.66	99.1	85	52.8024
2015	12	13	19	22	22	0.3	3.9	0.65	98.2	84.9344	51.4411
2015	12	13	19	32	22	0.3	3.9	0.66	101.3	84.9344	51.7049
2015	12	13	19	42	22	0.3	3.9	0.7	99.2	85.0656	55.487
2015	12	13	19	52	22	0.3	3.9	0.64	99.8	85	50.6903
2015	12	13	20	2	22	0.3	3.9	0.65	97.6	85.0656	51.7878
2015	12	13	20	12	22	0.3	3.9	0.69	98.2	85.0656	54.9585
2015	12	13	20	22	22	0.3	3.9	0.72	96.6	85.0656	57.3365
2015	12	13	20	32	22	0.3	3.9	0.67	103	85	52.8024
2015	12	13	20	42	22	0.3	3.9	0.67	100.7	85	53.0664
2015	12	13	20	52	22	0.3	3.9	0.67	101.1	85	52.5384
2015	12	13	21	2	22	0.3	3.9	0.67	99.4	85	52.8024
2015	12	13	21	12	22	0.3	3.9	0.66	102.3	85	52.2744
2015	12	13	21	22	22	0.3	3.9	0.67	97.7	85	53.0664
2015	12	13	21	32	22	0.3	3.9	0.64	98.3	85	50.6903
2015	12	13	21	42	22	0.3	3.9	0.65	102.6	85	50.6903
2015	12	13	21	52	22	0.3	3.9	0.66	101.7	85	52.2744
2015	12	13	22	2	22	0.3	3.9	0.65	98.9	85	52.0104
2015	12	13	22	12	22	0.3	3.9	0.65	100.5	85	51.2184
2015	12	13	22	22	22	0.3	3.9	0.65	100.5	85	51.4824
2015	12	13	22	32	22	0.3	3.9	0.64	98.3	85	50.6903
2015	12	13	22	42	22	0.3	3.9	0.65	99	85	51.7464
2015	12	13	22	52	22	0.3	3.9	0.66	100.9	85	52.2744
2015	12	13	23	2	22	0.3	3.9	0.66	102.3	85	52.2744
2015	12	13	23	12	22	0.3	3.9	0.64	100.6	85	50.6904
2015	12	13	23	22	22	0.3	3.9	0.67	99.9	85	53.0665
2015	12	13	23	32	22	0.3	3.9	0.66	99.2	85	52.2744
2015	12	13	23	42	22	0.3	3.9	0.64	99.4	85	50.9544
2015	12	13	23	52	22	0.3	3.9	0.68	102.3	85	53.0665
2015	12	14	0	2	22	0.3	3.9	0.7	101.3	85	55.4426
2015	12	14	0	12	22	0.3	3.9	0.65	99.8	85	51.7464
2015	12	14	0	22	22	0.3	3.9	0.67	101.3	85	53.0665
2015	12	14	0	32	22	0.3	3.9	0.66	100.5	85	52.5385
2015	12	14	0	42	22	0.3	3.9	0.67	100.2	85	52.8025
2015	12	14	0	52	22	0.3	3.9	0.67	99.3	85.0656	53.109
2015	12	14	1	2	22	0.3	3.9	0.67	103.2	85	52.8025
2015	12	14	1	12	22	0.3	3.9	0.7	101.2	85.0656	54.9586
2015	12	14	1	22	22	0.3	3.9	0.67	97.6	85.1312	53.6805
2015	12	14	1	32	22	0.3	3.9	0.64	98	85.0656	50.9953
2015	12	14	1	42	22	0.3	3.9	0.72	98.6	85.0656	57.3367
2015	12	14	1	52	22	0.3	3.9	0.67	96.8	85.1312	53.416
2015	12	14	2	2	22	0.3	3.9	0.69	101	85.1312	54.4738
2015	12	14	2	12	22	0.3	3.9	0.63	99.6	85.1312	50.2428

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	2	22	22	0.3	3.9	0.67	100.2	85.0656	52.8449
2015	12	14	2	32	22	0.3	3.9	0.69	99.3	85.1312	54.7382
2015	12	14	2	42	22	0.3	3.9	0.68	97.2	85.1969	54.782
2015	12	14	2	52	22	0.3	3.9	0.69	97.7	85.1312	55.0027
2015	12	14	3	2	22	0.3	3.9	0.7	99.1	85.1969	56.1053
2015	12	14	3	12	22	0.3	3.9	0.67	99	85.1312	53.4161
2015	12	14	3	22	22	0.3	3.9	0.67	96.2	85.1312	53.945
2015	12	14	3	32	22	0.3	3.9	0.66	99.1	85.1312	52.8872
2015	12	14	3	42	22	0.3	3.9	0.68	102.2	85.1312	53.6805
2015	12	14	3	52	22	0.3	3.9	0.67	101.5	85.1312	53.1517
2015	12	14	4	2	22	0.3	3.9	0.69	100.7	85.1312	54.4739
2015	12	14	4	12	22	0.3	3.9	0.65	96.7	85.1312	52.0939
2015	12	14	4	22	22	0.3	3.9	0.69	98.2	85.1312	55.2672
2015	12	14	4	32	22	0.3	3.9	0.66	98.5	85.1312	52.8872
2015	12	14	4	42	22	0.3	3.9	0.68	102	85.1969	53.7235
2015	12	14	4	52	22	0.3	3.9	0.64	102.1	85.1969	50.5477
2015	12	14	5	2	22	0.3	3.9	0.68	102.8	85.1969	53.7235
2015	12	14	5	12	22	0.3	3.9	0.71	101	85.1969	55.8407
2015	12	14	5	22	22	0.3	3.9	0.67	99	85.1969	53.7235
2015	12	14	5	32	22	0.3	3.9	0.65	103.8	85.1312	50.5073
2015	12	14	5	42	22	0.3	3.9	0.66	102.3	85.1969	52.4003
2015	12	14	5	52	22	0.3	3.9	0.68	101.7	85.1969	53.7235
2015	12	14	6	2	22	0.3	3.9	0.66	101.5	85.1969	52.1357
2015	12	14	6	12	22	0.3	3.9	0.65	102.2	85.1969	51.6064
2015	12	14	6	22	22	0.3	3.9	0.62	100.6	85.1969	49.4892
2015	12	14	6	32	22	0.3	3.9	0.66	100.5	85.1969	52.665
2015	12	14	6	42	22	0.3	3.9	0.68	97.7	85.2625	54.5611
2015	12	14	6	52	22	0.3	3.9	0.66	100.4	85.1969	52.1357
2015	12	14	7	2	22	0.3	3.9	0.69	103.1	85.1969	54.5175
2015	12	14	7	12	22	0.3	3.9	0.64	100.3	85.1969	50.8124
2015	12	14	7	22	22	0.3	3.9	0.65	99.4	85.1969	51.3417
2015	12	14	7	32	22	0.3	3.9	0.65	101.7	85.1969	51.0771
2015	12	14	7	42	22	0.3	3.9	0.64	100.6	85.1969	51.0771
2015	12	14	7	52	22	0.3	3.9	0.71	96.1	85.1969	56.8993
2015	12	14	8	2	22	0.3	3.9	0.74	97.1	85.1969	59.5458
2015	12	14	8	12	22	0.3	3.9	0.69	96.8	85.1969	55.3114
2015	12	14	8	22	22	0.3	3.9	0.69	99.6	85.2625	54.8259
2015	12	14	8	32	22	0.3	3.9	0.7	97.8	85.1969	55.8406
2015	12	14	8	42	22	0.3	3.9	0.72	99.4	85.1969	57.4285
2015	12	14	8	52	22	0.3	3.9	0.73	98.2	85.2625	58.5338
2015	12	14	9	2	22	0.3	3.9	0.7	98.4	85.3281	55.9298
2015	12	14	9	12	22	0.3	3.9	0.66	96.8	85.3281	53.2791
2015	12	14	9	22	22	0.3	3.9	0.69	97.7	85.3281	55.1346
2015	12	14	9	32	22	0.3	3.9	0.66	96.9	85.3281	52.7489
2015	12	14	9	42	22	0.3	3.9	0.73	99	85.2625	58.2688
2015	12	14	9	52	22	0.3	3.9	0.69	95.5	85.3281	55.3996

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	10	2	22	0.3	3.9	0.73	96.7	85.3281	58.3153
2015	12	14	10	12	22	0.3	3.9	0.73	97	85.3937	58.3618
2015	12	14	10	22	22	0.3	3.9	0.71	98.5	85.3281	56.7248
2015	12	14	10	32	22	0.3	3.9	0.73	100.1	85.3937	57.8312
2015	12	14	10	42	22	0.3	3.9	0.71	98.5	85.3281	56.4598
2015	12	14	10	52	22	0.3	3.9	0.71	98	85.3281	56.7248
2015	12	14	11	2	22	0.3	3.9	0.69	95.5	85.3281	55.3994
2015	12	14	11	12	22	0.3	3.9	0.74	95.6	85.3937	59.4228
2015	12	14	11	22	22	0.3	3.9	0.7	95.4	85.3281	56.1946
2015	12	14	11	32	22	0.3	3.9	0.74	96.7	85.3281	59.1103
2015	12	14	11	42	22	0.3	3.9	0.7	98.1	85.4593	56.0188
2015	12	14	11	52	22	0.3	3.9	0.7	98.7	85.3937	55.7089
2015	12	14	12	2	22	0.3	3.9	0.71	96.7	85.3937	56.77
2015	12	14	12	12	22	0.3	3.9	0.7	97.5	85.3937	56.2394
2015	12	14	12	22	22	0.3	3.9	0.73	97.8	85.4593	58.1427
2015	12	14	12	32	22	0.3	3.9	0.69	96.8	85.4593	55.4878
2015	12	14	12	42	22	0.3	3.9	0.74	98.4	85.3937	59.4228
2015	12	14	12	52	22	0.3	3.9	0.71	96.4	85.3281	56.9898
2015	12	14	13	2	22	0.3	3.9	0.7	96.5	85.3937	55.9742
2015	12	14	13	12	22	0.3	3.9	0.73	97.3	85.4593	58.4083
2015	12	14	13	22	22	0.3	3.9	0.74	98.9	85.3937	59.1576
2015	12	14	13	32	22	0.3	3.9	0.72	95.2	85.3281	57.7851
2015	12	14	13	42	22	0.3	3.9	0.7	99.2	85.3937	55.709
2015	12	14	13	52	22	0.3	3.9	0.69	97.4	85.3937	55.1785
2015	12	14	14	2	22	0.3	3.9	0.69	97.6	85.3937	55.4438
2015	12	14	14	12	22	0.3	3.9	0.73	96.2	85.3281	58.3154
2015	12	14	14	22	22	0.3	3.9	0.68	98.6	85.3281	54.3393
2015	12	14	14	32	22	0.3	3.9	0.69	98.7	85.2625	55.3554
2015	12	14	14	42	22	0.3	3.9	0.71	94.8	85.3281	57.2552
2015	12	14	14	52	22	0.3	3.9	0.72	98.7	85.3281	57.2552
2015	12	14	15	2	22	0.3	3.9	0.69	96.3	85.3281	55.6649
2015	12	14	15	12	22	0.3	3.9	0.74	97.9	85.2625	58.7988
2015	12	14	15	22	22	0.3	3.9	0.72	100.2	85.2625	57.2097
2015	12	14	15	32	22	0.3	3.9	0.73	99.3	85.2625	58.0043
2015	12	14	15	42	22	0.3	3.9	0.73	98.3	85.2625	58.0043
2015	12	14	15	52	22	0.3	3.9	0.69	96.3	85.2625	55.3557
2015	12	14	16	2	22	0.3	3.9	0.7	97	85.2625	55.8854
2015	12	14	16	12	22	0.3	3.9	0.71	100.4	85.2625	56.4152
2015	12	14	16	22	22	0.3	3.9	0.69	96	85.2625	55.3557
2015	12	14	16	32	22	0.3	3.9	0.7	97	85.2625	56.4152
2015	12	14	16	42	22	0.3	3.9	0.73	98	85.1969	58.4873
2015	12	14	16	52	22	0.3	3.9	0.71	99.2	85.1969	56.8995
2015	12	14	17	2	22	0.3	3.9	0.67	97.9	85.1969	53.459
2015	12	14	17	12	22	0.3	3.9	0.7	95.1	85.2625	56.1504
2015	12	14	17	22	22	0.3	3.9	0.67	98.7	85.1969	53.7237
2015	12	14	17	32	22	0.3	3.9	0.69	98.4	85.2625	55.3558

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	17	42	22	0.3	3.9	0.71	98.5	85.1969	56.3702
2015	12	14	17	52	22	0.3	3.9	0.66	98	85.2625	52.4423
2015	12	14	18	2	22	0.3	3.9	0.67	97.3	85.2625	53.5018
2015	12	14	18	12	22	0.3	3.9	0.72	99.2	85.2625	57.4747
2015	12	14	18	22	22	0.3	3.9	0.71	97.4	85.2625	56.945
2015	12	14	18	32	22	0.3	3.9	0.69	96.6	85.1969	55.047
2015	12	14	18	42	22	0.3	3.9	0.7	95.4	85.1969	55.8409
2015	12	14	18	52	22	0.3	3.9	0.69	98.5	85.1969	54.7823
2015	12	14	19	2	22	0.3	3.9	0.67	97.9	85.2625	53.2369
2015	12	14	19	12	22	0.3	3.9	0.68	99.4	85.2625	54.2964
2015	12	14	19	22	22	0.3	3.9	0.65	100.2	85.2625	51.6478
2015	12	14	19	32	22	0.3	3.9	0.71	99.3	85.2625	56.4153
2015	12	14	19	42	22	0.3	3.9	0.66	102	85.2625	52.1775
2015	12	14	19	52	22	0.3	3.9	0.68	104.2	85.2625	53.2369
2015	12	14	20	2	22	0.3	3.9	0.69	98.2	85.2625	55.3558
2015	12	14	20	12	22	0.3	3.9	0.7	97.8	85.1969	55.8409
2015	12	14	20	22	22	0.3	3.9	0.69	100.7	85.2625	54.5613
2015	12	14	20	32	22	0.3	3.9	0.68	100.9	85.1969	53.7237
2015	12	14	20	42	22	0.3	3.9	0.68	97.8	85.1969	53.9884
2015	12	14	20	52	22	0.3	3.9	0.7	98.4	85.2625	55.8856
2015	12	14	21	2	22	0.3	3.9	0.72	97.9	85.2625	57.4747
2015	12	14	21	12	22	0.3	3.9	0.71	98.5	85.2625	56.4153
2015	12	14	21	22	22	0.3	3.9	0.71	98	85.1969	56.6349
2015	12	14	21	32	22	0.3	3.9	0.65	98.2	85.2625	51.6478
2015	12	14	21	42	22	0.3	3.9	0.7	97.6	85.2625	55.8856
2015	12	14	21	52	22	0.3	3.9	0.66	96.6	85.1969	52.6651
2015	12	14	22	2	22	0.3	3.9	0.67	99.6	85.2625	52.9721
2015	12	14	22	12	22	0.3	3.9	0.63	96.2	85.2625	50.8532
2015	12	14	22	22	22	0.3	3.9	0.68	98.1	85.2625	54.2964
2015	12	14	22	32	22	0.3	3.9	0.66	99.5	85.2625	52.4424
2015	12	14	22	42	22	0.3	3.9	0.64	100.3	85.2625	51.1181
2015	12	14	22	52	22	0.3	3.9	0.64	99.4	85.2625	51.1181
2015	12	14	23	2	22	0.3	3.9	0.65	101	85.2625	51.6478
2015	12	14	23	12	22	0.3	3.9	0.65	100.2	85.2625	51.6479
2015	12	14	23	22	22	0.3	3.9	0.65	102.2	85.2625	51.383
2015	12	14	23	32	22	0.3	3.9	0.66	101.7	85.2625	52.4425
2015	12	14	23	42	22	0.3	3.9	0.66	102.3	85.2625	52.4425
2015	12	14	23	52	22	0.3	3.9	0.68	103.2	85.2625	53.2371
2015	12	15	0	2	22	0.3	3.9	0.65	101.6	85.2625	51.6479
2015	12	15	0	12	22	0.3	3.9	0.62	101	85.2625	49.2642
2015	12	15	0	22	22	0.3	3.9	0.68	99.1	85.2625	54.5614
2015	12	15	0	32	22	0.3	3.9	0.69	102.1	85.2625	54.2965
2015	12	15	0	42	22	0.3	3.9	0.67	100.4	85.2625	53.502
2015	12	15	0	52	22	0.3	3.9	0.65	97.8	85.2625	51.9128
2015	12	15	1	2	22	0.3	3.9	0.68	98.6	85.2625	54.2966
2015	12	15	1	12	22	0.3	3.9	0.63	100.8	85.2625	50.0588

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	1	22	22	0.3	3.9	0.66	98	85.2625	52.7074
2015	12	15	1	32	22	0.3	3.9	0.64	101.9	85.2625	50.3237
2015	12	15	1	42	22	0.3	3.9	0.65	101.6	85.2625	51.648
2015	12	15	1	52	22	0.3	3.9	0.66	103	85.2625	51.648
2015	12	15	2	2	22	0.3	3.9	0.62	99.8	85.2625	49.2643
2015	12	15	2	12	22	0.3	3.9	0.65	101.9	85.2625	51.3832
2015	12	15	2	22	22	0.3	3.9	0.65	101.3	85.2625	51.6481
2015	12	15	2	32	22	0.3	3.9	0.66	99.8	85.2625	52.1778
2015	12	15	2	42	22	0.3	3.9	0.64	98.8	85.2625	51.1184
2015	12	15	2	52	22	0.3	3.9	0.67	96.7	85.2625	53.767
2015	12	15	3	2	22	0.3	3.9	0.66	98.3	85.2625	52.4427
2015	12	15	3	12	22	0.3	3.9	0.69	96.8	85.2625	55.621
2015	12	15	3	22	22	0.3	3.9	0.68	97.5	85.2625	54.0319
2015	12	15	3	32	22	0.3	3.9	0.67	98.8	85.2625	53.2373
2015	12	15	3	42	22	0.3	3.9	0.7	99.5	85.2625	55.6211
2015	12	15	3	52	22	0.3	3.9	0.72	96	85.2625	57.74
2015	12	15	4	2	22	0.3	3.9	0.72	98.2	85.2625	57.2103
2015	12	15	4	12	22	0.3	3.9	0.69	95.5	85.2625	55.3563
2015	12	15	4	22	22	0.3	3.9	0.7	97.5	85.2625	56.1509
2015	12	15	4	32	22	0.3	3.9	0.7	96.2	85.2625	56.4157
2015	12	15	4	42	22	0.3	3.9	0.72	98.7	85.2625	57.2103
2015	12	15	4	52	22	0.3	3.9	0.66	95.4	85.2625	53.2374
2015	12	15	5	2	22	0.3	3.9	0.66	99.2	85.2625	52.4428
2015	12	15	5	12	22	0.3	3.9	0.7	97.6	85.2625	55.6212
2015	12	15	5	22	22	0.3	3.9	0.65	100.2	85.2625	51.3834
2015	12	15	5	32	22	0.3	3.9	0.65	99.7	85.2625	51.3834
2015	12	15	5	42	22	0.3	3.9	0.67	101.1	85.2625	52.7077
2015	12	15	5	52	22	0.3	3.9	0.68	99.1	85.2625	54.2969
2015	12	15	6	2	22	0.3	3.9	0.68	98.8	85.2625	54.5618
2015	12	15	6	12	22	0.3	3.9	0.65	102.8	85.2625	51.3835
2015	12	15	6	22	22	0.3	3.9	0.65	95.8	85.2625	52.1781
2015	12	15	6	32	22	0.3	3.9	0.67	96.2	85.2625	53.5024
2015	12	15	6	42	22	0.3	3.9	0.71	100.4	85.2625	56.151
2015	12	15	6	52	22	0.3	3.9	0.68	98.6	85.2625	54.5619
2015	12	15	7	2	22	0.3	3.9	0.65	99.9	85.2625	51.6484
2015	12	15	7	12	22	0.3	3.9	0.65	99.3	85.2625	51.9132
2015	12	15	7	22	22	0.3	3.9	0.65	100.1	85.2625	51.9132
2015	12	15	7	32	22	0.3	3.9	0.67	97	85.2625	54.0322
2015	12	15	7	42	22	0.3	3.9	0.62	101	85.2625	48.9997
2015	12	15	7	52	22	0.3	3.9	0.67	97.9	85.3281	53.2801
2015	12	15	8	2	22	0.3	3.9	0.67	99	85.3281	53.8102
2015	12	15	8	12	22	0.3	3.9	0.72	100.2	85.3281	57.2561
2015	12	15	8	22	22	0.3	3.9	0.71	99.6	85.3281	56.1958
2015	12	15	8	32	22	0.3	3.9	0.67	99.9	85.3281	53.0149
2015	12	15	8	42	22	0.3	3.9	0.72	96.1	85.3937	57.567
2015	12	15	8	52	22	0.3	3.9	0.72	96.5	85.3281	57.7862

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	9	2	22	0.3	3.9	0.69	96.3	85.3937	55.4447
2015	12	15	9	12	22	0.3	3.9	0.67	99.6	85.3281	53.2799
2015	12	15	9	22	22	0.3	3.9	0.65	95.5	85.3937	52.5265
2015	12	15	9	32	22	0.3	3.9	0.75	97.8	85.3937	59.9545
2015	12	15	9	42	22	0.3	3.9	0.72	98.4	85.3281	57.521
2015	12	15	9	52	22	0.3	3.9	0.71	99.3	85.3281	56.4607
2015	12	15	10	2	22	0.3	3.9	0.75	99.5	85.3937	59.9544
2015	12	15	10	12	22	0.3	3.9	0.67	99.6	85.3937	53.5875
2015	12	15	10	22	22	0.3	3.9	0.69	98.7	85.3937	55.1792
2015	12	15	10	32	22	0.3	3.9	0.68	98.1	85.3937	54.3834
2015	12	15	10	42	22	0.3	3.9	0.65	97	85.4593	52.0373
2015	12	15	10	52	22	0.3	3.9	0.65	96.7	85.4593	52.3027
2015	12	15	11	2	22	0.3	3.9	0.67	95.9	85.4593	53.8957
2015	12	15	11	12	22	0.3	3.9	0.68	98	85.4593	54.6922
2015	12	15	11	22	22	0.3	3.9	0.69	97.3	85.4593	55.7542
2015	12	15	11	32	22	0.3	3.9	0.7	98.6	85.4593	56.0196
2015	12	15	11	42	22	0.3	3.9	0.69	98.7	85.4593	55.2231
2015	12	15	11	52	22	0.3	3.9	0.67	98.2	85.4593	53.6302
2015	12	15	12	2	22	0.3	3.9	0.67	100.9	85.4593	53.6301
2015	12	15	12	12	22	0.3	3.9	0.66	92.9	85.3937	53.0568
2015	12	15	12	22	22	0.3	3.9	0.71	97.2	85.3937	56.7708
2015	12	15	12	32	22	0.3	3.9	0.71	98	85.4593	56.8161
2015	12	15	12	42	22	0.3	3.9	0.69	98.5	85.4593	54.9577
2015	12	15	12	52	22	0.3	3.9	0.71	96.1	85.3937	56.7709
2015	12	15	13	2	22	0.3	3.9	0.7	100	85.3937	55.4445
2015	12	15	13	12	22	0.3	3.9	0.67	98.1	85.4593	53.8957
2015	12	15	13	22	22	0.3	3.9	0.68	97.5	85.4593	54.1612
2015	12	15	13	32	22	0.3	3.9	0.7	97.2	85.3937	56.5057
2015	12	15	13	42	22	0.3	3.9	0.71	97.5	85.3937	56.771
2015	12	15	13	52	22	0.3	3.9	0.69	98.2	85.3937	55.4446
2015	12	15	14	2	22	0.3	3.9	0.67	98.7	85.3937	53.5876
2015	12	15	14	12	22	0.3	3.9	0.7	97.2	85.3937	56.5058
2015	12	15	14	22	22	0.3	3.9	0.71	95.1	85.3281	56.9909
2015	12	15	14	32	22	0.3	3.9	0.69	97.4	85.3281	55.4005
2015	12	15	14	42	22	0.3	3.9	0.7	97.8	85.3281	55.9306
2015	12	15	14	52	22	0.3	3.9	0.72	95	85.3281	57.7862
2015	12	15	15	2	22	0.3	3.9	0.66	97.7	85.2625	52.7077
2015	12	15	15	12	22	0.3	3.9	0.72	98.9	85.2625	57.2105
2015	12	15	15	22	22	0.3	3.9	0.68	97.5	85.2625	54.297
2015	12	15	15	32	22	0.3	3.9	0.67	97.7	85.2625	53.2376
2015	12	15	15	42	22	0.3	3.9	0.69	97.1	85.2625	55.3565
2015	12	15	15	52	22	0.3	3.9	0.68	98.6	85.2625	54.0322
2015	12	15	16	2	22	0.3	3.9	0.7	100.8	85.2625	55.3565
2015	12	15	16	12	22	0.3	3.9	0.68	99.4	85.2625	54.562
2015	12	15	16	22	22	0.3	3.9	0.66	99.4	85.2625	52.7079
2015	12	15	16	32	22	0.3	3.9	0.72	100	85.2625	57.2106

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	16	42	22	0.3	3.9	0.69	99.9	85.1969	54.783
2015	12	15	16	52	22	0.3	3.9	0.7	96.7	85.2625	56.1512
2015	12	15	17	2	22	0.3	3.9	0.7	97.5	85.1969	56.1063
2015	12	15	17	12	22	0.3	3.9	0.69	96.9	85.1312	55.0037
2015	12	15	17	22	22	0.3	3.9	0.69	99.6	85.1969	54.7831
2015	12	15	17	32	22	0.3	3.9	0.67	97.9	85.1969	53.4598
2015	12	15	17	42	22	0.3	3.9	0.65	98.7	85.1969	51.8719
2015	12	15	17	52	22	0.3	3.9	0.67	96.7	85.2625	53.7674
2015	12	15	18	2	22	0.3	3.9	0.69	96.3	85.1969	55.0477
2015	12	15	18	12	22	0.3	3.9	0.67	94.8	85.1969	53.9891
2015	12	15	18	22	22	0.3	3.9	0.68	98	85.1969	54.5184
2015	12	15	18	32	22	0.3	3.9	0.69	96.3	85.1969	55.3123
2015	12	15	18	42	22	0.3	3.9	0.66	103.1	85.1969	52.1365
2015	12	15	18	52	22	0.3	3.9	0.66	102.1	85.1969	51.8719
2015	12	15	19	2	22	0.3	3.9	0.69	101	85.1969	54.5184
2015	12	15	19	12	22	0.3	3.9	0.66	98	85.1969	52.9305
2015	12	15	19	22	22	0.3	3.9	0.67	98.2	85.1969	53.1951
2015	12	15	19	32	22	0.3	3.9	0.68	98.4	85.1969	53.9891
2015	12	15	19	42	22	0.3	3.9	0.66	97.4	85.1969	52.9305
2015	12	15	19	52	22	0.3	3.9	0.66	101.1	85.1969	52.4012
2015	12	15	20	2	22	0.3	3.9	0.67	104.1	85.1969	52.6658
2015	12	15	20	12	22	0.3	3.9	0.64	99.2	85.1969	50.8132
2015	12	15	20	22	22	0.3	3.9	0.64	98.8	85.1969	51.3425
2015	12	15	20	32	22	0.3	3.9	0.67	103	85.1969	52.9305
2015	12	15	20	42	22	0.3	3.9	0.66	100	85.1969	52.6658
2015	12	15	20	52	22	0.3	3.9	0.67	100.8	85.1969	52.9305
2015	12	15	21	2	22	0.3	3.9	0.68	99.1	85.1969	54.2537
2015	12	15	21	12	22	0.3	3.9	0.71	96.4	85.1969	56.6356
2015	12	15	21	22	22	0.3	3.9	0.72	96.8	85.1969	57.4296
2015	12	15	21	32	22	0.3	3.9	0.69	96.8	85.1969	55.577
2015	12	15	21	42	22	0.3	3.9	0.7	98.4	85.1969	55.577
2015	12	15	21	52	22	0.3	3.9	0.71	99.6	85.1312	56.0615
2015	12	15	22	2	22	0.3	3.9	0.71	97.7	85.1312	56.5903
2015	12	15	22	12	22	0.3	3.9	0.68	96.4	85.2625	54.562
2015	12	15	22	22	22	0.3	3.9	0.7	97	85.1969	55.8417
2015	12	15	22	32	22	0.3	3.9	0.73	96	85.1969	58.2235
2015	12	15	22	42	22	0.3	3.9	0.67	99.3	85.1969	53.4598
2015	12	15	22	52	22	0.3	3.9	0.67	101.6	85.1969	52.6658
2015	12	15	23	2	22	0.3	3.9	0.67	99.8	85.1969	53.4598
2015	12	15	23	12	22	0.3	3.9	0.68	97.5	85.1969	54.5184
2015	12	15	23	22	22	0.3	3.9	0.66	96.6	85.1312	52.8882
2015	12	15	23	32	22	0.3	3.9	0.67	94.2	85.1969	53.9891
2015	12	15	23	42	22	0.3	3.9	0.72	97.9	85.1969	57.165
2015	12	15	23	52	22	0.3	3.9	0.72	97	85.1969	57.9589
2015	12	16	0	2	22	0.3	3.9	0.73	98.5	85.1969	58.4882
2015	12	16	0	12	22	0.3	3.9	0.68	98.1	85.1969	53.9892

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	0	22	22	0.3	3.9	0.67	96.2	85.1969	53.9892
2015	12	16	0	32	22	0.3	3.9	0.63	101.8	85.1969	49.4901
2015	12	16	0	42	22	0.3	3.9	0.67	102.1	85.1969	52.9306
2015	12	16	0	52	22	0.3	3.9	0.63	103.2	85.1969	49.7547
2015	12	16	1	2	22	0.3	3.9	0.67	101.6	85.1969	52.6659
2015	12	16	1	12	22	0.3	3.9	0.67	103.6	85.1969	52.4013
2015	12	16	1	22	22	0.3	3.9	0.69	101.6	85.1969	54.2539
2015	12	16	1	32	22	0.3	3.9	0.66	103.6	85.1969	51.6073
2015	12	16	1	42	22	0.3	3.9	0.67	104.1	85.1969	52.666
2015	12	16	1	52	22	0.3	3.9	0.67	103.8	85.1969	52.666
2015	12	16	2	2	22	0.3	3.9	0.67	102.5	85.1969	52.666
2015	12	16	2	12	22	0.3	3.9	0.63	104.7	85.1969	49.4902
2015	12	16	2	22	22	0.3	3.9	0.66	102.4	85.1969	51.6074
2015	12	16	2	32	22	0.3	3.9	0.68	101.1	85.1969	53.7246
2015	12	16	2	42	22	0.3	3.9	0.68	105.6	85.1969	53.1953
2015	12	16	2	52	22	0.3	3.9	0.66	99.2	85.1969	52.4014
2015	12	16	3	2	22	0.3	3.9	0.68	101.7	85.1969	53.7247
2015	12	16	3	12	22	0.3	3.9	0.66	100.9	85.1969	52.1368
2015	12	16	3	22	22	0.3	3.9	0.68	103.4	85.1969	53.46
2015	12	16	3	32	22	0.3	3.9	0.64	101.5	85.1969	50.8135
2015	12	16	3	42	22	0.3	3.9	0.63	101.4	85.1969	50.0196
2015	12	16	3	52	22	0.3	3.9	0.64	100.3	85.1969	51.0782
2015	12	16	4	2	22	0.3	3.9	0.67	101.1	85.1312	52.624
2015	12	16	4	12	22	0.3	3.9	0.64	103.1	85.1969	50.0196
2015	12	16	4	22	22	0.3	3.9	0.67	102.8	85.1312	52.3596
2015	12	16	4	32	22	0.3	3.9	0.64	103.3	85.1312	50.2441
2015	12	16	4	42	22	0.3	3.9	0.64	100.9	85.1969	51.0783
2015	12	16	4	52	22	0.3	3.9	0.66	99.4	85.1312	52.6241
2015	12	16	5	2	22	0.3	3.9	0.67	100.7	85.1969	53.4602
2015	12	16	5	12	22	0.3	3.9	0.64	101.3	85.1312	50.2441
2015	12	16	5	22	22	0.3	3.9	0.64	103.1	85.1312	49.9797
2015	12	16	5	32	22	0.3	3.9	0.63	102.9	85.1312	49.7153
2015	12	16	5	42	22	0.3	3.9	0.68	102.8	85.1312	53.4175
2015	12	16	5	52	22	0.3	3.9	0.65	100.8	85.1312	51.302
2015	12	16	6	2	22	0.3	3.9	0.65	98.1	85.1312	52.0953
2015	12	16	6	12	22	0.3	3.9	0.65	98.9	85.1312	52.0953
2015	12	16	6	22	22	0.3	3.9	0.65	99.7	85.1312	51.302
2015	12	16	6	32	22	0.3	3.9	0.65	100.8	85.1312	51.302
2015	12	16	6	42	22	0.3	3.9	0.66	102	85.1312	52.3598
2015	12	16	6	52	22	0.3	3.9	0.66	99.7	85.1312	52.3598
2015	12	16	7	2	22	0.3	3.9	0.65	99.9	85.1312	51.3021
2015	12	16	7	12	22	0.3	3.9	0.63	101.8	85.1312	49.451
2015	12	16	7	22	22	0.3	3.9	0.64	101.3	85.1312	50.2443
2015	12	16	7	32	22	0.3	3.9	0.65	100.1	85.1969	51.8725
2015	12	16	7	42	22	0.3	3.9	0.64	103.3	85.1312	50.5088
2015	12	16	7	52	22	0.3	3.9	0.67	101.4	85.1312	52.6243

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	8	2	22	0.3	3.9	0.64	100.1	85.1312	50.5088
2015	12	16	8	12	22	0.3	3.9	0.66	102.9	85.1312	51.831
2015	12	16	8	22	22	0.3	3.9	0.64	101.9	85.1969	50.2845
2015	12	16	8	32	22	0.3	3.9	0.65	101.1	85.1312	51.3021
2015	12	16	8	42	22	0.3	3.9	0.63	101.5	85.1969	49.4905
2015	12	16	8	52	22	0.3	3.9	0.64	100.9	85.1969	51.0784
2015	12	16	9	2	22	0.3	3.9	0.64	98.5	85.1969	51.0784
2015	12	16	9	12	22	0.3	3.9	0.67	100.8	85.1969	52.9309
2015	12	16	9	22	22	0.3	3.9	0.63	99.3	85.1969	50.2844
2015	12	16	9	32	22	0.3	3.9	0.63	100.5	85.1969	50.0197
2015	12	16	9	42	22	0.3	3.9	0.67	102.8	85.1969	52.4016
2015	12	16	9	52	22	0.3	3.9	0.65	104	85.2625	51.1191
2015	12	16	10	2	22	0.3	3.9	0.65	105	85.2625	50.3245
2015	12	16	10	12	22	0.3	3.9	0.65	100.7	85.1969	51.6075
2015	12	16	10	22	22	0.3	3.9	0.66	100	85.2625	52.4434
2015	12	16	10	32	22	0.3	3.9	0.64	101.9	85.2625	50.3244
2015	12	16	10	42	22	0.3	3.9	0.59	101.8	85.2625	46.8811
2015	12	16	10	52	22	0.3	3.9	0.65	100.5	85.2625	51.6487
2015	12	16	11	2	22	0.3	3.9	0.63	101.8	85.2625	49.5298
2015	12	16	11	12	22	0.3	3.9	0.64	100.3	85.2625	50.8541
2015	12	16	11	22	22	0.3	3.9	0.64	101.3	85.2625	50.5892
2015	12	16	11	32	22	0.3	3.9	0.66	102.6	85.2625	52.1784
2015	12	16	11	42	22	0.3	3.9	0.66	102.1	85.2625	51.9135
2015	12	16	11	52	22	0.3	3.9	0.66	101.3	85.2625	51.9135
2015	12	16	12	2	22	0.3	3.9	0.65	101.9	85.2625	51.6486
2015	12	16	12	12	22	0.3	3.9	0.62	102.3	85.2625	48.7351
2015	12	16	12	22	22	0.3	3.9	0.63	102.3	85.2625	49.7946
2015	12	16	12	32	22	0.3	3.9	0.64	101.2	85.2625	50.854
2015	12	16	12	42	22	0.3	3.9	0.61	101.5	85.2625	48.2054
2015	12	16	12	52	22	0.3	3.9	0.65	101.9	85.2625	51.3838
2015	12	16	13	2	22	0.3	3.9	0.63	101.4	85.2625	50.0595
2015	12	16	13	12	22	0.3	3.9	0.65	102.6	85.2625	50.8541
2015	12	16	13	22	22	0.3	3.9	0.64	101.5	85.2625	50.5892
2015	12	16	13	32	22	0.3	3.9	0.61	99.6	85.2625	48.7351
2015	12	16	13	42	22	0.3	3.9	0.62	103.4	85.2625	48.7352
2015	12	16	13	52	22	0.3	3.9	0.62	100.6	85.2625	49.5298
2015	12	16	14	2	22	0.3	3.9	0.61	100.8	85.1969	48.6963
2015	12	16	14	12	22	0.3	3.9	0.64	101.3	85.1969	50.5489
2015	12	16	14	22	22	0.3	3.9	0.63	102.7	85.1969	49.4903
2015	12	16	14	32	22	0.3	3.9	0.62	101.5	85.1969	49.2256
2015	12	16	14	42	22	0.3	3.9	0.67	102.5	85.1969	52.4015
2015	12	16	14	52	22	0.3	3.9	0.6	100.9	85.1969	47.9024
2015	12	16	15	2	22	0.3	3.9	0.64	101.3	85.1969	50.2844
2015	12	16	15	12	22	0.3	3.9	0.63	100.3	85.1312	49.7153
2015	12	16	15	22	22	0.3	3.9	0.62	100.1	85.1312	49.1865
2015	12	16	15	32	22	0.3	3.9	0.65	102.9	85.1312	50.7732

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	15	42	22	0.3	3.9	0.67	99.4	85.1312	52.8887
2015	12	16	15	52	22	0.3	3.9	0.64	102.8	85.1312	50.2443
2015	12	16	16	2	22	0.3	3.9	0.64	101.2	85.1312	50.7732
2015	12	16	16	12	22	0.3	3.9	0.63	101.8	85.1312	49.451
2015	12	16	16	22	22	0.3	3.9	0.65	102.6	85.1312	50.7732
2015	12	16	16	32	22	0.3	3.9	0.65	100.5	85.1312	51.5665
2015	12	16	16	42	22	0.3	3.9	0.66	100.6	85.1312	52.0954
2015	12	16	16	52	22	0.3	3.9	0.59	100	85.1312	46.5421
2015	12	16	17	2	22	0.3	3.9	0.64	103.1	85.1312	49.9799
2015	12	16	17	12	22	0.3	3.9	0.62	100.4	85.1312	48.9221
2015	12	16	17	22	22	0.3	3.9	0.64	99.1	85.1312	51.3021
2015	12	16	17	32	22	0.3	3.9	0.63	101.1	85.1312	49.7155
2015	12	16	17	42	22	0.3	3.9	0.63	102.2	85.1312	49.9799
2015	12	16	17	52	22	0.3	3.9	0.63	102.4	85.1312	49.451
2015	12	16	18	2	22	0.3	3.9	0.63	100.4	85.1312	50.2444
2015	12	16	18	12	22	0.3	3.9	0.64	101.6	85.1312	50.2444
2015	12	16	18	22	22	0.3	3.9	0.65	101.4	85.1312	51.0377
2015	12	16	18	32	22	0.3	3.9	0.66	100.9	85.1312	52.0955
2015	12	16	18	42	22	0.3	3.9	0.63	100.3	85.1312	49.7155
2015	12	16	18	52	22	0.3	3.9	0.65	102.3	85.1312	51.0377
2015	12	16	19	2	22	0.3	3.9	0.66	99.5	85.1312	52.36
2015	12	16	19	12	22	0.3	3.9	0.63	101.7	85.1312	49.7155
2015	12	16	19	22	22	0.3	3.9	0.62	100.4	85.1312	49.1866
2015	12	16	19	32	22	0.3	3.9	0.64	101.2	85.1312	50.7733
2015	12	16	19	42	22	0.3	3.9	0.64	103	85.1312	50.2444
2015	12	16	19	52	22	0.3	3.9	0.62	102.1	85.0656	49.1473
2015	12	16	20	2	22	0.3	3.9	0.61	100.3	85.1312	48.1289
2015	12	16	20	12	22	0.3	3.9	0.64	100.6	85.1312	51.0378
2015	12	16	20	22	22	0.3	3.9	0.64	101.2	85.1312	50.7734
2015	12	16	20	32	22	0.3	3.9	0.64	100.6	85.1312	51.0378
2015	12	16	20	42	22	0.3	3.9	0.64	102.5	85.1312	49.9801
2015	12	16	20	52	22	0.3	3.9	0.64	101	85.0656	50.4685
2015	12	16	21	2	22	0.3	3.9	0.62	101.6	85.0656	48.8832
2015	12	16	21	12	22	0.3	3.9	0.62	103.2	85.0656	48.3547
2015	12	16	21	22	22	0.3	3.9	0.63	101.7	85.1312	49.9801
2015	12	16	21	32	22	0.3	3.9	0.62	100.4	85.0656	49.1474
2015	12	16	21	42	22	0.3	3.9	0.63	101.1	85.0656	49.9401
2015	12	16	21	52	22	0.3	3.9	0.65	103.4	85.1312	51.0379
2015	12	16	22	2	22	0.3	3.9	0.63	102.7	85.0656	49.4117
2015	12	16	22	12	22	0.3	3.9	0.63	100.8	85.1312	49.9802
2015	12	16	22	22	22	0.3	3.9	0.64	101	85.0656	50.4687
2015	12	16	22	32	22	0.3	3.9	0.67	100.7	85.0656	53.111
2015	12	16	22	42	22	0.3	3.9	0.6	102.9	85.0656	47.2979
2015	12	16	22	52	22	0.3	3.9	0.62	101.9	85.0656	48.8833
2015	12	16	23	2	22	0.3	3.9	0.64	98.8	85.0656	50.9972
2015	12	16	23	12	22	0.3	3.9	0.63	100.5	85.0656	49.9403

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	23	22	22	0.3	3.9	0.64	100.3	85.0656	50.9972
2015	12	16	23	32	22	0.3	3.9	0.64	101.5	85.0656	50.4687
2015	12	16	23	42	22	0.3	3.9	0.63	100.3	85.0656	49.6761
2015	12	16	23	52	22	0.3	3.9	0.65	101	85.0656	51.5257
2015	12	17	0	2	22	0.3	3.9	0.63	98	85.0656	50.4688
2015	12	17	0	12	22	0.3	3.9	0.62	102.1	85.0656	49.1476
2015	12	17	0	22	22	0.3	3.9	0.65	101.4	85.0656	50.9973
2015	12	17	0	32	22	0.3	3.9	0.66	100.1	85.0656	52.0543
2015	12	17	0	42	22	0.3	3.9	0.65	100.7	85.0656	51.79
2015	12	17	0	52	22	0.3	3.9	0.65	99.4	85.0656	51.2616
2015	12	17	1	2	22	0.3	3.9	0.65	99.8	85.0656	51.7901
2015	12	17	1	12	22	0.3	3.9	0.64	103.9	85.0656	50.2047
2015	12	17	1	22	22	0.3	3.9	0.66	101.3	85.0656	51.7901
2015	12	17	1	32	22	0.3	3.9	0.64	102.1	85.0656	50.4689
2015	12	17	1	42	22	0.3	3.9	0.67	100.8	85.0656	52.8471
2015	12	17	1	52	22	0.3	3.9	0.68	101.6	85.0656	53.904
2015	12	17	2	2	22	0.3	3.9	0.63	100.5	85.0656	49.6763
2015	12	17	2	12	22	0.3	3.9	0.67	101.9	85.0656	52.8471
2015	12	17	2	22	22	0.3	3.9	0.65	102.2	85.0656	51.5259
2015	12	17	2	32	22	0.3	3.9	0.62	101.9	85.0656	48.8836
2015	12	17	2	42	22	0.3	3.9	0.66	102.7	85.0656	51.7902
2015	12	17	2	52	22	0.3	3.9	0.64	102.7	85.0656	50.469
2015	12	17	3	2	22	0.3	3.9	0.64	101.5	85.0656	50.4691
2015	12	17	3	12	22	0.3	3.9	0.66	100.8	85.0656	52.583
2015	12	17	3	22	22	0.3	3.9	0.64	101.5	85.0656	50.4691
2015	12	17	3	32	22	0.3	3.9	0.61	98.4	85.0656	48.3552
2015	12	17	3	42	22	0.3	3.9	0.65	100.2	85	51.2208
2015	12	17	3	52	22	0.3	3.9	0.65	103.3	85.0656	51.2618
2015	12	17	4	2	22	0.3	3.9	0.64	100.4	85	50.4287
2015	12	17	4	12	22	0.3	3.9	0.64	100.1	85	50.4287
2015	12	17	4	22	22	0.3	3.9	0.66	100	85	52.541
2015	12	17	4	32	22	0.3	3.9	0.63	100.2	85.0656	49.9407
2015	12	17	4	42	22	0.3	3.9	0.65	101.1	85	51.2209
2015	12	17	4	52	22	0.3	3.9	0.68	102.2	85	53.8611
2015	12	17	5	2	22	0.3	3.9	0.65	99.2	85	52.013
2015	12	17	5	12	22	0.3	3.9	0.68	100.2	85	54.1252
2015	12	17	5	22	22	0.3	3.9	0.69	102.6	85	54.1252
2015	12	17	5	32	22	0.3	3.9	0.68	102.8	85	53.3331
2015	12	17	5	42	22	0.3	3.9	0.67	100.7	85	53.0691
2015	12	17	5	52	22	0.3	3.9	0.67	99.6	85	53.0691
2015	12	17	6	2	22	0.3	3.9	0.65	102.2	85	51.485
2015	12	17	6	12	22	0.3	3.9	0.62	102.3	85	48.5807
2015	12	17	6	22	22	0.3	3.9	0.63	101.9	85	49.9008
2015	12	17	6	32	22	0.3	3.9	0.65	101.1	85	50.957
2015	12	17	6	42	22	0.3	3.9	0.63	102.3	85	49.6368
2015	12	17	6	52	22	0.3	3.9	0.65	103.3	85	51.221

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	7	2	22	0.3	3.9	0.65	101.1	85	51.221
2015	12	17	7	12	22	0.3	3.9	0.66	102.7	85	51.7491
2015	12	17	7	22	22	0.3	3.9	0.64	102.4	85	50.4289
2015	12	17	7	32	22	0.3	3.9	0.66	103.3	84.9344	51.4438
2015	12	17	7	42	22	0.3	3.9	0.67	100.7	84.9344	53.0267
2015	12	17	7	52	22	0.3	3.9	0.67	100.2	84.9344	53.0267
2015	12	17	8	2	22	0.3	3.9	0.65	101.9	84.9344	51.1799
2015	12	17	8	12	22	0.3	3.9	0.66	100.1	84.9344	51.9714
2015	12	17	8	22	22	0.3	3.9	0.63	102.3	84.9344	49.597
2015	12	17	8	32	22	0.3	3.9	0.65	103.2	84.9344	50.6522
2015	12	17	8	42	22	0.3	3.9	0.65	101.1	85	51.2209
2015	12	17	8	52	22	0.3	3.9	0.64	102.2	84.9344	50.1245
2015	12	17	9	2	22	0.3	3.9	0.62	102.5	84.9344	48.8055
2015	12	17	9	12	22	0.3	3.9	0.63	101.2	85	49.3726
2015	12	17	9	22	22	0.3	3.9	0.62	102.6	85	48.5805
2015	12	17	9	32	22	0.3	3.9	0.63	100.8	85	49.6366
2015	12	17	9	42	22	0.3	3.9	0.65	99.3	85	51.4847
2015	12	17	9	52	22	0.3	3.9	0.64	102.4	85	50.4286
2015	12	17	10	2	22	0.3	3.9	0.63	101.4	85	49.9005
2015	12	17	10	12	22	0.3	3.9	0.64	99.8	85	50.6926
2015	12	17	10	22	22	0.3	3.9	0.63	102.4	85	49.3724
2015	12	17	10	32	22	0.3	3.9	0.64	100	85	50.6925
2015	12	17	10	42	22	0.3	3.9	0.63	99.7	85	49.6364
2015	12	17	10	52	22	0.3	3.9	0.61	102.3	85	48.3163
2015	12	17	11	2	22	0.3	3.9	0.63	100.5	85	49.6364
2015	12	17	11	12	22	0.3	3.9	0.61	102.8	85	47.5242
2015	12	17	11	22	22	0.3	3.9	0.66	102.9	85	52.0126
2015	12	17	11	32	22	0.3	3.9	0.62	101.9	85	48.8443
2015	12	17	11	42	22	0.3	3.9	0.63	98.4	85	50.1645
2015	12	17	11	52	22	0.3	3.9	0.62	102	85	48.5803
2015	12	17	12	2	22	0.3	3.9	0.66	101	85	51.7485
2015	12	17	12	12	22	0.3	3.9	0.65	99.9	85	51.4845
2015	12	17	12	22	22	0.3	3.9	0.66	101.7	85	52.2765
2015	12	17	12	32	22	0.3	3.9	0.63	101.7	85	49.6363
2015	12	17	12	42	22	0.3	3.9	0.62	101.7	85	48.5802
2015	12	17	12	52	22	0.3	3.9	0.67	100.8	84.9344	52.7623
2015	12	17	13	2	22	0.3	3.9	0.64	100.9	84.9344	50.6518
2015	12	17	13	12	22	0.3	3.9	0.64	100.6	84.9344	50.9156
2015	12	17	13	22	22	0.3	3.9	0.64	101.5	84.9344	50.6518
2015	12	17	13	32	22	0.3	3.9	0.63	99.9	84.9344	50.1242
2015	12	17	13	42	22	0.3	3.9	0.64	101.6	84.9344	50.1243
2015	12	17	13	52	22	0.3	3.9	0.63	101.1	84.9344	49.8605
2015	12	17	14	2	22	0.3	3.9	0.62	100.7	84.9344	49.0691
2015	12	17	14	12	22	0.3	3.9	0.62	103.2	84.8688	48.5025
2015	12	17	14	22	22	0.3	3.9	0.61	98.7	84.9344	48.5414
2015	12	17	14	32	22	0.3	3.9	0.66	101	84.8688	51.6658

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	14	42	22	0.3	3.9	0.62	100.6	84.8688	49.2934
2015	12	17	14	52	22	0.3	3.9	0.63	102.1	84.8688	49.2934
2015	12	17	15	2	22	0.3	3.9	0.65	99.4	84.8688	51.1387
2015	12	17	15	12	22	0.3	3.9	0.65	102.6	84.8032	50.5709
2015	12	17	15	22	22	0.3	3.9	0.64	100.1	84.8032	50.3076
2015	12	17	15	32	22	0.3	3.9	0.65	101.7	84.8032	51.0978
2015	12	17	15	42	22	0.3	3.9	0.65	99.9	84.8032	51.0978
2015	12	17	15	52	22	0.3	3.9	0.63	100.8	84.8032	49.5174
2015	12	17	16	2	22	0.3	3.9	0.65	102.2	84.8032	51.3612
2015	12	17	16	12	22	0.3	3.9	0.63	100.7	84.8032	50.0442
2015	12	17	16	22	22	0.3	3.9	0.65	99.9	84.8032	51.0978
2015	12	17	16	32	22	0.3	3.9	0.67	101.9	84.8032	52.4148
2015	12	17	16	42	22	0.3	3.9	0.63	99.9	84.7375	50.0041
2015	12	17	16	52	22	0.3	3.9	0.63	100.5	84.8032	49.7809
2015	12	17	17	2	22	0.3	3.9	0.65	99.9	84.8032	51.3612
2015	12	17	17	12	22	0.3	3.9	0.65	102.6	84.7375	50.5304
2015	12	17	17	22	22	0.3	3.9	0.64	100.1	84.7375	50.2673
2015	12	17	17	32	22	0.3	3.9	0.64	102.4	84.8032	50.3077
2015	12	17	17	42	22	0.3	3.9	0.65	99.8	84.7375	51.5832
2015	12	17	17	52	22	0.3	3.9	0.64	99.8	84.7375	50.2673
2015	12	17	18	2	22	0.3	3.9	0.64	101.8	84.7375	50.5305
2015	12	17	18	12	22	0.3	3.9	0.63	100.5	84.7375	49.4777
2015	12	17	18	22	22	0.3	3.9	0.63	100.5	84.7375	49.4777
2015	12	17	18	32	22	0.3	3.9	0.65	102.2	84.7375	51.32
2015	12	17	18	42	22	0.3	3.9	0.65	101.9	84.7375	51.0568
2015	12	17	18	52	22	0.3	3.9	0.63	101.1	84.7375	49.7409
2015	12	17	19	2	22	0.3	3.9	0.66	100.6	84.7375	52.1095
2015	12	17	19	12	22	0.3	3.9	0.63	102.7	84.7375	48.9514
2015	12	17	19	22	22	0.3	3.9	0.65	102.5	84.7375	51.0568
2015	12	17	19	32	22	0.3	3.9	0.63	103	84.7375	48.9514
2015	12	17	19	42	22	0.3	3.9	0.65	100.7	84.7375	51.32
2015	12	17	19	52	22	0.3	3.9	0.63	102.3	84.7375	49.4777
2015	12	17	20	2	22	0.3	3.9	0.65	104.7	84.7375	50.2673
2015	12	17	20	12	22	0.3	3.9	0.63	102.1	84.7375	49.2146
2015	12	17	20	22	22	0.3	3.9	0.67	105	84.7375	52.1095
2015	12	17	20	32	22	0.3	3.9	0.63	104.4	84.7375	49.2146
2015	12	17	20	42	22	0.3	3.9	0.67	103.6	84.7375	52.1095
2015	12	17	20	52	22	0.3	3.9	0.64	101.6	84.7375	50.0041
2015	12	17	21	2	22	0.3	3.9	0.64	103.4	84.7375	49.7409
2015	12	17	21	12	22	0.3	3.9	0.63	102.6	84.7375	49.4778
2015	12	17	21	22	22	0.3	3.9	0.61	101.4	84.7375	48.1619
2015	12	17	21	32	22	0.3	3.9	0.63	103.5	84.7375	49.2146
2015	12	17	21	42	22	0.3	3.9	0.65	104.2	84.7375	50.7937
2015	12	17	21	52	22	0.3	3.9	0.66	104	84.7375	51.5832
2015	12	17	22	2	22	0.3	3.9	0.63	101.4	84.7375	49.741
2015	12	17	22	12	22	0.3	3.9	0.66	103.1	84.7375	51.8464

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	22	22	22	0.3	3.9	0.64	100.1	84.6719	50.227
2015	12	17	22	32	22	0.3	3.9	0.66	104.2	84.6719	51.0159
2015	12	17	22	42	22	0.3	3.9	0.64	103.7	84.6719	49.701
2015	12	17	22	52	22	0.3	3.9	0.62	102.9	84.6719	48.1232
2015	12	17	23	2	22	0.3	3.9	0.67	102.8	84.6719	52.0678
2015	12	17	23	12	22	0.3	3.9	0.63	100.1	84.6719	49.964
2015	12	17	23	22	22	0.3	3.9	0.63	99.9	84.6719	49.964
2015	12	17	23	32	22	0.3	3.9	0.65	102.2	84.6719	51.0159
2015	12	17	23	42	22	0.3	3.9	0.66	99.7	84.6719	52.0678
2015	12	17	23	52	22	0.3	3.9	0.66	102	84.6719	51.8048
2015	12	18	0	2	22	0.3	3.9	0.66	103.4	84.6719	51.8049
2015	12	18	0	12	22	0.3	3.9	0.65	101.9	84.6719	51.016
2015	12	18	0	22	22	0.3	3.9	0.66	101.8	84.6719	51.5419
2015	12	18	0	32	22	0.3	3.9	0.64	100.3	84.6719	50.49
2015	12	18	0	42	22	0.3	3.9	0.61	103.7	84.6719	47.3344
2015	12	18	0	52	22	0.3	3.9	0.66	103.8	84.6719	51.279
2015	12	18	1	2	22	0.3	3.9	0.65	102.2	84.6719	51.016
2015	12	18	1	12	22	0.3	3.9	0.65	103.5	84.6719	50.4901
2015	12	18	1	22	22	0.3	3.9	0.67	101.3	84.6063	52.8143
2015	12	18	1	32	22	0.3	3.9	0.67	104.9	84.6063	51.5005
2015	12	18	1	42	22	0.3	3.9	0.65	101.6	84.6063	51.2377
2015	12	18	1	52	22	0.3	3.9	0.65	102.8	84.6063	50.7122
2015	12	18	2	2	22	0.3	3.9	0.67	102.7	84.6063	52.2888
2015	12	18	2	12	22	0.3	3.9	0.62	100.6	84.6063	49.1357
2015	12	18	2	22	22	0.3	3.9	0.64	103.7	84.6063	49.6612
2015	12	18	2	32	22	0.3	3.9	0.63	103.2	84.6063	49.3985
2015	12	18	2	42	22	0.3	3.9	0.66	102	84.6063	52.026
2015	12	18	2	52	22	0.3	3.9	0.67	102.7	84.6063	52.2888
2015	12	18	3	2	22	0.3	3.9	0.64	103	84.6063	50.1867
2015	12	18	3	12	22	0.3	3.9	0.63	103.9	84.6063	48.873
2015	12	18	3	22	22	0.3	3.9	0.66	103.2	84.6063	51.5005
2015	12	18	3	32	22	0.3	3.9	0.61	103.1	84.6063	47.5592
2015	12	18	3	42	22	0.3	3.9	0.65	103.4	84.6063	50.7123
2015	12	18	3	52	22	0.3	3.9	0.66	103.8	84.6063	51.5005
2015	12	18	4	2	22	0.3	3.9	0.64	101.3	84.6063	49.924
2015	12	18	4	12	22	0.3	3.9	0.63	104.3	84.6063	48.6102
2015	12	18	4	22	22	0.3	3.9	0.64	101.3	84.6063	49.924
2015	12	18	4	32	22	0.3	3.9	0.67	102.5	84.6063	52.2888
2015	12	18	4	42	22	0.3	3.9	0.66	100.9	84.6063	51.7633
2015	12	18	4	52	22	0.3	3.9	0.64	102.1	84.6063	50.1867
2015	12	18	5	2	22	0.3	3.9	0.61	102	84.6063	48.0847
2015	12	18	5	12	22	0.3	3.9	0.64	102.3	84.6063	50.4495
2015	12	18	5	22	22	0.3	3.9	0.62	102.1	84.6063	48.8729
2015	12	18	5	32	22	0.3	3.9	0.64	103.7	84.6063	49.6612
2015	12	18	5	42	22	0.3	3.9	0.65	102.3	84.6063	50.7122
2015	12	18	5	52	22	0.3	3.9	0.64	103.5	84.6063	50.1867

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	6	2	22	0.3	3.9	0.67	102.4	84.6063	52.5516
2015	12	18	6	12	22	0.3	3.9	0.64	102.3	84.6063	50.4495
2015	12	18	6	22	22	0.3	3.9	0.63	102.1	84.6063	49.1357
2015	12	18	6	32	22	0.3	3.9	0.67	102.7	84.6063	52.5516
2015	12	18	6	42	22	0.3	3.9	0.61	100.8	84.6063	48.3474
2015	12	18	6	52	22	0.3	3.9	0.63	102.2	84.6719	49.7012
2015	12	18	7	2	22	0.3	3.9	0.63	103.2	84.6719	49.4382
2015	12	18	7	12	22	0.3	3.9	0.67	105.1	84.6063	51.5005
2015	12	18	7	22	22	0.3	3.9	0.64	100.9	84.6063	50.7122
2015	12	18	7	32	22	0.3	3.9	0.65	102.3	84.6063	50.7122
2015	12	18	7	42	22	0.3	3.9	0.66	100.9	84.6719	52.0679
2015	12	18	7	52	22	0.3	3.9	0.63	103.9	84.6719	48.9122
2015	12	18	8	2	22	0.3	3.9	0.64	102.3	84.6719	50.49
2015	12	18	8	12	22	0.3	3.9	0.62	101.7	84.6719	48.3862
2015	12	18	8	22	22	0.3	3.9	0.63	102.3	84.6719	49.4381
2015	12	18	8	32	22	0.3	3.9	0.65	105.2	84.6719	50.227
2015	12	18	8	42	22	0.3	3.9	0.66	102.7	84.6719	51.5418
2015	12	18	8	52	22	0.3	3.9	0.65	102.2	84.6719	51.0158
2015	12	18	9	2	22	0.3	3.9	0.65	102.2	84.6719	51.0157
2015	12	18	9	12	22	0.3	3.9	0.66	102.1	84.6719	51.5416
2015	12	18	9	22	22	0.3	3.9	0.65	102.2	84.6719	51.0157
2015	12	18	9	32	22	0.3	3.9	0.65	102.2	84.6719	51.2786
2015	12	18	9	42	22	0.3	3.9	0.65	100.8	84.6719	51.0156
2015	12	18	9	52	22	0.3	3.9	0.67	100.5	84.6719	52.5933
2015	12	18	10	2	22	0.3	3.9	0.64	101.3	84.6719	50.2266
2015	12	18	10	12	22	0.3	3.9	0.63	99.7	84.6719	49.4377
2015	12	18	10	22	22	0.3	3.9	0.67	98.8	84.6719	52.8562
2015	12	18	10	32	22	0.3	3.9	0.66	101.8	84.7375	51.5828
2015	12	18	10	42	22	0.3	3.9	0.64	102.8	84.7375	49.7406
2015	12	18	10	52	22	0.3	3.9	0.64	101.3	84.7375	50.0037
2015	12	18	11	2	22	0.3	3.9	0.63	101.7	84.7375	49.4773
2015	12	18	11	12	22	0.3	3.9	0.64	102.3	84.7375	50.53
2015	12	18	11	22	22	0.3	3.9	0.63	102.6	84.7375	49.4773
2015	12	18	11	32	22	0.3	3.9	0.64	101	84.7375	50.2668
2015	12	18	11	42	22	0.3	3.9	0.65	103.5	84.7375	50.53
2015	12	18	11	52	22	0.3	3.9	0.64	102.7	84.7375	50.2668
2015	12	18	12	2	22	0.3	3.9	0.64	102.1	84.7375	50.53
2015	12	18	12	12	22	0.3	3.9	0.65	99.9	84.7375	51.3195
2015	12	18	12	22	22	0.3	3.9	0.64	102.4	84.6719	50.2264
2015	12	18	12	32	22	0.3	3.9	0.64	100.6	84.6719	50.4894
2015	12	18	12	42	22	0.3	3.9	0.6	102.3	84.6719	47.0709
2015	12	18	12	52	22	0.3	3.9	0.67	101.6	84.6719	52.5932
2015	12	18	13	2	22	0.3	3.9	0.66	104.7	84.6063	50.9743
2015	12	18	13	12	22	0.3	3.9	0.61	100.9	84.6719	47.8598
2015	12	18	13	22	22	0.3	3.9	0.66	101.8	84.6063	51.4999
2015	12	18	13	32	22	0.3	3.9	0.63	101.8	84.6719	49.1747

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	13	42	22	0.3	3.9	0.67	101	84.6719	52.8562
2015	12	18	13	52	22	0.3	3.9	0.63	103.6	84.6063	48.8724
2015	12	18	14	2	22	0.3	3.9	0.62	102.9	84.6063	48.3469
2015	12	18	14	12	22	0.3	3.9	0.63	102.7	84.6063	48.8725
2015	12	18	14	22	22	0.3	3.9	0.65	103.7	84.6063	50.7118
2015	12	18	14	32	22	0.3	3.9	0.62	102.1	84.6063	48.8726
2015	12	18	14	42	22	0.3	3.9	0.62	102.9	84.6719	48.123
2015	12	18	14	52	22	0.3	3.9	0.63	102.6	84.6063	49.3981
2015	12	18	15	2	22	0.3	3.9	0.64	101.3	84.5407	49.8835
2015	12	18	15	12	22	0.3	3.9	0.62	103.7	84.5407	48.3083
2015	12	18	15	22	22	0.3	3.9	0.66	102.7	84.4751	51.4175
2015	12	18	15	32	22	0.3	3.9	0.64	103	84.5407	50.1462
2015	12	18	15	42	22	0.3	3.9	0.64	99.1	84.5407	50.9339
2015	12	18	15	52	22	0.3	3.9	0.65	101.9	84.5407	50.9339
2015	12	18	16	2	22	0.3	3.9	0.65	103.1	84.5407	50.9339
2015	12	18	16	12	22	0.3	3.9	0.61	101.8	84.5407	47.7834
2015	12	18	16	22	22	0.3	3.9	0.63	101.9	84.5407	49.6212
2015	12	18	16	32	22	0.3	3.9	0.63	104	84.5407	48.571
2015	12	18	16	42	22	0.3	3.9	0.64	103	84.5407	50.1463
2015	12	18	16	52	22	0.3	3.9	0.63	104	84.5407	48.571
2015	12	18	17	2	22	0.3	3.9	0.64	102.1	84.5407	50.1463
2015	12	18	17	12	22	0.3	3.9	0.67	103.5	84.5407	52.5092
2015	12	18	17	22	22	0.3	3.9	0.63	101.7	84.5407	49.6212
2015	12	18	17	32	22	0.3	3.9	0.65	101.9	84.5407	50.9339
2015	12	18	17	42	22	0.3	3.9	0.65	102.2	84.5407	50.9339
2015	12	18	17	52	22	0.3	3.9	0.62	104.6	84.5407	48.3085
2015	12	18	18	2	22	0.3	3.9	0.62	99.2	84.5407	48.8336
2015	12	18	18	12	22	0.3	3.9	0.66	101.4	84.5407	51.9841
2015	12	18	18	22	22	0.3	3.9	0.66	101.3	84.5407	51.459
2015	12	18	18	32	22	0.3	3.9	0.65	102.2	84.5407	51.1965
2015	12	18	18	42	22	0.3	3.9	0.65	102.8	84.5407	50.934
2015	12	18	18	52	22	0.3	3.9	0.67	102.8	84.5407	51.9841
2015	12	18	19	2	22	0.3	3.9	0.64	102.8	84.5407	49.6212
2015	12	18	19	12	22	0.3	3.9	0.61	100.5	84.5407	48.046
2015	12	18	19	22	22	0.3	3.9	0.66	100.9	84.5407	51.9841
2015	12	18	19	32	22	0.3	3.9	0.65	102.6	84.5407	50.4089
2015	12	18	19	42	22	0.3	3.9	0.66	102.4	84.5407	51.1965
2015	12	18	19	52	22	0.3	3.9	0.62	101.5	84.6063	48.8729
2015	12	18	20	2	22	0.3	3.9	0.65	101.7	84.5407	50.6714
2015	12	18	20	12	22	0.3	3.9	0.66	101.5	84.6063	51.7633
2015	12	18	20	22	22	0.3	3.9	0.63	101.9	84.6063	49.6612
2015	12	18	20	32	22	0.3	3.9	0.64	101.2	84.6063	50.4495
2015	12	18	20	42	22	0.3	3.9	0.66	100.9	84.6063	51.7633
2015	12	18	20	52	22	0.3	3.9	0.66	104.1	84.6063	51.2378
2015	12	18	21	2	22	0.3	3.9	0.66	102.4	84.6063	51.2377
2015	12	18	21	12	22	0.3	3.9	0.64	99.7	84.6063	50.7122

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	21	22	22	0.3	3.9	0.66	102.1	84.6063	51.5005
2015	12	18	21	32	22	0.3	3.9	0.64	101.8	84.6063	50.4495
2015	12	18	21	42	22	0.3	3.9	0.64	102.1	84.6063	50.1867
2015	12	18	21	52	22	0.3	3.9	0.68	102.8	84.6063	53.3398
2015	12	18	22	2	22	0.3	3.9	0.67	101.8	84.6719	52.8568
2015	12	18	22	12	22	0.3	3.9	0.64	103.3	84.6063	49.924
2015	12	18	22	22	22	0.3	3.9	0.66	101.8	84.6719	51.542
2015	12	18	22	32	22	0.3	3.9	0.65	100.2	84.6719	51.279
2015	12	18	22	42	22	0.3	3.9	0.65	103.4	84.6719	50.7531
2015	12	18	22	52	22	0.3	3.9	0.64	102.4	84.6719	50.2271
2015	12	18	23	2	22	0.3	3.9	0.64	102.5	84.6719	49.7012
2015	12	18	23	12	22	0.3	3.9	0.66	103	84.6719	51.279
2015	12	18	23	22	22	0.3	3.9	0.67	101.9	84.6719	52.5938
2015	12	18	23	32	22	0.3	3.9	0.68	100.6	84.6719	53.6457
2015	12	18	23	42	22	0.3	3.9	0.67	101	84.6719	52.8568
2015	12	18	23	52	22	0.3	3.9	0.64	100.9	84.6719	50.7531
2015	12	19	0	2	22	0.3	3.9	0.66	101.4	84.6719	52.0679
2015	12	19	0	12	22	0.3	3.9	0.64	100.7	84.6719	50.2271
2015	12	19	0	22	22	0.3	3.9	0.66	102	84.6719	51.805
2015	12	19	0	32	22	0.3	3.9	0.65	102.3	84.6719	50.7531
2015	12	19	0	42	22	0.3	3.9	0.66	102.1	84.6719	51.542
2015	12	19	0	52	22	0.3	3.9	0.66	103.5	84.6719	51.542
2015	12	19	1	2	22	0.3	3.9	0.63	101.2	84.6719	49.1753
2015	12	19	1	12	22	0.3	3.9	0.64	100.3	84.6719	50.4901
2015	12	19	1	22	22	0.3	3.9	0.64	102.5	84.6719	49.7012
2015	12	19	1	32	22	0.3	3.9	0.65	101.1	84.6719	50.7531
2015	12	19	1	42	22	0.3	3.9	0.66	102.6	84.6719	51.805
2015	12	19	1	52	22	0.3	3.9	0.69	103	84.6719	53.6457
2015	12	19	2	2	22	0.3	3.9	0.65	101.4	84.6719	50.7531
2015	12	19	2	12	22	0.3	3.9	0.63	102.7	84.6719	49.1753
2015	12	19	2	22	22	0.3	3.9	0.63	101.7	84.6719	49.7012
2015	12	19	2	32	22	0.3	3.9	0.64	102.3	84.6719	50.4901
2015	12	19	2	42	22	0.3	3.9	0.67	102.7	84.6719	52.5939
2015	12	19	2	52	22	0.3	3.9	0.66	99.5	84.6719	51.805
2015	12	19	3	2	22	0.3	3.9	0.67	100.5	84.6719	52.5939
2015	12	19	3	12	22	0.3	3.9	0.65	102.3	84.7375	50.7939
2015	12	19	3	22	22	0.3	3.9	0.59	98	84.7375	46.583
2015	12	19	3	32	22	0.3	3.9	0.61	99.6	84.6719	48.1234
2015	12	19	3	42	22	0.3	3.9	0.67	101.8	84.7375	52.8993
2015	12	19	3	52	22	0.3	3.9	0.65	99.9	84.7375	51.3203
2015	12	19	4	2	22	0.3	3.9	0.65	100.2	84.7375	51.3203
2015	12	19	4	12	22	0.3	3.9	0.66	99.1	84.7375	52.6362
2015	12	19	4	22	22	0.3	3.9	0.67	102.8	84.7375	52.1098
2015	12	19	4	32	22	0.3	3.9	0.63	100.4	84.7375	50.0044
2015	12	19	4	42	22	0.3	3.9	0.66	101.8	84.7375	51.5834
2015	12	19	4	52	22	0.3	3.9	0.66	101.8	84.7375	51.5834

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	5	2	22	0.3	3.9	0.61	101.8	84.7375	47.8989
2015	12	19	5	12	22	0.3	3.9	0.63	102.7	84.7375	49.2148
2015	12	19	5	22	22	0.3	3.9	0.66	100.1	84.7375	51.8466
2015	12	19	5	32	22	0.3	3.9	0.65	103.3	84.7375	51.0571
2015	12	19	5	42	22	0.3	3.9	0.64	102.8	84.7375	49.7412
2015	12	19	5	52	22	0.3	3.9	0.63	102.6	84.7375	49.478
2015	12	19	6	2	22	0.3	3.9	0.62	101.9	84.7375	48.6885
2015	12	19	6	12	22	0.3	3.9	0.64	104.3	84.8032	49.7812
2015	12	19	6	22	22	0.3	3.9	0.64	101.9	84.7375	50.0044
2015	12	19	6	32	22	0.3	3.9	0.61	102	84.7375	48.1621
2015	12	19	6	42	22	0.3	3.9	0.64	104	84.8032	49.7812
2015	12	19	6	52	22	0.3	3.9	0.64	103.3	84.7375	50.0044
2015	12	19	7	2	22	0.3	3.9	0.65	102.8	84.8032	50.8347
2015	12	19	7	12	22	0.3	3.9	0.64	102.3	84.8032	50.5713
2015	12	19	7	22	22	0.3	3.9	0.65	102.6	84.8032	50.5713
2015	12	19	7	32	22	0.3	3.9	0.67	101.8	84.8032	52.9418
2015	12	19	7	42	22	0.3	3.9	0.65	103.1	84.8032	50.8347
2015	12	19	7	52	22	0.3	3.9	0.63	102.7	84.8032	48.9909
2015	12	19	8	2	22	0.3	3.9	0.62	102.3	84.8032	48.4641
2015	12	19	8	12	22	0.3	3.9	0.63	101.7	84.8032	49.5177
2015	12	19	8	22	22	0.3	3.9	0.64	102.8	84.7375	49.741
2015	12	19	8	32	22	0.3	3.9	0.62	100.7	84.8688	48.7665
2015	12	19	8	42	22	0.3	3.9	0.6	102.2	84.8688	47.4485
2015	12	19	8	52	22	0.3	3.9	0.63	102.7	84.8032	48.9907
2015	12	19	9	2	22	0.3	3.9	0.65	102.3	84.8688	50.8752
2015	12	19	9	12	22	0.3	3.9	0.63	104.1	84.8032	49.254
2015	12	19	9	22	22	0.3	3.9	0.63	101.9	84.8688	49.8208
2015	12	19	9	32	22	0.3	3.9	0.64	102.5	84.8688	50.0843
2015	12	19	9	42	22	0.3	3.9	0.65	102.8	84.8688	50.8751
2015	12	19	9	52	22	0.3	3.9	0.68	103.2	84.8688	52.9839
2015	12	19	10	2	22	0.3	3.9	0.62	99.1	84.8688	49.2934
2015	12	19	10	12	22	0.3	3.9	0.64	105.3	84.8688	49.2934
2015	12	19	10	22	22	0.3	3.9	0.67	100.5	84.8688	52.7201
2015	12	19	10	32	22	0.3	3.9	0.65	102.5	84.8688	51.1385
2015	12	19	10	42	22	0.3	3.9	0.61	101.7	84.8688	48.2389
2015	12	19	10	52	22	0.3	3.9	0.64	101.8	84.8688	50.3477
2015	12	19	11	2	22	0.3	3.9	0.63	107	84.8688	48.2388
2015	12	19	11	12	22	0.3	3.9	0.64	99.2	84.8688	50.6112
2015	12	19	11	22	22	0.3	3.9	0.66	102.1	84.8688	51.6657
2015	12	19	11	32	22	0.3	3.9	0.64	103.5	84.8688	50.3477
2015	12	19	11	42	22	0.3	3.9	0.66	102	84.8688	51.9293
2015	12	19	11	52	22	0.3	3.9	0.62	101	84.8032	48.7271
2015	12	19	12	2	22	0.3	3.9	0.64	102.1	84.8032	50.3075
2015	12	19	12	12	22	0.3	3.9	0.62	99.5	84.7375	48.9513
2015	12	19	12	22	22	0.3	3.9	0.61	101.4	84.7375	48.1618
2015	12	19	12	32	22	0.3	3.9	0.67	103.3	84.7375	52.3725

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	12	42	22	0.3	3.9	0.62	102.1	84.8032	48.9905
2015	12	19	12	52	22	0.3	3.9	0.66	101.1	84.8032	52.1511
2015	12	19	13	2	22	0.3	3.9	0.66	100.5	84.8032	52.4145
2015	12	19	13	12	22	0.3	3.9	0.63	100.5	84.8032	49.7806
2015	12	19	13	22	22	0.3	3.9	0.63	99.3	84.8032	49.7807
2015	12	19	13	32	22	0.3	3.9	0.65	100.2	84.8032	51.0976
2015	12	19	13	42	22	0.3	3.9	0.63	99.9	84.8032	50.0441
2015	12	19	13	52	22	0.3	3.9	0.63	103.9	84.7375	48.9512
2015	12	19	14	2	22	0.3	3.9	0.66	102.7	84.7375	51.5831
2015	12	19	14	12	22	0.3	3.9	0.65	99.8	84.7375	51.5832
2015	12	19	14	22	22	0.3	3.9	0.65	102.6	84.6719	50.4899
2015	12	19	14	32	22	0.3	3.9	0.64	100.1	84.7375	50.2673
2015	12	19	14	42	22	0.3	3.9	0.63	102.6	84.7375	49.4778
2015	12	19	14	52	22	0.3	3.9	0.61	101.7	84.6719	48.1232
2015	12	19	15	2	22	0.3	3.9	0.65	102	84.6719	50.7529
2015	12	19	15	12	22	0.3	3.9	0.64	101	84.6719	49.964
2015	12	19	15	22	22	0.3	3.9	0.62	101.6	84.6719	48.6492
2015	12	19	15	32	22	0.3	3.9	0.65	100.4	84.6719	51.5419
2015	12	19	15	42	22	0.3	3.9	0.66	101.5	84.6719	51.8049
2015	12	19	15	52	22	0.3	3.9	0.66	101.2	84.6719	51.8049
2015	12	19	16	2	22	0.3	3.9	0.62	100.7	84.6719	48.9122
2015	12	19	16	12	22	0.3	3.9	0.65	101.4	84.6719	50.753
2015	12	19	16	22	22	0.3	3.9	0.65	103.8	84.6719	50.2271
2015	12	19	16	32	22	0.3	3.9	0.68	101.1	84.6719	53.3827
2015	12	19	16	42	22	0.3	3.9	0.67	104.1	84.6063	52.2888
2015	12	19	16	52	22	0.3	3.9	0.67	100.7	84.6063	52.8143
2015	12	19	17	2	22	0.3	3.9	0.63	101.7	84.6719	49.7012
2015	12	19	17	12	22	0.3	3.9	0.66	100.9	84.6719	52.0679
2015	12	19	17	22	22	0.3	3.9	0.63	101.4	84.6719	49.7012
2015	12	19	17	32	22	0.3	3.9	0.66	104.2	84.6063	50.975
2015	12	19	17	42	22	0.3	3.9	0.66	102	84.6063	52.026
2015	12	19	17	52	22	0.3	3.9	0.65	102.2	84.6063	51.2377
2015	12	19	18	2	22	0.3	3.9	0.66	102	84.6063	52.026
2015	12	19	18	12	22	0.3	3.9	0.64	100.3	84.6063	50.4495
2015	12	19	18	22	22	0.3	3.9	0.69	101.2	84.6063	54.3908
2015	12	19	18	32	22	0.3	3.9	0.65	100.7	84.6719	51.279
2015	12	19	18	42	22	0.3	3.9	0.65	102.8	84.6063	50.7122
2015	12	19	18	52	22	0.3	3.9	0.65	100.7	84.6719	51.279
2015	12	19	19	2	22	0.3	3.9	0.69	104.7	84.6063	53.0771
2015	12	19	19	12	22	0.3	3.9	0.66	102.7	84.6063	51.5005
2015	12	19	19	22	22	0.3	3.9	0.66	101.8	84.6719	51.542
2015	12	19	19	32	22	0.3	3.9	0.65	103.5	84.6719	50.4901
2015	12	19	19	42	22	0.3	3.9	0.66	101.8	84.6063	51.5005
2015	12	19	19	52	22	0.3	3.9	0.64	102.8	84.6719	49.9642
2015	12	19	20	2	22	0.3	3.9	0.64	101.3	84.6063	50.1867
2015	12	19	20	12	22	0.3	3.9	0.66	102.3	84.6063	52.026

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	20	22	22	0.3	3.9	0.66	102.1	84.6719	51.542
2015	12	19	20	32	22	0.3	3.9	0.65	100.7	84.6063	51.2378
2015	12	19	20	42	22	0.3	3.9	0.65	103.8	84.6063	50.1867
2015	12	19	20	52	22	0.3	3.9	0.66	100.6	84.6063	52.026
2015	12	19	21	2	22	0.3	3.9	0.64	99.7	84.6063	50.7122
2015	12	19	21	12	22	0.3	3.9	0.64	101.5	84.6063	50.1867
2015	12	19	21	22	22	0.3	3.9	0.63	101.9	84.6063	49.6612
2015	12	19	21	32	22	0.3	3.9	0.66	100.9	84.6063	51.7633
2015	12	19	21	42	22	0.3	3.9	0.66	104.2	84.6063	50.975
2015	12	19	21	52	22	0.3	3.9	0.66	100.9	84.6063	52.026
2015	12	19	22	2	22	0.3	3.9	0.64	100.9	84.6719	50.4901
2015	12	19	22	12	22	0.3	3.9	0.68	103.1	84.6719	53.1198
2015	12	19	22	22	22	0.3	3.9	0.67	101.9	84.6063	52.2888
2015	12	19	22	32	22	0.3	3.9	0.66	102	84.6063	52.026
2015	12	19	22	42	22	0.3	3.9	0.65	102	84.6063	50.7122
2015	12	19	22	52	22	0.3	3.9	0.62	101.9	84.6063	48.6102
2015	12	19	23	2	22	0.3	3.9	0.64	101.5	84.6063	50.1867
2015	12	19	23	12	22	0.3	3.9	0.62	102.3	84.6063	48.3474
2015	12	19	23	22	22	0.3	3.9	0.62	100.7	84.6719	48.9123
2015	12	19	23	32	22	0.3	3.9	0.64	101.9	84.6063	49.924
2015	12	19	23	42	22	0.3	3.9	0.64	100.3	84.6063	50.7122
2015	12	19	23	52	22	0.3	3.9	0.67	103.3	84.6063	52.2888
2015	12	20	0	2	22	0.3	3.9	0.65	102.3	84.6063	50.7122
2015	12	20	0	12	22	0.3	3.9	0.64	100.9	84.6063	50.7122
2015	12	20	0	22	22	0.3	3.9	0.63	100.1	84.6063	49.924
2015	12	20	0	32	22	0.3	3.9	0.64	101.3	84.6063	50.1867
2015	12	20	0	42	22	0.3	3.9	0.64	101.2	84.6063	50.4495
2015	12	20	0	52	22	0.3	3.9	0.69	102.4	84.6063	53.6026
2015	12	20	1	2	22	0.3	3.9	0.64	100.3	84.6063	50.7122
2015	12	20	1	12	22	0.3	3.9	0.66	102.1	84.6063	51.5005
2015	12	20	1	22	22	0.3	3.9	0.62	101.9	84.6063	48.6102
2015	12	20	1	32	22	0.3	3.9	0.65	103.5	84.6063	50.4495
2015	12	20	1	42	22	0.3	3.9	0.65	101.6	84.6063	51.2378
2015	12	20	1	52	22	0.3	3.9	0.63	100.1	84.6063	49.924
2015	12	20	2	2	22	0.3	3.9	0.63	101.4	84.6063	49.6612
2015	12	20	2	12	22	0.3	3.9	0.65	101.4	84.6063	50.975
2015	12	20	2	22	22	0.3	3.9	0.6	109.9	84.6063	44.9316
2015	12	20	2	32	22	0.3	3.9	0.61	100.5	84.6063	48.0847
2015	12	20	2	42	22	0.3	3.9	0.62	102.6	84.6063	48.0847
2015	12	20	2	52	22	0.3	3.9	0.66	102.1	84.6063	51.5005
2015	12	20	3	2	22	0.3	3.9	0.65	99.8	84.6063	51.5005
2015	12	20	3	12	22	0.3	3.9	0.65	101.6	84.6063	51.2378
2015	12	20	3	22	22	0.3	3.9	0.67	101	84.6063	52.8143
2015	12	20	3	32	22	0.3	3.9	0.66	100.9	84.6719	51.805
2015	12	20	3	42	22	0.3	3.9	0.66	101	84.6719	51.542
2015	12	20	3	52	22	0.3	3.9	0.65	100.4	84.7375	51.5835

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	4	2	22	0.3	3.9	0.68	101.5	84.8032	53.2053
2015	12	20	4	12	22	0.3	3.9	0.64	103	84.7375	50.2675
2015	12	20	4	22	22	0.3	3.9	0.67	103.9	84.8032	52.1517
2015	12	20	4	32	22	0.3	3.9	0.64	105.1	84.8032	49.7812
2015	12	20	4	42	22	0.3	3.9	0.59	100.5	84.7375	46.8462
2015	12	20	4	52	22	0.3	3.9	0.61	104.1	84.7375	47.1094
2015	12	20	5	2	22	0.3	3.9	0.61	107	84.7375	46.583
2015	12	20	5	12	22	0.3	3.9	0.59	109	84.7375	45.0039
2015	12	20	5	22	22	0.3	3.9	0.63	101.7	84.8032	49.7812
2015	12	20	5	32	22	0.3	3.9	0.63	100.3	84.7375	49.478
2015	12	20	5	42	22	0.3	3.9	0.56	107	84.7375	43.1617
2015	12	20	5	52	22	0.3	3.9	0.53	108.3	84.7375	40.5299
2015	12	20	6	2	22	0.3	3.9	0.58	92.6	84.7375	46.8462
2015	12	20	6	12	22	0.3	3.9	0.55	103.2	84.8032	42.6696
2015	12	20	6	22	22	0.3	3.9	0.44	99.5	84.7375	34.4767
2015	12	20	6	32	22	0.3	3.9	0.65	101.7	84.8032	50.8347
2015	12	20	6	42	22	0.3	3.9	0.48	114	84.7375	35.5294
2015	12	20	6	52	22	0.3	3.9	0.54	111.4	84.7375	40.2667
2015	12	20	7	2	22	0.3	3.9	0.5	100.3	84.8032	39.2455
2015	12	20	7	12	22	0.3	3.9	0.52	135.5	84.7375	28.9499
2015	12	20	7	22	22	0.3	3.9	0.5	120.6	84.7375	34.7399
2015	12	20	7	32	22	0.3	3.9	0.51	89.6	84.7375	40.793
2015	12	20	7	42	22	0.3	3.9	0.57	95.9	84.8032	45.5669
2015	12	20	7	52	22	0.3	3.9	0.39	128.6	84.8032	24.7589
2015	12	20	8	2	22	0.3	3.9	0.5	124.7	84.8688	32.6868
2015	12	20	8	12	22	0.3	3.9	0.61	100.6	84.8032	47.9373
2015	12	20	8	22	22	0.3	3.9	0.74	114.6	84.8032	53.9953
2015	12	20	8	32	22	0.3	3.9	0.57	103	84.8032	44.5132
2015	12	20	8	42	22	0.3	3.9	0.9	92.7	84.8032	72.4327
2015	12	20	8	52	22	0.3	3.9	0.51	119.7	84.8032	35.5579
2015	12	20	9	2	22	0.3	3.9	0.48	68.7	84.8032	35.8212
2015	12	20	9	12	22	0.3	3.9	0.77	115.9	84.8688	55.8837
2015	12	20	9	22	22	0.3	3.9	0.5	97.2	84.8688	39.804
2015	12	20	9	32	22	0.3	3.9	0.68	92.2	84.8032	54.2586
2015	12	20	9	42	22	0.3	3.9	0.54	114.4	84.7375	39.4769
2015	12	20	9	52	22	0.3	3.9	0.69	137.1	84.7375	37.8977
2015	12	20	10	2	22	0.3	3.9	0.53	113.9	84.9344	38.7805
2015	12	20	10	12	22	0.3	3.9	0.68	112	84.8688	50.8752
2015	12	20	10	22	22	0.3	3.9	0.52	126.7	84.8032	33.1872
2015	12	20	10	32	22	0.3	3.9	0.42	118.8	84.8032	29.2364
2015	12	20	10	42	22	0.3	3.9	0.42	121.2	84.8032	28.7096
2015	12	20	10	52	22	0.3	3.9	0.52	97.3	84.7375	41.0559
2015	12	20	11	2	22	0.3	3.9	0.62	131.8	84.8032	36.8746
2015	12	20	11	12	22	0.3	3.9	0.52	121.8	84.8688	35.3225
2015	12	20	11	22	22	0.3	3.9	0.58	111.8	84.6719	43.3894
2015	12	20	11	32	22	0.3	3.9	0.55	121.4	84.6063	37.8367

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	11	42	22	0.3	3.9	0.54	127.1	84.5407	34.6558
2015	12	20	11	52	22	0.3	3.9	0.68	97.5	84.5407	53.8215
2015	12	20	12	2	22	0.3	3.9	0.7	96.5	84.6063	55.4413
2015	12	20	12	12	22	0.3	3.9	0.66	98.9	84.6063	52.2882
2015	12	20	12	22	22	0.3	3.9	0.52	124.5	84.5407	34.3931
2015	12	20	12	32	22	0.3	3.9	0.71	94.5	84.5407	56.9718
2015	12	20	12	42	22	0.3	3.9	0.66	99.7	84.6063	52.2881
2015	12	20	12	52	22	0.3	3.9	0.52	122.7	84.5407	35.1808
2015	12	20	13	2	22	0.3	3.9	0.65	103.1	84.5407	50.9333
2015	12	20	13	12	22	0.3	3.9	0.53	126.2	84.5407	34.3931
2015	12	20	13	22	22	0.3	3.9	0.54	117.3	84.5407	38.5938
2015	12	20	13	32	22	0.3	3.9	0.55	124.1	84.5407	36.4935
2015	12	20	13	42	22	0.3	3.9	0.64	103.4	84.5407	49.6207
2015	12	20	13	52	22	0.3	3.9	0.63	102.7	84.4751	48.7937
2015	12	20	14	2	22	0.3	3.9	0.61	102.3	84.4751	48.0068
2015	12	20	14	12	22	0.3	3.9	0.64	101.8	84.4095	50.3272
2015	12	20	14	22	22	0.3	3.9	0.6	104.6	84.3438	46.358
2015	12	20	14	32	22	0.3	3.9	0.63	102.4	84.3438	48.9771
2015	12	20	14	42	22	0.3	3.9	0.63	102.4	84.2782	48.9376
2015	12	20	14	52	22	0.3	3.9	0.65	101.7	84.2782	50.7695
2015	12	20	15	2	22	0.3	3.9	0.64	103.6	84.2126	49.6827
2015	12	20	15	12	22	0.3	3.9	0.65	103.6	84.2126	50.7287
2015	12	20	15	22	22	0.3	3.9	0.66	99.8	84.147	51.4715
2015	12	20	15	32	22	0.3	3.9	0.62	104.6	84.147	48.0749
2015	12	20	15	42	22	0.3	3.9	0.6	102	84.147	46.7685
2015	12	20	15	52	22	0.3	3.9	0.64	103.3	84.147	49.6426
2015	12	20	16	2	22	0.3	3.9	0.66	104.1	84.147	50.949
2015	12	20	16	12	22	0.3	3.9	0.64	103.5	84.147	49.9039
2015	12	20	16	22	22	0.3	3.9	0.65	102.8	84.147	50.4264
2015	12	20	16	32	22	0.3	3.9	0.63	102.7	84.147	48.5975
2015	12	20	16	42	22	0.3	3.9	0.64	103.6	84.147	49.6426
2015	12	20	16	52	22	0.3	3.9	0.62	101.6	84.147	48.3362
2015	12	20	17	2	22	0.3	3.9	0.62	101	84.0814	48.5582
2015	12	20	17	12	22	0.3	3.9	0.61	103	84.0814	47.5139
2015	12	20	17	22	22	0.3	3.9	0.66	104.2	84.147	50.6877
2015	12	20	17	32	22	0.3	3.9	0.66	100.9	84.0814	51.4299
2015	12	20	17	42	22	0.3	3.9	0.64	105.1	84.147	49.3814
2015	12	20	17	52	22	0.3	3.9	0.63	103.9	84.0814	48.5582
2015	12	20	18	2	22	0.3	3.9	0.63	105.4	84.0814	48.2971
2015	12	20	18	12	22	0.3	3.9	0.62	102.1	84.0814	48.5582
2015	12	20	18	22	22	0.3	3.9	0.64	102.3	84.0814	50.1246
2015	12	20	18	32	22	0.3	3.9	0.65	103.4	84.147	50.4265
2015	12	20	18	42	22	0.3	3.9	0.65	103.4	84.0814	50.3856
2015	12	20	18	52	22	0.3	3.9	0.64	100.7	84.0814	49.8635
2015	12	20	19	2	22	0.3	3.9	0.63	102.3	84.0814	49.0803
2015	12	20	19	12	22	0.3	3.9	0.63	103.2	84.0814	49.0803

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	19	22	22	0.3	3.9	0.66	102.3	84.0814	51.4299
2015	12	20	19	32	22	0.3	3.9	0.64	104.6	84.0814	49.0803
2015	12	20	19	42	22	0.3	3.9	0.66	102	84.0814	51.691
2015	12	20	19	52	22	0.3	3.9	0.65	102.3	84.0814	50.3856
2015	12	20	20	2	22	0.3	3.9	0.65	103.3	84.0814	50.6467
2015	12	20	20	12	22	0.3	3.9	0.65	101.7	84.0814	50.3856
2015	12	20	20	22	22	0.3	3.9	0.61	103	84.0814	47.5139
2015	12	20	20	32	22	0.3	3.9	0.64	103	84.0814	49.8635
2015	12	20	20	42	22	0.3	3.9	0.68	102.9	84.0814	52.4742
2015	12	20	20	52	22	0.3	3.9	0.63	100.8	84.0814	49.0803
2015	12	20	21	2	22	0.3	3.9	0.64	104.5	84.0814	49.6025
2015	12	20	21	12	22	0.3	3.9	0.64	103.5	84.0814	49.8635
2015	12	20	21	22	22	0.3	3.9	0.65	102	84.0814	50.3857
2015	12	20	21	32	22	0.3	3.9	0.66	103.8	84.0814	50.9078
2015	12	20	21	42	22	0.3	3.9	0.68	100.6	84.0814	53.2574
2015	12	20	21	52	22	0.3	3.9	0.6	108.1	84.0814	45.4254
2015	12	20	22	2	22	0.3	3.9	0.61	107.6	84.0814	46.2086
2015	12	20	22	12	22	0.3	3.9	0.57	113.2	84.0814	42.0315
2015	12	20	22	22	22	0.3	3.9	0.61	110	84.0814	45.9475
2015	12	20	22	32	22	0.3	3.9	0.56	116.3	84.0814	39.682
2015	12	20	22	42	22	0.3	3.9	0.65	98.1	84.0814	51.1689
2015	12	20	22	52	22	0.3	3.9	0.6	105.9	84.0814	45.6865
2015	12	20	23	2	22	0.3	3.9	0.57	114.1	84.0814	41.5094
2015	12	20	23	12	22	0.3	3.9	0.59	103.4	84.0814	45.9475
2015	12	20	23	22	22	0.3	3.9	0.66	99.8	84.0814	51.4299
2015	12	20	23	32	22	0.3	3.9	0.6	111.2	84.0814	44.3812
2015	12	20	23	42	22	0.3	3.9	0.58	113.2	84.0814	42.5537
2015	12	20	23	52	22	0.3	3.9	0.59	105.4	84.0814	45.4254
2015	12	21	0	2	22	0.3	3.9	0.58	109	84.0814	43.859
2015	12	21	0	12	22	0.3	3.9	0.59	110.7	84.0814	44.1201
2015	12	21	0	22	22	0.3	3.9	0.61	114.2	84.0814	44.1201
2015	12	21	0	32	22	0.3	3.9	0.48	103.8	84.0814	37.0713
2015	12	21	0	42	22	0.3	3.9	0.57	108	84.147	43.372
2015	12	21	0	52	22	0.3	3.9	0.61	107	84.147	46.2461
2015	12	21	1	2	22	0.3	3.9	0.59	110.7	84.147	43.6333
2015	12	21	1	12	22	0.3	3.9	0.51	112.3	84.147	37.6239
2015	12	21	1	22	22	0.3	3.9	0.56	108.1	84.0814	42.2926
2015	12	21	1	32	22	0.3	3.9	0.54	101.3	84.0814	41.7705
2015	12	21	1	42	22	0.3	3.9	0.54	114.6	84.0814	39.4209
2015	12	21	1	52	22	0.3	3.9	0.52	110.9	84.147	38.4077
2015	12	21	2	2	22	0.3	3.9	0.68	109.7	84.147	51.2103
2015	12	21	2	12	22	0.3	3.9	0.57	104	84.147	43.8946
2015	12	21	2	22	22	0.3	3.9	0.54	108.2	84.147	40.498
2015	12	21	2	32	22	0.3	3.9	0.63	100.8	84.147	49.3814
2015	12	21	2	42	22	0.3	3.9	0.6	95.7	84.147	47.2912
2015	12	21	2	52	22	0.3	3.9	0.51	94.4	84.147	40.7592

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	3	2	22	0.3	3.9	0.61	99.2	84.147	48.3363
2015	12	21	3	12	22	0.3	3.9	0.56	97.7	84.147	44.4171
2015	12	21	3	22	22	0.3	3.9	0.6	97.3	84.147	47.0299
2015	12	21	3	32	22	0.3	3.9	0.66	99.8	84.147	51.4716
2015	12	21	3	42	22	0.3	3.9	0.62	97.7	84.147	48.5975
2015	12	21	3	52	22	0.3	3.9	0.66	101.8	84.147	51.4716
2015	12	21	4	2	22	0.3	3.9	0.66	102.7	84.147	51.2103
2015	12	21	4	12	22	0.3	3.9	0.64	102.8	84.147	49.6427
2015	12	21	4	22	22	0.3	3.9	0.63	102.7	84.2126	48.6369
2015	12	21	4	32	22	0.3	3.9	0.63	101.4	84.2126	49.1599
2015	12	21	4	42	22	0.3	3.9	0.64	101.8	84.2782	50.2464
2015	12	21	4	52	22	0.3	3.9	0.64	103.7	84.2782	49.4613
2015	12	21	5	2	22	0.3	3.9	0.62	105.3	84.3438	47.9298
2015	12	21	5	12	22	0.3	3.9	0.59	108.3	84.3438	45.0488
2015	12	21	5	22	22	0.3	3.9	0.59	103.9	84.4095	45.6094
2015	12	21	5	32	22	0.3	3.9	0.59	106.1	84.4095	45.3473
2015	12	21	5	42	22	0.3	3.9	0.57	103.4	84.4095	44.0367
2015	12	21	5	52	22	0.3	3.9	0.53	111.1	84.4095	39.3185
2015	12	21	6	2	22	0.3	3.9	0.6	104.3	84.4095	46.3958
2015	12	21	6	12	22	0.3	3.9	0.55	113.1	84.4095	40.6291
2015	12	21	6	22	22	0.3	3.9	0.55	115.3	84.4751	39.8749
2015	12	21	6	32	22	0.3	3.9	0.6	101.9	84.4751	47.2203
2015	12	21	6	42	22	0.3	3.9	0.57	110	84.4751	42.4982
2015	12	21	6	52	22	0.3	3.9	0.68	108.3	84.4751	51.4176
2015	12	21	7	2	22	0.3	3.9	0.55	78	84.4751	43.2852
2015	12	21	7	12	22	0.3	3.9	0.66	97.1	84.5407	52.7718
2015	12	21	7	22	22	0.3	3.9	0.36	115.9	84.5407	25.9921
2015	12	21	7	32	22	0.3	3.9	0.49	100.7	84.6063	38.8881
2015	12	21	7	42	22	0.3	3.9	0.59	103.6	84.6063	45.7198
2015	12	21	7	52	22	0.3	3.9	0.53	94.6	84.6719	42.0751
2015	12	21	8	2	22	0.3	3.9	0.54	107.9	84.6719	41.5491
2015	12	21	8	12	22	0.3	3.9	0.53	104.5	84.6719	40.7602
2015	12	21	8	22	22	0.3	3.9	0.35	90	84.6719	28.1377
2015	12	21	8	32	22	0.3	3.9	0.56	100.1	84.7375	44.4775
2015	12	21	8	42	22	0.3	3.9	0.67	101.8	84.7375	52.8992
2015	12	21	8	52	22	0.3	3.9	0.58	103.8	84.8032	45.0398
2015	12	21	9	2	22	0.3	3.9	0.35	83.5	84.8688	27.6782
2015	12	21	9	12	22	0.3	3.9	0.42	105.6	84.8032	32.1337
2015	12	21	9	22	22	0.3	3.9	0.73	96.2	84.8688	57.9927
2015	12	21	9	32	22	0.3	3.9	0.9	122.1	84.8032	61.3702
2015	12	21	9	42	22	0.3	3.9	0.89	106	84.8032	68.7452
2015	12	21	9	52	22	0.3	3.9	0.73	112.2	84.8032	54.2586
2015	12	21	10	2	22	0.3	3.9	0.57	117.5	84.8032	40.5622
2015	12	21	10	12	22	0.3	3.9	0.87	100.9	84.8032	68.2183
2015	12	21	10	22	22	0.3	3.9	0.54	78.3	84.8688	42.1764
2015	12	21	10	32	22	0.3	3.9	0.45	93.8	84.8688	36.1135

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	10	42	22	0.3	3.9	0.32	70.3	84.8688	24.2514
2015	12	21	10	52	22	0.3	3.9	0.56	112.2	84.8688	41.9127
2015	12	21	11	2	22	0.3	3.9	0.52	91.5	84.9344	41.4187
2015	12	21	11	12	22	0.3	3.9	0.68	97.5	84.8688	54.3021
2015	12	21	11	22	22	0.3	3.9	0.52	110.3	84.8688	39.2767
2015	12	21	11	32	22	0.3	3.9	0.52	114.8	84.8688	38.2223
2015	12	21	11	42	22	0.3	3.9	0.36	98.4	84.8688	28.469
2015	12	21	11	52	22	0.3	3.9	0.48	111.5	84.8032	36.0845
2015	12	21	12	2	22	0.3	3.9	0.5	108	84.7375	38.161
2015	12	21	12	12	22	0.3	3.9	0.45	93.8	84.7375	36.0555
2015	12	21	12	22	22	0.3	3.9	0.51	108.9	84.7375	38.4242
2015	12	21	12	32	22	0.3	3.9	0.67	118.1	84.6719	47.3342
2015	12	21	12	42	22	0.3	3.9	0.78	113.5	84.6719	57.327
2015	12	21	12	52	22	0.3	3.9	0.54	96.6	84.6719	42.8638
2015	12	21	13	2	22	0.3	3.9	0.52	114.8	84.6063	37.5742
2015	12	21	13	12	22	0.3	3.9	0.67	105.3	84.6063	51.763
2015	12	21	13	22	22	0.3	3.9	0.67	98.1	84.6063	53.3396
2015	12	21	13	32	22	0.3	3.9	0.59	104.1	84.6063	45.9824
2015	12	21	13	42	22	0.3	3.9	0.71	95.8	84.6063	56.4927
2015	12	21	13	52	22	0.3	3.9	0.55	117.3	84.6063	39.1507
2015	12	21	14	2	22	0.3	3.9	0.55	128.4	84.6063	34.4211
2015	12	21	14	12	22	0.3	3.9	0.63	103.2	84.6063	49.3982
2015	12	21	14	22	22	0.3	3.9	0.6	113.4	84.6063	44.4059
2015	12	21	14	32	22	0.3	3.9	0.59	119	84.6063	41.2528
2015	12	21	14	42	22	0.3	3.9	0.6	111.1	84.6063	44.9314
2015	12	21	14	52	22	0.3	3.9	0.54	136	84.6063	29.9543
2015	12	21	15	2	22	0.3	3.9	0.56	123.7	84.6063	37.0487
2015	12	21	15	12	22	0.3	3.9	0.58	115.3	84.5407	42.2698
2015	12	21	15	22	22	0.3	3.9	0.58	122.2	84.6063	39.1508
2015	12	21	15	32	22	0.3	3.9	0.67	104.2	84.5407	51.7215
2015	12	21	15	42	22	0.3	3.9	0.58	115.1	84.5407	42.0073
2015	12	21	15	52	22	0.3	3.9	0.61	113.9	84.5407	44.3702
2015	12	21	16	2	22	0.3	3.9	0.63	100.1	84.5407	49.8837
2015	12	21	16	12	22	0.3	3.9	0.55	124.7	84.5407	35.9688
2015	12	21	16	22	22	0.3	3.9	0.53	123.6	84.5407	35.1811
2015	12	21	16	32	22	0.3	3.9	0.61	109	84.5407	46.4706
2015	12	21	16	42	22	0.3	3.9	0.64	107	84.5407	48.8336
2015	12	21	16	52	22	0.3	3.9	0.6	111.9	84.5407	44.3703
2015	12	21	17	2	22	0.3	3.9	0.63	109.4	84.5407	47.7834
2015	12	21	17	12	22	0.3	3.9	0.63	103	84.5407	48.8336
2015	12	21	17	22	22	0.3	3.9	0.62	106.4	84.5407	47.2583
2015	12	21	17	32	22	0.3	3.9	0.59	114	84.5407	43.0576
2015	12	21	17	42	22	0.3	3.9	0.63	105.6	84.5407	48.8336
2015	12	21	17	52	22	0.3	3.9	0.67	103.2	84.5407	52.5092
2015	12	21	18	2	22	0.3	3.9	0.64	112	84.6063	47.5591
2015	12	21	18	12	22	0.3	3.9	0.58	116.4	84.5407	41.2197

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	18	22	22	0.3	3.9	0.65	101.4	84.6063	50.975
2015	12	21	18	32	22	0.3	3.9	0.63	109.5	84.6063	47.5591
2015	12	21	18	42	22	0.3	3.9	0.63	112.2	84.6063	47.0336
2015	12	21	18	52	22	0.3	3.9	0.59	113.7	84.6063	43.6178
2015	12	21	19	2	22	0.3	3.9	0.59	124	84.6063	38.8881
2015	12	21	19	12	22	0.3	3.9	0.59	115.6	84.6063	42.8295
2015	12	21	19	22	22	0.3	3.9	0.67	100.9	84.6063	53.077
2015	12	21	19	32	22	0.3	3.9	0.67	101.9	84.6063	52.2887
2015	12	21	19	42	22	0.3	3.9	0.63	111.1	84.6063	47.0336
2015	12	21	19	52	22	0.3	3.9	0.68	102	84.6063	53.3398
2015	12	21	20	2	22	0.3	3.9	0.58	112.1	84.6063	43.355
2015	12	21	20	12	22	0.3	3.9	0.59	109.1	84.6063	44.6688
2015	12	21	20	22	22	0.3	3.9	0.59	111.3	84.6063	43.8805
2015	12	21	20	32	22	0.3	3.9	0.6	117	84.6063	42.8295
2015	12	21	20	42	22	0.3	3.9	0.59	113.4	84.6063	43.0922
2015	12	21	20	52	22	0.3	3.9	0.66	106.5	84.6063	50.7122
2015	12	21	21	2	22	0.3	3.9	0.66	106.5	84.6063	50.4494
2015	12	21	21	12	22	0.3	3.9	0.6	112.3	84.6063	44.1433
2015	12	21	21	22	22	0.3	3.9	0.64	107.9	84.6063	48.8729
2015	12	21	21	32	22	0.3	3.9	0.6	114.3	84.6063	43.6177
2015	12	21	21	42	22	0.3	3.9	0.62	103.9	84.6063	47.8218
2015	12	21	21	52	22	0.3	3.9	0.62	110.4	84.6063	46.5081
2015	12	21	22	2	22	0.3	3.9	0.57	113.6	84.6063	42.0412
2015	12	21	22	12	22	0.3	3.9	0.66	105.2	84.6063	51.2377
2015	12	21	22	22	22	0.3	3.9	0.63	107.4	84.6719	47.8603
2015	12	21	22	32	22	0.3	3.9	0.63	111	84.6719	47.3344
2015	12	21	22	42	22	0.3	3.9	0.64	108.2	84.6719	48.6492
2015	12	21	22	52	22	0.3	3.9	0.62	112.5	84.6719	45.7566
2015	12	21	23	2	22	0.3	3.9	0.6	108.8	84.6719	45.4936
2015	12	21	23	12	22	0.3	3.9	0.67	103.7	84.6719	51.8049
2015	12	21	23	22	22	0.3	3.9	0.64	109.6	84.6719	48.6492
2015	12	21	23	32	22	0.3	3.9	0.59	106.3	84.6719	45.7566
2015	12	21	23	42	22	0.3	3.9	0.64	108.3	84.6719	48.3863
2015	12	21	23	52	22	0.3	3.9	0.63	108.4	84.6719	48.1233
2015	12	22	0	2	22	0.3	3.9	0.64	105.4	84.6719	49.7011
2015	12	22	0	12	22	0.3	3.9	0.6	105.8	84.6719	46.5455
2015	12	22	0	22	22	0.3	3.9	0.63	108.6	84.6719	47.5973
2015	12	22	0	32	22	0.3	3.9	0.64	106.7	84.6719	49.1751
2015	12	22	0	42	22	0.3	3.9	0.62	108.9	84.6719	46.8084
2015	12	22	0	52	22	0.3	3.9	0.56	111.6	84.6719	41.812
2015	12	22	1	2	22	0.3	3.9	0.66	99.7	84.6719	52.0678
2015	12	22	1	12	22	0.3	3.9	0.66	105.4	84.6719	50.753
2015	12	22	1	22	22	0.3	3.9	0.62	105.4	84.6719	47.8603
2015	12	22	1	32	22	0.3	3.9	0.6	104.5	84.6719	46.8084
2015	12	22	1	42	22	0.3	3.9	0.63	107.3	84.6719	48.1232
2015	12	22	1	52	22	0.3	3.9	0.64	105.1	84.6719	49.7011

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	2	2	22	0.3	3.9	0.63	105	84.6719	48.9121
2015	12	22	2	12	22	0.3	3.9	0.63	105	84.6719	48.9121
2015	12	22	2	22	22	0.3	3.9	0.66	104.3	84.7375	51.5833
2015	12	22	2	32	22	0.3	3.9	0.64	107.3	84.6719	48.9121
2015	12	22	2	42	22	0.3	3.9	0.65	104.3	84.6719	50.4899
2015	12	22	2	52	22	0.3	3.9	0.65	103.2	84.6719	50.4899
2015	12	22	3	2	22	0.3	3.9	0.66	101.7	84.6719	52.0677
2015	12	22	3	12	22	0.3	3.9	0.63	104.8	84.7375	48.9515
2015	12	22	3	22	22	0.3	3.9	0.63	99	84.6719	49.964
2015	12	22	3	32	22	0.3	3.9	0.65	106.2	84.7375	49.741
2015	12	22	3	42	22	0.3	3.9	0.65	105.4	84.6719	50.4899
2015	12	22	3	52	22	0.3	3.9	0.64	105.3	84.7375	49.2146
2015	12	22	4	2	22	0.3	3.9	0.64	103.6	84.7375	50.0042
2015	12	22	4	12	22	0.3	3.9	0.66	105.3	84.7375	51.0569
2015	12	22	4	22	22	0.3	3.9	0.65	104	84.7375	50.5305
2015	12	22	4	32	22	0.3	3.9	0.66	105.4	84.7375	50.7937
2015	12	22	4	42	22	0.3	3.9	0.63	103.9	84.7375	48.9514
2015	12	22	4	52	22	0.3	3.9	0.62	103.7	84.7375	48.425
2015	12	22	5	2	22	0.3	3.9	0.63	105.9	84.7375	48.9514
2015	12	22	5	12	22	0.3	3.9	0.65	104.7	84.7375	50.2673
2015	12	22	5	22	22	0.3	3.9	0.66	102.9	84.7375	51.8464
2015	12	22	5	32	22	0.3	3.9	0.62	104.2	84.7375	47.8987
2015	12	22	5	42	22	0.3	3.9	0.61	104.4	84.7375	47.1091
2015	12	22	5	52	22	0.3	3.9	0.65	105.7	84.7375	50.5304
2015	12	22	6	2	22	0.3	3.9	0.64	105.8	84.7375	49.2145
2015	12	22	6	12	22	0.3	3.9	0.61	102.8	84.7375	47.3723
2015	12	22	6	22	22	0.3	3.9	0.63	105.9	84.7375	48.9513
2015	12	22	6	32	22	0.3	3.9	0.64	104.9	84.7375	49.4777
2015	12	22	6	42	22	0.3	3.9	0.65	105.7	84.7375	50.5304
2015	12	22	6	52	22	0.3	3.9	0.64	105.7	84.7375	49.7409
2015	12	22	7	2	22	0.3	3.9	0.62	107.2	84.7375	47.6354
2015	12	22	7	12	22	0.3	3.9	0.62	104.4	84.7375	48.1618
2015	12	22	7	22	22	0.3	3.9	0.62	105.7	84.7375	47.6354
2015	12	22	7	32	22	0.3	3.9	0.63	105	84.7375	48.9513
2015	12	22	7	42	22	0.3	3.9	0.64	105.7	84.7375	49.7408
2015	12	22	7	52	22	0.3	3.9	0.65	104.4	84.7375	50.2671
2015	12	22	8	2	22	0.3	3.9	0.62	105.3	84.8032	48.2004
2015	12	22	8	12	22	0.3	3.9	0.64	107	84.8032	48.9905
2015	12	22	8	22	22	0.3	3.9	0.64	106.1	84.8032	49.2539
2015	12	22	8	32	22	0.3	3.9	0.62	106.3	84.8032	47.6735
2015	12	22	8	42	22	0.3	3.9	0.62	105.7	84.8032	47.6735
2015	12	22	8	52	22	0.3	3.9	0.63	104.5	84.8032	48.9904
2015	12	22	9	2	22	0.3	3.9	0.65	104.9	84.8032	50.5708
2015	12	22	9	12	22	0.3	3.9	0.65	108.3	84.8688	49.2933
2015	12	22	9	22	22	0.3	3.9	0.62	104.5	84.8688	47.9752
2015	12	22	9	32	22	0.3	3.9	0.66	105.8	84.8688	51.402

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	9	42	22	0.3	3.9	0.63	103.6	84.8688	49.0296
2015	12	22	9	52	22	0.3	3.9	0.62	105.6	84.8688	48.2388
2015	12	22	10	2	22	0.3	3.9	0.6	102.5	84.9344	47.4859
2015	12	22	10	12	22	0.3	3.9	0.63	102.6	84.9344	49.5964
2015	12	22	10	22	22	0.3	3.9	0.63	104	84.8688	48.7659
2015	12	22	10	32	22	0.3	3.9	0.65	100.2	84.9344	51.1792
2015	12	22	10	42	22	0.3	3.9	0.67	99.9	84.9344	52.7619
2015	12	22	10	52	22	0.3	3.9	0.65	103.1	84.9344	50.9152
2015	12	22	11	2	22	0.3	3.9	0.65	103.5	85	50.692
2015	12	22	11	12	22	0.3	3.9	0.65	102.3	85	50.956
2015	12	22	11	22	22	0.3	3.9	0.64	104.7	85	50.1639
2015	12	22	11	32	22	0.3	3.9	0.66	102	85	52.276
2015	12	22	11	42	22	0.3	3.9	0.64	103	85	50.1639
2015	12	22	11	52	22	0.3	3.9	0.65	103.1	84.9344	50.9151
2015	12	22	12	2	22	0.3	3.9	0.64	101.6	85	50.1639
2015	12	22	12	12	22	0.3	3.9	0.66	102.1	85	51.748
2015	12	22	12	22	22	0.3	3.9	0.66	100	84.9344	52.2341
2015	12	22	12	32	22	0.3	3.9	0.65	102.9	84.9344	50.6513
2015	12	22	12	42	22	0.3	3.9	0.65	103.1	84.9344	51.1789
2015	12	22	12	52	22	0.3	3.9	0.62	101.7	84.9344	48.5407
2015	12	22	13	2	22	0.3	3.9	0.64	101.6	84.9344	50.1236
2015	12	22	13	12	22	0.3	3.9	0.62	101.7	84.9344	48.5408
2015	12	22	13	22	22	0.3	3.9	0.69	102.1	84.9344	54.0808
2015	12	22	13	32	22	0.3	3.9	0.64	101.3	84.9344	50.1236
2015	12	22	13	42	22	0.3	3.9	0.63	103	84.8688	49.0291
2015	12	22	13	52	22	0.3	3.9	0.65	100.7	84.8688	51.6652
2015	12	22	14	2	22	0.3	3.9	0.65	103.8	84.8032	50.5702
2015	12	22	14	12	22	0.3	3.9	0.64	104.5	84.8032	50.0434
2015	12	22	14	22	22	0.3	3.9	0.64	102.5	84.8032	49.7801
2015	12	22	14	32	22	0.3	3.9	0.65	102.2	84.7375	51.056
2015	12	22	14	42	22	0.3	3.9	0.66	102.1	84.7375	51.5823
2015	12	22	14	52	22	0.3	3.9	0.64	101.5	84.7375	50.2664
2015	12	22	15	2	22	0.3	3.9	0.63	99.9	84.7375	49.7401
2015	12	22	15	12	22	0.3	3.9	0.66	102.9	84.7375	51.5824
2015	12	22	15	22	22	0.3	3.9	0.67	101	84.8032	52.6774
2015	12	22	15	32	22	0.3	3.9	0.65	103.7	84.7375	50.7928
2015	12	22	15	42	22	0.3	3.9	0.65	102.2	84.8032	51.3605
2015	12	22	15	52	22	0.3	3.9	0.64	100.3	84.8032	50.8337
2015	12	22	16	2	22	0.3	3.9	0.69	101.8	84.7375	53.951
2015	12	22	16	12	22	0.3	3.9	0.63	103	84.7375	48.9506
2015	12	22	16	22	22	0.3	3.9	0.67	105.9	84.7375	51.5824
2015	12	22	16	32	22	0.3	3.9	0.63	100.4	84.7375	50.0033
2015	12	22	16	42	22	0.3	3.9	0.65	104.1	84.8032	50.3069
2015	12	22	16	52	22	0.3	3.9	0.66	103.8	84.7375	51.5824
2015	12	22	17	2	22	0.3	3.9	0.62	105.7	84.7375	47.6347
2015	12	22	17	12	22	0.3	3.9	0.65	101.1	84.8032	51.097

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	17	22	22	0.3	3.9	0.66	102.7	84.7375	51.3191
2015	12	22	17	32	22	0.3	3.9	0.63	104.2	84.8032	48.9899
2015	12	22	17	42	22	0.3	3.9	0.67	101	84.7375	52.635
2015	12	22	17	52	22	0.3	3.9	0.66	103.1	84.8032	51.8871
2015	12	22	18	2	22	0.3	3.9	0.66	100.8	84.7375	52.3718
2015	12	22	18	12	22	0.3	3.9	0.66	102.1	84.7375	51.5823
2015	12	22	18	22	22	0.3	3.9	0.61	101.4	84.7375	48.161
2015	12	22	18	32	22	0.3	3.9	0.64	101.6	84.7375	50.0032
2015	12	22	18	42	22	0.3	3.9	0.63	102.7	84.7375	49.2137
2015	12	22	18	52	22	0.3	3.9	0.61	101.9	84.8032	47.6729
2015	12	22	19	2	22	0.3	3.9	0.65	102.8	84.8032	50.8335
2015	12	22	19	12	22	0.3	3.9	0.64	101.9	84.7375	50.0032
2015	12	22	19	22	22	0.3	3.9	0.62	101.9	84.8032	48.7264
2015	12	22	19	32	22	0.3	3.9	0.61	100.9	84.8032	47.9362
2015	12	22	19	42	22	0.3	3.9	0.65	102.5	84.8032	51.0969
2015	12	22	19	52	22	0.3	3.9	0.63	103.9	84.8032	48.9898
2015	12	22	20	2	22	0.3	3.9	0.64	103.6	84.8032	50.0433
2015	12	22	20	12	22	0.3	3.9	0.64	101.6	84.8032	50.0433
2015	12	22	20	22	22	0.3	3.9	0.62	101.9	84.7375	48.6872
2015	12	22	20	32	22	0.3	3.9	0.66	102.6	84.8032	51.887
2015	12	22	20	42	22	0.3	3.9	0.62	102.1	84.8032	48.9897
2015	12	22	20	52	22	0.3	3.9	0.66	104.4	84.8032	51.3602
2015	12	22	21	2	22	0.3	3.9	0.64	101	84.8032	50.3066
2015	12	22	21	12	22	0.3	3.9	0.62	102.4	84.8032	48.9897
2015	12	22	21	22	22	0.3	3.9	0.63	104.1	84.8032	49.2531
2015	12	22	21	32	22	0.3	3.9	0.64	102.8	84.8688	50.0834
2015	12	22	21	42	22	0.3	3.9	0.62	103.2	84.8032	48.1995
2015	12	22	21	52	22	0.3	3.9	0.64	101.5	84.8032	50.57
2015	12	22	22	2	22	0.3	3.9	0.64	101.2	84.8688	50.6106
2015	12	22	22	12	22	0.3	3.9	0.66	102.4	84.8688	51.4014
2015	12	22	22	22	22	0.3	3.9	0.66	102.9	84.8688	51.665
2015	12	22	22	32	22	0.3	3.9	0.64	100.4	84.8032	50.3066
2015	12	22	22	42	22	0.3	3.9	0.62	102.4	84.8688	49.029
2015	12	22	22	52	22	0.3	3.9	0.66	102.7	84.8032	51.3601
2015	12	22	23	2	22	0.3	3.9	0.66	102.4	84.8688	51.4014
2015	12	22	23	12	22	0.3	3.9	0.64	103	84.8688	50.0834
2015	12	22	23	22	22	0.3	3.9	0.64	100	84.8688	50.8742
2015	12	22	23	32	22	0.3	3.9	0.64	99.1	84.8688	51.1377
2015	12	22	23	42	22	0.3	3.9	0.65	102.9	84.8688	50.6106
2015	12	22	23	52	22	0.3	3.9	0.65	102.9	84.8688	50.6106
2015	12	23	0	2	22	0.3	3.9	0.63	100.8	84.8688	49.8198
2015	12	23	0	12	22	0.3	3.9	0.66	102.4	84.8688	51.4014
2015	12	23	0	22	22	0.3	3.9	0.64	102.8	84.8688	50.0834
2015	12	23	0	32	22	0.3	3.9	0.63	101.7	84.8688	49.8198
2015	12	23	0	42	22	0.3	3.9	0.61	102.4	84.8688	47.9746
2015	12	23	0	52	22	0.3	3.9	0.63	100.7	84.8688	50.0834

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	1	2	22	0.3	3.9	0.66	100.8	84.8688	52.4558
2015	12	23	1	12	22	0.3	3.9	0.61	100.9	84.8688	47.9746
2015	12	23	1	22	22	0.3	3.9	0.64	102.1	84.8688	50.6106
2015	12	23	1	32	22	0.3	3.9	0.65	101.6	84.8688	51.4014
2015	12	23	1	42	22	0.3	3.9	0.63	100.3	84.8688	49.5562
2015	12	23	1	52	22	0.3	3.9	0.67	103.1	84.8688	52.1922
2015	12	23	2	2	22	0.3	3.9	0.67	101.6	84.8688	52.4558
2015	12	23	2	12	22	0.3	3.9	0.66	102.6	84.8688	51.9286
2015	12	23	2	22	22	0.3	3.9	0.66	103.5	84.8688	51.665
2015	12	23	2	32	22	0.3	3.9	0.6	100.9	84.9344	47.7493
2015	12	23	2	42	22	0.3	3.9	0.64	102.1	84.8688	50.6106
2015	12	23	2	52	22	0.3	3.9	0.64	102.5	84.8688	50.0834
2015	12	23	3	2	22	0.3	3.9	0.66	101.8	84.9344	51.9703
2015	12	23	3	12	22	0.3	3.9	0.63	101.1	84.9344	49.596
2015	12	23	3	22	22	0.3	3.9	0.67	101.6	84.9344	52.4979
2015	12	23	3	32	22	0.3	3.9	0.69	101.8	84.9344	54.0807
2015	12	23	3	42	22	0.3	3.9	0.63	102.9	84.9344	49.3322
2015	12	23	3	52	22	0.3	3.9	0.65	102.6	84.9344	50.915
2015	12	23	4	2	22	0.3	3.9	0.63	102.9	84.9344	49.3322
2015	12	23	4	12	22	0.3	3.9	0.66	102.7	84.9344	51.4426
2015	12	23	4	22	22	0.3	3.9	0.66	101.2	84.9344	51.9703
2015	12	23	4	32	22	0.3	3.9	0.67	101.6	84.9344	52.4979
2015	12	23	4	42	22	0.3	3.9	0.63	104.1	84.9344	49.3322
2015	12	23	4	52	22	0.3	3.9	0.68	104	84.9344	52.7617
2015	12	23	5	2	22	0.3	3.9	0.64	101.2	85	50.6919
2015	12	23	5	12	22	0.3	3.9	0.64	102.7	84.9344	50.3874
2015	12	23	5	22	22	0.3	3.9	0.63	100.8	85	49.8998
2015	12	23	5	32	22	0.3	3.9	0.62	102.6	85	48.5797
2015	12	23	5	42	22	0.3	3.9	0.64	100.4	85	50.4278
2015	12	23	5	52	22	0.3	3.9	0.65	99.7	85	51.2199
2015	12	23	6	2	22	0.3	3.9	0.66	104.6	85	51.7479
2015	12	23	6	12	22	0.3	3.9	0.65	102.8	85	51.2199
2015	12	23	6	22	22	0.3	3.9	0.66	103.8	85	51.7479
2015	12	23	6	32	22	0.3	3.9	0.65	101.3	85	51.4839
2015	12	23	6	42	22	0.3	3.9	0.63	102	85	49.6358
2015	12	23	6	52	22	0.3	3.9	0.66	103.5	85	51.7479
2015	12	23	7	2	22	0.3	3.9	0.66	102.6	85	52.012
2015	12	23	7	12	22	0.3	3.9	0.66	103.9	85	51.2199
2015	12	23	7	22	22	0.3	3.9	0.65	99.9	85	51.2199
2015	12	23	7	32	22	0.3	3.9	0.64	101.2	85	50.6918
2015	12	23	7	42	22	0.3	3.9	0.66	102.9	85	51.7479
2015	12	23	7	52	22	0.3	3.9	0.63	101.7	85.0656	49.6755
2015	12	23	8	2	22	0.3	3.9	0.64	102.8	85.0656	49.9397
2015	12	23	8	12	22	0.3	3.9	0.66	103.1	85.0656	52.0535
2015	12	23	8	22	22	0.3	3.9	0.66	102.9	85.0656	51.7893
2015	12	23	8	32	22	0.3	3.9	0.66	98.9	85.0656	52.5819

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	8	42	22	0.3	3.9	0.66	102.3	85.0656	52.3177
2015	12	23	8	52	22	0.3	3.9	0.64	100.7	85.1312	50.5084
2015	12	23	9	2	22	0.3	3.9	0.68	97.4	85.1312	54.7394
2015	12	23	9	12	22	0.3	3.9	0.7	99.1	85.1312	56.0616
2015	12	23	9	22	22	0.3	3.9	0.68	99.7	85.1312	53.946
2015	12	23	9	32	22	0.3	3.9	0.67	100.4	85.1312	53.1527
2015	12	23	9	42	22	0.3	3.9	0.67	101	85.1969	53.1951
2015	12	23	9	52	22	0.3	3.9	0.69	99.6	85.1312	54.4748
2015	12	23	10	2	22	0.3	3.9	0.68	98.8	85.1312	54.4747
2015	12	23	10	12	22	0.3	3.9	0.65	101.9	85.1312	51.3014
2015	12	23	10	22	22	0.3	3.9	0.63	100.1	85.1312	50.2436
2015	12	23	10	32	22	0.3	3.9	0.62	106.8	84.0814	47.5121
2015	12	23	10	42	22	0.3	3.9	0.57	107.3	82.7034	42.8547
2015	12	23	10	52	22	0.3	3.9	0.56	109.4	82.9003	41.6744
2015	12	23	11	2	22	0.3	3.9	0.58	107.1	82.9659	43.5108
2015	12	23	11	12	22	0.3	3.9	0.66	104.6	85.1312	51.8302
2015	12	23	11	22	22	0.3	3.9	0.67	103.4	85.1312	52.359
2015	12	23	11	32	22	0.3	3.9	0.67	105.7	85.1312	51.8301
2015	12	23	11	42	22	0.3	3.9	0.66	103	85.1312	51.5656
2015	12	23	11	52	22	0.3	3.9	0.66	104.7	85.1312	51.5656
2015	12	23	12	2	22	0.3	3.9	0.65	100.7	85.1312	51.5656
2015	12	23	12	12	22	0.3	3.9	0.65	102.8	85.1312	51.3012
2015	12	23	12	22	22	0.3	3.9	0.64	103.7	85.1312	49.979
2015	12	23	12	32	22	0.3	3.9	0.67	106.2	85.1312	51.83
2015	12	23	12	42	22	0.3	3.9	0.62	108.8	85.1312	47.3345
2015	12	23	12	52	22	0.3	3.9	0.63	106.4	85.1312	48.3923
2015	12	23	13	2	22	0.3	3.9	0.62	104.1	85.1312	48.3923
2015	12	23	13	12	22	0.3	3.9	0.62	100.9	85.1312	49.4501
2015	12	23	13	22	22	0.3	3.9	0.63	106.1	85.1312	48.6568
2015	12	23	13	32	22	0.3	3.9	0.61	107.6	85.1312	46.8057
2015	12	23	13	42	22	0.3	3.9	0.61	106.5	85.0656	47.2967
2015	12	23	13	52	22	0.3	3.9	0.62	107.2	85.0656	47.8253
2015	12	23	14	2	22	0.3	3.9	0.64	107.4	85.0656	48.8821
2015	12	23	14	12	22	0.3	3.9	0.62	107.2	85.0656	47.8252
2015	12	23	14	22	22	0.3	3.9	0.6	106.5	85.0656	46.5042
2015	12	23	14	32	22	0.3	3.9	0.64	105.7	85	49.6352
2015	12	23	14	42	22	0.3	3.9	0.61	107.6	85.0656	46.7684
2015	12	23	14	52	22	0.3	3.9	0.66	105	85	51.2193
2015	12	23	15	2	22	0.3	3.9	0.64	108.8	85.0656	48.8823
2015	12	23	15	12	22	0.3	3.9	0.63	106.1	85	48.5792
2015	12	23	15	22	22	0.3	3.9	0.64	106.3	85	49.6352
2015	12	23	15	32	22	0.3	3.9	0.64	109.6	85	48.3152
2015	12	23	15	42	22	0.3	3.9	0.61	107.7	85	46.4671
2015	12	23	15	52	22	0.3	3.9	0.63	105.5	85	48.5792
2015	12	23	16	2	22	0.3	3.9	0.64	103.7	85	49.8993
2015	12	23	16	12	22	0.3	3.9	0.65	105.4	85	50.6914

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	16	22	22	0.3	3.9	0.65	109.3	85	49.6353
2015	12	23	16	32	22	0.3	3.9	0.6	103.9	85	46.9951
2015	12	23	16	42	22	0.3	3.9	0.63	105.5	85	48.5792
2015	12	23	16	52	22	0.3	3.9	0.63	105.5	85	48.5792
2015	12	23	17	2	22	0.3	3.9	0.63	105.3	85	49.1072
2015	12	23	17	12	22	0.3	3.9	0.62	107.4	85	47.2591
2015	12	23	17	22	22	0.3	3.9	0.62	107.3	85	47.5231
2015	12	23	17	32	22	0.3	3.9	0.64	104	85.0656	49.9393
2015	12	23	17	42	22	0.3	3.9	0.63	105.5	85.0656	48.6181
2015	12	23	17	52	22	0.3	3.9	0.62	107.2	85.0656	47.8254
2015	12	23	18	2	22	0.3	3.9	0.63	105.4	85	48.8432
2015	12	23	18	12	22	0.3	3.9	0.62	105.4	85	48.0512
2015	12	23	18	22	22	0.3	3.9	0.64	106.3	85.0656	49.675
2015	12	23	18	32	22	0.3	3.9	0.66	101.5	85.0656	51.7889
2015	12	23	18	42	22	0.3	3.9	0.63	105.5	85.0656	48.6181
2015	12	23	18	52	22	0.3	3.9	0.63	105.3	85.0656	49.1466
2015	12	23	19	2	22	0.3	3.9	0.63	106.1	85.0656	48.6181
2015	12	23	19	12	22	0.3	3.9	0.62	105.9	85.0656	48.3539
2015	12	23	19	22	22	0.3	3.9	0.65	104.9	85.0656	50.7319
2015	12	23	19	32	22	0.3	3.9	0.66	105.4	85.0656	50.9961
2015	12	23	19	42	22	0.3	3.9	0.64	106	85.0656	49.675
2015	12	23	19	52	22	0.3	3.9	0.65	101.9	85.0656	51.2603
2015	12	23	20	2	22	0.3	3.9	0.65	101.6	85.0656	51.5246
2015	12	23	20	12	22	0.3	3.9	0.62	102	85.0656	48.6181
2015	12	23	20	22	22	0.3	3.9	0.67	107.2	85.0656	51.2603
2015	12	23	20	32	22	0.3	3.9	0.61	104.3	85.0656	47.8254
2015	12	23	20	42	22	0.3	3.9	0.63	104.5	85.0656	48.8823
2015	12	23	20	52	22	0.3	3.9	0.67	105.4	85.1312	51.8302
2015	12	23	21	2	22	0.3	3.9	0.65	105	85.1312	50.2436
2015	12	23	21	12	22	0.3	3.9	0.66	103.5	85.0656	51.7888
2015	12	23	21	22	22	0.3	3.9	0.66	103.2	85.0656	51.7888
2015	12	23	21	32	22	0.3	3.9	0.67	102.5	85.0656	52.5815
2015	12	23	21	42	22	0.3	3.9	0.66	103.6	85.1312	51.5658
2015	12	23	21	52	22	0.3	3.9	0.64	103.4	85.1312	49.9791
2015	12	23	22	2	22	0.3	3.9	0.63	103.3	85.1312	49.1858
2015	12	23	22	12	22	0.3	3.9	0.62	106	85.1312	47.8636
2015	12	23	22	22	22	0.3	3.9	0.64	103.3	85.1312	50.2436
2015	12	23	22	32	22	0.3	3.9	0.63	104.8	85.1312	49.1858
2015	12	23	22	42	22	0.3	3.9	0.61	103.4	85.1312	47.8636
2015	12	23	22	52	22	0.3	3.9	0.64	104.9	85.1312	49.7147
2015	12	23	23	2	22	0.3	3.9	0.62	103.2	85.1312	48.6569
2015	12	23	23	12	22	0.3	3.9	0.64	102.1	85.1312	50.508
2015	12	23	23	22	22	0.3	3.9	0.58	103.8	85.1969	45.2554
2015	12	23	23	32	22	0.3	3.9	0.64	104.3	85.1312	49.9791
2015	12	23	23	42	22	0.3	3.9	0.61	106.1	85.1312	47.5992
2015	12	23	23	52	22	0.3	3.9	0.67	106.9	85.1969	51.3424

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	0	2	22	0.3	3.9	0.64	102.5	85.1969	50.0191
2015	12	24	0	12	22	0.3	3.9	0.65	104.4	85.1969	50.5484
2015	12	24	0	22	22	0.3	3.9	0.62	104.3	85.1969	48.6959
2015	12	24	0	32	22	0.3	3.9	0.61	106.3	85.1969	47.108
2015	12	24	0	42	22	0.3	3.9	0.64	104	85.1969	49.7545
2015	12	24	0	52	22	0.3	3.9	0.64	104.6	85.1969	49.7545
2015	12	24	1	2	22	0.3	3.9	0.62	105.6	85.1969	48.4313
2015	12	24	1	12	22	0.3	3.9	0.65	105	85.1969	50.2838
2015	12	24	1	22	22	0.3	3.9	0.64	103.3	85.1969	50.2838
2015	12	24	1	32	22	0.3	3.9	0.64	105.1	85.1969	50.0192
2015	12	24	1	42	22	0.3	3.9	0.64	105.2	85.1969	49.7545
2015	12	24	1	52	22	0.3	3.9	0.63	107.7	85.1969	48.1666
2015	12	24	2	2	22	0.3	3.9	0.65	104.3	85.1969	50.8132
2015	12	24	2	12	22	0.3	3.9	0.66	108	85.1969	50.5485
2015	12	24	2	22	22	0.3	3.9	0.63	103.5	85.1969	49.4899
2015	12	24	2	32	22	0.3	3.9	0.65	104	85.1969	50.8132
2015	12	24	2	42	22	0.3	3.9	0.67	101.6	85.1969	52.9304
2015	12	24	2	52	22	0.3	3.9	0.65	104.6	85.1969	50.8132
2015	12	24	3	2	22	0.3	3.9	0.64	102.3	85.1969	50.8132
2015	12	24	3	12	22	0.3	3.9	0.68	103.8	85.1969	52.9305
2015	12	24	3	22	22	0.3	3.9	0.62	102.3	85.1969	48.696
2015	12	24	3	32	22	0.3	3.9	0.63	105.6	85.1969	49.2253
2015	12	24	3	42	22	0.3	3.9	0.66	102.4	85.1969	51.8719
2015	12	24	3	52	22	0.3	3.9	0.67	104.8	85.1969	52.1365
2015	12	24	4	2	22	0.3	3.9	0.67	104.6	85.1969	52.6658
2015	12	24	4	12	22	0.3	3.9	0.65	103.5	85.1969	50.8133
2015	12	24	4	22	22	0.3	3.9	0.62	105.7	85.1969	47.9021
2015	12	24	4	32	22	0.3	3.9	0.6	102.3	85.1969	47.3728
2015	12	24	4	42	22	0.3	3.9	0.64	106.3	85.1969	49.7547
2015	12	24	4	52	22	0.3	3.9	0.64	104	85.1969	50.0193
2015	12	24	5	2	22	0.3	3.9	0.62	103.5	85.1969	48.4314
2015	12	24	5	12	22	0.3	3.9	0.63	105.5	85.1969	48.6961
2015	12	24	5	22	22	0.3	3.9	0.66	103.8	85.1969	51.8719
2015	12	24	5	32	22	0.3	3.9	0.63	106	85.2625	48.9999
2015	12	24	5	42	22	0.3	3.9	0.63	106.4	85.2625	48.4702
2015	12	24	5	52	22	0.3	3.9	0.64	104.7	85.1969	50.284
2015	12	24	6	2	22	0.3	3.9	0.63	107.6	85.1969	48.4315
2015	12	24	6	12	22	0.3	3.9	0.61	105	85.1969	47.3729
2015	12	24	6	22	22	0.3	3.9	0.64	106.2	85.2625	49.2648
2015	12	24	6	32	22	0.3	3.9	0.64	107.8	85.2625	49.5297
2015	12	24	6	42	22	0.3	3.9	0.6	104.9	85.2625	46.881
2015	12	24	6	52	22	0.3	3.9	0.65	105.2	85.2625	50.854
2015	12	24	7	2	22	0.3	3.9	0.63	107.2	85.2625	48.7351
2015	12	24	7	12	22	0.3	3.9	0.61	105	85.2625	47.4108
2015	12	24	7	22	22	0.3	3.9	0.62	108	85.2625	47.4108
2015	12	24	7	32	22	0.3	3.9	0.62	106.2	85.2625	48.2054

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	7	42	22	0.3	3.9	0.63	103.5	85.2625	49.5297
2015	12	24	7	52	22	0.3	3.9	0.59	104.7	85.2625	46.3513
2015	12	24	8	2	22	0.3	3.9	0.66	107.1	85.2625	50.854
2015	12	24	8	12	22	0.3	3.9	0.64	103.1	85.2625	50.0594
2015	12	24	8	22	22	0.3	3.9	0.64	107.9	85.2625	49.2647
2015	12	24	8	32	22	0.3	3.9	0.61	107.5	85.3281	47.1835
2015	12	24	8	42	22	0.3	3.9	0.62	107.2	85.3281	47.9787
2015	12	24	8	52	22	0.3	3.9	0.65	108.1	85.3281	49.5691
2015	12	24	9	2	22	0.3	3.9	0.63	106.8	85.3281	49.0389
2015	12	24	9	12	22	0.3	3.9	0.63	107.2	85.3281	48.7738
2015	12	24	9	22	22	0.3	3.9	0.64	106.3	85.3281	49.8341
2015	12	24	9	32	22	0.3	3.9	0.64	107.7	85.3937	49.078
2015	12	24	9	42	22	0.3	3.9	0.62	108.8	85.3937	47.4862
2015	12	24	9	52	22	0.3	3.9	0.61	103.4	85.3937	48.0167
2015	12	24	10	2	22	0.3	3.9	0.64	106.3	85.3937	49.8737
2015	12	24	10	12	22	0.3	3.9	0.63	104.3	85.3937	49.0778
2015	12	24	10	22	22	0.3	3.9	0.64	106.9	85.3937	49.8736
2015	12	24	10	32	22	0.3	3.9	0.68	101.9	85.4593	54.1613
2015	12	24	10	42	22	0.3	3.9	0.71	102.4	85.3937	55.7099
2015	12	24	10	52	22	0.3	3.9	0.66	102.3	85.4593	52.3028
2015	12	24	11	2	22	0.3	3.9	0.67	101	85.4593	53.3648
2015	12	24	11	12	22	0.3	3.9	0.67	101.1	85.4593	52.8337
2015	12	24	11	22	22	0.3	3.9	0.68	103	85.5249	53.9387
2015	12	24	11	32	22	0.3	3.9	0.64	101	85.4593	50.4443
2015	12	24	11	42	22	0.3	3.9	0.68	104.8	85.4593	53.3647
2015	12	24	11	52	22	0.3	3.9	0.68	101.9	85.4593	54.1613
2015	12	24	12	2	22	0.3	3.9	0.69	99.6	85.4593	55.2232
2015	12	24	12	12	22	0.3	3.9	0.64	102.5	85.4593	50.1787
2015	12	24	12	22	22	0.3	3.9	0.64	102.8	85.5249	50.4844
2015	12	24	12	32	22	0.3	3.9	0.68	107.7	85.4593	52.3027
2015	12	24	12	42	22	0.3	3.9	0.63	105.3	85.4593	49.3823
2015	12	24	12	52	22	0.3	3.9	0.64	104.7	85.4593	50.4443
2015	12	24	13	2	22	0.3	3.9	0.65	106.2	85.4593	50.1788
2015	12	24	13	12	22	0.3	3.9	0.63	106.6	85.4593	49.1169
2015	12	24	13	22	22	0.3	3.9	0.63	103.7	85.4593	49.9134
2015	12	24	13	32	22	0.3	3.9	0.63	105.4	85.3937	49.0778
2015	12	24	13	42	22	0.3	3.9	0.64	104.8	85.3937	50.1389
2015	12	24	13	52	22	0.3	3.9	0.66	105.8	85.3937	51.4654
2015	12	24	14	2	22	0.3	3.9	0.66	101	85.4593	52.0374
2015	12	24	14	12	22	0.3	3.9	0.64	100.7	85.3937	50.6695
2015	12	24	14	22	22	0.3	3.9	0.66	101.8	85.3937	51.996
2015	12	24	14	32	22	0.3	3.9	0.64	102.3	85.3937	50.9349
2015	12	24	14	42	22	0.3	3.9	0.66	104.2	85.3937	51.4654
2015	12	24	14	52	22	0.3	3.9	0.65	102.2	85.3281	51.6895
2015	12	24	15	2	22	0.3	3.9	0.65	102.6	85.3937	51.2002
2015	12	24	15	12	22	0.3	3.9	0.66	102.3	85.3937	52.2613

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	15	22	22	0.3	3.9	0.66	102.9	85.3937	52.2613
2015	12	24	15	32	22	0.3	3.9	0.69	100.7	85.3937	54.6489
2015	12	24	15	42	22	0.3	3.9	0.66	102.6	85.3937	52.2613
2015	12	24	15	52	22	0.3	3.9	0.67	100.5	85.3937	53.0572
2015	12	24	16	2	22	0.3	3.9	0.68	103.3	85.3937	53.8531
2015	12	24	16	12	22	0.3	3.9	0.67	102.1	85.3937	53.0572
2015	12	24	16	22	22	0.3	3.9	0.63	104	85.3937	49.0779
2015	12	24	16	32	22	0.3	3.9	0.68	99.2	85.3281	54.0752
2015	12	24	16	42	22	0.3	3.9	0.67	102.8	85.3281	52.4848
2015	12	24	16	52	22	0.3	3.9	0.68	103.8	85.3937	53.0572
2015	12	24	17	2	22	0.3	3.9	0.64	103.4	85.3937	50.1391
2015	12	24	17	12	22	0.3	3.9	0.66	105.6	85.3937	51.4655
2015	12	24	17	22	22	0.3	3.9	0.65	105.3	85.3937	50.4044
2015	12	24	17	32	22	0.3	3.9	0.64	106.2	85.3281	49.3038
2015	12	24	17	42	22	0.3	3.9	0.64	104.7	85.3937	50.4043
2015	12	24	17	52	22	0.3	3.9	0.64	106.3	85.3937	49.8738
2015	12	24	18	2	22	0.3	3.9	0.65	104	85.3937	50.9349
2015	12	24	18	12	22	0.3	3.9	0.66	103.8	85.3937	51.7308
2015	12	24	18	22	22	0.3	3.9	0.64	107.9	85.3281	49.3038
2015	12	24	18	32	22	0.3	3.9	0.64	106	85.3281	49.834
2015	12	24	18	42	22	0.3	3.9	0.64	99.8	85.3937	50.6696
2015	12	24	18	52	22	0.3	3.9	0.67	101	85.3937	53.3225
2015	12	24	19	2	22	0.3	3.9	0.65	101.1	85.3937	51.2002
2015	12	24	19	12	22	0.3	3.9	0.66	103.8	85.3937	51.7307
2015	12	24	19	22	22	0.3	3.9	0.68	101.9	85.4593	54.1615
2015	12	24	19	32	22	0.3	3.9	0.69	99.9	85.4593	54.9579
2015	12	24	19	42	22	0.3	3.9	0.68	101.7	85.3281	53.8101
2015	12	24	19	52	22	0.3	3.9	0.64	102.1	85.3281	50.6292
2015	12	24	20	2	22	0.3	3.9	0.62	100.9	85.3281	49.5689
2015	12	24	20	12	22	0.3	3.9	0.63	102.1	85.3281	49.5689
2015	12	24	20	22	22	0.3	3.9	0.64	102.5	85.3937	50.4043
2015	12	24	20	32	22	0.3	3.9	0.67	103.3	85.3937	52.7919
2015	12	24	20	42	22	0.3	3.9	0.64	101.5	85.3937	50.9348
2015	12	24	20	52	22	0.3	3.9	0.66	101.8	85.3937	51.996
2015	12	24	21	2	22	0.3	3.9	0.67	104.9	85.3937	51.996
2015	12	24	21	12	22	0.3	3.9	0.62	106.2	85.3937	48.282
2015	12	24	21	22	22	0.3	3.9	0.65	103.2	85.3937	50.9348
2015	12	24	21	32	22	0.3	3.9	0.63	103.3	85.3937	49.3431
2015	12	24	21	42	22	0.3	3.9	0.63	104.8	85.3937	49.0778
2015	12	24	21	52	22	0.3	3.9	0.6	103.6	85.3937	47.2208
2015	12	24	22	2	22	0.3	3.9	0.64	104.2	85.3937	50.4043
2015	12	24	22	12	22	0.3	3.9	0.62	106	85.3937	48.0167
2015	12	24	22	22	22	0.3	3.9	0.63	104.4	85.3937	49.6084
2015	12	24	22	32	22	0.3	3.9	0.65	102.6	85.3937	51.2001
2015	12	24	22	42	22	0.3	3.9	0.64	103.4	85.3937	50.139
2015	12	24	22	52	22	0.3	3.9	0.66	103	85.3937	51.7307

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	23	2	22	0.3	3.9	0.64	105.2	85.3937	49.8737
2015	12	24	23	12	22	0.3	3.9	0.64	107.2	85.3937	49.6084
2015	12	24	23	22	22	0.3	3.9	0.65	101.7	85.3937	51.4654
2015	12	24	23	32	22	0.3	3.9	0.64	105.5	85.3937	49.6084
2015	12	24	23	42	22	0.3	3.9	0.64	104.7	85.3937	50.4043
2015	12	24	23	52	22	0.3	3.9	0.66	105.4	85.3937	51.2001
2015	12	25	0	2	22	0.3	3.9	0.64	106.5	85.3937	49.3432
2015	12	25	0	12	22	0.3	3.9	0.62	105.9	85.3937	48.5473
2015	12	25	0	22	22	0.3	3.9	0.65	103.8	85.3937	50.9349
2015	12	25	0	32	22	0.3	3.9	0.63	106.3	85.3937	49.0779
2015	12	25	0	42	22	0.3	3.9	0.64	106.6	85.3937	49.8738
2015	12	25	0	52	22	0.3	3.9	0.63	103.9	85.3937	49.3432
2015	12	25	1	2	22	0.3	3.9	0.64	106	85.3937	49.8738
2015	12	25	1	12	22	0.3	3.9	0.64	107	85.3937	49.3432
2015	12	25	1	22	22	0.3	3.9	0.63	108.9	85.3937	48.0168
2015	12	25	1	32	22	0.3	3.9	0.64	106.7	85.3937	49.6085
2015	12	25	1	42	22	0.3	3.9	0.63	106	85.3937	49.0779
2015	12	25	1	52	22	0.3	3.9	0.61	109.4	85.3937	46.6904
2015	12	25	2	2	22	0.3	3.9	0.65	108	85.3281	49.834
2015	12	25	2	12	22	0.3	3.9	0.63	107.7	85.3937	48.2821
2015	12	25	2	22	22	0.3	3.9	0.62	106.6	85.3937	48.0168
2015	12	25	2	32	22	0.3	3.9	0.62	109.6	85.3281	46.9182
2015	12	25	2	42	22	0.3	3.9	0.63	106.8	85.3281	49.0388
2015	12	25	2	52	22	0.3	3.9	0.61	108.2	85.3281	46.6532
2015	12	25	3	2	22	0.3	3.9	0.62	106.6	85.3281	47.9786
2015	12	25	3	12	22	0.3	3.9	0.62	107.4	85.3281	47.4484
2015	12	25	3	22	22	0.3	3.9	0.64	107.4	85.3281	49.0389
2015	12	25	3	32	22	0.3	3.9	0.65	107.3	85.3937	50.1392
2015	12	25	3	42	22	0.3	3.9	0.65	106.8	85.3937	50.1392
2015	12	25	3	52	22	0.3	3.9	0.66	105.9	85.3281	51.1595
2015	12	25	4	2	22	0.3	3.9	0.63	104.5	85.3937	49.0781
2015	12	25	4	12	22	0.3	3.9	0.63	107.2	85.3281	48.7738
2015	12	25	4	22	22	0.3	3.9	0.61	107.1	85.3281	47.4485
2015	12	25	4	32	22	0.3	3.9	0.67	105.3	85.3281	52.2198
2015	12	25	4	42	22	0.3	3.9	0.64	108.7	85.3281	49.304
2015	12	25	4	52	22	0.3	3.9	0.67	108.3	85.3281	51.1596
2015	12	25	5	2	22	0.3	3.9	0.66	107.1	85.3281	50.8945
2015	12	25	5	12	22	0.3	3.9	0.62	107.1	85.3281	48.2437
2015	12	25	5	22	22	0.3	3.9	0.61	108.6	85.3281	46.3882
2015	12	25	5	32	22	0.3	3.9	0.62	107.6	85.3281	47.7136
2015	12	25	5	42	22	0.3	3.9	0.63	106.4	85.3281	48.7739
2015	12	25	5	52	22	0.3	3.9	0.62	105.6	85.3281	48.5089
2015	12	25	6	2	22	0.3	3.9	0.62	106.6	85.3281	47.9787
2015	12	25	6	12	22	0.3	3.9	0.63	107.2	85.3281	48.7739
2015	12	25	6	22	22	0.3	3.9	0.62	107.9	85.3281	47.7136
2015	12	25	6	32	22	0.3	3.9	0.64	107.2	85.3281	49.5692

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	6	42	22	0.3	3.9	0.62	107.2	85.3281	47.9787
2015	12	25	6	52	22	0.3	3.9	0.62	107.9	85.3281	47.7137
2015	12	25	7	2	22	0.3	3.9	0.64	107.7	85.3281	49.039
2015	12	25	7	12	22	0.3	3.9	0.62	110.6	85.3281	47.1835
2015	12	25	7	22	22	0.3	3.9	0.66	107.7	85.3281	50.6295
2015	12	25	7	32	22	0.3	3.9	0.65	108.5	85.3281	49.8343
2015	12	25	7	42	22	0.3	3.9	0.63	106.1	85.3281	48.774
2015	12	25	7	52	22	0.3	3.9	0.63	110.8	85.3281	47.4486
2015	12	25	8	2	22	0.3	3.9	0.6	108.4	85.3281	46.1232
2015	12	25	8	12	22	0.3	3.9	0.64	107.6	85.3281	49.3041
2015	12	25	8	22	22	0.3	3.9	0.62	108	85.3281	47.4485
2015	12	25	8	32	22	0.3	3.9	0.65	108.6	85.3281	49.5691
2015	12	25	8	42	22	0.3	3.9	0.63	109.8	85.3281	47.9786
2015	12	25	8	52	22	0.3	3.9	0.63	109.3	85.3937	47.7516
2015	12	25	9	2	22	0.3	3.9	0.63	109.3	85.3281	47.7135
2015	12	25	9	12	22	0.3	3.9	0.59	108.2	85.3937	45.0987
2015	12	25	9	22	22	0.3	3.9	0.6	109.6	85.3937	45.364
2015	12	25	9	32	22	0.3	3.9	0.59	110.6	85.3937	44.5681
2015	12	25	9	42	22	0.3	3.9	0.61	110.4	85.3937	46.425
2015	12	25	9	52	22	0.3	3.9	0.6	111.8	85.3937	45.0986
2015	12	25	10	2	22	0.3	3.9	0.63	110.2	85.3937	47.4861
2015	12	25	10	12	22	0.3	3.9	0.64	110.8	85.3937	48.282
2015	12	25	10	22	22	0.3	3.9	0.63	111.6	85.3937	47.4861
2015	12	25	10	32	22	0.3	3.9	0.63	109	85.3937	48.5472
2015	12	25	10	42	22	0.3	3.9	0.62	109.9	85.4593	46.9929
2015	12	25	10	52	22	0.3	3.9	0.61	113.8	85.4593	45.1344
2015	12	25	11	2	22	0.3	3.9	0.63	111	85.4593	47.7894
2015	12	25	11	12	22	0.3	3.9	0.62	111.2	85.4593	46.4619
2015	12	25	11	22	22	0.3	3.9	0.62	110.4	85.4593	46.9929
2015	12	25	11	32	22	0.3	3.9	0.59	110	85.4593	45.1344
2015	12	25	11	42	22	0.3	3.9	0.61	109.9	85.4593	46.1963
2015	12	25	11	52	22	0.3	3.9	0.58	110.9	85.4593	43.8069
2015	12	25	12	2	22	0.3	3.9	0.6	112.9	85.4593	44.6034
2015	12	25	12	12	22	0.3	3.9	0.63	111	85.4593	47.7893
2015	12	25	12	22	22	0.3	3.9	0.63	103.2	85.4593	49.9133
2015	12	25	12	32	22	0.3	3.9	0.66	104.6	85.4593	52.0372
2015	12	25	12	42	22	0.3	3.9	0.67	99.6	85.4593	53.0992
2015	12	25	12	52	22	0.3	3.9	0.65	102.2	85.4593	51.7718
2015	12	25	13	2	22	0.3	3.9	0.69	101.8	85.3937	54.3834
2015	12	25	13	12	22	0.3	3.9	0.65	103.7	85.3937	51.2
2015	12	25	13	22	22	0.3	3.9	0.63	103	85.4593	49.3823
2015	12	25	13	32	22	0.3	3.9	0.66	103.9	85.3937	51.4653
2015	12	25	13	42	22	0.3	3.9	0.65	103.6	85.3937	51.4654
2015	12	25	13	52	22	0.3	3.9	0.68	103.8	85.3937	53.0571
2015	12	25	14	2	22	0.3	3.9	0.62	101.5	85.3937	49.3431
2015	12	25	14	12	22	0.3	3.9	0.67	101.5	85.3281	53.2799

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	14	22	22	0.3	3.9	0.67	103.5	85.3281	53.0148
2015	12	25	14	32	22	0.3	3.9	0.67	101	85.3281	53.28
2015	12	25	14	42	22	0.3	3.9	0.67	104.2	85.3281	52.4847
2015	12	25	14	52	22	0.3	3.9	0.66	102.4	85.2625	51.9132
2015	12	25	15	2	22	0.3	3.9	0.66	102.1	85.3281	51.9547
2015	12	25	15	12	22	0.3	3.9	0.69	103.8	85.2625	53.7673
2015	12	25	15	22	22	0.3	3.9	0.69	103.7	85.2625	54.297
2015	12	25	15	32	22	0.3	3.9	0.65	102.6	85.2625	51.1187
2015	12	25	15	42	22	0.3	3.9	0.61	103.6	85.2625	48.2052
2015	12	25	15	52	22	0.3	3.9	0.62	106.7	85.2625	47.6755
2015	12	25	16	2	22	0.3	3.9	0.62	107.5	85.2625	47.9404
2015	12	25	16	12	22	0.3	3.9	0.61	108.8	85.2625	46.616
2015	12	25	16	22	22	0.3	3.9	0.62	108.1	85.2625	47.6755
2015	12	25	16	32	22	0.3	3.9	0.65	100.7	85.2625	51.6485
2015	12	25	16	42	22	0.3	3.9	0.67	102.7	85.1969	52.9305
2015	12	25	16	52	22	0.3	3.9	0.65	102.6	85.1969	50.8133
2015	12	25	17	2	22	0.3	3.9	0.61	105.5	85.1969	47.6374
2015	12	25	17	12	22	0.3	3.9	0.62	110.8	85.1969	46.5788
2015	12	25	17	22	22	0.3	3.9	0.63	108.5	85.1969	48.1668
2015	12	25	17	32	22	0.3	3.9	0.65	109.8	85.1969	49.2254
2015	12	25	17	42	22	0.3	3.9	0.63	107.6	85.1969	48.4314
2015	12	25	17	52	22	0.3	3.9	0.6	108.3	85.1969	46.3142
2015	12	25	18	2	22	0.3	3.9	0.66	101.4	85.1969	52.4012
2015	12	25	18	12	22	0.3	3.9	0.64	104.7	85.1969	50.284
2015	12	25	18	22	22	0.3	3.9	0.67	101.1	85.1312	52.6238
2015	12	25	18	32	22	0.3	3.9	0.65	102.8	85.1969	51.3426
2015	12	25	18	42	22	0.3	3.9	0.6	99.7	85.1312	47.8638
2015	12	25	18	52	22	0.3	3.9	0.67	102.7	85.1312	52.6238
2015	12	25	19	2	22	0.3	3.9	0.71	101.3	85.1312	55.7971
2015	12	25	19	12	22	0.3	3.9	0.68	101.9	85.1312	53.946
2015	12	25	19	22	22	0.3	3.9	0.68	102.6	85.1312	53.1526
2015	12	25	19	32	22	0.3	3.9	0.67	100.8	85.1312	52.8882
2015	12	25	19	42	22	0.3	3.9	0.65	100.1	85.1312	51.8304
2015	12	25	19	52	22	0.3	3.9	0.69	101.7	85.1312	54.7393
2015	12	25	20	2	22	0.3	3.9	0.7	102.5	85.1969	54.7831
2015	12	25	20	12	22	0.3	3.9	0.68	98.9	85.1312	53.946
2015	12	25	20	22	22	0.3	3.9	0.7	98.6	85.1312	56.0615
2015	12	25	20	32	22	0.3	3.9	0.62	98.2	85.1312	49.7149
2015	12	25	20	42	22	0.3	3.9	0.67	101	85.1312	52.8882
2015	12	25	20	52	22	0.3	3.9	0.69	104.2	85.1312	54.2104
2015	12	25	21	2	22	0.3	3.9	0.66	105.6	85.1312	51.3016
2015	12	25	21	12	22	0.3	3.9	0.64	107	85.1312	49.186
2015	12	25	21	22	22	0.3	3.9	0.64	106.4	85.1312	49.4505
2015	12	25	21	32	22	0.3	3.9	0.67	103.2	85.1312	52.8882
2015	12	25	21	42	22	0.3	3.9	0.65	102.6	85.1312	50.7727
2015	12	25	21	52	22	0.3	3.9	0.66	102.4	85.1312	51.8305

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	22	2	22	0.3	3.9	0.64	104	85.1312	49.7149
2015	12	25	22	12	22	0.3	3.9	0.66	105.5	85.1312	51.566
2015	12	25	22	22	22	0.3	3.9	0.64	104	85.1312	49.7149
2015	12	25	22	32	22	0.3	3.9	0.64	104	85.1312	49.715
2015	12	25	22	42	22	0.3	3.9	0.64	101.5	85.1312	50.7727
2015	12	25	22	52	22	0.3	3.9	0.62	103.1	85.1312	48.9216
2015	12	25	23	2	22	0.3	3.9	0.68	100.9	85.1312	53.6816
2015	12	25	23	12	22	0.3	3.9	0.61	106.7	85.1312	46.8061
2015	12	25	23	22	22	0.3	3.9	0.64	106.4	85.1312	49.4505
2015	12	25	23	32	22	0.3	3.9	0.67	100.7	85.0656	53.3744
2015	12	25	23	42	22	0.3	3.9	0.68	104.6	85.0656	52.846
2015	12	25	23	52	22	0.3	3.9	0.68	103.1	85.0656	53.3744
2015	12	26	0	2	22	0.3	3.9	0.64	101.5	85.0656	50.7322
2015	12	26	0	12	22	0.3	3.9	0.63	102.9	85.0656	49.6752
2015	12	26	0	22	22	0.3	3.9	0.66	100.9	85.0656	52.0533
2015	12	26	0	32	22	0.3	3.9	0.66	101.4	85.0656	52.3176
2015	12	26	0	42	22	0.3	3.9	0.66	101.8	85.0656	52.0533
2015	12	26	0	52	22	0.3	3.9	0.66	105.4	85.0656	50.9964
2015	12	26	1	2	22	0.3	3.9	0.68	103	85.0656	53.6387
2015	12	26	1	12	22	0.3	3.9	0.63	106.6	85.0656	48.6184
2015	12	26	1	22	22	0.3	3.9	0.64	105.4	85.0656	49.9395
2015	12	26	1	32	22	0.3	3.9	0.61	105	85.0656	47.2972
2015	12	26	1	42	22	0.3	3.9	0.64	106.5	85.0656	49.1468
2015	12	26	1	52	22	0.3	3.9	0.66	103	85	51.4837
2015	12	26	2	2	22	0.3	3.9	0.62	103.7	85.0656	48.8826
2015	12	26	2	12	22	0.3	3.9	0.63	107.9	85	48.3155
2015	12	26	2	22	22	0.3	3.9	0.65	106.9	85	50.4276
2015	12	26	2	32	22	0.3	3.9	0.63	106.6	85	48.8435
2015	12	26	2	42	22	0.3	3.9	0.61	104.6	85	47.7875
2015	12	26	2	52	22	0.3	3.9	0.64	104.7	85	50.1636
2015	12	26	3	2	22	0.3	3.9	0.61	104.3	85	47.7875
2015	12	26	3	12	22	0.3	3.9	0.66	101.2	85	52.0118
2015	12	26	3	22	22	0.3	3.9	0.68	102	84.9344	53.2892
2015	12	26	3	32	22	0.3	3.9	0.63	104.2	85	49.1076
2015	12	26	3	42	22	0.3	3.9	0.68	102	85	53.3319
2015	12	26	3	52	22	0.3	3.9	0.63	103.5	84.9344	49.5959
2015	12	26	4	2	22	0.3	3.9	0.65	103.5	85	50.6917
2015	12	26	4	12	22	0.3	3.9	0.66	106	84.9344	50.6511
2015	12	26	4	22	22	0.3	3.9	0.66	104.4	84.9344	51.4426
2015	12	26	4	32	22	0.3	3.9	0.65	101.6	84.9344	51.4426
2015	12	26	4	42	22	0.3	3.9	0.68	100.9	84.9344	53.5531
2015	12	26	4	52	22	0.3	3.9	0.67	102.2	84.9344	52.4978
2015	12	26	5	2	22	0.3	3.9	0.68	99.4	84.9344	54.3445
2015	12	26	5	12	22	0.3	3.9	0.67	101.6	84.9344	52.7617
2015	12	26	5	22	22	0.3	3.9	0.69	99.6	84.9344	54.3445
2015	12	26	5	32	22	0.3	3.9	0.62	101.7	84.9344	48.5407

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	5	42	22	0.3	3.9	0.65	102.6	84.9344	50.915
2015	12	26	5	52	22	0.3	3.9	0.65	102.3	84.9344	50.9151
2015	12	26	6	2	22	0.3	3.9	0.67	104.2	84.8688	52.1922
2015	12	26	6	12	22	0.3	3.9	0.66	102.1	84.9344	51.7065
2015	12	26	6	22	22	0.3	3.9	0.66	100.8	84.8688	52.4558
2015	12	26	6	32	22	0.3	3.9	0.6	102.3	84.9344	47.2218
2015	12	26	6	42	22	0.3	3.9	0.66	104.5	84.8688	51.1379
2015	12	26	6	52	22	0.3	3.9	0.64	102.8	84.8688	50.0835
2015	12	26	7	2	22	0.3	3.9	0.65	103.1	84.9344	51.1789
2015	12	26	7	12	22	0.3	3.9	0.67	102.8	84.9344	52.2342
2015	12	26	7	22	22	0.3	3.9	0.68	101.1	84.8688	53.7739
2015	12	26	7	32	22	0.3	3.9	0.66	102.6	84.8688	51.9287
2015	12	26	7	42	22	0.3	3.9	0.66	102.7	84.8688	51.4015
2015	12	26	7	52	22	0.3	3.9	0.66	102.3	84.9344	52.2342
2015	12	26	8	2	22	0.3	3.9	0.65	103.1	84.8688	51.1379
2015	12	26	8	12	22	0.3	3.9	0.67	100.4	84.8688	53.2466
2015	12	26	8	22	22	0.3	3.9	0.69	102.1	84.8688	54.0374
2015	12	26	8	32	22	0.3	3.9	0.63	102.2	84.8688	49.8198
2015	12	26	8	42	22	0.3	3.9	0.68	103.9	84.8688	53.2466
2015	12	26	8	52	22	0.3	3.9	0.7	101.9	84.8688	54.8281
2015	12	26	9	2	22	0.3	3.9	0.68	101.2	84.8688	53.2465
2015	12	26	9	12	22	0.3	3.9	0.68	103	84.9344	53.553
2015	12	26	9	22	22	0.3	3.9	0.66	102.3	84.9344	51.9702
2015	12	26	9	32	22	0.3	3.9	0.66	102.4	84.9344	51.4425
2015	12	26	9	42	22	0.3	3.9	0.65	100.5	84.9344	51.1787
2015	12	26	9	52	22	0.3	3.9	0.69	101	84.8688	54.3008
2015	12	26	10	2	22	0.3	3.9	0.64	98.9	84.9344	50.651
2015	12	26	10	12	22	0.3	3.9	0.69	102.3	84.9344	54.3443
2015	12	26	10	22	22	0.3	3.9	0.71	98.3	84.8688	56.1459
2015	12	26	10	32	22	0.3	3.9	0.63	102.3	85	49.6355
2015	12	26	10	42	22	0.3	3.9	0.64	98.3	84.9344	50.651
2015	12	26	10	52	22	0.3	3.9	0.67	101	84.9344	53.0252
2015	12	26	11	2	22	0.3	3.9	0.66	98.3	84.9344	52.2338
2015	12	26	11	12	22	0.3	3.9	0.68	101.4	84.8688	53.5098
2015	12	26	11	22	22	0.3	3.9	0.65	100.7	85	51.4836
2015	12	26	11	32	22	0.3	3.9	0.67	101.3	85	52.8036
2015	12	26	11	42	22	0.3	3.9	0.68	102	84.9344	53.2889
2015	12	26	11	52	22	0.3	3.9	0.7	99.5	84.9344	55.3994
2015	12	26	12	2	22	0.3	3.9	0.67	101	85	53.0676
2015	12	26	12	12	22	0.3	3.9	0.65	97.8	84.9344	51.9699
2015	12	26	12	22	22	0.3	3.9	0.68	100.9	84.9344	53.5527
2015	12	26	12	32	22	0.3	3.9	0.7	104.8	85	54.1237
2015	12	26	12	42	22	0.3	3.9	0.67	101.9	85	52.8036
2015	12	26	12	52	22	0.3	3.9	0.65	102.5	84.9344	51.1785
2015	12	26	13	2	22	0.3	3.9	0.65	99.6	84.8688	51.6646
2015	12	26	13	12	22	0.3	3.9	0.63	101.4	84.8688	49.5559

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	13	22	22	0.3	3.9	0.67	103.9	84.8688	52.1919
2015	12	26	13	32	22	0.3	3.9	0.67	100.4	84.8032	52.9402
2015	12	26	13	42	22	0.3	3.9	0.68	100.6	84.8688	53.5099
2015	12	26	13	52	22	0.3	3.9	0.66	101.2	84.8032	51.8867
2015	12	26	14	2	22	0.3	3.9	0.67	101.6	84.8688	52.4556
2015	12	26	14	12	22	0.3	3.9	0.65	101.1	84.8688	51.1376
2015	12	26	14	22	22	0.3	3.9	0.62	99.7	84.8032	49.2529
2015	12	26	14	32	22	0.3	3.9	0.64	101	84.8032	50.3065
2015	12	26	14	42	22	0.3	3.9	0.66	102.4	84.7375	51.3188
2015	12	26	14	52	22	0.3	3.9	0.61	99.3	84.7375	48.1607
2015	12	26	15	2	22	0.3	3.9	0.64	101.2	84.8032	50.5699
2015	12	26	15	12	22	0.3	3.9	0.69	99.6	84.7375	54.2138
2015	12	26	15	22	22	0.3	3.9	0.66	102.1	84.7375	51.5821
2015	12	26	15	32	22	0.3	3.9	0.65	105.2	84.7375	50.5294
2015	12	26	15	42	22	0.3	3.9	0.65	101.9	84.6719	51.2777
2015	12	26	15	52	22	0.3	3.9	0.67	104	84.7375	51.8453
2015	12	26	16	2	22	0.3	3.9	0.66	100.8	84.7375	52.3717
2015	12	26	16	12	22	0.3	3.9	0.66	101	84.6719	51.5407
2015	12	26	16	22	22	0.3	3.9	0.65	105.8	84.6719	50.2259
2015	12	26	16	32	22	0.3	3.9	0.6	102.4	84.6719	46.8074
2015	12	26	16	42	22	0.3	3.9	0.67	101.3	84.6719	52.8556
2015	12	26	16	52	22	0.3	3.9	0.67	104.7	84.6719	52.0667
2015	12	26	17	2	22	0.3	3.9	0.64	101.9	84.6063	49.9228
2015	12	26	17	12	22	0.3	3.9	0.65	102.6	84.6063	50.4483
2015	12	26	17	22	22	0.3	3.9	0.65	103.7	84.6719	50.7519
2015	12	26	17	32	22	0.3	3.9	0.62	100.7	84.6719	48.9111
2015	12	26	17	42	22	0.3	3.9	0.65	104.7	84.6063	50.1856
2015	12	26	17	52	22	0.3	3.9	0.62	103.1	84.6063	48.609
2015	12	26	18	2	22	0.3	3.9	0.64	103.9	84.6063	49.9228
2015	12	26	18	12	22	0.3	3.9	0.62	101.8	84.6063	48.8718
2015	12	26	18	22	22	0.3	3.9	0.64	101	84.6063	49.9228
2015	12	26	18	32	22	0.3	3.9	0.68	102.9	84.6063	52.8131
2015	12	26	18	42	22	0.3	3.9	0.64	102.4	84.5407	50.1451
2015	12	26	18	52	22	0.3	3.9	0.66	100.9	84.5407	51.7204
2015	12	26	19	2	22	0.3	3.9	0.67	103.1	84.6063	52.0248
2015	12	26	19	12	22	0.3	3.9	0.66	99.2	84.6063	52.0248
2015	12	26	19	22	22	0.3	3.9	0.65	103.1	84.5407	50.9328
2015	12	26	19	32	22	0.3	3.9	0.66	103.1	84.5407	51.7204
2015	12	26	19	42	22	0.3	3.9	0.63	101.7	84.5407	49.6201
2015	12	26	19	52	22	0.3	3.9	0.66	100.9	84.5407	51.9829
2015	12	26	20	2	22	0.3	3.9	0.66	100.6	84.5407	51.7204
2015	12	26	20	12	22	0.3	3.9	0.68	102.3	84.5407	52.7705
2015	12	26	20	22	22	0.3	3.9	0.68	100.6	84.5407	53.2956
2015	12	26	20	32	22	0.3	3.9	0.66	101	84.5407	51.4578
2015	12	26	20	42	22	0.3	3.9	0.68	102.8	84.5407	53.0331
2015	12	26	20	52	22	0.3	3.9	0.68	103.4	84.5407	52.7705

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	21	2	22	0.3	3.9	0.69	104	84.5407	53.5581
2015	12	26	21	12	22	0.3	3.9	0.67	103.2	84.5407	52.508
2015	12	26	21	22	22	0.3	3.9	0.66	102.3	84.4751	51.6787
2015	12	26	21	32	22	0.3	3.9	0.64	107.6	84.4751	48.7931
2015	12	26	21	42	22	0.3	3.9	0.64	104	84.4095	49.278
2015	12	26	21	52	22	0.3	3.9	0.6	107.1	84.4095	46.1326
2015	12	26	22	2	22	0.3	3.9	0.67	101.6	84.4751	52.4657
2015	12	26	22	12	22	0.3	3.9	0.64	103.7	84.5407	49.62
2015	12	26	22	22	22	0.3	3.9	0.63	102.6	84.4751	49.3177
2015	12	26	22	32	22	0.3	3.9	0.62	101	84.4751	48.7931
2015	12	26	22	42	22	0.3	3.9	0.69	101.7	84.4095	54.2582
2015	12	26	22	52	22	0.3	3.9	0.62	102.6	84.4095	48.2295
2015	12	26	23	2	22	0.3	3.9	0.66	102.3	84.4095	51.8991
2015	12	26	23	12	22	0.3	3.9	0.62	104.2	84.4095	47.7053
2015	12	26	23	22	22	0.3	3.9	0.66	100.1	84.4095	51.637
2015	12	26	23	32	22	0.3	3.9	0.61	106.7	84.4095	46.3947
2015	12	26	23	42	22	0.3	3.9	0.6	108.7	84.4095	45.6083
2015	12	26	23	52	22	0.3	3.9	0.62	106.4	84.4095	47.1811
2015	12	27	0	2	22	0.3	3.9	0.62	105.3	84.4095	47.9674
2015	12	27	0	12	22	0.3	3.9	0.61	106.8	84.4095	46.9189
2015	12	27	0	22	22	0.3	3.9	0.61	106.8	84.4095	46.9189
2015	12	27	0	32	22	0.3	3.9	0.62	105.4	84.4095	47.7053
2015	12	27	0	42	22	0.3	3.9	0.64	106.6	84.3438	49.2383
2015	12	27	0	52	22	0.3	3.9	0.63	104.1	84.4095	49.0159
2015	12	27	1	2	22	0.3	3.9	0.62	105.1	84.4095	47.4432
2015	12	27	1	12	22	0.3	3.9	0.62	104.3	84.4095	48.2296
2015	12	27	1	22	22	0.3	3.9	0.61	105.9	84.3438	46.8812
2015	12	27	1	32	22	0.3	3.9	0.63	106.3	84.3438	48.4526
2015	12	27	1	42	22	0.3	3.9	0.63	105.7	84.3438	48.4526
2015	12	27	1	52	22	0.3	3.9	0.65	105.7	84.3438	50.286
2015	12	27	2	2	22	0.3	3.9	0.67	103.4	84.3438	51.8574
2015	12	27	2	12	22	0.3	3.9	0.6	102.7	84.3438	46.3574
2015	12	27	2	22	22	0.3	3.9	0.64	103.7	84.3438	49.5003
2015	12	27	2	32	22	0.3	3.9	0.63	106.4	84.3438	48.1908
2015	12	27	2	42	22	0.3	3.9	0.64	101.6	84.3438	49.7622
2015	12	27	2	52	22	0.3	3.9	0.67	105.1	84.3438	51.3337
2015	12	27	3	2	22	0.3	3.9	0.62	101.3	84.3438	48.7146
2015	12	27	3	12	22	0.3	3.9	0.62	105.6	84.3438	47.9289
2015	12	27	3	22	22	0.3	3.9	0.61	104.3	84.3438	47.4051
2015	12	27	3	32	22	0.3	3.9	0.6	105.5	84.2782	46.3201
2015	12	27	3	42	22	0.3	3.9	0.61	104	84.2782	47.3669
2015	12	27	3	52	22	0.3	3.9	0.66	105.1	84.2782	50.5072
2015	12	27	4	2	22	0.3	3.9	0.64	103.6	84.2782	49.7221
2015	12	27	4	12	22	0.3	3.9	0.63	103.8	84.2782	48.9371
2015	12	27	4	22	22	0.3	3.9	0.64	104.8	84.2782	49.4605
2015	12	27	4	32	22	0.3	3.9	0.66	102.4	84.2782	51.2924

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	4	42	22	0.3	3.9	0.61	104	84.2782	47.367
2015	12	27	4	52	22	0.3	3.9	0.63	102	84.2782	49.1988
2015	12	27	5	2	22	0.3	3.9	0.68	101.7	84.2782	53.1243
2015	12	27	5	12	22	0.3	3.9	0.67	103.8	84.2126	52.0354
2015	12	27	5	22	22	0.3	3.9	0.64	104.9	84.2126	49.1591
2015	12	27	5	32	22	0.3	3.9	0.61	105.5	84.2126	47.0673
2015	12	27	5	42	22	0.3	3.9	0.64	103	84.2126	49.6821
2015	12	27	5	52	22	0.3	3.9	0.62	104.6	84.2126	48.1132
2015	12	27	6	2	22	0.3	3.9	0.63	105.2	84.2126	48.1133
2015	12	27	6	12	22	0.3	3.9	0.65	106.7	84.2126	49.6822
2015	12	27	6	22	22	0.3	3.9	0.61	105.2	84.2126	47.0674
2015	12	27	6	32	22	0.3	3.9	0.64	105.7	84.2126	49.4207
2015	12	27	6	42	22	0.3	3.9	0.63	103.5	84.2126	49.1593
2015	12	27	6	52	22	0.3	3.9	0.64	104.6	84.2126	49.1593
2015	12	27	7	2	22	0.3	3.9	0.63	103.5	84.147	48.8583
2015	12	27	7	12	22	0.3	3.9	0.64	105.3	84.147	48.8583
2015	12	27	7	22	22	0.3	3.9	0.64	106.8	84.147	48.597
2015	12	27	7	32	22	0.3	3.9	0.64	104.5	84.147	49.6421
2015	12	27	7	42	22	0.3	3.9	0.64	107.1	84.147	48.3358
2015	12	27	7	52	22	0.3	3.9	0.63	106.4	84.147	47.8132
2015	12	27	8	2	22	0.3	3.9	0.65	106.4	84.147	49.6421
2015	12	27	8	12	22	0.3	3.9	0.62	104.1	84.147	47.8132
2015	12	27	8	22	22	0.3	3.9	0.63	103.8	84.147	48.8583
2015	12	27	8	32	22	0.3	3.9	0.59	106.9	84.147	44.6779
2015	12	27	8	42	22	0.3	3.9	0.62	103.8	84.147	47.8131
2015	12	27	8	52	22	0.3	3.9	0.61	105.5	84.147	47.0293
2015	12	27	9	2	22	0.3	3.9	0.65	105.7	84.147	50.1645
2015	12	27	9	12	22	0.3	3.9	0.62	107.3	84.147	47.0292
2015	12	27	9	22	22	0.3	3.9	0.6	106.8	84.2126	46.0213
2015	12	27	9	32	22	0.3	3.9	0.6	108.4	84.147	45.4615
2015	12	27	9	42	22	0.3	3.9	0.61	107.7	84.2126	46.0213
2015	12	27	9	52	22	0.3	3.9	0.62	108.1	84.2126	47.0672
2015	12	27	10	2	22	0.3	3.9	0.62	107.7	84.2126	46.8057
2015	12	27	10	12	22	0.3	3.9	0.63	105.9	84.2126	48.636
2015	12	27	10	22	22	0.3	3.9	0.61	104.9	84.2126	47.0671
2015	12	27	10	32	22	0.3	3.9	0.62	107	84.2126	47.0671
2015	12	27	10	42	22	0.3	3.9	0.63	107.9	84.2126	47.8515
2015	12	27	10	52	22	0.3	3.9	0.63	105.1	84.2126	48.3744
2015	12	27	11	2	22	0.3	3.9	0.61	106.6	84.2126	46.544
2015	12	27	11	12	22	0.3	3.9	0.58	106.7	84.2782	44.4881
2015	12	27	11	22	22	0.3	3.9	0.63	105.7	84.2126	48.3744
2015	12	27	11	32	22	0.3	3.9	0.62	104	84.2126	48.1129
2015	12	27	11	42	22	0.3	3.9	0.61	108.4	84.2126	46.2825
2015	12	27	11	52	22	0.3	3.9	0.6	108.5	84.2126	45.2365
2015	12	27	12	2	22	0.3	3.9	0.59	108.4	84.2126	44.7136
2015	12	27	12	12	22	0.3	3.9	0.6	108.5	84.2126	45.2365

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	12	22	22	0.3	3.9	0.61	109.4	84.2126	46.021
2015	12	27	12	32	22	0.3	3.9	0.62	107	84.2126	47.0669
2015	12	27	12	42	22	0.3	3.9	0.62	109.6	84.2126	46.2825
2015	12	27	12	52	22	0.3	3.9	0.62	106	84.2126	47.3284
2015	12	27	13	2	22	0.3	3.9	0.62	106.8	84.2126	47.5899
2015	12	27	13	12	22	0.3	3.9	0.61	106	84.147	46.5064
2015	12	27	13	22	22	0.3	3.9	0.58	109.5	84.147	43.6324
2015	12	27	13	32	22	0.3	3.9	0.64	108.2	84.147	48.5965
2015	12	27	13	42	22	0.3	3.9	0.6	106.2	84.147	45.9838
2015	12	27	13	52	22	0.3	3.9	0.6	108.6	84.0814	44.9024
2015	12	27	14	2	22	0.3	3.9	0.58	105.3	84.147	44.9388
2015	12	27	14	12	22	0.3	3.9	0.58	107.1	84.0814	44.1192
2015	12	27	14	22	22	0.3	3.9	0.61	107.3	84.147	46.2451
2015	12	27	14	32	22	0.3	3.9	0.58	104	84.0814	45.1635
2015	12	27	14	42	22	0.3	3.9	0.61	106.7	84.0814	46.2077
2015	12	27	14	52	22	0.3	3.9	0.59	106.2	84.0814	44.9025
2015	12	27	15	2	22	0.3	3.9	0.6	108.1	84.0814	45.4246
2015	12	27	15	12	22	0.3	3.9	0.61	110.5	84.0814	45.4247
2015	12	27	15	22	22	0.3	3.9	0.61	107.9	84.0158	45.9096
2015	12	27	15	32	22	0.3	3.9	0.57	107	84.0158	43.562
2015	12	27	15	42	22	0.3	3.9	0.59	106.4	84.0158	45.1271
2015	12	27	15	52	22	0.3	3.9	0.58	109	84.0158	43.8229
2015	12	27	16	2	22	0.3	3.9	0.64	107.1	84.0158	48.2573
2015	12	27	16	12	22	0.3	3.9	0.62	107.9	84.0158	46.9531
2015	12	27	16	22	22	0.3	3.9	0.65	108.6	84.0158	48.7791
2015	12	27	16	32	22	0.3	3.9	0.64	107.4	84.0158	48.2574
2015	12	27	16	42	22	0.3	3.9	0.66	105.2	84.0158	50.8659
2015	12	27	16	52	22	0.3	3.9	0.62	107.2	84.0158	47.214
2015	12	27	17	2	22	0.3	3.9	0.64	107.8	84.0158	48.7791
2015	12	27	17	12	22	0.3	3.9	0.65	105.5	84.0158	49.8225
2015	12	27	17	22	22	0.3	3.9	0.62	106.5	84.0158	47.4749
2015	12	27	17	32	22	0.3	3.9	0.63	105.2	84.0158	47.9966
2015	12	27	17	42	22	0.3	3.9	0.64	105	83.9501	48.7396
2015	12	27	17	52	22	0.3	3.9	0.63	105.8	84.0158	47.9966
2015	12	27	18	2	22	0.3	3.9	0.65	104.7	84.0158	49.8225
2015	12	27	18	12	22	0.3	3.9	0.61	106.2	83.9501	46.6545
2015	12	27	18	22	22	0.3	3.9	0.62	105.3	83.9501	47.697
2015	12	27	18	32	22	0.3	3.9	0.61	106.1	83.9501	46.9151
2015	12	27	18	42	22	0.3	3.9	0.65	106.6	83.9501	49.7822
2015	12	27	18	52	22	0.3	3.9	0.65	104.4	83.9501	49.7822
2015	12	27	19	2	22	0.3	3.9	0.64	107.6	83.9501	48.479
2015	12	27	19	12	22	0.3	3.9	0.63	103.9	83.9501	48.479
2015	12	27	19	22	22	0.3	3.9	0.65	107.9	83.9501	49.2609
2015	12	27	19	32	22	0.3	3.9	0.62	104.6	83.9501	47.9577
2015	12	27	19	42	22	0.3	3.9	0.65	102.3	83.9501	50.3035
2015	12	27	19	52	22	0.3	3.9	0.63	101.4	83.9501	49.2609

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	20	2	22	0.3	3.9	0.65	108.1	83.8845	48.7001
2015	12	27	20	12	22	0.3	3.9	0.64	103.6	83.9501	49.5216
2015	12	27	20	22	22	0.3	3.9	0.63	104.3	83.9501	48.2184
2015	12	27	20	32	22	0.3	3.9	0.64	105.5	83.9501	48.7397
2015	12	27	20	42	22	0.3	3.9	0.6	105.9	83.8845	45.8354
2015	12	27	20	52	22	0.3	3.9	0.63	107	83.8845	47.6584
2015	12	27	21	2	22	0.3	3.9	0.63	103.6	83.8845	48.4397
2015	12	27	21	12	22	0.3	3.9	0.61	103.7	83.8845	46.8771
2015	12	27	21	22	22	0.3	3.9	0.61	107.3	83.8845	46.0959
2015	12	27	21	32	22	0.3	3.9	0.65	108	83.8845	48.9606
2015	12	27	21	42	22	0.3	3.9	0.57	106	83.8845	43.4916
2015	12	27	21	52	22	0.3	3.9	0.63	108.6	83.8845	47.1376
2015	12	27	22	2	22	0.3	3.9	0.65	107.1	83.8845	48.9606
2015	12	27	22	12	22	0.3	3.9	0.58	104.2	83.8845	44.2729
2015	12	27	22	22	22	0.3	3.9	0.64	106.9	83.8845	48.9607
2015	12	27	22	32	22	0.3	3.9	0.62	108.4	83.8189	46.8391
2015	12	27	22	42	22	0.3	3.9	0.62	106.5	83.8189	47.3596
2015	12	27	22	52	22	0.3	3.9	0.62	105.6	83.8189	47.6198
2015	12	27	23	2	22	0.3	3.9	0.61	102.8	83.8189	46.8392
2015	12	27	23	12	22	0.3	3.9	0.65	103.7	83.8189	50.222
2015	12	27	23	22	22	0.3	3.9	0.64	106.2	83.8189	48.4005
2015	12	27	23	32	22	0.3	3.9	0.66	103	83.8189	50.7425
2015	12	27	23	42	22	0.3	3.9	0.62	104.6	83.8189	47.8801
2015	12	27	23	52	22	0.3	3.9	0.62	104.4	83.8189	47.6199
2015	12	28	0	2	22	0.3	3.9	0.63	106.7	83.8189	47.6199
2015	12	28	0	12	22	0.3	3.9	0.6	105.6	83.8189	45.5382
2015	12	28	0	22	22	0.3	3.9	0.65	103.8	83.8189	49.7017
2015	12	28	0	32	22	0.3	3.9	0.62	107.9	83.8189	46.8393
2015	12	28	0	42	22	0.3	3.9	0.64	105	83.7533	48.6213
2015	12	28	0	52	22	0.3	3.9	0.62	106.2	83.7533	47.3213
2015	12	28	1	2	22	0.3	3.9	0.61	108.5	83.7533	45.7612
2015	12	28	1	12	22	0.3	3.9	0.63	105.3	83.7533	48.3613
2015	12	28	1	22	22	0.3	3.9	0.64	107.7	83.7533	48.1013
2015	12	28	1	32	22	0.3	3.9	0.64	108	83.7533	48.1013
2015	12	28	1	42	22	0.3	3.9	0.64	107.4	83.6877	48.0622
2015	12	28	1	52	22	0.3	3.9	0.64	107	83.6877	48.5818
2015	12	28	2	2	22	0.3	3.9	0.62	106.8	83.6877	47.2828
2015	12	28	2	12	22	0.3	3.9	0.62	106.4	83.6877	46.7633
2015	12	28	2	22	22	0.3	3.9	0.59	104.1	83.6877	45.4643
2015	12	28	2	32	22	0.3	3.9	0.61	106.8	83.6877	46.5035
2015	12	28	2	42	22	0.3	3.9	0.64	106.7	83.6221	48.5423
2015	12	28	2	52	22	0.3	3.9	0.62	105.9	83.6221	47.504
2015	12	28	3	2	22	0.3	3.9	0.64	107.1	83.6877	48.0623
2015	12	28	3	12	22	0.3	3.9	0.65	106.5	83.6221	49.0615
2015	12	28	3	22	22	0.3	3.9	0.6	109.3	83.6221	45.1677
2015	12	28	3	32	22	0.3	3.9	0.58	107.5	83.6221	43.6102

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	3	42	22	0.3	3.9	0.62	108.3	83.6221	46.2061
2015	12	28	3	52	22	0.3	3.9	0.63	106.9	83.5564	47.7247
2015	12	28	4	2	22	0.3	3.9	0.6	109.3	83.4908	45.0942
2015	12	28	4	12	22	0.3	3.9	0.58	109	83.4908	43.5392
2015	12	28	4	22	22	0.3	3.9	0.61	108.1	83.5564	45.9091
2015	12	28	4	32	22	0.3	3.9	0.6	105.5	83.4908	45.8717
2015	12	28	4	42	22	0.3	3.9	0.61	107.8	83.4908	46.1308
2015	12	28	4	52	22	0.3	3.9	0.64	105.8	83.5564	48.5028
2015	12	28	5	2	22	0.3	3.9	0.62	106.4	83.4908	46.6492
2015	12	28	5	12	22	0.3	3.9	0.63	103.6	83.4908	48.2041
2015	12	28	5	22	22	0.3	3.9	0.62	110.2	83.4908	45.8717
2015	12	28	5	32	22	0.3	3.9	0.59	110.1	83.4908	43.7984
2015	12	28	5	42	22	0.3	3.9	0.59	110.4	83.4908	43.7984
2015	12	28	5	52	22	0.3	3.9	0.6	110	83.4908	44.835
2015	12	28	6	2	22	0.3	3.9	0.63	109.6	83.4908	46.6492
2015	12	28	6	12	22	0.3	3.9	0.6	107.1	83.4908	45.3534
2015	12	28	6	22	22	0.3	3.9	0.59	112.7	83.4908	42.7617
2015	12	28	6	32	22	0.3	3.9	0.63	107.2	83.4252	47.6469
2015	12	28	6	42	22	0.3	3.9	0.6	108.3	83.4908	45.3534
2015	12	28	6	52	22	0.3	3.9	0.63	110.5	83.4908	46.39
2015	12	28	7	2	22	0.3	3.9	0.61	106.8	83.4908	46.39
2015	12	28	7	12	22	0.3	3.9	0.63	108	83.4908	47.1675
2015	12	28	7	22	22	0.3	3.9	0.63	106.8	83.4252	47.9059
2015	12	28	7	32	22	0.3	3.9	0.64	108.2	83.4908	47.945
2015	12	28	7	42	22	0.3	3.9	0.63	110.7	83.4252	46.6111
2015	12	28	7	52	22	0.3	3.9	0.61	110.5	83.4908	45.0942
2015	12	28	8	2	22	0.3	3.9	0.59	107	83.4252	44.7984
2015	12	28	8	12	22	0.3	3.9	0.6	110.1	83.4252	44.5395
2015	12	28	8	22	22	0.3	3.9	0.62	110	83.4252	46.3521
2015	12	28	8	32	22	0.3	3.9	0.6	109.6	83.4252	44.2804
2015	12	28	8	42	22	0.3	3.9	0.63	110.9	83.4252	46.0931
2015	12	28	8	52	22	0.3	3.9	0.62	108.2	83.4252	46.352
2015	12	28	9	2	22	0.3	3.9	0.6	109.8	83.4252	44.5393
2015	12	28	9	12	22	0.3	3.9	0.6	111.8	83.4252	44.0213
2015	12	28	9	22	22	0.3	3.9	0.59	111	83.4252	43.7624
2015	12	28	9	32	22	0.3	3.9	0.59	112.7	83.4252	43.2444
2015	12	28	9	42	22	0.3	3.9	0.6	110.2	83.4252	44.2802
2015	12	28	9	52	22	0.3	3.9	0.59	115.1	83.4908	41.9839
2015	12	28	10	2	22	0.3	3.9	0.62	108.1	83.4908	46.9079
2015	12	28	10	12	22	0.3	3.9	0.62	106.3	83.5564	46.9462
2015	12	28	10	22	22	0.3	3.9	0.59	108.3	83.5564	44.6118
2015	12	28	10	32	22	0.3	3.9	0.64	104.3	83.4908	48.9811
2015	12	28	10	42	22	0.3	3.9	0.59	104.7	83.4908	45.3528
2015	12	28	10	52	22	0.3	3.9	0.63	104.5	83.4908	48.2036
2015	12	28	11	2	22	0.3	3.9	0.63	105.2	83.4908	47.6852
2015	12	28	11	12	22	0.3	3.9	0.62	101.6	83.4252	47.9053

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	11	22	22	0.3	3.9	0.64	104	83.4252	48.682
2015	12	28	11	32	22	0.3	3.9	0.63	103.9	83.4252	48.1642
2015	12	28	11	42	22	0.3	3.9	0.67	103.4	83.3596	51.2299
2015	12	28	11	52	22	0.3	3.9	0.66	103	83.4252	50.4949
2015	12	28	12	2	22	0.3	3.9	0.64	103	83.3596	49.4187
2015	12	28	12	12	22	0.3	3.9	0.63	102.1	83.3596	48.3838
2015	12	28	12	22	22	0.3	3.9	0.62	104.5	83.3596	47.0901
2015	12	28	12	32	22	0.3	3.9	0.64	103	83.3596	49.16
2015	12	28	12	42	22	0.3	3.9	0.66	103.8	83.3596	50.4537
2015	12	28	12	52	22	0.3	3.9	0.67	104.5	83.3596	50.9712
2015	12	28	13	2	22	0.3	3.9	0.67	102.7	83.3596	51.7475
2015	12	28	13	12	22	0.3	3.9	0.63	102.9	83.294	48.3444
2015	12	28	13	22	22	0.3	3.9	0.68	100.3	83.294	52.4809
2015	12	28	13	32	22	0.3	3.9	0.66	104.2	83.294	50.1542
2015	12	28	13	42	22	0.3	3.9	0.63	102.7	83.2284	48.0466
2015	12	28	13	52	22	0.3	3.9	0.67	103.1	83.294	51.1882
2015	12	28	14	2	22	0.3	3.9	0.65	101.1	83.294	50.1541
2015	12	28	14	12	22	0.3	3.9	0.66	103.2	83.294	50.6712
2015	12	28	14	22	22	0.3	3.9	0.65	103.8	83.294	49.3786
2015	12	28	14	32	22	0.3	3.9	0.64	104.2	83.2284	49.0799
2015	12	28	14	42	22	0.3	3.9	0.64	103.6	83.2284	49.08
2015	12	28	14	52	22	0.3	3.9	0.66	103.4	83.2284	50.8882
2015	12	28	15	2	22	0.3	3.9	0.63	104.3	83.2284	47.7884
2015	12	28	15	12	22	0.3	3.9	0.68	102.6	83.2284	51.9214
2015	12	28	15	22	22	0.3	3.9	0.63	104.8	83.2284	48.0467
2015	12	28	15	32	22	0.3	3.9	0.68	96.4	83.2284	52.9547
2015	12	28	15	42	22	0.3	3.9	0.68	97	83.2284	52.9547
2015	12	28	15	52	22	0.3	3.9	0.64	104.5	83.2284	48.8217
2015	12	28	16	2	22	0.3	3.9	0.64	103.5	83.2284	49.3383
2015	12	28	16	12	22	0.3	3.9	0.63	103.5	83.2284	48.3051
2015	12	28	16	22	22	0.3	3.9	0.66	103.8	83.2284	50.6299
2015	12	28	16	32	22	0.3	3.9	0.65	104	83.2284	49.5967
2015	12	28	16	42	22	0.3	3.9	0.67	104.1	83.2284	51.4049
2015	12	28	16	52	22	0.3	3.9	0.68	103.8	83.2284	51.6632
2015	12	28	17	2	22	0.3	3.9	0.67	102.8	83.2284	51.1466
2015	12	28	17	12	22	0.3	3.9	0.66	105.4	83.2284	49.855
2015	12	28	17	22	22	0.3	3.9	0.62	104.8	83.2284	47.0135
2015	12	28	17	32	22	0.3	3.9	0.63	101.9	83.2284	48.8217
2015	12	28	17	42	22	0.3	3.9	0.63	106	83.2284	47.7885
2015	12	28	17	52	22	0.3	3.9	0.64	102.8	83.2284	49.0801
2015	12	28	18	2	22	0.3	3.9	0.65	104.3	83.2284	49.5967
2015	12	28	18	12	22	0.3	3.9	0.62	101	83.2284	48.0468
2015	12	28	18	22	22	0.3	3.9	0.65	103.3	83.1627	50.0723
2015	12	28	18	32	22	0.3	3.9	0.65	103.2	83.1627	49.5561
2015	12	28	18	42	22	0.3	3.9	0.67	101.9	83.1627	51.3628
2015	12	28	18	52	22	0.3	3.9	0.64	102.3	83.1627	49.5561

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	19	2	22	0.3	3.9	0.65	102	83.1627	49.8142
2015	12	28	19	12	22	0.3	3.9	0.63	104.4	83.1627	48.2656
2015	12	28	19	22	22	0.3	3.9	0.63	101.9	83.1627	48.7818
2015	12	28	19	32	22	0.3	3.9	0.6	104.9	83.1627	45.6845
2015	12	28	19	42	22	0.3	3.9	0.65	105.7	83.1627	49.5561
2015	12	28	19	52	22	0.3	3.9	0.6	103.7	83.1627	45.6845
2015	12	28	20	2	22	0.3	3.9	0.62	105.7	83.1627	46.975
2015	12	28	20	12	22	0.3	3.9	0.62	107.2	83.1627	46.7169
2015	12	28	20	22	22	0.3	3.9	0.59	109.8	83.1627	43.6197
2015	12	28	20	32	22	0.3	3.9	0.61	109.1	83.1627	45.4264
2015	12	28	20	42	22	0.3	3.9	0.64	108.6	83.1627	47.4913
2015	12	28	20	52	22	0.3	3.9	0.61	107.6	83.1627	45.6845
2015	12	28	21	2	22	0.3	3.9	0.63	106.6	83.1627	47.7494
2015	12	28	21	12	22	0.3	3.9	0.66	108.1	83.1627	49.0399
2015	12	28	21	22	22	0.3	3.9	0.63	108.9	83.1627	46.7169
2015	12	28	21	32	22	0.3	3.9	0.63	108.1	83.1627	47.4913
2015	12	28	21	42	22	0.3	3.9	0.61	110.4	83.1627	45.1683
2015	12	28	21	52	22	0.3	3.9	0.63	105.4	83.1627	47.7494
2015	12	28	22	2	22	0.3	3.9	0.6	112.5	83.1627	43.6197
2015	12	28	22	12	22	0.3	3.9	0.65	106.2	83.1627	48.7818
2015	12	28	22	22	22	0.3	3.9	0.62	108.8	83.1627	46.2007
2015	12	28	22	32	22	0.3	3.9	0.6	107.4	82.9659	45.0573
2015	12	28	22	42	22	0.3	3.9	0.58	108.4	83.0971	43.3261
2015	12	28	22	52	22	0.3	3.9	0.62	109.5	83.1627	45.9426
2015	12	28	23	2	22	0.3	3.9	0.62	109.6	83.1627	45.6845
2015	12	28	23	12	22	0.3	3.9	0.63	108.3	83.1627	46.7169
2015	12	28	23	22	22	0.3	3.9	0.62	110.8	83.0971	45.3892
2015	12	28	23	32	22	0.3	3.9	0.6	112.8	83.0315	43.5482
2015	12	28	23	42	22	0.3	3.9	0.58	113.1	83.0315	41.7445
2015	12	28	23	52	22	0.3	3.9	0.6	109.5	83.0971	44.3576
2015	12	29	0	2	22	0.3	3.9	0.6	108.2	83.0315	44.5789
2015	12	29	0	12	22	0.3	3.9	0.55	105.5	83.0971	41.7787
2015	12	29	0	22	22	0.3	3.9	0.52	111.1	83.1627	38.1995
2015	12	29	0	32	22	0.3	3.9	0.54	107.8	83.0315	40.1984
2015	12	29	0	42	22	0.3	3.9	0.58	110.3	82.8347	42.4128
2015	12	29	0	52	22	0.3	3.9	0.61	107.3	83.1627	45.6845
2015	12	29	1	2	22	0.3	3.9	0.65	103.8	83.1627	49.298
2015	12	29	1	12	22	0.3	3.9	0.63	106.8	83.1627	47.7494
2015	12	29	1	22	22	0.3	3.9	0.64	106.1	83.1627	48.2656
2015	12	29	1	32	22	0.3	3.9	0.6	114.8	83.1627	43.1035
2015	12	29	1	42	22	0.3	3.9	0.57	116.1	83.1627	40.5224
2015	12	29	1	52	22	0.3	3.9	0.56	120.3	83.1627	37.9414
2015	12	29	2	2	22	0.3	3.9	0.67	99.6	83.1627	51.6209
2015	12	29	2	12	22	0.3	3.9	0.63	110.5	83.1627	46.2008
2015	12	29	2	22	22	0.3	3.9	0.59	117	83.0971	41.5208
2015	12	29	2	32	22	0.3	3.9	0.58	111.1	83.1627	42.8454

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	2	42	22	0.3	3.9	0.6	112.7	83.1627	43.8778
2015	12	29	2	52	22	0.3	3.9	0.63	107.3	82.8347	47.0397
2015	12	29	3	2	22	0.3	3.9	0.61	110.4	82.5722	44.8353
2015	12	29	3	12	22	0.3	3.9	0.65	101.1	82.9003	49.651
2015	12	29	3	22	22	0.3	3.9	0.61	105.4	83.1627	45.9426
2015	12	29	3	32	22	0.3	3.9	0.62	105.7	83.1627	46.717
2015	12	29	3	42	22	0.3	3.9	0.58	98.8	83.1627	44.9102
2015	12	29	3	52	22	0.3	3.9	0.55	113.2	83.1627	39.7481
2015	12	29	4	2	22	0.3	3.9	0.54	100.9	83.0971	41.5208
2015	12	29	4	12	22	0.3	3.9	0.52	105.3	83.1627	39.7481
2015	12	29	4	22	22	0.3	3.9	0.47	122.1	83.1627	31.2307
2015	12	29	4	32	22	0.3	3.9	0.56	107.6	83.0971	42.2945
2015	12	29	4	42	22	0.3	3.9	0.59	98	83.1627	45.6845
2015	12	29	4	52	22	0.3	3.9	0.65	97.5	83.1627	50.8466
2015	12	29	5	2	22	0.3	3.9	0.58	107.5	83.1627	43.3616
2015	12	29	5	12	22	0.3	3.9	0.56	109.3	83.1627	41.2968
2015	12	29	5	22	22	0.3	3.9	0.57	112.3	83.1627	41.5549
2015	12	29	5	32	22	0.3	3.9	0.56	107.4	83.1627	42.0711
2015	12	29	5	42	22	0.3	3.9	0.56	106	83.2284	42.3639
2015	12	29	5	52	22	0.3	3.9	0.53	111.2	83.294	39.2962
2015	12	29	6	2	22	0.3	3.9	0.53	111	83.3596	39.0696
2015	12	29	6	12	22	0.3	3.9	0.48	135.3	83.4252	26.413
2015	12	29	6	22	22	0.3	3.9	0.51	123.9	83.4252	33.1457
2015	12	29	6	32	22	0.3	3.9	0.42	126.3	83.3596	26.3914
2015	12	29	6	42	22	0.3	3.9	0.51	125.5	83.1627	32.5212
2015	12	29	6	52	22	0.3	3.9	0.58	114.4	83.3596	41.657
2015	12	29	7	2	22	0.3	3.9	0.54	114.6	83.294	39.0377
2015	12	29	7	12	22	0.3	3.9	0.59	111.2	83.3596	43.4682
2015	12	29	7	22	22	0.3	3.9	0.57	110.8	83.4252	42.209
2015	12	29	7	32	22	0.3	3.9	0.65	108.4	83.3596	48.9017
2015	12	29	7	42	22	0.3	3.9	0.59	98.6	83.3596	46.0556
2015	12	29	7	52	22	0.3	3.9	0.51	93	83.3596	40.1045
2015	12	29	8	2	22	0.3	3.9	0.43	105	83.3596	32.8598
2015	12	29	8	12	22	0.3	3.9	0.55	105.9	83.4252	41.9499
2015	12	29	8	22	22	0.3	3.9	0.64	95.9	83.4252	50.2363
2015	12	29	8	32	22	0.3	3.9	0.58	112.1	83.3596	42.6919
2015	12	29	8	42	22	0.3	3.9	0.54	121.2	83.294	36.7108
2015	12	29	8	52	22	0.3	3.9	0.46	110.5	83.4252	33.9224
2015	12	29	9	2	22	0.3	3.9	0.56	107.6	83.3596	42.433
2015	12	29	9	12	22	0.3	3.9	0.51	118.6	83.4252	35.2171
2015	12	29	9	22	22	0.3	3.9	0.54	107.8	83.294	40.3301
2015	12	29	9	32	22	0.3	3.9	0.55	106.3	83.294	41.6226
2015	12	29	9	42	22	0.3	3.9	0.51	107	83.294	38.7788
2015	12	29	9	52	22	0.3	3.9	0.51	114.4	83.294	36.4521
2015	12	29	10	2	22	0.3	3.9	0.5	107.8	83.2284	37.7139
2015	12	29	10	12	22	0.3	3.9	0.56	106.2	83.0971	42.552

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	10	22	22	0.3	3.9	0.55	107.7	82.9659	41.1949
2015	12	29	10	32	22	0.3	3.9	0.51	105.5	82.8347	38.8138
2015	12	29	10	42	22	0.3	3.9	0.54	104.5	82.4409	40.4127
2015	12	29	10	52	22	0.3	3.9	0.53	109.8	81.9816	38.9073
2015	12	29	11	2	22	0.3	3.9	0.65	101.9	83.3596	50.4536
2015	12	29	11	12	22	0.3	3.9	0.6	113.4	83.3596	43.7264
2015	12	29	11	22	22	0.3	3.9	0.62	108.8	83.3596	46.3137
2015	12	29	11	32	22	0.3	3.9	0.58	112.2	83.3596	42.4327
2015	12	29	11	42	22	0.3	3.9	0.62	111.9	83.3596	45.02
2015	12	29	11	52	22	0.3	3.9	0.59	113	83.3596	42.6914
2015	12	29	12	2	22	0.3	3.9	0.58	110.7	83.3596	42.4327
2015	12	29	12	12	22	0.3	3.9	0.58	110.8	83.3596	42.9501
2015	12	29	12	22	22	0.3	3.9	0.6	110.1	83.3596	44.5026
2015	12	29	12	32	22	0.3	3.9	0.56	110.9	83.3596	41.3978
2015	12	29	12	42	22	0.3	3.9	0.6	111.5	83.294	43.9491
2015	12	29	12	52	22	0.3	3.9	0.62	110.3	83.3596	46.055
2015	12	29	13	2	22	0.3	3.9	0.62	110.3	83.294	46.0173
2015	12	29	13	12	22	0.3	3.9	0.59	110.3	83.294	43.4321
2015	12	29	13	22	22	0.3	3.9	0.61	112.3	83.294	44.2077
2015	12	29	13	32	22	0.3	3.9	0.62	108	83.294	46.2759
2015	12	29	13	42	22	0.3	3.9	0.62	109.2	83.294	46.0174
2015	12	29	13	52	22	0.3	3.9	0.6	109.2	83.294	44.4663
2015	12	29	14	2	22	0.3	3.9	0.58	109.2	83.294	43.1737
2015	12	29	14	12	22	0.3	3.9	0.6	111.4	83.2284	44.1716
2015	12	29	14	22	22	0.3	3.9	0.62	107.9	83.2284	46.4965
2015	12	29	14	32	22	0.3	3.9	0.61	109.8	83.2284	45.2049
2015	12	29	14	42	22	0.3	3.9	0.61	109.5	83.2284	45.205
2015	12	29	14	52	22	0.3	3.9	0.63	108.2	83.2284	47.2715
2015	12	29	15	2	22	0.3	3.9	0.62	110.3	83.2284	45.98
2015	12	29	15	12	22	0.3	3.9	0.62	109.3	83.2284	45.7218
2015	12	29	15	22	22	0.3	3.9	0.63	108.6	83.1627	46.7168
2015	12	29	15	32	22	0.3	3.9	0.63	110.7	83.1627	46.4587
2015	12	29	15	42	22	0.3	3.9	0.64	109.2	83.1627	47.4911
2015	12	29	15	52	22	0.3	3.9	0.62	110	83.1627	46.2006
2015	12	29	16	2	22	0.3	3.9	0.64	108.3	83.1627	47.4912
2015	12	29	16	12	22	0.3	3.9	0.61	110	83.1627	45.4264
2015	12	29	16	22	22	0.3	3.9	0.61	108.1	83.1627	45.6845
2015	12	29	16	32	22	0.3	3.9	0.63	111	83.1627	46.4588
2015	12	29	16	42	22	0.3	3.9	0.61	106.6	83.1627	45.9426
2015	12	29	16	52	22	0.3	3.9	0.64	108.5	83.0971	47.7102
2015	12	29	17	2	22	0.3	3.9	0.62	109.2	83.0971	45.9049
2015	12	29	17	12	22	0.3	3.9	0.62	109.7	83.0971	46.1628
2015	12	29	17	22	22	0.3	3.9	0.59	108.9	83.0971	43.5839
2015	12	29	17	32	22	0.3	3.9	0.6	107.2	83.0971	44.8734
2015	12	29	17	42	22	0.3	3.9	0.62	105.1	83.0971	46.9365
2015	12	29	17	52	22	0.3	3.9	0.64	108.2	83.0971	47.9681

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	18	2	22	0.3	3.9	0.64	105.8	83.0971	48.226
2015	12	29	18	12	22	0.3	3.9	0.67	106	83.0971	50.2891
2015	12	29	18	22	22	0.3	3.9	0.62	108.8	83.0971	46.1629
2015	12	29	18	32	22	0.3	3.9	0.61	109	83.0971	45.6471
2015	12	29	18	42	22	0.3	3.9	0.61	112.3	83.0971	44.0997
2015	12	29	18	52	22	0.3	3.9	0.6	119.1	83.0971	41.2629
2015	12	29	19	2	22	0.3	3.9	0.62	105.7	83.0971	46.9365
2015	12	29	19	12	22	0.3	3.9	0.59	121.2	83.0971	39.9734
2015	12	29	19	22	22	0.3	3.9	0.58	107.9	83.0971	43.0681
2015	12	29	19	32	22	0.3	3.9	0.61	119.9	83.0971	41.2629
2015	12	29	19	42	22	0.3	3.9	0.59	112.4	83.0971	43.0681
2015	12	29	19	52	22	0.3	3.9	0.65	97.2	83.0971	50.805
2015	12	29	20	2	22	0.3	3.9	0.61	113.2	83.0971	43.8418
2015	12	29	20	12	22	0.3	3.9	0.63	108.8	83.0971	46.9366
2015	12	29	20	22	22	0.3	3.9	0.59	110.9	83.0971	43.3261
2015	12	29	20	32	22	0.3	3.9	0.67	97.1	83.0971	52.0944
2015	12	29	20	42	22	0.3	3.9	0.59	109.5	83.0971	43.5839
2015	12	29	20	52	22	0.3	3.9	0.61	107.9	83.0971	45.6471
2015	12	29	21	2	22	0.3	3.9	0.57	108.2	83.0971	42.2945
2015	12	29	21	12	22	0.3	3.9	0.61	110.6	83.0971	44.6155
2015	12	29	21	22	22	0.3	3.9	0.45	123.1	83.0971	29.6577
2015	12	29	21	32	22	0.3	3.9	0.54	111.9	83.0971	39.7156
2015	12	29	21	42	22	0.3	3.9	0.53	104.2	83.0971	40.7471
2015	12	29	21	52	22	0.3	3.9	0.65	105.7	83.0971	49.5155
2015	12	29	22	2	22	0.3	3.9	0.62	109.5	83.1627	45.9426
2015	12	29	22	12	22	0.3	3.9	0.64	115.2	83.1627	45.4264
2015	12	29	22	22	22	0.3	3.9	0.57	126.6	83.1627	36.1347
2015	12	29	22	32	22	0.3	3.9	0.72	97	83.1627	56.5249
2015	12	29	22	42	22	0.3	3.9	0.54	109.1	83.1627	40.2643
2015	12	29	22	52	22	0.3	3.9	0.61	93.4	83.1627	47.7494
2015	12	29	23	2	22	0.3	3.9	0.62	108.1	83.1627	46.717
2015	12	29	23	12	22	0.3	3.9	0.7	92.7	83.1627	54.7182
2015	12	29	23	22	22	0.3	3.9	0.66	104	83.1627	50.5885
2015	12	29	23	32	22	0.3	3.9	0.5	102.9	83.1627	38.1995
2015	12	29	23	42	22	0.3	3.9	0.55	105.9	83.2284	41.8472
2015	12	29	23	52	22	0.3	3.9	0.59	94.2	83.2284	45.9803
2015	12	30	0	2	22	0.3	3.9	0.62	105.4	83.2284	46.7552
2015	12	30	0	12	22	0.3	3.9	0.57	113.9	83.294	40.8474
2015	12	30	0	22	22	0.3	3.9	0.63	101.4	83.294	48.8617
2015	12	30	0	32	22	0.3	3.9	0.48	116.2	83.3596	34.1536
2015	12	30	0	42	22	0.3	3.9	0.59	110.3	83.2284	43.3971
2015	12	30	0	52	22	0.3	3.9	0.5	106.3	83.2284	37.9725
2015	12	30	1	2	22	0.3	3.9	0.58	102.5	83.1627	44.394
2015	12	30	1	12	22	0.3	3.9	0.61	113.3	83.2284	44.4304
2015	12	30	1	22	22	0.3	3.9	0.72	106.6	83.2284	54.5047
2015	12	30	1	32	22	0.3	3.9	0.71	110.4	83.294	52.7397

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	1	42	22	0.3	3.9	0.45	106.5	83.294	34.1257
2015	12	30	1	52	22	0.3	3.9	0.61	112.3	83.294	44.7253
2015	12	30	2	2	22	0.3	3.9	0.5	106	83.2284	37.7142
2015	12	30	2	12	22	0.3	3.9	0.67	113.8	83.3596	48.1255
2015	12	30	2	22	22	0.3	3.9	0.52	102.3	83.294	40.3303
2015	12	30	2	32	22	0.3	3.9	0.58	113.8	83.3596	42.1745
2015	12	30	2	42	22	0.3	3.9	0.5	102.9	83.294	38.2621
2015	12	30	2	52	22	0.3	3.9	0.67	110.8	83.3596	49.1605
2015	12	30	3	2	22	0.3	3.9	0.54	109.4	83.3596	40.3633
2015	12	30	3	12	22	0.3	3.9	0.62	116.4	83.3596	43.7269
2015	12	30	3	22	22	0.3	3.9	0.6	108.6	83.3596	44.5032
2015	12	30	3	32	22	0.3	3.9	0.59	107.6	83.294	43.9497
2015	12	30	3	42	22	0.3	3.9	0.71	110.3	83.4252	52.567
2015	12	30	3	52	22	0.3	3.9	0.52	108	83.3596	39.0696
2015	12	30	4	2	22	0.3	3.9	0.67	115.7	83.294	47.3106
2015	12	30	4	12	22	0.3	3.9	0.64	114.6	83.2284	45.722
2015	12	30	4	22	22	0.3	3.9	0.59	102.6	83.3596	45.2794
2015	12	30	4	32	22	0.3	3.9	0.71	110.4	83.3596	52.7828
2015	12	30	4	42	22	0.3	3.9	0.37	83.9	83.4252	29.2614
2015	12	30	4	52	22	0.3	3.9	0.52	104.7	83.4252	39.3605
2015	12	30	5	2	22	0.3	3.9	0.49	103.1	83.3596	37.7759
2015	12	30	5	12	22	0.3	3.9	0.71	115.7	83.3596	50.4542
2015	12	30	5	22	22	0.3	3.9	0.77	121	83.3596	51.7478
2015	12	30	5	32	22	0.3	3.9	0.65	115.7	83.3596	46.3143
2015	12	30	5	42	22	0.3	3.9	0.72	112.2	83.3596	52.5241
2015	12	30	5	52	22	0.3	3.9	0.72	122.1	83.3596	47.8668
2015	12	30	6	2	22	0.3	3.9	0.66	114.1	83.4908	47.4267
2015	12	30	6	12	22	0.3	3.9	0.61	119.5	83.3596	41.657
2015	12	30	6	22	22	0.3	3.9	0.57	110.3	83.4252	41.95
2015	12	30	6	32	22	0.3	3.9	0.51	98.5	83.3596	39.5871
2015	12	30	6	42	22	0.3	3.9	0.42	88.6	83.294	32.833
2015	12	30	6	52	22	0.3	3.9	0.48	105.8	83.4252	36.5121
2015	12	30	7	2	22	0.3	3.9	0.48	119.4	83.3596	33.1186
2015	12	30	7	12	22	0.3	3.9	0.5	106.9	83.3596	37.5172
2015	12	30	7	22	22	0.3	3.9	0.36	108.3	83.3596	26.6501
2015	12	30	7	32	22	0.3	3.9	0.64	115.1	83.3596	45.7968
2015	12	30	7	42	22	0.3	3.9	0.66	114	83.294	47.5691
2015	12	30	7	52	22	0.3	3.9	0.69	114	83.3596	49.9366
2015	12	30	8	2	22	0.3	3.9	0.42	97.2	83.294	32.833
2015	12	30	8	12	22	0.3	3.9	0.55	109.2	83.294	40.8473
2015	12	30	8	22	22	0.3	3.9	0.45	99.7	83.4252	34.9583
2015	12	30	8	32	22	0.3	3.9	0.58	104.1	83.294	44.2081
2015	12	30	8	42	22	0.3	3.9	0.53	102.8	83.2284	41.0722
2015	12	30	8	52	22	0.3	3.9	0.55	105.4	83.3596	42.1743
2015	12	30	9	2	22	0.3	3.9	0.84	104.1	83.3596	63.9083
2015	12	30	9	12	22	0.3	3.9	0.87	100.9	83.3596	67.0131

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	9	22	22	0.3	3.9	0.75	112.9	83.4252	54.6382
2015	12	30	9	32	22	0.3	3.9	0.67	119.2	83.3596	46.314
2015	12	30	9	42	22	0.3	3.9	0.65	112	83.294	47.3102
2015	12	30	9	52	22	0.3	3.9	0.61	100.2	83.3596	47.6076
2015	12	30	10	2	22	0.3	3.9	0.4	110.5	83.294	29.7304
2015	12	30	10	12	22	0.3	3.9	0.58	105.4	83.294	44.2079
2015	12	30	10	22	22	0.3	3.9	0.37	115	83.3596	26.1324
2015	12	30	10	32	22	0.3	3.9	0.62	111.9	83.294	44.9834
2015	12	30	10	42	22	0.3	3.9	0.48	102.6	83.0971	36.8784
2015	12	30	10	52	22	0.3	3.9	0.67	85.5	83.0971	52.3518
2015	12	30	11	2	22	0.3	3.9	0.67	104.6	83.0971	51.3203
2015	12	30	11	12	22	0.3	3.9	0.6	113.2	83.2284	43.3967
2015	12	30	11	22	22	0.3	3.9	0.75	107.3	83.2284	56.3124
2015	12	30	11	32	22	0.3	3.9	0.66	95.5	83.1627	51.3623
2015	12	30	11	42	22	0.3	3.9	0.59	108.3	83.2284	44.4299
2015	12	30	11	52	22	0.3	3.9	0.54	114.6	83.3596	39.0691
2015	12	30	12	2	22	0.3	3.9	0.43	133.2	83.294	24.8183
2015	12	30	12	12	22	0.3	3.9	0.67	107.6	83.1627	50.3298
2015	12	30	12	22	22	0.3	3.9	0.52	120.1	83.2284	35.6472
2015	12	30	12	32	22	0.3	3.9	0.47	96.8	83.1627	36.6504
2015	12	30	12	42	22	0.3	3.9	0.6	118.9	83.294	41.6225
2015	12	30	12	52	22	0.3	3.9	0.78	123.6	83.2284	51.4044
2015	12	30	13	2	22	0.3	3.9	0.87	100.7	83.2284	67.1616
2015	12	30	13	12	22	0.3	3.9	0.7	104.9	83.1627	53.4272
2015	12	30	13	22	22	0.3	3.9	0.51	110.8	83.0315	37.3635
2015	12	30	13	32	22	0.3	3.9	0.63	131	83.0315	37.1058
2015	12	30	13	42	22	0.3	3.9	0.5	123.2	83.1627	32.779
2015	12	30	13	52	22	0.3	3.9	0.51	123.2	83.0971	33.5258
2015	12	30	14	2	22	0.3	3.9	0.59	107	83.0971	44.6152
2015	12	30	14	12	22	0.3	3.9	0.57	112.3	83.3596	41.6568
2015	12	30	14	33	46	0.3	3	0.66	102.7	83.294	50.6712
2015	12	30	14	43	46	0.3	3	0.66	105.8	83.294	50.1542
2015	12	30	14	53	46	0.3	3	0.68	102	83.294	52.4809
2015	12	30	15	3	46	0.3	3	0.65	102.3	83.2284	49.8549
2015	12	30	15	13	46	0.3	3	0.65	103.5	83.2284	49.5967
2015	12	30	15	23	46	0.3	3	0.65	103.3	83.1627	50.0723
2015	12	30	15	33	46	0.3	3	0.65	101.6	83.2284	50.3717
2015	12	30	15	43	46	0.3	3	0.6	105.3	83.1627	45.4264
2015	12	30	15	53	46	0.3	3	0.64	100	83.1627	49.8142
2015	12	30	16	3	46	0.3	3	0.67	101	83.1627	51.8791
2015	12	30	16	13	46	0.3	3	0.65	104.3	83.1627	49.5561
2015	12	30	16	23	46	0.3	3	0.67	105.1	83.1627	50.8467
2015	12	30	16	33	46	0.3	3	0.67	102.7	83.1627	51.621
2015	12	30	16	43	46	0.3	3	0.66	104.2	83.1627	50.0724
2015	12	30	16	53	46	0.3	3	0.67	101	83.1627	51.8791
2015	12	30	17	3	46	0.3	3	0.63	104.8	83.1627	48.0075

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	17	13	46	0.3	3	0.67	102.7	83.0971	51.3208
2015	12	30	17	23	46	0.3	3.9	0.64	102.5	83.1627	49.04
2015	12	30	17	33	46	0.3	3	0.67	100.7	83.2284	51.9216
2015	12	30	17	43	46	0.3	3.9	0.56	120.5	83.2284	37.7142
2015	12	30	17	53	46	0.3	3	0.64	101.8	83.1627	49.5562
2015	12	30	18	3	46	0.3	3	0.67	103.8	83.1627	51.3629
2015	12	30	18	13	46	0.3	3	0.67	105.1	83.2284	50.8884
2015	12	30	18	23	46	0.3	3	0.64	104.5	83.2284	48.8218
2015	12	30	18	33	46	0.3	3	0.65	104	83.1627	49.8143
2015	12	30	18	43	46	0.3	3	0.65	101	83.2284	50.3717
2015	12	30	18	53	46	0.3	3	0.66	105.3	83.0971	50.0314
2015	12	30	19	3	46	0.3	3	0.67	101.9	83.0971	51.5787
2015	12	30	19	13	46	0.3	3	0.66	104	83.0971	50.5472
2015	12	30	19	23	46	0.3	3	0.62	101.4	83.0971	47.4524
2015	12	30	19	33	46	0.3	3.9	0.59	114	83.0971	42.2946
2015	12	30	19	43	46	0.3	3	0.65	103.2	83.1627	49.5562
2015	12	30	19	53	46	0.3	3	0.64	102.3	83.1627	49.5562
2015	12	30	20	3	46	0.3	3	0.64	104.3	83.2284	48.8218
2015	12	30	20	13	46	0.3	3	0.64	103.3	83.2284	49.0802
2015	12	30	20	23	46	0.3	3	0.66	102.1	83.294	50.6715
2015	12	30	20	33	46	0.3	3	0.67	100.4	83.294	52.2227
2015	12	30	20	43	46	0.3	3	0.65	102.2	83.2284	50.1134
2015	12	30	20	53	46	0.3	3	0.65	103.5	83.294	49.6374
2015	12	30	21	3	46	0.3	3	0.64	102.5	83.2284	48.8218
2015	12	30	21	13	46	0.3	3	0.68	104.6	83.2284	51.6633
2015	12	30	21	23	46	0.3	3	0.61	104.3	83.1627	46.717
2015	12	30	21	33	46	0.3	3.9	0.65	103.5	83.4252	49.7186
2015	12	30	21	43	46	0.3	3	0.69	104.1	83.294	52.4812
2015	12	30	21	53	46	0.3	3	0.65	104.9	83.294	49.6374
2015	12	30	22	3	46	0.3	3	0.66	102.1	83.294	50.6715
2015	12	30	22	13	46	0.3	3	0.68	104.8	83.2284	51.6633
2015	12	30	22	23	46	0.3	3	0.66	103	83.294	50.413
2015	12	30	22	33	46	0.3	3	0.66	104	83.1627	50.5886
2015	12	30	22	43	46	0.3	3	0.64	103.6	83.294	49.1203
2015	12	30	22	53	46	0.3	3	0.68	106.6	83.1627	51.1048
2015	12	30	23	3	46	0.3	3	0.66	102.4	83.294	50.413
2015	12	30	23	13	46	0.3	3	0.71	100.4	83.294	54.808
2015	12	30	23	23	46	0.3	3	0.65	102.6	83.2284	49.5968
2015	12	30	23	33	46	0.3	3	0.66	101.7	83.294	51.1886
2015	12	30	23	43	46	0.3	3	0.68	100.6	83.2284	52.4383
2015	12	30	23	53	46	0.3	3	0.64	101.5	83.294	49.3789
2015	12	31	0	3	46	0.3	3	0.66	104.1	83.2284	50.3717
2015	12	31	0	13	46	0.3	3	0.66	103.8	83.294	50.6715
2015	12	31	0	23	46	0.3	3	0.65	103.1	83.2284	49.8551
2015	12	31	0	33	46	0.3	3	0.66	101.8	83.2284	50.6301
2015	12	31	0	43	46	0.3	3	0.65	103.8	83.2284	49.5968

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	0	53	46	0.3	3	0.65	100.7	83.2284	50.3717
2015	12	31	1	3	46	0.3	3	0.62	103.7	83.2284	47.5303
2015	12	31	1	13	46	0.3	3	0.67	102.5	83.1627	51.3629
2015	12	31	1	23	46	0.3	3	0.7	105	83.2284	52.9549
2015	12	31	1	33	46	0.3	3	0.63	102.7	83.2284	48.0469
2015	12	31	1	43	46	0.3	3	0.67	102.5	83.2284	51.405
2015	12	31	1	53	46	0.3	3	0.68	105.2	83.2284	51.405
2015	12	31	2	3	46	0.3	3	0.67	104.4	83.2284	51.405
2015	12	31	2	13	46	0.3	3	0.64	102.3	83.2284	49.5968
2015	12	31	2	23	46	0.3	3	0.66	102.4	83.1627	50.5886
2015	12	31	2	33	46	0.3	3	0.65	103.3	83.294	50.1545
2015	12	31	2	43	46	0.3	3	0.66	102.7	83.1627	50.5886
2015	12	31	2	53	46	0.3	3	0.66	104.1	83.2284	50.3717
2015	12	31	3	3	46	0.3	3	0.64	102.1	83.1627	49.5562
2015	12	31	3	13	46	0.3	3	0.65	103.8	83.1627	49.2981
2015	12	31	3	23	46	0.3	3	0.67	103.8	83.2284	51.405
2015	12	31	3	33	46	0.3	3	0.61	102.8	83.1627	46.717
2015	12	31	3	43	46	0.3	3	0.66	103.2	83.2284	50.6301
2015	12	31	3	53	46	0.3	3	0.7	102.2	83.2284	53.7299
2015	12	31	4	3	46	0.3	3	0.64	103.1	83.1627	48.7819
2015	12	31	4	13	46	0.3	3	0.68	104.9	83.2284	51.405
2015	12	31	4	23	46	0.3	3	0.67	104.2	83.0971	50.8051
2015	12	31	4	33	46	0.3	3	0.69	102.4	83.1627	52.6535
2015	12	31	4	43	46	0.3	3	0.62	102.9	83.1627	47.2333
2015	12	31	4	53	46	0.3	3	0.67	101.3	83.0971	51.8366
2015	12	31	5	3	46	0.3	3	0.66	102.6	83.2284	50.8884
2015	12	31	5	13	46	0.3	3	0.67	102.1	83.0971	51.8366
2015	12	31	5	23	46	0.3	3	0.67	103.3	83.0971	51.3208
2015	12	31	5	33	46	0.3	3	0.67	101.6	83.1627	51.3629
2015	12	31	5	43	46	0.3	3	0.68	104.8	83.0971	51.5787
2015	12	31	5	53	46	0.3	3	0.63	101.7	83.1627	48.7819
2015	12	31	6	3	46	0.3	3	0.71	103	83.0971	54.6735
2015	12	31	6	13	46	0.3	3	0.64	100.7	83.0971	49.2577
2015	12	31	6	23	46	0.3	3	0.69	103.4	83.1627	52.9116
2015	12	31	6	33	46	0.3	3	0.64	103.5	83.0971	49.2577
2015	12	31	6	43	46	0.3	3	0.68	100.8	83.1627	52.9116
2015	12	31	6	53	46	0.3	3	0.66	102.4	83.0971	50.5472
2015	12	31	7	3	46	0.3	3	0.65	103.5	83.0971	49.5156
2015	12	31	7	13	46	0.3	3	0.69	101.3	83.1627	53.1697
2015	12	31	7	23	46	0.3	3	0.64	103.6	83.0971	48.9998
2015	12	31	7	33	46	0.3	3	0.67	101.9	83.1627	51.3629
2015	12	31	7	43	46	0.3	3	0.65	103.3	83.1627	50.0724
2015	12	31	7	53	46	0.3	3	0.64	101.8	83.0971	49.5156
2015	12	31	8	3	46	0.3	3	0.65	98.4	83.2284	50.8884
2015	12	31	8	13	46	0.3	3	0.65	99.8	83.2284	50.63
2015	12	31	8	23	46	0.3	3	0.69	102.4	83.1627	52.9115

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	8	33	46	0.3	3	0.64	105.8	83.1627	48.2656
2015	12	31	8	43	46	0.3	3	0.7	105.3	83.2284	52.9548
2015	12	31	8	53	46	0.3	3	0.66	103.1	83.2284	50.8883
2015	12	31	9	3	46	0.3	3	0.69	103.6	83.2284	52.4382
2015	12	31	9	13	46	0.3	3	0.67	101	83.2284	51.9215
2015	12	31	9	23	46	0.3	3	0.66	102.1	83.2284	50.6299
2015	12	31	9	33	46	0.3	3	0.65	102.2	83.1627	50.0723
2015	12	31	9	43	46	0.3	3	0.67	103.1	83.2284	51.1465
2015	12	31	9	53	46	0.3	3	0.64	104.5	83.1627	49.0398
2015	12	31	10	3	46	0.3	3	0.67	103.1	83.1627	51.1046
2015	12	31	10	13	46	0.3	3	0.68	102.9	83.0971	51.8364
2015	12	31	10	23	46	0.3	3	0.62	103.4	83.0315	47.671
2015	12	31	10	33	46	0.3	3	0.7	100.5	83.0971	54.1574
2015	12	31	10	43	46	0.3	3	0.66	100.3	82.9659	51.2364
2015	12	31	10	53	46	0.3	3	0.66	102.9	82.8347	50.6382
2015	12	31	11	3	46	0.3	3	0.66	103	82.8347	50.1241
2015	12	31	11	13	46	0.3	3	0.63	99.3	82.8347	48.8388
2015	12	31	11	23	46	0.3	3	0.64	103.6	82.9003	48.879
2015	12	31	11	33	46	0.3	3	0.66	105.1	82.769	49.5692
2015	12	31	11	43	46	0.3	3	0.66	106.2	82.8347	49.61
2015	12	31	11	53	46	0.3	3	0.65	103.1	82.9003	49.908
2015	12	31	12	3	46	0.3	3	0.64	102.5	82.8347	48.5818
2015	12	31	12	13	46	0.3	3	0.66	103.2	82.9659	50.464
2015	12	31	12	23	46	0.3	3	0.63	103.3	82.769	47.7713
2015	12	31	12	33	46	0.3	3	0.64	102.8	82.8347	48.8388
2015	12	31	12	43	46	0.3	3	0.69	104.3	82.9003	52.4806
2015	12	31	12	53	46	0.3	3	0.68	105	82.9003	51.7089
2015	12	31	13	3	46	0.3	3	0.67	103.3	82.9659	51.2364
2015	12	31	13	13	46	0.3	3	0.64	102.1	82.8347	49.0959
2015	12	31	13	23	46	0.3	3	0.67	104.4	82.8347	50.8952
2015	12	31	13	33	46	0.3	3	0.67	106	82.8347	50.1241
2015	12	31	13	43	46	0.3	3	0.66	101.1	82.9659	50.979
2015	12	31	13	53	46	0.3	3	0.66	103.2	82.9003	50.4226
2015	12	31	14	3	46	0.3	3	0.66	101.8	82.9003	50.4226
2015	12	31	14	13	46	0.3	3	0.65	103.1	82.9659	49.9491
2015	12	31	14	23	46	0.3	3	0.63	103.2	82.9003	48.3646
2015	12	31	14	33	46	0.3	3	0.66	104.3	82.8347	50.3812
2015	12	31	14	43	46	0.3	3	0.64	104	82.9003	48.6219
2015	12	31	14	53	46	0.3	3	0.67	101.6	83.0315	51.2786
2015	12	31	15	3	46	0.3	3	0.65	103.1	82.8347	49.6101
2015	12	31	15	13	46	0.3	3	0.63	104.2	82.9003	47.8501
2015	12	31	15	23	46	0.3	3	0.65	104.2	82.8347	49.6102
2015	12	31	15	33	46	0.3	3	0.68	98.6	82.8347	52.4377
2015	12	31	15	43	46	0.3	3	0.65	101	83.0315	50.248
2015	12	31	15	53	46	0.3	3	0.65	104.2	83.0315	49.7326
2015	12	31	16	3	46	0.3	3	0.7	100	82.8347	53.98

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	16	13	46	0.3	3	0.64	103.7	83.1627	48.7818
2015	12	31	16	23	46	0.3	3	0.64	103.5	83.0971	49.2577
2015	12	31	16	33	46	0.3	3	0.63	104	83.0971	47.7103
2015	12	31	16	43	46	0.3	3	0.65	102.9	83.0315	49.475
2015	12	31	16	53	46	0.3	3	0.63	103.8	82.8347	48.0679
2015	12	31	17	3	46	0.3	3	0.65	101.4	82.9003	49.9083
2015	12	31	17	13	46	0.3	3	0.67	103.1	82.9659	50.9792
2015	12	31	17	23	46	0.3	3	0.66	104.5	83.0971	50.0314
2015	12	31	17	33	46	0.3	3	0.64	101.2	82.9659	49.4344
2015	12	31	17	43	46	0.3	3	0.62	102.8	82.769	47.5147
2015	12	31	17	53	46	0.3	3	0.65	102.9	82.8347	49.3532
2015	12	31	18	3	46	0.3	3	0.67	104.4	83.0971	51.0629
2015	12	31	18	13	46	0.3	3	0.65	100.1	82.9003	50.4228
2015	12	31	18	23	46	0.3	3	0.67	102.7	82.8347	51.4096
2015	12	31	18	33	46	0.3	3	0.7	102.8	82.9659	53.2964
2015	12	31	18	43	46	0.3	3	0.64	103.5	83.0971	49.2577
2015	12	31	18	53	46	0.3	3	0.68	102	82.8347	52.1807
2015	12	31	19	3	46	0.3	3	0.68	104.2	82.769	51.6241
2015	12	31	19	13	46	0.3	3	0.68	101.7	83.0315	52.0518
2015	12	31	19	23	46	0.3	3	0.65	103.3	83.0971	50.0314
2015	12	31	19	33	46	0.3	3	0.64	102.8	82.769	48.5421
2015	12	31	19	43	46	0.3	3	0.66	102.1	82.8347	50.3814
2015	12	31	19	53	46	0.3	3	0.66	101.2	83.1627	50.8467
2015	12	31	20	3	46	0.3	3	0.65	103.3	82.9003	49.9083
2015	12	31	20	13	46	0.3	3	0.65	99.8	82.769	50.3399
2015	12	31	20	23	46	0.3	3	0.66	104.3	82.8347	50.3814
2015	12	31	20	33	46	0.3	3	0.67	104.8	83.0315	50.7634
2015	12	31	20	43	46	0.3	3	0.64	102.8	82.769	48.5421
2015	12	31	20	53	46	0.3	3	0.68	101.5	82.769	51.8809
2015	12	31	21	3	46	0.3	3	0.67	102.7	82.9659	51.4942
2015	12	31	21	13	46	0.3	3	0.65	100.7	82.7034	50.0419
2015	12	31	21	23	46	0.3	3	0.68	102.2	82.769	52.3946
2015	12	31	21	33	46	0.3	3	0.69	102.3	82.9003	52.9954
2015	12	31	21	43	46	0.3	3	0.62	105.7	82.769	46.4874
2015	12	31	21	53	46	0.3	3	0.64	102.5	82.769	48.5421
2015	12	31	22	3	46	0.3	3	0.7	104.9	82.8347	53.2089
2015	12	31	22	13	46	0.3	3	0.66	101.5	82.769	50.3399
2015	12	31	22	23	46	0.3	3	0.64	101.5	82.769	49.3126
2015	12	31	22	33	46	0.3	3	0.65	105.6	82.8347	48.8391
2015	12	31	22	43	46	0.3	3	0.68	101.4	82.7034	52.0949
2015	12	31	22	53	46	0.3	3	0.67	100.5	82.769	51.3673
2015	12	31	23	3	46	0.3	3	0.66	101.8	82.8347	50.3814
2015	12	31	23	13	46	0.3	3	0.64	103.7	82.769	48.5421
2015	12	31	23	23	46	0.3	3	0.66	99.1	82.769	51.3673
2015	12	31	23	33	46	0.3	3	0.66	99.2	82.9003	50.9373
2015	12	31	23	43	46	0.3	3	0.64	101.8	82.769	49.3126

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	23	53	46	0.3	3	0.66	102	82.769	50.8536

Locust Ditch Return

Station	0215
Date	
12/1/2015	4.592
12/2/2015	4.997
12/3/2015	5.644
12/4/2015	5.678
12/5/2015	4.108
12/6/2015	0.003
12/7/2015	0
12/8/2015	0
12/9/2015	0
12/10/2015	0
12/11/2015	0
12/12/2015	0
12/13/2015	0
12/14/2015	0
12/15/2015	0
12/16/2015	0
12/17/2015	0
12/18/2015	0
12/19/2015	0
12/20/2015	0
12/21/2015	0
12/22/2015	0
12/23/2015	0
12/24/2015	0
12/25/2015	0
12/26/2015	0
12/27/2015	0
12/28/2015	0
12/29/2015	0
12/30/2015	0
12/31/2015	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	12:00:00 AM	0.41
12/1/2015	12:15:00 AM	0.41
12/1/2015	12:30:00 AM	0.41
12/1/2015	12:45:00 AM	0.41
12/1/2015	1:00:00 AM	0.41
12/1/2015	1:15:00 AM	0.41
12/1/2015	1:30:00 AM	0.41
12/1/2015	1:45:00 AM	0.41
12/1/2015	2:00:00 AM	0.41
12/1/2015	2:15:00 AM	0.41
12/1/2015	2:30:00 AM	0.41
12/1/2015	2:45:00 AM	0.41
12/1/2015	3:00:00 AM	0.41
12/1/2015	3:15:00 AM	0.41
12/1/2015	3:30:00 AM	0.41
12/1/2015	3:45:00 AM	0.41
12/1/2015	4:00:00 AM	0.41
12/1/2015	4:15:00 AM	0.41
12/1/2015	4:30:00 AM	0.41
12/1/2015	4:45:00 AM	0.41
12/1/2015	5:00:00 AM	0.41
12/1/2015	5:15:00 AM	0.41
12/1/2015	5:30:00 AM	0.41
12/1/2015	5:45:00 AM	0.41
12/1/2015	6:00:00 AM	0.41
12/1/2015	6:15:00 AM	0.41
12/1/2015	6:30:00 AM	0.41
12/1/2015	6:45:00 AM	0.41
12/1/2015	7:00:00 AM	0.41
12/1/2015	7:15:00 AM	0.41
12/1/2015	7:30:00 AM	0.41
12/1/2015	7:45:00 AM	0.41
12/1/2015	8:00:00 AM	0.41
12/1/2015	8:15:00 AM	0.41
12/1/2015	8:30:00 AM	0.41
12/1/2015	8:45:00 AM	0.41
12/1/2015	9:00:00 AM	0.41
12/1/2015	9:15:00 AM	0.41
12/1/2015	9:30:00 AM	0.41
12/1/2015	9:45:00 AM	0.41
12/1/2015	10:00:00 AM	0.41
12/1/2015	10:15:00 AM	0.41
12/1/2015	10:30:00 AM	0.41
12/1/2015	10:45:00 AM	0.41
12/1/2015	11:00:00 AM	0.41
12/1/2015	11:15:00 AM	0.41

Locust Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	11:30:00 AM	0.42
12/1/2015	11:45:00 AM	0.42
12/1/2015	12:00:00 PM	0.43
12/1/2015	12:15:00 PM	0.43
12/1/2015	12:30:00 PM	0.43
12/1/2015	12:45:00 PM	0.43
12/1/2015	1:00:00 PM	0.44
12/1/2015	1:15:00 PM	0.43
12/1/2015	1:30:00 PM	0.44
12/1/2015	1:45:00 PM	0.43
12/1/2015	2:00:00 PM	0.43
12/1/2015	2:15:00 PM	0.43
12/1/2015	2:30:00 PM	0.43
12/1/2015	2:45:00 PM	0.43
12/1/2015	3:00:00 PM	0.43
12/1/2015	3:15:00 PM	0.43
12/1/2015	3:30:00 PM	0.43
12/1/2015	3:45:00 PM	0.43
12/1/2015	4:00:00 PM	0.43
12/1/2015	4:15:00 PM	0.43
12/1/2015	4:30:00 PM	0.43
12/1/2015	4:45:00 PM	0.43
12/1/2015	5:00:00 PM	0.43
12/1/2015	5:15:00 PM	0.43
12/1/2015	5:30:00 PM	0.43
12/1/2015	5:45:00 PM	0.43
12/1/2015	6:00:00 PM	0.43
12/1/2015	6:15:00 PM	0.43
12/1/2015	6:30:00 PM	0.43
12/1/2015	6:45:00 PM	0.43
12/1/2015	7:00:00 PM	0.43
12/1/2015	7:15:00 PM	0.43
12/1/2015	7:30:00 PM	0.43
12/1/2015	7:45:00 PM	0.43
12/1/2015	8:00:00 PM	0.43
12/1/2015	8:15:00 PM	0.43
12/1/2015	8:30:00 PM	0.43
12/1/2015	8:45:00 PM	0.43
12/1/2015	9:00:00 PM	0.43
12/1/2015	9:15:00 PM	0.43
12/1/2015	9:30:00 PM	0.43
12/1/2015	9:45:00 PM	0.43
12/1/2015	10:00:00 PM	0.43
12/1/2015	10:15:00 PM	0.43
12/1/2015	10:30:00 PM	0.43
12/1/2015	10:45:00 PM	0.43

Locust Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	11:00:00 PM	0.43
12/1/2015	11:15:00 PM	0.43
12/1/2015	11:30:00 PM	0.43
12/1/2015	11:45:00 PM	0.43
12/2/2015	12:00:00 AM	0.43
12/2/2015	12:15:00 AM	0.43
12/2/2015	12:30:00 AM	0.43
12/2/2015	12:45:00 AM	0.43
12/2/2015	1:00:00 AM	0.43
12/2/2015	1:15:00 AM	0.43
12/2/2015	1:30:00 AM	0.43
12/2/2015	1:45:00 AM	0.43
12/2/2015	2:00:00 AM	0.43
12/2/2015	2:15:00 AM	0.43
12/2/2015	2:30:00 AM	0.43
12/2/2015	2:45:00 AM	0.43
12/2/2015	3:00:00 AM	0.43
12/2/2015	3:15:00 AM	0.43
12/2/2015	3:30:00 AM	0.43
12/2/2015	3:45:00 AM	0.43
12/2/2015	4:00:00 AM	0.43
12/2/2015	4:15:00 AM	0.43
12/2/2015	4:30:00 AM	0.43
12/2/2015	4:45:00 AM	0.43
12/2/2015	5:00:00 AM	0.43
12/2/2015	5:15:00 AM	0.43
12/2/2015	5:30:00 AM	0.43
12/2/2015	5:45:00 AM	0.43
12/2/2015	6:00:00 AM	0.43
12/2/2015	6:15:00 AM	0.43
12/2/2015	6:30:00 AM	0.43
12/2/2015	6:45:00 AM	0.43
12/2/2015	7:00:00 AM	0.43
12/2/2015	7:15:00 AM	0.43
12/2/2015	7:30:00 AM	0.43
12/2/2015	7:45:00 AM	0.43
12/2/2015	8:00:00 AM	0.43
12/2/2015	8:15:00 AM	0.43
12/2/2015	8:30:00 AM	0.43
12/2/2015	8:45:00 AM	0.43
12/2/2015	9:00:00 AM	0.43
12/2/2015	9:15:00 AM	0.43
12/2/2015	9:30:00 AM	0.43
12/2/2015	9:45:00 AM	0.43
12/2/2015	10:00:00 AM	0.43
12/2/2015	10:15:00 AM	0.43

Locust Ditch Return Gage

DATE	TIME	GAGE
12/2/2015	10:30:00 AM	0.43
12/2/2015	10:45:00 AM	0.43
12/2/2015	11:00:00 AM	0.43
12/2/2015	11:15:00 AM	0.43
12/2/2015	11:30:00 AM	0.43
12/2/2015	11:45:00 AM	0.43
12/2/2015	12:00:00 PM	0.43
12/2/2015	12:15:00 PM	0.43
12/2/2015	12:30:00 PM	0.43
12/2/2015	12:45:00 PM	0.43
12/2/2015	1:00:00 PM	0.43
12/2/2015	1:15:00 PM	0.43
12/2/2015	1:30:00 PM	0.43
12/2/2015	1:45:00 PM	0.43
12/2/2015	2:00:00 PM	0.43
12/2/2015	2:15:00 PM	0.43
12/2/2015	2:30:00 PM	0.43
12/2/2015	2:45:00 PM	0.43
12/2/2015	3:00:00 PM	0.43
12/2/2015	3:15:00 PM	0.43
12/2/2015	3:30:00 PM	0.43
12/2/2015	3:45:00 PM	0.43
12/2/2015	4:00:00 PM	0.43
12/2/2015	4:15:00 PM	0.44
12/2/2015	4:30:00 PM	0.44
12/2/2015	4:45:00 PM	0.44
12/2/2015	5:00:00 PM	0.45
12/2/2015	5:15:00 PM	0.47
12/2/2015	5:30:00 PM	0.47
12/2/2015	5:45:00 PM	0.47
12/2/2015	6:00:00 PM	0.48
12/2/2015	6:15:00 PM	0.48
12/2/2015	6:30:00 PM	0.48
12/2/2015	6:45:00 PM	0.48
12/2/2015	7:00:00 PM	0.48
12/2/2015	7:15:00 PM	0.48
12/2/2015	7:30:00 PM	0.48
12/2/2015	7:45:00 PM	0.48
12/2/2015	8:00:00 PM	0.48
12/2/2015	8:15:00 PM	0.48
12/2/2015	8:30:00 PM	0.49
12/2/2015	8:45:00 PM	0.48
12/2/2015	9:00:00 PM	0.48
12/2/2015	9:15:00 PM	0.48
12/2/2015	9:30:00 PM	0.48
12/2/2015	9:45:00 PM	0.48

Locust Ditch Return Gage

DATE	TIME	GAGE
12/2/2015	10:00:00 PM	0.48
12/2/2015	10:15:00 PM	0.48
12/2/2015	10:30:00 PM	0.48
12/2/2015	10:45:00 PM	0.48
12/2/2015	11:00:00 PM	0.48
12/2/2015	11:15:00 PM	0.48
12/2/2015	11:30:00 PM	0.48
12/2/2015	11:45:00 PM	0.48
12/3/2015	12:00:00 AM	0.49
12/3/2015	12:15:00 AM	0.48
12/3/2015	12:30:00 AM	0.48
12/3/2015	12:45:00 AM	0.48
12/3/2015	1:00:00 AM	0.48
12/3/2015	1:15:00 AM	0.48
12/3/2015	1:30:00 AM	0.48
12/3/2015	1:45:00 AM	0.48
12/3/2015	2:00:00 AM	0.48
12/3/2015	2:15:00 AM	0.48
12/3/2015	2:30:00 AM	0.48
12/3/2015	2:45:00 AM	0.49
12/3/2015	3:00:00 AM	0.48
12/3/2015	3:15:00 AM	0.48
12/3/2015	3:30:00 AM	0.48
12/3/2015	3:45:00 AM	0.49
12/3/2015	4:00:00 AM	0.49
12/3/2015	4:15:00 AM	0.49
12/3/2015	4:30:00 AM	0.48
12/3/2015	4:45:00 AM	0.48
12/3/2015	5:00:00 AM	0.48
12/3/2015	5:15:00 AM	0.48
12/3/2015	5:30:00 AM	0.48
12/3/2015	5:45:00 AM	0.48
12/3/2015	6:00:00 AM	0.48
12/3/2015	6:15:00 AM	0.48
12/3/2015	6:30:00 AM	0.48
12/3/2015	6:45:00 AM	0.48
12/3/2015	7:00:00 AM	0.48
12/3/2015	7:15:00 AM	0.48
12/3/2015	7:30:00 AM	0.48
12/3/2015	7:45:00 AM	0.48
12/3/2015	8:00:00 AM	0.48
12/3/2015	8:15:00 AM	0.48
12/3/2015	8:30:00 AM	0.48
12/3/2015	8:45:00 AM	0.48
12/3/2015	9:00:00 AM	0.48
12/3/2015	9:15:00 AM	0.48

Locust Ditch Return Gage

DATE	TIME	GAGE
12/3/2015	9:30:00 AM	0.48
12/3/2015	9:45:00 AM	0.48
12/3/2015	10:00:00 AM	0.48
12/3/2015	10:15:00 AM	0.48
12/3/2015	10:30:00 AM	0.48
12/3/2015	10:45:00 AM	0.48
12/3/2015	11:00:00 AM	0.48
12/3/2015	11:15:00 AM	0.48
12/3/2015	11:30:00 AM	0.48
12/3/2015	11:45:00 AM	0.48
12/3/2015	12:00:00 PM	0.48
12/3/2015	12:15:00 PM	0.48
12/3/2015	12:30:00 PM	0.49
12/3/2015	12:45:00 PM	0.49
12/3/2015	1:00:00 PM	0.48
12/3/2015	1:15:00 PM	0.49
12/3/2015	1:30:00 PM	0.49
12/3/2015	1:45:00 PM	0.49
12/3/2015	2:00:00 PM	0.48
12/3/2015	2:15:00 PM	0.49
12/3/2015	2:30:00 PM	0.49
12/3/2015	2:45:00 PM	0.49
12/3/2015	3:00:00 PM	0.49
12/3/2015	3:15:00 PM	0.48
12/3/2015	3:30:00 PM	0.48
12/3/2015	3:45:00 PM	0.48
12/3/2015	4:00:00 PM	0.49
12/3/2015	4:15:00 PM	0.49
12/3/2015	4:30:00 PM	0.49
12/3/2015	4:45:00 PM	0.49
12/3/2015	5:00:00 PM	0.48
12/3/2015	5:15:00 PM	0.49
12/3/2015	5:30:00 PM	0.48
12/3/2015	5:45:00 PM	0.48
12/3/2015	6:00:00 PM	0.48
12/3/2015	6:15:00 PM	0.48
12/3/2015	6:30:00 PM	0.48
12/3/2015	6:45:00 PM	0.48
12/3/2015	7:00:00 PM	0.48
12/3/2015	7:15:00 PM	0.48
12/3/2015	7:30:00 PM	0.48
12/3/2015	7:45:00 PM	0.48
12/3/2015	8:00:00 PM	0.48
12/3/2015	8:15:00 PM	0.48
12/3/2015	8:30:00 PM	0.48
12/3/2015	8:45:00 PM	0.48

Locust Ditch Return Gage

DATE	TIME	GAGE
12/3/2015	9:00:00 PM	0.48
12/3/2015	9:15:00 PM	0.48
12/3/2015	9:30:00 PM	0.48
12/3/2015	9:45:00 PM	0.48
12/3/2015	10:00:00 PM	0.48
12/3/2015	10:15:00 PM	0.48
12/3/2015	10:30:00 PM	0.49
12/3/2015	10:45:00 PM	0.49
12/3/2015	11:00:00 PM	0.49
12/3/2015	11:15:00 PM	0.49
12/3/2015	11:30:00 PM	0.49
12/3/2015	11:45:00 PM	0.49
12/4/2015	12:00:00 AM	0.49
12/4/2015	12:15:00 AM	0.48
12/4/2015	12:30:00 AM	0.48
12/4/2015	12:45:00 AM	0.48
12/4/2015	1:00:00 AM	0.48
12/4/2015	1:15:00 AM	0.49
12/4/2015	1:30:00 AM	0.48
12/4/2015	1:45:00 AM	0.48
12/4/2015	2:00:00 AM	0.49
12/4/2015	2:15:00 AM	0.48
12/4/2015	2:30:00 AM	0.48
12/4/2015	2:45:00 AM	0.48
12/4/2015	3:00:00 AM	0.49
12/4/2015	3:15:00 AM	0.48
12/4/2015	3:30:00 AM	0.48
12/4/2015	3:45:00 AM	0.48
12/4/2015	4:00:00 AM	0.48
12/4/2015	4:15:00 AM	0.48
12/4/2015	4:30:00 AM	0.48
12/4/2015	4:45:00 AM	0.48
12/4/2015	5:00:00 AM	0.48
12/4/2015	5:15:00 AM	0.48
12/4/2015	5:30:00 AM	0.48
12/4/2015	5:45:00 AM	0.48
12/4/2015	6:00:00 AM	0.49
12/4/2015	6:15:00 AM	0.49
12/4/2015	6:30:00 AM	0.48
12/4/2015	6:45:00 AM	0.48
12/4/2015	7:00:00 AM	0.48
12/4/2015	7:15:00 AM	0.49
12/4/2015	7:30:00 AM	0.48
12/4/2015	7:45:00 AM	0.48
12/4/2015	8:00:00 AM	0.48
12/4/2015	8:15:00 AM	0.48

Locust Ditch Return Gage

DATE	TIME	GAGE
12/4/2015	8:30:00 AM	0.48
12/4/2015	8:45:00 AM	0.48
12/4/2015	9:00:00 AM	0.48
12/4/2015	9:15:00 AM	0.48
12/4/2015	9:30:00 AM	0.48
12/4/2015	9:45:00 AM	0.48
12/4/2015	10:00:00 AM	0.48
12/4/2015	10:15:00 AM	0.48
12/4/2015	10:30:00 AM	0.48
12/4/2015	10:45:00 AM	0.48
12/4/2015	11:00:00 AM	0.48
12/4/2015	11:15:00 AM	0.48
12/4/2015	11:30:00 AM	0.48
12/4/2015	11:45:00 AM	0.48
12/4/2015	12:00:00 PM	0.48
12/4/2015	12:15:00 PM	0.48
12/4/2015	12:30:00 PM	0.49
12/4/2015	12:45:00 PM	0.48
12/4/2015	1:00:00 PM	0.49
12/4/2015	1:15:00 PM	0.49
12/4/2015	1:30:00 PM	0.48
12/4/2015	1:45:00 PM	0.49
12/4/2015	2:00:00 PM	0.49
12/4/2015	2:15:00 PM	0.49
12/4/2015	2:30:00 PM	0.49
12/4/2015	2:45:00 PM	0.48
12/4/2015	3:00:00 PM	0.49
12/4/2015	3:15:00 PM	0.49
12/4/2015	3:30:00 PM	0.48
12/4/2015	3:45:00 PM	0.49
12/4/2015	4:00:00 PM	0.49
12/4/2015	4:15:00 PM	0.49
12/4/2015	4:30:00 PM	0.49
12/4/2015	4:45:00 PM	0.49
12/4/2015	5:00:00 PM	0.49
12/4/2015	5:15:00 PM	0.49
12/4/2015	5:30:00 PM	0.49
12/4/2015	5:45:00 PM	0.49
12/4/2015	6:00:00 PM	0.49
12/4/2015	6:15:00 PM	0.49
12/4/2015	6:30:00 PM	0.48
12/4/2015	6:45:00 PM	0.49
12/4/2015	7:00:00 PM	0.49
12/4/2015	7:15:00 PM	0.49
12/4/2015	7:30:00 PM	0.49
12/4/2015	7:45:00 PM	0.49

Locust Ditch Return Gage

DATE	TIME	GAGE
12/4/2015	8:00:00 PM	0.49
12/4/2015	8:15:00 PM	0.49
12/4/2015	8:30:00 PM	0.49
12/4/2015	8:45:00 PM	0.49
12/4/2015	9:00:00 PM	0.49
12/4/2015	9:15:00 PM	0.49
12/4/2015	9:30:00 PM	0.49
12/4/2015	9:45:00 PM	0.49
12/4/2015	10:00:00 PM	0.49
12/4/2015	10:15:00 PM	0.48
12/4/2015	10:30:00 PM	0.48
12/4/2015	10:45:00 PM	0.48
12/4/2015	11:00:00 PM	0.48
12/4/2015	11:15:00 PM	0.49
12/4/2015	11:30:00 PM	0.49
12/4/2015	11:45:00 PM	0.49
12/5/2015	12:00:00 AM	0.48
12/5/2015	12:15:00 AM	0.49
12/5/2015	12:30:00 AM	0.49
12/5/2015	12:45:00 AM	0.48
12/5/2015	1:00:00 AM	0.49
12/5/2015	1:15:00 AM	0.48
12/5/2015	1:30:00 AM	0.49
12/5/2015	1:45:00 AM	0.48
12/5/2015	2:00:00 AM	0.49
12/5/2015	2:15:00 AM	0.49
12/5/2015	2:30:00 AM	0.48
12/5/2015	2:45:00 AM	0.49
12/5/2015	3:00:00 AM	0.49
12/5/2015	3:15:00 AM	0.48
12/5/2015	3:30:00 AM	0.48
12/5/2015	3:45:00 AM	0.48
12/5/2015	4:00:00 AM	0.49
12/5/2015	4:15:00 AM	0.48
12/5/2015	4:30:00 AM	0.49
12/5/2015	4:45:00 AM	0.49
12/5/2015	5:00:00 AM	0.48
12/5/2015	5:15:00 AM	0.48
12/5/2015	5:30:00 AM	0.49
12/5/2015	5:45:00 AM	0.49
12/5/2015	6:00:00 AM	0.49
12/5/2015	6:15:00 AM	0.49
12/5/2015	6:30:00 AM	0.49
12/5/2015	6:45:00 AM	0.48
12/5/2015	7:00:00 AM	0.48
12/5/2015	7:15:00 AM	0.49

Locust Ditch Return Gage

DATE	TIME	GAGE
12/5/2015	7:30:00 AM	0.48
12/5/2015	7:45:00 AM	0.49
12/5/2015	8:00:00 AM	0.48
12/5/2015	8:15:00 AM	0.49
12/5/2015	8:30:00 AM	0.49
12/5/2015	8:45:00 AM	0.49
12/5/2015	9:00:00 AM	0.49
12/5/2015	9:15:00 AM	0.49
12/5/2015	9:30:00 AM	0.48
12/5/2015	9:45:00 AM	0.48
12/5/2015	10:00:00 AM	0.49
12/5/2015	10:15:00 AM	0.49
12/5/2015	10:30:00 AM	0.49
12/5/2015	10:45:00 AM	0.48
12/5/2015	11:00:00 AM	0.48
12/5/2015	11:15:00 AM	0.48
12/5/2015	11:30:00 AM	0.48
12/5/2015	11:45:00 AM	0.49
12/5/2015	12:00:00 PM	0.49
12/5/2015	12:15:00 PM	0.48
12/5/2015	12:30:00 PM	0.49
12/5/2015	12:45:00 PM	0.49
12/5/2015	1:00:00 PM	0.49
12/5/2015	1:15:00 PM	0.49
12/5/2015	1:30:00 PM	0.49
12/5/2015	1:45:00 PM	0.49
12/5/2015	2:00:00 PM	0.49
12/5/2015	2:15:00 PM	0.48
12/5/2015	2:30:00 PM	0.49
12/5/2015	2:45:00 PM	0.49
12/5/2015	3:00:00 PM	0.49
12/5/2015	3:15:00 PM	0.49
12/5/2015	3:30:00 PM	0.48
12/5/2015	3:45:00 PM	0.48
12/5/2015	4:00:00 PM	0.49
12/5/2015	4:15:00 PM	0.48
12/5/2015	4:30:00 PM	0.45
12/5/2015	4:45:00 PM	0.37
12/5/2015	5:00:00 PM	0.28
12/5/2015	5:15:00 PM	0.21
12/5/2015	5:30:00 PM	0.17
12/5/2015	5:45:00 PM	0.14
12/5/2015	6:00:00 PM	0.12
12/5/2015	6:15:00 PM	0.11
12/5/2015	6:30:00 PM	0.09
12/5/2015	6:45:00 PM	0.09

Locust Ditch Return Gage

DATE	TIME	GAGE
12/5/2015	7:00:00 PM	0.08
12/5/2015	7:15:00 PM	0.07
12/5/2015	7:30:00 PM	0.07
12/5/2015	7:45:00 PM	0.06
12/5/2015	8:00:00 PM	0.05
12/5/2015	8:15:00 PM	0.05
12/5/2015	8:30:00 PM	0.05
12/5/2015	8:45:00 PM	0.05
12/5/2015	9:00:00 PM	0.05
12/5/2015	9:15:00 PM	0.04
12/5/2015	9:30:00 PM	0.04
12/5/2015	9:45:00 PM	0.04
12/5/2015	10:00:00 PM	0.04
12/5/2015	10:15:00 PM	0.03
12/5/2015	10:30:00 PM	0.03
12/5/2015	10:45:00 PM	0.03
12/5/2015	11:00:00 PM	0.03
12/5/2015	11:15:00 PM	0.03
12/5/2015	11:30:00 PM	0.03
12/5/2015	11:45:00 PM	0.03
12/6/2015	12:00:00 AM	0.03
12/6/2015	12:15:00 AM	0.03
12/6/2015	12:30:00 AM	0.03
12/6/2015	12:45:00 AM	0.02
12/6/2015	1:00:00 AM	0.02
12/6/2015	1:15:00 AM	0.01
12/6/2015	1:30:00 AM	0
12/6/2015	1:45:00 AM	0
12/6/2015	2:00:00 AM	0
12/6/2015	2:15:00 AM	0
12/6/2015	2:30:00 AM	0
12/6/2015	2:45:00 AM	0
12/6/2015	3:00:00 AM	0
12/6/2015	3:15:00 AM	0
12/6/2015	3:30:00 AM	0
12/6/2015	3:45:00 AM	0
12/6/2015	4:00:00 AM	0
12/6/2015	4:15:00 AM	0
12/6/2015	4:30:00 AM	0
12/6/2015	4:45:00 AM	0
12/6/2015	5:00:00 AM	0
12/6/2015	5:15:00 AM	0
12/6/2015	5:30:00 AM	0
12/6/2015	5:45:00 AM	0
12/6/2015	6:00:00 AM	0
12/6/2015	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/6/2015	6:30:00 AM	0
12/6/2015	6:45:00 AM	0
12/6/2015	7:00:00 AM	0
12/6/2015	7:15:00 AM	0
12/6/2015	7:30:00 AM	0
12/6/2015	7:45:00 AM	0
12/6/2015	8:00:00 AM	0
12/6/2015	8:15:00 AM	0
12/6/2015	8:30:00 AM	0
12/6/2015	8:45:00 AM	0
12/6/2015	9:00:00 AM	0
12/6/2015	9:15:00 AM	0
12/6/2015	9:30:00 AM	0
12/6/2015	9:45:00 AM	0
12/6/2015	10:00:00 AM	0
12/6/2015	10:15:00 AM	0
12/6/2015	10:30:00 AM	0
12/6/2015	10:45:00 AM	0
12/6/2015	11:00:00 AM	0
12/6/2015	11:15:00 AM	0
12/6/2015	11:30:00 AM	0
12/6/2015	11:45:00 AM	0
12/6/2015	12:00:00 PM	0
12/6/2015	12:15:00 PM	0
12/6/2015	12:30:00 PM	0
12/6/2015	12:45:00 PM	0
12/6/2015	1:00:00 PM	0
12/6/2015	1:15:00 PM	0
12/6/2015	1:30:00 PM	0
12/6/2015	1:45:00 PM	0
12/6/2015	2:00:00 PM	0
12/6/2015	2:15:00 PM	0
12/6/2015	2:30:00 PM	0
12/6/2015	2:45:00 PM	0
12/6/2015	3:00:00 PM	0
12/6/2015	3:15:00 PM	0
12/6/2015	3:30:00 PM	0
12/6/2015	3:45:00 PM	0
12/6/2015	4:00:00 PM	0
12/6/2015	4:15:00 PM	0
12/6/2015	4:30:00 PM	0
12/6/2015	4:45:00 PM	0
12/6/2015	5:00:00 PM	0
12/6/2015	5:15:00 PM	0
12/6/2015	5:30:00 PM	0
12/6/2015	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/6/2015	6:00:00 PM	0
12/6/2015	6:15:00 PM	0
12/6/2015	6:30:00 PM	0
12/6/2015	6:45:00 PM	0
12/6/2015	7:00:00 PM	0
12/6/2015	7:15:00 PM	0
12/6/2015	7:30:00 PM	0
12/6/2015	7:45:00 PM	0
12/6/2015	8:00:00 PM	0
12/6/2015	8:15:00 PM	0
12/6/2015	8:30:00 PM	0
12/6/2015	8:45:00 PM	0
12/6/2015	9:00:00 PM	0
12/6/2015	9:15:00 PM	0
12/6/2015	9:30:00 PM	0
12/6/2015	9:45:00 PM	0
12/6/2015	10:00:00 PM	0
12/6/2015	10:15:00 PM	0
12/6/2015	10:30:00 PM	0
12/6/2015	10:45:00 PM	0
12/6/2015	11:00:00 PM	0
12/6/2015	11:15:00 PM	0
12/6/2015	11:30:00 PM	0
12/6/2015	11:45:00 PM	0
12/7/2015	12:00:00 AM	0
12/7/2015	12:15:00 AM	0
12/7/2015	12:30:00 AM	0
12/7/2015	12:45:00 AM	0
12/7/2015	1:00:00 AM	0
12/7/2015	1:15:00 AM	0
12/7/2015	1:30:00 AM	0
12/7/2015	1:45:00 AM	0
12/7/2015	2:00:00 AM	0
12/7/2015	2:15:00 AM	0
12/7/2015	2:30:00 AM	0
12/7/2015	2:45:00 AM	0
12/7/2015	3:00:00 AM	0
12/7/2015	3:15:00 AM	0
12/7/2015	3:30:00 AM	0
12/7/2015	3:45:00 AM	0
12/7/2015	4:00:00 AM	0
12/7/2015	4:15:00 AM	0
12/7/2015	4:30:00 AM	0
12/7/2015	4:45:00 AM	0
12/7/2015	5:00:00 AM	0
12/7/2015	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/7/2015	5:30:00 AM	0
12/7/2015	5:45:00 AM	0
12/7/2015	6:00:00 AM	0
12/7/2015	6:15:00 AM	0
12/7/2015	6:30:00 AM	0
12/7/2015	6:45:00 AM	0
12/7/2015	7:00:00 AM	0
12/7/2015	7:15:00 AM	0
12/7/2015	7:30:00 AM	0
12/7/2015	7:45:00 AM	0
12/7/2015	8:00:00 AM	0
12/7/2015	8:15:00 AM	0
12/7/2015	8:30:00 AM	0
12/7/2015	8:45:00 AM	0
12/7/2015	9:00:00 AM	0
12/7/2015	9:15:00 AM	0
12/7/2015	9:30:00 AM	0
12/7/2015	9:45:00 AM	0
12/7/2015	10:00:00 AM	0
12/7/2015	10:15:00 AM	0
12/7/2015	10:30:00 AM	0
12/7/2015	10:45:00 AM	0
12/7/2015	11:00:00 AM	0
12/7/2015	11:15:00 AM	0
12/7/2015	11:30:00 AM	0
12/7/2015	11:45:00 AM	0
12/7/2015	12:00:00 PM	0
12/7/2015	12:15:00 PM	0
12/7/2015	12:30:00 PM	0
12/7/2015	12:45:00 PM	0
12/7/2015	1:00:00 PM	0
12/7/2015	1:15:00 PM	0
12/7/2015	1:30:00 PM	0
12/7/2015	1:45:00 PM	0
12/7/2015	2:00:00 PM	0
12/7/2015	2:15:00 PM	0
12/7/2015	2:30:00 PM	0
12/7/2015	2:45:00 PM	0
12/7/2015	3:00:00 PM	0
12/7/2015	3:15:00 PM	0
12/7/2015	3:30:00 PM	0
12/7/2015	3:45:00 PM	0
12/7/2015	4:00:00 PM	0
12/7/2015	4:15:00 PM	0
12/7/2015	4:30:00 PM	0
12/7/2015	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/7/2015	5:00:00 PM	0
12/7/2015	5:15:00 PM	0
12/7/2015	5:30:00 PM	0
12/7/2015	5:45:00 PM	0
12/7/2015	6:00:00 PM	0
12/7/2015	6:15:00 PM	0
12/7/2015	6:30:00 PM	0
12/7/2015	6:45:00 PM	0
12/7/2015	7:00:00 PM	0
12/7/2015	7:15:00 PM	0
12/7/2015	7:30:00 PM	0
12/7/2015	7:45:00 PM	0
12/7/2015	8:00:00 PM	0
12/7/2015	8:15:00 PM	0
12/7/2015	8:30:00 PM	0
12/7/2015	8:45:00 PM	0
12/7/2015	9:00:00 PM	0
12/7/2015	9:15:00 PM	0
12/7/2015	9:30:00 PM	0
12/7/2015	9:45:00 PM	0
12/7/2015	10:00:00 PM	0
12/7/2015	10:15:00 PM	0
12/7/2015	10:30:00 PM	0
12/7/2015	10:45:00 PM	0
12/7/2015	11:00:00 PM	0
12/7/2015	11:15:00 PM	0
12/7/2015	11:30:00 PM	0
12/7/2015	11:45:00 PM	0
12/8/2015	12:00:00 AM	0
12/8/2015	12:15:00 AM	0
12/8/2015	12:30:00 AM	0
12/8/2015	12:45:00 AM	0
12/8/2015	1:00:00 AM	0
12/8/2015	1:15:00 AM	0
12/8/2015	1:30:00 AM	0
12/8/2015	1:45:00 AM	0
12/8/2015	2:00:00 AM	0
12/8/2015	2:15:00 AM	0
12/8/2015	2:30:00 AM	0
12/8/2015	2:45:00 AM	0
12/8/2015	3:00:00 AM	0
12/8/2015	3:15:00 AM	0
12/8/2015	3:30:00 AM	0
12/8/2015	3:45:00 AM	0
12/8/2015	4:00:00 AM	0
12/8/2015	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/8/2015	4:30:00 AM	0
12/8/2015	4:45:00 AM	0
12/8/2015	5:00:00 AM	0
12/8/2015	5:15:00 AM	0
12/8/2015	5:30:00 AM	0
12/8/2015	5:45:00 AM	0
12/8/2015	6:00:00 AM	0
12/8/2015	6:15:00 AM	0
12/8/2015	6:30:00 AM	0
12/8/2015	6:45:00 AM	0
12/8/2015	7:00:00 AM	0
12/8/2015	7:15:00 AM	0
12/8/2015	7:30:00 AM	0
12/8/2015	7:45:00 AM	0
12/8/2015	8:00:00 AM	0
12/8/2015	8:15:00 AM	0
12/8/2015	8:30:00 AM	0
12/8/2015	8:45:00 AM	0
12/8/2015	9:00:00 AM	0
12/8/2015	9:15:00 AM	0
12/8/2015	9:30:00 AM	0
12/8/2015	9:45:00 AM	0
12/8/2015	10:00:00 AM	0
12/8/2015	10:15:00 AM	0
12/8/2015	10:30:00 AM	0
12/8/2015	10:45:00 AM	0
12/8/2015	11:00:00 AM	0
12/8/2015	11:15:00 AM	0
12/8/2015	11:30:00 AM	0
12/8/2015	11:45:00 AM	0
12/8/2015	12:00:00 PM	0
12/8/2015	12:15:00 PM	0
12/8/2015	12:30:00 PM	0
12/8/2015	12:45:00 PM	0
12/8/2015	1:00:00 PM	0
12/8/2015	1:15:00 PM	0
12/8/2015	1:30:00 PM	0
12/8/2015	1:45:00 PM	0
12/8/2015	2:00:00 PM	0
12/8/2015	2:15:00 PM	0
12/8/2015	2:30:00 PM	0
12/8/2015	2:45:00 PM	0
12/8/2015	3:00:00 PM	0
12/8/2015	3:15:00 PM	0
12/8/2015	3:30:00 PM	0
12/8/2015	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/8/2015	4:00:00 PM	0
12/8/2015	4:15:00 PM	0
12/8/2015	4:30:00 PM	0
12/8/2015	4:45:00 PM	0
12/8/2015	5:00:00 PM	0
12/8/2015	5:15:00 PM	0
12/8/2015	5:30:00 PM	0
12/8/2015	5:45:00 PM	0
12/8/2015	6:00:00 PM	0
12/8/2015	6:15:00 PM	0
12/8/2015	6:30:00 PM	0
12/8/2015	6:45:00 PM	0
12/8/2015	7:00:00 PM	0
12/8/2015	7:15:00 PM	0
12/8/2015	7:30:00 PM	0
12/8/2015	7:45:00 PM	0
12/8/2015	8:00:00 PM	0
12/8/2015	8:15:00 PM	0
12/8/2015	8:30:00 PM	0
12/8/2015	8:45:00 PM	0
12/8/2015	9:00:00 PM	0
12/8/2015	9:15:00 PM	0
12/8/2015	9:30:00 PM	0
12/8/2015	9:45:00 PM	0
12/8/2015	10:00:00 PM	0
12/8/2015	10:15:00 PM	0
12/8/2015	10:30:00 PM	0
12/8/2015	10:45:00 PM	0
12/8/2015	11:00:00 PM	0
12/8/2015	11:15:00 PM	0
12/8/2015	11:30:00 PM	0
12/8/2015	11:45:00 PM	0
12/9/2015	12:00:00 AM	0
12/9/2015	12:15:00 AM	0
12/9/2015	12:30:00 AM	0
12/9/2015	12:45:00 AM	0
12/9/2015	1:00:00 AM	0
12/9/2015	1:15:00 AM	0
12/9/2015	1:30:00 AM	0
12/9/2015	1:45:00 AM	0
12/9/2015	2:00:00 AM	0
12/9/2015	2:15:00 AM	0
12/9/2015	2:30:00 AM	0
12/9/2015	2:45:00 AM	0
12/9/2015	3:00:00 AM	0
12/9/2015	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/9/2015	3:30:00 AM	0
12/9/2015	3:45:00 AM	0
12/9/2015	4:00:00 AM	0
12/9/2015	4:15:00 AM	0
12/9/2015	4:30:00 AM	0
12/9/2015	4:45:00 AM	0
12/9/2015	5:00:00 AM	0
12/9/2015	5:15:00 AM	0
12/9/2015	5:30:00 AM	0
12/9/2015	5:45:00 AM	0
12/9/2015	6:00:00 AM	0
12/9/2015	6:15:00 AM	0
12/9/2015	6:30:00 AM	0
12/9/2015	6:45:00 AM	0
12/9/2015	7:00:00 AM	0
12/9/2015	7:15:00 AM	0
12/9/2015	7:30:00 AM	0
12/9/2015	7:45:00 AM	0
12/9/2015	8:00:00 AM	0
12/9/2015	8:15:00 AM	0
12/9/2015	8:30:00 AM	0
12/9/2015	8:45:00 AM	0
12/9/2015	9:00:00 AM	0
12/9/2015	9:15:00 AM	0
12/9/2015	9:30:00 AM	0
12/9/2015	9:45:00 AM	0
12/9/2015	10:00:00 AM	0
12/9/2015	10:15:00 AM	0
12/9/2015	10:30:00 AM	0
12/9/2015	10:45:00 AM	0
12/9/2015	11:00:00 AM	0
12/9/2015	11:15:00 AM	0
12/9/2015	11:30:00 AM	0
12/9/2015	11:45:00 AM	0
12/9/2015	12:00:00 PM	0
12/9/2015	12:15:00 PM	0
12/9/2015	12:30:00 PM	0
12/9/2015	12:45:00 PM	0
12/9/2015	1:00:00 PM	0
12/9/2015	1:15:00 PM	0
12/9/2015	1:30:00 PM	0
12/9/2015	1:45:00 PM	0
12/9/2015	2:00:00 PM	0
12/9/2015	2:15:00 PM	0
12/9/2015	2:30:00 PM	0
12/9/2015	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/9/2015	3:00:00 PM	0
12/9/2015	3:15:00 PM	0
12/9/2015	3:30:00 PM	0
12/9/2015	3:45:00 PM	0
12/9/2015	4:00:00 PM	0
12/9/2015	4:15:00 PM	0
12/9/2015	4:30:00 PM	0
12/9/2015	4:45:00 PM	0
12/9/2015	5:00:00 PM	0
12/9/2015	5:15:00 PM	0
12/9/2015	5:30:00 PM	0
12/9/2015	5:45:00 PM	0
12/9/2015	6:00:00 PM	0
12/9/2015	6:15:00 PM	0
12/9/2015	6:30:00 PM	0
12/9/2015	6:45:00 PM	0
12/9/2015	7:00:00 PM	0
12/9/2015	7:15:00 PM	0
12/9/2015	7:30:00 PM	0
12/9/2015	7:45:00 PM	0
12/9/2015	8:00:00 PM	0
12/9/2015	8:15:00 PM	0
12/9/2015	8:30:00 PM	0
12/9/2015	8:45:00 PM	0
12/9/2015	9:00:00 PM	0
12/9/2015	9:15:00 PM	0
12/9/2015	9:30:00 PM	0
12/9/2015	9:45:00 PM	0
12/9/2015	10:00:00 PM	0
12/9/2015	10:15:00 PM	0
12/9/2015	10:30:00 PM	0
12/9/2015	10:45:00 PM	0
12/9/2015	11:00:00 PM	0
12/9/2015	11:15:00 PM	0
12/9/2015	11:30:00 PM	0
12/9/2015	11:45:00 PM	0
12/10/2015	12:00:00 AM	0
12/10/2015	12:15:00 AM	0
12/10/2015	12:30:00 AM	0
12/10/2015	12:45:00 AM	0
12/10/2015	1:00:00 AM	0
12/10/2015	1:15:00 AM	0
12/10/2015	1:30:00 AM	0
12/10/2015	1:45:00 AM	0
12/10/2015	2:00:00 AM	0
12/10/2015	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/10/2015	2:30:00 AM	0
12/10/2015	2:45:00 AM	0
12/10/2015	3:00:00 AM	0
12/10/2015	3:15:00 AM	0
12/10/2015	3:30:00 AM	0
12/10/2015	3:45:00 AM	0
12/10/2015	4:00:00 AM	0
12/10/2015	4:15:00 AM	0
12/10/2015	4:30:00 AM	0
12/10/2015	4:45:00 AM	0
12/10/2015	5:00:00 AM	0
12/10/2015	5:15:00 AM	0
12/10/2015	5:30:00 AM	0
12/10/2015	5:45:00 AM	0
12/10/2015	6:00:00 AM	0
12/10/2015	6:15:00 AM	0
12/10/2015	6:30:00 AM	0
12/10/2015	6:45:00 AM	0
12/10/2015	7:00:00 AM	0
12/10/2015	7:15:00 AM	0
12/10/2015	7:30:00 AM	0
12/10/2015	7:45:00 AM	0
12/10/2015	8:00:00 AM	0
12/10/2015	8:15:00 AM	0
12/10/2015	8:30:00 AM	0
12/10/2015	8:45:00 AM	0
12/10/2015	9:00:00 AM	0
12/10/2015	9:15:00 AM	0
12/10/2015	9:30:00 AM	0
12/10/2015	9:45:00 AM	0
12/10/2015	10:00:00 AM	0
12/10/2015	10:15:00 AM	0
12/10/2015	10:30:00 AM	0
12/10/2015	10:45:00 AM	0
12/10/2015	11:00:00 AM	0
12/10/2015	11:15:00 AM	0
12/10/2015	11:30:00 AM	0
12/10/2015	11:45:00 AM	0
12/10/2015	12:00:00 PM	0
12/10/2015	12:15:00 PM	0
12/10/2015	12:30:00 PM	0
12/10/2015	12:45:00 PM	0
12/10/2015	1:00:00 PM	0
12/10/2015	1:15:00 PM	0
12/10/2015	1:30:00 PM	0
12/10/2015	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/10/2015	2:00:00 PM	0
12/10/2015	2:15:00 PM	0
12/10/2015	2:30:00 PM	0
12/10/2015	2:45:00 PM	0
12/10/2015	3:00:00 PM	0
12/10/2015	3:15:00 PM	0
12/10/2015	3:30:00 PM	0
12/10/2015	3:45:00 PM	0
12/10/2015	4:00:00 PM	0
12/10/2015	4:15:00 PM	0
12/10/2015	4:30:00 PM	0
12/10/2015	4:45:00 PM	0
12/10/2015	5:00:00 PM	0
12/10/2015	5:15:00 PM	0
12/10/2015	5:30:00 PM	0
12/10/2015	5:45:00 PM	0
12/10/2015	6:00:00 PM	0
12/10/2015	6:15:00 PM	0
12/10/2015	6:30:00 PM	0
12/10/2015	6:45:00 PM	0
12/10/2015	7:00:00 PM	0
12/10/2015	7:15:00 PM	0
12/10/2015	7:30:00 PM	0
12/10/2015	7:45:00 PM	0
12/10/2015	8:00:00 PM	0
12/10/2015	8:15:00 PM	0
12/10/2015	8:30:00 PM	0
12/10/2015	8:45:00 PM	0
12/10/2015	9:00:00 PM	0
12/10/2015	9:15:00 PM	0
12/10/2015	9:30:00 PM	0
12/10/2015	9:45:00 PM	0
12/10/2015	10:00:00 PM	0
12/10/2015	10:15:00 PM	0
12/10/2015	10:30:00 PM	0
12/10/2015	10:45:00 PM	0
12/10/2015	11:00:00 PM	0
12/10/2015	11:15:00 PM	0
12/10/2015	11:30:00 PM	0
12/10/2015	11:45:00 PM	0
12/11/2015	12:00:00 AM	0
12/11/2015	12:15:00 AM	0
12/11/2015	12:30:00 AM	0
12/11/2015	12:45:00 AM	0
12/11/2015	1:00:00 AM	0
12/11/2015	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/11/2015	1:30:00 AM	0
12/11/2015	1:45:00 AM	0
12/11/2015	2:00:00 AM	0
12/11/2015	2:15:00 AM	0
12/11/2015	2:30:00 AM	0
12/11/2015	2:45:00 AM	0
12/11/2015	3:00:00 AM	0
12/11/2015	3:15:00 AM	0
12/11/2015	3:30:00 AM	0
12/11/2015	3:45:00 AM	0
12/11/2015	4:00:00 AM	0
12/11/2015	4:15:00 AM	0
12/11/2015	4:30:00 AM	0
12/11/2015	4:45:00 AM	0
12/11/2015	5:00:00 AM	0
12/11/2015	5:15:00 AM	0
12/11/2015	5:30:00 AM	0
12/11/2015	5:45:00 AM	0
12/11/2015	6:00:00 AM	0
12/11/2015	6:15:00 AM	0
12/11/2015	6:30:00 AM	0
12/11/2015	6:45:00 AM	0
12/11/2015	7:00:00 AM	0
12/11/2015	7:15:00 AM	0
12/11/2015	7:30:00 AM	0
12/11/2015	7:45:00 AM	0
12/11/2015	8:00:00 AM	0
12/11/2015	8:15:00 AM	0
12/11/2015	8:30:00 AM	0
12/11/2015	8:45:00 AM	0
12/11/2015	9:00:00 AM	0
12/11/2015	9:15:00 AM	0
12/11/2015	9:30:00 AM	0
12/11/2015	9:45:00 AM	0
12/11/2015	10:00:00 AM	0
12/11/2015	10:15:00 AM	0
12/11/2015	10:30:00 AM	0
12/11/2015	10:45:00 AM	0
12/11/2015	11:00:00 AM	0
12/11/2015	11:15:00 AM	0
12/11/2015	11:30:00 AM	0
12/11/2015	11:45:00 AM	0
12/11/2015	12:00:00 PM	0
12/11/2015	12:15:00 PM	0
12/11/2015	12:30:00 PM	0
12/11/2015	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/11/2015	1:00:00 PM	0
12/11/2015	1:15:00 PM	0
12/11/2015	1:30:00 PM	0
12/11/2015	1:45:00 PM	0
12/11/2015	2:00:00 PM	0
12/11/2015	2:15:00 PM	0
12/11/2015	2:30:00 PM	0
12/11/2015	2:45:00 PM	0
12/11/2015	3:00:00 PM	0
12/11/2015	3:15:00 PM	0
12/11/2015	3:30:00 PM	0
12/11/2015	3:45:00 PM	0
12/11/2015	4:00:00 PM	0
12/11/2015	4:15:00 PM	0
12/11/2015	4:30:00 PM	0
12/11/2015	4:45:00 PM	0
12/11/2015	5:00:00 PM	0
12/11/2015	5:15:00 PM	0
12/11/2015	5:30:00 PM	0
12/11/2015	5:45:00 PM	0
12/11/2015	6:00:00 PM	0
12/11/2015	6:15:00 PM	0
12/11/2015	6:30:00 PM	0
12/11/2015	6:45:00 PM	0
12/11/2015	7:00:00 PM	0
12/11/2015	7:15:00 PM	0
12/11/2015	7:30:00 PM	0
12/11/2015	7:45:00 PM	0
12/11/2015	8:00:00 PM	0
12/11/2015	8:15:00 PM	0
12/11/2015	8:30:00 PM	0
12/11/2015	8:45:00 PM	0
12/11/2015	9:00:00 PM	0
12/11/2015	9:15:00 PM	0
12/11/2015	9:30:00 PM	0
12/11/2015	9:45:00 PM	0
12/11/2015	10:00:00 PM	0
12/11/2015	10:15:00 PM	0
12/11/2015	10:30:00 PM	0
12/11/2015	10:45:00 PM	0
12/11/2015	11:00:00 PM	0
12/11/2015	11:15:00 PM	0
12/11/2015	11:30:00 PM	0
12/11/2015	11:45:00 PM	0
12/12/2015	12:00:00 AM	0
12/12/2015	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	12:30:00 AM	0
12/12/2015	12:45:00 AM	0
12/12/2015	1:00:00 AM	0
12/12/2015	1:15:00 AM	0
12/12/2015	1:30:00 AM	0
12/12/2015	1:45:00 AM	0
12/12/2015	2:00:00 AM	0
12/12/2015	2:15:00 AM	0
12/12/2015	2:30:00 AM	0
12/12/2015	2:45:00 AM	0
12/12/2015	3:00:00 AM	0
12/12/2015	3:15:00 AM	0
12/12/2015	3:30:00 AM	0
12/12/2015	3:45:00 AM	0
12/12/2015	4:00:00 AM	0
12/12/2015	4:15:00 AM	0
12/12/2015	4:30:00 AM	0
12/12/2015	4:45:00 AM	0
12/12/2015	5:00:00 AM	0
12/12/2015	5:15:00 AM	0
12/12/2015	5:30:00 AM	0
12/12/2015	5:45:00 AM	0
12/12/2015	6:00:00 AM	0
12/12/2015	6:15:00 AM	0
12/12/2015	6:30:00 AM	0
12/12/2015	6:45:00 AM	0
12/12/2015	7:00:00 AM	0
12/12/2015	7:15:00 AM	0
12/12/2015	7:30:00 AM	0
12/12/2015	7:45:00 AM	0
12/12/2015	8:00:00 AM	0
12/12/2015	8:15:00 AM	0
12/12/2015	8:30:00 AM	0
12/12/2015	8:45:00 AM	0
12/12/2015	9:00:00 AM	0
12/12/2015	9:15:00 AM	0
12/12/2015	9:30:00 AM	0
12/12/2015	9:45:00 AM	0
12/12/2015	10:00:00 AM	0
12/12/2015	10:15:00 AM	0
12/12/2015	10:30:00 AM	0
12/12/2015	10:45:00 AM	0
12/12/2015	11:00:00 AM	0
12/12/2015	11:15:00 AM	0
12/12/2015	11:30:00 AM	0
12/12/2015	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	12:00:00 PM	0
12/12/2015	12:15:00 PM	0
12/12/2015	12:30:00 PM	0
12/12/2015	12:45:00 PM	0
12/12/2015	1:00:00 PM	0
12/12/2015	1:15:00 PM	0
12/12/2015	1:30:00 PM	0
12/12/2015	1:45:00 PM	0
12/12/2015	2:00:00 PM	0
12/12/2015	2:15:00 PM	0
12/12/2015	2:30:00 PM	0
12/12/2015	2:45:00 PM	0
12/12/2015	3:00:00 PM	0
12/12/2015	3:15:00 PM	0
12/12/2015	3:30:00 PM	0
12/12/2015	3:45:00 PM	0
12/12/2015	4:00:00 PM	0
12/12/2015	4:15:00 PM	0
12/12/2015	4:30:00 PM	0
12/12/2015	4:45:00 PM	0
12/12/2015	5:00:00 PM	0
12/12/2015	5:15:00 PM	0
12/12/2015	5:30:00 PM	0
12/12/2015	5:45:00 PM	0
12/12/2015	6:00:00 PM	0
12/12/2015	6:15:00 PM	0
12/12/2015	6:30:00 PM	0
12/12/2015	6:45:00 PM	0
12/12/2015	7:00:00 PM	0
12/12/2015	7:15:00 PM	0
12/12/2015	7:30:00 PM	0
12/12/2015	7:45:00 PM	0
12/12/2015	8:00:00 PM	0
12/12/2015	8:15:00 PM	0
12/12/2015	8:30:00 PM	0
12/12/2015	8:45:00 PM	0
12/12/2015	9:00:00 PM	0
12/12/2015	9:15:00 PM	0
12/12/2015	9:30:00 PM	0
12/12/2015	9:45:00 PM	0
12/12/2015	10:00:00 PM	0
12/12/2015	10:15:00 PM	0
12/12/2015	10:30:00 PM	0
12/12/2015	10:45:00 PM	0
12/12/2015	11:00:00 PM	0
12/12/2015	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	11:30:00 PM	0
12/12/2015	11:45:00 PM	0
12/13/2015	12:00:00 AM	0
12/13/2015	12:15:00 AM	0
12/13/2015	12:30:00 AM	0
12/13/2015	12:45:00 AM	0
12/13/2015	1:00:00 AM	0
12/13/2015	1:15:00 AM	0
12/13/2015	1:30:00 AM	0
12/13/2015	1:45:00 AM	0
12/13/2015	2:00:00 AM	0
12/13/2015	2:15:00 AM	0
12/13/2015	2:30:00 AM	0
12/13/2015	2:45:00 AM	0
12/13/2015	3:00:00 AM	0
12/13/2015	3:15:00 AM	0
12/13/2015	3:30:00 AM	0
12/13/2015	3:45:00 AM	0
12/13/2015	4:00:00 AM	0
12/13/2015	4:15:00 AM	0
12/13/2015	4:30:00 AM	0
12/13/2015	4:45:00 AM	0
12/13/2015	5:00:00 AM	0
12/13/2015	5:15:00 AM	0
12/13/2015	5:30:00 AM	0
12/13/2015	5:45:00 AM	0
12/13/2015	6:00:00 AM	0
12/13/2015	6:15:00 AM	0
12/13/2015	6:30:00 AM	0
12/13/2015	6:45:00 AM	0
12/13/2015	7:00:00 AM	0
12/13/2015	7:15:00 AM	0
12/13/2015	7:30:00 AM	0
12/13/2015	7:45:00 AM	0
12/13/2015	8:00:00 AM	0
12/13/2015	8:15:00 AM	0
12/13/2015	8:30:00 AM	0
12/13/2015	8:45:00 AM	0
12/13/2015	9:00:00 AM	0
12/13/2015	9:15:00 AM	0
12/13/2015	9:30:00 AM	0
12/13/2015	9:45:00 AM	0
12/13/2015	10:00:00 AM	0
12/13/2015	10:15:00 AM	0
12/13/2015	10:30:00 AM	0
12/13/2015	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/13/2015	11:00:00 AM	0
12/13/2015	11:15:00 AM	0
12/13/2015	11:30:00 AM	0
12/13/2015	11:45:00 AM	0
12/13/2015	12:00:00 PM	0
12/13/2015	12:15:00 PM	0
12/13/2015	12:30:00 PM	0
12/13/2015	12:45:00 PM	0
12/13/2015	1:00:00 PM	0
12/13/2015	1:15:00 PM	0
12/13/2015	1:30:00 PM	0
12/13/2015	1:45:00 PM	0
12/13/2015	2:00:00 PM	0
12/13/2015	2:15:00 PM	0
12/13/2015	2:30:00 PM	0
12/13/2015	2:45:00 PM	0
12/13/2015	3:00:00 PM	0
12/13/2015	3:15:00 PM	0
12/13/2015	3:30:00 PM	0
12/13/2015	3:45:00 PM	0
12/13/2015	4:00:00 PM	0
12/13/2015	4:15:00 PM	0
12/13/2015	4:30:00 PM	0
12/13/2015	4:45:00 PM	0
12/13/2015	5:00:00 PM	0
12/13/2015	5:15:00 PM	0
12/13/2015	5:30:00 PM	0
12/13/2015	5:45:00 PM	0
12/13/2015	6:00:00 PM	0
12/13/2015	6:15:00 PM	0
12/13/2015	6:30:00 PM	0
12/13/2015	6:45:00 PM	0
12/13/2015	7:00:00 PM	0
12/13/2015	7:15:00 PM	0
12/13/2015	7:30:00 PM	0
12/13/2015	7:45:00 PM	0
12/13/2015	8:00:00 PM	0
12/13/2015	8:15:00 PM	0
12/13/2015	8:30:00 PM	0
12/13/2015	8:45:00 PM	0
12/13/2015	9:00:00 PM	0
12/13/2015	9:15:00 PM	0
12/13/2015	9:30:00 PM	0
12/13/2015	9:45:00 PM	0
12/13/2015	10:00:00 PM	0
12/13/2015	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/13/2015	10:30:00 PM	0
12/13/2015	10:45:00 PM	0
12/13/2015	11:00:00 PM	0
12/13/2015	11:15:00 PM	0
12/13/2015	11:30:00 PM	0
12/13/2015	11:45:00 PM	0
12/14/2015	12:00:00 AM	0
12/14/2015	12:15:00 AM	0
12/14/2015	12:30:00 AM	0
12/14/2015	12:45:00 AM	0
12/14/2015	1:00:00 AM	0
12/14/2015	1:15:00 AM	0
12/14/2015	1:30:00 AM	0
12/14/2015	1:45:00 AM	0
12/14/2015	2:00:00 AM	0
12/14/2015	2:15:00 AM	0
12/14/2015	2:30:00 AM	0
12/14/2015	2:45:00 AM	0
12/14/2015	3:00:00 AM	0
12/14/2015	3:15:00 AM	0
12/14/2015	3:30:00 AM	0
12/14/2015	3:45:00 AM	0
12/14/2015	4:00:00 AM	0
12/14/2015	4:15:00 AM	0
12/14/2015	4:30:00 AM	0
12/14/2015	4:45:00 AM	0
12/14/2015	5:00:00 AM	0
12/14/2015	5:15:00 AM	0
12/14/2015	5:30:00 AM	0
12/14/2015	5:45:00 AM	0
12/14/2015	6:00:00 AM	0
12/14/2015	6:15:00 AM	0
12/14/2015	6:30:00 AM	0
12/14/2015	6:45:00 AM	0
12/14/2015	7:00:00 AM	0
12/14/2015	7:15:00 AM	0
12/14/2015	7:30:00 AM	0
12/14/2015	7:45:00 AM	0
12/14/2015	8:00:00 AM	0
12/14/2015	8:15:00 AM	0
12/14/2015	8:30:00 AM	0
12/14/2015	8:45:00 AM	0
12/14/2015	9:00:00 AM	0
12/14/2015	9:15:00 AM	0
12/14/2015	9:30:00 AM	0
12/14/2015	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/14/2015	10:00:00 AM	0
12/14/2015	10:15:00 AM	0
12/14/2015	10:30:00 AM	0
12/14/2015	10:45:00 AM	0
12/14/2015	11:00:00 AM	0
12/14/2015	11:15:00 AM	0
12/14/2015	11:30:00 AM	0
12/14/2015	11:45:00 AM	0
12/14/2015	12:00:00 PM	0
12/14/2015	12:15:00 PM	0
12/14/2015	12:30:00 PM	0
12/14/2015	12:45:00 PM	0
12/14/2015	1:00:00 PM	0
12/14/2015	1:15:00 PM	0
12/14/2015	1:30:00 PM	0
12/14/2015	1:45:00 PM	0
12/14/2015	2:00:00 PM	0
12/14/2015	2:15:00 PM	0
12/14/2015	2:30:00 PM	0
12/14/2015	2:45:00 PM	0
12/14/2015	3:00:00 PM	0
12/14/2015	3:15:00 PM	0
12/14/2015	3:30:00 PM	0
12/14/2015	3:45:00 PM	0
12/14/2015	4:00:00 PM	0
12/14/2015	4:15:00 PM	0
12/14/2015	4:30:00 PM	0
12/14/2015	4:45:00 PM	0
12/14/2015	5:00:00 PM	0
12/14/2015	5:15:00 PM	0
12/14/2015	5:30:00 PM	0
12/14/2015	5:45:00 PM	0
12/14/2015	6:00:00 PM	0
12/14/2015	6:15:00 PM	0
12/14/2015	6:30:00 PM	0
12/14/2015	6:45:00 PM	0
12/14/2015	7:00:00 PM	0
12/14/2015	7:15:00 PM	0
12/14/2015	7:30:00 PM	0
12/14/2015	7:45:00 PM	0
12/14/2015	8:00:00 PM	0
12/14/2015	8:15:00 PM	0
12/14/2015	8:30:00 PM	0
12/14/2015	8:45:00 PM	0
12/14/2015	9:00:00 PM	0
12/14/2015	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/14/2015	9:30:00 PM	0
12/14/2015	9:45:00 PM	0
12/14/2015	10:00:00 PM	0
12/14/2015	10:15:00 PM	0
12/14/2015	10:30:00 PM	0
12/14/2015	10:45:00 PM	0
12/14/2015	11:00:00 PM	0
12/14/2015	11:15:00 PM	0
12/14/2015	11:30:00 PM	0
12/14/2015	11:45:00 PM	0
12/15/2015	12:00:00 AM	0
12/15/2015	12:15:00 AM	0
12/15/2015	12:30:00 AM	0
12/15/2015	12:45:00 AM	0
12/15/2015	1:00:00 AM	0
12/15/2015	1:15:00 AM	0
12/15/2015	1:30:00 AM	0
12/15/2015	1:45:00 AM	0
12/15/2015	2:00:00 AM	0
12/15/2015	2:15:00 AM	0
12/15/2015	2:30:00 AM	0
12/15/2015	2:45:00 AM	0
12/15/2015	3:00:00 AM	0
12/15/2015	3:15:00 AM	0
12/15/2015	3:30:00 AM	0
12/15/2015	3:45:00 AM	0
12/15/2015	4:00:00 AM	0
12/15/2015	4:15:00 AM	0
12/15/2015	4:30:00 AM	0
12/15/2015	4:45:00 AM	0
12/15/2015	5:00:00 AM	0
12/15/2015	5:15:00 AM	0
12/15/2015	5:30:00 AM	0
12/15/2015	5:45:00 AM	0
12/15/2015	6:00:00 AM	0
12/15/2015	6:15:00 AM	0
12/15/2015	6:30:00 AM	0
12/15/2015	6:45:00 AM	0
12/15/2015	7:00:00 AM	0
12/15/2015	7:15:00 AM	0
12/15/2015	7:30:00 AM	0
12/15/2015	7:45:00 AM	0
12/15/2015	8:00:00 AM	0
12/15/2015	8:15:00 AM	0
12/15/2015	8:30:00 AM	0
12/15/2015	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/15/2015	9:00:00 AM	0
12/15/2015	9:15:00 AM	0
12/15/2015	9:30:00 AM	0
12/15/2015	9:45:00 AM	0
12/15/2015	10:00:00 AM	0
12/15/2015	10:15:00 AM	0
12/15/2015	10:30:00 AM	0
12/15/2015	10:45:00 AM	0
12/15/2015	11:00:00 AM	0
12/15/2015	11:15:00 AM	0
12/15/2015	11:30:00 AM	0
12/15/2015	11:45:00 AM	0
12/15/2015	12:00:00 PM	0
12/15/2015	12:15:00 PM	0
12/15/2015	12:30:00 PM	0
12/15/2015	12:45:00 PM	0
12/15/2015	1:00:00 PM	0
12/15/2015	1:15:00 PM	0
12/15/2015	1:30:00 PM	0
12/15/2015	1:45:00 PM	0
12/15/2015	2:00:00 PM	0
12/15/2015	2:15:00 PM	0
12/15/2015	2:30:00 PM	0
12/15/2015	2:45:00 PM	0
12/15/2015	3:00:00 PM	0
12/15/2015	3:15:00 PM	0
12/15/2015	3:30:00 PM	0
12/15/2015	3:45:00 PM	0
12/15/2015	4:00:00 PM	0
12/15/2015	4:15:00 PM	0
12/15/2015	4:30:00 PM	0
12/15/2015	4:45:00 PM	0
12/15/2015	5:00:00 PM	0
12/15/2015	5:15:00 PM	0
12/15/2015	5:30:00 PM	0
12/15/2015	5:45:00 PM	0
12/15/2015	6:00:00 PM	0
12/15/2015	6:15:00 PM	0
12/15/2015	6:30:00 PM	0
12/15/2015	6:45:00 PM	0
12/15/2015	7:00:00 PM	0
12/15/2015	7:15:00 PM	0
12/15/2015	7:30:00 PM	0
12/15/2015	7:45:00 PM	0
12/15/2015	8:00:00 PM	0
12/15/2015	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/15/2015	8:30:00 PM	0
12/15/2015	8:45:00 PM	0
12/15/2015	9:00:00 PM	0
12/15/2015	9:15:00 PM	0
12/15/2015	9:30:00 PM	0
12/15/2015	9:45:00 PM	0
12/15/2015	10:00:00 PM	0
12/15/2015	10:15:00 PM	0
12/15/2015	10:30:00 PM	0
12/15/2015	10:45:00 PM	0
12/15/2015	11:00:00 PM	0
12/15/2015	11:15:00 PM	0
12/15/2015	11:30:00 PM	0
12/15/2015	11:45:00 PM	0
12/16/2015	12:00:00 AM	0
12/16/2015	12:15:00 AM	0
12/16/2015	12:30:00 AM	0
12/16/2015	12:45:00 AM	0
12/16/2015	1:00:00 AM	0
12/16/2015	1:15:00 AM	0
12/16/2015	1:30:00 AM	0
12/16/2015	1:45:00 AM	0
12/16/2015	2:00:00 AM	0
12/16/2015	2:15:00 AM	0
12/16/2015	2:30:00 AM	0
12/16/2015	2:45:00 AM	0
12/16/2015	3:00:00 AM	0
12/16/2015	3:15:00 AM	0
12/16/2015	3:30:00 AM	0
12/16/2015	3:45:00 AM	0
12/16/2015	4:00:00 AM	0
12/16/2015	4:15:00 AM	0
12/16/2015	4:30:00 AM	0
12/16/2015	4:45:00 AM	0
12/16/2015	5:00:00 AM	0
12/16/2015	5:15:00 AM	0
12/16/2015	5:30:00 AM	0
12/16/2015	5:45:00 AM	0
12/16/2015	6:00:00 AM	0
12/16/2015	6:15:00 AM	0
12/16/2015	6:30:00 AM	0
12/16/2015	6:45:00 AM	0
12/16/2015	7:00:00 AM	0
12/16/2015	7:15:00 AM	0
12/16/2015	7:30:00 AM	0
12/16/2015	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/16/2015	8:00:00 AM	0
12/16/2015	8:15:00 AM	0
12/16/2015	8:30:00 AM	0
12/16/2015	8:45:00 AM	0
12/16/2015	9:00:00 AM	0
12/16/2015	9:15:00 AM	0
12/16/2015	9:30:00 AM	0
12/16/2015	9:45:00 AM	0
12/16/2015	10:00:00 AM	0
12/16/2015	10:15:00 AM	0
12/16/2015	10:30:00 AM	0
12/16/2015	10:45:00 AM	0
12/16/2015	11:00:00 AM	0
12/16/2015	11:15:00 AM	0
12/16/2015	11:30:00 AM	0
12/16/2015	11:45:00 AM	0
12/16/2015	12:00:00 PM	0
12/16/2015	12:15:00 PM	0
12/16/2015	12:30:00 PM	0
12/16/2015	12:45:00 PM	0
12/16/2015	1:00:00 PM	0
12/16/2015	1:15:00 PM	0
12/16/2015	1:30:00 PM	0
12/16/2015	1:45:00 PM	0
12/16/2015	2:00:00 PM	0
12/16/2015	2:15:00 PM	0
12/16/2015	2:30:00 PM	0
12/16/2015	2:45:00 PM	0
12/16/2015	3:00:00 PM	0
12/16/2015	3:15:00 PM	0
12/16/2015	3:30:00 PM	0
12/16/2015	3:45:00 PM	0
12/16/2015	4:00:00 PM	0
12/16/2015	4:15:00 PM	0
12/16/2015	4:30:00 PM	0
12/16/2015	4:45:00 PM	0
12/16/2015	5:00:00 PM	0
12/16/2015	5:15:00 PM	0
12/16/2015	5:30:00 PM	0
12/16/2015	5:45:00 PM	0
12/16/2015	6:00:00 PM	0
12/16/2015	6:15:00 PM	0
12/16/2015	6:30:00 PM	0
12/16/2015	6:45:00 PM	0
12/16/2015	7:00:00 PM	0
12/16/2015	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/16/2015	7:30:00 PM	0
12/16/2015	7:45:00 PM	0
12/16/2015	8:00:00 PM	0
12/16/2015	8:15:00 PM	0
12/16/2015	8:30:00 PM	0
12/16/2015	8:45:00 PM	0
12/16/2015	9:00:00 PM	0
12/16/2015	9:15:00 PM	0
12/16/2015	9:30:00 PM	0
12/16/2015	9:45:00 PM	0
12/16/2015	10:00:00 PM	0
12/16/2015	10:15:00 PM	0
12/16/2015	10:30:00 PM	0
12/16/2015	10:45:00 PM	0
12/16/2015	11:00:00 PM	0
12/16/2015	11:15:00 PM	0
12/16/2015	11:30:00 PM	0
12/16/2015	11:45:00 PM	0
12/17/2015	12:00:00 AM	0
12/17/2015	12:15:00 AM	0
12/17/2015	12:30:00 AM	0
12/17/2015	12:45:00 AM	0
12/17/2015	1:00:00 AM	0
12/17/2015	1:15:00 AM	0
12/17/2015	1:30:00 AM	0
12/17/2015	1:45:00 AM	0
12/17/2015	2:00:00 AM	0
12/17/2015	2:15:00 AM	0
12/17/2015	2:30:00 AM	0
12/17/2015	2:45:00 AM	0
12/17/2015	3:00:00 AM	0
12/17/2015	3:15:00 AM	0
12/17/2015	3:30:00 AM	0
12/17/2015	3:45:00 AM	0
12/17/2015	4:00:00 AM	0
12/17/2015	4:15:00 AM	0
12/17/2015	4:30:00 AM	0
12/17/2015	4:45:00 AM	0
12/17/2015	5:00:00 AM	0
12/17/2015	5:15:00 AM	0
12/17/2015	5:30:00 AM	0
12/17/2015	5:45:00 AM	0
12/17/2015	6:00:00 AM	0
12/17/2015	6:15:00 AM	0
12/17/2015	6:30:00 AM	0
12/17/2015	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/17/2015	7:00:00 AM	0
12/17/2015	7:15:00 AM	0
12/17/2015	7:30:00 AM	0
12/17/2015	7:45:00 AM	0
12/17/2015	8:00:00 AM	0
12/17/2015	8:15:00 AM	0
12/17/2015	8:30:00 AM	0
12/17/2015	8:45:00 AM	0
12/17/2015	9:00:00 AM	0
12/17/2015	9:15:00 AM	0
12/17/2015	9:30:00 AM	0
12/17/2015	9:45:00 AM	0
12/17/2015	10:00:00 AM	0
12/17/2015	10:15:00 AM	0
12/17/2015	10:30:00 AM	0
12/17/2015	10:45:00 AM	0
12/17/2015	11:00:00 AM	0
12/17/2015	11:15:00 AM	0
12/17/2015	11:30:00 AM	0
12/17/2015	11:45:00 AM	0
12/17/2015	12:00:00 PM	0
12/17/2015	12:15:00 PM	0
12/17/2015	12:30:00 PM	0
12/17/2015	12:45:00 PM	0
12/17/2015	1:00:00 PM	0
12/17/2015	1:15:00 PM	0
12/17/2015	1:30:00 PM	0
12/17/2015	1:45:00 PM	0
12/17/2015	2:00:00 PM	0
12/17/2015	2:15:00 PM	0
12/17/2015	2:30:00 PM	0
12/17/2015	2:45:00 PM	0
12/17/2015	3:00:00 PM	0
12/17/2015	3:15:00 PM	0
12/17/2015	3:30:00 PM	0
12/17/2015	3:45:00 PM	0
12/17/2015	4:00:00 PM	0
12/17/2015	4:15:00 PM	0
12/17/2015	4:30:00 PM	0
12/17/2015	4:45:00 PM	0
12/17/2015	5:00:00 PM	0
12/17/2015	5:15:00 PM	0
12/17/2015	5:30:00 PM	0
12/17/2015	5:45:00 PM	0
12/17/2015	6:00:00 PM	0
12/17/2015	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/17/2015	6:30:00 PM	0
12/17/2015	6:45:00 PM	0
12/17/2015	7:00:00 PM	0
12/17/2015	7:15:00 PM	0
12/17/2015	7:30:00 PM	0
12/17/2015	7:45:00 PM	0
12/17/2015	8:00:00 PM	0
12/17/2015	8:15:00 PM	0
12/17/2015	8:30:00 PM	0
12/17/2015	8:45:00 PM	0
12/17/2015	9:00:00 PM	0
12/17/2015	9:15:00 PM	0
12/17/2015	9:30:00 PM	0
12/17/2015	9:45:00 PM	0
12/17/2015	10:00:00 PM	0
12/17/2015	10:15:00 PM	0
12/17/2015	10:30:00 PM	0
12/17/2015	10:45:00 PM	0
12/17/2015	11:00:00 PM	0
12/17/2015	11:15:00 PM	0
12/17/2015	11:30:00 PM	0
12/17/2015	11:45:00 PM	0
12/18/2015	12:00:00 AM	0
12/18/2015	12:15:00 AM	0
12/18/2015	12:30:00 AM	0
12/18/2015	12:45:00 AM	0
12/18/2015	1:00:00 AM	0
12/18/2015	1:15:00 AM	0
12/18/2015	1:30:00 AM	0
12/18/2015	1:45:00 AM	0
12/18/2015	2:00:00 AM	0
12/18/2015	2:15:00 AM	0
12/18/2015	2:30:00 AM	0
12/18/2015	2:45:00 AM	0
12/18/2015	3:00:00 AM	0
12/18/2015	3:15:00 AM	0
12/18/2015	3:30:00 AM	0
12/18/2015	3:45:00 AM	0
12/18/2015	4:00:00 AM	0
12/18/2015	4:15:00 AM	0
12/18/2015	4:30:00 AM	0
12/18/2015	4:45:00 AM	0
12/18/2015	5:00:00 AM	0
12/18/2015	5:15:00 AM	0
12/18/2015	5:30:00 AM	0
12/18/2015	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/18/2015	6:00:00 AM	0
12/18/2015	6:15:00 AM	0
12/18/2015	6:30:00 AM	0
12/18/2015	6:45:00 AM	0
12/18/2015	7:00:00 AM	0
12/18/2015	7:15:00 AM	0
12/18/2015	7:30:00 AM	0
12/18/2015	7:45:00 AM	0
12/18/2015	8:00:00 AM	0
12/18/2015	8:15:00 AM	0
12/18/2015	8:30:00 AM	0
12/18/2015	8:45:00 AM	0
12/18/2015	9:00:00 AM	0
12/18/2015	9:15:00 AM	0
12/18/2015	9:30:00 AM	0
12/18/2015	9:45:00 AM	0
12/18/2015	10:00:00 AM	0
12/18/2015	10:15:00 AM	0
12/18/2015	10:30:00 AM	0
12/18/2015	10:45:00 AM	0
12/18/2015	11:00:00 AM	0
12/18/2015	11:15:00 AM	0
12/18/2015	11:30:00 AM	0
12/18/2015	11:45:00 AM	0
12/18/2015	12:00:00 PM	0
12/18/2015	12:15:00 PM	0
12/18/2015	12:30:00 PM	0
12/18/2015	12:45:00 PM	0
12/18/2015	1:00:00 PM	0
12/18/2015	1:15:00 PM	0
12/18/2015	1:30:00 PM	0
12/18/2015	1:45:00 PM	0
12/18/2015	2:00:00 PM	0
12/18/2015	2:15:00 PM	0
12/18/2015	2:30:00 PM	0
12/18/2015	2:45:00 PM	0
12/18/2015	3:00:00 PM	0
12/18/2015	3:15:00 PM	0
12/18/2015	3:30:00 PM	0
12/18/2015	3:45:00 PM	0
12/18/2015	4:00:00 PM	0
12/18/2015	4:15:00 PM	0
12/18/2015	4:30:00 PM	0
12/18/2015	4:45:00 PM	0
12/18/2015	5:00:00 PM	0
12/18/2015	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/18/2015	5:30:00 PM	0
12/18/2015	5:45:00 PM	0
12/18/2015	6:00:00 PM	0
12/18/2015	6:15:00 PM	0
12/18/2015	6:30:00 PM	0
12/18/2015	6:45:00 PM	0
12/18/2015	7:00:00 PM	0
12/18/2015	7:15:00 PM	0
12/18/2015	7:30:00 PM	0
12/18/2015	7:45:00 PM	0
12/18/2015	8:00:00 PM	0
12/18/2015	8:15:00 PM	0
12/18/2015	8:30:00 PM	0
12/18/2015	8:45:00 PM	0
12/18/2015	9:00:00 PM	0
12/18/2015	9:15:00 PM	0
12/18/2015	9:30:00 PM	0
12/18/2015	9:45:00 PM	0
12/18/2015	10:00:00 PM	0
12/18/2015	10:15:00 PM	0
12/18/2015	10:30:00 PM	0
12/18/2015	10:45:00 PM	0
12/18/2015	11:00:00 PM	0
12/18/2015	11:15:00 PM	0
12/18/2015	11:30:00 PM	0
12/18/2015	11:45:00 PM	0
12/19/2015	12:00:00 AM	0
12/19/2015	12:15:00 AM	0
12/19/2015	12:30:00 AM	0
12/19/2015	12:45:00 AM	0
12/19/2015	1:00:00 AM	0
12/19/2015	1:15:00 AM	0
12/19/2015	1:30:00 AM	0
12/19/2015	1:45:00 AM	0
12/19/2015	2:00:00 AM	0
12/19/2015	2:15:00 AM	0
12/19/2015	2:30:00 AM	0
12/19/2015	2:45:00 AM	0
12/19/2015	3:00:00 AM	0
12/19/2015	3:15:00 AM	0
12/19/2015	3:30:00 AM	0
12/19/2015	3:45:00 AM	0
12/19/2015	4:00:00 AM	0
12/19/2015	4:15:00 AM	0
12/19/2015	4:30:00 AM	0
12/19/2015	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/19/2015	5:00:00 AM	0
12/19/2015	5:15:00 AM	0
12/19/2015	5:30:00 AM	0
12/19/2015	5:45:00 AM	0
12/19/2015	6:00:00 AM	0
12/19/2015	6:15:00 AM	0
12/19/2015	6:30:00 AM	0
12/19/2015	6:45:00 AM	0
12/19/2015	7:00:00 AM	0
12/19/2015	7:15:00 AM	0
12/19/2015	7:30:00 AM	0
12/19/2015	7:45:00 AM	0
12/19/2015	8:00:00 AM	0
12/19/2015	8:15:00 AM	0
12/19/2015	8:30:00 AM	0
12/19/2015	8:45:00 AM	0
12/19/2015	9:00:00 AM	0
12/19/2015	9:15:00 AM	0
12/19/2015	9:30:00 AM	0
12/19/2015	9:45:00 AM	0
12/19/2015	10:00:00 AM	0
12/19/2015	10:15:00 AM	0
12/19/2015	10:30:00 AM	0
12/19/2015	10:45:00 AM	0
12/19/2015	11:00:00 AM	0
12/19/2015	11:15:00 AM	0
12/19/2015	11:30:00 AM	0
12/19/2015	11:45:00 AM	0
12/19/2015	12:00:00 PM	0
12/19/2015	12:15:00 PM	0
12/19/2015	12:30:00 PM	0
12/19/2015	12:45:00 PM	0
12/19/2015	1:00:00 PM	0
12/19/2015	1:15:00 PM	0
12/19/2015	1:30:00 PM	0
12/19/2015	1:45:00 PM	0
12/19/2015	2:00:00 PM	0
12/19/2015	2:15:00 PM	0
12/19/2015	2:30:00 PM	0
12/19/2015	2:45:00 PM	0
12/19/2015	3:00:00 PM	0
12/19/2015	3:15:00 PM	0
12/19/2015	3:30:00 PM	0
12/19/2015	3:45:00 PM	0
12/19/2015	4:00:00 PM	0
12/19/2015	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/19/2015	4:30:00 PM	0
12/19/2015	4:45:00 PM	0
12/19/2015	5:00:00 PM	0
12/19/2015	5:15:00 PM	0
12/19/2015	5:30:00 PM	0
12/19/2015	5:45:00 PM	0
12/19/2015	6:00:00 PM	0
12/19/2015	6:15:00 PM	0
12/19/2015	6:30:00 PM	0
12/19/2015	6:45:00 PM	0
12/19/2015	7:00:00 PM	0
12/19/2015	7:15:00 PM	0
12/19/2015	7:30:00 PM	0
12/19/2015	7:45:00 PM	0
12/19/2015	8:00:00 PM	0
12/19/2015	8:15:00 PM	0
12/19/2015	8:30:00 PM	0
12/19/2015	8:45:00 PM	0
12/19/2015	9:00:00 PM	0
12/19/2015	9:15:00 PM	0
12/19/2015	9:30:00 PM	0
12/19/2015	9:45:00 PM	0
12/19/2015	10:00:00 PM	0
12/19/2015	10:15:00 PM	0
12/19/2015	10:30:00 PM	0
12/19/2015	10:45:00 PM	0
12/19/2015	11:00:00 PM	0
12/19/2015	11:15:00 PM	0
12/19/2015	11:30:00 PM	0
12/19/2015	11:45:00 PM	0
12/20/2015	12:00:00 AM	0
12/20/2015	12:15:00 AM	0
12/20/2015	12:30:00 AM	0
12/20/2015	12:45:00 AM	0
12/20/2015	1:00:00 AM	0
12/20/2015	1:15:00 AM	0
12/20/2015	1:30:00 AM	0
12/20/2015	1:45:00 AM	0
12/20/2015	2:00:00 AM	0
12/20/2015	2:15:00 AM	0
12/20/2015	2:30:00 AM	0
12/20/2015	2:45:00 AM	0
12/20/2015	3:00:00 AM	0
12/20/2015	3:15:00 AM	0
12/20/2015	3:30:00 AM	0
12/20/2015	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/20/2015	4:00:00 AM	0
12/20/2015	4:15:00 AM	0
12/20/2015	4:30:00 AM	0
12/20/2015	4:45:00 AM	0
12/20/2015	5:00:00 AM	0
12/20/2015	5:15:00 AM	0
12/20/2015	5:30:00 AM	0
12/20/2015	5:45:00 AM	0
12/20/2015	6:00:00 AM	0
12/20/2015	6:15:00 AM	0
12/20/2015	6:30:00 AM	0
12/20/2015	6:45:00 AM	0
12/20/2015	7:00:00 AM	0
12/20/2015	7:15:00 AM	0
12/20/2015	7:30:00 AM	0
12/20/2015	7:45:00 AM	0
12/20/2015	8:00:00 AM	0
12/20/2015	8:15:00 AM	0
12/20/2015	8:30:00 AM	0
12/20/2015	8:45:00 AM	0
12/20/2015	9:00:00 AM	0
12/20/2015	9:15:00 AM	0
12/20/2015	9:30:00 AM	0
12/20/2015	9:45:00 AM	0
12/20/2015	10:00:00 AM	0
12/20/2015	10:15:00 AM	0
12/20/2015	10:30:00 AM	0
12/20/2015	10:45:00 AM	0
12/20/2015	11:00:00 AM	0
12/20/2015	11:15:00 AM	0
12/20/2015	11:30:00 AM	0
12/20/2015	11:45:00 AM	0
12/20/2015	12:00:00 PM	0
12/20/2015	12:15:00 PM	0
12/20/2015	12:30:00 PM	0
12/20/2015	12:45:00 PM	0
12/20/2015	1:00:00 PM	0
12/20/2015	1:15:00 PM	0
12/20/2015	1:30:00 PM	0
12/20/2015	1:45:00 PM	0
12/20/2015	2:00:00 PM	0
12/20/2015	2:15:00 PM	0
12/20/2015	2:30:00 PM	0
12/20/2015	2:45:00 PM	0
12/20/2015	3:00:00 PM	0
12/20/2015	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/20/2015	3:30:00 PM	0
12/20/2015	3:45:00 PM	0
12/20/2015	4:00:00 PM	0
12/20/2015	4:15:00 PM	0
12/20/2015	4:30:00 PM	0
12/20/2015	4:45:00 PM	0
12/20/2015	5:00:00 PM	0
12/20/2015	5:15:00 PM	0
12/20/2015	5:30:00 PM	0
12/20/2015	5:45:00 PM	0
12/20/2015	6:00:00 PM	0
12/20/2015	6:15:00 PM	0
12/20/2015	6:30:00 PM	0
12/20/2015	6:45:00 PM	0
12/20/2015	7:00:00 PM	0
12/20/2015	7:15:00 PM	0
12/20/2015	7:30:00 PM	0
12/20/2015	7:45:00 PM	0
12/20/2015	8:00:00 PM	0
12/20/2015	8:15:00 PM	0
12/20/2015	8:30:00 PM	0
12/20/2015	8:45:00 PM	0
12/20/2015	9:00:00 PM	0
12/20/2015	9:15:00 PM	0
12/20/2015	9:30:00 PM	0
12/20/2015	9:45:00 PM	0
12/20/2015	10:00:00 PM	0
12/20/2015	10:15:00 PM	0
12/20/2015	10:30:00 PM	0
12/20/2015	10:45:00 PM	0
12/20/2015	11:00:00 PM	0
12/20/2015	11:15:00 PM	0
12/20/2015	11:30:00 PM	0
12/20/2015	11:45:00 PM	0
12/21/2015	12:00:00 AM	0
12/21/2015	12:15:00 AM	0
12/21/2015	12:30:00 AM	0
12/21/2015	12:45:00 AM	0
12/21/2015	1:00:00 AM	0
12/21/2015	1:15:00 AM	0
12/21/2015	1:30:00 AM	0
12/21/2015	1:45:00 AM	0
12/21/2015	2:00:00 AM	0
12/21/2015	2:15:00 AM	0
12/21/2015	2:30:00 AM	0
12/21/2015	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/21/2015	3:00:00 AM	0
12/21/2015	3:15:00 AM	0
12/21/2015	3:30:00 AM	0
12/21/2015	3:45:00 AM	0
12/21/2015	4:00:00 AM	0
12/21/2015	4:15:00 AM	0
12/21/2015	4:30:00 AM	0
12/21/2015	4:45:00 AM	0
12/21/2015	5:00:00 AM	0
12/21/2015	5:15:00 AM	0
12/21/2015	5:30:00 AM	0
12/21/2015	5:45:00 AM	0
12/21/2015	6:00:00 AM	0
12/21/2015	6:15:00 AM	0
12/21/2015	6:30:00 AM	0
12/21/2015	6:45:00 AM	0
12/21/2015	7:00:00 AM	0
12/21/2015	7:15:00 AM	0
12/21/2015	7:30:00 AM	0
12/21/2015	7:45:00 AM	0
12/21/2015	8:00:00 AM	0
12/21/2015	8:15:00 AM	0
12/21/2015	8:30:00 AM	0
12/21/2015	8:45:00 AM	0
12/21/2015	9:00:00 AM	0
12/21/2015	9:15:00 AM	0
12/21/2015	9:30:00 AM	0
12/21/2015	9:45:00 AM	0
12/21/2015	10:00:00 AM	0
12/21/2015	10:15:00 AM	0
12/21/2015	10:30:00 AM	0
12/21/2015	10:45:00 AM	0
12/21/2015	11:00:00 AM	0
12/21/2015	11:15:00 AM	0
12/21/2015	11:30:00 AM	0
12/21/2015	11:45:00 AM	0
12/21/2015	12:00:00 PM	0
12/21/2015	12:15:00 PM	0
12/21/2015	12:30:00 PM	0
12/21/2015	12:45:00 PM	0
12/21/2015	1:00:00 PM	0
12/21/2015	1:15:00 PM	0
12/21/2015	1:30:00 PM	0
12/21/2015	1:45:00 PM	0
12/21/2015	2:00:00 PM	0
12/21/2015	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/21/2015	2:30:00 PM	0
12/21/2015	2:45:00 PM	0
12/21/2015	3:00:00 PM	0
12/21/2015	3:15:00 PM	0
12/21/2015	3:30:00 PM	0
12/21/2015	3:45:00 PM	0
12/21/2015	4:00:00 PM	0
12/21/2015	4:15:00 PM	0
12/21/2015	4:30:00 PM	0
12/21/2015	4:45:00 PM	0
12/21/2015	5:00:00 PM	0
12/21/2015	5:15:00 PM	0
12/21/2015	5:30:00 PM	0
12/21/2015	5:45:00 PM	0
12/21/2015	6:00:00 PM	0
12/21/2015	6:15:00 PM	0
12/21/2015	6:30:00 PM	0
12/21/2015	6:45:00 PM	0
12/21/2015	7:00:00 PM	0
12/21/2015	7:15:00 PM	0
12/21/2015	7:30:00 PM	0
12/21/2015	7:45:00 PM	0
12/21/2015	8:00:00 PM	0
12/21/2015	8:15:00 PM	0
12/21/2015	8:30:00 PM	0
12/21/2015	8:45:00 PM	0
12/21/2015	9:00:00 PM	0
12/21/2015	9:15:00 PM	0
12/21/2015	9:30:00 PM	0
12/21/2015	9:45:00 PM	0
12/21/2015	10:00:00 PM	0
12/21/2015	10:15:00 PM	0
12/21/2015	10:30:00 PM	0
12/21/2015	10:45:00 PM	0
12/21/2015	11:00:00 PM	0
12/21/2015	11:15:00 PM	0
12/21/2015	11:30:00 PM	0
12/21/2015	11:45:00 PM	0
12/22/2015	12:00:00 AM	0
12/22/2015	12:15:00 AM	0
12/22/2015	12:30:00 AM	0
12/22/2015	12:45:00 AM	0
12/22/2015	1:00:00 AM	0
12/22/2015	1:15:00 AM	0
12/22/2015	1:30:00 AM	0
12/22/2015	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/22/2015	2:00:00 AM	0
12/22/2015	2:15:00 AM	0
12/22/2015	2:30:00 AM	0
12/22/2015	2:45:00 AM	0
12/22/2015	3:00:00 AM	0
12/22/2015	3:15:00 AM	0
12/22/2015	3:30:00 AM	0
12/22/2015	3:45:00 AM	0
12/22/2015	4:00:00 AM	0
12/22/2015	4:15:00 AM	0
12/22/2015	4:30:00 AM	0
12/22/2015	4:45:00 AM	0
12/22/2015	5:00:00 AM	0
12/22/2015	5:15:00 AM	0
12/22/2015	5:30:00 AM	0
12/22/2015	5:45:00 AM	0
12/22/2015	6:00:00 AM	0
12/22/2015	6:15:00 AM	0
12/22/2015	6:30:00 AM	0
12/22/2015	6:45:00 AM	0
12/22/2015	7:00:00 AM	0
12/22/2015	7:15:00 AM	0
12/22/2015	7:30:00 AM	0
12/22/2015	7:45:00 AM	0
12/22/2015	8:00:00 AM	0
12/22/2015	8:15:00 AM	0
12/22/2015	8:30:00 AM	0
12/22/2015	8:45:00 AM	0
12/22/2015	9:00:00 AM	0
12/22/2015	9:15:00 AM	0
12/22/2015	9:30:00 AM	0
12/22/2015	9:45:00 AM	0
12/22/2015	10:00:00 AM	0
12/22/2015	10:15:00 AM	0
12/22/2015	10:30:00 AM	0
12/22/2015	10:45:00 AM	0
12/22/2015	11:00:00 AM	0
12/22/2015	11:15:00 AM	0
12/22/2015	11:30:00 AM	0
12/22/2015	11:45:00 AM	0
12/22/2015	12:00:00 PM	0
12/22/2015	12:15:00 PM	0
12/22/2015	12:30:00 PM	0
12/22/2015	12:45:00 PM	0
12/22/2015	1:00:00 PM	0
12/22/2015	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/22/2015	1:30:00 PM	0
12/22/2015	1:45:00 PM	0
12/22/2015	2:00:00 PM	0
12/22/2015	2:15:00 PM	0
12/22/2015	2:30:00 PM	0
12/22/2015	2:45:00 PM	0
12/22/2015	3:00:00 PM	0
12/22/2015	3:15:00 PM	0
12/22/2015	3:30:00 PM	0
12/22/2015	3:45:00 PM	0
12/22/2015	4:00:00 PM	0
12/22/2015	4:15:00 PM	0
12/22/2015	4:30:00 PM	0
12/22/2015	4:45:00 PM	0
12/22/2015	5:00:00 PM	0
12/22/2015	5:15:00 PM	0
12/22/2015	5:30:00 PM	0
12/22/2015	5:45:00 PM	0
12/22/2015	6:00:00 PM	0
12/22/2015	6:15:00 PM	0
12/22/2015	6:30:00 PM	0
12/22/2015	6:45:00 PM	0
12/22/2015	7:00:00 PM	0
12/22/2015	7:15:00 PM	0
12/22/2015	7:30:00 PM	0
12/22/2015	7:45:00 PM	0
12/22/2015	8:00:00 PM	0
12/22/2015	8:15:00 PM	0
12/22/2015	8:30:00 PM	0
12/22/2015	8:45:00 PM	0
12/22/2015	9:00:00 PM	0
12/22/2015	9:15:00 PM	0
12/22/2015	9:30:00 PM	0
12/22/2015	9:45:00 PM	0
12/22/2015	10:00:00 PM	0
12/22/2015	10:15:00 PM	0
12/22/2015	10:30:00 PM	0
12/22/2015	10:45:00 PM	0
12/22/2015	11:00:00 PM	0
12/22/2015	11:15:00 PM	0
12/22/2015	11:30:00 PM	0
12/22/2015	11:45:00 PM	0
12/23/2015	12:00:00 AM	0
12/23/2015	12:15:00 AM	0
12/23/2015	12:30:00 AM	0
12/23/2015	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/23/2015	1:00:00 AM	0
12/23/2015	1:15:00 AM	0
12/23/2015	1:30:00 AM	0
12/23/2015	1:45:00 AM	0
12/23/2015	2:00:00 AM	0
12/23/2015	2:15:00 AM	0
12/23/2015	2:30:00 AM	0
12/23/2015	2:45:00 AM	0
12/23/2015	3:00:00 AM	0
12/23/2015	3:15:00 AM	0
12/23/2015	3:30:00 AM	0
12/23/2015	3:45:00 AM	0
12/23/2015	4:00:00 AM	0
12/23/2015	4:15:00 AM	0
12/23/2015	4:30:00 AM	0
12/23/2015	4:45:00 AM	0
12/23/2015	5:00:00 AM	0
12/23/2015	5:15:00 AM	0
12/23/2015	5:30:00 AM	0
12/23/2015	5:45:00 AM	0
12/23/2015	6:00:00 AM	0
12/23/2015	6:15:00 AM	0
12/23/2015	6:30:00 AM	0
12/23/2015	6:45:00 AM	0
12/23/2015	7:00:00 AM	0
12/23/2015	7:15:00 AM	0
12/23/2015	7:30:00 AM	0
12/23/2015	7:45:00 AM	0
12/23/2015	8:00:00 AM	0
12/23/2015	8:15:00 AM	0
12/23/2015	8:30:00 AM	0
12/23/2015	8:45:00 AM	0
12/23/2015	9:00:00 AM	0
12/23/2015	9:15:00 AM	0
12/23/2015	9:30:00 AM	0
12/23/2015	9:45:00 AM	0
12/23/2015	10:00:00 AM	0
12/23/2015	10:15:00 AM	0
12/23/2015	10:30:00 AM	0
12/23/2015	10:45:00 AM	0
12/23/2015	11:00:00 AM	0
12/23/2015	11:15:00 AM	0
12/23/2015	11:30:00 AM	0
12/23/2015	11:45:00 AM	0
12/23/2015	12:00:00 PM	0
12/23/2015	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/23/2015	12:30:00 PM	0
12/23/2015	12:45:00 PM	0
12/23/2015	1:00:00 PM	0
12/23/2015	1:15:00 PM	0
12/23/2015	1:30:00 PM	0
12/23/2015	1:45:00 PM	0
12/23/2015	2:00:00 PM	0
12/23/2015	2:15:00 PM	0
12/23/2015	2:30:00 PM	0
12/23/2015	2:45:00 PM	0
12/23/2015	3:00:00 PM	0
12/23/2015	3:15:00 PM	0
12/23/2015	3:30:00 PM	0
12/23/2015	3:45:00 PM	0
12/23/2015	4:00:00 PM	0
12/23/2015	4:15:00 PM	0
12/23/2015	4:30:00 PM	0
12/23/2015	4:45:00 PM	0
12/23/2015	5:00:00 PM	0
12/23/2015	5:15:00 PM	0
12/23/2015	5:30:00 PM	0
12/23/2015	5:45:00 PM	0
12/23/2015	6:00:00 PM	0
12/23/2015	6:15:00 PM	0
12/23/2015	6:30:00 PM	0
12/23/2015	6:45:00 PM	0
12/23/2015	7:00:00 PM	0
12/23/2015	7:15:00 PM	0
12/23/2015	7:30:00 PM	0
12/23/2015	7:45:00 PM	0
12/23/2015	8:00:00 PM	0
12/23/2015	8:15:00 PM	0
12/23/2015	8:30:00 PM	0
12/23/2015	8:45:00 PM	0
12/23/2015	9:00:00 PM	0
12/23/2015	9:15:00 PM	0
12/23/2015	9:30:00 PM	0
12/23/2015	9:45:00 PM	0
12/23/2015	10:00:00 PM	0
12/23/2015	10:15:00 PM	0
12/23/2015	10:30:00 PM	0
12/23/2015	10:45:00 PM	0
12/23/2015	11:00:00 PM	0
12/23/2015	11:15:00 PM	0
12/23/2015	11:30:00 PM	0
12/23/2015	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/24/2015	12:00:00 AM	0
12/24/2015	12:15:00 AM	0
12/24/2015	12:30:00 AM	0
12/24/2015	12:45:00 AM	0
12/24/2015	1:00:00 AM	0
12/24/2015	1:15:00 AM	0
12/24/2015	1:30:00 AM	0
12/24/2015	1:45:00 AM	0
12/24/2015	2:00:00 AM	0
12/24/2015	2:15:00 AM	0
12/24/2015	2:30:00 AM	0
12/24/2015	2:45:00 AM	0
12/24/2015	3:00:00 AM	0
12/24/2015	3:15:00 AM	0
12/24/2015	3:30:00 AM	0
12/24/2015	3:45:00 AM	0
12/24/2015	4:00:00 AM	0
12/24/2015	4:15:00 AM	0
12/24/2015	4:30:00 AM	0
12/24/2015	4:45:00 AM	0
12/24/2015	5:00:00 AM	0
12/24/2015	5:15:00 AM	0
12/24/2015	5:30:00 AM	0
12/24/2015	5:45:00 AM	0
12/24/2015	6:00:00 AM	0
12/24/2015	6:15:00 AM	0
12/24/2015	6:30:00 AM	0
12/24/2015	6:45:00 AM	0
12/24/2015	7:00:00 AM	0
12/24/2015	7:15:00 AM	0
12/24/2015	7:30:00 AM	0
12/24/2015	7:45:00 AM	0
12/24/2015	8:00:00 AM	0
12/24/2015	8:15:00 AM	0
12/24/2015	8:30:00 AM	0
12/24/2015	8:45:00 AM	0
12/24/2015	9:00:00 AM	0
12/24/2015	9:15:00 AM	0
12/24/2015	9:30:00 AM	0
12/24/2015	9:45:00 AM	0
12/24/2015	10:00:00 AM	0
12/24/2015	10:15:00 AM	0
12/24/2015	10:30:00 AM	0
12/24/2015	10:45:00 AM	0
12/24/2015	11:00:00 AM	0
12/24/2015	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/24/2015	11:30:00 AM	0
12/24/2015	11:45:00 AM	0
12/24/2015	12:00:00 PM	0
12/24/2015	12:15:00 PM	0
12/24/2015	12:30:00 PM	0
12/24/2015	12:45:00 PM	0
12/24/2015	1:00:00 PM	0
12/24/2015	1:15:00 PM	0
12/24/2015	1:30:00 PM	0
12/24/2015	1:45:00 PM	0
12/24/2015	2:00:00 PM	0
12/24/2015	2:15:00 PM	0
12/24/2015	2:30:00 PM	0
12/24/2015	2:45:00 PM	0
12/24/2015	3:00:00 PM	0
12/24/2015	3:15:00 PM	0
12/24/2015	3:30:00 PM	0
12/24/2015	3:45:00 PM	0
12/24/2015	4:00:00 PM	0
12/24/2015	4:15:00 PM	0
12/24/2015	4:30:00 PM	0
12/24/2015	4:45:00 PM	0
12/24/2015	5:00:00 PM	0
12/24/2015	5:15:00 PM	0
12/24/2015	5:30:00 PM	0
12/24/2015	5:45:00 PM	0
12/24/2015	6:00:00 PM	0
12/24/2015	6:15:00 PM	0
12/24/2015	6:30:00 PM	0
12/24/2015	6:45:00 PM	0
12/24/2015	7:00:00 PM	0
12/24/2015	7:15:00 PM	0
12/24/2015	7:30:00 PM	0
12/24/2015	7:45:00 PM	0
12/24/2015	8:00:00 PM	0
12/24/2015	8:15:00 PM	0
12/24/2015	8:30:00 PM	0
12/24/2015	8:45:00 PM	0
12/24/2015	9:00:00 PM	0
12/24/2015	9:15:00 PM	0
12/24/2015	9:30:00 PM	0
12/24/2015	9:45:00 PM	0
12/24/2015	10:00:00 PM	0
12/24/2015	10:15:00 PM	0
12/24/2015	10:30:00 PM	0
12/24/2015	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/24/2015	11:00:00 PM	0
12/24/2015	11:15:00 PM	0
12/24/2015	11:30:00 PM	0
12/24/2015	11:45:00 PM	0
12/25/2015	12:00:00 AM	0
12/25/2015	12:15:00 AM	0
12/25/2015	12:30:00 AM	0
12/25/2015	12:45:00 AM	0
12/25/2015	1:00:00 AM	0
12/25/2015	1:15:00 AM	0
12/25/2015	1:30:00 AM	0
12/25/2015	1:45:00 AM	0
12/25/2015	2:00:00 AM	0
12/25/2015	2:15:00 AM	0
12/25/2015	2:30:00 AM	0
12/25/2015	2:45:00 AM	0
12/25/2015	3:00:00 AM	0
12/25/2015	3:15:00 AM	0
12/25/2015	3:30:00 AM	0
12/25/2015	3:45:00 AM	0
12/25/2015	4:00:00 AM	0
12/25/2015	4:15:00 AM	0
12/25/2015	4:30:00 AM	0
12/25/2015	4:45:00 AM	0
12/25/2015	5:00:00 AM	0
12/25/2015	5:15:00 AM	0
12/25/2015	5:30:00 AM	0
12/25/2015	5:45:00 AM	0
12/25/2015	6:00:00 AM	0
12/25/2015	6:15:00 AM	0
12/25/2015	6:30:00 AM	0
12/25/2015	6:45:00 AM	0
12/25/2015	7:00:00 AM	0
12/25/2015	7:15:00 AM	0
12/25/2015	7:30:00 AM	0
12/25/2015	7:45:00 AM	0
12/25/2015	8:00:00 AM	0
12/25/2015	8:15:00 AM	0
12/25/2015	8:30:00 AM	0
12/25/2015	8:45:00 AM	0
12/25/2015	9:00:00 AM	0
12/25/2015	9:15:00 AM	0
12/25/2015	9:30:00 AM	0
12/25/2015	9:45:00 AM	0
12/25/2015	10:00:00 AM	0
12/25/2015	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/25/2015	10:30:00 AM	0
12/25/2015	10:45:00 AM	0
12/25/2015	11:00:00 AM	0
12/25/2015	11:15:00 AM	0
12/25/2015	11:30:00 AM	0
12/25/2015	11:45:00 AM	0
12/25/2015	12:00:00 PM	0
12/25/2015	12:15:00 PM	0
12/25/2015	12:30:00 PM	0
12/25/2015	12:45:00 PM	0
12/25/2015	1:00:00 PM	0
12/25/2015	1:15:00 PM	0
12/25/2015	1:30:00 PM	0
12/25/2015	1:45:00 PM	0
12/25/2015	2:00:00 PM	0
12/25/2015	2:15:00 PM	0
12/25/2015	2:30:00 PM	0
12/25/2015	2:45:00 PM	0
12/25/2015	3:00:00 PM	0
12/25/2015	3:15:00 PM	0
12/25/2015	3:30:00 PM	0
12/25/2015	3:45:00 PM	0
12/25/2015	4:00:00 PM	0
12/25/2015	4:15:00 PM	0
12/25/2015	4:30:00 PM	0
12/25/2015	4:45:00 PM	0
12/25/2015	5:00:00 PM	0
12/25/2015	5:15:00 PM	0
12/25/2015	5:30:00 PM	0
12/25/2015	5:45:00 PM	0
12/25/2015	6:00:00 PM	0
12/25/2015	6:15:00 PM	0
12/25/2015	6:30:00 PM	0
12/25/2015	6:45:00 PM	0
12/25/2015	7:00:00 PM	0
12/25/2015	7:15:00 PM	0
12/25/2015	7:30:00 PM	0
12/25/2015	7:45:00 PM	0
12/25/2015	8:00:00 PM	0
12/25/2015	8:15:00 PM	0
12/25/2015	8:30:00 PM	0
12/25/2015	8:45:00 PM	0
12/25/2015	9:00:00 PM	0
12/25/2015	9:15:00 PM	0
12/25/2015	9:30:00 PM	0
12/25/2015	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/25/2015	10:00:00 PM	0
12/25/2015	10:15:00 PM	0
12/25/2015	10:30:00 PM	0
12/25/2015	10:45:00 PM	0
12/25/2015	11:00:00 PM	0
12/25/2015	11:15:00 PM	0
12/25/2015	11:30:00 PM	0
12/25/2015	11:45:00 PM	0
12/26/2015	12:00:00 AM	0
12/26/2015	12:15:00 AM	0
12/26/2015	12:30:00 AM	0
12/26/2015	12:45:00 AM	0
12/26/2015	1:00:00 AM	0
12/26/2015	1:15:00 AM	0
12/26/2015	1:30:00 AM	0
12/26/2015	1:45:00 AM	0
12/26/2015	2:00:00 AM	0
12/26/2015	2:15:00 AM	0
12/26/2015	2:30:00 AM	0
12/26/2015	2:45:00 AM	0
12/26/2015	3:00:00 AM	0
12/26/2015	3:15:00 AM	0
12/26/2015	3:30:00 AM	0
12/26/2015	3:45:00 AM	0
12/26/2015	4:00:00 AM	0
12/26/2015	4:15:00 AM	0
12/26/2015	4:30:00 AM	0
12/26/2015	4:45:00 AM	0
12/26/2015	5:00:00 AM	0
12/26/2015	5:15:00 AM	0
12/26/2015	5:30:00 AM	0
12/26/2015	5:45:00 AM	0
12/26/2015	6:00:00 AM	0
12/26/2015	6:15:00 AM	0
12/26/2015	6:30:00 AM	0
12/26/2015	6:45:00 AM	0
12/26/2015	7:00:00 AM	0
12/26/2015	7:15:00 AM	0
12/26/2015	7:30:00 AM	0
12/26/2015	7:45:00 AM	0
12/26/2015	8:00:00 AM	0
12/26/2015	8:15:00 AM	0
12/26/2015	8:30:00 AM	0
12/26/2015	8:45:00 AM	0
12/26/2015	9:00:00 AM	0
12/26/2015	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/26/2015	9:30:00 AM	0
12/26/2015	9:45:00 AM	0
12/26/2015	10:00:00 AM	0
12/26/2015	10:15:00 AM	0
12/26/2015	10:30:00 AM	0
12/26/2015	10:45:00 AM	0
12/26/2015	11:00:00 AM	0
12/26/2015	11:15:00 AM	0
12/26/2015	11:30:00 AM	0
12/26/2015	11:45:00 AM	0
12/26/2015	12:00:00 PM	0
12/26/2015	12:15:00 PM	0
12/26/2015	12:30:00 PM	0
12/26/2015	12:45:00 PM	0
12/26/2015	1:00:00 PM	0
12/26/2015	1:15:00 PM	0
12/26/2015	1:30:00 PM	0
12/26/2015	1:45:00 PM	0
12/26/2015	2:00:00 PM	0
12/26/2015	2:15:00 PM	0
12/26/2015	2:30:00 PM	0
12/26/2015	2:45:00 PM	0
12/26/2015	3:00:00 PM	0
12/26/2015	3:15:00 PM	0
12/26/2015	3:30:00 PM	0
12/26/2015	3:45:00 PM	0
12/26/2015	4:00:00 PM	0
12/26/2015	4:15:00 PM	0
12/26/2015	4:30:00 PM	0
12/26/2015	4:45:00 PM	0
12/26/2015	5:00:00 PM	0
12/26/2015	5:15:00 PM	0
12/26/2015	5:30:00 PM	0
12/26/2015	5:45:00 PM	0
12/26/2015	6:00:00 PM	0
12/26/2015	6:15:00 PM	0
12/26/2015	6:30:00 PM	0
12/26/2015	6:45:00 PM	0
12/26/2015	7:00:00 PM	0
12/26/2015	7:15:00 PM	0
12/26/2015	7:30:00 PM	0
12/26/2015	7:45:00 PM	0
12/26/2015	8:00:00 PM	0
12/26/2015	8:15:00 PM	0
12/26/2015	8:30:00 PM	0
12/26/2015	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/26/2015	9:00:00 PM	0
12/26/2015	9:15:00 PM	0
12/26/2015	9:30:00 PM	0
12/26/2015	9:45:00 PM	0
12/26/2015	10:00:00 PM	0
12/26/2015	10:15:00 PM	0
12/26/2015	10:30:00 PM	0
12/26/2015	10:45:00 PM	0
12/26/2015	11:00:00 PM	0
12/26/2015	11:15:00 PM	0
12/26/2015	11:30:00 PM	0
12/26/2015	11:45:00 PM	0
12/27/2015	12:00:00 AM	0
12/27/2015	12:15:00 AM	0
12/27/2015	12:30:00 AM	0
12/27/2015	12:45:00 AM	0
12/27/2015	1:00:00 AM	0
12/27/2015	1:15:00 AM	0
12/27/2015	1:30:00 AM	0
12/27/2015	1:45:00 AM	0
12/27/2015	2:00:00 AM	0
12/27/2015	2:15:00 AM	0
12/27/2015	2:30:00 AM	0
12/27/2015	2:45:00 AM	0
12/27/2015	3:00:00 AM	0
12/27/2015	3:15:00 AM	0
12/27/2015	3:30:00 AM	0
12/27/2015	3:45:00 AM	0
12/27/2015	4:00:00 AM	0
12/27/2015	4:15:00 AM	0
12/27/2015	4:30:00 AM	0
12/27/2015	4:45:00 AM	0
12/27/2015	5:00:00 AM	0
12/27/2015	5:15:00 AM	0
12/27/2015	5:30:00 AM	0
12/27/2015	5:45:00 AM	0
12/27/2015	6:00:00 AM	0
12/27/2015	6:15:00 AM	0
12/27/2015	6:30:00 AM	0
12/27/2015	6:45:00 AM	0
12/27/2015	7:00:00 AM	0
12/27/2015	7:15:00 AM	0
12/27/2015	7:30:00 AM	0
12/27/2015	7:45:00 AM	0
12/27/2015	8:00:00 AM	0
12/27/2015	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/27/2015	8:30:00 AM	0
12/27/2015	8:45:00 AM	0
12/27/2015	9:00:00 AM	0
12/27/2015	9:15:00 AM	0
12/27/2015	9:30:00 AM	0
12/27/2015	9:45:00 AM	0
12/27/2015	10:00:00 AM	0
12/27/2015	10:15:00 AM	0
12/27/2015	10:30:00 AM	0
12/27/2015	10:45:00 AM	0
12/27/2015	11:00:00 AM	0
12/27/2015	11:15:00 AM	0
12/27/2015	11:30:00 AM	0
12/27/2015	11:45:00 AM	0
12/27/2015	12:00:00 PM	0
12/27/2015	12:15:00 PM	0
12/27/2015	12:30:00 PM	0
12/27/2015	12:45:00 PM	0
12/27/2015	1:00:00 PM	0
12/27/2015	1:15:00 PM	0
12/27/2015	1:30:00 PM	0
12/27/2015	1:45:00 PM	0
12/27/2015	2:00:00 PM	0
12/27/2015	2:15:00 PM	0
12/27/2015	2:30:00 PM	0
12/27/2015	2:45:00 PM	0
12/27/2015	3:00:00 PM	0
12/27/2015	3:15:00 PM	0
12/27/2015	3:30:00 PM	0
12/27/2015	3:45:00 PM	0
12/27/2015	4:00:00 PM	0
12/27/2015	4:15:00 PM	0
12/27/2015	4:30:00 PM	0
12/27/2015	4:45:00 PM	0
12/27/2015	5:00:00 PM	0
12/27/2015	5:15:00 PM	0
12/27/2015	5:30:00 PM	0
12/27/2015	5:45:00 PM	0
12/27/2015	6:00:00 PM	0
12/27/2015	6:15:00 PM	0
12/27/2015	6:30:00 PM	0
12/27/2015	6:45:00 PM	0
12/27/2015	7:00:00 PM	0
12/27/2015	7:15:00 PM	0
12/27/2015	7:30:00 PM	0
12/27/2015	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/27/2015	8:00:00 PM	0
12/27/2015	8:15:00 PM	0
12/27/2015	8:30:00 PM	0
12/27/2015	8:45:00 PM	0
12/27/2015	9:00:00 PM	0
12/27/2015	9:15:00 PM	0
12/27/2015	9:30:00 PM	0
12/27/2015	9:45:00 PM	0
12/27/2015	10:00:00 PM	0
12/27/2015	10:15:00 PM	0
12/27/2015	10:30:00 PM	0
12/27/2015	10:45:00 PM	0
12/27/2015	11:00:00 PM	0
12/27/2015	11:15:00 PM	0
12/27/2015	11:30:00 PM	0
12/27/2015	11:45:00 PM	0
12/28/2015	12:00:00 AM	0
12/28/2015	12:15:00 AM	0
12/28/2015	12:30:00 AM	0
12/28/2015	12:45:00 AM	0
12/28/2015	1:00:00 AM	0
12/28/2015	1:15:00 AM	0
12/28/2015	1:30:00 AM	0
12/28/2015	1:45:00 AM	0
12/28/2015	2:00:00 AM	0
12/28/2015	2:15:00 AM	0
12/28/2015	2:30:00 AM	0
12/28/2015	2:45:00 AM	0
12/28/2015	3:00:00 AM	0
12/28/2015	3:15:00 AM	0
12/28/2015	3:30:00 AM	0
12/28/2015	3:45:00 AM	0
12/28/2015	4:00:00 AM	0
12/28/2015	4:15:00 AM	0
12/28/2015	4:30:00 AM	0
12/28/2015	4:45:00 AM	0
12/28/2015	5:00:00 AM	0
12/28/2015	5:15:00 AM	0
12/28/2015	5:30:00 AM	0
12/28/2015	5:45:00 AM	0
12/28/2015	6:00:00 AM	0
12/28/2015	6:15:00 AM	0
12/28/2015	6:30:00 AM	0
12/28/2015	6:45:00 AM	0
12/28/2015	7:00:00 AM	0
12/28/2015	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/28/2015	7:30:00 AM	0
12/28/2015	7:45:00 AM	0
12/28/2015	8:00:00 AM	0
12/28/2015	8:15:00 AM	0
12/28/2015	8:30:00 AM	0
12/28/2015	8:45:00 AM	0
12/28/2015	9:00:00 AM	0
12/28/2015	9:15:00 AM	0
12/28/2015	9:30:00 AM	0
12/28/2015	9:45:00 AM	0
12/28/2015	10:00:00 AM	0
12/28/2015	10:15:00 AM	0
12/28/2015	10:30:00 AM	0
12/28/2015	10:45:00 AM	0
12/28/2015	11:00:00 AM	0
12/28/2015	11:15:00 AM	0
12/28/2015	11:30:00 AM	0
12/28/2015	11:45:00 AM	0
12/28/2015	12:00:00 PM	0
12/28/2015	12:15:00 PM	0
12/28/2015	12:30:00 PM	0
12/28/2015	12:45:00 PM	0
12/28/2015	1:00:00 PM	0
12/28/2015	1:15:00 PM	0
12/28/2015	1:30:00 PM	0
12/28/2015	1:45:00 PM	0
12/28/2015	2:00:00 PM	0
12/28/2015	2:15:00 PM	0
12/28/2015	2:30:00 PM	0
12/28/2015	2:45:00 PM	0
12/28/2015	3:00:00 PM	0
12/28/2015	3:15:00 PM	0
12/28/2015	3:30:00 PM	0
12/28/2015	3:45:00 PM	0
12/28/2015	4:00:00 PM	0
12/28/2015	4:15:00 PM	0
12/28/2015	4:30:00 PM	0
12/28/2015	4:45:00 PM	0
12/28/2015	5:00:00 PM	0
12/28/2015	5:15:00 PM	0
12/28/2015	5:30:00 PM	0
12/28/2015	5:45:00 PM	0
12/28/2015	6:00:00 PM	0
12/28/2015	6:15:00 PM	0
12/28/2015	6:30:00 PM	0
12/28/2015	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/28/2015	7:00:00 PM	0
12/28/2015	7:15:00 PM	0
12/28/2015	7:30:00 PM	0
12/28/2015	7:45:00 PM	0
12/28/2015	8:00:00 PM	0
12/28/2015	8:15:00 PM	0
12/28/2015	8:30:00 PM	0
12/28/2015	8:45:00 PM	0
12/28/2015	9:00:00 PM	0
12/28/2015	9:15:00 PM	0
12/28/2015	9:30:00 PM	0
12/28/2015	9:45:00 PM	0
12/28/2015	10:00:00 PM	0
12/28/2015	10:15:00 PM	0
12/28/2015	10:30:00 PM	0
12/28/2015	10:45:00 PM	0
12/28/2015	11:00:00 PM	0
12/28/2015	11:15:00 PM	0
12/28/2015	11:30:00 PM	0
12/28/2015	11:45:00 PM	0
12/29/2015	12:00:00 AM	0
12/29/2015	12:15:00 AM	0
12/29/2015	12:30:00 AM	0
12/29/2015	12:45:00 AM	0
12/29/2015	1:00:00 AM	0
12/29/2015	1:15:00 AM	0
12/29/2015	1:30:00 AM	0
12/29/2015	1:45:00 AM	0
12/29/2015	2:00:00 AM	0
12/29/2015	2:15:00 AM	0
12/29/2015	2:30:00 AM	0
12/29/2015	2:45:00 AM	0
12/29/2015	3:00:00 AM	0
12/29/2015	3:15:00 AM	0
12/29/2015	3:30:00 AM	0
12/29/2015	3:45:00 AM	0
12/29/2015	4:00:00 AM	0
12/29/2015	4:15:00 AM	0
12/29/2015	4:30:00 AM	0
12/29/2015	4:45:00 AM	0
12/29/2015	5:00:00 AM	0
12/29/2015	5:15:00 AM	0
12/29/2015	5:30:00 AM	0
12/29/2015	5:45:00 AM	0
12/29/2015	6:00:00 AM	0
12/29/2015	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/29/2015	6:30:00 AM	0
12/29/2015	6:45:00 AM	0
12/29/2015	7:00:00 AM	0
12/29/2015	7:15:00 AM	0
12/29/2015	7:30:00 AM	0
12/29/2015	7:45:00 AM	0
12/29/2015	8:00:00 AM	0
12/29/2015	8:15:00 AM	0
12/29/2015	8:30:00 AM	0
12/29/2015	8:45:00 AM	0
12/29/2015	9:00:00 AM	0
12/29/2015	9:15:00 AM	0
12/29/2015	9:30:00 AM	0
12/29/2015	9:45:00 AM	0
12/29/2015	10:00:00 AM	0
12/29/2015	10:15:00 AM	0
12/29/2015	10:30:00 AM	0
12/29/2015	10:45:00 AM	0
12/29/2015	11:00:00 AM	0
12/29/2015	11:15:00 AM	0
12/29/2015	11:30:00 AM	0
12/29/2015	11:45:00 AM	0
12/29/2015	12:00:00 PM	0
12/29/2015	12:15:00 PM	0
12/29/2015	12:30:00 PM	0
12/29/2015	12:45:00 PM	0
12/29/2015	1:00:00 PM	0
12/29/2015	1:15:00 PM	0
12/29/2015	1:30:00 PM	0
12/29/2015	1:45:00 PM	0
12/29/2015	2:00:00 PM	0
12/29/2015	2:15:00 PM	0
12/29/2015	2:30:00 PM	0
12/29/2015	2:45:00 PM	0
12/29/2015	3:00:00 PM	0
12/29/2015	3:15:00 PM	0
12/29/2015	3:30:00 PM	0
12/29/2015	3:45:00 PM	0
12/29/2015	4:00:00 PM	0
12/29/2015	4:15:00 PM	0
12/29/2015	4:30:00 PM	0
12/29/2015	4:45:00 PM	0
12/29/2015	5:00:00 PM	0
12/29/2015	5:15:00 PM	0
12/29/2015	5:30:00 PM	0
12/29/2015	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/29/2015	6:00:00 PM	0
12/29/2015	6:15:00 PM	0
12/29/2015	6:30:00 PM	0
12/29/2015	6:45:00 PM	0
12/29/2015	7:00:00 PM	0
12/29/2015	7:15:00 PM	0
12/29/2015	7:30:00 PM	0
12/29/2015	7:45:00 PM	0
12/29/2015	8:00:00 PM	0
12/29/2015	8:15:00 PM	0
12/29/2015	8:30:00 PM	0
12/29/2015	8:45:00 PM	0
12/29/2015	9:00:00 PM	0
12/29/2015	9:15:00 PM	0
12/29/2015	9:30:00 PM	0
12/29/2015	9:45:00 PM	0
12/29/2015	10:00:00 PM	0
12/29/2015	10:15:00 PM	0
12/29/2015	10:30:00 PM	0
12/29/2015	10:45:00 PM	0
12/29/2015	11:00:00 PM	0
12/29/2015	11:15:00 PM	0
12/29/2015	11:30:00 PM	0
12/29/2015	11:45:00 PM	0
12/30/2015	12:00:00 AM	0
12/30/2015	12:15:00 AM	0
12/30/2015	12:30:00 AM	0
12/30/2015	12:45:00 AM	0
12/30/2015	1:00:00 AM	0
12/30/2015	1:15:00 AM	0
12/30/2015	1:30:00 AM	0
12/30/2015	1:45:00 AM	0
12/30/2015	2:00:00 AM	0
12/30/2015	2:15:00 AM	0
12/30/2015	2:30:00 AM	0
12/30/2015	2:45:00 AM	0
12/30/2015	3:00:00 AM	0
12/30/2015	3:15:00 AM	0
12/30/2015	3:30:00 AM	0
12/30/2015	3:45:00 AM	0
12/30/2015	4:00:00 AM	0
12/30/2015	4:15:00 AM	0
12/30/2015	4:30:00 AM	0
12/30/2015	4:45:00 AM	0
12/30/2015	5:00:00 AM	0
12/30/2015	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/30/2015	5:30:00 AM	0
12/30/2015	5:45:00 AM	0
12/30/2015	6:00:00 AM	0
12/30/2015	6:15:00 AM	0
12/30/2015	6:30:00 AM	0
12/30/2015	6:45:00 AM	0
12/30/2015	7:00:00 AM	0
12/30/2015	7:15:00 AM	0
12/30/2015	7:30:00 AM	0
12/30/2015	7:45:00 AM	0
12/30/2015	8:00:00 AM	0
12/30/2015	8:15:00 AM	0
12/30/2015	8:30:00 AM	0
12/30/2015	8:45:00 AM	0
12/30/2015	9:00:00 AM	0
12/30/2015	9:15:00 AM	0
12/30/2015	9:30:00 AM	0
12/30/2015	9:45:00 AM	0
12/30/2015	10:00:00 AM	0
12/30/2015	10:15:00 AM	0
12/30/2015	10:30:00 AM	0
12/30/2015	10:45:00 AM	0
12/30/2015	11:00:00 AM	0
12/30/2015	11:15:00 AM	0
12/30/2015	11:30:00 AM	0
12/30/2015	11:45:00 AM	0
12/30/2015	12:00:00 PM	0
12/30/2015	12:15:00 PM	0
12/30/2015	12:30:00 PM	0
12/30/2015	12:45:00 PM	0
12/30/2015	1:00:00 PM	0
12/30/2015	1:15:00 PM	0
12/30/2015	1:30:00 PM	0
12/30/2015	1:45:00 PM	0
12/30/2015	2:00:00 PM	0
12/30/2015	2:15:00 PM	0
12/30/2015	2:30:00 PM	0
12/30/2015	2:45:00 PM	0
12/30/2015	3:00:00 PM	0
12/30/2015	3:15:00 PM	0
12/30/2015	3:30:00 PM	0
12/30/2015	3:45:00 PM	0
12/30/2015	4:00:00 PM	0
12/30/2015	4:15:00 PM	0
12/30/2015	4:30:00 PM	0
12/30/2015	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/30/2015	5:00:00 PM	0
12/30/2015	5:15:00 PM	0
12/30/2015	5:30:00 PM	0
12/30/2015	5:45:00 PM	0
12/30/2015	6:00:00 PM	0
12/30/2015	6:15:00 PM	0
12/30/2015	6:30:00 PM	0
12/30/2015	6:45:00 PM	0
12/30/2015	7:00:00 PM	0
12/30/2015	7:15:00 PM	0
12/30/2015	7:30:00 PM	0
12/30/2015	7:45:00 PM	0
12/30/2015	8:00:00 PM	0
12/30/2015	8:15:00 PM	0
12/30/2015	8:30:00 PM	0
12/30/2015	8:45:00 PM	0
12/30/2015	9:00:00 PM	0
12/30/2015	9:15:00 PM	0
12/30/2015	9:30:00 PM	0
12/30/2015	9:45:00 PM	0
12/30/2015	10:00:00 PM	0
12/30/2015	10:15:00 PM	0
12/30/2015	10:30:00 PM	0
12/30/2015	10:45:00 PM	0
12/30/2015	11:00:00 PM	0
12/30/2015	11:15:00 PM	0
12/30/2015	11:30:00 PM	0
12/30/2015	11:45:00 PM	0
12/31/2015	12:00:00 AM	0
12/31/2015	12:15:00 AM	0
12/31/2015	12:30:00 AM	0
12/31/2015	12:45:00 AM	0
12/31/2015	1:00:00 AM	0
12/31/2015	1:15:00 AM	0
12/31/2015	1:30:00 AM	0
12/31/2015	1:45:00 AM	0
12/31/2015	2:00:00 AM	0
12/31/2015	2:15:00 AM	0
12/31/2015	2:30:00 AM	0
12/31/2015	2:45:00 AM	0
12/31/2015	3:00:00 AM	0
12/31/2015	3:15:00 AM	0
12/31/2015	3:30:00 AM	0
12/31/2015	3:45:00 AM	0
12/31/2015	4:00:00 AM	0
12/31/2015	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/31/2015	4:30:00 AM	0
12/31/2015	4:45:00 AM	0
12/31/2015	5:00:00 AM	0
12/31/2015	5:15:00 AM	0
12/31/2015	5:30:00 AM	0
12/31/2015	5:45:00 AM	0
12/31/2015	6:00:00 AM	0
12/31/2015	6:15:00 AM	0
12/31/2015	6:30:00 AM	0
12/31/2015	6:45:00 AM	0
12/31/2015	7:00:00 AM	0
12/31/2015	7:15:00 AM	0
12/31/2015	7:30:00 AM	0
12/31/2015	7:45:00 AM	0
12/31/2015	8:00:00 AM	0
12/31/2015	8:15:00 AM	0
12/31/2015	8:30:00 AM	0
12/31/2015	8:45:00 AM	0
12/31/2015	9:00:00 AM	0
12/31/2015	9:15:00 AM	0
12/31/2015	9:30:00 AM	0
12/31/2015	9:45:00 AM	0
12/31/2015	10:00:00 AM	0
12/31/2015	10:15:00 AM	0
12/31/2015	10:30:00 AM	0
12/31/2015	10:45:00 AM	0
12/31/2015	11:00:00 AM	0
12/31/2015	11:15:00 AM	0
12/31/2015	11:30:00 AM	0
12/31/2015	11:45:00 AM	0
12/31/2015	12:00:00 PM	0
12/31/2015	12:15:00 PM	0
12/31/2015	12:30:00 PM	0
12/31/2015	12:45:00 PM	0
12/31/2015	1:00:00 PM	0
12/31/2015	1:15:00 PM	0
12/31/2015	1:30:00 PM	0
12/31/2015	1:45:00 PM	0
12/31/2015	2:00:00 PM	0
12/31/2015	2:15:00 PM	0
12/31/2015	2:30:00 PM	0
12/31/2015	2:45:00 PM	0
12/31/2015	3:00:00 PM	0
12/31/2015	3:15:00 PM	0
12/31/2015	3:30:00 PM	0
12/31/2015	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
12/31/2015	4:00:00 PM	0
12/31/2015	4:15:00 PM	0
12/31/2015	4:30:00 PM	0
12/31/2015	4:45:00 PM	0
12/31/2015	5:00:00 PM	0
12/31/2015	5:15:00 PM	0
12/31/2015	5:30:00 PM	0
12/31/2015	5:45:00 PM	0
12/31/2015	6:00:00 PM	0
12/31/2015	6:15:00 PM	0
12/31/2015	6:30:00 PM	0
12/31/2015	6:45:00 PM	0
12/31/2015	7:00:00 PM	0
12/31/2015	7:15:00 PM	0
12/31/2015	7:30:00 PM	0
12/31/2015	7:45:00 PM	0
12/31/2015	8:00:00 PM	0
12/31/2015	8:15:00 PM	0
12/31/2015	8:30:00 PM	0
12/31/2015	8:45:00 PM	0
12/31/2015	9:00:00 PM	0
12/31/2015	9:15:00 PM	0
12/31/2015	9:30:00 PM	0
12/31/2015	9:45:00 PM	0
12/31/2015	10:00:00 PM	0
12/31/2015	10:15:00 PM	0
12/31/2015	10:30:00 PM	0
12/31/2015	10:45:00 PM	0
12/31/2015	11:00:00 PM	0
12/31/2015	11:15:00 PM	0
12/31/2015	11:30:00 PM	0
12/31/2015	11:45:00 PM	0

Georges Ditch Return
Station 0217

Date	Flow (cfs)
12/1/2015	17.796
12/2/2015	17.858
12/3/2015	18.09
12/4/2015	18.288
12/5/2015	14.819
12/6/2015	0.449
12/7/2015	0.837
12/8/2015	0.338
12/9/2015	0.33
12/10/2015	0.263
12/11/2015	0.214
12/12/2015	0.139
12/13/2015	0.165
12/14/2015	0.068
12/15/2015	0.078
12/16/2015	0.12
12/17/2015	0.135
12/18/2015	0.119
12/19/2015	0.112
12/20/2015	0.429
12/21/2015	0.784
12/22/2015	0.556
12/23/2015	0.323
12/24/2015	0.504
12/25/2015	0.628
12/26/2015	0.729
12/27/2015	0.886
12/28/2015	0.975
12/29/2015	0.354
12/30/2015	0.237
12/31/2015	0.181

Georges Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	12:00:00 AM	1.04
12/1/2015	12:15:00 AM	1.04
12/1/2015	12:30:00 AM	1.04
12/1/2015	12:45:00 AM	1.04
12/1/2015	1:00:00 AM	1.04
12/1/2015	1:15:00 AM	1.04
12/1/2015	1:30:00 AM	1.04
12/1/2015	1:45:00 AM	1.04
12/1/2015	2:00:00 AM	1.04
12/1/2015	2:15:00 AM	1.03
12/1/2015	2:30:00 AM	1.04
12/1/2015	2:45:00 AM	1.04
12/1/2015	3:00:00 AM	1.04
12/1/2015	3:15:00 AM	1.04
12/1/2015	3:30:00 AM	1.04
12/1/2015	3:45:00 AM	1.04
12/1/2015	4:00:00 AM	1.04
12/1/2015	4:15:00 AM	1.04
12/1/2015	4:30:00 AM	1.04
12/1/2015	4:45:00 AM	1.04
12/1/2015	5:00:00 AM	1.04
12/1/2015	5:15:00 AM	1.04
12/1/2015	5:30:00 AM	1.04
12/1/2015	5:45:00 AM	1.04
12/1/2015	6:00:00 AM	1.03
12/1/2015	6:15:00 AM	1.04
12/1/2015	6:30:00 AM	1.04
12/1/2015	6:45:00 AM	1.04
12/1/2015	7:00:00 AM	1.03
12/1/2015	7:15:00 AM	1.03
12/1/2015	7:30:00 AM	1.04
12/1/2015	7:45:00 AM	1.04
12/1/2015	8:00:00 AM	1.04
12/1/2015	8:15:00 AM	1.04
12/1/2015	8:30:00 AM	1.04
12/1/2015	8:45:00 AM	1.03
12/1/2015	9:00:00 AM	1.03
12/1/2015	9:15:00 AM	1.03
12/1/2015	9:30:00 AM	1.04
12/1/2015	9:45:00 AM	1.04
12/1/2015	10:00:00 AM	1.04
12/1/2015	10:15:00 AM	1.04
12/1/2015	10:30:00 AM	1.04
12/1/2015	10:45:00 AM	1.04
12/1/2015	11:00:00 AM	1.04
12/1/2015	11:15:00 AM	1.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	11:30:00 AM	1.04
12/1/2015	11:45:00 AM	1.04
12/1/2015	12:00:00 PM	1.04
12/1/2015	12:15:00 PM	1.03
12/1/2015	12:30:00 PM	1.03
12/1/2015	12:45:00 PM	1.03
12/1/2015	1:00:00 PM	1.03
12/1/2015	1:15:00 PM	1.03
12/1/2015	1:30:00 PM	1.04
12/1/2015	1:45:00 PM	1.04
12/1/2015	2:00:00 PM	1.04
12/1/2015	2:15:00 PM	1.04
12/1/2015	2:30:00 PM	1.04
12/1/2015	2:45:00 PM	1.04
12/1/2015	3:00:00 PM	1.03
12/1/2015	3:15:00 PM	1.03
12/1/2015	3:30:00 PM	1.03
12/1/2015	3:45:00 PM	1.04
12/1/2015	4:00:00 PM	1.04
12/1/2015	4:15:00 PM	1.03
12/1/2015	4:30:00 PM	1.03
12/1/2015	4:45:00 PM	1.03
12/1/2015	5:00:00 PM	1.03
12/1/2015	5:15:00 PM	1.03
12/1/2015	5:30:00 PM	1.03
12/1/2015	5:45:00 PM	1.04
12/1/2015	6:00:00 PM	1.04
12/1/2015	6:15:00 PM	1.04
12/1/2015	6:30:00 PM	1.04
12/1/2015	6:45:00 PM	1.03
12/1/2015	7:00:00 PM	1.04
12/1/2015	7:15:00 PM	1.04
12/1/2015	7:30:00 PM	1.04
12/1/2015	7:45:00 PM	1.04
12/1/2015	8:00:00 PM	1.04
12/1/2015	8:15:00 PM	1.04
12/1/2015	8:30:00 PM	1.04
12/1/2015	8:45:00 PM	1.04
12/1/2015	9:00:00 PM	1.04
12/1/2015	9:15:00 PM	1.04
12/1/2015	9:30:00 PM	1.04
12/1/2015	9:45:00 PM	1.04
12/1/2015	10:00:00 PM	1.04
12/1/2015	10:15:00 PM	1.04
12/1/2015	10:30:00 PM	1.04
12/1/2015	10:45:00 PM	1.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/1/2015	11:00:00 PM	1.04
12/1/2015	11:15:00 PM	1.04
12/1/2015	11:30:00 PM	1.04
12/1/2015	11:45:00 PM	1.04
12/2/2015	12:00:00 AM	1.04
12/2/2015	12:15:00 AM	1.04
12/2/2015	12:30:00 AM	1.04
12/2/2015	12:45:00 AM	1.04
12/2/2015	1:00:00 AM	1.04
12/2/2015	1:15:00 AM	1.04
12/2/2015	1:30:00 AM	1.04
12/2/2015	1:45:00 AM	1.04
12/2/2015	2:00:00 AM	1.04
12/2/2015	2:15:00 AM	1.04
12/2/2015	2:30:00 AM	1.04
12/2/2015	2:45:00 AM	1.04
12/2/2015	3:00:00 AM	1.04
12/2/2015	3:15:00 AM	1.04
12/2/2015	3:30:00 AM	1.04
12/2/2015	3:45:00 AM	1.04
12/2/2015	4:00:00 AM	1.04
12/2/2015	4:15:00 AM	1.04
12/2/2015	4:30:00 AM	1.04
12/2/2015	4:45:00 AM	1.04
12/2/2015	5:00:00 AM	1.04
12/2/2015	5:15:00 AM	1.04
12/2/2015	5:30:00 AM	1.04
12/2/2015	5:45:00 AM	1.04
12/2/2015	6:00:00 AM	1.04
12/2/2015	6:15:00 AM	1.04
12/2/2015	6:30:00 AM	1.04
12/2/2015	6:45:00 AM	1.04
12/2/2015	7:00:00 AM	1.04
12/2/2015	7:15:00 AM	1.04
12/2/2015	7:30:00 AM	1.04
12/2/2015	7:45:00 AM	1.04
12/2/2015	8:00:00 AM	1.04
12/2/2015	8:15:00 AM	1.04
12/2/2015	8:30:00 AM	1.04
12/2/2015	8:45:00 AM	1.04
12/2/2015	9:00:00 AM	1.04
12/2/2015	9:15:00 AM	1.04
12/2/2015	9:30:00 AM	1.04
12/2/2015	9:45:00 AM	1.04
12/2/2015	10:00:00 AM	1.04
12/2/2015	10:15:00 AM	1.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/2/2015	10:30:00 AM	1.04
12/2/2015	10:45:00 AM	1.04
12/2/2015	11:00:00 AM	1.04
12/2/2015	11:15:00 AM	1.04
12/2/2015	11:30:00 AM	1.04
12/2/2015	11:45:00 AM	1.04
12/2/2015	12:00:00 PM	1.04
12/2/2015	12:15:00 PM	1.04
12/2/2015	12:30:00 PM	1.04
12/2/2015	12:45:00 PM	1.04
12/2/2015	1:00:00 PM	1.04
12/2/2015	1:15:00 PM	1.04
12/2/2015	1:30:00 PM	1.04
12/2/2015	1:45:00 PM	1.04
12/2/2015	2:00:00 PM	1.04
12/2/2015	2:15:00 PM	1.04
12/2/2015	2:30:00 PM	1.04
12/2/2015	2:45:00 PM	1.04
12/2/2015	3:00:00 PM	1.04
12/2/2015	3:15:00 PM	1.04
12/2/2015	3:30:00 PM	1.04
12/2/2015	3:45:00 PM	1.04
12/2/2015	4:00:00 PM	1.04
12/2/2015	4:15:00 PM	1.04
12/2/2015	4:30:00 PM	1.04
12/2/2015	4:45:00 PM	1.04
12/2/2015	5:00:00 PM	1.04
12/2/2015	5:15:00 PM	1.04
12/2/2015	5:30:00 PM	1.04
12/2/2015	5:45:00 PM	1.04
12/2/2015	6:00:00 PM	1.04
12/2/2015	6:15:00 PM	1.04
12/2/2015	6:30:00 PM	1.04
12/2/2015	6:45:00 PM	1.04
12/2/2015	7:00:00 PM	1.04
12/2/2015	7:15:00 PM	1.04
12/2/2015	7:30:00 PM	1.04
12/2/2015	7:45:00 PM	1.04
12/2/2015	8:00:00 PM	1.04
12/2/2015	8:15:00 PM	1.04
12/2/2015	8:30:00 PM	1.04
12/2/2015	8:45:00 PM	1.04
12/2/2015	9:00:00 PM	1.04
12/2/2015	9:15:00 PM	1.04
12/2/2015	9:30:00 PM	1.04
12/2/2015	9:45:00 PM	1.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/2/2015	10:00:00 PM	1.04
12/2/2015	10:15:00 PM	1.04
12/2/2015	10:30:00 PM	1.04
12/2/2015	10:45:00 PM	1.04
12/2/2015	11:00:00 PM	1.04
12/2/2015	11:15:00 PM	1.05
12/2/2015	11:30:00 PM	1.04
12/2/2015	11:45:00 PM	1.04
12/3/2015	12:00:00 AM	1.04
12/3/2015	12:15:00 AM	1.04
12/3/2015	12:30:00 AM	1.04
12/3/2015	12:45:00 AM	1.04
12/3/2015	1:00:00 AM	1.04
12/3/2015	1:15:00 AM	1.04
12/3/2015	1:30:00 AM	1.04
12/3/2015	1:45:00 AM	1.05
12/3/2015	2:00:00 AM	1.05
12/3/2015	2:15:00 AM	1.04
12/3/2015	2:30:00 AM	1.04
12/3/2015	2:45:00 AM	1.05
12/3/2015	3:00:00 AM	1.05
12/3/2015	3:15:00 AM	1.05
12/3/2015	3:30:00 AM	1.05
12/3/2015	3:45:00 AM	1.05
12/3/2015	4:00:00 AM	1.04
12/3/2015	4:15:00 AM	1.04
12/3/2015	4:30:00 AM	1.05
12/3/2015	4:45:00 AM	1.05
12/3/2015	5:00:00 AM	1.04
12/3/2015	5:15:00 AM	1.05
12/3/2015	5:30:00 AM	1.05
12/3/2015	5:45:00 AM	1.05
12/3/2015	6:00:00 AM	1.05
12/3/2015	6:15:00 AM	1.05
12/3/2015	6:30:00 AM	1.05
12/3/2015	6:45:00 AM	1.05
12/3/2015	7:00:00 AM	1.05
12/3/2015	7:15:00 AM	1.05
12/3/2015	7:30:00 AM	1.05
12/3/2015	7:45:00 AM	1.05
12/3/2015	8:00:00 AM	1.05
12/3/2015	8:15:00 AM	1.05
12/3/2015	8:30:00 AM	1.05
12/3/2015	8:45:00 AM	1.05
12/3/2015	9:00:00 AM	1.05
12/3/2015	9:15:00 AM	1.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/3/2015	9:30:00 AM	1.05
12/3/2015	9:45:00 AM	1.05
12/3/2015	10:00:00 AM	1.05
12/3/2015	10:15:00 AM	1.05
12/3/2015	10:30:00 AM	1.05
12/3/2015	10:45:00 AM	1.04
12/3/2015	11:00:00 AM	1.05
12/3/2015	11:15:00 AM	1.05
12/3/2015	11:30:00 AM	1.05
12/3/2015	11:45:00 AM	1.05
12/3/2015	12:00:00 PM	1.05
12/3/2015	12:15:00 PM	1.05
12/3/2015	12:30:00 PM	1.05
12/3/2015	12:45:00 PM	1.05
12/3/2015	1:00:00 PM	1.05
12/3/2015	1:15:00 PM	1.05
12/3/2015	1:30:00 PM	1.05
12/3/2015	1:45:00 PM	1.05
12/3/2015	2:00:00 PM	1.05
12/3/2015	2:15:00 PM	1.05
12/3/2015	2:30:00 PM	1.05
12/3/2015	2:45:00 PM	1.05
12/3/2015	3:00:00 PM	1.05
12/3/2015	3:15:00 PM	1.05
12/3/2015	3:30:00 PM	1.05
12/3/2015	3:45:00 PM	1.05
12/3/2015	4:00:00 PM	1.05
12/3/2015	4:15:00 PM	1.05
12/3/2015	4:30:00 PM	1.05
12/3/2015	4:45:00 PM	1.05
12/3/2015	5:00:00 PM	1.05
12/3/2015	5:15:00 PM	1.05
12/3/2015	5:30:00 PM	1.05
12/3/2015	5:45:00 PM	1.05
12/3/2015	6:00:00 PM	1.05
12/3/2015	6:15:00 PM	1.05
12/3/2015	6:30:00 PM	1.05
12/3/2015	6:45:00 PM	1.05
12/3/2015	7:00:00 PM	1.05
12/3/2015	7:15:00 PM	1.05
12/3/2015	7:30:00 PM	1.05
12/3/2015	7:45:00 PM	1.05
12/3/2015	8:00:00 PM	1.05
12/3/2015	8:15:00 PM	1.05
12/3/2015	8:30:00 PM	1.05
12/3/2015	8:45:00 PM	1.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/3/2015	9:00:00 PM	1.05
12/3/2015	9:15:00 PM	1.05
12/3/2015	9:30:00 PM	1.06
12/3/2015	9:45:00 PM	1.05
12/3/2015	10:00:00 PM	1.05
12/3/2015	10:15:00 PM	1.06
12/3/2015	10:30:00 PM	1.05
12/3/2015	10:45:00 PM	1.06
12/3/2015	11:00:00 PM	1.06
12/3/2015	11:15:00 PM	1.05
12/3/2015	11:30:00 PM	1.05
12/3/2015	11:45:00 PM	1.05
12/4/2015	12:00:00 AM	1.05
12/4/2015	12:15:00 AM	1.05
12/4/2015	12:30:00 AM	1.05
12/4/2015	12:45:00 AM	1.05
12/4/2015	1:00:00 AM	1.05
12/4/2015	1:15:00 AM	1.05
12/4/2015	1:30:00 AM	1.05
12/4/2015	1:45:00 AM	1.05
12/4/2015	2:00:00 AM	1.05
12/4/2015	2:15:00 AM	1.05
12/4/2015	2:30:00 AM	1.05
12/4/2015	2:45:00 AM	1.05
12/4/2015	3:00:00 AM	1.05
12/4/2015	3:15:00 AM	1.05
12/4/2015	3:30:00 AM	1.05
12/4/2015	3:45:00 AM	1.05
12/4/2015	4:00:00 AM	1.05
12/4/2015	4:15:00 AM	1.05
12/4/2015	4:30:00 AM	1.05
12/4/2015	4:45:00 AM	1.05
12/4/2015	5:00:00 AM	1.05
12/4/2015	5:15:00 AM	1.05
12/4/2015	5:30:00 AM	1.05
12/4/2015	5:45:00 AM	1.05
12/4/2015	6:00:00 AM	1.05
12/4/2015	6:15:00 AM	1.05
12/4/2015	6:30:00 AM	1.05
12/4/2015	6:45:00 AM	1.05
12/4/2015	7:00:00 AM	1.05
12/4/2015	7:15:00 AM	1.05
12/4/2015	7:30:00 AM	1.05
12/4/2015	7:45:00 AM	1.05
12/4/2015	8:00:00 AM	1.05
12/4/2015	8:15:00 AM	1.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/4/2015	8:30:00 AM	1.05
12/4/2015	8:45:00 AM	1.06
12/4/2015	9:00:00 AM	1.06
12/4/2015	9:15:00 AM	1.06
12/4/2015	9:30:00 AM	1.06
12/4/2015	9:45:00 AM	1.06
12/4/2015	10:00:00 AM	1.06
12/4/2015	10:15:00 AM	1.06
12/4/2015	10:30:00 AM	1.06
12/4/2015	10:45:00 AM	1.06
12/4/2015	11:00:00 AM	1.06
12/4/2015	11:15:00 AM	1.06
12/4/2015	11:30:00 AM	1.06
12/4/2015	11:45:00 AM	1.06
12/4/2015	12:00:00 PM	1.06
12/4/2015	12:15:00 PM	1.06
12/4/2015	12:30:00 PM	1.06
12/4/2015	12:45:00 PM	1.05
12/4/2015	1:00:00 PM	1.06
12/4/2015	1:15:00 PM	1.06
12/4/2015	1:30:00 PM	1.06
12/4/2015	1:45:00 PM	1.06
12/4/2015	2:00:00 PM	1.06
12/4/2015	2:15:00 PM	1.06
12/4/2015	2:30:00 PM	1.06
12/4/2015	2:45:00 PM	1.06
12/4/2015	3:00:00 PM	1.06
12/4/2015	3:15:00 PM	1.06
12/4/2015	3:30:00 PM	1.06
12/4/2015	3:45:00 PM	1.06
12/4/2015	4:00:00 PM	1.06
12/4/2015	4:15:00 PM	1.06
12/4/2015	4:30:00 PM	1.06
12/4/2015	4:45:00 PM	1.06
12/4/2015	5:00:00 PM	1.06
12/4/2015	5:15:00 PM	1.06
12/4/2015	5:30:00 PM	1.06
12/4/2015	5:45:00 PM	1.06
12/4/2015	6:00:00 PM	1.06
12/4/2015	6:15:00 PM	1.06
12/4/2015	6:30:00 PM	1.06
12/4/2015	6:45:00 PM	1.06
12/4/2015	7:00:00 PM	1.06
12/4/2015	7:15:00 PM	1.06
12/4/2015	7:30:00 PM	1.06
12/4/2015	7:45:00 PM	1.06

Georges Ditch Return Gage

DATE	TIME	GAGE
12/4/2015	8:00:00 PM	1.06
12/4/2015	8:15:00 PM	1.06
12/4/2015	8:30:00 PM	1.06
12/4/2015	8:45:00 PM	1.06
12/4/2015	9:00:00 PM	1.06
12/4/2015	9:15:00 PM	1.06
12/4/2015	9:30:00 PM	1.06
12/4/2015	9:45:00 PM	1.06
12/4/2015	10:00:00 PM	1.06
12/4/2015	10:15:00 PM	1.06
12/4/2015	10:30:00 PM	1.06
12/4/2015	10:45:00 PM	1.07
12/4/2015	11:00:00 PM	1.06
12/4/2015	11:15:00 PM	1.07
12/4/2015	11:30:00 PM	1.07
12/4/2015	11:45:00 PM	1.07
12/5/2015	12:00:00 AM	1.06
12/5/2015	12:15:00 AM	1.06
12/5/2015	12:30:00 AM	1.06
12/5/2015	12:45:00 AM	1.06
12/5/2015	1:00:00 AM	1.06
12/5/2015	1:15:00 AM	1.06
12/5/2015	1:30:00 AM	1.06
12/5/2015	1:45:00 AM	1.06
12/5/2015	2:00:00 AM	1.06
12/5/2015	2:15:00 AM	1.07
12/5/2015	2:30:00 AM	1.07
12/5/2015	2:45:00 AM	1.07
12/5/2015	3:00:00 AM	1.06
12/5/2015	3:15:00 AM	1.06
12/5/2015	3:30:00 AM	1.07
12/5/2015	3:45:00 AM	1.06
12/5/2015	4:00:00 AM	1.07
12/5/2015	4:15:00 AM	1.06
12/5/2015	4:30:00 AM	1.06
12/5/2015	4:45:00 AM	1.06
12/5/2015	5:00:00 AM	1.06
12/5/2015	5:15:00 AM	1.07
12/5/2015	5:30:00 AM	1.07
12/5/2015	5:45:00 AM	1.07
12/5/2015	6:00:00 AM	1.07
12/5/2015	6:15:00 AM	1.06
12/5/2015	6:30:00 AM	1.06
12/5/2015	6:45:00 AM	1.06
12/5/2015	7:00:00 AM	1.06
12/5/2015	7:15:00 AM	1.07

Georges Ditch Return Gage

DATE	TIME	GAGE
12/5/2015	7:30:00 AM	1.07
12/5/2015	7:45:00 AM	1.07
12/5/2015	8:00:00 AM	1.07
12/5/2015	8:15:00 AM	1.07
12/5/2015	8:30:00 AM	1.06
12/5/2015	8:45:00 AM	1.07
12/5/2015	9:00:00 AM	1.06
12/5/2015	9:15:00 AM	1.07
12/5/2015	9:30:00 AM	1.07
12/5/2015	9:45:00 AM	1.07
12/5/2015	10:00:00 AM	1.07
12/5/2015	10:15:00 AM	1.07
12/5/2015	10:30:00 AM	1.06
12/5/2015	10:45:00 AM	1.07
12/5/2015	11:00:00 AM	1.06
12/5/2015	11:15:00 AM	1.07
12/5/2015	11:30:00 AM	1.07
12/5/2015	11:45:00 AM	1.06
12/5/2015	12:00:00 PM	1.07
12/5/2015	12:15:00 PM	1.07
12/5/2015	12:30:00 PM	1.07
12/5/2015	12:45:00 PM	1.07
12/5/2015	1:00:00 PM	1.07
12/5/2015	1:15:00 PM	1.07
12/5/2015	1:30:00 PM	1.07
12/5/2015	1:45:00 PM	1.07
12/5/2015	2:00:00 PM	1.07
12/5/2015	2:15:00 PM	1.07
12/5/2015	2:30:00 PM	1.06
12/5/2015	2:45:00 PM	1.07
12/5/2015	3:00:00 PM	1.07
12/5/2015	3:15:00 PM	1.07
12/5/2015	3:30:00 PM	1.07
12/5/2015	3:45:00 PM	1.07
12/5/2015	4:00:00 PM	1.07
12/5/2015	4:15:00 PM	1.07
12/5/2015	4:30:00 PM	1.07
12/5/2015	4:45:00 PM	1.06
12/5/2015	5:00:00 PM	1.06
12/5/2015	5:15:00 PM	1.07
12/5/2015	5:30:00 PM	1.07
12/5/2015	5:45:00 PM	1.06
12/5/2015	6:00:00 PM	1.03
12/5/2015	6:15:00 PM	0.91
12/5/2015	6:30:00 PM	0.72
12/5/2015	6:45:00 PM	0.57

Georges Ditch Return Gage

DATE	TIME	GAGE
12/5/2015	7:00:00 PM	0.5
12/5/2015	7:15:00 PM	0.44
12/5/2015	7:30:00 PM	0.4
12/5/2015	7:45:00 PM	0.36
12/5/2015	8:00:00 PM	0.34
12/5/2015	8:15:00 PM	0.31
12/5/2015	8:30:00 PM	0.29
12/5/2015	8:45:00 PM	0.27
12/5/2015	9:00:00 PM	0.25
12/5/2015	9:15:00 PM	0.24
12/5/2015	9:30:00 PM	0.22
12/5/2015	9:45:00 PM	0.21
12/5/2015	10:00:00 PM	0.2
12/5/2015	10:15:00 PM	0.19
12/5/2015	10:30:00 PM	0.19
12/5/2015	10:45:00 PM	0.18
12/5/2015	11:00:00 PM	0.17
12/5/2015	11:15:00 PM	0.17
12/5/2015	11:30:00 PM	0.16
12/5/2015	11:45:00 PM	0.16
12/6/2015	12:00:00 AM	0.16
12/6/2015	12:15:00 AM	0.15
12/6/2015	12:30:00 AM	0.14
12/6/2015	12:45:00 AM	0.14
12/6/2015	1:00:00 AM	0.14
12/6/2015	1:15:00 AM	0.13
12/6/2015	1:30:00 AM	0.13
12/6/2015	1:45:00 AM	0.12
12/6/2015	2:00:00 AM	0.12
12/6/2015	2:15:00 AM	0.12
12/6/2015	2:30:00 AM	0.12
12/6/2015	2:45:00 AM	0.11
12/6/2015	3:00:00 AM	0.11
12/6/2015	3:15:00 AM	0.11
12/6/2015	3:30:00 AM	0.1
12/6/2015	3:45:00 AM	0.1
12/6/2015	4:00:00 AM	0.1
12/6/2015	4:15:00 AM	0.1
12/6/2015	4:30:00 AM	0.1
12/6/2015	4:45:00 AM	0.1
12/6/2015	5:00:00 AM	0.1
12/6/2015	5:15:00 AM	0.09
12/6/2015	5:30:00 AM	0.09
12/6/2015	5:45:00 AM	0.09
12/6/2015	6:00:00 AM	0.09
12/6/2015	6:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
12/6/2015	6:30:00 AM	0.08
12/6/2015	6:45:00 AM	0.08
12/6/2015	7:00:00 AM	0.08
12/6/2015	7:15:00 AM	0.08
12/6/2015	7:30:00 AM	0.08
12/6/2015	7:45:00 AM	0.08
12/6/2015	8:00:00 AM	0.08
12/6/2015	8:15:00 AM	0.08
12/6/2015	8:30:00 AM	0.08
12/6/2015	8:45:00 AM	0.07
12/6/2015	9:00:00 AM	0.07
12/6/2015	9:15:00 AM	0.07
12/6/2015	9:30:00 AM	0.07
12/6/2015	9:45:00 AM	0.07
12/6/2015	10:00:00 AM	0.07
12/6/2015	10:15:00 AM	0.07
12/6/2015	10:30:00 AM	0.07
12/6/2015	10:45:00 AM	0.07
12/6/2015	11:00:00 AM	0.07
12/6/2015	11:15:00 AM	0.07
12/6/2015	11:30:00 AM	0.07
12/6/2015	11:45:00 AM	0.07
12/6/2015	12:00:00 PM	0.07
12/6/2015	12:15:00 PM	0.07
12/6/2015	12:30:00 PM	0.07
12/6/2015	12:45:00 PM	0.06
12/6/2015	1:00:00 PM	0.06
12/6/2015	1:15:00 PM	0.06
12/6/2015	1:30:00 PM	0.06
12/6/2015	1:45:00 PM	0.06
12/6/2015	2:00:00 PM	0.06
12/6/2015	2:15:00 PM	0.06
12/6/2015	2:30:00 PM	0.06
12/6/2015	2:45:00 PM	0.06
12/6/2015	3:00:00 PM	0.06
12/6/2015	3:15:00 PM	0.06
12/6/2015	3:30:00 PM	0.06
12/6/2015	3:45:00 PM	0.06
12/6/2015	4:00:00 PM	0.06
12/6/2015	4:15:00 PM	0.06
12/6/2015	4:30:00 PM	0.06
12/6/2015	4:45:00 PM	0.06
12/6/2015	5:00:00 PM	0.06
12/6/2015	5:15:00 PM	0.06
12/6/2015	5:30:00 PM	0.06
12/6/2015	5:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
12/6/2015	6:00:00 PM	0.06
12/6/2015	6:15:00 PM	0.06
12/6/2015	6:30:00 PM	0.06
12/6/2015	6:45:00 PM	0.06
12/6/2015	7:00:00 PM	0.06
12/6/2015	7:15:00 PM	0.06
12/6/2015	7:30:00 PM	0.06
12/6/2015	7:45:00 PM	0.06
12/6/2015	8:00:00 PM	0.06
12/6/2015	8:15:00 PM	0.06
12/6/2015	8:30:00 PM	0.05
12/6/2015	8:45:00 PM	0.05
12/6/2015	9:00:00 PM	0.05
12/6/2015	9:15:00 PM	0.05
12/6/2015	9:30:00 PM	0.05
12/6/2015	9:45:00 PM	0.11
12/6/2015	10:00:00 PM	0.15
12/6/2015	10:15:00 PM	0.16
12/6/2015	10:30:00 PM	0.16
12/6/2015	10:45:00 PM	0.16
12/6/2015	11:00:00 PM	0.16
12/6/2015	11:15:00 PM	0.16
12/6/2015	11:30:00 PM	0.16
12/6/2015	11:45:00 PM	0.16
12/7/2015	12:00:00 AM	0.16
12/7/2015	12:15:00 AM	0.16
12/7/2015	12:30:00 AM	0.16
12/7/2015	12:45:00 AM	0.16
12/7/2015	1:00:00 AM	0.16
12/7/2015	1:15:00 AM	0.16
12/7/2015	1:30:00 AM	0.16
12/7/2015	1:45:00 AM	0.16
12/7/2015	2:00:00 AM	0.16
12/7/2015	2:15:00 AM	0.16
12/7/2015	2:30:00 AM	0.16
12/7/2015	2:45:00 AM	0.15
12/7/2015	3:00:00 AM	0.15
12/7/2015	3:15:00 AM	0.15
12/7/2015	3:30:00 AM	0.15
12/7/2015	3:45:00 AM	0.15
12/7/2015	4:00:00 AM	0.15
12/7/2015	4:15:00 AM	0.15
12/7/2015	4:30:00 AM	0.14
12/7/2015	4:45:00 AM	0.14
12/7/2015	5:00:00 AM	0.15
12/7/2015	5:15:00 AM	0.15

Georges Ditch Return Gage

DATE	TIME	GAGE
12/7/2015	5:30:00 AM	0.15
12/7/2015	5:45:00 AM	0.15
12/7/2015	6:00:00 AM	0.15
12/7/2015	6:15:00 AM	0.15
12/7/2015	6:30:00 AM	0.15
12/7/2015	6:45:00 AM	0.15
12/7/2015	7:00:00 AM	0.15
12/7/2015	7:15:00 AM	0.15
12/7/2015	7:30:00 AM	0.15
12/7/2015	7:45:00 AM	0.15
12/7/2015	8:00:00 AM	0.15
12/7/2015	8:15:00 AM	0.15
12/7/2015	8:30:00 AM	0.15
12/7/2015	8:45:00 AM	0.15
12/7/2015	9:00:00 AM	0.15
12/7/2015	9:15:00 AM	0.15
12/7/2015	9:30:00 AM	0.15
12/7/2015	9:45:00 AM	0.15
12/7/2015	10:00:00 AM	0.15
12/7/2015	10:15:00 AM	0.15
12/7/2015	10:30:00 AM	0.15
12/7/2015	10:45:00 AM	0.15
12/7/2015	11:00:00 AM	0.15
12/7/2015	11:15:00 AM	0.15
12/7/2015	11:30:00 AM	0.15
12/7/2015	11:45:00 AM	0.15
12/7/2015	12:00:00 PM	0.15
12/7/2015	12:15:00 PM	0.15
12/7/2015	12:30:00 PM	0.15
12/7/2015	12:45:00 PM	0.15
12/7/2015	1:00:00 PM	0.15
12/7/2015	1:15:00 PM	0.15
12/7/2015	1:30:00 PM	0.15
12/7/2015	1:45:00 PM	0.15
12/7/2015	2:00:00 PM	0.15
12/7/2015	2:15:00 PM	0.15
12/7/2015	2:30:00 PM	0.15
12/7/2015	2:45:00 PM	0.15
12/7/2015	3:00:00 PM	0.15
12/7/2015	3:15:00 PM	0.15
12/7/2015	3:30:00 PM	0.15
12/7/2015	3:45:00 PM	0.15
12/7/2015	4:00:00 PM	0.15
12/7/2015	4:15:00 PM	0.15
12/7/2015	4:30:00 PM	0.14
12/7/2015	4:45:00 PM	0.14

Georges Ditch Return Gage

DATE	TIME	GAGE
12/7/2015	5:00:00 PM	0.13
12/7/2015	5:15:00 PM	0.13
12/7/2015	5:30:00 PM	0.12
12/7/2015	5:45:00 PM	0.12
12/7/2015	6:00:00 PM	0.11
12/7/2015	6:15:00 PM	0.11
12/7/2015	6:30:00 PM	0.1
12/7/2015	6:45:00 PM	0.1
12/7/2015	7:00:00 PM	0.1
12/7/2015	7:15:00 PM	0.1
12/7/2015	7:30:00 PM	0.09
12/7/2015	7:45:00 PM	0.09
12/7/2015	8:00:00 PM	0.09
12/7/2015	8:15:00 PM	0.09
12/7/2015	8:30:00 PM	0.08
12/7/2015	8:45:00 PM	0.08
12/7/2015	9:00:00 PM	0.08
12/7/2015	9:15:00 PM	0.08
12/7/2015	9:30:00 PM	0.08
12/7/2015	9:45:00 PM	0.08
12/7/2015	10:00:00 PM	0.08
12/7/2015	10:15:00 PM	0.08
12/7/2015	10:30:00 PM	0.08
12/7/2015	10:45:00 PM	0.08
12/7/2015	11:00:00 PM	0.08
12/7/2015	11:15:00 PM	0.08
12/7/2015	11:30:00 PM	0.08
12/7/2015	11:45:00 PM	0.08
12/8/2015	12:00:00 AM	0.08
12/8/2015	12:15:00 AM	0.08
12/8/2015	12:30:00 AM	0.08
12/8/2015	12:45:00 AM	0.08
12/8/2015	1:00:00 AM	0.08
12/8/2015	1:15:00 AM	0.08
12/8/2015	1:30:00 AM	0.08
12/8/2015	1:45:00 AM	0.08
12/8/2015	2:00:00 AM	0.08
12/8/2015	2:15:00 AM	0.08
12/8/2015	2:30:00 AM	0.08
12/8/2015	2:45:00 AM	0.08
12/8/2015	3:00:00 AM	0.08
12/8/2015	3:15:00 AM	0.08
12/8/2015	3:30:00 AM	0.08
12/8/2015	3:45:00 AM	0.08
12/8/2015	4:00:00 AM	0.08
12/8/2015	4:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
12/8/2015	4:30:00 AM	0.08
12/8/2015	4:45:00 AM	0.07
12/8/2015	5:00:00 AM	0.07
12/8/2015	5:15:00 AM	0.07
12/8/2015	5:30:00 AM	0.07
12/8/2015	5:45:00 AM	0.07
12/8/2015	6:00:00 AM	0.07
12/8/2015	6:15:00 AM	0.07
12/8/2015	6:30:00 AM	0.07
12/8/2015	6:45:00 AM	0.07
12/8/2015	7:00:00 AM	0.07
12/8/2015	7:15:00 AM	0.07
12/8/2015	7:30:00 AM	0.07
12/8/2015	7:45:00 AM	0.07
12/8/2015	8:00:00 AM	0.07
12/8/2015	8:15:00 AM	0.07
12/8/2015	8:30:00 AM	0.07
12/8/2015	8:45:00 AM	0.07
12/8/2015	9:00:00 AM	0.07
12/8/2015	9:15:00 AM	0.07
12/8/2015	9:30:00 AM	0.07
12/8/2015	9:45:00 AM	0.07
12/8/2015	10:00:00 AM	0.07
12/8/2015	10:15:00 AM	0.07
12/8/2015	10:30:00 AM	0.07
12/8/2015	10:45:00 AM	0.07
12/8/2015	11:00:00 AM	0.07
12/8/2015	11:15:00 AM	0.07
12/8/2015	11:30:00 AM	0.07
12/8/2015	11:45:00 AM	0.07
12/8/2015	12:00:00 PM	0.07
12/8/2015	12:15:00 PM	0.07
12/8/2015	12:30:00 PM	0.07
12/8/2015	12:45:00 PM	0.07
12/8/2015	1:00:00 PM	0.07
12/8/2015	1:15:00 PM	0.07
12/8/2015	1:30:00 PM	0.07
12/8/2015	1:45:00 PM	0.07
12/8/2015	2:00:00 PM	0.07
12/8/2015	2:15:00 PM	0.07
12/8/2015	2:30:00 PM	0.07
12/8/2015	2:45:00 PM	0.07
12/8/2015	3:00:00 PM	0.07
12/8/2015	3:15:00 PM	0.07
12/8/2015	3:30:00 PM	0.07
12/8/2015	3:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
12/8/2015	4:00:00 PM	0.07
12/8/2015	4:15:00 PM	0.07
12/8/2015	4:30:00 PM	0.07
12/8/2015	4:45:00 PM	0.07
12/8/2015	5:00:00 PM	0.07
12/8/2015	5:15:00 PM	0.07
12/8/2015	5:30:00 PM	0.07
12/8/2015	5:45:00 PM	0.07
12/8/2015	6:00:00 PM	0.07
12/8/2015	6:15:00 PM	0.07
12/8/2015	6:30:00 PM	0.07
12/8/2015	6:45:00 PM	0.07
12/8/2015	7:00:00 PM	0.07
12/8/2015	7:15:00 PM	0.07
12/8/2015	7:30:00 PM	0.08
12/8/2015	7:45:00 PM	0.08
12/8/2015	8:00:00 PM	0.08
12/8/2015	8:15:00 PM	0.08
12/8/2015	8:30:00 PM	0.08
12/8/2015	8:45:00 PM	0.08
12/8/2015	9:00:00 PM	0.08
12/8/2015	9:15:00 PM	0.08
12/8/2015	9:30:00 PM	0.08
12/8/2015	9:45:00 PM	0.08
12/8/2015	10:00:00 PM	0.08
12/8/2015	10:15:00 PM	0.08
12/8/2015	10:30:00 PM	0.08
12/8/2015	10:45:00 PM	0.08
12/8/2015	11:00:00 PM	0.08
12/8/2015	11:15:00 PM	0.08
12/8/2015	11:30:00 PM	0.08
12/8/2015	11:45:00 PM	0.08
12/9/2015	12:00:00 AM	0.08
12/9/2015	12:15:00 AM	0.08
12/9/2015	12:30:00 AM	0.08
12/9/2015	12:45:00 AM	0.08
12/9/2015	1:00:00 AM	0.08
12/9/2015	1:15:00 AM	0.08
12/9/2015	1:30:00 AM	0.08
12/9/2015	1:45:00 AM	0.08
12/9/2015	2:00:00 AM	0.08
12/9/2015	2:15:00 AM	0.08
12/9/2015	2:30:00 AM	0.08
12/9/2015	2:45:00 AM	0.08
12/9/2015	3:00:00 AM	0.08
12/9/2015	3:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
12/9/2015	3:30:00 AM	0.08
12/9/2015	3:45:00 AM	0.08
12/9/2015	4:00:00 AM	0.08
12/9/2015	4:15:00 AM	0.08
12/9/2015	4:30:00 AM	0.08
12/9/2015	4:45:00 AM	0.08
12/9/2015	5:00:00 AM	0.08
12/9/2015	5:15:00 AM	0.08
12/9/2015	5:30:00 AM	0.08
12/9/2015	5:45:00 AM	0.08
12/9/2015	6:00:00 AM	0.08
12/9/2015	6:15:00 AM	0.08
12/9/2015	6:30:00 AM	0.07
12/9/2015	6:45:00 AM	0.07
12/9/2015	7:00:00 AM	0.07
12/9/2015	7:15:00 AM	0.07
12/9/2015	7:30:00 AM	0.07
12/9/2015	7:45:00 AM	0.07
12/9/2015	8:00:00 AM	0.07
12/9/2015	8:15:00 AM	0.07
12/9/2015	8:30:00 AM	0.07
12/9/2015	8:45:00 AM	0.07
12/9/2015	9:00:00 AM	0.07
12/9/2015	9:15:00 AM	0.07
12/9/2015	9:30:00 AM	0.07
12/9/2015	9:45:00 AM	0.07
12/9/2015	10:00:00 AM	0.07
12/9/2015	10:15:00 AM	0.07
12/9/2015	10:30:00 AM	0.07
12/9/2015	10:45:00 AM	0.07
12/9/2015	11:00:00 AM	0.07
12/9/2015	11:15:00 AM	0.07
12/9/2015	11:30:00 AM	0.07
12/9/2015	11:45:00 AM	0.07
12/9/2015	12:00:00 PM	0.07
12/9/2015	12:15:00 PM	0.07
12/9/2015	12:30:00 PM	0.07
12/9/2015	12:45:00 PM	0.07
12/9/2015	1:00:00 PM	0.07
12/9/2015	1:15:00 PM	0.07
12/9/2015	1:30:00 PM	0.07
12/9/2015	1:45:00 PM	0.07
12/9/2015	2:00:00 PM	0.07
12/9/2015	2:15:00 PM	0.07
12/9/2015	2:30:00 PM	0.07
12/9/2015	2:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
12/9/2015	3:00:00 PM	0.07
12/9/2015	3:15:00 PM	0.07
12/9/2015	3:30:00 PM	0.07
12/9/2015	3:45:00 PM	0.07
12/9/2015	4:00:00 PM	0.07
12/9/2015	4:15:00 PM	0.07
12/9/2015	4:30:00 PM	0.07
12/9/2015	4:45:00 PM	0.07
12/9/2015	5:00:00 PM	0.07
12/9/2015	5:15:00 PM	0.07
12/9/2015	5:30:00 PM	0.07
12/9/2015	5:45:00 PM	0.07
12/9/2015	6:00:00 PM	0.07
12/9/2015	6:15:00 PM	0.07
12/9/2015	6:30:00 PM	0.07
12/9/2015	6:45:00 PM	0.07
12/9/2015	7:00:00 PM	0.07
12/9/2015	7:15:00 PM	0.07
12/9/2015	7:30:00 PM	0.07
12/9/2015	7:45:00 PM	0.07
12/9/2015	8:00:00 PM	0.07
12/9/2015	8:15:00 PM	0.07
12/9/2015	8:30:00 PM	0.07
12/9/2015	8:45:00 PM	0.07
12/9/2015	9:00:00 PM	0.07
12/9/2015	9:15:00 PM	0.07
12/9/2015	9:30:00 PM	0.07
12/9/2015	9:45:00 PM	0.07
12/9/2015	10:00:00 PM	0.07
12/9/2015	10:15:00 PM	0.07
12/9/2015	10:30:00 PM	0.07
12/9/2015	10:45:00 PM	0.07
12/9/2015	11:00:00 PM	0.07
12/9/2015	11:15:00 PM	0.07
12/9/2015	11:30:00 PM	0.07
12/9/2015	11:45:00 PM	0.07
12/10/2015	12:00:00 AM	0.07
12/10/2015	12:15:00 AM	0.07
12/10/2015	12:30:00 AM	0.07
12/10/2015	12:45:00 AM	0.07
12/10/2015	1:00:00 AM	0.07
12/10/2015	1:15:00 AM	0.07
12/10/2015	1:30:00 AM	0.07
12/10/2015	1:45:00 AM	0.07
12/10/2015	2:00:00 AM	0.07
12/10/2015	2:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
12/10/2015	2:30:00 AM	0.07
12/10/2015	2:45:00 AM	0.07
12/10/2015	3:00:00 AM	0.07
12/10/2015	3:15:00 AM	0.07
12/10/2015	3:30:00 AM	0.07
12/10/2015	3:45:00 AM	0.07
12/10/2015	4:00:00 AM	0.07
12/10/2015	4:15:00 AM	0.07
12/10/2015	4:30:00 AM	0.07
12/10/2015	4:45:00 AM	0.07
12/10/2015	5:00:00 AM	0.07
12/10/2015	5:15:00 AM	0.07
12/10/2015	5:30:00 AM	0.06
12/10/2015	5:45:00 AM	0.06
12/10/2015	6:00:00 AM	0.06
12/10/2015	6:15:00 AM	0.06
12/10/2015	6:30:00 AM	0.06
12/10/2015	6:45:00 AM	0.06
12/10/2015	7:00:00 AM	0.06
12/10/2015	7:15:00 AM	0.06
12/10/2015	7:30:00 AM	0.06
12/10/2015	7:45:00 AM	0.06
12/10/2015	8:00:00 AM	0.06
12/10/2015	8:15:00 AM	0.06
12/10/2015	8:30:00 AM	0.06
12/10/2015	8:45:00 AM	0.06
12/10/2015	9:00:00 AM	0.06
12/10/2015	9:15:00 AM	0.06
12/10/2015	9:30:00 AM	0.06
12/10/2015	9:45:00 AM	0.06
12/10/2015	10:00:00 AM	0.06
12/10/2015	10:15:00 AM	0.06
12/10/2015	10:30:00 AM	0.06
12/10/2015	10:45:00 AM	0.06
12/10/2015	11:00:00 AM	0.06
12/10/2015	11:15:00 AM	0.06
12/10/2015	11:30:00 AM	0.06
12/10/2015	11:45:00 AM	0.06
12/10/2015	12:00:00 PM	0.06
12/10/2015	12:15:00 PM	0.06
12/10/2015	12:30:00 PM	0.06
12/10/2015	12:45:00 PM	0.06
12/10/2015	1:00:00 PM	0.07
12/10/2015	1:15:00 PM	0.06
12/10/2015	1:30:00 PM	0.06
12/10/2015	1:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
12/10/2015	2:00:00 PM	0.06
12/10/2015	2:15:00 PM	0.06
12/10/2015	2:30:00 PM	0.06
12/10/2015	2:45:00 PM	0.06
12/10/2015	3:00:00 PM	0.06
12/10/2015	3:15:00 PM	0.06
12/10/2015	3:30:00 PM	0.06
12/10/2015	3:45:00 PM	0.06
12/10/2015	4:00:00 PM	0.06
12/10/2015	4:15:00 PM	0.06
12/10/2015	4:30:00 PM	0.06
12/10/2015	4:45:00 PM	0.06
12/10/2015	5:00:00 PM	0.06
12/10/2015	5:15:00 PM	0.06
12/10/2015	5:30:00 PM	0.06
12/10/2015	5:45:00 PM	0.06
12/10/2015	6:00:00 PM	0.06
12/10/2015	6:15:00 PM	0.06
12/10/2015	6:30:00 PM	0.06
12/10/2015	6:45:00 PM	0.06
12/10/2015	7:00:00 PM	0.06
12/10/2015	7:15:00 PM	0.06
12/10/2015	7:30:00 PM	0.06
12/10/2015	7:45:00 PM	0.06
12/10/2015	8:00:00 PM	0.06
12/10/2015	8:15:00 PM	0.06
12/10/2015	8:30:00 PM	0.06
12/10/2015	8:45:00 PM	0.06
12/10/2015	9:00:00 PM	0.06
12/10/2015	9:15:00 PM	0.06
12/10/2015	9:30:00 PM	0.06
12/10/2015	9:45:00 PM	0.06
12/10/2015	10:00:00 PM	0.06
12/10/2015	10:15:00 PM	0.06
12/10/2015	10:30:00 PM	0.06
12/10/2015	10:45:00 PM	0.06
12/10/2015	11:00:00 PM	0.06
12/10/2015	11:15:00 PM	0.06
12/10/2015	11:30:00 PM	0.06
12/10/2015	11:45:00 PM	0.06
12/11/2015	12:00:00 AM	0.06
12/11/2015	12:15:00 AM	0.06
12/11/2015	12:30:00 AM	0.06
12/11/2015	12:45:00 AM	0.06
12/11/2015	1:00:00 AM	0.06
12/11/2015	1:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
12/11/2015	1:30:00 AM	0.06
12/11/2015	1:45:00 AM	0.06
12/11/2015	2:00:00 AM	0.06
12/11/2015	2:15:00 AM	0.06
12/11/2015	2:30:00 AM	0.06
12/11/2015	2:45:00 AM	0.06
12/11/2015	3:00:00 AM	0.06
12/11/2015	3:15:00 AM	0.06
12/11/2015	3:30:00 AM	0.06
12/11/2015	3:45:00 AM	0.06
12/11/2015	4:00:00 AM	0.06
12/11/2015	4:15:00 AM	0.06
12/11/2015	4:30:00 AM	0.06
12/11/2015	4:45:00 AM	0.06
12/11/2015	5:00:00 AM	0.06
12/11/2015	5:15:00 AM	0.06
12/11/2015	5:30:00 AM	0.06
12/11/2015	5:45:00 AM	0.06
12/11/2015	6:00:00 AM	0.06
12/11/2015	6:15:00 AM	0.06
12/11/2015	6:30:00 AM	0.06
12/11/2015	6:45:00 AM	0.06
12/11/2015	7:00:00 AM	0.06
12/11/2015	7:15:00 AM	0.06
12/11/2015	7:30:00 AM	0.06
12/11/2015	7:45:00 AM	0.06
12/11/2015	8:00:00 AM	0.06
12/11/2015	8:15:00 AM	0.06
12/11/2015	8:30:00 AM	0.06
12/11/2015	8:45:00 AM	0.06
12/11/2015	9:00:00 AM	0.06
12/11/2015	9:15:00 AM	0.06
12/11/2015	9:30:00 AM	0.06
12/11/2015	9:45:00 AM	0.06
12/11/2015	10:00:00 AM	0.06
12/11/2015	10:15:00 AM	0.06
12/11/2015	10:30:00 AM	0.06
12/11/2015	10:45:00 AM	0.05
12/11/2015	11:00:00 AM	0.05
12/11/2015	11:15:00 AM	0.05
12/11/2015	11:30:00 AM	0.05
12/11/2015	11:45:00 AM	0.05
12/11/2015	12:00:00 PM	0.05
12/11/2015	12:15:00 PM	0.05
12/11/2015	12:30:00 PM	0.05
12/11/2015	12:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/11/2015	1:00:00 PM	0.05
12/11/2015	1:15:00 PM	0.05
12/11/2015	1:30:00 PM	0.05
12/11/2015	1:45:00 PM	0.05
12/11/2015	2:00:00 PM	0.05
12/11/2015	2:15:00 PM	0.05
12/11/2015	2:30:00 PM	0.05
12/11/2015	2:45:00 PM	0.05
12/11/2015	3:00:00 PM	0.05
12/11/2015	3:15:00 PM	0.05
12/11/2015	3:30:00 PM	0.05
12/11/2015	3:45:00 PM	0.05
12/11/2015	4:00:00 PM	0.05
12/11/2015	4:15:00 PM	0.05
12/11/2015	4:30:00 PM	0.05
12/11/2015	4:45:00 PM	0.05
12/11/2015	5:00:00 PM	0.05
12/11/2015	5:15:00 PM	0.05
12/11/2015	5:30:00 PM	0.05
12/11/2015	5:45:00 PM	0.05
12/11/2015	6:00:00 PM	0.05
12/11/2015	6:15:00 PM	0.05
12/11/2015	6:30:00 PM	0.05
12/11/2015	6:45:00 PM	0.05
12/11/2015	7:00:00 PM	0.05
12/11/2015	7:15:00 PM	0.05
12/11/2015	7:30:00 PM	0.05
12/11/2015	7:45:00 PM	0.05
12/11/2015	8:00:00 PM	0.05
12/11/2015	8:15:00 PM	0.05
12/11/2015	8:30:00 PM	0.05
12/11/2015	8:45:00 PM	0.05
12/11/2015	9:00:00 PM	0.05
12/11/2015	9:15:00 PM	0.05
12/11/2015	9:30:00 PM	0.05
12/11/2015	9:45:00 PM	0.05
12/11/2015	10:00:00 PM	0.05
12/11/2015	10:15:00 PM	0.05
12/11/2015	10:30:00 PM	0.05
12/11/2015	10:45:00 PM	0.05
12/11/2015	11:00:00 PM	0.05
12/11/2015	11:15:00 PM	0.05
12/11/2015	11:30:00 PM	0.05
12/11/2015	11:45:00 PM	0.05
12/12/2015	12:00:00 AM	0.05
12/12/2015	12:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	12:30:00 AM	0.05
12/12/2015	12:45:00 AM	0.05
12/12/2015	1:00:00 AM	0.05
12/12/2015	1:15:00 AM	0.05
12/12/2015	1:30:00 AM	0.05
12/12/2015	1:45:00 AM	0.05
12/12/2015	2:00:00 AM	0.05
12/12/2015	2:15:00 AM	0.04
12/12/2015	2:30:00 AM	0.04
12/12/2015	2:45:00 AM	0.04
12/12/2015	3:00:00 AM	0.04
12/12/2015	3:15:00 AM	0.04
12/12/2015	3:30:00 AM	0.04
12/12/2015	3:45:00 AM	0.04
12/12/2015	4:00:00 AM	0.04
12/12/2015	4:15:00 AM	0.04
12/12/2015	4:30:00 AM	0.04
12/12/2015	4:45:00 AM	0.04
12/12/2015	5:00:00 AM	0.04
12/12/2015	5:15:00 AM	0.04
12/12/2015	5:30:00 AM	0.04
12/12/2015	5:45:00 AM	0.04
12/12/2015	6:00:00 AM	0.04
12/12/2015	6:15:00 AM	0.04
12/12/2015	6:30:00 AM	0.04
12/12/2015	6:45:00 AM	0.04
12/12/2015	7:00:00 AM	0.04
12/12/2015	7:15:00 AM	0.04
12/12/2015	7:30:00 AM	0.04
12/12/2015	7:45:00 AM	0.04
12/12/2015	8:00:00 AM	0.04
12/12/2015	8:15:00 AM	0.04
12/12/2015	8:30:00 AM	0.04
12/12/2015	8:45:00 AM	0.04
12/12/2015	9:00:00 AM	0.04
12/12/2015	9:15:00 AM	0.04
12/12/2015	9:30:00 AM	0.04
12/12/2015	9:45:00 AM	0.04
12/12/2015	10:00:00 AM	0.04
12/12/2015	10:15:00 AM	0.04
12/12/2015	10:30:00 AM	0.04
12/12/2015	10:45:00 AM	0.04
12/12/2015	11:00:00 AM	0.04
12/12/2015	11:15:00 AM	0.04
12/12/2015	11:30:00 AM	0.04
12/12/2015	11:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	12:00:00 PM	0.04
12/12/2015	12:15:00 PM	0.04
12/12/2015	12:30:00 PM	0.04
12/12/2015	12:45:00 PM	0.04
12/12/2015	1:00:00 PM	0.04
12/12/2015	1:15:00 PM	0.04
12/12/2015	1:30:00 PM	0.04
12/12/2015	1:45:00 PM	0.04
12/12/2015	2:00:00 PM	0.04
12/12/2015	2:15:00 PM	0.04
12/12/2015	2:30:00 PM	0.04
12/12/2015	2:45:00 PM	0.04
12/12/2015	3:00:00 PM	0.04
12/12/2015	3:15:00 PM	0.04
12/12/2015	3:30:00 PM	0.04
12/12/2015	3:45:00 PM	0.04
12/12/2015	4:00:00 PM	0.04
12/12/2015	4:15:00 PM	0.04
12/12/2015	4:30:00 PM	0.04
12/12/2015	4:45:00 PM	0.04
12/12/2015	5:00:00 PM	0.04
12/12/2015	5:15:00 PM	0.04
12/12/2015	5:30:00 PM	0.04
12/12/2015	5:45:00 PM	0.04
12/12/2015	6:00:00 PM	0.04
12/12/2015	6:15:00 PM	0.04
12/12/2015	6:30:00 PM	0.04
12/12/2015	6:45:00 PM	0.04
12/12/2015	7:00:00 PM	0.04
12/12/2015	7:15:00 PM	0.04
12/12/2015	7:30:00 PM	0.04
12/12/2015	7:45:00 PM	0.04
12/12/2015	8:00:00 PM	0.04
12/12/2015	8:15:00 PM	0.04
12/12/2015	8:30:00 PM	0.04
12/12/2015	8:45:00 PM	0.04
12/12/2015	9:00:00 PM	0.04
12/12/2015	9:15:00 PM	0.04
12/12/2015	9:30:00 PM	0.04
12/12/2015	9:45:00 PM	0.04
12/12/2015	10:00:00 PM	0.04
12/12/2015	10:15:00 PM	0.04
12/12/2015	10:30:00 PM	0.04
12/12/2015	10:45:00 PM	0.04
12/12/2015	11:00:00 PM	0.04
12/12/2015	11:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/12/2015	11:30:00 PM	0.04
12/12/2015	11:45:00 PM	0.04
12/13/2015	12:00:00 AM	0.04
12/13/2015	12:15:00 AM	0.04
12/13/2015	12:30:00 AM	0.04
12/13/2015	12:45:00 AM	0.04
12/13/2015	1:00:00 AM	0.04
12/13/2015	1:15:00 AM	0.04
12/13/2015	1:30:00 AM	0.04
12/13/2015	1:45:00 AM	0.04
12/13/2015	2:00:00 AM	0.04
12/13/2015	2:15:00 AM	0.04
12/13/2015	2:30:00 AM	0.04
12/13/2015	2:45:00 AM	0.04
12/13/2015	3:00:00 AM	0.04
12/13/2015	3:15:00 AM	0.04
12/13/2015	3:30:00 AM	0.04
12/13/2015	3:45:00 AM	0.04
12/13/2015	4:00:00 AM	0.04
12/13/2015	4:15:00 AM	0.04
12/13/2015	4:30:00 AM	0.04
12/13/2015	4:45:00 AM	0.04
12/13/2015	5:00:00 AM	0.04
12/13/2015	5:15:00 AM	0.04
12/13/2015	5:30:00 AM	0.04
12/13/2015	5:45:00 AM	0.04
12/13/2015	6:00:00 AM	0.04
12/13/2015	6:15:00 AM	0.04
12/13/2015	6:30:00 AM	0.04
12/13/2015	6:45:00 AM	0.04
12/13/2015	7:00:00 AM	0.04
12/13/2015	7:15:00 AM	0.04
12/13/2015	7:30:00 AM	0.04
12/13/2015	7:45:00 AM	0.04
12/13/2015	8:00:00 AM	0.04
12/13/2015	8:15:00 AM	0.04
12/13/2015	8:30:00 AM	0.04
12/13/2015	8:45:00 AM	0.04
12/13/2015	9:00:00 AM	0.04
12/13/2015	9:15:00 AM	0.04
12/13/2015	9:30:00 AM	0.04
12/13/2015	9:45:00 AM	0.04
12/13/2015	10:00:00 AM	0.04
12/13/2015	10:15:00 AM	0.04
12/13/2015	10:30:00 AM	0.04
12/13/2015	10:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/13/2015	11:00:00 AM	0.05
12/13/2015	11:15:00 AM	0.05
12/13/2015	11:30:00 AM	0.05
12/13/2015	11:45:00 AM	0.05
12/13/2015	12:00:00 PM	0.05
12/13/2015	12:15:00 PM	0.05
12/13/2015	12:30:00 PM	0.04
12/13/2015	12:45:00 PM	0.04
12/13/2015	1:00:00 PM	0.04
12/13/2015	1:15:00 PM	0.04
12/13/2015	1:30:00 PM	0.04
12/13/2015	1:45:00 PM	0.04
12/13/2015	2:00:00 PM	0.04
12/13/2015	2:15:00 PM	0.04
12/13/2015	2:30:00 PM	0.04
12/13/2015	2:45:00 PM	0.04
12/13/2015	3:00:00 PM	0.04
12/13/2015	3:15:00 PM	0.04
12/13/2015	3:30:00 PM	0.04
12/13/2015	3:45:00 PM	0.04
12/13/2015	4:00:00 PM	0.04
12/13/2015	4:15:00 PM	0.04
12/13/2015	4:30:00 PM	0.04
12/13/2015	4:45:00 PM	0.04
12/13/2015	5:00:00 PM	0.04
12/13/2015	5:15:00 PM	0.05
12/13/2015	5:30:00 PM	0.07
12/13/2015	5:45:00 PM	0.08
12/13/2015	6:00:00 PM	0.08
12/13/2015	6:15:00 PM	0.08
12/13/2015	6:30:00 PM	0.08
12/13/2015	6:45:00 PM	0.07
12/13/2015	7:00:00 PM	0.07
12/13/2015	7:15:00 PM	0.07
12/13/2015	7:30:00 PM	0.06
12/13/2015	7:45:00 PM	0.06
12/13/2015	8:00:00 PM	0.06
12/13/2015	8:15:00 PM	0.06
12/13/2015	8:30:00 PM	0.06
12/13/2015	8:45:00 PM	0.06
12/13/2015	9:00:00 PM	0.05
12/13/2015	9:15:00 PM	0.05
12/13/2015	9:30:00 PM	0.04
12/13/2015	9:45:00 PM	0.04
12/13/2015	10:00:00 PM	0.04
12/13/2015	10:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
12/13/2015	10:30:00 PM	0.04
12/13/2015	10:45:00 PM	0.04
12/13/2015	11:00:00 PM	0.04
12/13/2015	11:15:00 PM	0.04
12/13/2015	11:30:00 PM	0.04
12/13/2015	11:45:00 PM	0.04
12/14/2015	12:00:00 AM	0.04
12/14/2015	12:15:00 AM	0.04
12/14/2015	12:30:00 AM	0.04
12/14/2015	12:45:00 AM	0.04
12/14/2015	1:00:00 AM	0.04
12/14/2015	1:15:00 AM	0.04
12/14/2015	1:30:00 AM	0.04
12/14/2015	1:45:00 AM	0.03
12/14/2015	2:00:00 AM	0.03
12/14/2015	2:15:00 AM	0.03
12/14/2015	2:30:00 AM	0.03
12/14/2015	2:45:00 AM	0.03
12/14/2015	3:00:00 AM	0.03
12/14/2015	3:15:00 AM	0.03
12/14/2015	3:30:00 AM	0.03
12/14/2015	3:45:00 AM	0.03
12/14/2015	4:00:00 AM	0.03
12/14/2015	4:15:00 AM	0.03
12/14/2015	4:30:00 AM	0.03
12/14/2015	4:45:00 AM	0.03
12/14/2015	5:00:00 AM	0.03
12/14/2015	5:15:00 AM	0.03
12/14/2015	5:30:00 AM	0.03
12/14/2015	5:45:00 AM	0.03
12/14/2015	6:00:00 AM	0.03
12/14/2015	6:15:00 AM	0.03
12/14/2015	6:30:00 AM	0.03
12/14/2015	6:45:00 AM	0.03
12/14/2015	7:00:00 AM	0.03
12/14/2015	7:15:00 AM	0.03
12/14/2015	7:30:00 AM	0.02
12/14/2015	7:45:00 AM	0.02
12/14/2015	8:00:00 AM	0.02
12/14/2015	8:15:00 AM	0.02
12/14/2015	8:30:00 AM	0.02
12/14/2015	8:45:00 AM	0.02
12/14/2015	9:00:00 AM	0.02
12/14/2015	9:15:00 AM	0.02
12/14/2015	9:30:00 AM	0.02
12/14/2015	9:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
12/14/2015	10:00:00 AM	0.02
12/14/2015	10:15:00 AM	0.02
12/14/2015	10:30:00 AM	0.02
12/14/2015	10:45:00 AM	0.02
12/14/2015	11:00:00 AM	0.02
12/14/2015	11:15:00 AM	0.03
12/14/2015	11:30:00 AM	0.03
12/14/2015	11:45:00 AM	0.03
12/14/2015	12:00:00 PM	0.03
12/14/2015	12:15:00 PM	0.03
12/14/2015	12:30:00 PM	0.03
12/14/2015	12:45:00 PM	0.03
12/14/2015	1:00:00 PM	0.03
12/14/2015	1:15:00 PM	0.03
12/14/2015	1:30:00 PM	0.03
12/14/2015	1:45:00 PM	0.03
12/14/2015	2:00:00 PM	0.02
12/14/2015	2:15:00 PM	0.02
12/14/2015	2:30:00 PM	0.02
12/14/2015	2:45:00 PM	0.02
12/14/2015	3:00:00 PM	0.02
12/14/2015	3:15:00 PM	0.02
12/14/2015	3:30:00 PM	0.02
12/14/2015	3:45:00 PM	0.02
12/14/2015	4:00:00 PM	0.02
12/14/2015	4:15:00 PM	0.02
12/14/2015	4:30:00 PM	0.02
12/14/2015	4:45:00 PM	0.02
12/14/2015	5:00:00 PM	0.02
12/14/2015	5:15:00 PM	0.02
12/14/2015	5:30:00 PM	0.02
12/14/2015	5:45:00 PM	0.02
12/14/2015	6:00:00 PM	0.02
12/14/2015	6:15:00 PM	0.02
12/14/2015	6:30:00 PM	0.02
12/14/2015	6:45:00 PM	0.02
12/14/2015	7:00:00 PM	0.02
12/14/2015	7:15:00 PM	0.02
12/14/2015	7:30:00 PM	0.02
12/14/2015	7:45:00 PM	0.02
12/14/2015	8:00:00 PM	0.02
12/14/2015	8:15:00 PM	0.02
12/14/2015	8:30:00 PM	0.02
12/14/2015	8:45:00 PM	0.02
12/14/2015	9:00:00 PM	0.02
12/14/2015	9:15:00 PM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
12/14/2015	9:30:00 PM	0.02
12/14/2015	9:45:00 PM	0.02
12/14/2015	10:00:00 PM	0.02
12/14/2015	10:15:00 PM	0.02
12/14/2015	10:30:00 PM	0.02
12/14/2015	10:45:00 PM	0.02
12/14/2015	11:00:00 PM	0.02
12/14/2015	11:15:00 PM	0.02
12/14/2015	11:30:00 PM	0.02
12/14/2015	11:45:00 PM	0.02
12/15/2015	12:00:00 AM	0.02
12/15/2015	12:15:00 AM	0.02
12/15/2015	12:30:00 AM	0.02
12/15/2015	12:45:00 AM	0.02
12/15/2015	1:00:00 AM	0.02
12/15/2015	1:15:00 AM	0.02
12/15/2015	1:30:00 AM	0.02
12/15/2015	1:45:00 AM	0.02
12/15/2015	2:00:00 AM	0.02
12/15/2015	2:15:00 AM	0.02
12/15/2015	2:30:00 AM	0.02
12/15/2015	2:45:00 AM	0.02
12/15/2015	3:00:00 AM	0.02
12/15/2015	3:15:00 AM	0.02
12/15/2015	3:30:00 AM	0.02
12/15/2015	3:45:00 AM	0.02
12/15/2015	4:00:00 AM	0.02
12/15/2015	4:15:00 AM	0.02
12/15/2015	4:30:00 AM	0.02
12/15/2015	4:45:00 AM	0.02
12/15/2015	5:00:00 AM	0.02
12/15/2015	5:15:00 AM	0.02
12/15/2015	5:30:00 AM	0.02
12/15/2015	5:45:00 AM	0.02
12/15/2015	6:00:00 AM	0.02
12/15/2015	6:15:00 AM	0.02
12/15/2015	6:30:00 AM	0.02
12/15/2015	6:45:00 AM	0.02
12/15/2015	7:00:00 AM	0.02
12/15/2015	7:15:00 AM	0.02
12/15/2015	7:30:00 AM	0.02
12/15/2015	7:45:00 AM	0.02
12/15/2015	8:00:00 AM	0.02
12/15/2015	8:15:00 AM	0.02
12/15/2015	8:30:00 AM	0.02
12/15/2015	8:45:00 AM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
12/15/2015	9:00:00 AM	0.02
12/15/2015	9:15:00 AM	0.02
12/15/2015	9:30:00 AM	0.02
12/15/2015	9:45:00 AM	0.02
12/15/2015	10:00:00 AM	0.02
12/15/2015	10:15:00 AM	0.02
12/15/2015	10:30:00 AM	0.02
12/15/2015	10:45:00 AM	0.02
12/15/2015	11:00:00 AM	0.02
12/15/2015	11:15:00 AM	0.02
12/15/2015	11:30:00 AM	0.02
12/15/2015	11:45:00 AM	0.02
12/15/2015	12:00:00 PM	0.02
12/15/2015	12:15:00 PM	0.03
12/15/2015	12:30:00 PM	0.03
12/15/2015	12:45:00 PM	0.03
12/15/2015	1:00:00 PM	0.03
12/15/2015	1:15:00 PM	0.04
12/15/2015	1:30:00 PM	0.04
12/15/2015	1:45:00 PM	0.04
12/15/2015	2:00:00 PM	0.04
12/15/2015	2:15:00 PM	0.05
12/15/2015	2:30:00 PM	0.05
12/15/2015	2:45:00 PM	0.05
12/15/2015	3:00:00 PM	0.04
12/15/2015	3:15:00 PM	0.04
12/15/2015	3:30:00 PM	0.04
12/15/2015	3:45:00 PM	0.04
12/15/2015	4:00:00 PM	0.04
12/15/2015	4:15:00 PM	0.04
12/15/2015	4:30:00 PM	0.04
12/15/2015	4:45:00 PM	0.03
12/15/2015	5:00:00 PM	0.03
12/15/2015	5:15:00 PM	0.03
12/15/2015	5:30:00 PM	0.03
12/15/2015	5:45:00 PM	0.03
12/15/2015	6:00:00 PM	0.03
12/15/2015	6:15:00 PM	0.03
12/15/2015	6:30:00 PM	0.03
12/15/2015	6:45:00 PM	0.03
12/15/2015	7:00:00 PM	0.03
12/15/2015	7:15:00 PM	0.02
12/15/2015	7:30:00 PM	0.02
12/15/2015	7:45:00 PM	0.02
12/15/2015	8:00:00 PM	0.02
12/15/2015	8:15:00 PM	0.02

Georges Ditch Return Gage

DATE	TIME	GAGE
12/15/2015	8:30:00 PM	0.02
12/15/2015	8:45:00 PM	0.02
12/15/2015	9:00:00 PM	0.03
12/15/2015	9:15:00 PM	0.03
12/15/2015	9:30:00 PM	0.04
12/15/2015	9:45:00 PM	0.04
12/15/2015	10:00:00 PM	0.04
12/15/2015	10:15:00 PM	0.04
12/15/2015	10:30:00 PM	0.04
12/15/2015	10:45:00 PM	0.04
12/15/2015	11:00:00 PM	0.04
12/15/2015	11:15:00 PM	0.04
12/15/2015	11:30:00 PM	0.04
12/15/2015	11:45:00 PM	0.04
12/16/2015	12:00:00 AM	0.04
12/16/2015	12:15:00 AM	0.04
12/16/2015	12:30:00 AM	0.04
12/16/2015	12:45:00 AM	0.04
12/16/2015	1:00:00 AM	0.04
12/16/2015	1:15:00 AM	0.04
12/16/2015	1:30:00 AM	0.04
12/16/2015	1:45:00 AM	0.04
12/16/2015	2:00:00 AM	0.04
12/16/2015	2:15:00 AM	0.04
12/16/2015	2:30:00 AM	0.04
12/16/2015	2:45:00 AM	0.04
12/16/2015	3:00:00 AM	0.04
12/16/2015	3:15:00 AM	0.04
12/16/2015	3:30:00 AM	0.04
12/16/2015	3:45:00 AM	0.04
12/16/2015	4:00:00 AM	0.04
12/16/2015	4:15:00 AM	0.04
12/16/2015	4:30:00 AM	0.03
12/16/2015	4:45:00 AM	0.03
12/16/2015	5:00:00 AM	0.03
12/16/2015	5:15:00 AM	0.03
12/16/2015	5:30:00 AM	0.03
12/16/2015	5:45:00 AM	0.03
12/16/2015	6:00:00 AM	0.03
12/16/2015	6:15:00 AM	0.03
12/16/2015	6:30:00 AM	0.03
12/16/2015	6:45:00 AM	0.03
12/16/2015	7:00:00 AM	0.03
12/16/2015	7:15:00 AM	0.03
12/16/2015	7:30:00 AM	0.03
12/16/2015	7:45:00 AM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
12/16/2015	8:00:00 AM	0.03
12/16/2015	8:15:00 AM	0.03
12/16/2015	8:30:00 AM	0.03
12/16/2015	8:45:00 AM	0.03
12/16/2015	9:00:00 AM	0.03
12/16/2015	9:15:00 AM	0.03
12/16/2015	9:30:00 AM	0.03
12/16/2015	9:45:00 AM	0.03
12/16/2015	10:00:00 AM	0.03
12/16/2015	10:15:00 AM	0.03
12/16/2015	10:30:00 AM	0.03
12/16/2015	10:45:00 AM	0.03
12/16/2015	11:00:00 AM	0.03
12/16/2015	11:15:00 AM	0.03
12/16/2015	11:30:00 AM	0.03
12/16/2015	11:45:00 AM	0.04
12/16/2015	12:00:00 PM	0.04
12/16/2015	12:15:00 PM	0.04
12/16/2015	12:30:00 PM	0.04
12/16/2015	12:45:00 PM	0.04
12/16/2015	1:00:00 PM	0.04
12/16/2015	1:15:00 PM	0.04
12/16/2015	1:30:00 PM	0.04
12/17/2015	8:17:00 AM	0.04
12/18/2015	9:35:00 AM	0.04
12/19/2015	10:07:00 AM	0.02
12/20/2015	2:54:00 PM	0.09
12/21/2015	9:33:00 AM	0.14
12/22/2015	6:56:00 AM	0.11
12/23/2015	2:27:00 PM	0.06
12/24/2015	12:15:00 PM	0.1
12/25/2015	7:34:00 AM	0.11
12/26/2015	8:30:00 AM	0.12
12/28/2015	4:20:00 PM	0.16
12/29/2015	8:00:00 AM	0.06
12/29/2015	8:45:00 AM	0.06
12/29/2015	9:00:00 AM	0.06
12/29/2015	9:15:00 AM	0.06
12/29/2015	9:30:00 AM	0.06
12/29/2015	9:45:00 AM	0.06
12/29/2015	10:00:00 AM	0.07
12/29/2015	10:15:00 AM	0.07
12/29/2015	10:30:00 AM	0.07
12/29/2015	10:45:00 AM	0.07
12/29/2015	11:00:00 AM	0.07
12/29/2015	11:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
12/29/2015	11:30:00 AM	0.08
12/29/2015	11:45:00 AM	0.08
12/29/2015	12:00:00 PM	0.09
12/29/2015	12:15:00 PM	0.09
12/29/2015	12:30:00 PM	0.09
12/29/2015	12:45:00 PM	0.09
12/29/2015	1:00:00 PM	0.09
12/29/2015	1:15:00 PM	0.09
12/29/2015	1:30:00 PM	0.08
12/29/2015	1:45:00 PM	0.08
12/29/2015	2:00:00 PM	0.08
12/29/2015	2:15:00 PM	0.07
12/29/2015	2:30:00 PM	0.07
12/29/2015	2:45:00 PM	0.07
12/29/2015	3:00:00 PM	0.07
12/29/2015	3:15:00 PM	0.07
12/29/2015	3:30:00 PM	0.07
12/29/2015	3:45:00 PM	0.07
12/29/2015	4:00:00 PM	0.07
12/29/2015	4:15:00 PM	0.07
12/29/2015	4:30:00 PM	0.07
12/29/2015	4:45:00 PM	0.07
12/29/2015	5:00:00 PM	0.07
12/29/2015	5:15:00 PM	0.07
12/29/2015	5:30:00 PM	0.07
12/29/2015	5:45:00 PM	0.07
12/29/2015	6:00:00 PM	0.07
12/29/2015	6:15:00 PM	0.07
12/29/2015	6:30:00 PM	0.07
12/29/2015	6:45:00 PM	0.06
12/29/2015	7:00:00 PM	0.06
12/29/2015	7:15:00 PM	0.06
12/29/2015	7:30:00 PM	0.06
12/29/2015	7:45:00 PM	0.06
12/29/2015	8:00:00 PM	0.06
12/29/2015	8:15:00 PM	0.06
12/29/2015	8:30:00 PM	0.06
12/29/2015	8:45:00 PM	0.06
12/29/2015	9:00:00 PM	0.06
12/29/2015	9:15:00 PM	0.06
12/29/2015	9:30:00 PM	0.06
12/29/2015	9:45:00 PM	0.06
12/29/2015	10:00:00 PM	0.06
12/29/2015	10:15:00 PM	0.06
12/29/2015	10:30:00 PM	0.06
12/29/2015	10:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
12/29/2015	11:00:00 PM	0.06
12/29/2015	11:15:00 PM	0.06
12/29/2015	11:30:00 PM	0.06
12/29/2015	11:45:00 PM	0.06
12/30/2015	12:00:00 AM	0.06
12/30/2015	12:15:00 AM	0.06
12/30/2015	12:30:00 AM	0.06
12/30/2015	12:45:00 AM	0.05
12/30/2015	1:00:00 AM	0.05
12/30/2015	1:15:00 AM	0.05
12/30/2015	1:30:00 AM	0.04
12/30/2015	1:45:00 AM	0.03
12/30/2015	2:00:00 AM	0.03
12/30/2015	2:15:00 AM	0.02
12/30/2015	2:30:00 AM	0.02
12/30/2015	2:45:00 AM	0.02
12/30/2015	3:00:00 AM	0.02
12/30/2015	3:15:00 AM	0.02
12/30/2015	3:30:00 AM	0.03
12/30/2015	3:45:00 AM	0.03
12/30/2015	4:00:00 AM	0.03
12/30/2015	4:15:00 AM	0.03
12/30/2015	4:30:00 AM	0.03
12/30/2015	4:45:00 AM	0.03
12/30/2015	5:00:00 AM	0.03
12/30/2015	5:15:00 AM	0.03
12/30/2015	5:30:00 AM	0.03
12/30/2015	5:45:00 AM	0.03
12/30/2015	6:00:00 AM	0.03
12/30/2015	6:15:00 AM	0.03
12/30/2015	6:30:00 AM	0.03
12/30/2015	6:45:00 AM	0.03
12/30/2015	7:00:00 AM	0.03
12/30/2015	7:15:00 AM	0.03
12/30/2015	7:30:00 AM	0.04
12/30/2015	7:45:00 AM	0.04
12/30/2015	8:00:00 AM	0.04
12/30/2015	8:15:00 AM	0.05
12/30/2015	8:30:00 AM	0.05
12/30/2015	8:45:00 AM	0.05
12/30/2015	9:00:00 AM	0.05
12/30/2015	9:15:00 AM	0.05
12/30/2015	9:30:00 AM	0.05
12/30/2015	9:45:00 AM	0.05
12/30/2015	10:00:00 AM	0.05
12/30/2015	10:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/30/2015	10:30:00 AM	0.05
12/30/2015	10:45:00 AM	0.06
12/30/2015	11:00:00 AM	0.06
12/30/2015	11:15:00 AM	0.07
12/30/2015	11:30:00 AM	0.07
12/30/2015	11:45:00 AM	0.09
12/30/2015	12:00:00 PM	0.1
12/30/2015	12:15:00 PM	0.11
12/30/2015	12:30:00 PM	0.11
12/30/2015	12:45:00 PM	0.12
12/30/2015	1:00:00 PM	0.11
12/30/2015	1:15:00 PM	0.11
12/30/2015	1:30:00 PM	0.11
12/30/2015	1:45:00 PM	0.1
12/30/2015	2:00:00 PM	0.09
12/30/2015	2:15:00 PM	0.09
12/30/2015	2:30:00 PM	0.09
12/30/2015	2:45:00 PM	0.08
12/30/2015	3:00:00 PM	0.08
12/30/2015	3:15:00 PM	0.08
12/30/2015	3:30:00 PM	0.07
12/30/2015	3:45:00 PM	0.07
12/30/2015	4:00:00 PM	0.07
12/30/2015	4:15:00 PM	0.07
12/30/2015	4:30:00 PM	0.07
12/30/2015	4:45:00 PM	0.07
12/30/2015	5:00:00 PM	0.07
12/30/2015	5:15:00 PM	0.07
12/30/2015	5:30:00 PM	0.07
12/30/2015	5:45:00 PM	0.06
12/30/2015	6:00:00 PM	0.06
12/30/2015	6:15:00 PM	0.06
12/30/2015	6:30:00 PM	0.06
12/30/2015	6:45:00 PM	0.06
12/30/2015	7:00:00 PM	0.06
12/30/2015	7:15:00 PM	0.06
12/30/2015	7:30:00 PM	0.06
12/30/2015	7:45:00 PM	0.06
12/30/2015	8:00:00 PM	0.06
12/30/2015	8:15:00 PM	0.06
12/30/2015	8:30:00 PM	0.06
12/30/2015	8:45:00 PM	0.06
12/30/2015	9:00:00 PM	0.06
12/30/2015	9:15:00 PM	0.05
12/30/2015	9:30:00 PM	0.05
12/30/2015	9:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/30/2015	10:00:00 PM	0.05
12/30/2015	10:15:00 PM	0.05
12/30/2015	10:30:00 PM	0.05
12/30/2015	10:45:00 PM	0.05
12/30/2015	11:00:00 PM	0.05
12/30/2015	11:15:00 PM	0.05
12/30/2015	11:30:00 PM	0.05
12/30/2015	11:45:00 PM	0.05
12/31/2015	12:00:00 AM	0.05
12/31/2015	12:15:00 AM	0.05
12/31/2015	12:30:00 AM	0.05
12/31/2015	12:45:00 AM	0.05
12/31/2015	1:00:00 AM	0.04
12/31/2015	1:15:00 AM	0.03
12/31/2015	1:30:00 AM	0.02
12/31/2015	1:45:00 AM	0.02
12/31/2015	2:00:00 AM	0.01
12/31/2015	2:15:00 AM	0.01
12/31/2015	2:30:00 AM	0.01
12/31/2015	2:45:00 AM	0.02
12/31/2015	3:00:00 AM	0.03
12/31/2015	3:15:00 AM	0.03
12/31/2015	3:30:00 AM	0.03
12/31/2015	3:45:00 AM	0.03
12/31/2015	4:00:00 AM	0.03
12/31/2015	4:15:00 AM	0.03
12/31/2015	4:30:00 AM	0.03
12/31/2015	4:45:00 AM	0.03
12/31/2015	5:00:00 AM	0.03
12/31/2015	5:15:00 AM	0.03
12/31/2015	5:30:00 AM	0.03
12/31/2015	5:45:00 AM	0.03
12/31/2015	6:00:00 AM	0.03
12/31/2015	6:15:00 AM	0.03
12/31/2015	6:30:00 AM	0.03
12/31/2015	6:45:00 AM	0.03
12/31/2015	7:00:00 AM	0.03
12/31/2015	7:15:00 AM	0.03
12/31/2015	7:30:00 AM	0.03
12/31/2015	7:45:00 AM	0.03
12/31/2015	8:00:00 AM	0.03
12/31/2015	8:15:00 AM	0.03
12/31/2015	8:30:00 AM	0.04
12/31/2015	8:45:00 AM	0.04
12/31/2015	9:00:00 AM	0.04
12/31/2015	9:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/31/2015	9:30:00 AM	0.05
12/31/2015	9:45:00 AM	0.05
12/31/2015	10:00:00 AM	0.05
12/31/2015	10:15:00 AM	0.05
12/31/2015	10:30:00 AM	0.05
12/31/2015	10:45:00 AM	0.05
12/31/2015	11:00:00 AM	0.05
12/31/2015	11:15:00 AM	0.06
12/31/2015	11:30:00 AM	0.07
12/31/2015	11:45:00 AM	0.08
12/31/2015	12:00:00 PM	0.09
12/31/2015	12:15:00 PM	0.09
12/31/2015	12:30:00 PM	0.08
12/31/2015	12:45:00 PM	0.08
12/31/2015	1:00:00 PM	0.08
12/31/2015	1:15:00 PM	0.07
12/31/2015	1:30:00 PM	0.07
12/31/2015	1:45:00 PM	0.07
12/31/2015	2:00:00 PM	0.07
12/31/2015	2:15:00 PM	0.07
12/31/2015	2:30:00 PM	0.07
12/31/2015	2:45:00 PM	0.06
12/31/2015	3:00:00 PM	0.06
12/31/2015	3:15:00 PM	0.06
12/31/2015	3:30:00 PM	0.06
12/31/2015	3:45:00 PM	0.06
12/31/2015	4:00:00 PM	0.06
12/31/2015	4:15:00 PM	0.06
12/31/2015	4:30:00 PM	0.06
12/31/2015	4:45:00 PM	0.06
12/31/2015	5:00:00 PM	0.05
12/31/2015	5:15:00 PM	0.05
12/31/2015	5:30:00 PM	0.05
12/31/2015	5:45:00 PM	0.05
12/31/2015	6:00:00 PM	0.05
12/31/2015	6:15:00 PM	0.05
12/31/2015	6:30:00 PM	0.05
12/31/2015	6:45:00 PM	0.05
12/31/2015	7:00:00 PM	0.05
12/31/2015	7:15:00 PM	0.05
12/31/2015	7:30:00 PM	0.05
12/31/2015	7:45:00 PM	0.05
12/31/2015	8:00:00 PM	0.05
12/31/2015	8:15:00 PM	0.05
12/31/2015	8:30:00 PM	0.05
12/31/2015	8:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
12/31/2015	9:00:00 PM	0.05
12/31/2015	9:15:00 PM	0.05
12/31/2015	9:30:00 PM	0.05
12/31/2015	9:45:00 PM	0.05
12/31/2015	10:00:00 PM	0.05
12/31/2015	10:15:00 PM	0.05
12/31/2015	10:30:00 PM	0.05
12/31/2015	10:45:00 PM	0.05
12/31/2015	11:00:00 PM	0.05
12/31/2015	11:15:00 PM	0.05
12/31/2015	11:30:00 PM	0.05
12/31/2015	11:45:00 PM	0.05

Station Number: 0356 Meas. No: 004

Station Name: LOR @ REINHACKLE Date: 12/03/2015

Party: MKH / BRP	Width: 19.9 ft	Processed by: MKH
Boat/Motor:	Area: 87.0 ft²	Mean Velocity: 0.709 ft/s
Gage Height: 4.76 ft	G.H.Change: 0.000 ft	Discharge: 61.6 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 2.81 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 7.27 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 4.37 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 70.74	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 52.5 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151203LOR @ REINHACKLE0

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	*R*	*2*	*2*	*34*	*6.75*	*41.4*	*6.36*	*1.98*	*1.34*	*57.8*	*21*	*92*	*14:01*	*14:02*	*0.54*	*0.63*	*6*	*0*
001	L	*2*	*2*	*34*	*7.52*	*44.5*	*8.30*	*1.59*	*2.08*	*64.0*	*20*	*90*	*14:03*	*14:03*	*0.52*	*0.71*	*6*	*3*
002	R	*2*	*2*	*36*	*6.99*	*42.8*	*5.86*	*2.26*	*2.08*	*60.0*	*20*	*88*	*14:04*	*14:04*	*0.49*	*0.69*	*6*	*3*
003	L	*2*	*2*	*35*	*7.42*	*45.0*	*6.53*	*1.91*	*2.05*	*62.9*	*19*	*83*	*14:05*	*14:05*	*0.55*	*0.75*	*6*	*2*
004	R	*2*	*2*	*34*	*7.42*	*44.1*	*7.45*	*2.58*	*1.59*	*63.1*	*19*	*82*	*14:06*	*14:07*	*0.53*	*0.77*	*6*	*2*
Mean		2	2	34	7.22	43.6	6.90	2.06	1.83	61.6	20	87	**Total**	00:05	0.52	0.71	6	2
SDev		0	0	1	0.334	1.46	0.971	0.374	0.344	2.59	0.8	4.3			0.02	0.06		
SD/M		0.00	0.00	0.03	0.05	0.03	0.14	0.18	0.19	0.04	0.04	0.05			0.05	0.08		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Station Number: 0356 Meas. No: 006

Station Name: LOR @ REINHACKLE Date: 12/30/2015

Party: MKH / BRP	Width: 21.2 ft	Processed by: MKH
Boat/Motor:	Area: 83.6 ft²	Mean Velocity: 0.578 ft/s
Gage Height: 4.30 ft	G.H.Change: 0.000 ft	Discharge: 48.2 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:

BT 3-Beam Solution: NO	Max. Vel.: 3.97 ft/s	ADCP:
WT 3-Beam Solution: NO	Max. Depth: 6.52 ft	Type/Freq.: StreamPro / 2000 kHz
BT Error Vel.: 32.81 ft/s	Mean Depth: 3.95 ft	Serial #: Firmware: 31.12
WT Error Vel.: 32.81 ft/s	% Meas.: 70.79	Bin Size: 10 cm Blank: 3 cm
BT Up Vel.: 32.81 ft/s	Water Temp.: None	BT Mode: 10 BT Pings: 2
WT Up Vel.: 32.81 ft/s	ADCP Temp.: 52.3 °F	WT Mode: 12 WT Pings: 6
Use Weighted Mean Depth: NO		WV : 0 WO : 1, 4

Performed Diag. Test: NO Project Name: 151230 rein000r.mmt

Performed Moving Bed Test: NO Software: 2.11

Performed Compass Calibration: NO Evaluation: NO

Meas. Location:

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	*L*	*2*	*2*	*33*	*6.82*	*37.7*	*4.84*	*1.38*	*1.02*	*51.8*	*22*	*86*	*13:45*	*13:46*	*0.52*	*0.60*	*6*	*2*
001	R	*2*	*2*	*33*	*6.04*	*33.1*	*4.73*	*1.02*	*0.989*	*45.9*	*21*	*86*	*13:46*	*13:47*	*0.52*	*0.53*	*6*	*1*
002	L	*2*	*2*	*35*	*6.04*	*33.4*	*3.96*	*1.59*	*1.31*	*46.3*	*21*	*85*	*13:47*	*13:48*	*0.49*	*0.54*	*6*	*2*
003	*R*	*2*	*2*	*35*	*6.92*	*36.1*	*6.85*	*1.66*	*0.812*	*52.3*	*20*	*78*	*13:48*	*13:49*	*0.50*	*0.67*	*6*	*3*
004	L	*2*	*2*	*34*	*6.43*	*34.8*	*4.77*	*1.24*	*0.883*	*48.2*	*21*	*81*	*13:49*	*13:50*	*0.53*	*0.60*	*9*	*2*
005	R	*2*	*2*	*35*	*6.32*	*32.5*	*6.29*	*0.953*	*0.989*	*47.1*	*21*	*84*	*13:50*	*13:51*	*0.49*	*0.56*	*6*	*1*
006	L	*2*	*2*	*38*	*6.18*	*31.3*	*6.43*	*1.24*	*0.918*	*46.1*	*22*	*86*	*13:51*	*13:52*	*0.49*	*0.53*	*11*	*0*
Mean		2	2	34	6.39	34.1	5.41	1.30	0.989	48.2	21	84	**Total**	00:06	0.51	0.58	7	2
SDev		0	0	2	0.356	2.23	1.10	0.266	0.158	2.74	0.7	3.2			0.02	0.05		
SD/M		0.00	0.00	0.06	0.06	0.07	0.20	0.20	0.16	0.06	0.03	0.04			0.04	0.09		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	0	5	33	0.85	-0.108	4.534	0.01	0.007	0	18.1	15.1	73.5	82	71	0	40	36
2015	12	1	0	15	33	0.85	-0.128	4.534	0.01	0.007	0	18.5	15.5	74	83	72	0	40	36
2015	12	1	0	25	33	0.85	-0.141	4.534	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	1	0	35	33	0.873	-0.128	4.534	0.01	0.007	0	17.6	15.1	73.5	81	71	0	40	36
2015	12	1	0	45	33	0.846	-0.121	4.534	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	0	55	33	0.86	-0.128	4.534	0.01	0.007	0	17.6	14.6	73.5	81	71	0	40	37
2015	12	1	1	5	33	0.866	-0.164	4.534	0.01	0.007	0	18.1	14.2	73.5	81	70	0	39	37
2015	12	1	1	15	33	0.833	-0.131	4.534	0.01	0.007	0	18.1	14.2	73.1	81	70	0	39	37
2015	12	1	1	25	33	0.827	-0.135	4.534	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	1	35	33	0.837	-0.112	4.534	0.01	0.007	0	18.1	14.6	73.5	81	71	0	39	37
2015	12	1	1	45	33	0.804	-0.148	4.534	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	1	55	33	0.85	-0.144	4.534	0.01	0.007	0	17.6	14.2	73.1	80	70	0	39	37
2015	12	1	2	5	33	0.837	-0.115	4.531	0.01	0.007	0	18.1	14.2	74	81	70	0	39	37
2015	12	1	2	15	33	0.84	-0.148	4.531	0.01	0.007	0	17.6	14.2	73.1	81	70	0	40	37
2015	12	1	2	25	33	0.84	-0.102	4.531	0.013	0.01	0	18.1	14.6	73.5	81	70	0	39	36
2015	12	1	2	35	33	0.82	-0.131	4.534	0.01	0.007	0	17.6	14.2	73.5	81	70	0	40	37
2015	12	1	2	45	33	0.84	-0.144	4.531	0.01	0.007	0	17.6	13.8	73.1	81	70	0	40	38
2015	12	1	2	55	33	0.866	-0.138	4.531	0.01	0.007	0	18.1	14.2	73.5	81	70	0	39	37
2015	12	1	3	5	33	0.843	-0.135	4.531	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	3	15	33	0.873	-0.131	4.531	0.01	0.007	0	18.1	14.2	73.5	81	70	0	39	37
2015	12	1	3	25	33	0.856	-0.144	4.531	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	3	35	33	0.85	-0.148	4.531	0.01	0.007	0	17.6	15.1	73.5	81	71	0	40	36
2015	12	1	3	45	33	0.85	-0.128	4.531	0.01	0.007	0	18.1	14.6	72.7	81	71	0	39	37
2015	12	1	3	55	33	0.82	-0.131	4.531	0.01	0.007	0	17.6	14.6	72.7	81	71	0	40	37
2015	12	1	4	5	33	0.823	-0.131	4.531	0.01	0.007	0	17.6	14.6	73.1	81	70	0	40	36
2015	12	1	4	15	33	0.827	-0.154	4.531	0.01	0.007	0	17.6	14.6	73.5	81	71	0	40	37
2015	12	1	4	25	33	0.823	-0.141	4.531	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	4	35	33	0.85	-0.121	4.528	0.01	0.007	0	18.1	14.2	73.5	81	70	0	39	37
2015	12	1	4	45	33	0.846	-0.128	4.528	0.01	0.007	0	18.1	13.8	73.5	81	70	0	39	38
2015	12	1	4	55	33	0.85	-0.118	4.528	0.01	0.007	0	17.6	14.2	72.7	81	70	0	40	37
2015	12	1	5	5	33	0.84	-0.105	4.528	0.01	0.007	0	18.1	14.2	74	81	70	0	39	37
2015	12	1	5	15	33	0.876	-0.118	4.528	0.01	0.007	0	17.2	14.6	74	80	70	0	40	36
2015	12	1	5	25	33	0.86	-0.108	4.528	0.01	0.007	0	17.6	14.6	73.5	81	70	0	40	36
2015	12	1	5	35	33	0.85	-0.118	4.528	0.01	0.007	0	19.8	16.3	71.8	85	75	0	39	37
2015	12	1	5	45	33	0.863	-0.151	4.528	0.01	0.007	0	18.5	15.1	72.2	83	72	0	40	37
2015	12	1	5	55	33	0.899	-0.151	4.528	0.01	0.007	0	18.1	15.1	73.5	82	72	0	40	37
2015	12	1	6	5	33	0.827	-0.141	4.528	0.01	0.007	0	18.5	15.1	73.1	82	72	0	39	37
2015	12	1	6	15	33	0.873	-0.144	4.528	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	1	6	25	33	0.856	-0.125	4.528	0.01	0.007	0	18.1	14.6	73.1	82	71	0	40	37
2015	12	1	6	35	33	0.856	-0.151	4.524	0.01	0.007	0	18.1	15.5	73.1	82	72	0	40	36
2015	12	1	6	45	33	0.84	-0.148	4.528	0.01	0.007	0	18.1	14.6	73.1	82	71	0	40	37
2015	12	1	6	55	33	0.846	-0.141	4.524	0.01	0.007	0	17.6	14.6	73.1	81	71	0	40	37
2015	12	1	7	5	33	0.837	-0.125	4.524	0.01	0.007	0	18.1	14.6	72.7	82	71	0	40	37
2015	12	1	7	15	33	0.863	-0.118	4.524	0.01	0.007	0	18.5	15.1	72.7	82	72	0	39	37
2015	12	1	7	25	33	0.846	-0.135	4.524	0.01	0.007	0	18.5	15.1	72.7	83	72	0	40	37
2015	12	1	7	35	33	0.827	-0.125	4.524	0.01	0.007	0	18.9	15.5	72.7	84	73	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	7	45	33	0.892	-0.151	4.524	0.01	0.007	0	19.8	16.8	73.1	86	75	0	40	36
2015	12	1	7	55	33	0.837	-0.125	4.524	0.01	0.007	0	19.4	16.3	73.1	85	74	0	40	36
2015	12	1	8	5	33	0.846	-0.135	4.524	0.01	0.007	0	18.9	15.5	73.5	84	73	0	40	37
2015	12	1	8	15	33	0.879	-0.151	4.528	0.01	0.007	0	18.9	15.5	72.7	84	74	0	40	38
2015	12	1	8	25	33	0.869	-0.131	4.528	0.01	0.007	0	18.5	15.5	73.1	83	73	0	40	37
2015	12	1	8	35	33	0.85	-0.112	4.524	0.01	0.007	0	19.4	15.5	72.7	84	73	0	39	37
2015	12	1	8	45	33	0.856	-0.141	4.528	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	1	8	55	33	0.843	-0.138	4.528	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	1	9	5	33	0.853	-0.128	4.528	0.01	0.007	0	18.9	15.1	73.5	83	72	0	39	37
2015	12	1	9	15	33	0.83	-0.144	4.528	0.01	0.007	0	18.5	15.5	73.5	82	72	0	39	36
2015	12	1	9	25	33	0.869	-0.115	4.528	0.01	0.007	0	18.9	15.5	73.5	83	72	0	39	36
2015	12	1	9	35	33	0.84	-0.102	4.528	0.01	0.007	0	18.5	15.9	72.2	83	73	0	40	36
2015	12	1	9	45	33	0.85	-0.138	4.528	0.01	0.007	0	18.9	15.5	73.1	83	73	0	39	37
2015	12	1	9	55	33	0.876	-0.157	4.528	0.01	0.007	0	18.5	15.5	74.4	82	72	0	39	36
2015	12	1	10	5	33	0.823	-0.144	4.528	0.01	0.007	0	18.9	15.5	74.4	83	73	0	39	37
2015	12	1	10	15	33	0.827	-0.161	4.528	0.01	0.007	0	18.5	15.1	74	82	72	0	39	37
2015	12	1	10	25	33	0.85	-0.118	4.531	0.01	0.007	0	18.1	15.5	74	82	73	0	40	37
2015	12	1	10	35	33	0.86	-0.135	4.528	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	1	10	45	33	0.869	-0.098	4.531	0.01	0.007	0	18.1	15.5	73.1	82	72	0	40	36
2015	12	1	10	55	33	0.873	-0.118	4.531	0.01	0.007	0	18.1	15.5	74	82	73	0	40	37
2015	12	1	11	5	33	0.886	-0.115	4.531	0.01	0.007	0	24.1	20.6	74	96	85	0	40	37
2015	12	1	11	15	33	0.883	-0.128	4.531	0.01	0.007	0	21.5	18.9	74.4	90	80	0	40	36
2015	12	1	11	25	33	0.807	-0.118	4.531	0.01	0.007	0	19.4	15.5	73.1	85	74	0	40	38
2015	12	1	11	35	33	0.823	-0.095	4.528	0.01	0.007	0	19.4	16.8	73.5	85	75	0	40	36
2015	12	1	11	45	33	0.846	-0.128	4.528	0.01	0.007	0	20.2	16.8	73.1	87	76	0	40	37
2015	12	1	11	55	33	0.886	-0.135	4.528	0.01	0.007	0	19.8	17.2	73.5	86	76	0	40	36
2015	12	1	12	5	33	0.837	-0.115	4.528	0.013	0.01	0	19.4	16.8	73.1	85	75	0	40	36
2015	12	1	12	15	33	0.86	-0.125	4.528	0.01	0.007	0	18.9	15.9	73.1	84	74	0	40	37
2015	12	1	12	25	33	0.817	-0.125	4.528	0.01	0.007	0	18.9	15.5	65.4	83	73	0	39	37
2015	12	1	12	35	33	0.843	-0.141	4.528	0.01	0.007	0	18.1	15.5	72.2	82	72	0	40	36
2015	12	1	12	45	33	0.863	-0.138	4.528	0.01	0.007	0	18.1	15.1	71	82	72	0	40	37
2015	12	1	12	55	33	0.827	-0.161	4.528	0.01	0.007	0	18.5	15.5	69.2	83	73	0	40	37
2015	12	1	13	5	33	0.827	-0.121	4.528	0.01	0.007	0	18.9	15.5	69.2	83	73	0	39	37
2015	12	1	13	15	33	0.84	-0.131	4.528	0.01	0.007	0	18.5	15.5	51.2	83	73	0	40	37
2015	12	1	13	25	33	0.837	-0.144	4.528	0.01	0.007	0	18.5	15.9	61.1	83	73	0	40	36
2015	12	1	13	35	33	0.843	-0.144	4.528	0.01	0.007	0	18.5	15.9	70.1	83	73	0	40	36
2015	12	1	13	45	33	0.85	-0.118	4.528	0.01	0.007	0	18.9	15.5	66.2	83	73	0	39	37
2015	12	1	13	55	33	0.833	-0.118	4.528	0.01	0.007	0	18.1	15.1	67.9	82	72	0	40	37
2015	12	1	14	5	33	0.86	-0.148	4.528	0.01	0.007	0	18.9	15.5	67.1	83	73	0	39	37
2015	12	1	14	15	33	0.883	-0.121	4.524	0.01	0.007	0	20.2	17.2	65.8	87	77	0	40	37
2015	12	1	14	25	33	0.886	-0.125	4.524	0.01	0.007	0	21.5	18.1	60.2	90	79	0	40	37
2015	12	1	14	35	33	0.869	-0.131	4.524	0.01	0.007	0	19.8	16.3	55	85	75	0	39	37
2015	12	1	14	45	33	0.837	-0.118	4.524	0.01	0.007	0	20.2	17.2	68.8	87	77	0	40	37
2015	12	1	14	55	33	0.85	-0.128	4.524	0.01	0.007	0	19.8	17.2	67.5	86	75	0	40	35
2015	12	1	15	5	33	0.82	-0.112	4.524	0.01	0.007	0	19.4	15.9	71	84	74	0	39	37
2015	12	1	15	15	33	0.837	-0.118	4.524	0.01	0.007	0	18.9	15.5	70.1	83	73	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	15	25	33	0.814	-0.102	4.524	0.01	0.007	0	21.1	18.1	64.9	89	78	0	40	36
2015	12	1	15	35	33	0.876	-0.098	4.524	0.01	0.007	0	26.2	22.8	69.7	101	89	0	40	36
2015	12	1	15	45	33	0.84	-0.092	4.524	0.01	0.007	0	25.8	21.5	70.1	99	87	0	39	37
2015	12	1	15	55	33	0.827	-0.118	4.524	0.01	0.007	0	26.7	22.8	71.4	102	90	0	40	37
2015	12	1	16	5	33	0.856	-0.105	4.524	0.01	0.007	0	21.1	17.6	71.4	88	78	0	39	37
2015	12	1	16	15	33	0.863	-0.108	4.521	0.01	0.007	0	22.8	19.4	71.4	93	82	0	40	37
2015	12	1	16	25	33	0.837	-0.115	4.524	0.01	0.007	0	22.8	19.4	70.5	93	82	0	40	37
2015	12	1	16	35	33	0.82	-0.121	4.521	0.01	0.007	0	26.2	22.8	65.4	101	90	0	40	37
2015	12	1	16	45	33	0.876	-0.128	4.524	0.01	0.007	0	21.5	18.1	71	90	79	0	40	37
2015	12	1	16	55	33	0.833	-0.154	4.524	0.01	0.007	0	18.9	15.9	71	84	74	0	40	37
2015	12	1	17	5	33	0.837	-0.125	4.524	0.01	0.007	0	18.5	15.5	71.4	83	72	0	40	36
2015	12	1	17	15	33	0.843	-0.125	4.521	0.01	0.007	0	18.5	15.1	71	83	72	0	40	37
2015	12	1	17	25	33	0.837	-0.125	4.524	0.01	0.007	0	18.5	15.1	71.4	83	72	0	40	37
2015	12	1	17	35	33	0.85	-0.128	4.524	0.01	0.007	0	18.1	14.6	70.5	82	71	0	40	37
2015	12	1	17	45	33	0.873	-0.144	4.521	0.01	0.007	0	18.5	15.5	71.4	82	72	0	39	36
2015	12	1	17	55	33	0.827	-0.125	4.524	0.01	0.007	0	18.5	15.1	71.4	82	71	0	39	36
2015	12	1	18	5	33	0.85	-0.125	4.521	0.01	0.007	0	17.6	14.6	71.4	81	71	0	40	37
2015	12	1	18	15	33	0.863	-0.135	4.521	0.01	0.007	0	18.1	14.6	71	81	71	0	39	37
2015	12	1	18	25	33	0.823	-0.125	4.521	0.01	0.007	0	18.1	15.1	71.4	82	71	0	40	36
2015	12	1	18	35	33	0.853	-0.141	4.524	0.01	0.007	0	18.1	15.1	71	81	71	0	39	36
2015	12	1	18	45	33	0.817	-0.125	4.524	0.01	0.007	0	17.6	14.2	71	81	70	0	40	37
2015	12	1	18	55	33	0.853	-0.115	4.521	0.01	0.007	0	18.1	14.6	71	82	71	0	40	37
2015	12	1	19	5	33	0.863	-0.118	4.521	0.01	0.007	0	18.1	14.2	71	81	70	0	39	37
2015	12	1	19	15	33	0.837	-0.115	4.521	0.01	0.007	0	17.6	14.2	70.5	81	70	0	40	37
2015	12	1	19	25	33	0.86	-0.135	4.524	0.01	0.007	0	17.2	14.2	70.5	80	70	0	40	37
2015	12	1	19	35	33	0.853	-0.128	4.521	0.01	0.007	0	17.6	13.8	70.5	80	69	0	39	37
2015	12	1	19	45	33	0.86	-0.115	4.521	0.013	0.01	0	17.6	15.1	71	81	71	0	40	36
2015	12	1	19	55	33	0.86	-0.144	4.521	0.01	0.007	0	17.2	14.2	71	80	69	0	40	36
2015	12	1	20	5	33	0.833	-0.125	4.521	0.01	0.007	0	18.1	14.2	71	81	70	0	39	37
2015	12	1	20	15	33	0.843	-0.151	4.521	0.01	0.007	0	18.1	14.6	70.1	81	70	0	39	36
2015	12	1	20	25	33	0.869	-0.135	4.521	0.01	0.007	0	17.6	15.1	70.5	81	71	0	40	36
2015	12	1	20	35	33	0.869	-0.154	4.521	0.01	0.007	0	17.2	14.2	71	80	70	0	40	37
2015	12	1	20	45	33	0.846	-0.131	4.521	0.01	0.007	0	17.6	14.2	70.5	81	70	0	40	37
2015	12	1	20	55	33	0.876	-0.128	4.521	0.01	0.007	0	17.6	14.6	70.5	81	71	0	40	37
2015	12	1	21	5	33	0.85	-0.135	4.521	0.01	0.007	0	17.6	14.6	70.1	81	70	0	40	36
2015	12	1	21	15	33	0.823	-0.128	4.521	0.01	0.007	0	18.9	15.5	70.1	83	72	0	39	36
2015	12	1	21	25	33	0.823	-0.115	4.521	0.01	0.007	0	17.6	14.2	70.5	80	70	0	39	37
2015	12	1	21	35	33	0.807	-0.115	4.521	0.01	0.007	0	17.6	14.2	70.5	81	70	0	40	37
2015	12	1	21	45	33	0.873	-0.121	4.521	0.01	0.007	0	17.6	14.6	71	80	70	0	39	36
2015	12	1	21	55	33	0.863	-0.128	4.521	0.01	0.007	0	17.2	14.2	70.5	80	69	0	40	36
2015	12	1	22	5	33	0.846	-0.148	4.521	0.01	0.007	0	17.2	14.2	71	80	70	0	40	37
2015	12	1	22	15	33	0.853	-0.128	4.521	0.01	0.007	0	18.1	14.2	70.1	81	70	0	39	37
2015	12	1	22	25	33	0.823	-0.118	4.518	0.01	0.007	0	17.2	14.6	70.1	80	70	0	40	36
2015	12	1	22	35	33	0.817	-0.135	4.521	0.01	0.007	0	17.2	15.1	70.1	80	71	0	40	36
2015	12	1	22	45	33	0.856	-0.154	4.521	0.01	0.007	0	17.6	15.1	69.7	81	71	0	40	36
2015	12	1	22	55	33	0.896	-0.148	4.518	0.01	0.007	0	17.6	14.6	70.1	81	70	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	1	23	5	33	0.886	-0.138	4.518	0.01	0.007	0	17.6	14.2	69.7	81	70	0	40	37
2015	12	1	23	15	33	0.856	-0.128	4.521	0.01	0.007	0	18.1	14.6	70.5	81	71	0	39	37
2015	12	1	23	25	33	0.873	-0.131	4.521	0.013	0.01	0	18.1	15.1	69.7	81	71	0	39	36
2015	12	1	23	35	33	0.876	-0.154	4.521	0.01	0.007	0	17.2	14.2	70.1	80	69	0	40	36
2015	12	1	23	45	33	0.856	-0.118	4.521	0.007	0.007	0	17.2	14.2	71	80	70	0	40	37
2015	12	1	23	55	33	0.85	-0.128	4.518	0.01	0.007	0	17.6	14.2	69.2	80	70	0	39	37
2015	12	2	0	5	33	0.899	-0.118	4.518	0.01	0.007	0	17.6	14.6	69.7	80	70	0	39	36
2015	12	2	0	15	33	0.86	-0.121	4.518	0.01	0.007	0	17.2	14.2	70.5	80	70	0	40	37
2015	12	2	0	25	33	0.823	-0.135	4.518	0.01	0.007	0	17.6	14.2	69.2	80	70	0	39	37
2015	12	2	0	35	33	0.863	-0.118	4.518	0.01	0.007	0	17.2	14.2	69.7	80	70	0	40	37
2015	12	2	0	45	33	0.84	-0.112	4.518	0.01	0.007	0	17.6	14.6	70.1	80	70	0	39	36
2015	12	2	0	55	33	0.866	-0.131	4.518	0.01	0.007	0	17.6	13.8	69.2	80	70	0	39	38
2015	12	2	1	5	33	0.86	-0.121	4.518	0.01	0.007	0	17.2	13.8	69.7	79	69	0	39	37
2015	12	2	1	15	33	0.879	-0.125	4.518	0.01	0.007	0	17.2	14.2	69.7	80	69	0	40	36
2015	12	2	1	25	33	0.866	-0.157	4.518	0.01	0.007	0	17.2	13.8	69.2	79	69	0	39	37
2015	12	2	1	35	33	0.889	-0.115	4.518	0.01	0.007	0	17.2	14.2	70.1	80	70	0	40	37
2015	12	2	1	45	33	0.794	-0.102	4.514	0.01	0.007	0	17.2	14.2	70.1	80	70	0	40	37
2015	12	2	1	55	33	0.873	-0.151	4.518	0.01	0.007	0	17.6	14.6	69.2	80	70	0	39	36
2015	12	2	2	5	33	0.823	-0.115	4.518	0.01	0.007	0	17.6	14.6	70.1	80	70	0	39	36
2015	12	2	2	15	33	0.873	-0.161	4.518	0.01	0.007	0	17.2	13.3	69.2	79	69	0	39	38
2015	12	2	2	25	33	0.879	-0.125	4.514	0.01	0.007	0	16.8	14.2	69.7	79	69	0	40	36
2015	12	2	2	35	33	0.856	-0.131	4.514	0.013	0.01	0	17.2	14.6	69.7	80	70	0	40	36
2015	12	2	2	45	33	0.856	-0.138	4.514	0.01	0.007	0	17.2	14.2	69.7	80	69	0	40	36
2015	12	2	2	55	33	0.86	-0.131	4.514	0.01	0.007	0	17.2	13.8	69.2	80	69	0	40	37
2015	12	2	3	5	33	0.817	-0.135	4.514	0.01	0.007	0	17.2	14.2	69.2	80	70	0	40	37
2015	12	2	3	15	33	0.823	-0.148	4.514	0.01	0.007	0	17.6	14.2	69.7	81	70	0	40	37
2015	12	2	3	25	33	0.853	-0.135	4.514	0.01	0.007	0	17.6	13.8	69.7	80	69	0	39	37
2015	12	2	3	35	33	0.856	-0.131	4.514	0.01	0.007	0	17.6	14.2	69.2	80	70	0	39	37
2015	12	2	3	45	33	0.856	-0.164	4.511	0.01	0.007	0	16.8	13.8	69.7	79	69	0	40	37
2015	12	2	3	55	33	0.879	-0.141	4.514	0.013	0.01	0	17.6	14.2	68.8	80	70	0	39	37
2015	12	2	4	5	33	0.863	-0.135	4.514	0.01	0.007	0	17.2	13.8	68.8	80	69	0	40	37
2015	12	2	4	15	33	0.85	-0.157	4.511	0.01	0.007	0	17.6	14.2	69.2	80	70	0	39	37
2015	12	2	4	25	33	0.843	-0.154	4.511	0.01	0.007	0	17.6	14.2	69.2	81	70	0	40	37
2015	12	2	4	35	33	0.86	-0.141	4.511	0.01	0.007	0	17.2	14.2	68.8	80	70	0	40	37
2015	12	2	4	45	33	0.837	-0.108	4.511	0.01	0.007	0	17.6	14.6	68.4	81	71	0	40	37
2015	12	2	4	55	33	0.869	-0.105	4.511	0.01	0.007	0	17.2	14.2	69.7	80	70	0	40	37
2015	12	2	5	5	33	0.853	-0.128	4.511	0.01	0.007	0	17.2	14.2	68.8	80	69	0	40	36
2015	12	2	5	15	33	0.837	-0.118	4.508	0.01	0.007	0	17.6	14.6	69.2	80	70	0	39	36
2015	12	2	5	25	33	0.85	-0.118	4.511	0.01	0.007	0	17.2	14.2	69.2	80	69	0	40	36
2015	12	2	5	35	33	0.866	-0.102	4.511	0.01	0.007	0	17.6	14.6	69.7	81	71	0	40	37
2015	12	2	5	45	33	0.85	-0.105	4.511	0.01	0.007	0	17.2	14.2	69.2	80	70	0	40	37
2015	12	2	5	55	33	0.843	-0.112	4.508	0.01	0.007	0	17.6	15.1	68.8	81	71	0	40	36
2015	12	2	6	5	33	0.84	-0.128	4.508	0.01	0.007	0	17.6	14.6	68.8	81	71	0	40	37
2015	12	2	6	15	33	0.84	-0.144	4.508	0.01	0.007	0	17.6	15.1	69.2	81	71	0	40	36
2015	12	2	6	25	33	0.86	-0.102	4.508	0.01	0.007	0	18.5	14.6	69.2	82	71	0	39	37
2015	12	2	6	35	33	0.846	-0.144	4.505	0.01	0.007	0	19.4	15.5	68.8	85	74	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	6	45	33	0.843	-0.115	4.508	0.01	0.007	0	21.9	18.5	68.8	91	80	0	40	37
2015	12	2	6	55	33	0.843	-0.154	4.505	0.01	0.007	0	20.6	17.2	68.8	88	77	0	40	37
2015	12	2	7	5	33	0.84	-0.105	4.508	0.01	0.007	0	18.9	15.5	69.7	84	73	0	40	37
2015	12	2	7	15	33	0.863	-0.125	4.508	0.01	0.007	0	18.1	15.5	69.7	82	72	0	40	36
2015	12	2	7	25	33	0.83	-0.135	4.505	0.01	0.007	0	18.1	14.6	68.8	82	71	0	40	37
2015	12	2	7	35	33	0.84	-0.141	4.505	0.01	0.007	0	18.1	14.6	69.2	82	71	0	40	37
2015	12	2	7	45	33	0.86	-0.121	4.505	0.01	0.007	0	18.1	14.6	68.8	81	71	0	39	37
2015	12	2	7	55	33	0.801	-0.118	4.505	0.01	0.007	0	18.5	15.1	68.8	83	72	0	40	37
2015	12	2	8	5	33	0.843	-0.141	4.505	0.01	0.007	0	18.5	15.5	69.2	82	72	0	39	36
2015	12	2	8	15	33	0.837	-0.125	4.501	0.01	0.007	0	17.6	14.6	69.2	81	71	0	40	37
2015	12	2	8	25	33	0.843	-0.125	4.501	0.01	0.007	0	18.1	15.1	68.8	82	72	0	40	37
2015	12	2	8	35	33	0.837	-0.141	4.505	0.01	0.007	0	18.1	15.1	68.8	82	72	0	40	37
2015	12	2	8	45	33	0.843	-0.121	4.505	0.01	0.007	0	18.1	15.1	69.7	82	72	0	40	37
2015	12	2	8	55	33	0.853	-0.151	4.505	0.01	0.007	0	18.1	15.1	68.8	82	72	0	40	37
2015	12	2	9	5	33	0.83	-0.151	4.505	0.01	0.007	0	18.5	15.5	68.8	83	73	0	40	37
2015	12	2	9	15	33	0.801	-0.095	4.505	0.01	0.007	0	18.1	15.1	67.9	82	72	0	40	37
2015	12	2	9	25	33	0.807	-0.131	4.505	0.01	0.007	0	18.1	15.1	67.1	82	72	0	40	37
2015	12	2	9	35	33	0.83	-0.131	4.505	0.01	0.007	0	19.4	16.3	62.8	85	74	0	40	36
2015	12	2	9	45	33	0.856	-0.148	4.505	0.01	0.007	0	18.9	15.5	64.1	84	73	0	40	37
2015	12	2	9	55	33	0.856	-0.141	4.505	0.01	0.007	0	18.5	15.5	66.7	82	73	0	39	37
2015	12	2	10	5	33	0.83	-0.154	4.505	0.01	0.007	0	18.1	14.6	63.2	81	71	0	39	37
2015	12	2	10	15	33	0.804	-0.121	4.505	0.01	0.007	0	18.1	15.1	64.5	82	72	0	40	37
2015	12	2	10	25	33	0.856	-0.167	4.505	0.01	0.007	0	18.1	15.1	66.2	82	72	0	40	37
2015	12	2	10	35	33	0.81	-0.161	4.505	0.01	0.007	0	18.1	15.1	59.8	82	71	0	40	36
2015	12	2	10	45	33	0.883	-0.148	4.505	0.01	0.007	0	18.1	15.1	63.6	82	72	0	40	37
2015	12	2	10	55	33	0.853	-0.118	4.505	0.01	0.007	0	18.5	15.5	65.4	83	73	0	40	37
2015	12	2	11	5	33	0.85	-0.148	4.505	0.01	0.007	0	19.4	16.8	64.9	85	75	0	40	36
2015	12	2	11	15	33	0.843	-0.125	4.505	0.01	0.007	0	18.9	16.3	66.7	84	74	0	40	36
2015	12	2	11	25	33	0.833	-0.118	4.505	0.01	0.007	0	18.1	15.1	65.4	82	72	0	40	37
2015	12	2	11	35	33	0.82	-0.138	4.505	0.01	0.007	0	18.1	15.5	69.7	82	73	0	40	37
2015	12	2	11	45	33	0.814	-0.108	4.505	0.01	0.007	0	18.1	15.5	71	82	73	0	40	37
2015	12	2	11	55	33	0.846	-0.105	4.505	0.01	0.007	0	18.5	15.1	71.4	82	72	0	39	37
2015	12	2	12	5	33	0.804	-0.108	4.505	0.01	0.007	0	18.9	15.9	71.4	84	74	0	40	37
2015	12	2	12	15	33	0.84	-0.128	4.505	0.01	0.007	0	18.1	15.1	71.8	82	72	0	40	37
2015	12	2	12	25	33	0.86	-0.144	4.505	0.01	0.007	0	18.5	14.6	71.4	82	71	0	39	37
2015	12	2	12	35	33	0.837	-0.118	4.505	0.01	0.007	0	18.5	15.5	71.8	82	72	0	39	36
2015	12	2	12	45	33	0.85	-0.112	4.505	0.01	0.007	0	17.6	14.6	71.8	81	71	0	40	37
2015	12	2	12	55	33	0.833	-0.115	4.505	0.01	0.007	0	18.1	15.5	71.8	82	72	0	40	36
2015	12	2	13	5	33	0.833	-0.125	4.501	0.01	0.007	0	18.9	15.9	72.2	83	73	0	39	36
2015	12	2	13	15	33	0.82	-0.102	4.501	0.01	0.007	0	21.5	18.1	71.8	90	79	0	40	37
2015	12	2	13	25	33	0.827	-0.138	4.501	0.01	0.007	0	19.4	15.9	72.7	84	74	0	39	37
2015	12	2	13	35	33	0.86	-0.151	4.501	0.01	0.007	0	20.2	17.2	71.4	87	77	0	40	37
2015	12	2	13	45	33	0.863	-0.144	4.501	0.01	0.007	0	23.2	20.2	72.7	94	83	0	40	36
2015	12	2	13	55	33	0.814	-0.118	4.501	0.01	0.007	0	20.6	17.2	72.7	88	77	0	40	37
2015	12	2	14	5	33	0.873	-0.121	4.501	0.01	0.007	0	19.4	16.8	71.4	85	75	0	40	36
2015	12	2	14	15	33	0.807	-0.098	4.501	0.01	0.007	0	18.9	15.5	73.1	83	73	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	14	25	33	0.886	-0.141	4.501	0.01	0.007	0	20.6	17.6	73.1	87	77	0	39	36
2015	12	2	14	35	33	0.82	-0.112	4.501	0.01	0.007	0	20.6	17.6	73.5	88	78	0	40	37
2015	12	2	14	45	33	0.86	-0.118	4.501	0.01	0.007	0	20.6	17.2	73.5	87	77	0	39	37
2015	12	2	14	55	33	0.863	-0.138	4.501	0.01	0.007	0	19.4	15.9	73.5	84	74	0	39	37
2015	12	2	15	5	33	0.81	-0.118	4.501	0.013	0.01	0	18.1	15.5	73.1	82	72	0	40	36
2015	12	2	15	15	33	0.84	-0.128	4.501	0.013	0.01	0	17.6	15.1	72.2	81	71	0	40	36
2015	12	2	15	25	33	0.85	-0.105	4.501	0.013	0.01	0	20.6	18.1	73.5	88	78	0	40	36
2015	12	2	15	35	33	0.833	-0.108	4.498	0.01	0.007	0	18.1	15.5	74	82	72	0	40	36
2015	12	2	15	45	33	0.833	-0.095	4.498	0.01	0.007	0	17.6	14.6	73.5	81	71	0	40	37
2015	12	2	15	55	33	0.846	-0.128	4.498	0.01	0.007	0	17.2	15.1	74	80	71	0	40	36
2015	12	2	16	5	33	0.837	-0.131	4.498	0.01	0.007	0	17.2	13.8	73.1	79	69	0	39	37
2015	12	2	16	15	33	0.846	-0.131	4.498	0.01	0.007	0	17.6	14.6	73.5	80	70	0	39	36
2015	12	2	16	25	33	0.856	-0.131	4.498	0.01	0.007	0	17.2	13.8	73.5	79	69	0	39	37
2015	12	2	16	35	33	0.814	-0.108	4.498	0.01	0.007	0	17.2	14.6	74	80	70	0	40	36
2015	12	2	16	45	33	0.846	-0.138	4.498	0.01	0.007	0	17.6	14.2	73.5	80	70	0	39	37
2015	12	2	16	55	33	0.837	-0.105	4.498	0.01	0.007	0	17.6	14.2	74	80	70	0	39	37
2015	12	2	17	5	33	0.843	-0.115	4.498	0.01	0.007	0	17.2	14.2	73.5	80	70	0	40	37
2015	12	2	17	15	33	0.85	-0.112	4.498	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	2	17	25	33	0.853	-0.135	4.498	0.01	0.007	0	17.6	14.2	74.4	80	70	0	39	37
2015	12	2	17	35	33	0.837	-0.118	4.498	0.01	0.007	0	17.2	14.2	73.5	80	70	0	40	37
2015	12	2	17	45	33	0.86	-0.108	4.498	0.01	0.007	0	17.6	14.6	74.4	81	71	0	40	37
2015	12	2	17	55	33	0.814	-0.118	4.498	0.01	0.007	0	17.2	14.2	74	80	70	0	40	37
2015	12	2	18	5	33	0.853	-0.118	4.498	0.01	0.007	0	17.6	14.6	74	80	70	0	39	36
2015	12	2	18	15	33	0.84	-0.112	4.498	0.01	0.007	0	17.6	14.2	74.4	80	70	0	39	37
2015	12	2	18	25	33	0.853	-0.108	4.498	0.01	0.007	0	17.2	14.2	73.1	80	70	0	40	37
2015	12	2	18	35	33	0.833	-0.108	4.498	0.01	0.007	0	17.6	14.2	74	80	70	0	39	37
2015	12	2	18	45	33	0.817	-0.131	4.498	0.01	0.007	0	17.6	13.8	74	80	69	0	39	37
2015	12	2	18	55	33	0.787	-0.115	4.498	0.01	0.007	0	17.6	14.2	73.5	80	70	0	39	37
2015	12	2	19	5	33	0.837	-0.125	4.498	0.01	0.007	0	17.2	14.2	74.8	80	70	0	40	37
2015	12	2	19	15	33	0.82	-0.118	4.498	0.01	0.007	0	16.8	13.8	74.4	79	69	0	40	37
2015	12	2	19	25	33	0.856	-0.128	4.498	0.01	0.007	0	17.6	14.2	74	80	70	0	39	37
2015	12	2	19	35	33	0.853	-0.118	4.495	0.01	0.007	0	16.8	14.2	74.4	79	70	0	40	37
2015	12	2	19	45	33	0.787	-0.125	4.498	0.01	0.007	0	17.6	13.8	74.8	80	69	0	39	37
2015	12	2	19	55	33	0.823	-0.141	4.498	0.01	0.007	0	17.6	14.2	66.7	80	70	0	39	37
2015	12	2	20	5	33	0.85	-0.138	4.495	0.01	0.007	0	17.2	14.6	62.8	80	70	0	40	36
2015	12	2	20	15	33	0.86	-0.135	4.495	0.01	0.007	0	18.1	14.6	58.9	81	71	0	39	37
2015	12	2	20	25	33	0.827	-0.118	4.495	0.01	0.007	0	18.9	15.1	75.7	83	72	0	39	37
2015	12	2	20	35	33	0.85	-0.118	4.495	0.013	0.01	0	28.4	24.5	71.4	106	94	0	40	37
2015	12	2	20	45	33	0.873	-0.112	4.495	0.01	0.007	0	22.4	19.4	71.4	92	81	0	40	36
2015	12	2	20	55	33	0.853	-0.115	4.498	0.01	0.007	0	20.2	16.8	74	87	76	0	40	37
2015	12	2	21	5	33	0.853	-0.105	4.495	0.01	0.007	0	19.8	16.8	74.8	86	75	0	40	36
2015	12	2	21	15	33	0.827	-0.144	4.495	0.01	0.007	0	19.4	15.9	74.8	84	73	0	39	36
2015	12	2	21	25	33	0.856	-0.102	4.495	0.01	0.007	0	18.5	15.5	74.4	83	73	0	40	37
2015	12	2	21	35	33	0.784	-0.085	4.495	0.01	0.007	0	18.5	15.1	74.8	82	72	0	39	37
2015	12	2	21	45	33	0.817	-0.095	4.495	0.01	0.007	0	18.5	14.6	74.4	82	71	0	39	37
2015	12	2	21	55	33	0.856	-0.144	4.495	0.01	0.007	0	17.6	14.6	74.4	81	70	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	2	22	5	33	0.827	-0.118	4.495	0.01	0.007	0	18.1	14.6	74.8	81	71	0	39	37
2015	12	2	22	15	33	0.84	-0.131	4.495	0.01	0.007	0	17.6	14.6	75.3	81	71	0	40	37
2015	12	2	22	25	33	0.83	-0.118	4.495	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	2	22	35	33	0.814	-0.108	4.495	0.01	0.007	0	18.1	14.6	74.4	82	71	0	40	37
2015	12	2	22	45	33	0.82	-0.121	4.495	0.01	0.007	0	18.1	14.6	75.3	82	72	0	40	38
2015	12	2	22	55	33	0.814	-0.128	4.495	0.01	0.007	0	18.1	14.6	72.7	82	71	0	40	37
2015	12	2	23	5	33	0.873	-0.105	4.495	0.01	0.007	0	27.1	23.6	72.7	103	91	0	40	36
2015	12	2	23	15	33	0.873	-0.115	4.495	0.01	0.007	0	28	24.1	74	105	93	0	40	37
2015	12	2	23	25	33	0.889	-0.105	4.495	0.01	0.007	0	22.4	19.4	71.4	92	81	0	40	36
2015	12	2	23	35	33	0.889	-0.125	4.495	0.01	0.007	0	28	24.5	74	105	94	0	40	37
2015	12	2	23	45	33	0.883	-0.121	4.495	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	2	23	55	33	0.817	-0.118	4.495	0.01	0.007	0	20.2	16.3	74.8	86	75	0	39	37
2015	12	3	0	5	33	0.86	-0.141	4.495	0.01	0.007	0	18.5	15.5	74	82	73	0	39	37
2015	12	3	0	15	33	0.86	-0.151	4.495	0.01	0.007	0	18.5	15.5	75.3	83	73	0	40	37
2015	12	3	0	25	33	0.84	-0.105	4.495	0.01	0.007	0	20.6	16.8	74.8	87	76	0	39	37
2015	12	3	0	35	33	0.823	-0.108	4.491	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	3	0	45	33	0.85	-0.118	4.491	0.01	0.007	0	19.4	15.5	74.4	84	73	0	39	37
2015	12	3	0	55	33	0.899	-0.125	4.491	0.01	0.007	0	18.5	15.9	74.4	83	73	0	40	36
2015	12	3	1	5	33	0.85	-0.102	4.491	0.01	0.007	0	18.1	15.5	74.4	82	72	0	40	36
2015	12	3	1	15	33	0.823	-0.102	4.491	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	3	1	25	33	0.843	-0.125	4.491	0.01	0.007	0	17.6	14.6	74.4	81	71	0	40	37
2015	12	3	1	35	33	0.82	-0.148	4.491	0.01	0.007	0	17.6	15.1	74	80	71	0	39	36
2015	12	3	1	45	33	0.833	-0.141	4.491	0.01	0.007	0	17.6	15.1	74.4	81	71	0	40	36
2015	12	3	1	55	33	0.837	-0.131	4.491	0.01	0.007	0	17.6	14.2	74	80	70	0	39	37
2015	12	3	2	5	33	0.85	-0.138	4.488	0.01	0.007	0	17.2	14.2	65.4	80	70	0	40	37
2015	12	3	2	15	33	0.863	-0.125	4.491	0.01	0.007	0	18.5	15.5	74	83	73	0	40	37
2015	12	3	2	25	33	0.837	-0.131	4.488	0.01	0.007	0	17.6	14.6	55.9	81	71	0	40	37
2015	12	3	2	35	33	0.85	-0.095	4.491	0.01	0.007	0	18.1	15.5	74	82	72	0	40	36
2015	12	3	2	45	33	0.873	-0.128	4.491	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	3	2	55	33	0.84	-0.128	4.491	0.01	0.007	0	18.1	15.1	73.5	82	72	0	40	37
2015	12	3	3	5	33	0.853	-0.095	4.488	0.01	0.007	0	17.6	15.5	73.5	81	72	0	40	36
2015	12	3	3	15	33	0.86	-0.118	4.488	0.01	0.007	0	17.6	15.1	74.4	81	71	0	40	36
2015	12	3	3	25	33	0.837	-0.141	4.488	0.01	0.007	0	17.6	15.1	73.1	81	71	0	40	36
2015	12	3	3	35	33	0.801	-0.121	4.488	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	3	3	45	33	0.823	-0.108	4.488	0.01	0.007	0	18.1	14.6	73.1	82	71	0	40	37
2015	12	3	3	55	33	0.84	-0.141	4.488	0.01	0.007	0	17.2	14.6	74	80	70	0	40	36
2015	12	3	4	5	33	0.833	-0.131	4.488	0.01	0.007	0	17.2	14.6	73.5	80	71	0	40	37
2015	12	3	4	15	33	0.82	-0.121	4.488	0.01	0.007	0	17.2	14.2	74	80	70	0	40	37
2015	12	3	4	25	33	0.846	-0.128	4.488	0.01	0.007	0	17.2	14.2	73.5	79	70	0	39	37
2015	12	3	4	35	33	0.856	-0.121	4.488	0.01	0.007	0	17.6	15.1	72.7	80	71	0	39	36
2015	12	3	4	45	33	0.843	-0.118	4.488	0.01	0.007	0	17.2	14.2	74	80	70	0	40	37
2015	12	3	4	55	33	0.82	-0.108	4.488	0.01	0.007	0	17.2	14.6	73.5	80	70	0	40	36
2015	12	3	5	5	33	0.856	-0.118	4.488	0.01	0.007	0	17.2	14.2	74	80	70	0	40	37
2015	12	3	5	15	33	0.827	-0.118	4.488	0.01	0.007	0	17.2	14.2	74.4	79	70	0	39	37
2015	12	3	5	25	33	0.814	-0.108	4.488	0.01	0.007	0	17.2	14.6	74	80	70	0	40	36
2015	12	3	5	35	33	0.876	-0.138	4.488	0.01	0.007	0	16.8	14.2	74	79	70	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	5	45	33	0.869	-0.115	4.488	0.01	0.007	0	17.2	14.6	74.4	80	70	0	40	36
2015	12	3	5	55	33	0.85	-0.131	4.488	0.01	0.007	0	17.2	14.6	74	80	70	0	40	36
2015	12	3	6	5	33	0.82	-0.121	4.485	0.01	0.007	0	17.6	14.2	73.1	80	70	0	39	37
2015	12	3	6	15	33	0.801	-0.105	4.485	0.01	0.007	0	17.6	14.6	74	80	71	0	39	37
2015	12	3	6	25	33	0.856	-0.141	4.488	0.01	0.007	0	18.1	14.6	74.4	81	71	0	39	37
2015	12	3	6	35	33	0.853	-0.108	4.488	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	3	6	45	33	0.801	-0.118	4.485	0.01	0.007	0	17.2	14.2	73.1	80	70	0	40	37
2015	12	3	6	55	33	0.81	-0.098	4.485	0.01	0.007	0	17.2	14.2	74	80	70	0	40	37
2015	12	3	7	5	33	0.837	-0.108	4.485	0.01	0.007	0	17.6	14.6	73.5	81	71	0	40	37
2015	12	3	7	15	33	0.886	-0.128	4.485	0.01	0.007	0	17.6	14.2	74	80	70	0	39	37
2015	12	3	7	25	33	0.843	-0.141	4.485	0.01	0.007	0	17.6	13.8	74.4	80	70	0	39	38
2015	12	3	7	35	33	0.856	-0.128	4.485	0.01	0.007	0	17.2	14.2	73.5	80	70	0	40	37
2015	12	3	7	45	33	0.876	-0.151	4.485	0.01	0.007	0	17.6	14.6	73.1	80	70	0	39	36
2015	12	3	7	55	33	0.83	-0.138	4.485	0.01	0.007	0	18.9	15.9	74	84	74	0	40	37
2015	12	3	8	5	33	0.817	-0.089	4.485	0.01	0.007	0	18.9	15.9	74	84	74	0	40	37
2015	12	3	8	15	33	0.827	-0.125	4.485	0.01	0.007	0	19.8	15.9	73.1	85	74	0	39	37
2015	12	3	8	25	33	0.833	-0.115	4.485	0.01	0.007	0	18.5	15.1	73.1	83	73	0	40	38
2015	12	3	8	35	33	0.833	-0.115	4.488	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	3	8	45	33	0.846	-0.118	4.488	0.01	0.007	0	18.9	15.5	73.1	83	73	0	39	37
2015	12	3	8	55	33	0.853	-0.141	4.485	0.01	0.007	0	17.6	14.6	72.7	81	71	0	40	37
2015	12	3	9	5	33	0.843	-0.131	4.485	0.01	0.007	0	17.6	14.6	72.7	81	71	0	40	37
2015	12	3	9	15	33	0.843	-0.141	4.485	0.01	0.007	0	17.6	14.6	73.1	81	71	0	40	37
2015	12	3	9	25	33	0.817	-0.135	4.488	0.01	0.007	0	17.6	14.6	73.1	81	71	0	40	37
2015	12	3	9	35	33	0.784	-0.102	4.488	0.01	0.007	0	18.5	15.5	73.1	82	72	0	39	36
2015	12	3	9	45	33	0.863	-0.105	4.488	0.01	0.007	0	18.1	15.1	73.1	81	71	0	39	36
2015	12	3	9	55	33	0.807	-0.115	4.488	0.01	0.007	0	18.1	15.1	72.2	82	72	0	40	37
2015	12	3	10	5	33	0.873	-0.135	4.488	0.01	0.007	0	17.6	15.1	72.7	81	71	0	40	36
2015	12	3	10	15	33	0.846	-0.151	4.488	0.01	0.007	0	17.6	15.1	72.2	81	71	0	40	36
2015	12	3	10	25	33	0.83	-0.118	4.488	0.01	0.007	0	18.1	15.1	72.7	81	72	0	39	37
2015	12	3	10	35	33	0.83	-0.092	4.488	0.01	0.007	0	18.1	15.1	73.1	81	72	0	39	37
2015	12	3	10	45	33	0.837	-0.135	4.488	0.01	0.007	0	17.6	15.1	72.2	81	71	0	40	36
2015	12	3	10	55	33	0.814	-0.121	4.488	0.01	0.007	0	21.1	18.1	72.2	89	79	0	40	37
2015	12	3	11	5	33	0.856	-0.138	4.488	0.01	0.007	0	19.4	15.9	68.8	84	74	0	39	37
2015	12	3	11	15	33	0.833	-0.125	4.488	0.01	0.007	0	18.9	15.9	71.4	84	75	0	40	38
2015	12	3	11	25	33	0.83	-0.121	4.485	0.01	0.007	0	18.5	15.5	67.9	83	73	0	40	37
2015	12	3	11	35	33	0.863	-0.118	4.488	0.01	0.007	0	25.8	22.4	68.4	99	89	0	39	37
2015	12	3	11	45	33	0.846	-0.128	4.488	0.01	0.007	0	20.2	17.2	67.5	87	77	0	40	37
2015	12	3	11	55	33	0.833	-0.108	4.485	0.01	0.007	0	20.6	17.6	58.5	87	77	0	39	36
2015	12	3	12	5	33	0.856	-0.148	4.488	0.01	0.007	0	21.1	18.5	67.9	89	79	0	40	36
2015	12	3	12	15	33	0.833	-0.151	4.488	0.01	0.007	0	21.1	18.1	66.7	89	79	0	40	37
2015	12	3	12	25	33	0.85	-0.144	4.488	0.01	0.007	0	20.2	16.8	59.8	86	76	0	39	37
2015	12	3	12	35	33	0.801	-0.121	4.485	0.01	0.007	0	19.4	16.8	52.5	85	76	0	40	37
2015	12	3	12	45	33	0.81	-0.148	4.485	0.01	0.007	0	18.9	16.3	52.5	84	74	0	40	36
2015	12	3	12	55	33	0.81	-0.138	4.485	0.01	0.007	0	18.9	15.9	57.6	83	73	0	39	36
2015	12	3	13	5	33	0.804	-0.112	4.482	0.01	0.007	0	18.9	15.9	49	83	74	0	39	37
2015	12	3	13	15	33	0.827	-0.144	4.485	0.01	0.007	0	19.4	16.3	59.8	85	75	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	13	25	33	0.827	-0.108	4.482	0.01	0.007	0	19.4	16.8	53.8	85	75	0	40	36
2015	12	3	13	35	33	0.81	-0.128	4.482	0.01	0.007	0	20.2	17.6	51.6	86	77	0	39	36
2015	12	3	13	45	33	0.801	-0.112	4.478	0.01	0.007	0	19.8	16.3	50.3	85	75	0	39	37
2015	12	3	13	55	33	0.823	-0.115	4.482	0.01	0.007	0	18.9	15.5	63.2	83	73	0	39	37
2015	12	3	14	5	33	0.853	-0.151	4.478	0.01	0.007	0	18.9	15.9	52.9	83	74	0	39	37
2015	12	3	14	15	33	0.814	-0.138	4.482	0.01	0.007	0	19.4	15.9	64.9	84	74	0	39	37
2015	12	3	14	25	33	0.778	-0.125	4.475	0.01	0.007	0	18.5	15.5	47.7	83	73	0	40	37
2015	12	3	14	35	33	0.833	-0.144	4.475	0.01	0.007	0	18.5	15.9	58.5	82	73	0	39	36
2015	12	3	14	45	33	0.791	-0.157	4.478	0.01	0.007	0	18.5	15.9	60.2	82	73	0	39	36
2015	12	3	14	55	33	0.814	-0.138	4.475	0.01	0.007	0	18.9	16.3	47.7	84	74	0	40	36
2015	12	3	15	5	33	0.764	-0.082	4.475	0.01	0.007	0	18.9	15.5	41.7	83	73	0	39	37
2015	12	3	15	15	33	0.764	-0.138	4.475	0.01	0.007	0	18.5	16.3	44.3	83	74	0	40	36
2015	12	3	15	25	33	0.804	-0.108	4.475	0.01	0.007	0	18.1	15.5	45.6	82	73	0	40	37
2015	12	3	15	35	33	0.804	-0.118	4.472	0.01	0.007	0	18.5	15.5	48.6	83	73	0	40	37
2015	12	3	15	45	33	0.791	-0.138	4.472	0.01	0.007	0	18.9	15.5	49.5	83	73	0	39	37
2015	12	3	15	55	33	0.823	-0.125	4.475	0.01	0.007	0	18.1	15.5	66.7	82	72	0	40	36
2015	12	3	16	5	33	0.833	-0.131	4.475	0.01	0.007	0	17.6	15.1	67.5	81	71	0	40	36
2015	12	3	16	15	33	0.82	-0.128	4.472	0.01	0.007	0	17.6	15.1	66.7	81	71	0	40	36
2015	12	3	16	25	33	0.804	-0.144	4.472	0.01	0.007	0	18.5	15.9	70.1	83	73	0	40	36
2015	12	3	16	35	33	0.814	-0.128	4.472	0.01	0.007	0	17.2	14.6	64.9	80	71	0	40	37
2015	12	3	16	45	33	0.801	-0.102	4.472	0.01	0.007	0	18.5	14.6	54.2	82	71	0	39	37
2015	12	3	16	55	33	0.83	-0.121	4.472	0.01	0.007	0	17.6	14.6	70.1	81	71	0	40	37
2015	12	3	17	5	33	0.817	-0.105	4.472	0.01	0.007	0	18.1	14.6	68.4	81	71	0	39	37
2015	12	3	17	15	33	0.797	-0.151	4.472	0.007	0.007	0	17.6	14.2	55.5	81	71	0	40	38
2015	12	3	17	25	33	0.846	-0.131	4.472	0.01	0.007	0	17.2	15.1	70.5	80	71	0	40	36
2015	12	3	17	35	33	0.827	-0.131	4.472	0.01	0.007	0	18.1	14.6	69.7	81	71	0	39	37
2015	12	3	17	45	33	0.86	-0.131	4.472	0.01	0.007	0	17.2	14.2	71	80	70	0	40	37
2015	12	3	17	55	33	0.866	-0.118	4.472	0.01	0.007	0	17.2	14.6	70.5	80	70	0	40	36
2015	12	3	18	5	33	0.846	-0.105	4.472	0.01	0.007	0	17.6	14.2	70.5	81	70	0	40	37
2015	12	3	18	15	33	0.814	-0.157	4.472	0.01	0.007	0	18.1	14.6	60.2	81	71	0	39	37
2015	12	3	18	25	33	0.794	-0.154	4.472	0.01	0.007	0	17.6	15.1	67.5	81	71	0	40	36
2015	12	3	18	35	33	0.807	-0.125	4.472	0.01	0.007	0	17.2	14.2	68.4	80	70	0	40	37
2015	12	3	18	45	33	0.814	-0.108	4.472	0.01	0.007	0	17.2	15.1	70.5	80	71	0	40	36
2015	12	3	18	55	33	0.791	-0.098	4.475	0.01	0.007	0	17.6	15.1	71.4	81	71	0	40	36
2015	12	3	19	5	33	0.846	-0.148	4.472	0.01	0.007	0	17.6	14.2	65.4	81	70	0	40	37
2015	12	3	19	15	33	0.833	-0.135	4.472	0.01	0.007	0	18.1	15.5	52.5	82	73	0	40	37
2015	12	3	19	25	33	0.853	-0.108	4.472	0.01	0.007	0	20.6	16.8	46	87	76	0	39	37
2015	12	3	19	35	33	0.866	-0.105	4.472	0.01	0.007	0	31.4	27.5	48.6	113	101	0	40	37
2015	12	3	19	45	33	0.853	-0.138	4.472	0.01	0.007	0	27.5	24.1	56.8	104	93	0	40	37
2015	12	3	19	55	33	0.82	-0.138	4.472	0.01	0.007	0	23.2	19.8	50.3	94	83	0	40	37
2015	12	3	20	5	33	0.794	-0.082	4.475	0.01	0.007	0	24.1	20.6	42.1	95	85	0	39	37
2015	12	3	20	15	33	0.774	-0.072	4.472	0.01	0.007	0	24.9	21.9	40.4	98	88	0	40	37
2015	12	3	20	25	33	0.82	-0.121	4.475	0.01	0.007	0	30.1	26.7	43	110	99	0	40	37
2015	12	3	20	35	33	0.823	-0.095	4.472	0.01	0.007	0	30.1	26.2	43.4	109	97	0	39	36
2015	12	3	20	45	33	0.823	-0.079	4.472	0.01	0.007	0	29.2	24.9	39.6	107	95	0	39	37
2015	12	3	20	55	33	0.823	-0.121	4.475	0.01	0.007	0	28.4	24.1	43	105	93	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	3	21	5	33	0.833	-0.095	4.472	0.01	0.007	0	28.4	24.9	41.3	106	94	0	40	36
2015	12	3	21	15	33	0.817	-0.108	4.472	0.01	0.007	0	28.8	24.5	41.7	106	94	0	39	37
2015	12	3	21	25	33	0.853	-0.128	4.475	0.01	0.007	0	28.8	25.4	40.9	107	96	0	40	37
2015	12	3	21	35	33	0.817	-0.105	4.469	0.01	0.007	0	30.5	26.2	40.9	110	98	0	39	37
2015	12	3	21	45	33	0.814	-0.121	4.472	0.01	0.007	0	29.2	24.9	40.4	107	95	0	39	37
2015	12	3	21	55	33	0.853	-0.082	4.475	0.01	0.007	0	28.4	24.5	37.4	105	93	0	39	36
2015	12	3	22	5	33	0.807	-0.108	4.472	0.01	0.007	0	26.7	23.6	43.4	102	91	0	40	36
2015	12	3	22	15	33	0.771	-0.098	4.475	0.01	0.007	0	26.7	23.2	40.9	102	91	0	40	37
2015	12	3	22	25	33	0.797	-0.098	4.475	0.01	0.007	0	28.8	24.5	43.4	106	94	0	39	37
2015	12	3	22	35	33	0.82	-0.128	4.472	0.01	0.007	0	30.5	27.1	42.1	110	99	0	39	36
2015	12	3	22	45	33	0.823	-0.105	4.475	0.01	0.007	0	28.8	25.8	41.3	107	96	0	40	36
2015	12	3	22	55	33	0.83	-0.085	4.475	0.01	0.007	0	28.4	24.5	43	105	93	0	39	36
2015	12	3	23	5	33	0.837	-0.085	4.472	0.01	0.007	0	26.7	23.2	46	101	90	0	39	36
2015	12	3	23	15	33	0.837	-0.138	4.472	0.01	0.007	0	25.4	21.5	45.2	99	87	0	40	37
2015	12	3	23	25	33	0.83	-0.112	4.475	0.01	0.007	0	24.1	20.6	45.2	96	84	0	40	36
2015	12	3	23	35	33	0.771	-0.105	4.472	0.01	0.007	0	23.2	19.8	45.2	94	83	0	40	37
2015	12	3	23	45	33	0.82	-0.118	4.475	0.01	0.007	0	23.2	19.4	44.7	93	82	0	39	37
2015	12	3	23	55	33	0.784	-0.095	4.472	0.01	0.007	0	22.8	19.4	42.1	92	82	0	39	37
2015	12	4	0	5	33	0.843	-0.131	4.475	0.01	0.007	0	22.8	19.4	46	93	82	0	40	37
2015	12	4	0	15	33	0.807	-0.098	4.472	0.01	0.007	0	23.6	19.8	44.3	94	83	0	39	37
2015	12	4	0	25	33	0.837	-0.108	4.472	0.01	0.007	0	24.9	21.1	46.4	97	85	0	39	36
2015	12	4	0	35	33	0.843	-0.085	4.472	0.01	0.007	0	22.4	19.8	47.3	92	82	0	40	36
2015	12	4	0	45	33	0.846	-0.148	4.472	0.01	0.007	0	23.6	19.8	59.8	94	83	0	39	37
2015	12	4	0	55	33	0.833	-0.128	4.475	0.01	0.007	0	21.1	17.6	70.1	88	78	0	39	37
2015	12	4	1	5	33	0.781	-0.121	4.475	0.01	0.007	0	21.5	18.1	58	89	78	0	39	36
2015	12	4	1	15	33	0.82	-0.112	4.475	0.01	0.007	0	21.1	17.2	72.7	88	77	0	39	37
2015	12	4	1	25	33	0.856	-0.131	4.475	0.01	0.007	0	20.6	16.8	72.2	87	76	0	39	37
2015	12	4	1	35	33	0.81	-0.115	4.475	0.013	0.01	0	34	30.1	72.2	118	106	0	39	36
2015	12	4	1	45	33	0.876	-0.131	4.475	0.01	0.007	0	24.9	21.1	72.7	97	86	0	39	37
2015	12	4	1	55	33	0.807	-0.108	4.475	0.01	0.007	0	21.5	18.5	72.7	90	80	0	40	37
2015	12	4	2	5	33	0.82	-0.092	4.475	0.01	0.007	0	22.4	18.5	71.8	91	80	0	39	37
2015	12	4	2	15	33	0.863	-0.128	4.475	0.01	0.007	0	21.9	18.9	72.7	90	80	0	39	36
2015	12	4	2	25	33	0.846	-0.102	4.475	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	4	2	35	33	0.873	-0.138	4.475	0.01	0.007	0	22.8	19.4	72.2	92	81	0	39	36
2015	12	4	2	45	33	0.843	-0.125	4.475	0.01	0.007	0	22.4	18.5	71.4	91	80	0	39	37
2015	12	4	2	55	33	0.856	-0.121	4.475	0.01	0.007	0	20.6	17.2	72.2	87	77	0	39	37
2015	12	4	3	5	33	0.843	-0.098	4.475	0.01	0.007	0	20.6	16.8	72.2	87	76	0	39	37
2015	12	4	3	15	33	0.817	-0.121	4.475	0.01	0.007	0	19.8	15.9	72.7	85	74	0	39	37
2015	12	4	3	25	33	0.876	-0.135	4.475	0.01	0.007	0	19.4	16.3	72.7	84	74	0	39	36
2015	12	4	3	35	33	0.807	-0.135	4.475	0.01	0.007	0	19.4	16.3	72.2	84	74	0	39	36
2015	12	4	3	45	33	0.837	-0.102	4.475	0.01	0.007	0	18.9	15.9	72.7	84	73	0	40	36
2015	12	4	3	55	33	0.856	-0.118	4.475	0.01	0.007	0	18.9	15.9	72.7	83	73	0	39	36
2015	12	4	4	5	33	0.84	-0.135	4.475	0.01	0.007	0	18.5	15.5	71.8	83	73	0	40	37
2015	12	4	4	15	33	0.843	-0.151	4.475	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	4	4	25	33	0.856	-0.141	4.475	0.01	0.007	0	18.5	15.5	72.2	83	73	0	40	37
2015	12	4	4	35	33	0.853	-0.128	4.475	0.01	0.007	0	18.5	15.5	71.8	83	73	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	4	45	33	0.843	-0.125	4.475	0.01	0.007	0	18.9	15.9	72.7	83	73	0	39	36
2015	12	4	4	55	33	0.866	-0.125	4.475	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	4	5	5	33	0.869	-0.141	4.475	0.01	0.007	0	18.9	15.1	71.8	83	72	0	39	37
2015	12	4	5	15	33	0.843	-0.121	4.475	0.01	0.007	0	18.5	15.1	72.2	82	72	0	39	37
2015	12	4	5	25	33	0.846	-0.144	4.475	0.01	0.007	0	18.9	15.5	71.8	83	72	0	39	36
2015	12	4	5	35	33	0.823	-0.131	4.475	0.01	0.007	0	18.5	15.5	72.7	82	72	0	39	36
2015	12	4	5	45	33	0.837	-0.118	4.475	0.01	0.007	0	18.1	15.1	71.4	82	72	0	40	37
2015	12	4	5	55	33	0.856	-0.144	4.475	0.01	0.007	0	18.1	15.5	72.2	82	72	0	40	36
2015	12	4	6	5	33	0.84	-0.151	4.475	0.013	0.01	0	18.5	15.1	71.8	82	72	0	39	37
2015	12	4	6	15	33	0.817	-0.144	4.475	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	4	6	25	33	0.866	-0.154	4.475	0.01	0.007	0	18.1	15.1	71.8	82	72	0	40	37
2015	12	4	6	35	33	0.807	-0.125	4.475	0.01	0.007	0	19.4	15.5	71.8	84	73	0	39	37
2015	12	4	6	45	33	0.869	-0.115	4.475	0.01	0.007	0	25.4	21.9	67.9	98	87	0	39	36
2015	12	4	6	55	33	0.853	-0.112	4.475	0.01	0.007	0	21.9	18.9	71.8	90	80	0	39	36
2015	12	4	7	5	33	0.873	-0.138	4.475	0.01	0.007	0	21.9	18.5	72.2	90	80	0	39	37
2015	12	4	7	15	33	0.843	-0.102	4.475	0.01	0.007	0	19.8	17.2	71.4	86	76	0	40	36
2015	12	4	7	25	33	0.817	-0.141	4.475	0.01	0.007	0	18.9	16.3	71.8	84	74	0	40	36
2015	12	4	7	35	33	0.833	-0.121	4.475	0.01	0.007	0	18.9	15.5	71.8	83	73	0	39	37
2015	12	4	7	45	33	0.823	-0.141	4.475	0.013	0.01	0	18.5	15.9	71.8	83	73	0	40	36
2015	12	4	7	55	33	0.823	-0.135	4.475	0.01	0.007	0	19.4	15.9	71.8	83	73	0	38	36
2015	12	4	8	5	33	0.85	-0.115	4.475	0.01	0.007	0	18.5	15.5	71.8	82	73	0	39	37
2015	12	4	8	15	33	0.846	-0.128	4.475	0.01	0.007	0	18.5	15.1	71.4	82	72	0	39	37
2015	12	4	8	25	33	0.856	-0.131	4.475	0.01	0.007	0	18.5	15.5	71	82	72	0	39	36
2015	12	4	8	35	33	0.817	-0.148	4.475	0.01	0.007	0	18.5	15.5	71.4	82	72	0	39	36
2015	12	4	8	45	33	0.801	-0.128	4.478	0.01	0.007	0	18.5	15.1	71.8	82	72	0	39	37
2015	12	4	8	55	33	0.879	-0.144	4.475	0.01	0.007	0	18.9	15.9	71.8	83	73	0	39	36
2015	12	4	9	5	33	0.866	-0.131	4.478	0.01	0.007	0	18.1	15.5	71.8	82	72	0	40	36
2015	12	4	9	15	33	0.833	-0.121	4.478	0.01	0.007	0	18.5	15.1	71.8	82	72	0	39	37
2015	12	4	9	25	33	0.843	-0.131	4.478	0.01	0.007	0	17.6	15.1	71.8	81	72	0	40	37
2015	12	4	9	35	33	0.807	-0.144	4.478	0.01	0.007	0	18.1	15.1	70.5	82	72	0	40	37
2015	12	4	9	45	33	0.85	-0.144	4.478	0.01	0.007	0	17.6	14.6	71.4	81	71	0	40	37
2015	12	4	9	55	33	0.83	-0.135	4.478	0.01	0.007	0	18.5	15.9	71.8	82	73	0	39	36
2015	12	4	10	5	33	0.82	-0.144	4.478	0.01	0.007	0	18.5	15.1	71.8	82	72	0	39	37
2015	12	4	10	15	33	0.843	-0.138	4.478	0.007	0.007	0	18.1	15.1	71.8	82	72	0	40	37
2015	12	4	10	25	33	0.81	-0.121	4.478	0.01	0.007	0	18.1	15.1	71.8	81	72	0	39	37
2015	12	4	10	35	33	0.846	-0.154	4.482	0.01	0.007	0	18.1	15.1	70.5	81	72	0	39	37
2015	12	4	10	45	33	0.794	-0.121	4.478	0.01	0.007	0	18.5	15.5	72.2	82	72	0	39	36
2015	12	4	10	55	33	0.823	-0.128	4.478	0.01	0.007	0	18.5	15.1	71.8	82	72	0	39	37
2015	12	4	11	5	33	0.801	-0.128	4.482	0.01	0.007	0	17.6	15.5	72.7	81	72	0	40	36
2015	12	4	11	15	33	0.827	-0.128	4.482	0.01	0.007	0	18.1	14.6	72.2	81	71	0	39	37
2015	12	4	11	25	33	0.827	-0.141	4.482	0.01	0.007	0	17.6	15.5	71.8	81	72	0	40	36
2015	12	4	11	35	33	0.814	-0.138	4.482	0.013	0.01	0	18.1	15.5	71.8	82	72	0	40	36
2015	12	4	11	45	33	0.827	-0.108	4.482	0.01	0.007	0	18.1	15.5	71.8	81	72	0	39	36
2015	12	4	11	55	33	0.794	-0.131	4.482	0.01	0.007	0	18.5	15.5	73.1	82	73	0	39	37
2015	12	4	12	5	33	0.856	-0.135	4.478	0.01	0.007	0	18.1	15.9	71.8	82	73	0	40	36
2015	12	4	12	15	33	0.817	-0.144	4.482	0.01	0.007	0	18.5	15.1	72.2	82	72	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	12	25	33	0.843	-0.128	4.478	0.01	0.007	0	18.5	15.9	72.2	82	73	0	39	36
2015	12	4	12	35	33	0.85	-0.144	4.478	0.01	0.007	0	18.1	15.1	72.2	82	72	0	40	37
2015	12	4	12	45	33	0.846	-0.125	4.478	0.01	0.007	0	19.4	16.3	72.2	84	74	0	39	36
2015	12	4	12	55	33	0.82	-0.131	4.482	0.01	0.007	0	19.4	15.9	72.7	84	74	0	39	37
2015	12	4	13	5	33	0.837	-0.141	4.482	0.01	0.007	0	19.4	16.3	72.2	84	74	0	39	36
2015	12	4	13	15	33	0.804	-0.135	4.482	0.01	0.007	0	18.9	15.9	72.7	83	74	0	39	37
2015	12	4	13	25	33	0.804	-0.102	4.478	0.01	0.007	0	21.9	18.1	73.1	90	79	0	39	37
2015	12	4	13	35	33	0.827	-0.148	4.482	0.01	0.007	0	20.6	17.2	72.7	87	76	0	39	36
2015	12	4	13	45	33	0.817	-0.144	4.478	0.01	0.007	0	20.2	17.2	72.7	87	77	0	40	37
2015	12	4	13	55	33	0.814	-0.118	4.478	0.01	0.007	0	20.2	17.2	67.5	86	76	0	39	36
2015	12	4	14	5	33	0.85	-0.115	4.478	0.01	0.007	0	20.6	17.6	72.7	87	77	0	39	36
2015	12	4	14	15	33	0.827	-0.144	4.478	0.01	0.007	0	19.4	15.9	73.1	84	74	0	39	37
2015	12	4	14	25	33	0.837	-0.128	4.478	0.01	0.007	0	19.4	16.3	73.5	84	74	0	39	36
2015	12	4	14	35	33	0.843	-0.164	4.478	0.01	0.007	0	19.4	15.9	72.7	84	74	0	39	37
2015	12	4	14	45	33	0.794	-0.121	4.478	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37
2015	12	4	14	55	33	0.833	-0.118	4.478	0.01	0.007	0	18.9	15.9	73.1	84	74	0	40	37
2015	12	4	15	5	33	0.794	-0.121	4.478	0.01	0.007	0	20.2	16.3	73.1	86	75	0	39	37
2015	12	4	15	15	33	0.83	-0.151	4.478	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	4	15	25	33	0.814	-0.118	4.478	0.01	0.007	0	18.9	16.3	73.1	84	74	0	40	36
2015	12	4	15	35	33	0.807	-0.148	4.478	0.01	0.007	0	19.4	15.9	73.1	84	73	0	39	36
2015	12	4	15	45	33	0.801	-0.095	4.478	0.01	0.007	0	18.5	15.9	72.7	83	73	0	40	36
2015	12	4	15	55	33	0.827	-0.121	4.478	0.01	0.007	0	18.5	15.5	73.5	82	72	0	39	36
2015	12	4	16	5	33	0.837	-0.121	4.478	0.01	0.007	0	18.5	15.1	73.5	82	72	0	39	37
2015	12	4	16	15	33	0.833	-0.135	4.478	0.01	0.007	0	18.1	15.5	72.7	82	72	0	40	36
2015	12	4	16	25	33	0.84	-0.177	4.478	0.01	0.007	0	18.1	14.6	72.7	81	71	0	39	37
2015	12	4	16	35	33	0.85	-0.135	4.478	0.01	0.007	0	18.1	15.5	73.5	82	72	0	40	36
2015	12	4	16	45	33	0.84	-0.144	4.478	0.01	0.007	0	17.6	14.6	73.1	81	71	0	40	37
2015	12	4	16	55	33	0.85	-0.121	4.478	0.01	0.007	0	18.5	15.5	73.1	83	73	0	40	37
2015	12	4	17	5	33	0.807	-0.121	4.478	0.01	0.007	0	18.9	15.9	72.7	83	73	0	39	36
2015	12	4	17	15	33	0.82	-0.131	4.478	0.01	0.007	0	18.5	15.5	72.7	83	73	0	40	37
2015	12	4	17	25	33	0.843	-0.112	4.478	0.01	0.007	0	18.9	15.5	73.5	83	72	0	39	36
2015	12	4	17	35	33	0.823	-0.115	4.478	0.01	0.007	0	18.5	15.5	72.7	83	73	0	40	37
2015	12	4	17	45	33	0.807	-0.108	4.478	0.01	0.007	0	18.5	15.5	72.2	82	72	0	39	36
2015	12	4	17	55	33	0.83	-0.131	4.482	0.01	0.007	0	18.5	14.6	73.1	82	71	0	39	37
2015	12	4	18	5	33	0.837	-0.118	4.478	0.01	0.007	0	18.5	15.5	73.1	82	72	0	39	36
2015	12	4	18	15	33	0.85	-0.135	4.482	0.01	0.007	0	18.5	14.6	73.1	82	71	0	39	37
2015	12	4	18	25	33	0.801	-0.098	4.482	0.01	0.007	0	18.5	15.1	72.7	83	72	0	40	37
2015	12	4	18	35	33	0.82	-0.144	4.482	0.01	0.007	0	18.1	14.6	72.7	81	71	0	39	37
2015	12	4	18	45	33	0.814	-0.144	4.482	0.013	0.01	0	18.1	15.1	72.2	82	72	0	40	37
2015	12	4	18	55	33	0.817	-0.121	4.478	0.01	0.007	0	18.1	14.6	72.2	81	71	0	39	37
2015	12	4	19	5	33	0.807	-0.121	4.482	0.01	0.007	0	17.6	15.1	72.2	81	71	0	40	36
2015	12	4	19	15	33	0.84	-0.151	4.482	0.01	0.007	0	18.1	15.1	72.2	82	71	0	40	36
2015	12	4	19	25	33	0.823	-0.095	4.482	0.01	0.007	0	21.5	18.1	66.2	89	79	0	39	37
2015	12	4	19	35	33	0.886	-0.125	4.482	0.01	0.007	0	20.6	17.6	71.4	87	77	0	39	36
2015	12	4	19	45	33	0.886	-0.125	4.482	0.01	0.007	0	25.8	21.9	71	100	88	0	40	37
2015	12	4	19	55	33	0.873	-0.121	4.482	0.01	0.007	0	23.6	20.2	71.8	94	83	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	4	20	5	33	0.853	-0.108	4.482	0.01	0.007	0	24.1	21.1	66.2	96	86	0	40	37
2015	12	4	20	15	33	0.837	-0.138	4.482	0.01	0.007	0	23.2	20.2	70.1	94	84	0	40	37
2015	12	4	20	25	33	0.83	-0.121	4.482	0.01	0.007	0	22.8	19.8	69.7	93	82	0	40	36
2015	12	4	20	35	33	0.833	-0.131	4.482	0.01	0.007	0	21.5	17.6	71	89	78	0	39	37
2015	12	4	20	45	33	0.883	-0.151	4.482	0.01	0.007	0	23.2	19.4	71.4	93	82	0	39	37
2015	12	4	20	55	33	0.846	-0.108	4.482	0.01	0.007	0	21.1	17.2	71	88	77	0	39	37
2015	12	4	21	5	33	0.833	-0.108	4.482	0.01	0.007	0	20.2	16.3	71.4	86	75	0	39	37
2015	12	4	21	15	33	0.86	-0.141	4.482	0.01	0.007	0	19.4	16.3	71	85	74	0	40	36
2015	12	4	21	25	33	0.853	-0.121	4.482	0.01	0.007	0	19.8	16.8	71	86	76	0	40	37
2015	12	4	21	35	33	0.85	-0.125	4.482	0.01	0.007	0	21.5	18.5	71	89	79	0	39	36
2015	12	4	21	45	33	0.833	-0.115	4.485	0.01	0.007	0	20.2	16.3	71	86	75	0	39	37
2015	12	4	21	55	33	0.86	-0.131	4.485	0.01	0.007	0	24.9	21.9	71	98	87	0	40	36
2015	12	4	22	5	33	0.791	-0.108	4.485	0.01	0.007	0	22.8	19.4	70.1	92	81	0	39	36
2015	12	4	22	15	33	0.823	-0.121	4.488	0.01	0.007	0	21.1	18.1	70.5	89	79	0	40	37
2015	12	4	22	25	33	0.856	-0.128	4.488	0.01	0.007	0	20.6	18.1	70.5	88	78	0	40	36
2015	12	4	22	35	33	0.833	-0.118	4.488	0.01	0.007	0	25.8	21.9	70.5	99	87	0	39	36
2015	12	4	22	45	33	0.86	-0.144	4.488	0.01	0.007	0	21.5	18.1	70.5	89	78	0	39	36
2015	12	4	22	55	33	0.833	-0.121	4.491	0.01	0.007	0	21.5	18.1	69.7	89	79	0	39	37
2015	12	4	23	5	33	0.846	-0.125	4.495	0.01	0.007	0	24.5	21.1	71.8	96	85	0	39	36
2015	12	4	23	15	33	0.837	-0.082	4.495	0.01	0.007	0	23.6	19.8	71.4	94	82	0	39	36
2015	12	4	23	25	33	0.82	-0.108	4.495	0.01	0.007	0	21.5	17.6	71.4	89	78	0	39	37
2015	12	4	23	35	33	0.843	-0.118	4.495	0.01	0.007	0	20.6	16.8	72.7	87	76	0	39	37
2015	12	4	23	45	33	0.886	-0.135	4.495	0.01	0.007	0	19.8	16.3	72.7	85	74	0	39	36
2015	12	4	23	55	33	0.833	-0.128	4.495	0.01	0.007	0	19.8	15.9	72.2	85	74	0	39	37
2015	12	5	0	5	33	0.866	-0.135	4.495	0.01	0.007	0	19.4	15.9	72.2	84	74	0	39	37
2015	12	5	0	15	33	0.807	-0.112	4.495	0.01	0.007	0	18.9	15.5	72.2	83	73	0	39	37
2015	12	5	0	25	33	0.846	-0.131	4.495	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	5	0	35	33	0.787	-0.105	4.495	0.01	0.007	0	18.5	15.5	72.7	83	73	0	40	37
2015	12	5	0	45	33	0.869	-0.141	4.495	0.01	0.007	0	18.9	15.1	72.2	83	72	0	39	37
2015	12	5	0	55	33	0.843	-0.112	4.495	0.01	0.007	0	18.9	15.5	73.5	83	73	0	39	37
2015	12	5	1	5	33	0.823	-0.135	4.495	0.01	0.007	0	19.4	15.9	72.2	83	73	0	38	36
2015	12	5	1	15	33	0.833	-0.141	4.495	0.01	0.007	0	19.4	15.9	72.7	85	74	0	40	37
2015	12	5	1	25	33	0.794	-0.125	4.495	0.01	0.007	0	19.8	17.2	61.1	86	76	0	40	36
2015	12	5	1	35	33	0.856	-0.131	4.495	0.01	0.007	0	20.6	17.2	71.8	87	76	0	39	36
2015	12	5	1	45	33	0.86	-0.118	4.495	0.01	0.007	0	18.9	15.9	73.1	84	74	0	40	37
2015	12	5	1	55	33	0.843	-0.108	4.498	0.01	0.007	0	19.4	16.3	74	84	74	0	39	36
2015	12	5	2	5	33	0.85	-0.121	4.495	0.01	0.007	0	19.8	16.3	73.5	85	74	0	39	36
2015	12	5	2	15	33	0.817	-0.128	4.498	0.01	0.007	0	24.9	21.1	74	97	86	0	39	37
2015	12	5	2	25	33	0.837	-0.138	4.498	0.01	0.007	0	21.1	17.6	74.8	88	77	0	39	36
2015	12	5	2	35	33	0.853	-0.138	4.498	0.01	0.007	0	19.4	15.9	73.5	84	74	0	39	37
2015	12	5	2	45	33	0.84	-0.131	4.498	0.01	0.007	0	22.8	19.4	74.4	92	81	0	39	36
2015	12	5	2	55	33	0.837	-0.095	4.498	0.01	0.007	0	19.8	16.3	70.5	86	75	0	40	37
2015	12	5	3	5	33	0.876	-0.125	4.498	0.01	0.007	0	19.4	15.9	73.5	85	74	0	40	37
2015	12	5	3	15	33	0.784	-0.095	4.498	0.01	0.007	0	18.9	16.3	74	84	74	0	40	36
2015	12	5	3	25	33	0.814	-0.131	4.498	0.01	0.007	0	18.9	15.5	74	83	73	0	39	37
2015	12	5	3	35	33	0.84	-0.144	4.498	0.01	0.007	0	18.5	15.1	74	83	72	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	3	45	33	0.846	-0.131	4.498	0.01	0.007	0	18.1	15.1	74.8	82	72	0	40	37
2015	12	5	3	55	33	0.843	-0.105	4.498	0.01	0.007	0	18.1	15.1	73.5	82	72	0	40	37
2015	12	5	4	5	33	0.833	-0.125	4.498	0.01	0.007	0	18.1	15.1	74.8	82	72	0	40	37
2015	12	5	4	15	33	0.827	-0.095	4.498	0.01	0.007	0	18.1	15.1	75.7	82	72	0	40	37
2015	12	5	4	25	33	0.85	-0.115	4.498	0.01	0.007	0	18.1	14.6	74.4	81	71	0	39	37
2015	12	5	4	35	33	0.833	-0.121	4.498	0.01	0.007	0	18.9	15.1	74.4	83	72	0	39	37
2015	12	5	4	45	33	0.846	-0.138	4.498	0.01	0.007	0	18.1	15.5	75.3	82	72	0	40	36
2015	12	5	4	55	33	0.791	-0.135	4.498	0.01	0.007	0	18.5	14.6	74.8	82	71	0	39	37
2015	12	5	5	5	33	0.863	-0.131	4.498	0.01	0.007	0	18.1	15.1	74.8	82	71	0	40	36
2015	12	5	5	15	33	0.814	-0.121	4.498	0.01	0.007	0	18.5	14.6	74.8	82	71	0	39	37
2015	12	5	5	25	33	0.814	-0.128	4.498	0.013	0.01	0	18.1	14.6	74.4	81	71	0	39	37
2015	12	5	5	35	33	0.85	-0.131	4.498	0.01	0.007	0	18.5	14.6	74.8	82	71	0	39	37
2015	12	5	5	45	33	0.863	-0.144	4.498	0.01	0.007	0	18.5	15.1	74.4	82	71	0	39	36
2015	12	5	5	55	33	0.837	-0.131	4.498	0.01	0.007	0	18.5	15.5	74	82	72	0	39	36
2015	12	5	6	5	33	0.778	-0.118	4.498	0.01	0.007	0	18.9	15.5	74.4	83	73	0	39	37
2015	12	5	6	15	33	0.85	-0.121	4.498	0.01	0.007	0	17.6	15.1	74.8	81	71	0	40	36
2015	12	5	6	25	33	0.83	-0.105	4.498	0.01	0.007	0	18.5	15.1	74.4	82	72	0	39	37
2015	12	5	6	35	33	0.843	-0.131	4.498	0.01	0.007	0	18.1	15.5	74	82	72	0	40	36
2015	12	5	6	45	33	0.791	-0.121	4.498	0.01	0.007	0	18.5	15.5	74.8	82	72	0	39	36
2015	12	5	6	55	33	0.81	-0.138	4.498	0.01	0.007	0	18.1	15.5	73.5	82	72	0	40	36
2015	12	5	7	5	33	0.791	-0.138	4.498	0.01	0.007	0	18.9	15.1	74	83	72	0	39	37
2015	12	5	7	15	33	0.801	-0.144	4.498	0.01	0.007	0	18.5	15.5	74	82	72	0	39	36
2015	12	5	7	25	33	0.837	-0.125	4.498	0.01	0.007	0	18.5	15.1	73.5	82	72	0	39	37
2015	12	5	7	35	33	0.886	-0.121	4.498	0.01	0.007	0	17.6	15.5	72.7	81	72	0	40	36
2015	12	5	7	45	33	0.837	-0.135	4.498	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	5	7	55	33	0.804	-0.105	4.498	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	5	8	5	33	0.797	-0.115	4.498	0.01	0.007	0	18.5	15.9	73.5	83	73	0	40	36
2015	12	5	8	15	33	0.823	-0.135	4.498	0.01	0.007	0	18.1	15.1	72.2	82	72	0	40	37
2015	12	5	8	25	33	0.804	-0.105	4.498	0.01	0.007	0	18.9	15.5	73.5	83	72	0	39	36
2015	12	5	8	35	33	0.83	-0.128	4.498	0.01	0.007	0	18.5	15.1	73.5	82	72	0	39	37
2015	12	5	8	45	33	0.814	-0.105	4.501	0.01	0.007	0	18.5	15.5	73.1	83	72	0	40	36
2015	12	5	8	55	33	0.827	-0.118	4.501	0.01	0.007	0	18.5	15.1	72.7	82	72	0	39	37
2015	12	5	9	5	33	0.84	-0.098	4.501	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	5	9	15	33	0.853	-0.135	4.501	0.01	0.007	0	18.1	15.1	73.1	82	72	0	40	37
2015	12	5	9	25	33	0.833	-0.135	4.501	0.01	0.007	0	18.1	15.1	73.5	82	72	0	40	37
2015	12	5	9	35	33	0.82	-0.118	4.501	0.01	0.007	0	18.1	15.5	73.5	82	72	0	40	36
2015	12	5	9	45	33	0.817	-0.105	4.501	0.01	0.007	0	18.1	15.1	73.5	82	72	0	40	37
2015	12	5	9	55	33	0.774	-0.121	4.501	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	5	10	5	33	0.853	-0.157	4.505	0.01	0.007	0	18.1	15.5	72.7	81	72	0	39	36
2015	12	5	10	15	33	0.83	-0.154	4.505	0.01	0.007	0	18.9	15.9	73.1	83	73	0	39	36
2015	12	5	10	25	33	0.807	-0.108	4.505	0.01	0.007	0	18.9	15.5	73.5	83	73	0	39	37
2015	12	5	10	35	33	0.823	-0.115	4.505	0.01	0.007	0	18.9	15.5	74	83	73	0	39	37
2015	12	5	10	45	33	0.84	-0.144	4.505	0.01	0.007	0	18.9	15.5	73.5	83	73	0	39	37
2015	12	5	10	55	33	0.794	-0.118	4.505	0.01	0.007	0	18.5	15.1	74	82	72	0	39	37
2015	12	5	11	5	33	0.807	-0.128	4.501	0.01	0.007	0	17.6	15.1	74	81	71	0	40	36
2015	12	5	11	15	33	0.81	-0.121	4.505	0.01	0.007	0	18.9	15.9	73.1	83	73	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	11	25	33	0.827	-0.112	4.505	0.01	0.007	0	18.9	15.5	74.4	84	73	0	40	37
2015	12	5	11	35	33	0.82	-0.098	4.505	0.01	0.007	0	18.1	15.5	71.4	82	72	0	40	36
2015	12	5	11	45	33	0.837	-0.121	4.505	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37
2015	12	5	11	55	33	0.846	-0.118	4.505	0.01	0.007	0	18.9	15.5	73.1	83	73	0	39	37
2015	12	5	12	5	33	0.843	-0.105	4.505	0.01	0.007	0	18.5	15.9	70.1	83	73	0	40	36
2015	12	5	12	15	33	0.781	-0.102	4.505	0.01	0.007	0	18.9	16.3	67.1	84	74	0	40	36
2015	12	5	12	25	33	0.807	-0.138	4.505	0.01	0.007	0	19.8	16.8	73.1	86	75	0	40	36
2015	12	5	12	35	33	0.84	-0.135	4.508	0.01	0.007	0	18.9	16.3	73.1	84	74	0	40	36
2015	12	5	12	45	33	0.814	-0.115	4.505	0.01	0.007	0	18.5	15.5	73.5	83	73	0	40	37
2015	12	5	12	55	33	0.85	-0.115	4.505	0.01	0.007	0	18.9	15.5	73.1	83	73	0	39	37
2015	12	5	13	5	33	0.84	-0.125	4.505	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	5	13	15	33	0.84	-0.125	4.505	0.013	0.01	0	18.5	15.5	74	82	72	0	39	36
2015	12	5	13	25	33	0.86	-0.141	4.505	0.01	0.007	0	18.1	15.5	74	82	72	0	40	36
2015	12	5	13	35	33	0.787	-0.135	4.508	0.01	0.007	0	18.9	15.9	73.1	83	73	0	39	36
2015	12	5	13	45	33	0.804	-0.135	4.505	0.01	0.007	0	18.5	15.5	72.7	83	73	0	40	37
2015	12	5	13	55	33	0.833	-0.121	4.505	0.01	0.007	0	19.8	15.9	72.2	85	74	0	39	37
2015	12	5	14	5	33	0.823	-0.161	4.505	0.01	0.007	0	18.9	15.9	72.2	84	73	0	40	36
2015	12	5	14	15	33	0.856	-0.151	4.505	0.01	0.007	0	18.9	15.1	73.1	83	72	0	39	37
2015	12	5	14	25	33	0.843	-0.135	4.505	0.01	0.007	0	18.9	15.9	73.5	83	73	0	39	36
2015	12	5	14	35	33	0.843	-0.144	4.505	0.01	0.007	0	18.5	15.9	71	83	73	0	40	36
2015	12	5	14	45	33	0.791	-0.118	4.505	0.01	0.007	0	20.6	17.6	72.7	88	78	0	40	37
2015	12	5	14	55	33	0.801	-0.095	4.505	0.01	0.007	0	19.4	15.9	64.5	84	74	0	39	37
2015	12	5	15	5	33	0.807	-0.157	4.505	0.01	0.007	0	18.9	16.3	57.6	84	74	0	40	36
2015	12	5	15	15	33	0.81	-0.138	4.505	0.01	0.007	0	18.9	15.9	69.2	83	73	0	39	36
2015	12	5	15	25	33	0.823	-0.105	4.505	0.01	0.007	0	18.5	15.1	71	82	72	0	39	37
2015	12	5	15	35	33	0.817	-0.085	4.505	0.01	0.007	0	20.2	17.2	62.8	86	76	0	39	36
2015	12	5	15	45	33	0.84	-0.131	4.505	0.01	0.007	0	19.8	16.3	73.1	85	75	0	39	37
2015	12	5	15	55	33	0.827	-0.121	4.505	0.01	0.007	0	18.9	16.3	73.5	84	74	0	40	36
2015	12	5	16	5	33	0.827	-0.118	4.505	0.01	0.007	0	18.5	15.1	73.1	83	72	0	40	37
2015	12	5	16	15	33	0.866	-0.135	4.505	0.01	0.007	0	18.5	14.6	74	82	71	0	39	37
2015	12	5	16	25	33	0.843	-0.128	4.505	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	5	16	35	33	0.82	-0.092	4.505	0.01	0.007	0	18.1	14.2	73.5	82	71	0	40	38
2015	12	5	16	45	33	0.846	-0.128	4.505	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	5	16	55	33	0.804	-0.141	4.505	0.01	0.007	0	18.1	14.6	73.5	81	71	0	39	37
2015	12	5	17	5	33	0.843	-0.144	4.505	0.01	0.007	0	18.5	14.6	73.1	82	71	0	39	37
2015	12	5	17	15	33	0.82	-0.135	4.508	0.01	0.007	0	18.5	15.5	73.5	82	72	0	39	36
2015	12	5	17	25	33	0.863	-0.131	4.505	0.01	0.007	0	18.5	15.5	74	82	72	0	39	36
2015	12	5	17	35	33	0.814	-0.131	4.505	0.01	0.007	0	18.5	15.5	73.5	83	72	0	40	36
2015	12	5	17	45	33	0.807	-0.128	4.505	0.01	0.007	0	18.5	15.1	73.5	82	72	0	39	37
2015	12	5	17	55	33	0.82	-0.115	4.505	0.01	0.007	0	18.5	14.6	74	82	71	0	39	37
2015	12	5	18	5	33	0.804	-0.141	4.505	0.01	0.007	0	18.1	14.6	74	82	71	0	40	37
2015	12	5	18	15	33	0.843	-0.138	4.508	0.01	0.007	0	18.5	14.6	73.1	82	71	0	39	37
2015	12	5	18	25	33	0.82	-0.131	4.508	0.01	0.007	0	18.1	15.1	73.5	81	71	0	39	36
2015	12	5	18	35	33	0.827	-0.128	4.505	0.01	0.007	0	18.1	14.6	61.5	81	71	0	39	37
2015	12	5	18	45	33	0.873	-0.157	4.508	0.01	0.007	0	18.5	15.5	73.1	83	73	0	40	37
2015	12	5	18	55	33	0.866	-0.125	4.508	0.01	0.007	0	29.2	24.1	72.7	106	93	0	38	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	5	19	5	33	0.85	-0.121	4.508	0.01	0.007	0	23.6	19.8	70.1	94	83	0	39	37
2015	12	5	19	15	33	0.856	-0.128	4.508	0.01	0.007	0	20.2	17.2	72.7	86	76	0	39	36
2015	12	5	19	25	33	0.823	-0.131	4.508	0.01	0.007	0	19.8	16.8	72.2	86	76	0	40	37
2015	12	5	19	35	33	0.866	-0.161	4.508	0.01	0.007	0	19.4	15.9	73.1	84	73	0	39	36
2015	12	5	19	45	33	0.876	-0.105	4.508	0.01	0.007	0	23.6	20.2	73.1	94	83	0	39	36
2015	12	5	19	55	33	0.82	-0.135	4.508	0.01	0.007	0	21.1	17.6	71	88	77	0	39	36
2015	12	5	20	5	33	0.833	-0.121	4.508	0.01	0.007	0	19.8	16.3	73.1	85	74	0	39	36
2015	12	5	20	15	33	0.823	-0.135	4.508	0.01	0.007	0	18.9	15.9	73.1	84	74	0	40	37
2015	12	5	20	25	33	0.83	-0.141	4.508	0.01	0.007	0	18.9	15.5	72.2	83	73	0	39	37
2015	12	5	20	35	33	0.856	-0.108	4.508	0.01	0.007	0	18.1	15.5	73.1	82	72	0	40	36
2015	12	5	20	45	33	0.807	-0.095	4.508	0.013	0.01	0	18.5	15.1	73.1	82	72	0	39	37
2015	12	5	20	55	33	0.817	-0.092	4.508	0.01	0.007	0	18.9	15.1	72.7	83	72	0	39	37
2015	12	5	21	5	33	0.833	-0.141	4.508	0.01	0.007	0	18.5	15.1	73.1	82	72	0	39	37
2015	12	5	21	15	33	0.866	-0.131	4.508	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	5	21	25	33	0.797	-0.112	4.508	0.01	0.007	0	18.9	15.9	72.7	84	74	0	40	37
2015	12	5	21	35	33	0.837	-0.112	4.508	0.01	0.007	0	18.5	15.1	73.1	82	72	0	39	37
2015	12	5	21	45	33	0.892	-0.115	4.508	0.01	0.007	0	18.1	15.1	72.2	81	71	0	39	36
2015	12	5	21	55	33	0.833	-0.135	4.508	0.01	0.007	0	18.1	15.1	72.2	82	72	0	40	37
2015	12	5	22	5	33	0.846	-0.121	4.508	0.01	0.007	0	17.6	15.1	72.2	81	71	0	40	36
2015	12	5	22	15	33	0.837	-0.108	4.508	0.01	0.007	0	18.5	15.5	73.1	82	72	0	39	36
2015	12	5	22	25	33	0.817	-0.121	4.508	0.01	0.007	0	18.1	15.1	72.7	81	71	0	39	36
2015	12	5	22	35	33	0.804	-0.089	4.508	0.01	0.007	0	18.5	15.5	73.5	82	72	0	39	36
2015	12	5	22	45	33	0.794	-0.098	4.508	0.01	0.007	0	17.6	14.6	72.7	81	71	0	40	37
2015	12	5	22	55	33	0.866	-0.135	4.508	0.01	0.007	0	18.1	15.1	72.2	82	71	0	40	36
2015	12	5	23	5	33	0.837	-0.144	4.508	0.01	0.007	0	17.6	14.6	73.1	81	71	0	40	37
2015	12	5	23	15	33	0.84	-0.135	4.508	0.01	0.007	0	18.1	14.6	72.7	81	71	0	39	37
2015	12	5	23	25	33	0.82	-0.095	4.508	0.01	0.007	0	18.5	15.5	73.5	82	72	0	39	36
2015	12	5	23	35	33	0.84	-0.121	4.505	0.01	0.007	0	17.2	14.6	73.1	80	70	0	40	36
2015	12	5	23	45	33	0.804	-0.105	4.505	0.01	0.007	0	18.1	14.6	73.1	81	71	0	39	37
2015	12	5	23	55	33	0.817	-0.108	4.505	0.01	0.007	0	17.6	14.6	74	81	71	0	40	37
2015	12	6	0	5	33	0.823	-0.125	4.505	0.01	0.007	0	17.2	15.1	73.5	80	71	0	40	36
2015	12	6	0	15	33	0.797	-0.105	4.505	0.01	0.007	0	18.9	15.9	73.5	83	73	0	39	36
2015	12	6	0	25	33	0.81	-0.138	4.505	0.01	0.007	0	18.1	14.6	73.5	81	71	0	39	37
2015	12	6	0	35	33	0.804	-0.108	4.505	0.013	0.01	0	17.6	14.6	74	81	71	0	40	37
2015	12	6	0	45	33	0.81	-0.112	4.501	0.01	0.007	0	18.1	14.2	74	81	70	0	39	37
2015	12	6	0	55	33	0.804	-0.105	4.501	0.01	0.007	0	18.1	15.1	74.4	82	72	0	40	37
2015	12	6	1	5	33	0.856	-0.108	4.501	0.01	0.007	0	18.5	15.1	74.4	82	71	0	39	36
2015	12	6	1	15	33	0.837	-0.118	4.498	0.01	0.007	0	18.1	14.2	74.4	81	70	0	39	37
2015	12	6	1	25	33	0.833	-0.141	4.498	0.01	0.007	0	17.6	14.6	74	80	70	0	39	36
2015	12	6	1	35	33	0.797	-0.121	4.495	0.01	0.007	0	18.1	14.6	73.5	81	71	0	39	37
2015	12	6	1	45	33	0.81	-0.102	4.495	0.01	0.007	0	18.1	14.6	72.7	81	71	0	39	37
2015	12	6	1	55	33	0.843	-0.125	4.491	0.01	0.007	0	21.5	18.1	72.2	89	78	0	39	36
2015	12	6	2	5	33	0.83	-0.115	4.488	0.01	0.007	0	23.2	19.4	70.5	93	82	0	39	37
2015	12	6	2	15	33	0.774	-0.108	4.485	0.01	0.007	0	22.4	18.9	69.7	91	81	0	39	37
2015	12	6	2	25	33	0.84	-0.144	4.475	0.01	0.007	0	21.1	17.6	70.5	88	77	0	39	36
2015	12	6	2	35	33	0.823	-0.135	4.475	0.01	0.007	0	19.8	16.8	71	85	75	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	2	45	33	0.817	-0.138	4.472	0.01	0.007	0	19.8	16.8	71.8	85	75	0	39	36
2015	12	6	2	55	33	0.853	-0.115	4.472	0.01	0.007	0	27.1	23.2	72.7	102	90	0	39	36
2015	12	6	3	5	33	0.843	-0.144	4.469	0.01	0.007	0	23.2	19.4	72.7	93	82	0	39	37
2015	12	6	3	15	33	0.833	-0.131	4.465	0.01	0.007	0	22.8	19.4	73.1	93	82	0	40	37
2015	12	6	3	25	33	0.837	-0.131	4.465	0.01	0.007	0	20.6	17.6	74	88	78	0	40	37
2015	12	6	3	35	33	0.807	-0.115	4.462	0.01	0.007	0	19.8	17.2	74.8	86	76	0	40	36
2015	12	6	3	45	33	0.83	-0.115	4.459	0.01	0.007	0	24.5	21.1	74.4	96	85	0	39	36
2015	12	6	3	55	33	0.791	-0.102	4.455	0.01	0.007	0	20.2	17.2	71.4	87	76	0	40	36
2015	12	6	4	5	33	0.787	-0.121	4.452	0.01	0.007	0	18.9	16.3	71.4	84	74	0	40	36
2015	12	6	4	15	33	0.817	-0.095	4.446	0.01	0.007	0	19.4	16.3	70.1	84	74	0	39	36
2015	12	6	4	25	33	0.801	-0.095	4.439	0.01	0.007	0	19.8	15.9	71	85	74	0	39	37
2015	12	6	4	35	33	0.768	-0.125	4.436	0.01	0.007	0	18.9	15.5	71	83	73	0	39	37
2015	12	6	4	45	33	0.817	-0.112	4.432	0.01	0.007	0	18.9	15.1	72.7	83	72	0	39	37
2015	12	6	4	55	33	0.823	-0.125	4.429	0.01	0.007	0	18.1	15.5	74	82	72	0	40	36
2015	12	6	5	5	33	0.778	-0.128	4.426	0.01	0.007	0	18.9	15.1	73.5	83	72	0	39	37
2015	12	6	5	15	33	0.82	-0.108	4.423	0.01	0.007	0	17.6	15.1	74.8	81	72	0	40	37
2015	12	6	5	25	33	0.784	-0.121	4.419	0.013	0.01	0	18.1	15.5	73.1	82	72	0	40	36
2015	12	6	5	35	33	0.817	-0.141	4.416	0.01	0.007	0	18.5	15.1	72.2	82	72	0	39	37
2015	12	6	5	45	33	0.804	-0.131	4.413	0.01	0.007	0	18.9	15.9	70.1	83	73	0	39	36
2015	12	6	5	55	33	0.85	-0.131	4.4	0.01	0.007	0	18.1	15.1	71	82	72	0	40	37
2015	12	6	6	5	33	0.797	-0.118	4.396	0.01	0.007	0	18.5	14.6	71.4	82	71	0	39	37
2015	12	6	6	15	33	0.781	-0.115	4.39	0.01	0.007	0	17.6	15.5	73.1	81	72	0	40	36
2015	12	6	6	25	33	0.823	-0.135	4.386	0.01	0.007	0	18.1	15.1	71.8	82	72	0	40	37
2015	12	6	6	35	33	0.814	-0.138	4.386	0.01	0.007	0	18.5	15.5	74	82	72	0	39	36
2015	12	6	6	45	33	0.823	-0.144	4.383	0.01	0.007	0	18.1	15.1	74.4	82	72	0	40	37
2015	12	6	6	55	33	0.817	-0.125	4.38	0.01	0.007	0	18.5	15.1	72.7	82	72	0	39	37
2015	12	6	7	5	33	0.817	-0.135	4.373	0.01	0.007	0	18.5	15.1	70.1	82	72	0	39	37
2015	12	6	7	15	33	0.827	-0.115	4.36	0.01	0.007	0	18.5	15.5	71	83	72	0	40	36
2015	12	6	7	25	33	0.804	-0.118	4.357	0.01	0.007	0	18.1	15.1	71.8	81	71	0	39	36
2015	12	6	7	35	33	0.797	-0.118	4.354	0.01	0.007	0	18.1	15.1	72.7	82	72	0	40	37
2015	12	6	7	45	33	0.771	-0.105	4.35	0.01	0.007	0	18.1	15.1	74	82	72	0	40	37
2015	12	6	7	55	33	0.787	-0.112	4.347	0.01	0.007	0	18.9	15.1	74.8	83	72	0	39	37
2015	12	6	8	5	33	0.801	-0.121	4.344	0.01	0.007	0	18.1	15.5	74.4	82	73	0	40	37
2015	12	6	8	15	33	0.784	-0.128	4.341	0.01	0.007	0	18.5	15.5	73.1	83	73	0	40	37
2015	12	6	8	25	33	0.801	-0.128	4.331	0.01	0.007	0	18.5	15.5	70.1	83	73	0	40	37
2015	12	6	8	35	33	0.807	-0.141	4.321	0.01	0.007	0	18.9	15.5	71.4	83	73	0	39	37
2015	12	6	8	45	33	0.82	-0.131	4.318	0.01	0.007	0	18.5	15.9	72.7	83	73	0	40	36
2015	12	6	8	55	33	0.804	-0.131	4.314	0.01	0.007	0	18.5	15.5	74	83	73	0	40	37
2015	12	6	9	5	33	0.771	-0.131	4.314	0.01	0.007	0	18.5	15.5	74.4	83	73	0	40	37
2015	12	6	9	15	33	0.82	-0.154	4.311	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	6	9	25	33	0.791	-0.121	4.308	0.01	0.007	0	18.9	15.9	72.2	84	74	0	40	37
2015	12	6	9	35	33	0.784	-0.095	4.298	0.01	0.007	0	19.4	16.3	70.5	85	75	0	40	37
2015	12	6	9	45	33	0.814	-0.131	4.288	0.01	0.007	0	23.2	19.4	71.8	93	82	0	39	37
2015	12	6	9	55	33	0.778	-0.128	4.285	0.013	0.01	0	19.8	17.2	72.7	86	76	0	40	36
2015	12	6	10	5	33	0.751	-0.098	4.281	0.01	0.007	0	19.8	16.3	74	85	75	0	39	37
2015	12	6	10	15	33	0.817	-0.128	4.278	0.01	0.007	0	18.9	16.8	75.3	84	75	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	10	25	33	0.778	-0.148	4.275	0.01	0.007	0	19.4	15.9	74	84	74	0	39	37
2015	12	6	10	35	33	0.745	-0.112	4.272	0.01	0.007	0	18.9	15.9	72.2	84	74	0	40	37
2015	12	6	10	45	33	0.741	-0.154	4.259	0.01	0.007	0	19.4	16.3	69.7	84	75	0	39	37
2015	12	6	10	55	33	0.741	-0.105	4.252	0.01	0.007	0	19.4	16.3	64.9	84	75	0	39	37
2015	12	6	11	5	33	0.768	-0.135	4.245	0.01	0.007	0	19.4	16.3	72.7	85	75	0	40	37
2015	12	6	11	15	33	0.728	-0.108	4.242	0.01	0.007	0	19.4	16.8	68.4	85	75	0	40	36
2015	12	6	11	25	33	0.738	-0.112	4.242	0.01	0.007	0	25.8	22.4	72.2	99	89	0	39	37
2015	12	6	11	35	33	0.758	-0.105	4.239	0.01	0.007	0	21.5	18.5	61.5	89	79	0	39	36
2015	12	6	11	45	33	0.738	-0.118	4.229	0.01	0.007	0	20.2	17.6	53.3	87	77	0	40	36
2015	12	6	11	55	33	0.712	-0.108	4.216	0.01	0.007	0	20.2	17.2	51.6	87	77	0	40	37
2015	12	6	12	5	33	0.728	-0.102	4.213	0.01	0.007	0	20.6	17.2	68.4	88	77	0	40	37
2015	12	6	12	15	33	0.712	-0.092	4.209	0.01	0.007	0	20.2	17.2	48.2	87	77	0	40	37
2015	12	6	12	25	33	0.748	-0.138	4.206	0.01	0.007	0	21.1	17.6	46	88	78	0	39	37
2015	12	6	12	35	33	0.735	-0.112	4.203	0.01	0.007	0	21.1	17.6	46.9	88	78	0	39	37
2015	12	6	12	45	33	0.728	-0.118	4.196	0.01	0.007	0	23.6	20.2	44.3	94	84	0	39	37
2015	12	6	12	55	33	0.722	-0.138	4.19	0.01	0.007	0	21.1	18.1	43.9	89	79	0	40	37
2015	12	6	13	5	33	0.709	-0.128	4.183	0.01	0.007	0	21.9	18.5	48.6	91	80	0	40	37
2015	12	6	13	15	33	0.748	-0.154	4.177	0.01	0.007	0	21.1	18.1	49.9	88	78	0	39	36
2015	12	6	13	25	33	0.741	-0.098	4.173	0.01	0.007	0	21.1	18.1	69.2	89	79	0	40	37
2015	12	6	13	35	33	0.725	-0.157	4.173	0.01	0.007	0	20.2	17.2	71.8	87	77	0	40	37
2015	12	6	13	45	33	0.705	-0.105	4.17	0.01	0.007	0	21.1	17.6	71.4	88	78	0	39	37
2015	12	6	13	55	33	0.728	-0.118	4.167	0.01	0.007	0	20.6	17.2	71	88	77	0	40	37
2015	12	6	14	5	33	0.712	-0.112	4.163	0.01	0.007	0	20.6	17.2	49.9	87	77	0	39	37
2015	12	6	14	15	33	0.732	-0.108	4.16	0.01	0.007	0	20.2	16.3	71.4	86	76	0	39	38
2015	12	6	14	25	33	0.696	-0.112	4.147	0.01	0.007	0	20.2	16.8	63.2	86	76	0	39	37
2015	12	6	14	35	33	0.745	-0.148	4.144	0.01	0.007	0	20.2	16.8	70.5	86	76	0	39	37
2015	12	6	14	45	33	0.741	-0.131	4.137	0.01	0.007	0	19.4	16.3	73.1	85	75	0	40	37
2015	12	6	14	55	33	0.738	-0.128	4.134	0.01	0.007	0	19.8	16.8	74	86	76	0	40	37
2015	12	6	15	5	33	0.696	-0.125	4.134	0.01	0.007	0	20.6	17.6	74.4	87	77	0	39	36
2015	12	6	15	15	33	0.784	-0.108	4.131	0.01	0.007	0	19.4	16.8	71.8	85	75	0	40	36
2015	12	6	15	25	33	0.741	-0.115	4.127	0.01	0.007	0	19.8	16.8	71.8	86	75	0	40	36
2015	12	6	15	35	33	0.745	-0.135	4.124	0.01	0.007	0	19.8	15.9	75.3	85	74	0	39	37
2015	12	6	15	45	33	0.755	-0.138	4.121	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	6	15	55	33	0.735	-0.148	4.114	0.01	0.007	0	19.4	15.9	71.8	85	74	0	40	37
2015	12	6	16	5	33	0.751	-0.148	4.104	0.01	0.007	0	19.8	16.8	72.2	85	75	0	39	36
2015	12	6	16	15	33	0.712	-0.128	4.101	0.01	0.007	0	19.4	15.5	73.5	84	74	0	39	38
2015	12	6	16	25	33	0.768	-0.141	4.101	0.013	0.01	0	18.9	16.3	74.8	84	74	0	40	36
2015	12	6	16	35	33	0.751	-0.135	4.098	0.01	0.007	0	19.8	16.3	74.8	85	74	0	39	36
2015	12	6	16	45	33	0.722	-0.108	4.094	0.01	0.007	0	20.2	16.8	75.3	86	75	0	39	36
2015	12	6	16	55	33	0.741	-0.135	4.094	0.01	0.007	0	18.9	15.9	75.7	84	74	0	40	37
2015	12	6	17	5	33	0.768	-0.148	4.091	0.01	0.007	0	19.4	15.9	76.5	84	74	0	39	37
2015	12	6	17	15	33	0.84	-0.135	4.088	0.01	0.007	0	19.8	16.8	76.1	85	75	0	39	36
2015	12	6	17	25	33	0.768	-0.138	4.088	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	6	17	35	33	0.758	-0.144	4.085	0.01	0.007	0	19.4	15.9	74.4	85	74	0	40	37
2015	12	6	17	45	33	0.751	-0.112	4.081	0.01	0.007	0	19.8	15.9	72.7	85	74	0	39	37
2015	12	6	17	55	33	0.715	-0.125	4.075	0.01	0.007	0	18.9	15.9	71.4	84	74	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	6	18	5	33	0.768	-0.148	4.068	0.01	0.007	0	19.4	15.9	71.8	84	73	0	39	36
2015	12	6	18	15	33	0.722	-0.144	4.065	0.01	0.007	0	19.4	15.9	73.1	84	74	0	39	37
2015	12	6	18	25	33	0.728	-0.098	4.062	0.01	0.007	0	18.9	15.5	73.5	84	73	0	40	37
2015	12	6	18	35	33	0.787	-0.148	4.062	0.01	0.007	0	19.4	15.9	74.8	84	74	0	39	37
2015	12	6	18	45	33	0.768	-0.138	4.058	0.01	0.007	0	18.9	15.5	74.4	84	73	0	40	37
2015	12	6	18	55	33	0.728	-0.095	4.058	0.01	0.007	0	19.4	15.5	75.3	84	73	0	39	37
2015	12	6	19	5	33	0.755	-0.112	4.058	0.01	0.007	0	18.9	15.5	75.7	84	73	0	40	37
2015	12	6	19	15	33	0.745	-0.115	4.055	0.01	0.007	0	18.5	15.5	76.1	83	73	0	40	37
2015	12	6	19	25	33	0.735	-0.121	4.055	0.01	0.007	0	18.9	15.9	76.1	83	74	0	39	37
2015	12	6	19	35	33	0.768	-0.118	4.052	0.01	0.007	0	19.4	15.5	64.1	84	73	0	39	37
2015	12	6	19	45	33	0.751	-0.141	4.052	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	6	19	55	33	0.745	-0.141	4.049	0.01	0.007	0	19.8	16.3	75.7	86	75	0	40	37
2015	12	6	20	5	33	0.738	-0.121	4.049	0.013	0.01	0	19.8	16.3	74.8	85	75	0	39	37
2015	12	6	20	15	33	0.745	-0.105	4.042	0.01	0.007	0	26.2	22.8	52	101	90	0	40	37
2015	12	6	20	25	33	0.741	-0.118	4.045	0.013	0.01	0	25.4	22.4	73.5	99	88	0	40	36
2015	12	6	20	35	33	0.755	-0.115	4.042	0.013	0.01	0	28.4	24.5	73.1	105	93	0	39	36
2015	12	6	20	45	33	0.774	-0.118	4.039	0.01	0.007	0	30.5	26.7	72.7	110	99	0	39	37
2015	12	6	20	55	33	0.764	-0.102	4.032	0.013	0.01	0	28	24.5	71.8	105	94	0	40	37
2015	12	6	21	5	33	0.755	-0.082	4.029	0.01	0.007	0	27.5	23.6	71.8	103	92	0	39	37
2015	12	6	21	15	33	0.748	-0.112	4.026	0.01	0.007	0	25.8	22.8	73.1	100	89	0	40	36
2015	12	6	21	25	33	0.778	-0.131	4.026	0.01	0.007	0	28.4	24.9	73.5	106	94	0	40	36
2015	12	6	21	35	33	0.817	-0.115	4.026	0.01	0.007	0	31.8	28.4	73.5	114	102	0	40	36
2015	12	6	21	45	33	0.781	-0.131	4.022	0.01	0.007	0	30.1	26.2	73.5	110	98	0	40	37
2015	12	6	21	55	33	0.738	-0.082	4.022	0.01	0.007	0	28.4	24.9	74.4	105	94	0	39	36
2015	12	6	22	5	33	0.755	-0.115	4.022	0.01	0.007	0	26.2	23.2	74.4	101	90	0	40	36
2015	12	6	22	15	33	0.797	-0.135	4.022	0.01	0.007	0	24.1	20.6	74.8	95	84	0	39	36
2015	12	6	22	25	33	0.751	-0.095	4.019	0.01	0.007	0	28.8	25.8	73.1	107	96	0	40	36
2015	12	6	22	35	33	0.764	-0.098	4.019	0.01	0.007	0	31.8	28.4	75.7	114	102	0	40	36
2015	12	6	22	45	33	0.781	-0.095	4.019	0.01	0.007	0	29.2	24.9	76.5	107	95	0	39	37
2015	12	6	22	55	33	0.781	-0.098	4.016	0.01	0.007	0	25.4	21.5	75.7	99	87	0	40	37
2015	12	6	23	5	33	0.804	-0.102	4.016	0.01	0.007	0	24.1	20.2	76.5	96	84	0	40	37
2015	12	6	23	15	33	0.725	-0.121	4.016	0.01	0.007	0	24.1	21.1	76.5	96	85	0	40	36
2015	12	6	23	25	33	0.719	-0.105	4.016	0.01	0.007	0	27.1	23.2	69.2	102	91	0	39	37
2015	12	6	23	35	33	0.774	-0.141	4.012	0.01	0.007	0	31.8	28.4	77	114	103	0	40	37
2015	12	6	23	45	33	0.745	-0.105	4.016	0.01	0.007	0	29.2	24.9	76.5	107	95	0	39	37
2015	12	6	23	55	33	0.791	-0.095	4.012	0.013	0.01	0	24.9	21.5	76.5	98	87	0	40	37
2015	12	7	0	5	33	0.764	-0.125	4.012	0.01	0.007	0	26.7	23.2	76.5	101	90	0	39	36
2015	12	7	0	15	33	0.771	-0.121	4.009	0.01	0.007	0	32.3	28	66.7	114	102	0	39	37
2015	12	7	0	25	33	0.774	-0.095	4.009	0.01	0.007	0	28.4	24.5	76.1	105	94	0	39	37
2015	12	7	0	35	33	0.778	-0.095	4.009	0.01	0.007	0	27.5	23.2	75.7	103	91	0	39	37
2015	12	7	0	45	33	0.784	-0.121	4.009	0.01	0.007	0	29.7	25.4	75.3	109	96	0	40	37
2015	12	7	0	55	33	0.732	-0.118	4.009	0.01	0.007	0	29.2	25.8	74.8	108	97	0	40	37
2015	12	7	1	5	33	0.778	-0.108	4.009	0.01	0.007	0	25.8	21.9	75.3	100	88	0	40	37
2015	12	7	1	15	33	0.741	-0.112	4.006	0.01	0.007	0	23.6	19.8	74.8	94	83	0	39	37
2015	12	7	1	25	33	0.738	-0.112	4.006	0.01	0.007	0	24.5	20.6	74.4	96	85	0	39	37
2015	12	7	1	35	33	0.764	-0.108	4.006	0.01	0.007	0	21.9	18.5	74.4	91	80	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	1	45	33	0.709	-0.089	4.006	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	7	1	55	33	0.755	-0.121	4.003	0.01	0.007	0	21.1	17.6	73.5	88	78	0	39	37
2015	12	7	2	5	33	0.774	-0.108	4.003	0.01	0.007	0	20.2	16.8	73.5	86	76	0	39	37
2015	12	7	2	15	33	0.778	-0.102	4.003	0.01	0.007	0	20.2	16.8	72.7	86	76	0	39	37
2015	12	7	2	25	33	0.719	-0.115	4.003	0.01	0.007	0	20.2	17.2	72.7	87	77	0	40	37
2015	12	7	2	35	33	0.755	-0.121	3.999	0.01	0.007	0	19.4	16.3	72.2	85	75	0	40	37
2015	12	7	2	45	33	0.738	-0.082	3.999	0.01	0.007	0	20.6	17.2	72.2	87	76	0	39	36
2015	12	7	2	55	33	0.745	-0.095	3.996	0.01	0.007	0	19.8	16.3	72.2	86	75	0	40	37
2015	12	7	3	5	33	0.692	-0.062	3.993	0.01	0.007	0	19.8	16.3	72.7	86	75	0	40	37
2015	12	7	3	15	33	0.748	-0.125	3.993	0.01	0.007	0	20.2	17.2	72.2	86	76	0	39	36
2015	12	7	3	25	33	0.719	-0.115	3.99	0.01	0.007	0	19.4	16.3	72.2	85	75	0	40	37
2015	12	7	3	35	33	0.719	-0.131	3.99	0.01	0.007	0	19.8	16.3	72.2	85	74	0	39	36
2015	12	7	3	45	33	0.719	-0.121	3.99	0.01	0.007	0	19.4	16.3	72.7	85	75	0	40	37
2015	12	7	3	55	33	0.745	-0.141	3.986	0.01	0.007	0	19.4	15.9	72.7	84	74	0	39	37
2015	12	7	4	5	33	0.738	-0.105	3.986	0.01	0.007	0	19.8	16.3	72.7	85	74	0	39	36
2015	12	7	4	15	33	0.715	-0.085	3.986	0.01	0.007	0	19.8	16.3	71.8	85	75	0	39	37
2015	12	7	4	25	33	0.702	-0.089	3.986	0.01	0.007	0	19.4	16.3	72.7	85	75	0	40	37
2015	12	7	4	35	33	0.715	-0.118	3.986	0.013	0.01	0	18.9	15.9	72.7	84	74	0	40	37
2015	12	7	4	45	33	0.758	-0.118	3.986	0.01	0.007	0	19.4	15.9	72.7	84	74	0	39	37
2015	12	7	4	55	33	0.778	-0.102	3.986	0.01	0.007	0	19.4	16.3	73.5	85	75	0	40	37
2015	12	7	5	5	33	0.741	-0.092	3.983	0.01	0.007	0	19.4	16.3	73.1	85	75	0	40	37
2015	12	7	5	15	33	0.738	-0.125	3.983	0.01	0.007	0	19.4	16.8	73.1	85	75	0	40	36
2015	12	7	5	25	33	0.699	-0.125	3.983	0.01	0.007	0	19.4	16.3	74	85	75	0	40	37
2015	12	7	5	35	33	0.745	-0.115	3.983	0.01	0.007	0	19.8	15.9	73.5	85	74	0	39	37
2015	12	7	5	45	33	0.745	-0.131	3.983	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	7	5	55	33	0.761	-0.108	3.983	0.01	0.007	0	18.9	15.9	74	84	74	0	40	37
2015	12	7	6	5	33	0.722	-0.095	3.983	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	7	6	15	33	0.722	-0.112	3.983	0.01	0.007	0	19.4	15.5	74	84	74	0	39	38
2015	12	7	6	25	33	0.738	-0.105	3.983	0.01	0.007	0	19.4	16.3	73.1	85	75	0	40	37
2015	12	7	6	35	33	0.761	-0.121	3.983	0.01	0.007	0	19.4	16.3	74	85	75	0	40	37
2015	12	7	6	45	33	0.738	-0.121	3.983	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37
2015	12	7	6	55	33	0.712	-0.098	3.983	0.01	0.007	0	20.2	16.8	74.4	86	76	0	39	37
2015	12	7	7	5	33	0.771	-0.115	3.98	0.01	0.007	0	19.8	16.3	74	86	75	0	40	37
2015	12	7	7	15	33	0.748	-0.112	3.98	0.01	0.007	0	19.8	15.9	74	85	74	0	39	37
2015	12	7	7	25	33	0.784	-0.098	3.983	0.01	0.007	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	7	7	35	33	0.735	-0.105	3.98	0.013	0.01	0	21.9	18.5	73.5	90	80	0	39	37
2015	12	7	7	45	33	0.728	-0.112	3.98	0.01	0.007	0	20.2	16.8	74	87	77	0	40	38
2015	12	7	7	55	33	0.712	-0.102	3.983	0.01	0.007	0	20.2	16.8	74.4	86	76	0	39	37
2015	12	7	8	5	33	0.705	-0.092	3.983	0.01	0.007	0	18.9	16.3	74.4	84	75	0	40	37
2015	12	7	8	15	33	0.732	-0.118	3.98	0.01	0.007	0	20.2	16.3	73.5	86	75	0	39	37
2015	12	7	8	25	33	0.689	-0.112	3.98	0.01	0.007	0	19.8	16.8	53.8	86	76	0	40	37
2015	12	7	8	35	33	0.755	-0.115	3.983	0.01	0.007	0	21.9	18.5	72.7	91	80	0	40	37
2015	12	7	8	45	33	0.738	-0.089	3.983	0.01	0.007	0	20.6	17.6	73.5	88	78	0	40	37
2015	12	7	8	55	33	0.748	-0.115	3.983	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	7	9	5	33	0.689	-0.112	3.983	0.013	0.01	0	20.2	17.2	74.4	86	76	0	39	36
2015	12	7	9	15	33	0.768	-0.112	3.983	0.01	0.007	0	20.6	17.2	74.4	87	77	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	9	25	33	0.755	-0.112	3.983	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	7	9	35	33	0.702	-0.112	3.983	0.01	0.007	0	19.4	16.8	74.8	85	76	0	40	37
2015	12	7	9	45	33	0.732	-0.102	3.983	0.01	0.007	0	19.8	16.8	74.4	86	76	0	40	37
2015	12	7	9	55	33	0.715	-0.102	3.986	0.01	0.007	0	19.4	16.8	74.8	85	75	0	40	36
2015	12	7	10	5	33	0.735	-0.115	3.986	0.01	0.007	0	19.4	16.3	74	85	75	0	40	37
2015	12	7	10	15	33	0.728	-0.079	3.986	0.01	0.007	0	18.9	15.9	74.4	84	74	0	40	37
2015	12	7	10	25	33	0.705	-0.079	3.986	0.01	0.007	0	19.8	16.3	74.4	85	75	0	39	37
2015	12	7	10	35	33	0.758	-0.102	3.986	0.01	0.007	0	19.8	15.9	74.8	85	74	0	39	37
2015	12	7	10	45	33	0.712	-0.102	3.986	0.01	0.007	0	19.4	16.8	74.8	85	75	0	40	36
2015	12	7	10	55	33	0.741	-0.112	3.986	0.01	0.007	0	19.4	15.9	74.4	84	74	0	39	37
2015	12	7	11	5	33	0.764	-0.135	3.986	0.01	0.007	0	19.8	16.3	74.4	85	75	0	39	37
2015	12	7	11	15	33	0.745	-0.141	3.986	0.01	0.007	0	19.4	16.3	74.8	85	75	0	40	37
2015	12	7	11	25	33	0.751	-0.148	3.986	0.01	0.007	0	19.8	16.3	74.4	85	75	0	39	37
2015	12	7	11	35	33	0.745	-0.125	3.986	0.01	0.007	0	19.4	15.9	74.4	85	75	0	40	38
2015	12	7	11	45	33	0.745	-0.121	3.986	0.01	0.007	0	19.8	16.8	74.4	85	75	0	39	36
2015	12	7	11	55	33	0.751	-0.164	3.986	0.013	0.01	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	7	12	5	33	0.735	-0.095	3.986	0.01	0.007	0	18.9	16.8	75.3	84	75	0	40	36
2015	12	7	12	15	33	0.725	-0.098	3.986	0.01	0.007	0	19.4	17.2	74.8	85	76	0	40	36
2015	12	7	12	25	33	0.732	-0.125	3.986	0.01	0.007	0	19.8	16.3	75.3	86	75	0	40	37
2015	12	7	12	35	33	0.748	-0.164	3.986	0.01	0.007	0	20.6	17.2	74.8	87	77	0	39	37
2015	12	7	12	45	33	0.735	-0.121	3.986	0.01	0.007	0	19.8	16.3	74.8	85	75	0	39	37
2015	12	7	12	55	33	0.715	-0.135	3.986	0.01	0.007	0	19.8	16.3	75.3	86	75	0	40	37
2015	12	7	13	5	33	0.719	-0.131	3.986	0.01	0.007	0	19.8	16.3	74.8	85	75	0	39	37
2015	12	7	13	15	33	0.709	-0.131	3.986	0.01	0.007	0	20.2	16.8	74.4	87	76	0	40	37
2015	12	7	13	25	33	0.755	-0.108	3.986	0.01	0.007	0	20.2	17.2	74.8	86	76	0	39	36
2015	12	7	13	35	33	0.732	-0.125	3.986	0.01	0.007	0	19.8	16.8	74.4	86	76	0	40	37
2015	12	7	13	45	33	0.692	-0.125	3.986	0.01	0.007	0	20.2	16.8	74.8	86	76	0	39	37
2015	12	7	13	55	33	0.709	-0.135	3.986	0.013	0.01	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	7	14	5	33	0.735	-0.112	3.983	0.01	0.007	0	19.8	17.2	74	86	76	0	40	36
2015	12	7	14	15	33	0.702	-0.138	3.983	0.01	0.007	0	20.6	17.2	56.3	87	77	0	39	37
2015	12	7	14	25	33	0.702	-0.148	3.983	0.01	0.007	0	20.6	17.6	53.3	87	77	0	39	36
2015	12	7	14	35	33	0.689	-0.089	3.983	0.01	0.007	0	20.6	17.2	50.3	88	77	0	40	37
2015	12	7	14	45	33	0.735	-0.112	3.983	0.01	0.007	0	22.4	18.9	54.6	91	81	0	39	37
2015	12	7	14	55	33	0.728	-0.115	3.983	0.01	0.007	0	22.8	19.4	62.4	92	81	0	39	36
2015	12	7	15	5	33	0.732	-0.128	3.983	0.01	0.007	0	22.8	18.9	74.4	92	81	0	39	37
2015	12	7	15	15	33	0.748	-0.128	3.983	0.01	0.007	0	24.5	21.1	64.5	97	86	0	40	37
2015	12	7	15	25	33	0.679	-0.079	3.98	0.01	0.007	0	22.4	18.5	55.5	91	80	0	39	37
2015	12	7	15	35	33	0.738	-0.098	3.983	0.01	0.007	0	24.5	21.1	75.3	96	85	0	39	36
2015	12	7	15	45	33	0.725	-0.131	3.983	0.01	0.007	0	22.4	19.4	75.7	92	81	0	40	36
2015	12	7	15	55	33	0.755	-0.138	3.983	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	7	16	5	33	0.692	-0.112	3.983	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	7	16	15	33	0.735	-0.121	3.983	0.01	0.007	0	20.6	17.6	76.1	88	77	0	40	36
2015	12	7	16	25	33	0.722	-0.108	3.983	0.013	0.01	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	7	16	35	33	0.709	-0.121	3.983	0.01	0.007	0	20.2	17.2	75.7	86	76	0	39	36
2015	12	7	16	45	33	0.705	-0.112	3.983	0.01	0.007	0	19.8	16.3	76.5	85	75	0	39	37
2015	12	7	16	55	33	0.748	-0.138	3.983	0.01	0.007	0	19.8	16.3	76.1	85	75	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	7	17	5	33	0.764	-0.125	3.983	0.01	0.007	0	19.4	15.9	76.1	85	74	0	40	37
2015	12	7	17	15	33	0.705	-0.118	3.983	0.01	0.007	0	19.8	16.3	77	85	74	0	39	36
2015	12	7	17	25	33	0.682	-0.105	3.98	0.01	0.007	0	19.8	16.3	76.5	85	74	0	39	36
2015	12	7	17	35	33	0.725	-0.131	3.983	0.01	0.007	0	19.8	16.3	76.1	85	74	0	39	36
2015	12	7	17	45	33	0.689	-0.115	3.983	0.01	0.007	0	19.4	15.9	76.1	84	74	0	39	37
2015	12	7	17	55	33	0.741	-0.135	3.98	0.01	0.007	0	18.9	16.3	76.1	84	74	0	40	36
2015	12	7	18	5	33	0.709	-0.098	3.98	0.01	0.007	0	19.4	15.9	77	84	74	0	39	37
2015	12	7	18	15	33	0.732	-0.154	3.983	0.01	0.007	0	18.9	15.9	76.5	84	74	0	40	37
2015	12	7	18	25	33	0.709	-0.112	3.98	0.01	0.007	0	19.8	15.9	76.5	85	74	0	39	37
2015	12	7	18	35	33	0.725	-0.135	3.98	0.01	0.007	0	19.4	15.9	76.1	84	73	0	39	36
2015	12	7	18	45	33	0.732	-0.102	3.98	0.01	0.007	0	19.4	15.1	76.1	84	73	0	39	38
2015	12	7	18	55	33	0.702	-0.118	3.98	0.01	0.007	0	19.4	16.3	76.5	84	74	0	39	36
2015	12	7	19	5	33	0.728	-0.148	3.98	0.01	0.007	0	18.9	15.5	77	84	73	0	40	37
2015	12	7	19	15	33	0.715	-0.112	3.98	0.013	0.01	0	18.9	15.5	77	84	73	0	40	37
2015	12	7	19	25	33	0.705	-0.135	3.98	0.01	0.007	0	19.4	15.9	77	84	74	0	39	37
2015	12	7	19	35	33	0.692	-0.128	3.98	0.01	0.007	0	19.4	15.5	68.8	85	74	0	40	38
2015	12	7	19	45	33	0.745	-0.125	3.98	0.01	0.007	0	27.1	22.8	76.5	102	90	0	39	37
2015	12	7	19	55	33	0.751	-0.157	3.98	0.01	0.007	0	22.4	18.9	77	92	81	0	40	37
2015	12	7	20	5	33	0.745	-0.121	3.98	0.01	0.007	0	23.2	19.8	77.4	94	82	0	40	36
2015	12	7	20	15	33	0.761	-0.115	3.98	0.01	0.007	0	21.5	17.6	77	89	78	0	39	37
2015	12	7	20	25	33	0.722	-0.161	3.98	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	7	20	35	33	0.715	-0.121	3.98	0.01	0.007	0	19.8	16.3	77	85	75	0	39	37
2015	12	7	20	45	33	0.722	-0.135	3.98	0.01	0.007	0	20.2	15.9	76.5	86	74	0	39	37
2015	12	7	20	55	33	0.696	-0.148	3.98	0.01	0.007	0	19.4	16.8	76.5	85	75	0	40	36
2015	12	7	21	5	33	0.725	-0.125	3.98	0.01	0.007	0	19.8	16.8	76.5	85	75	0	39	36
2015	12	7	21	15	33	0.673	-0.125	3.976	0.01	0.007	0	20.2	16.3	77	86	75	0	39	37
2015	12	7	21	25	33	0.741	-0.131	3.976	0.01	0.007	0	19.4	16.3	76.1	85	74	0	40	36
2015	12	7	21	35	33	0.709	-0.131	3.976	0.016	0.013	0	19.4	15.9	77	84	74	0	39	37
2015	12	7	21	45	33	0.764	-0.105	3.976	0.01	0.007	0	19.4	15.9	76.1	85	74	0	40	37
2015	12	7	21	55	33	0.705	-0.108	3.976	0.01	0.007	0	19.4	15.9	77	85	74	0	40	37
2015	12	7	22	5	33	0.679	-0.115	3.976	0.01	0.007	0	18.9	16.3	75.7	84	74	0	40	36
2015	12	7	22	15	33	0.758	-0.118	3.976	0.01	0.007	0	18.9	15.9	76.1	84	74	0	40	37
2015	12	7	22	25	33	0.712	-0.112	3.976	0.01	0.007	0	19.8	15.9	76.5	85	74	0	39	37
2015	12	7	22	35	33	0.748	-0.144	3.976	0.01	0.007	0	19.4	15.5	76.1	84	73	0	39	37
2015	12	7	22	45	33	0.758	-0.118	3.976	0.01	0.007	0	19.4	15.9	76.1	85	74	0	40	37
2015	12	7	22	55	33	0.741	-0.144	3.976	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	7	23	5	33	0.728	-0.121	3.976	0.01	0.007	0	19.8	15.9	76.1	85	73	0	39	36
2015	12	7	23	15	33	0.725	-0.141	3.973	0.01	0.007	0	18.9	15.9	75.7	84	74	0	40	37
2015	12	7	23	25	33	0.738	-0.118	3.973	0.013	0.01	0	18.9	15.9	75.3	84	74	0	40	37
2015	12	7	23	35	33	0.712	-0.121	3.973	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	7	23	45	33	0.745	-0.131	3.973	0.01	0.007	0	19.8	16.3	74.8	86	75	0	40	37
2015	12	7	23	55	33	0.751	-0.151	3.97	0.01	0.007	0	20.2	16.3	74	86	75	0	39	37
2015	12	8	0	5	33	0.689	-0.141	3.97	0.01	0.007	0	21.1	17.2	74	89	77	0	40	37
2015	12	8	0	15	33	0.764	-0.135	3.97	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	8	0	25	33	0.725	-0.121	3.97	0.01	0.007	0	20.2	16.3	73.1	87	75	0	40	37
2015	12	8	0	35	33	0.751	-0.115	3.97	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	0	45	33	0.705	-0.144	3.97	0.013	0.01	0	19.8	15.9	74.4	85	74	0	39	37
2015	12	8	0	55	33	0.751	-0.131	3.967	0.01	0.007	0	19.8	15.9	73.5	85	74	0	39	37
2015	12	8	1	5	33	0.728	-0.115	3.967	0.01	0.007	0	28.8	25.4	73.1	107	96	0	40	37
2015	12	8	1	15	33	0.761	-0.131	3.967	0.01	0.007	0	31	27.1	72.7	112	100	0	40	37
2015	12	8	1	25	33	0.755	-0.115	3.967	0.013	0.01	0	23.6	19.8	73.1	94	83	0	39	37
2015	12	8	1	35	33	0.751	-0.157	3.963	0.01	0.007	0	22.4	18.9	72.7	92	80	0	40	36
2015	12	8	1	45	33	0.738	-0.131	3.96	0.01	0.007	0	21.5	17.6	72.7	90	78	0	40	37
2015	12	8	1	55	33	0.728	-0.135	3.957	0.01	0.007	0	21.1	17.2	72.7	88	77	0	39	37
2015	12	8	2	5	33	0.699	-0.138	3.957	0.013	0.01	0	20.6	17.6	72.2	88	77	0	40	36
2015	12	8	2	15	33	0.715	-0.151	3.953	0.01	0.007	0	20.2	16.8	67.1	87	77	0	40	38
2015	12	8	2	25	33	0.699	-0.105	3.953	0.01	0.007	0	20.2	16.8	72.7	87	76	0	40	37
2015	12	8	2	35	33	0.755	-0.141	3.953	0.01	0.007	0	21.9	18.1	73.1	90	79	0	39	37
2015	12	8	2	45	33	0.715	-0.161	3.953	0.01	0.007	0	20.2	16.3	73.1	87	76	0	40	38
2015	12	8	2	55	33	0.761	-0.164	3.953	0.01	0.007	0	20.2	16.8	74	86	76	0	39	37
2015	12	8	3	5	33	0.702	-0.135	3.95	0.01	0.007	0	20.2	16.8	61.9	86	75	0	39	36
2015	12	8	3	15	33	0.781	-0.141	3.95	0.01	0.007	0	19.8	15.9	73.5	85	74	0	39	37
2015	12	8	3	25	33	0.745	-0.125	3.95	0.01	0.007	0	20.2	16.3	69.7	86	75	0	39	37
2015	12	8	3	35	33	0.748	-0.102	3.947	0.01	0.007	0	19.4	15.9	73.5	85	74	0	40	37
2015	12	8	3	45	33	0.725	-0.135	3.947	0.01	0.007	0	18.9	15.9	74	84	74	0	40	37
2015	12	8	3	55	33	0.732	-0.118	3.947	0.01	0.007	0	19.4	16.3	74	85	74	0	40	36
2015	12	8	4	5	33	0.689	-0.118	3.947	0.01	0.007	0	19.8	15.5	74.8	85	73	0	39	37
2015	12	8	4	15	33	0.689	-0.098	3.947	0.01	0.007	0	19.4	16.3	74.4	85	75	0	40	37
2015	12	8	4	25	33	0.709	-0.105	3.947	0.01	0.007	0	19.4	15.5	74.4	84	73	0	39	37
2015	12	8	4	35	33	0.699	-0.121	3.947	0.01	0.007	0	18.9	16.3	74.4	84	74	0	40	36
2015	12	8	4	45	33	0.705	-0.082	3.944	0.01	0.007	0	18.9	15.5	74.8	83	73	0	39	37
2015	12	8	4	55	33	0.692	-0.112	3.944	0.01	0.007	0	18.9	15.9	74.8	84	74	0	40	37
2015	12	8	5	5	33	0.735	-0.141	3.944	0.01	0.007	0	19.4	15.9	75.7	85	74	0	40	37
2015	12	8	5	15	33	0.692	-0.121	3.944	0.01	0.007	0	19.4	15.9	75.7	84	73	0	39	36
2015	12	8	5	25	33	0.659	-0.112	3.94	0.01	0.007	0	19.4	15.5	75.7	84	73	0	39	37
2015	12	8	5	35	33	0.728	-0.121	3.94	0.01	0.007	0	18.5	15.5	76.1	83	73	0	40	37
2015	12	8	5	45	33	0.676	-0.138	3.94	0.01	0.007	0	18.5	15.9	75.7	83	73	0	40	36
2015	12	8	5	55	33	0.722	-0.112	3.94	0.01	0.007	0	19.4	15.9	76.1	84	73	0	39	36
2015	12	8	6	5	33	0.722	-0.121	3.94	0.01	0.007	0	18.9	15.1	76.1	83	73	0	39	38
2015	12	8	6	15	33	0.689	-0.115	3.937	0.01	0.007	0	18.9	15.5	76.5	84	73	0	40	37
2015	12	8	6	25	33	0.702	-0.141	3.937	0.01	0.007	0	18.9	15.5	75.7	83	73	0	39	37
2015	12	8	6	35	33	0.666	-0.092	3.937	0.01	0.007	0	18.9	16.3	77	84	74	0	40	36
2015	12	8	6	45	33	0.709	-0.112	3.937	0.01	0.007	0	19.8	15.9	76.5	85	74	0	39	37
2015	12	8	6	55	33	0.702	-0.121	3.937	0.01	0.007	0	18.9	15.9	76.5	84	74	0	40	37
2015	12	8	7	5	33	0.676	-0.125	3.937	0.01	0.007	0	19.4	16.8	76.5	85	75	0	40	36
2015	12	8	7	15	33	0.719	-0.131	3.934	0.01	0.007	0	19.4	15.9	76.5	85	74	0	40	37
2015	12	8	7	25	33	0.682	-0.095	3.934	0.01	0.007	0	18.9	15.9	76.1	84	74	0	40	37
2015	12	8	7	35	33	0.719	-0.115	3.934	0.01	0.007	0	18.9	15.9	75.3	84	74	0	40	37
2015	12	8	7	45	33	0.689	-0.115	3.934	0.01	0.007	0	19.4	15.5	74.4	84	73	0	39	37
2015	12	8	7	55	33	0.712	-0.089	3.93	0.01	0.007	0	18.9	15.1	74	83	73	0	39	38
2015	12	8	8	5	33	0.673	-0.121	3.93	0.01	0.007	0	18.9	15.5	74.4	84	73	0	40	37
2015	12	8	8	15	33	0.676	-0.135	3.93	0.01	0.007	0	19.4	15.5	73.1	84	73	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	8	25	33	0.663	-0.141	3.93	0.01	0.007	0	18.9	15.9	72.7	84	74	0	40	37
2015	12	8	8	35	33	0.686	-0.118	3.924	0.01	0.007	0	19.4	15.5	72.2	84	73	0	39	37
2015	12	8	8	45	33	0.686	-0.112	3.924	0.01	0.007	0	19.8	15.9	70.5	85	74	0	39	37
2015	12	8	8	55	33	0.666	-0.089	3.917	0.01	0.007	0	18.9	15.5	72.2	84	73	0	40	37
2015	12	8	9	5	33	0.692	-0.095	3.917	0.01	0.007	0	19.4	15.5	72.7	84	73	0	39	37
2015	12	8	9	15	33	0.659	-0.135	3.917	0.01	0.007	0	18.9	15.9	73.1	84	73	0	40	36
2015	12	8	9	25	33	0.689	-0.131	3.914	0.013	0.01	0	19.4	15.9	73.1	84	74	0	39	37
2015	12	8	9	35	33	0.705	-0.098	3.917	0.01	0.007	0	18.5	15.9	73.5	83	74	0	40	37
2015	12	8	9	45	33	0.686	-0.092	3.914	0.01	0.007	0	18.9	15.9	74	84	74	0	40	37
2015	12	8	9	55	33	0.679	-0.089	3.914	0.01	0.007	0	19.4	16.3	74.8	84	74	0	39	36
2015	12	8	10	5	33	0.682	-0.105	3.914	0.01	0.007	0	19.4	15.9	74	84	74	0	39	37
2015	12	8	10	15	33	0.692	-0.108	3.911	0.01	0.007	0	18.9	15.9	62.8	84	74	0	40	37
2015	12	8	10	25	33	0.699	-0.131	3.914	0.013	0.01	0	18.9	15.5	72.2	83	73	0	39	37
2015	12	8	10	35	33	0.682	-0.089	3.911	0.01	0.007	0	19.4	15.5	62.4	84	74	0	39	38
2015	12	8	10	45	33	0.696	-0.098	3.911	0.01	0.007	0	19.4	15.9	69.7	84	74	0	39	37
2015	12	8	10	55	33	0.669	-0.095	3.911	0.01	0.007	0	18.9	15.9	68.8	84	74	0	40	37
2015	12	8	11	5	33	0.659	-0.118	3.911	0.01	0.007	0	19.4	16.3	75.3	84	74	0	39	36
2015	12	8	11	15	33	0.686	-0.092	3.911	0.01	0.007	0	20.2	17.2	76.1	87	76	0	40	36
2015	12	8	11	25	33	0.712	-0.112	3.911	0.01	0.007	0	23.2	19.8	76.1	93	82	0	39	36
2015	12	8	11	35	33	0.745	-0.079	3.911	0.013	0.01	0	21.9	18.5	74.8	90	80	0	39	37
2015	12	8	11	45	33	0.65	-0.092	3.911	0.01	0.007	0	21.9	18.1	76.1	90	79	0	39	37
2015	12	8	11	55	33	0.682	-0.121	3.907	0.01	0.007	0	20.2	17.2	76.1	87	76	0	40	36
2015	12	8	12	5	33	0.682	-0.095	3.907	0.01	0.007	0	19.8	16.8	76.5	85	75	0	39	36
2015	12	8	12	15	33	0.659	-0.108	3.904	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	8	12	25	33	0.669	-0.089	3.904	0.01	0.007	0	19.4	15.9	74.4	85	74	0	40	37
2015	12	8	12	35	33	0.755	-0.135	3.901	0.01	0.007	0	20.2	16.3	68.8	86	75	0	39	37
2015	12	8	12	45	33	0.689	-0.115	3.901	0.01	0.007	0	19.8	16.8	74	86	76	0	40	37
2015	12	8	12	55	33	0.696	-0.148	3.898	0.01	0.007	0	20.2	16.3	72.7	86	75	0	39	37
2015	12	8	13	5	33	0.719	-0.115	3.898	0.01	0.007	0	19.8	17.2	71.8	86	76	0	40	36
2015	12	8	13	15	33	0.702	-0.144	3.898	0.01	0.007	0	20.2	16.8	72.7	87	76	0	40	37
2015	12	8	13	25	33	0.699	-0.112	3.891	0.01	0.007	0	19.8	16.3	72.7	86	75	0	40	37
2015	12	8	13	35	33	0.696	-0.135	3.888	0.01	0.007	0	19.4	16.8	73.1	85	75	0	40	36
2015	12	8	13	45	33	0.682	-0.164	3.885	0.01	0.007	0	20.2	16.8	72.7	86	75	0	39	36
2015	12	8	13	55	33	0.725	-0.141	3.885	0.01	0.007	0	19.8	16.8	73.5	86	76	0	40	37
2015	12	8	14	5	33	0.709	-0.138	3.885	0.01	0.007	0	19.4	16.3	74.4	85	75	0	40	37
2015	12	8	14	15	33	0.656	-0.118	3.881	0.01	0.007	0	20.6	16.8	73.5	87	76	0	39	37
2015	12	8	14	25	33	0.728	-0.154	3.881	0.01	0.007	0	21.9	19.4	74.8	91	81	0	40	36
2015	12	8	14	35	33	0.696	-0.135	3.878	0.01	0.007	0	25.8	22.4	74.4	100	89	0	40	37
2015	12	8	14	45	33	0.702	-0.148	3.878	0.013	0.01	0	22.8	19.4	74.8	93	82	0	40	37
2015	12	8	14	55	33	0.696	-0.125	3.878	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	8	15	5	33	0.673	-0.131	3.878	0.013	0.01	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	8	15	15	33	0.65	-0.128	3.878	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	8	15	25	33	0.699	-0.131	3.875	0.01	0.007	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	8	15	35	33	0.689	-0.151	3.875	0.01	0.007	0	20.6	16.8	76.5	87	76	0	39	37
2015	12	8	15	45	33	0.666	-0.138	3.875	0.016	0.013	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	8	15	55	33	0.705	-0.131	3.875	0.013	0.01	0	20.2	17.2	76.5	86	75	0	39	35

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	16	5	33	0.676	-0.108	3.871	0.01	0.007	0	19.8	15.9	76.5	85	74	0	39	37
2015	12	8	16	15	33	0.653	-0.148	3.871	0.01	0.007	0	20.2	15.9	77	86	74	0	39	37
2015	12	8	16	25	33	0.692	-0.135	3.871	0.01	0.007	0	19.4	16.3	77.4	85	74	0	40	36
2015	12	8	16	35	33	0.656	-0.102	3.871	0.01	0.007	0	19.4	16.8	76.5	85	75	0	40	36
2015	12	8	16	45	33	0.666	-0.118	3.871	0.01	0.007	0	20.2	16.8	77.4	86	75	0	39	36
2015	12	8	16	55	33	0.679	-0.121	3.868	0.01	0.007	0	19.4	15.9	76.5	85	74	0	40	37
2015	12	8	17	5	33	0.676	-0.135	3.868	0.013	0.01	0	19.8	16.3	77	85	74	0	39	36
2015	12	8	17	15	33	0.669	-0.128	3.868	0.01	0.007	0	19.8	15.9	76.5	85	74	0	39	37
2015	12	8	17	25	33	0.669	-0.125	3.868	0.01	0.007	0	20.2	16.3	76.1	86	75	0	39	37
2015	12	8	17	35	33	0.673	-0.089	3.868	0.01	0.007	0	20.2	16.8	76.1	86	75	0	39	36
2015	12	8	17	45	33	0.659	-0.125	3.865	0.013	0.01	0	20.2	16.3	75.7	86	75	0	39	37
2015	12	8	17	55	33	0.696	-0.118	3.865	0.01	0.007	0	19.8	16.3	71.4	86	75	0	40	37
2015	12	8	18	5	33	0.755	-0.148	3.865	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	8	18	15	33	0.659	-0.102	3.865	0.01	0.007	0	20.2	16.8	74	86	75	0	39	36
2015	12	8	18	25	33	0.689	-0.105	3.862	0.01	0.007	0	19.4	15.9	73.1	85	74	0	40	37
2015	12	8	18	35	33	0.676	-0.125	3.862	0.01	0.007	0	20.2	16.3	73.5	86	75	0	39	37
2015	12	8	18	45	33	0.682	-0.098	3.858	0.01	0.007	0	19.8	16.3	73.1	85	75	0	39	37
2015	12	8	18	55	33	0.689	-0.095	3.858	0.01	0.007	0	19.4	15.9	73.5	85	74	0	40	37
2015	12	8	19	5	33	0.722	-0.085	3.852	0.01	0.007	0	20.2	16.3	72.2	86	75	0	39	37
2015	12	8	19	15	33	0.659	-0.138	3.852	0.01	0.007	0	20.2	16.3	73.1	86	75	0	39	37
2015	12	8	19	25	33	0.705	-0.075	3.848	0.01	0.007	0	19.8	16.3	72.7	85	74	0	39	36
2015	12	8	19	35	33	0.679	-0.138	3.848	0.01	0.007	0	19.8	16.3	73.5	86	75	0	40	37
2015	12	8	19	45	33	0.705	-0.128	3.848	0.01	0.007	0	19.4	15.9	73.5	85	74	0	40	37
2015	12	8	19	55	33	0.709	-0.105	3.848	0.01	0.007	0	24.9	21.9	74	97	86	0	39	35
2015	12	8	20	5	33	0.692	-0.098	3.845	0.01	0.007	0	22.8	19.4	74	93	82	0	40	37
2015	12	8	20	15	33	0.666	-0.102	3.845	0.01	0.007	0	22.4	18.1	74	91	79	0	39	37
2015	12	8	20	25	33	0.715	-0.131	3.845	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	8	20	35	33	0.689	-0.121	3.845	0.01	0.007	0	20.2	16.3	74.8	86	75	0	39	37
2015	12	8	20	45	33	0.682	-0.115	3.845	0.01	0.007	0	19.4	15.9	74.8	85	74	0	40	37
2015	12	8	20	55	33	0.722	-0.128	3.842	0.01	0.007	0	20.2	16.3	75.3	86	75	0	39	37
2015	12	8	21	5	33	0.656	-0.092	3.845	0.013	0.01	0	19.8	16.8	75.3	86	75	0	40	36
2015	12	8	21	15	33	0.712	-0.125	3.842	0.01	0.007	0	19.8	16.3	75.7	85	74	0	39	36
2015	12	8	21	25	33	0.686	-0.144	3.842	0.01	0.007	0	19.4	15.9	75.7	85	74	0	40	37
2015	12	8	21	35	33	0.656	-0.092	3.842	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	8	21	45	33	0.666	-0.135	3.842	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	8	21	55	33	0.659	-0.108	3.842	0.01	0.007	0	19.8	15.9	74.8	85	74	0	39	37
2015	12	8	22	5	33	0.676	-0.102	3.839	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	8	22	15	33	0.686	-0.138	3.842	0.01	0.007	0	19.8	16.3	76.1	85	74	0	39	36
2015	12	8	22	25	33	0.666	-0.138	3.839	0.01	0.007	0	19.8	16.3	75.7	85	75	0	39	37
2015	12	8	22	35	33	0.689	-0.121	3.839	0.01	0.007	0	19.8	16.8	75.7	85	75	0	39	36
2015	12	8	22	45	33	0.659	-0.098	3.839	0.01	0.007	0	20.2	16.3	74.8	86	75	0	39	37
2015	12	8	22	55	33	0.722	-0.128	3.839	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	8	23	5	33	0.666	-0.138	3.839	0.01	0.007	0	19.8	15.9	77.4	86	74	0	40	37
2015	12	8	23	15	33	0.679	-0.131	3.839	0.01	0.007	0	19.8	15.9	77.4	86	74	0	40	37
2015	12	8	23	25	33	0.709	-0.112	3.839	0.01	0.007	0	19.8	16.3	77	86	75	0	40	37
2015	12	8	23	35	33	0.682	-0.115	3.839	0.01	0.007	0	21.9	18.5	77	91	80	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	8	23	45	33	0.692	-0.138	3.835	0.01	0.007	0	20.2	16.8	77.4	87	76	0	40	37
2015	12	8	23	55	33	0.679	-0.131	3.839	0.01	0.007	0	21.1	18.1	77.4	89	78	0	40	36
2015	12	9	0	5	33	0.728	-0.157	3.835	0.01	0.007	0	21.9	18.1	76.1	90	79	0	39	37
2015	12	9	0	15	33	0.676	-0.115	3.835	0.01	0.007	0	20.6	16.8	77.4	87	76	0	39	37
2015	12	9	0	25	33	0.715	-0.098	3.835	0.01	0.007	0	19.8	15.9	77.8	86	75	0	40	38
2015	12	9	0	35	33	0.755	-0.128	3.835	0.01	0.007	0	29.2	25.4	74.8	108	95	0	40	36
2015	12	9	0	45	33	0.715	-0.098	3.835	0.013	0.01	0	28	23.2	77	104	91	0	39	37
2015	12	9	0	55	33	0.728	-0.135	3.835	0.01	0.007	0	24.1	19.8	78.3	95	83	0	39	37
2015	12	9	1	5	33	0.719	-0.112	3.835	0.01	0.007	0	21.1	18.1	78.3	89	78	0	40	36
2015	12	9	1	15	33	0.676	-0.138	3.835	0.01	0.007	0	21.9	18.1	78.3	90	79	0	39	37
2015	12	9	1	25	33	0.702	-0.098	3.835	0.01	0.007	0	21.1	17.2	78.7	88	77	0	39	37
2015	12	9	1	35	33	0.656	-0.102	3.832	0.01	0.007	0	20.6	16.8	77.8	87	76	0	39	37
2015	12	9	1	45	33	0.702	-0.144	3.832	0.013	0.01	0	19.8	16.3	63.2	86	75	0	40	37
2015	12	9	1	55	33	0.719	-0.135	3.832	0.01	0.007	0	19.8	16.3	78.3	86	75	0	40	37
2015	12	9	2	5	33	0.682	-0.108	3.832	0.01	0.007	0	19.8	16.8	78.3	85	75	0	39	36
2015	12	9	2	15	33	0.656	-0.125	3.832	0.01	0.007	0	20.2	16.3	77.8	86	75	0	39	37
2015	12	9	2	25	33	0.692	-0.112	3.832	0.01	0.007	0	19.8	16.3	77.4	86	75	0	40	37
2015	12	9	2	35	33	0.686	-0.112	3.832	0.01	0.007	0	19.8	15.9	77.4	85	74	0	39	37
2015	12	9	2	45	33	0.666	-0.092	3.832	0.01	0.007	0	19.4	15.9	77.4	85	74	0	40	37
2015	12	9	2	55	33	0.686	-0.118	3.832	0.01	0.007	0	19.4	15.9	77	85	74	0	40	37
2015	12	9	3	5	33	0.686	-0.118	3.829	0.01	0.007	0	19.8	16.3	77.4	85	75	0	39	37
2015	12	9	3	15	33	0.669	-0.121	3.832	0.01	0.007	0	19.8	15.9	77.8	85	74	0	39	37
2015	12	9	3	25	33	0.682	-0.125	3.829	0.01	0.007	0	19.8	15.9	77.4	85	74	0	39	37
2015	12	9	3	35	33	0.692	-0.125	3.829	0.01	0.007	0	19.8	16.3	77.8	85	74	0	39	36
2015	12	9	3	45	33	0.663	-0.112	3.829	0.01	0.007	0	19.8	15.9	77.4	85	74	0	39	37
2015	12	9	3	55	33	0.663	-0.121	3.829	0.01	0.007	0	19.4	15.9	77.4	84	74	0	39	37
2015	12	9	4	5	33	0.709	-0.115	3.829	0.01	0.007	0	19.4	16.3	76.5	85	74	0	40	36
2015	12	9	4	15	33	0.715	-0.089	3.829	0.01	0.007	0	18.9	15.9	75.3	84	74	0	40	37
2015	12	9	4	25	33	0.679	-0.098	3.829	0.01	0.007	0	19.8	16.3	75.3	85	75	0	39	37
2015	12	9	4	35	33	0.699	-0.085	3.825	0.01	0.007	0	18.9	15.9	76.1	84	74	0	40	37
2015	12	9	4	45	33	0.689	-0.121	3.825	0.01	0.007	0	18.9	15.9	75.7	84	74	0	40	37
2015	12	9	4	55	33	0.682	-0.151	3.825	0.01	0.007	0	19.4	15.9	75.7	85	74	0	40	37
2015	12	9	5	5	33	0.732	-0.108	3.825	0.01	0.007	0	19.4	15.9	75.7	85	74	0	40	37
2015	12	9	5	15	33	0.696	-0.138	3.825	0.01	0.007	0	19.8	15.9	75.7	85	74	0	39	37
2015	12	9	5	25	33	0.715	-0.118	3.825	0.01	0.007	0	18.9	16.3	74	84	74	0	40	36
2015	12	9	5	35	33	0.669	-0.125	3.825	0.01	0.007	0	18.9	15.5	74.4	84	73	0	40	37
2015	12	9	5	45	33	0.715	-0.121	3.822	0.01	0.007	0	19.4	15.9	75.3	85	74	0	40	37
2015	12	9	5	55	33	0.715	-0.131	3.822	0.01	0.007	0	18.9	15.9	74.8	84	74	0	40	37
2015	12	9	6	5	33	0.689	-0.138	3.822	0.013	0.01	0	19.8	15.9	74.8	85	74	0	39	37
2015	12	9	6	15	33	0.732	-0.125	3.822	0.01	0.007	0	19.4	15.9	74.4	84	74	0	39	37
2015	12	9	6	25	33	0.705	-0.112	3.822	0.01	0.007	0	18.9	15.9	74.4	84	74	0	40	37
2015	12	9	6	35	33	0.705	-0.154	3.822	0.013	0.01	0	19.4	15.9	74	85	74	0	40	37
2015	12	9	6	45	33	0.696	-0.144	3.822	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37
2015	12	9	6	55	33	0.692	-0.115	3.819	0.01	0.007	0	18.9	15.9	73.5	84	74	0	40	37
2015	12	9	7	5	33	0.715	-0.115	3.819	0.016	0.013	0	19.4	15.9	73.5	85	74	0	40	37
2015	12	9	7	15	33	0.696	-0.128	3.819	0.01	0.007	0	19.4	15.9	74.4	85	74	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	7	25	33	0.682	-0.131	3.819	0.01	0.007	0	19.4	16.3	74.4	85	75	0	40	37
2015	12	9	7	35	33	0.705	-0.135	3.819	0.01	0.007	0	18.9	16.3	73.1	84	74	0	40	36
2015	12	9	7	45	33	0.696	-0.128	3.816	0.01	0.007	0	19.8	15.9	73.1	85	74	0	39	37
2015	12	9	7	55	33	0.696	-0.154	3.812	0.01	0.007	0	19.8	16.3	72.7	85	74	0	39	36
2015	12	9	8	5	33	0.692	-0.138	3.812	0.01	0.007	0	19.4	15.5	73.1	85	74	0	40	38
2015	12	9	8	15	33	0.751	-0.125	3.809	0.01	0.007	0	19.4	15.9	73.1	85	74	0	40	37
2015	12	9	8	25	33	0.715	-0.115	3.809	0.01	0.007	0	19.8	15.9	73.5	85	74	0	39	37
2015	12	9	8	35	33	0.719	-0.125	3.809	0.01	0.007	0	19.8	16.3	73.5	85	75	0	39	37
2015	12	9	8	45	33	0.692	-0.135	3.809	0.01	0.007	0	19.4	15.9	74	84	74	0	39	37
2015	12	9	8	55	33	0.676	-0.135	3.809	0.01	0.007	0	20.2	16.3	73.5	86	75	0	39	37
2015	12	9	9	5	33	0.732	-0.115	3.809	0.01	0.007	0	19.8	16.3	74	85	75	0	39	37
2015	12	9	9	15	33	0.699	-0.115	3.809	0.01	0.007	0	18.9	16.3	74.4	84	75	0	40	37
2015	12	9	9	25	33	0.689	-0.115	3.809	0.01	0.007	0	19.4	16.8	74.8	85	75	0	40	36
2015	12	9	9	35	33	0.676	-0.138	3.809	0.01	0.007	0	19.4	16.3	74.8	85	74	0	40	36
2015	12	9	9	45	33	0.709	-0.115	3.809	0.016	0.013	0	19.8	16.3	74.8	85	75	0	39	37
2015	12	9	9	55	33	0.663	-0.131	3.809	0.01	0.007	0	19.8	16.3	74.8	85	75	0	39	37
2015	12	9	10	5	33	0.682	-0.125	3.809	0.01	0.007	0	19.4	15.9	74.8	85	74	0	40	37
2015	12	9	10	15	33	0.689	-0.112	3.809	0.013	0.01	0	19.8	16.3	75.3	85	74	0	39	36
2015	12	9	10	25	33	0.679	-0.131	3.809	0.01	0.007	0	19.4	16.3	76.1	84	75	0	39	37
2015	12	9	10	35	33	0.699	-0.108	3.809	0.01	0.007	0	19.8	16.8	76.1	85	75	0	39	36
2015	12	9	10	45	33	0.682	-0.128	3.809	0.01	0.007	0	19.4	16.3	75.7	85	75	0	40	37
2015	12	9	10	55	33	0.705	-0.098	3.809	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	9	11	5	33	0.659	-0.112	3.809	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	9	11	15	33	0.692	-0.089	3.809	0.01	0.007	0	20.2	17.2	76.1	86	77	0	39	37
2015	12	9	11	25	33	0.669	-0.115	3.809	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	9	11	35	33	0.699	-0.102	3.806	0.01	0.007	0	19.8	16.8	76.1	85	76	0	39	37
2015	12	9	11	45	33	0.699	-0.138	3.809	0.01	0.007	0	21.5	18.5	76.1	90	79	0	40	36
2015	12	9	11	55	33	0.709	-0.121	3.806	0.01	0.007	0	20.6	17.6	77	87	77	0	39	36
2015	12	9	12	5	33	0.673	-0.128	3.806	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	9	12	15	33	0.702	-0.125	3.806	0.01	0.007	0	20.2	17.6	77.4	87	78	0	40	37
2015	12	9	12	25	33	0.735	-0.102	3.806	0.01	0.007	0	20.2	16.8	77	86	76	0	39	37
2015	12	9	12	35	33	0.682	-0.092	3.806	0.01	0.007	0	19.8	17.2	73.5	86	77	0	40	37
2015	12	9	12	45	33	0.663	-0.131	3.806	0.013	0.01	0	21.1	17.6	77	87	77	0	38	36
2015	12	9	12	55	33	0.659	-0.125	3.806	0.01	0.007	0	21.1	17.6	66.7	88	78	0	39	37
2015	12	9	13	5	33	0.679	-0.105	3.806	0.013	0.01	0	20.2	17.6	61.5	87	77	0	40	36
2015	12	9	13	15	33	0.676	-0.121	3.806	0.01	0.007	0	20.2	17.2	77	87	77	0	40	37
2015	12	9	13	25	33	0.712	-0.098	3.806	0.01	0.007	0	20.6	17.6	77.4	87	77	0	39	36
2015	12	9	13	35	33	0.682	-0.112	3.806	0.01	0.007	0	20.2	17.6	72.7	87	77	0	40	36
2015	12	9	13	45	33	0.636	-0.138	3.802	0.01	0.007	0	21.1	17.6	59.3	88	78	0	39	37
2015	12	9	13	55	33	0.673	-0.102	3.802	0.01	0.007	0	21.1	18.1	58.5	88	78	0	39	36
2015	12	9	14	5	33	0.686	-0.157	3.802	0.01	0.007	0	20.6	18.1	66.2	88	78	0	40	36
2015	12	9	14	15	33	0.656	-0.118	3.802	0.01	0.007	0	21.1	17.6	64.5	88	78	0	39	37
2015	12	9	14	25	33	0.666	-0.115	3.799	0.01	0.007	0	21.1	17.2	59.3	88	77	0	39	37
2015	12	9	14	35	33	0.64	-0.098	3.799	0.01	0.007	0	21.1	17.6	66.7	88	77	0	39	36
2015	12	9	14	45	33	0.65	-0.121	3.799	0.01	0.007	0	21.1	18.1	52.9	88	78	0	39	36
2015	12	9	14	55	33	0.656	-0.125	3.796	0.01	0.007	0	21.1	18.1	51.2	88	78	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	15	5	33	0.663	-0.102	3.796	0.01	0.007	0	21.1	17.2	52.5	88	77	0	39	37
2015	12	9	15	15	33	0.699	-0.115	3.796	0.013	0.01	0	20.6	17.6	55.5	87	77	0	39	36
2015	12	9	15	25	33	0.686	-0.112	3.796	0.01	0.007	0	20.2	16.8	52.9	87	76	0	40	37
2015	12	9	15	35	33	0.679	-0.125	3.796	0.01	0.007	0	20.2	16.8	56.3	87	76	0	40	37
2015	12	9	15	45	33	0.676	-0.125	3.796	0.013	0.01	0	20.6	17.2	74.8	87	77	0	39	37
2015	12	9	15	55	33	0.663	-0.105	3.796	0.01	0.007	0	21.5	18.9	76.1	90	80	0	40	36
2015	12	9	16	5	33	0.715	-0.105	3.796	0.01	0.007	0	21.1	17.2	75.3	88	77	0	39	37
2015	12	9	16	15	33	0.732	-0.105	3.793	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	9	16	25	33	0.663	-0.089	3.793	0.01	0.007	0	21.5	18.1	74.8	89	79	0	39	37
2015	12	9	16	35	33	0.663	-0.089	3.793	0.01	0.007	0	20.2	17.2	74.8	87	77	0	40	37
2015	12	9	16	45	33	0.689	-0.112	3.793	0.01	0.007	0	20.6	17.2	74	87	76	0	39	36
2015	12	9	16	55	33	0.692	-0.098	3.793	0.01	0.007	0	20.2	16.8	74	86	75	0	39	36
2015	12	9	17	5	33	0.646	-0.118	3.793	0.01	0.007	0	19.8	16.3	74.4	86	75	0	40	37
2015	12	9	17	15	33	0.669	-0.102	3.789	0.013	0.01	0	20.2	16.8	74	86	76	0	39	37
2015	12	9	17	25	33	0.673	-0.098	3.786	0.01	0.007	0	20.2	16.8	72.7	86	76	0	39	37
2015	12	9	17	35	33	0.699	-0.098	3.786	0.01	0.007	0	20.6	17.6	73.1	87	77	0	39	36
2015	12	9	17	45	33	0.689	-0.121	3.783	0.01	0.007	0	19.8	17.2	74	86	76	0	40	36
2015	12	9	17	55	33	0.699	-0.105	3.783	0.01	0.007	0	20.6	17.6	74.4	87	77	0	39	36
2015	12	9	18	5	33	0.689	-0.075	3.783	0.01	0.007	0	20.2	16.8	74	86	76	0	39	37
2015	12	9	18	15	33	0.712	-0.125	3.78	0.01	0.007	0	20.2	16.8	74	86	76	0	39	37
2015	12	9	18	25	33	0.669	-0.079	3.78	0.01	0.007	0	20.2	17.2	74.4	87	76	0	40	36
2015	12	9	18	35	33	0.679	-0.112	3.78	0.01	0.007	0	20.6	17.2	58.9	87	77	0	39	37
2015	12	9	18	45	33	0.745	-0.144	3.78	0.01	0.007	0	21.9	18.9	74	91	81	0	40	37
2015	12	9	18	55	33	0.755	-0.135	3.78	0.01	0.007	0	22.8	18.9	74.4	92	81	0	39	37
2015	12	9	19	5	33	0.699	-0.102	3.78	0.01	0.007	0	21.1	17.6	74.8	88	78	0	39	37
2015	12	9	19	15	33	0.719	-0.092	3.78	0.01	0.007	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	9	19	25	33	0.676	-0.105	3.78	0.01	0.007	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	9	19	35	33	0.676	-0.105	3.78	0.01	0.007	0	20.6	16.8	74.8	87	76	0	39	37
2015	12	9	19	45	33	0.709	-0.108	3.78	0.01	0.007	0	21.9	18.9	74.4	90	80	0	39	36
2015	12	9	19	55	33	0.738	-0.112	3.78	0.01	0.007	0	22.8	18.9	74	92	81	0	39	37
2015	12	9	20	5	33	0.689	-0.112	3.78	0.01	0.007	0	21.1	18.1	74	88	78	0	39	36
2015	12	9	20	15	33	0.699	-0.128	3.78	0.01	0.007	0	20.2	17.2	74.8	87	77	0	40	37
2015	12	9	20	25	33	0.689	-0.125	3.78	0.01	0.007	0	20.2	17.2	74.8	87	76	0	40	36
2015	12	9	20	35	33	0.696	-0.085	3.78	0.01	0.007	0	20.2	16.8	74.8	86	76	0	39	37
2015	12	9	20	45	33	0.702	-0.112	3.78	0.013	0.01	0	20.2	16.8	74	86	76	0	39	37
2015	12	9	20	55	33	0.676	-0.115	3.78	0.01	0.007	0	20.2	16.8	72.7	86	76	0	39	37
2015	12	9	21	5	33	0.719	-0.102	3.776	0.01	0.007	0	22.8	19.8	60.2	93	83	0	40	37
2015	12	9	21	15	33	0.702	-0.092	3.78	0.01	0.007	0	22.4	19.4	74.8	92	81	0	40	36
2015	12	9	21	25	33	0.636	-0.108	3.78	0.01	0.007	0	23.2	19.8	75.3	93	82	0	39	36
2015	12	9	21	35	33	0.722	-0.105	3.78	0.013	0.01	0	29.2	25.4	75.3	107	96	0	39	37
2015	12	9	21	45	33	0.719	-0.102	3.78	0.01	0.007	0	28.8	24.5	74.8	106	94	0	39	37
2015	12	9	21	55	33	0.712	-0.131	3.776	0.01	0.007	0	28	23.6	74.8	104	92	0	39	37
2015	12	9	22	5	33	0.705	-0.085	3.78	0.013	0.01	0	24.5	20.6	74.8	96	84	0	39	36
2015	12	9	22	15	33	0.679	-0.115	3.776	0.013	0.01	0	26.2	22.4	71	100	89	0	39	37
2015	12	9	22	25	33	0.709	-0.102	3.78	0.013	0.01	0	28	24.1	74.8	105	93	0	40	37
2015	12	9	22	35	33	0.738	-0.128	3.776	0.016	0.013	0	24.1	20.6	74.8	96	85	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	9	22	45	33	0.715	-0.105	3.78	0.01	0.007	0	23.2	19.4	74.8	93	82	0	39	37
2015	12	9	22	55	33	0.722	-0.095	3.78	0.01	0.007	0	21.9	18.5	74.8	91	79	0	40	36
2015	12	9	23	5	33	0.692	-0.102	3.78	0.01	0.007	0	21.1	18.1	74.4	89	78	0	40	36
2015	12	9	23	15	33	0.682	-0.098	3.78	0.01	0.007	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	9	23	25	33	0.709	-0.115	3.776	0.01	0.007	0	21.1	17.2	74	88	77	0	39	37
2015	12	9	23	35	33	0.699	-0.105	3.78	0.013	0.01	0	22.4	18.5	74.4	92	80	0	40	37
2015	12	9	23	45	33	0.686	-0.115	3.776	0.01	0.007	0	24.9	20.2	74.4	96	84	0	38	37
2015	12	9	23	55	33	0.696	-0.112	3.776	0.01	0.007	0	23.2	19.4	74	93	82	0	39	37
2015	12	10	0	5	33	0.689	-0.095	3.776	0.013	0.01	0	21.9	18.5	73.5	90	79	0	39	36
2015	12	10	0	15	33	0.669	-0.135	3.776	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	10	0	25	33	0.702	-0.112	3.776	0.01	0.007	0	21.1	17.6	69.2	88	77	0	39	36
2015	12	10	0	35	33	0.705	-0.098	3.776	0.01	0.007	0	28	24.1	74	104	92	0	39	36
2015	12	10	0	45	33	0.676	-0.102	3.776	0.01	0.007	0	22.8	19.4	74.4	92	81	0	39	36
2015	12	10	0	55	33	0.709	-0.112	3.776	0.01	0.007	0	21.1	18.1	74.8	89	78	0	40	36
2015	12	10	1	5	33	0.725	-0.131	3.776	0.01	0.007	0	22.4	19.8	71	92	82	0	40	36
2015	12	10	1	15	33	0.686	-0.095	3.776	0.01	0.007	0	21.5	18.5	74.4	89	79	0	39	36
2015	12	10	1	25	33	0.682	-0.108	3.776	0.01	0.007	0	21.1	18.1	74	88	78	0	39	36
2015	12	10	1	35	33	0.673	-0.098	3.776	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	10	1	45	33	0.722	-0.105	3.776	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	10	1	55	33	0.682	-0.128	3.776	0.016	0.013	0	21.1	17.2	74.4	88	76	0	39	36
2015	12	10	2	5	33	0.715	-0.098	3.776	0.013	0.01	0	20.6	16.8	74.8	87	76	0	39	37
2015	12	10	2	15	33	0.709	-0.095	3.776	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	10	2	25	33	0.673	-0.115	3.776	0.01	0.007	0	20.6	16.3	74.8	87	76	0	39	38
2015	12	10	2	35	33	0.686	-0.108	3.776	0.01	0.007	0	20.2	16.8	74.4	87	76	0	40	37
2015	12	10	2	45	33	0.719	-0.108	3.776	0.01	0.007	0	20.2	17.2	74.8	87	76	0	40	36
2015	12	10	2	55	33	0.696	-0.138	3.776	0.01	0.007	0	20.6	17.2	74	88	77	0	40	37
2015	12	10	3	5	33	0.699	-0.121	3.78	0.01	0.007	0	20.6	17.2	74.4	88	77	0	40	37
2015	12	10	3	15	33	0.676	-0.089	3.776	0.01	0.007	0	20.2	17.2	74.4	87	76	0	40	36
2015	12	10	3	25	33	0.682	-0.089	3.776	0.01	0.007	0	19.8	16.8	74.4	86	76	0	40	37
2015	12	10	3	35	33	0.702	-0.128	3.776	0.01	0.007	0	20.6	17.2	74.4	87	77	0	39	37
2015	12	10	3	45	33	0.748	-0.128	3.776	0.01	0.007	0	20.6	17.2	74.8	88	77	0	40	37
2015	12	10	3	55	33	0.702	-0.138	3.776	0.01	0.007	0	20.6	17.2	73.5	88	77	0	40	37
2015	12	10	4	5	33	0.712	-0.112	3.776	0.013	0.01	0	20.2	17.2	74.4	86	76	0	39	36
2015	12	10	4	15	33	0.722	-0.128	3.776	0.01	0.007	0	21.1	17.6	74.4	88	77	0	39	36
2015	12	10	4	25	33	0.712	-0.148	3.776	0.01	0.007	0	20.6	17.2	74.4	88	76	0	40	36
2015	12	10	4	35	33	0.673	-0.125	3.776	0.01	0.007	0	20.2	17.2	72.7	87	76	0	40	36
2015	12	10	4	45	33	0.696	-0.151	3.776	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	10	4	55	33	0.709	-0.135	3.776	0.01	0.007	0	20.6	17.2	73.1	87	76	0	39	36
2015	12	10	5	5	33	0.699	-0.131	3.776	0.01	0.007	0	20.2	16.8	74.4	87	76	0	40	37
2015	12	10	5	15	33	0.696	-0.128	3.776	0.01	0.007	0	20.2	17.2	74	87	76	0	40	36
2015	12	10	5	25	33	0.709	-0.108	3.776	0.01	0.007	0	20.2	16.8	74.4	86	75	0	39	36
2015	12	10	5	35	33	0.709	-0.131	3.773	0.01	0.007	0	20.2	16.8	74.8	86	75	0	39	36
2015	12	10	5	45	33	0.699	-0.095	3.776	0.01	0.007	0	20.6	17.2	74.4	87	76	0	39	36
2015	12	10	5	55	33	0.696	-0.125	3.776	0.01	0.007	0	20.2	16.8	74.8	86	75	0	39	36
2015	12	10	6	5	33	0.699	-0.115	3.773	0.013	0.01	0	20.2	17.2	74	87	76	0	40	36
2015	12	10	6	15	33	0.666	-0.118	3.773	0.01	0.007	0	20.6	16.8	74.8	87	76	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	6	25	33	0.699	-0.125	3.773	0.01	0.007	0	20.2	17.2	74.8	86	76	0	39	36
2015	12	10	6	35	33	0.699	-0.131	3.773	0.01	0.007	0	21.5	17.2	74	89	77	0	39	37
2015	12	10	6	45	33	0.719	-0.135	3.773	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	10	6	55	33	0.705	-0.141	3.773	0.01	0.007	0	20.6	16.8	74.8	87	76	0	39	37
2015	12	10	7	5	33	0.696	-0.135	3.773	0.01	0.007	0	20.6	17.2	74.8	87	76	0	39	36
2015	12	10	7	15	33	0.709	-0.108	3.773	0.01	0.007	0	22.8	19.4	74	92	81	0	39	36
2015	12	10	7	25	33	0.705	-0.089	3.773	0.01	0.007	0	25.8	21.9	75.3	100	88	0	40	37
2015	12	10	7	35	33	0.745	-0.125	3.773	0.01	0.007	0	30.1	26.7	75.3	110	99	0	40	37
2015	12	10	7	45	33	0.702	-0.098	3.773	0.01	0.007	0	24.5	21.1	75.3	96	85	0	39	36
2015	12	10	7	55	33	0.682	-0.118	3.77	0.01	0.007	0	21.5	18.1	62.8	90	79	0	40	37
2015	12	10	8	5	33	0.696	-0.095	3.773	0.01	0.007	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	10	8	15	33	0.715	-0.115	3.773	0.01	0.007	0	20.2	16.8	75.3	87	76	0	40	37
2015	12	10	8	25	33	0.722	-0.102	3.773	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	10	8	35	33	0.709	-0.135	3.77	0.01	0.007	0	20.2	17.2	74.8	86	76	0	39	36
2015	12	10	8	45	33	0.709	-0.108	3.77	0.01	0.007	0	25.8	21.9	71	99	88	0	39	37
2015	12	10	8	55	33	0.712	-0.112	3.773	0.01	0.007	0	21.5	18.5	74.4	90	79	0	40	36
2015	12	10	9	5	33	0.686	-0.075	3.773	0.01	0.007	0	21.9	18.9	73.5	91	81	0	40	37
2015	12	10	9	15	33	0.64	-0.098	3.77	0.01	0.007	0	22.4	18.9	48.2	92	81	0	40	37
2015	12	10	9	25	33	0.728	-0.128	3.77	0.013	0.01	0	21.9	18.5	74	91	80	0	40	37
2015	12	10	9	35	33	0.659	-0.131	3.773	0.01	0.007	0	21.5	18.5	76.1	90	79	0	40	36
2015	12	10	9	45	33	0.669	-0.089	3.77	0.01	0.007	0	21.5	18.1	60.2	89	79	0	39	37
2015	12	10	9	55	33	0.673	-0.102	3.77	0.013	0.01	0	21.5	18.5	52.5	90	80	0	40	37
2015	12	10	10	5	33	0.679	-0.121	3.773	0.01	0.007	0	21.5	18.1	71.4	89	79	0	39	37
2015	12	10	10	15	33	0.676	-0.085	3.773	0.01	0.007	0	21.9	18.1	57.2	90	79	0	39	37
2015	12	10	10	25	33	0.666	-0.108	3.773	0.01	0.007	0	22.4	18.9	59.3	92	81	0	40	37
2015	12	10	10	35	33	0.725	-0.112	3.773	0.01	0.007	0	21.9	19.4	77	91	81	0	40	36
2015	12	10	10	45	33	0.705	-0.115	3.773	0.01	0.007	0	21.5	18.5	77.4	90	79	0	40	36
2015	12	10	10	55	33	0.705	-0.125	3.77	0.01	0.007	0	22.4	18.5	77	91	80	0	39	37
2015	12	10	11	5	33	0.689	-0.118	3.77	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	10	11	15	33	0.741	-0.098	3.77	0.01	0.007	0	22.4	18.9	76.1	92	81	0	40	37
2015	12	10	11	25	33	0.692	-0.108	3.77	0.01	0.007	0	22.8	18.9	75.3	92	81	0	39	37
2015	12	10	11	35	33	0.709	-0.112	3.77	0.01	0.007	0	22.4	18.9	75.3	91	80	0	39	36
2015	12	10	11	45	33	0.709	-0.108	3.77	0.01	0.007	0	22.4	19.4	77	92	81	0	40	36
2015	12	10	11	55	33	0.702	-0.118	3.766	0.013	0.01	0	23.6	19.4	58.9	94	82	0	39	37
2015	12	10	12	5	33	0.689	-0.115	3.77	0.01	0.007	0	24.1	20.6	67.9	95	84	0	39	36
2015	12	10	12	15	33	0.682	-0.125	3.77	0.01	0.007	0	24.5	20.6	71.8	96	85	0	39	37
2015	12	10	12	25	33	0.702	-0.125	3.766	0.01	0.007	0	24.9	21.5	68.4	97	86	0	39	36
2015	12	10	12	35	33	0.712	-0.102	3.766	0.01	0.007	0	24.5	20.6	72.2	96	84	0	39	36
2015	12	10	12	45	33	0.686	-0.105	3.766	0.01	0.007	0	24.1	20.6	69.2	95	84	0	39	36
2015	12	10	12	55	33	0.692	-0.082	3.766	0.01	0.007	0	23.6	20.2	77.4	94	83	0	39	36
2015	12	10	13	5	33	0.692	-0.102	3.766	0.01	0.007	0	22.8	19.4	77.8	92	82	0	39	37
2015	12	10	13	15	33	0.699	-0.125	3.766	0.01	0.007	0	22.4	19.4	60.2	92	81	0	40	36
2015	12	10	13	25	33	0.689	-0.112	3.766	0.01	0.007	0	22.8	18.9	74.4	92	81	0	39	37
2015	12	10	13	35	33	0.696	-0.105	3.763	0.01	0.007	0	22.4	18.9	63.2	91	80	0	39	36
2015	12	10	13	45	33	0.682	-0.128	3.766	0.01	0.007	0	21.9	18.9	77	91	80	0	40	36
2015	12	10	13	55	33	0.689	-0.098	3.763	0.01	0.007	0	22.8	18.9	72.2	92	81	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	14	5	33	0.676	-0.121	3.763	0.01	0.007	0	21.9	18.5	76.5	91	80	0	40	37
2015	12	10	14	15	33	0.666	-0.102	3.76	0.01	0.007	0	23.2	19.4	47.3	93	82	0	39	37
2015	12	10	14	25	33	0.702	-0.128	3.76	0.01	0.007	0	24.5	21.5	52.9	97	86	0	40	36
2015	12	10	14	35	33	0.699	-0.135	3.76	0.01	0.007	0	24.1	21.1	60.6	96	85	0	40	36
2015	12	10	14	45	33	0.673	-0.102	3.753	0.01	0.007	0	29.7	25.8	48.6	108	96	0	39	36
2015	12	10	14	55	33	0.692	-0.108	3.757	0.013	0.01	0	30.5	26.2	48.2	110	98	0	39	37
2015	12	10	15	5	33	0.709	-0.112	3.753	0.01	0.007	0	30.5	27.1	49.9	111	100	0	40	37
2015	12	10	15	15	33	0.709	-0.118	3.753	0.01	0.007	0	29.2	25.8	52	108	96	0	40	36
2015	12	10	15	25	33	0.699	-0.128	3.757	0.01	0.007	0	28	24.1	51.6	104	92	0	39	36
2015	12	10	15	35	33	0.748	-0.098	3.757	0.013	0.01	0	26.2	22.4	60.2	101	89	0	40	37
2015	12	10	15	45	33	0.686	-0.128	3.753	0.013	0.01	0	28	24.9	63.2	105	94	0	40	36
2015	12	10	15	55	33	0.656	-0.102	3.75	0.01	0.007	0	27.5	23.2	58	103	91	0	39	37
2015	12	10	16	5	33	0.715	-0.135	3.757	0.013	0.01	0	25.4	21.5	65.4	98	87	0	39	37
2015	12	10	16	15	33	0.679	-0.095	3.753	0.01	0.007	0	24.5	20.6	61.1	97	85	0	40	37
2015	12	10	16	25	33	0.682	-0.108	3.75	0.013	0.01	0	26.7	22.8	53.3	102	90	0	40	37
2015	12	10	16	35	33	0.666	-0.121	3.75	0.01	0.007	0	31	26.7	48.6	111	99	0	39	37
2015	12	10	16	45	33	0.679	-0.128	3.75	0.01	0.007	0	30.1	25.8	48.6	109	97	0	39	37
2015	12	10	16	55	33	0.705	-0.141	3.75	0.013	0.01	0	28	24.5	51.6	105	93	0	40	36
2015	12	10	17	5	33	0.712	-0.121	3.75	0.01	0.007	0	27.1	22.8	57.2	102	90	0	39	37
2015	12	10	17	15	33	0.705	-0.125	3.75	0.01	0.007	0	26.2	21.9	58.5	100	88	0	39	37
2015	12	10	17	25	33	0.669	-0.121	3.75	0.01	0.007	0	25.4	21.1	51.6	98	86	0	39	37
2015	12	10	17	35	33	0.738	-0.131	3.753	0.01	0.007	0	24.9	21.1	72.7	97	85	0	39	36
2015	12	10	17	45	33	0.666	-0.112	3.753	0.01	0.007	0	24.1	20.2	71.4	95	84	0	39	37
2015	12	10	17	55	33	0.719	-0.131	3.753	0.01	0.007	0	23.2	19.4	70.5	94	83	0	40	38
2015	12	10	18	5	33	0.705	-0.131	3.75	0.01	0.007	0	23.2	19.8	73.1	93	82	0	39	36
2015	12	10	18	15	33	0.659	-0.105	3.75	0.01	0.007	0	22.8	18.9	74.4	92	81	0	39	37
2015	12	10	18	25	33	0.663	-0.118	3.75	0.01	0.007	0	22.8	18.9	74.4	92	80	0	39	36
2015	12	10	18	35	33	0.679	-0.115	3.75	0.01	0.007	0	21.9	18.9	72.2	91	80	0	40	36
2015	12	10	18	45	33	0.676	-0.102	3.75	0.01	0.007	0	22.4	18.9	74.4	91	80	0	39	36
2015	12	10	18	55	33	0.719	-0.125	3.75	0.013	0.01	0	21.5	18.5	69.7	90	79	0	40	36
2015	12	10	19	5	33	0.689	-0.125	3.75	0.01	0.007	0	22.8	18.9	74.8	92	80	0	39	36
2015	12	10	19	15	33	0.689	-0.108	3.75	0.01	0.007	0	22.8	18.9	74	92	80	0	39	36
2015	12	10	19	25	33	0.656	-0.125	3.75	0.01	0.007	0	22.8	19.4	51.6	92	81	0	39	36
2015	12	10	19	35	33	0.656	-0.102	3.75	0.01	0.007	0	23.6	19.8	49.5	94	83	0	39	37
2015	12	10	19	45	33	0.689	-0.108	3.75	0.01	0.007	0	24.1	20.6	49.9	95	84	0	39	36
2015	12	10	19	55	33	0.669	-0.118	3.75	0.01	0.007	0	24.1	20.2	49.9	95	83	0	39	36
2015	12	10	20	5	33	0.669	-0.121	3.75	0.01	0.007	0	23.6	20.2	48.6	94	83	0	39	36
2015	12	10	20	15	33	0.705	-0.144	3.75	0.01	0.007	0	23.2	19.8	49.9	93	82	0	39	36
2015	12	10	20	25	33	0.696	-0.128	3.753	0.01	0.007	0	23.2	18.9	64.1	92	81	0	38	37
2015	12	10	20	35	33	0.679	-0.128	3.75	0.013	0.01	0	22.4	18.9	52.5	91	80	0	39	36
2015	12	10	20	45	33	0.666	-0.112	3.753	0.01	0.007	0	22.4	18.5	73.5	91	80	0	39	37
2015	12	10	20	55	33	0.682	-0.115	3.753	0.01	0.007	0	22.8	18.9	72.2	91	80	0	38	36
2015	12	10	21	5	33	0.669	-0.128	3.75	0.01	0.007	0	21.5	18.1	56.3	90	79	0	40	37
2015	12	10	21	15	33	0.669	-0.128	3.753	0.01	0.007	0	21.9	18.5	73.1	91	80	0	40	37
2015	12	10	21	25	33	0.728	-0.112	3.753	0.01	0.007	0	21.9	18.5	73.1	90	79	0	39	36
2015	12	10	21	35	33	0.686	-0.148	3.753	0.01	0.007	0	21.9	18.5	74	90	79	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	10	21	45	33	0.686	-0.151	3.753	0.013	0.01	0	22.4	18.5	63.2	91	79	0	39	36
2015	12	10	21	55	33	0.646	-0.092	3.75	0.01	0.007	0	22.8	18.5	51.6	92	80	0	39	37
2015	12	10	22	5	33	0.676	-0.102	3.753	0.01	0.007	0	23.6	19.8	60.2	94	82	0	39	36
2015	12	10	22	15	33	0.699	-0.151	3.753	0.01	0.007	0	27.1	22.8	55	102	89	0	39	36
2015	12	10	22	25	33	0.692	-0.115	3.753	0.01	0.007	0	28.8	24.5	55.9	106	94	0	39	37
2015	12	10	22	35	33	0.725	-0.128	3.753	0.01	0.007	0	29.7	25.4	63.2	108	95	0	39	36
2015	12	10	22	45	33	0.709	-0.115	3.753	0.01	0.007	0	28.4	24.5	52.9	105	93	0	39	36
2015	12	10	22	55	33	0.735	-0.098	3.753	0.013	0.01	0	27.1	23.2	61.5	102	90	0	39	36
2015	12	10	23	5	33	0.679	-0.125	3.753	0.01	0.007	0	26.2	22.4	58	100	88	0	39	36
2015	12	10	23	15	33	0.732	-0.115	3.757	0.01	0.007	0	24.9	21.5	72.7	97	86	0	39	36
2015	12	10	23	25	33	0.719	-0.118	3.757	0.01	0.007	0	24.5	20.6	73.1	96	84	0	39	36
2015	12	10	23	35	33	0.709	-0.121	3.753	0.01	0.007	0	23.2	19.8	59.3	94	83	0	40	37
2015	12	10	23	45	33	0.692	-0.131	3.757	0.01	0.007	0	24.5	20.6	65.4	97	85	0	40	37
2015	12	10	23	55	33	0.699	-0.128	3.753	0.01	0.007	0	24.5	20.2	57.6	96	84	0	39	37
2015	12	11	0	5	33	0.673	-0.102	3.753	0.01	0.007	0	24.1	20.2	56.3	95	83	0	39	36
2015	12	11	0	15	33	0.712	-0.112	3.757	0.01	0.007	0	23.6	19.8	72.2	94	82	0	39	36
2015	12	11	0	25	33	0.735	-0.115	3.757	0.013	0.01	0	23.2	19.4	72.7	93	82	0	39	37
2015	12	11	0	35	33	0.692	-0.138	3.757	0.01	0.007	0	23.2	19.8	73.5	93	82	0	39	36
2015	12	11	0	45	33	0.696	-0.128	3.757	0.01	0.007	0	22.8	18.9	72.7	93	81	0	40	37
2015	12	11	0	55	33	0.682	-0.125	3.76	0.013	0.01	0	22.8	19.4	73.5	92	81	0	39	36
2015	12	11	1	5	33	0.732	-0.092	3.76	0.01	0.007	0	22.4	18.1	74	91	79	0	39	37
2015	12	11	1	15	33	0.732	-0.128	3.76	0.01	0.007	0	22.4	18.5	69.7	91	79	0	39	36
2015	12	11	1	25	33	0.722	-0.098	3.76	0.01	0.007	0	21.9	18.1	74.4	90	78	0	39	36
2015	12	11	1	35	33	0.682	-0.135	3.76	0.01	0.007	0	21.9	17.6	74	90	78	0	39	37
2015	12	11	1	45	33	0.719	-0.125	3.763	0.01	0.007	0	26.2	22.4	74	100	88	0	39	36
2015	12	11	1	55	33	0.719	-0.121	3.76	0.01	0.007	0	22.8	18.9	70.5	92	81	0	39	37
2015	12	11	2	5	33	0.692	-0.141	3.763	0.01	0.007	0	22.4	18.5	74	91	80	0	39	37
2015	12	11	2	15	33	0.696	-0.125	3.76	0.01	0.007	0	21.9	18.1	73.5	90	78	0	39	36
2015	12	11	2	25	33	0.709	-0.102	3.76	0.01	0.007	0	22.8	19.4	71.8	92	81	0	39	36
2015	12	11	2	35	33	0.722	-0.131	3.763	0.01	0.007	0	22.4	18.1	74	91	79	0	39	37
2015	12	11	2	45	33	0.705	-0.141	3.763	0.01	0.007	0	21.9	18.1	74.4	90	78	0	39	36
2015	12	11	2	55	33	0.689	-0.118	3.763	0.01	0.007	0	21.5	18.5	74.4	90	79	0	40	36
2015	12	11	3	5	33	0.676	-0.121	3.763	0.01	0.007	0	21.5	18.1	74.4	89	78	0	39	36
2015	12	11	3	15	33	0.705	-0.089	3.763	0.01	0.007	0	21.5	18.1	74.4	89	78	0	39	36
2015	12	11	3	25	33	0.722	-0.125	3.763	0.01	0.007	0	21.5	17.6	74.4	89	77	0	39	36
2015	12	11	3	35	33	0.722	-0.148	3.763	0.01	0.007	0	21.1	17.6	74	88	77	0	39	36
2015	12	11	3	45	33	0.696	-0.108	3.766	0.01	0.007	0	21.5	17.2	74.4	89	77	0	39	37
2015	12	11	3	55	33	0.709	-0.121	3.763	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	11	4	5	33	0.686	-0.128	3.766	0.013	0.01	0	21.9	17.6	74.8	89	78	0	38	37
2015	12	11	4	15	33	0.735	-0.125	3.766	0.01	0.007	0	21.5	17.6	74.8	89	77	0	39	36
2015	12	11	4	25	33	0.696	-0.148	3.766	0.016	0.013	0	21.1	17.6	75.3	89	77	0	40	36
2015	12	11	4	35	33	0.696	-0.125	3.766	0.01	0.007	0	21.5	17.6	75.3	89	77	0	39	36
2015	12	11	4	45	33	0.722	-0.121	3.766	0.01	0.007	0	21.5	17.2	74.4	89	77	0	39	37
2015	12	11	4	55	33	0.709	-0.128	3.766	0.01	0.007	0	21.5	18.1	75.3	89	78	0	39	36
2015	12	11	5	5	33	0.696	-0.112	3.766	0.01	0.007	0	21.5	18.1	74.8	89	78	0	39	36
2015	12	11	5	15	33	0.689	-0.144	3.766	0.01	0.007	0	21.5	17.2	75.3	89	77	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	5	25	33	0.702	-0.121	3.766	0.01	0.007	0	21.5	17.2	74.8	89	77	0	39	37
2015	12	11	5	35	33	0.709	-0.118	3.766	0.01	0.007	0	21.1	17.6	75.3	88	77	0	39	36
2015	12	11	5	45	33	0.702	-0.148	3.766	0.01	0.007	0	21.1	17.6	75.3	88	77	0	39	36
2015	12	11	5	55	33	0.696	-0.125	3.766	0.01	0.007	0	21.5	17.2	75.7	89	77	0	39	37
2015	12	11	6	5	33	0.653	-0.157	3.766	0.01	0.007	0	21.5	17.2	75.7	89	77	0	39	37
2015	12	11	6	15	33	0.735	-0.151	3.766	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	11	6	25	33	0.696	-0.131	3.766	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	11	6	35	33	0.669	-0.151	3.766	0.01	0.007	0	21.5	17.2	76.1	89	77	0	39	37
2015	12	11	6	45	33	0.669	-0.131	3.766	0.013	0.01	0	21.1	17.6	75.7	88	77	0	39	36
2015	12	11	6	55	33	0.712	-0.131	3.766	0.01	0.007	0	21.5	17.2	75.3	89	77	0	39	37
2015	12	11	7	5	33	0.709	-0.154	3.763	0.01	0.007	0	20.6	17.6	73.1	88	77	0	40	36
2015	12	11	7	15	33	0.692	-0.141	3.766	0.013	0.01	0	20.6	17.2	74.4	88	77	0	40	37
2015	12	11	7	25	33	0.692	-0.141	3.763	0.01	0.007	0	21.1	17.2	73.5	88	77	0	39	37
2015	12	11	7	35	33	0.696	-0.131	3.757	0.013	0.01	0	21.5	17.6	54.2	89	77	0	39	36
2015	12	11	7	45	33	0.696	-0.102	3.76	0.01	0.007	0	21.9	18.5	54.6	90	79	0	39	36
2015	12	11	7	55	33	0.689	-0.118	3.763	0.01	0.007	0	21.9	18.9	67.9	91	80	0	40	36
2015	12	11	8	5	33	0.709	-0.128	3.76	0.01	0.007	0	22.4	18.9	62.4	91	80	0	39	36
2015	12	11	8	15	33	0.699	-0.128	3.763	0.01	0.007	0	22.4	18.5	65.4	91	80	0	39	37
2015	12	11	8	25	33	0.676	-0.128	3.766	0.01	0.007	0	25.4	21.9	73.5	98	87	0	39	36
2015	12	11	8	35	33	0.722	-0.102	3.766	0.01	0.007	0	23.2	19.4	73.5	93	81	0	39	36
2015	12	11	8	45	33	0.719	-0.141	3.766	0.013	0.01	0	21.9	18.5	74.8	90	79	0	39	36
2015	12	11	8	55	33	0.696	-0.131	3.766	0.01	0.007	0	21.5	17.6	74.4	89	77	0	39	36
2015	12	11	9	5	33	0.689	-0.118	3.766	0.013	0.01	0	21.5	17.6	74.4	89	78	0	39	37
2015	12	11	9	15	33	0.673	-0.135	3.766	0.01	0.007	0	21.5	17.6	74	89	77	0	39	36
2015	12	11	9	25	33	0.699	-0.141	3.766	0.01	0.007	0	21.5	17.2	73.1	89	77	0	39	37
2015	12	11	9	35	33	0.715	-0.118	3.766	0.01	0.007	0	23.6	19.8	74	94	82	0	39	36
2015	12	11	9	45	33	0.725	-0.128	3.766	0.01	0.007	0	21.5	18.1	73.1	89	78	0	39	36
2015	12	11	9	55	33	0.712	-0.118	3.763	0.01	0.007	0	21.1	17.6	71.4	89	78	0	40	37
2015	12	11	10	5	33	0.738	-0.148	3.763	0.01	0.007	0	28.4	24.5	74.4	106	93	0	40	36
2015	12	11	10	15	33	0.699	-0.128	3.76	0.01	0.007	0	24.5	20.6	74	96	84	0	39	36
2015	12	11	10	25	33	0.702	-0.115	3.76	0.01	0.007	0	24.1	20.2	74	95	83	0	39	36
2015	12	11	10	35	33	0.725	-0.115	3.76	0.013	0.01	0	24.1	20.2	74	95	83	0	39	36
2015	12	11	10	45	33	0.725	-0.148	3.76	0.01	0.007	0	21.5	18.1	72.7	89	78	0	39	36
2015	12	11	10	55	33	0.712	-0.128	3.76	0.01	0.007	0	20.6	18.1	74.8	88	77	0	40	35
2015	12	11	11	5	33	0.699	-0.135	3.76	0.01	0.007	0	21.1	17.6	73.1	88	77	0	39	36
2015	12	11	11	15	33	0.712	-0.138	3.76	0.01	0.007	0	20.2	17.2	75.3	87	76	0	40	36
2015	12	11	11	25	33	0.709	-0.112	3.76	0.01	0.007	0	20.6	17.6	74.4	88	77	0	40	36
2015	12	11	11	35	33	0.705	-0.102	3.76	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	11	11	45	33	0.679	-0.151	3.757	0.01	0.007	0	21.1	17.6	66.7	88	77	0	39	36
2015	12	11	11	55	33	0.659	-0.135	3.76	0.01	0.007	0	21.1	17.6	73.5	88	78	0	39	37
2015	12	11	12	5	33	0.725	-0.141	3.76	0.01	0.007	0	20.6	17.6	72.7	88	77	0	40	36
2015	12	11	12	15	33	0.709	-0.131	3.76	0.01	0.007	0	21.9	18.5	74	90	79	0	39	36
2015	12	11	12	25	33	0.663	-0.085	3.757	0.01	0.007	0	21.1	17.6	71.4	88	77	0	39	36
2015	12	11	12	35	33	0.702	-0.128	3.757	0.01	0.007	0	21.9	18.5	68.4	91	79	0	40	36
2015	12	11	12	45	33	0.663	-0.131	3.757	0.01	0.007	0	21.9	18.5	53.8	90	79	0	39	36
2015	12	11	12	55	33	0.689	-0.112	3.757	0.01	0.007	0	23.2	19.4	68.8	93	81	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	13	5	33	0.653	-0.082	3.757	0.01	0.007	0	22.4	18.9	59.8	91	80	0	39	36
2015	12	11	13	15	33	0.686	-0.066	3.753	0.01	0.007	0	22.8	18.9	51.6	91	80	0	38	36
2015	12	11	13	25	33	0.65	-0.105	3.753	0.01	0.007	0	24.1	19.8	51.6	95	83	0	39	37
2015	12	11	13	35	33	0.705	-0.075	3.753	0.01	0.007	0	23.6	20.2	52.9	94	83	0	39	36
2015	12	11	13	45	33	0.692	-0.108	3.753	0.01	0.007	0	24.1	20.2	56.8	95	83	0	39	36
2015	12	11	13	55	33	0.673	-0.105	3.753	0.01	0.007	0	23.6	20.2	51.2	94	83	0	39	36
2015	12	11	14	5	33	0.732	-0.082	3.753	0.01	0.007	0	29.2	24.9	51.2	107	94	0	39	36
2015	12	11	14	15	33	0.712	-0.102	3.753	0.01	0.007	0	29.7	25.4	49.5	108	96	0	39	37
2015	12	11	14	25	33	0.709	-0.075	3.753	0.01	0.007	0	31	27.1	49.5	111	99	0	39	36
2015	12	11	14	35	33	0.725	-0.085	3.753	0.01	0.007	0	31.8	28	47.7	113	101	0	39	36
2015	12	11	14	45	33	0.722	-0.128	3.753	0.01	0.007	0	31	27.1	49	111	99	0	39	36
2015	12	11	14	55	33	0.705	-0.039	3.753	0.013	0.01	0	31	27.1	49.9	111	99	0	39	36
2015	12	11	15	5	33	0.705	-0.092	3.753	0.013	0.01	0	29.7	25.8	49.5	108	96	0	39	36
2015	12	11	15	15	33	0.741	-0.085	3.753	0.01	0.007	0	28.4	24.1	50.3	106	93	0	40	37
2015	12	11	15	25	33	0.715	-0.115	3.75	0.01	0.007	0	28	23.6	52	104	92	0	39	37
2015	12	11	15	35	33	0.702	-0.092	3.75	0.013	0.01	0	26.7	22.8	58.9	101	89	0	39	36
2015	12	11	15	45	33	0.676	-0.118	3.75	0.01	0.007	0	26.2	21.9	51.6	99	87	0	38	36
2015	12	11	15	55	33	0.65	-0.115	3.75	0.01	0.007	0	24.9	21.1	55	97	85	0	39	36
2015	12	11	16	5	33	0.692	-0.112	3.75	0.013	0.01	0	24.1	19.8	53.8	95	83	0	39	37
2015	12	11	16	15	33	0.705	-0.102	3.747	0.013	0.01	0	23.6	19.4	51.6	94	82	0	39	37
2015	12	11	16	25	33	0.689	-0.092	3.747	0.01	0.007	0	23.6	19.8	51.6	94	82	0	39	36
2015	12	11	16	35	33	0.728	-0.102	3.75	0.01	0.007	0	23.6	19.4	51.2	94	81	0	39	36
2015	12	11	16	45	33	0.679	-0.046	3.75	0.01	0.007	0	23.2	19.4	51.6	93	81	0	39	36
2015	12	11	16	55	33	0.719	-0.121	3.747	0.01	0.007	0	23.2	19.4	54.2	93	81	0	39	36
2015	12	11	17	5	33	0.679	-0.089	3.747	0.01	0.007	0	23.2	18.9	55	93	80	0	39	36
2015	12	11	17	15	33	0.676	-0.089	3.75	0.01	0.007	0	22.8	18.9	55	92	80	0	39	36
2015	12	11	17	25	33	0.666	-0.148	3.747	0.01	0.007	0	22.8	18.9	59.8	92	80	0	39	36
2015	12	11	17	35	33	0.689	-0.095	3.75	0.013	0.01	0	22.4	18.9	60.6	91	80	0	39	36
2015	12	11	17	45	33	0.709	-0.102	3.747	0.01	0.007	0	22.4	18.1	58.9	91	79	0	39	37
2015	12	11	17	55	33	0.719	-0.128	3.75	0.01	0.007	0	22.4	18.5	62.4	91	79	0	39	36
2015	12	11	18	5	33	0.676	-0.118	3.75	0.01	0.007	0	22.4	18.5	72.7	91	79	0	39	36
2015	12	11	18	15	33	0.705	-0.115	3.75	0.01	0.007	0	21.9	18.5	72.7	90	79	0	39	36
2015	12	11	18	25	33	0.725	-0.121	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	11	18	35	33	0.682	-0.118	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	11	18	45	33	0.702	-0.121	3.75	0.01	0.007	0	21.9	17.6	77	90	77	0	39	36
2015	12	11	18	55	33	0.702	-0.131	3.75	0.01	0.007	0	21.5	18.1	77.4	89	78	0	39	36
2015	12	11	19	5	33	0.715	-0.144	3.75	0.01	0.007	0	21.5	18.1	71	89	78	0	39	36
2015	12	11	19	15	33	0.699	-0.131	3.75	0.01	0.007	0	21.5	17.6	72.7	89	78	0	39	37
2015	12	11	19	25	33	0.709	-0.115	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	11	19	35	33	0.702	-0.128	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	11	19	45	33	0.666	-0.128	3.75	0.01	0.007	0	21.5	18.5	77.4	89	78	0	39	35
2015	12	11	19	55	33	0.689	-0.102	3.75	0.013	0.01	0	21.9	18.1	77	89	78	0	38	36
2015	12	11	20	5	33	0.676	-0.105	3.75	0.01	0.007	0	21.5	17.6	77.4	89	78	0	39	37
2015	12	11	20	15	33	0.715	-0.128	3.75	0.01	0.007	0	21.5	17.6	77	89	77	0	39	36
2015	12	11	20	25	33	0.689	-0.105	3.75	0.01	0.007	0	21.5	17.6	77.4	89	77	0	39	36
2015	12	11	20	35	33	0.696	-0.128	3.75	0.01	0.007	0	24.5	20.6	76.5	96	84	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	11	20	45	33	0.676	-0.115	3.75	0.01	0.007	0	22.4	18.9	77.4	91	80	0	39	36
2015	12	11	20	55	33	0.715	-0.144	3.75	0.01	0.007	0	21.5	18.1	77	89	78	0	39	36
2015	12	11	21	5	33	0.728	-0.138	3.75	0.01	0.007	0	21.9	18.1	77.4	90	78	0	39	36
2015	12	11	21	15	33	0.663	-0.125	3.75	0.01	0.007	0	22.4	18.5	77.4	90	78	0	38	35
2015	12	11	21	25	33	0.719	-0.141	3.75	0.01	0.007	0	21.5	17.6	77.4	89	77	0	39	36
2015	12	11	21	35	33	0.689	-0.128	3.75	0.01	0.007	0	21.9	17.6	76.5	89	77	0	38	36
2015	12	11	21	45	33	0.692	-0.105	3.75	0.01	0.007	0	21.5	18.1	77.4	89	78	0	39	36
2015	12	11	21	55	33	0.699	-0.128	3.75	0.013	0.01	0	21.5	17.6	77.4	89	77	0	39	36
2015	12	11	22	5	33	0.728	-0.115	3.75	0.01	0.007	0	21.1	17.6	77.4	88	77	0	39	36
2015	12	11	22	15	33	0.699	-0.105	3.75	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	11	22	25	33	0.686	-0.151	3.75	0.01	0.007	0	21.9	18.1	77	90	78	0	39	36
2015	12	11	22	35	33	0.692	-0.112	3.75	0.01	0.007	0	21.1	17.6	77.4	88	77	0	39	36
2015	12	11	22	45	33	0.719	-0.121	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	11	22	55	33	0.709	-0.112	3.75	0.01	0.007	0	21.5	17.6	77	89	77	0	39	36
2015	12	11	23	5	33	0.705	-0.128	3.75	0.01	0.007	0	21.5	18.1	76.1	89	78	0	39	36
2015	12	11	23	15	33	0.679	-0.115	3.75	0.01	0.007	0	21.1	17.6	76.5	89	77	0	40	36
2015	12	11	23	25	33	0.696	-0.128	3.75	0.01	0.007	0	21.5	17.6	66.7	89	77	0	39	36
2015	12	11	23	35	33	0.682	-0.128	3.75	0.01	0.007	0	21.1	17.2	76.1	88	77	0	39	37
2015	12	11	23	45	33	0.709	-0.121	3.75	0.01	0.007	0	22.4	18.1	76.5	91	79	0	39	37
2015	12	11	23	55	33	0.689	-0.144	3.75	0.01	0.007	0	23.2	19.4	74.8	93	81	0	39	36
2015	12	12	0	5	33	0.666	-0.141	3.75	0.01	0.007	0	22.8	18.9	72.2	92	81	0	39	37
2015	12	12	0	15	33	0.699	-0.115	3.75	0.01	0.007	0	22.8	18.9	76.1	92	80	0	39	36
2015	12	12	0	25	33	0.696	-0.125	3.75	0.01	0.007	0	24.5	21.1	76.5	97	85	0	40	36
2015	12	12	0	35	33	0.699	-0.105	3.75	0.01	0.007	0	25.8	21.9	72.2	99	87	0	39	36
2015	12	12	0	45	33	0.722	-0.128	3.75	0.013	0.01	0	25.8	21.9	75.7	99	87	0	39	36
2015	12	12	0	55	33	0.738	-0.128	3.75	0.013	0.01	0	24.9	21.1	75.7	97	85	0	39	36
2015	12	12	1	5	33	0.748	-0.151	3.75	0.01	0.007	0	24.5	20.2	76.1	96	83	0	39	36
2015	12	12	1	15	33	0.699	-0.128	3.75	0.01	0.007	0	23.6	19.4	76.1	94	82	0	39	37
2015	12	12	1	25	33	0.699	-0.115	3.75	0.01	0.007	0	23.2	19.4	75.7	93	81	0	39	36
2015	12	12	1	35	33	0.705	-0.125	3.75	0.01	0.007	0	22.4	18.5	76.1	91	79	0	39	36
2015	12	12	1	45	33	0.689	-0.118	3.75	0.013	0.01	0	21.9	18.1	77	90	78	0	39	36
2015	12	12	1	55	33	0.702	-0.157	3.75	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	12	2	5	33	0.673	-0.121	3.75	0.01	0.007	0	21.9	17.2	76.5	89	77	0	38	37
2015	12	12	2	15	33	0.696	-0.098	3.75	0.01	0.007	0	21.9	18.5	76.1	90	79	0	39	36
2015	12	12	2	25	33	0.705	-0.141	3.75	0.01	0.007	0	21.5	18.5	75.7	90	79	0	40	36
2015	12	12	2	35	33	0.722	-0.125	3.75	0.01	0.007	0	23.6	20.2	75.7	94	83	0	39	36
2015	12	12	2	45	33	0.689	-0.125	3.75	0.01	0.007	0	22.4	18.1	75.3	91	79	0	39	37
2015	12	12	2	55	33	0.735	-0.138	3.75	0.01	0.007	0	21.9	18.1	75.3	90	78	0	39	36
2015	12	12	3	5	33	0.725	-0.138	3.75	0.01	0.007	0	21.9	18.1	75.7	90	78	0	39	36
2015	12	12	3	15	33	0.709	-0.115	3.75	0.01	0.007	0	22.8	18.9	75.3	92	80	0	39	36
2015	12	12	3	25	33	0.702	-0.157	3.75	0.01	0.007	0	21.9	18.1	74.8	90	78	0	39	36
2015	12	12	3	35	33	0.679	-0.151	3.75	0.01	0.007	0	21.9	18.1	75.3	90	78	0	39	36
2015	12	12	3	45	33	0.679	-0.151	3.75	0.01	0.007	0	21.1	18.1	75.3	89	78	0	40	36
2015	12	12	3	55	33	0.705	-0.115	3.75	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	12	4	5	33	0.696	-0.135	3.75	0.01	0.007	0	21.5	17.6	75.3	89	77	0	39	36
2015	12	12	4	15	33	0.732	-0.138	3.75	0.01	0.007	0	21.5	17.6	74.8	89	77	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	4	25	33	0.719	-0.112	3.75	0.01	0.007	0	21.5	17.6	75.3	89	77	0	39	36
2015	12	12	4	35	33	0.725	-0.125	3.75	0.01	0.007	0	21.5	17.6	74.8	89	77	0	39	36
2015	12	12	4	45	33	0.732	-0.135	3.75	0.013	0.01	0	21.5	17.6	74.8	89	77	0	39	36
2015	12	12	4	55	33	0.725	-0.115	3.75	0.01	0.007	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	12	5	5	33	0.696	-0.118	3.753	0.01	0.007	0	21.1	16.8	74.8	88	76	0	39	37
2015	12	12	5	15	33	0.725	-0.125	3.75	0.01	0.007	0	20.6	17.6	74.8	88	77	0	40	36
2015	12	12	5	25	33	0.715	-0.138	3.75	0.013	0.01	0	20.6	17.2	75.3	87	76	0	39	36
2015	12	12	5	35	33	0.692	-0.141	3.75	0.01	0.007	0	20.6	17.6	74.8	87	77	0	39	36
2015	12	12	5	45	33	0.699	-0.125	3.753	0.01	0.007	0	21.1	17.6	74.4	88	77	0	39	36
2015	12	12	5	55	33	0.709	-0.151	3.75	0.01	0.007	0	21.1	17.2	74.8	88	76	0	39	36
2015	12	12	6	5	33	0.682	-0.135	3.753	0.01	0.007	0	21.5	17.2	74	89	77	0	39	37
2015	12	12	6	15	33	0.735	-0.161	3.75	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	12	6	25	33	0.702	-0.131	3.75	0.013	0.01	0	23.2	19.8	73.5	93	82	0	39	36
2015	12	12	6	35	33	0.719	-0.138	3.753	0.01	0.007	0	23.2	19.4	74	93	81	0	39	36
2015	12	12	6	45	33	0.709	-0.144	3.753	0.01	0.007	0	24.1	20.2	74	95	83	0	39	36
2015	12	12	6	55	33	0.719	-0.128	3.75	0.01	0.007	0	22.4	18.5	74.8	91	80	0	39	37
2015	12	12	7	5	33	0.686	-0.131	3.753	0.01	0.007	0	21.9	18.5	73.5	90	79	0	39	36
2015	12	12	7	15	33	0.719	-0.138	3.753	0.01	0.007	0	21.1	18.1	74	89	78	0	40	36
2015	12	12	7	25	33	0.699	-0.108	3.753	0.01	0.007	0	25.8	21.5	74	99	87	0	39	37
2015	12	12	7	35	33	0.715	-0.108	3.753	0.01	0.007	0	23.2	18.9	73.1	93	81	0	39	37
2015	12	12	7	45	33	0.712	-0.115	3.753	0.01	0.007	0	23.2	19.4	73.1	93	81	0	39	36
2015	12	12	7	55	33	0.673	-0.144	3.753	0.01	0.007	0	23.2	19.8	73.1	93	82	0	39	36
2015	12	12	8	5	33	0.709	-0.112	3.753	0.01	0.007	0	27.1	23.2	73.1	103	90	0	40	36
2015	12	12	8	15	33	0.755	-0.121	3.753	0.01	0.007	0	23.2	19.8	73.5	93	82	0	39	36
2015	12	12	8	25	33	0.689	-0.118	3.753	0.01	0.007	0	21.9	18.5	73.5	91	79	0	40	36
2015	12	12	8	35	33	0.715	-0.128	3.753	0.01	0.007	0	21.9	18.1	72.7	90	78	0	39	36
2015	12	12	8	45	33	0.689	-0.118	3.757	0.013	0.01	0	21.5	18.1	70.1	89	78	0	39	36
2015	12	12	8	55	33	0.696	-0.125	3.757	0.01	0.007	0	21.1	17.6	71.8	88	77	0	39	36
2015	12	12	9	5	33	0.679	-0.144	3.757	0.01	0.007	0	21.1	17.2	64.9	88	77	0	39	37
2015	12	12	9	15	33	0.702	-0.121	3.757	0.01	0.007	0	21.1	17.6	70.1	88	77	0	39	36
2015	12	12	9	25	33	0.679	-0.125	3.757	0.01	0.007	0	21.9	18.5	70.1	90	79	0	39	36
2015	12	12	9	35	33	0.725	-0.079	3.757	0.01	0.007	0	23.2	20.2	49.5	93	83	0	39	36
2015	12	12	9	45	33	0.702	-0.121	3.757	0.01	0.007	0	24.1	20.6	50.3	95	84	0	39	36
2015	12	12	9	55	33	0.669	-0.115	3.76	0.01	0.007	0	26.2	21.5	50.3	100	87	0	39	37
2015	12	12	10	5	33	0.705	-0.082	3.76	0.01	0.007	0	25.8	21.9	48.2	99	87	0	39	36
2015	12	12	10	15	33	0.689	-0.112	3.757	0.01	0.007	0	26.7	22.4	52	101	88	0	39	36
2015	12	12	10	25	33	0.696	-0.118	3.757	0.01	0.007	0	26.2	22.4	49	100	88	0	39	36
2015	12	12	10	35	33	0.702	-0.115	3.757	0.01	0.007	0	25.4	21.9	52.5	99	87	0	40	36
2015	12	12	10	45	33	0.712	-0.138	3.76	0.01	0.007	0	24.5	21.1	61.5	96	85	0	39	36
2015	12	12	10	55	33	0.696	-0.072	3.757	0.01	0.007	0	24.1	20.6	49.9	96	84	0	40	36
2015	12	12	11	5	33	0.715	-0.115	3.757	0.01	0.007	0	24.1	20.2	62.4	95	83	0	39	36
2015	12	12	11	15	33	0.663	-0.115	3.757	0.01	0.007	0	24.1	20.6	52	96	84	0	40	36
2015	12	12	11	25	33	0.682	-0.115	3.757	0.01	0.007	0	23.6	19.8	61.9	94	83	0	39	37
2015	12	12	11	35	33	0.696	-0.128	3.757	0.01	0.007	0	23.6	19.8	66.2	94	82	0	39	36
2015	12	12	11	45	33	0.676	-0.128	3.757	0.01	0.007	0	25.4	21.5	64.1	98	86	0	39	36
2015	12	12	11	55	33	0.666	-0.128	3.757	0.01	0.007	0	23.2	19.8	64.1	93	82	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	12	5	33	0.653	-0.115	3.757	0.01	0.007	0	23.6	20.2	58.5	94	83	0	39	36
2015	12	12	12	15	33	0.712	-0.118	3.757	0.01	0.007	0	23.2	18.9	70.5	93	81	0	39	37
2015	12	12	12	25	33	0.663	-0.141	3.757	0.013	0.01	0	22.8	18.9	71	92	80	0	39	36
2015	12	12	12	35	33	0.679	-0.108	3.757	0.01	0.007	0	22.4	18.5	73.1	91	79	0	39	36
2015	12	12	12	45	33	0.686	-0.115	3.757	0.01	0.007	0	22.4	18.9	73.5	91	80	0	39	36
2015	12	12	12	55	33	0.656	-0.154	3.757	0.01	0.007	0	21.9	18.5	75.7	90	79	0	39	36
2015	12	12	13	5	33	0.696	-0.125	3.753	0.01	0.007	0	21.9	18.5	59.8	90	79	0	39	36
2015	12	12	13	15	33	0.663	-0.141	3.753	0.01	0.007	0	21.9	18.5	72.2	90	79	0	39	36
2015	12	12	13	25	33	0.689	-0.128	3.753	0.01	0.007	0	21.9	18.5	75.3	91	80	0	40	37
2015	12	12	13	35	33	0.663	-0.105	3.753	0.013	0.01	0	22.8	18.9	69.2	91	80	0	38	36
2015	12	12	13	45	33	0.65	-0.092	3.753	0.01	0.007	0	22.8	19.4	73.1	92	81	0	39	36
2015	12	12	13	55	33	0.686	-0.102	3.757	0.013	0.01	0	25.8	21.1	75.7	99	86	0	39	37
2015	12	12	14	5	33	0.689	-0.102	3.757	0.01	0.007	0	24.1	20.2	73.1	95	83	0	39	36
2015	12	12	14	15	33	0.712	-0.112	3.753	0.01	0.007	0	34	30.1	71.8	118	106	0	39	36
2015	12	12	14	25	33	0.722	-0.135	3.757	0.01	0.007	0	26.2	21.9	74.8	100	88	0	39	37
2015	12	12	14	35	33	0.686	-0.125	3.757	0.01	0.007	0	28	23.6	76.5	104	91	0	39	36
2015	12	12	14	45	33	0.702	-0.121	3.76	0.01	0.007	0	27.5	23.6	74.4	103	91	0	39	36
2015	12	12	14	55	33	0.686	-0.125	3.753	0.01	0.007	0	25.8	21.9	77	99	87	0	39	36
2015	12	12	15	5	33	0.676	-0.138	3.753	0.01	0.007	0	23.6	19.8	76.5	94	82	0	39	36
2015	12	12	15	15	33	0.676	-0.102	3.75	0.01	0.007	0	23.2	19.4	77	93	81	0	39	36
2015	12	12	15	25	33	0.679	-0.151	3.75	0.01	0.007	0	22.8	18.5	77	92	79	0	39	36
2015	12	12	15	35	33	0.653	-0.177	3.75	0.01	0.007	0	21.9	18.1	77.8	90	78	0	39	36
2015	12	12	15	45	33	0.656	-0.138	3.75	0.01	0.007	0	21.5	17.6	77.8	89	77	0	39	36
2015	12	12	15	55	33	0.682	-0.151	3.75	0.01	0.007	0	21.5	17.6	78.3	89	77	0	39	36
2015	12	12	16	5	33	0.646	-0.167	3.75	0.01	0.007	0	21.5	17.2	77.8	89	77	0	39	37
2015	12	12	16	15	33	0.646	-0.148	3.75	0.01	0.007	0	21.5	17.6	78.7	89	77	0	39	36
2015	12	12	16	25	33	0.643	-0.18	3.75	0.01	0.007	0	21.5	17.6	77.4	89	77	0	39	36
2015	12	12	16	35	33	0.673	-0.2	3.747	0.013	0.01	0	21.5	17.2	77	88	76	0	38	36
2015	12	12	16	45	33	0.646	-0.154	3.747	0.013	0.01	0	20.6	17.6	77	88	77	0	40	36
2015	12	12	16	55	33	0.646	-0.164	3.747	0.01	0.007	0	21.5	17.6	77.4	89	77	0	39	36
2015	12	12	17	5	33	0.65	-0.174	3.747	0.013	0.01	0	21.5	17.6	76.5	89	77	0	39	36
2015	12	12	17	15	33	0.646	-0.171	3.747	0.01	0.007	0	21.1	18.1	77	89	78	0	40	36
2015	12	12	17	25	33	0.633	-0.171	3.747	0.01	0.007	0	21.5	17.6	77.4	89	78	0	39	37
2015	12	12	17	35	33	0.64	-0.194	3.747	0.01	0.007	0	21.9	18.9	77.4	90	80	0	39	36
2015	12	12	17	45	33	0.623	-0.154	3.747	0.01	0.007	0	21.5	18.5	77.4	89	80	0	39	37
2015	12	12	17	55	33	0.659	-0.174	3.747	0.016	0.013	0	20.2	17.6	77.8	87	78	0	40	37
2015	12	12	18	5	33	0.653	-0.141	3.747	0.013	0.01	0	21.1	18.5	77.4	88	80	0	39	37
2015	12	12	18	15	33	0.617	-0.167	3.747	0.013	0.01	0	20.6	18.1	77.4	87	78	0	39	36
2015	12	12	18	25	33	0.646	-0.177	3.747	0.01	0.007	0	22.4	19.4	77.4	91	82	0	39	37
2015	12	12	18	35	33	0.653	-0.154	3.747	0.013	0.01	0	21.5	19.4	77.8	89	82	0	39	37
2015	12	12	18	45	33	0.633	-0.187	3.747	0.01	0.007	0	23.2	21.5	77.4	93	86	0	39	36
2015	12	12	18	55	33	0.656	-0.157	3.747	0.016	0.013	0	21.9	19.4	77.8	90	82	0	39	37
2015	12	12	19	5	33	0.646	-0.167	3.747	0.013	0.01	0	21.5	19.4	77.8	89	81	0	39	36
2015	12	12	19	15	33	0.65	-0.207	3.747	0.013	0.01	0	20.6	18.5	77.4	87	79	0	39	36
2015	12	12	19	25	33	0.63	-0.194	3.747	0.01	0.007	0	21.1	18.1	77.8	88	79	0	39	37
2015	12	12	19	35	33	0.669	-0.171	3.747	0.013	0.01	0	20.6	17.6	77.8	87	78	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	12	19	45	33	0.607	-0.19	3.747	0.01	0.007	0	20.6	18.1	77.4	87	78	0	39	36
2015	12	12	19	55	33	0.607	-0.194	3.747	0.01	0.007	0	21.1	17.6	77.4	88	78	0	39	37
2015	12	12	20	5	33	0.62	-0.187	3.747	0.01	0.007	0	21.1	18.1	77.8	88	78	0	39	36
2015	12	12	20	15	33	0.604	-0.203	3.747	0.016	0.013	0	21.5	18.1	77.8	89	78	0	39	36
2015	12	12	20	25	33	0.62	-0.213	3.747	0.01	0.007	0	21.5	18.9	77.4	90	80	0	40	36
2015	12	12	20	35	33	0.63	-0.18	3.747	0.01	0.007	0	22.4	18.5	77	91	80	0	39	37
2015	12	12	20	45	33	0.705	-0.171	3.747	0.013	0.01	0	22.8	18.5	77	92	80	0	39	37
2015	12	12	20	55	33	0.748	-0.138	3.747	0.01	0.007	0	21.9	18.1	77	90	78	0	39	36
2015	12	12	21	5	33	0.679	-0.128	3.747	0.01	0.007	0	21.9	18.1	77.8	90	78	0	39	36
2015	12	12	21	15	33	0.679	-0.098	3.747	0.01	0.007	0	24.1	20.6	78.3	95	84	0	39	36
2015	12	12	21	25	33	0.702	-0.115	3.747	0.01	0.007	0	26.2	22.4	78.3	100	88	0	39	36
2015	12	12	21	35	33	0.705	-0.128	3.747	0.01	0.007	0	24.5	20.2	78.7	96	84	0	39	37
2015	12	12	21	45	33	0.686	-0.121	3.747	0.01	0.007	0	23.6	20.2	77.4	94	83	0	39	36
2015	12	12	21	55	33	0.646	-0.125	3.747	0.013	0.01	0	23.2	19.4	78.3	93	81	0	39	36
2015	12	12	22	5	33	0.656	-0.128	3.747	0.01	0.007	0	22.8	18.9	77.8	92	80	0	39	36
2015	12	12	22	15	33	0.696	-0.118	3.747	0.01	0.007	0	22.8	18.5	77	92	80	0	39	37
2015	12	12	22	25	33	0.673	-0.144	3.747	0.016	0.013	0	22.4	18.5	77.4	91	79	0	39	36
2015	12	12	22	35	33	0.686	-0.144	3.747	0.01	0.007	0	22.4	18.5	77.8	91	79	0	39	36
2015	12	12	22	45	33	0.686	-0.125	3.747	0.01	0.007	0	23.6	19.4	77.4	94	81	0	39	36
2015	12	12	22	55	33	0.676	-0.121	3.747	0.01	0.007	0	25.8	21.5	77	99	86	0	39	36
2015	12	12	23	5	33	0.646	-0.125	3.747	0.013	0.01	0	24.1	20.2	77	95	83	0	39	36
2015	12	12	23	15	33	0.696	-0.135	3.747	0.01	0.007	0	23.6	19.8	77.4	94	82	0	39	36
2015	12	12	23	25	33	0.646	-0.115	3.747	0.01	0.007	0	23.2	19.4	77.8	93	81	0	39	36
2015	12	12	23	35	33	0.65	-0.115	3.747	0.01	0.007	0	22.4	18.5	77.8	91	79	0	39	36
2015	12	12	23	45	33	0.702	-0.115	3.747	0.01	0.007	0	24.5	20.6	75.3	96	84	0	39	36
2015	12	12	23	55	33	0.673	-0.131	3.747	0.01	0.007	0	22.8	18.9	77	92	80	0	39	36
2015	12	13	0	5	33	0.709	-0.135	3.747	0.016	0.013	0	21.9	18.1	77.4	90	79	0	39	37
2015	12	13	0	15	33	0.696	-0.125	3.747	0.01	0.007	0	23.2	19.4	77.4	93	81	0	39	36
2015	12	13	0	25	33	0.65	-0.154	3.747	0.01	0.007	0	22.4	18.5	77	92	80	0	40	37
2015	12	13	0	35	33	0.722	-0.125	3.747	0.01	0.007	0	24.5	21.1	77.8	96	85	0	39	36
2015	12	13	0	45	33	0.696	-0.128	3.747	0.01	0.007	0	23.2	19.4	77.4	93	81	0	39	36
2015	12	13	0	55	33	0.702	-0.167	3.747	0.01	0.007	0	21.9	18.5	77	90	79	0	39	36
2015	12	13	1	5	33	0.689	-0.151	3.747	0.01	0.007	0	22.4	18.1	77	91	79	0	39	37
2015	12	13	1	15	33	0.696	-0.141	3.75	0.013	0.01	0	21.9	18.1	77	91	79	0	40	37
2015	12	13	1	25	33	0.659	-0.121	3.747	0.01	0.007	0	23.2	20.2	77.4	94	83	0	40	36
2015	12	13	1	35	33	0.673	-0.115	3.75	0.01	0.007	0	21.9	18.1	76.5	91	79	0	40	37
2015	12	13	1	45	33	0.659	-0.154	3.75	0.013	0.01	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	13	1	55	33	0.666	-0.148	3.75	0.01	0.007	0	22.4	18.5	77	91	79	0	39	36
2015	12	13	2	5	33	0.709	-0.128	3.75	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	13	2	15	33	0.682	-0.141	3.75	0.01	0.007	0	21.5	17.6	76.1	89	77	0	39	36
2015	12	13	2	25	33	0.679	-0.118	3.75	0.01	0.007	0	21.9	18.1	76.1	90	78	0	39	36
2015	12	13	2	35	33	0.676	-0.128	3.747	0.01	0.007	0	21.9	18.1	75.7	90	78	0	39	36
2015	12	13	2	45	33	0.646	-0.135	3.75	0.01	0.007	0	21.9	18.1	76.1	90	78	0	39	36
2015	12	13	2	55	33	0.669	-0.141	3.75	0.01	0.007	0	21.9	18.1	76.5	90	78	0	39	36
2015	12	13	3	5	33	0.669	-0.148	3.75	0.01	0.007	0	21.9	18.1	75.7	90	78	0	39	36
2015	12	13	3	15	33	0.673	-0.135	3.75	0.013	0.01	0	21.9	18.1	75.3	90	78	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	3	25	33	0.679	-0.161	3.75	0.01	0.007	0	22.4	17.6	75.7	91	78	0	39	37
2015	12	13	3	35	33	0.673	-0.125	3.75	0.01	0.007	0	21.9	18.1	75.7	90	78	0	39	36
2015	12	13	3	45	33	0.705	-0.161	3.75	0.013	0.01	0	21.5	17.2	75.7	89	77	0	39	37
2015	12	13	3	55	33	0.663	-0.135	3.75	0.01	0.007	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	13	4	5	33	0.64	-0.148	3.75	0.01	0.007	0	21.9	17.6	76.1	90	77	0	39	36
2015	12	13	4	15	33	0.676	-0.105	3.75	0.01	0.007	0	21.9	17.6	75.7	91	78	0	40	37
2015	12	13	4	25	33	0.686	-0.148	3.75	0.01	0.007	0	21.9	17.6	75.3	90	78	0	39	37
2015	12	13	4	35	33	0.682	-0.128	3.75	0.01	0.007	0	21.5	17.2	75.3	89	77	0	39	37
2015	12	13	4	45	33	0.676	-0.115	3.75	0.01	0.007	0	21.9	17.2	75.3	90	77	0	39	37
2015	12	13	4	55	33	0.673	-0.118	3.75	0.01	0.007	0	21.5	17.6	74.4	89	77	0	39	36
2015	12	13	5	5	33	0.669	-0.128	3.75	0.01	0.007	0	21.5	17.6	74.4	89	77	0	39	36
2015	12	13	5	15	33	0.673	-0.151	3.75	0.01	0.007	0	21.5	17.6	74.8	90	77	0	40	36
2015	12	13	5	25	33	0.653	-0.154	3.75	0.01	0.007	0	21.9	17.2	74.8	90	77	0	39	37
2015	12	13	5	35	33	0.666	-0.112	3.75	0.01	0.007	0	21.1	17.2	73.5	89	77	0	40	37
2015	12	13	5	45	33	0.715	-0.154	3.75	0.01	0.007	0	21.5	17.6	74.4	89	78	0	39	37
2015	12	13	5	55	33	0.689	-0.161	3.75	0.01	0.007	0	21.5	17.2	74.4	89	77	0	39	37
2015	12	13	6	5	33	0.725	-0.144	3.75	0.01	0.007	0	21.9	18.1	74.4	90	78	0	39	36
2015	12	13	6	15	33	0.679	-0.151	3.75	0.01	0.007	0	21.5	17.6	74	90	78	0	40	37
2015	12	13	6	25	33	0.663	-0.144	3.753	0.01	0.007	0	22.4	17.6	74.4	90	78	0	38	37
2015	12	13	6	35	33	0.719	-0.138	3.753	0.013	0.01	0	21.9	18.1	74	90	78	0	39	36
2015	12	13	6	45	33	0.702	-0.131	3.753	0.01	0.007	0	21.1	18.1	74	89	78	0	40	36
2015	12	13	6	55	33	0.702	-0.138	3.753	0.01	0.007	0	22.8	19.4	74	93	81	0	40	36
2015	12	13	7	5	33	0.699	-0.144	3.757	0.01	0.007	0	21.9	18.5	74.4	91	79	0	40	36
2015	12	13	7	15	33	0.705	-0.131	3.757	0.01	0.007	0	24.5	19.8	74.4	95	83	0	38	37
2015	12	13	7	25	33	0.643	-0.105	3.757	0.01	0.007	0	22.4	18.9	74.4	92	80	0	40	36
2015	12	13	7	35	33	0.653	-0.121	3.76	0.01	0.007	0	22.8	18.5	74.4	92	80	0	39	37
2015	12	13	7	45	33	0.676	-0.118	3.757	0.01	0.007	0	21.9	18.5	74	90	79	0	39	36
2015	12	13	7	55	33	0.689	-0.125	3.76	0.013	0.01	0	24.5	21.1	74.4	96	85	0	39	36
2015	12	13	8	5	33	0.702	-0.115	3.76	0.01	0.007	0	27.1	22.8	74.8	102	90	0	39	37
2015	12	13	8	15	33	0.715	-0.112	3.76	0.01	0.007	0	23.2	19.4	74	93	81	0	39	36
2015	12	13	8	25	33	0.682	-0.128	3.76	0.01	0.007	0	21.9	18.1	75.3	91	79	0	40	37
2015	12	13	8	35	33	0.666	-0.112	3.76	0.01	0.007	0	21.9	18.1	75.3	90	79	0	39	37
2015	12	13	8	45	33	0.653	-0.098	3.763	0.01	0.007	0	21.9	18.5	75.3	90	79	0	39	36
2015	12	13	8	55	33	0.676	-0.121	3.763	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	13	9	5	33	0.699	-0.128	3.76	0.01	0.007	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	13	9	15	33	0.65	-0.105	3.763	0.013	0.01	0	21.1	17.6	74.4	88	77	0	39	36
2015	12	13	9	25	33	0.659	-0.131	3.763	0.013	0.01	0	21.1	17.6	68.4	88	77	0	39	36
2015	12	13	9	35	33	0.669	-0.105	3.76	0.01	0.007	0	21.1	17.2	64.5	88	77	0	39	37
2015	12	13	9	45	33	0.673	-0.125	3.763	0.013	0.01	0	22.4	18.1	69.2	90	79	0	38	37
2015	12	13	9	55	33	0.682	-0.112	3.763	0.013	0.01	0	22.8	19.4	75.3	92	81	0	39	36
2015	12	13	10	5	33	0.702	-0.125	3.763	0.013	0.01	0	27.1	22.8	74	102	90	0	39	37
2015	12	13	10	15	33	0.669	-0.128	3.763	0.01	0.007	0	24.9	21.1	73.5	97	85	0	39	36
2015	12	13	10	25	33	0.712	-0.079	3.76	0.01	0.007	0	29.7	25.4	69.2	108	96	0	39	37
2015	12	13	10	35	33	0.709	-0.102	3.763	0.01	0.007	0	23.2	19.8	70.1	93	82	0	39	36
2015	12	13	10	45	33	0.679	-0.115	3.763	0.01	0.007	0	21.9	18.5	74	91	80	0	40	37
2015	12	13	10	55	33	0.669	-0.135	3.763	0.01	0.007	0	21.9	18.1	74	90	79	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	11	5	33	0.682	-0.128	3.763	0.01	0.007	0	22.4	18.5	73.5	91	79	0	39	36
2015	12	13	11	15	33	0.676	-0.128	3.763	0.01	0.007	0	21.9	18.5	73.1	90	79	0	39	36
2015	12	13	11	25	33	0.656	-0.115	3.757	0.016	0.013	0	21.9	18.5	59.3	90	79	0	39	36
2015	12	13	11	35	33	0.696	-0.125	3.76	0.01	0.007	0	21.9	18.5	64.5	90	79	0	39	36
2015	12	13	11	45	33	0.682	-0.102	3.76	0.01	0.007	0	24.1	20.2	71	96	84	0	40	37
2015	12	13	11	55	33	0.659	-0.144	3.763	0.01	0.007	0	23.6	19.8	73.5	94	82	0	39	36
2015	12	13	12	5	33	0.659	-0.115	3.763	0.01	0.007	0	22.8	18.5	72.7	92	80	0	39	37
2015	12	13	12	15	33	0.64	-0.095	3.757	0.01	0.007	0	21.9	18.5	56.3	90	79	0	39	36
2015	12	13	12	25	33	0.643	-0.098	3.757	0.013	0.01	0	21.9	18.1	51.6	90	79	0	39	37
2015	12	13	12	35	33	0.686	-0.115	3.757	0.01	0.007	0	23.6	20.2	51.6	94	83	0	39	36
2015	12	13	12	45	33	0.656	-0.108	3.757	0.01	0.007	0	24.9	21.5	49.9	97	86	0	39	36
2015	12	13	12	55	33	0.669	-0.095	3.753	0.01	0.007	0	24.1	20.2	46.9	95	84	0	39	37
2015	12	13	13	5	33	0.63	-0.085	3.757	0.01	0.007	0	23.2	19.8	49.5	93	82	0	39	36
2015	12	13	13	15	33	0.682	-0.118	3.757	0.01	0.007	0	23.6	20.6	52.5	95	84	0	40	36
2015	12	13	13	25	33	0.656	-0.062	3.757	0.01	0.007	0	27.5	23.2	47.7	103	91	0	39	37
2015	12	13	13	35	33	0.656	-0.095	3.753	0.01	0.007	0	34.4	31	46.9	119	108	0	39	36
2015	12	13	13	45	33	0.676	-0.105	3.753	0.01	0.007	0	35.3	31	46	121	109	0	39	37
2015	12	13	13	55	33	0.653	-0.108	3.753	0.01	0.007	0	34	30.1	46.4	118	106	0	39	36
2015	12	13	14	5	33	0.705	-0.135	3.753	0.01	0.007	0	32.7	28.8	47.3	115	103	0	39	36
2015	12	13	14	15	33	0.659	-0.121	3.753	0.01	0.007	0	31.4	27.5	44.3	112	100	0	39	36
2015	12	13	14	25	33	0.692	-0.075	3.753	0.01	0.007	0	33.5	29.7	46.9	118	106	0	40	37
2015	12	13	14	35	33	0.646	-0.075	3.753	0.01	0.007	0	33.1	29.2	44.3	116	105	0	39	37
2015	12	13	14	45	33	0.682	-0.085	3.757	0.01	0.007	0	31.8	27.5	42.6	113	101	0	39	37
2015	12	13	14	55	33	0.656	-0.098	3.753	0.01	0.007	0	29.7	26.7	45.6	109	98	0	40	36
2015	12	13	15	5	33	0.659	-0.089	3.753	0.01	0.007	0	28.8	25.4	46.9	107	95	0	40	36
2015	12	13	15	15	33	0.686	-0.105	3.753	0.01	0.007	0	26.7	23.2	52.9	102	91	0	40	37
2015	12	13	15	25	33	0.676	-0.102	3.757	0.01	0.007	0	26.2	22.4	67.5	100	88	0	39	36
2015	12	13	15	35	33	0.676	-0.121	3.753	0.01	0.007	0	24.9	21.5	52.9	97	86	0	39	36
2015	12	13	15	45	33	0.669	-0.112	3.753	0.01	0.007	0	24.5	21.1	54.2	96	85	0	39	36
2015	12	13	15	55	33	0.669	-0.089	3.753	0.013	0.01	0	24.5	20.6	49	96	84	0	39	36
2015	12	13	16	5	33	0.656	-0.102	3.757	0.01	0.007	0	25.4	21.9	46.9	98	87	0	39	36
2015	12	13	16	15	33	0.699	-0.125	3.757	0.01	0.007	0	24.5	21.1	59.3	96	85	0	39	36
2015	12	13	16	25	33	0.699	-0.154	3.763	0.01	0.007	0	24.1	20.6	71	95	84	0	39	36
2015	12	13	16	35	33	0.709	-0.138	3.766	0.01	0.007	0	23.6	20.2	74.4	94	83	0	39	36
2015	12	13	16	45	33	0.666	-0.095	3.766	0.01	0.007	0	24.1	19.8	74.4	94	82	0	38	36
2015	12	13	16	55	33	0.699	-0.135	3.766	0.013	0.01	0	23.2	18.9	74.4	93	81	0	39	37
2015	12	13	17	5	33	0.679	-0.125	3.757	0.01	0.007	0	23.6	19.8	57.2	94	82	0	39	36
2015	12	13	17	15	33	0.712	-0.098	3.763	0.01	0.007	0	23.6	19.8	73.5	94	83	0	39	37
2015	12	13	17	25	33	0.666	-0.128	3.766	0.01	0.007	0	23.6	20.2	74.8	94	83	0	39	36
2015	12	13	17	35	33	0.696	-0.125	3.763	0.013	0.01	0	23.2	19.4	61.9	93	81	0	39	36
2015	12	13	17	45	33	0.689	-0.102	3.763	0.01	0.007	0	23.2	18.9	66.7	93	81	0	39	37
2015	12	13	17	55	33	0.709	-0.135	3.763	0.01	0.007	0	22.4	19.4	66.7	92	81	0	40	36
2015	12	13	18	5	33	0.686	-0.112	3.76	0.01	0.007	0	23.2	19.4	55.9	93	81	0	39	36
2015	12	13	18	15	33	0.709	-0.118	3.76	0.01	0.007	0	23.2	19.4	49	93	81	0	39	36
2015	12	13	18	25	33	0.669	-0.138	3.76	0.01	0.007	0	23.2	19.4	55.9	93	81	0	39	36
2015	12	13	18	35	33	0.748	-0.125	3.766	0.01	0.007	0	22.8	18.9	71.8	92	81	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	13	18	45	33	0.712	-0.095	3.763	0.01	0.007	0	23.2	19.4	51.2	93	82	0	39	37
2015	12	13	18	55	33	0.689	-0.144	3.77	0.01	0.007	0	25.4	20.6	74.4	97	85	0	38	37
2015	12	13	19	5	33	0.689	-0.102	3.77	0.01	0.007	0	24.1	20.6	75.7	95	84	0	39	36
2015	12	13	19	15	33	0.735	-0.108	3.766	0.01	0.007	0	23.6	19.8	74.4	94	82	0	39	36
2015	12	13	19	25	33	0.656	-0.115	3.77	0.01	0.007	0	23.6	20.2	75.7	94	83	0	39	36
2015	12	13	19	35	33	0.702	-0.112	3.77	0.01	0.007	0	24.1	19.8	74.4	95	83	0	39	37
2015	12	13	19	45	33	0.705	-0.108	3.76	0.01	0.007	0	24.5	20.2	49	96	84	0	39	37
2015	12	13	19	55	33	0.689	-0.108	3.77	0.01	0.007	0	27.1	23.2	63.2	102	90	0	39	36
2015	12	13	20	5	33	0.686	-0.121	3.77	0.01	0.007	0	26.2	22.8	76.1	100	88	0	39	35
2015	12	13	20	15	33	0.676	-0.102	3.766	0.01	0.007	0	24.9	21.1	54.2	97	85	0	39	36
2015	12	13	20	25	33	0.715	-0.118	3.77	0.01	0.007	0	24.1	20.2	70.1	95	83	0	39	36
2015	12	13	20	35	33	0.696	-0.089	3.766	0.01	0.007	0	24.1	20.2	51.6	95	83	0	39	36
2015	12	13	20	45	33	0.699	-0.102	3.77	0.013	0.01	0	23.2	19.8	72.7	93	82	0	39	36
2015	12	13	20	55	33	0.728	-0.148	3.773	0.01	0.007	0	22.8	18.9	76.5	92	81	0	39	37
2015	12	13	21	5	33	0.748	-0.138	3.773	0.01	0.007	0	22.8	18.9	76.5	92	80	0	39	36
2015	12	13	21	15	33	0.725	-0.115	3.773	0.01	0.007	0	22.8	18.5	77.4	92	80	0	39	37
2015	12	13	21	25	33	0.696	-0.151	3.773	0.01	0.007	0	22.8	19.4	77	92	81	0	39	36
2015	12	13	21	35	33	0.725	-0.154	3.773	0.01	0.007	0	22.4	18.9	77.4	91	80	0	39	36
2015	12	13	21	45	33	0.702	-0.131	3.773	0.01	0.007	0	22.4	18.5	77.8	91	79	0	39	36
2015	12	13	21	55	33	0.696	-0.135	3.773	0.01	0.007	0	22.4	18.9	77.4	91	80	0	39	36
2015	12	13	22	5	33	0.712	-0.138	3.773	0.01	0.007	0	22.4	18.9	77.8	91	80	0	39	36
2015	12	13	22	15	33	0.735	-0.131	3.773	0.01	0.007	0	22.8	18.9	77.8	92	80	0	39	36
2015	12	13	22	25	33	0.689	-0.092	3.776	0.01	0.007	0	23.2	19.8	77	93	82	0	39	36
2015	12	13	22	35	33	0.699	-0.161	3.776	0.013	0.01	0	23.2	19.4	77	93	82	0	39	37
2015	12	13	22	45	33	0.663	-0.108	3.776	0.01	0.007	0	23.2	19.4	76.1	93	81	0	39	36
2015	12	13	22	55	33	0.689	-0.089	3.776	0.01	0.007	0	22.4	19.4	76.5	91	81	0	39	36
2015	12	13	23	5	33	0.686	-0.098	3.776	0.013	0.01	0	22.8	19.4	75.3	92	81	0	39	36
2015	12	13	23	15	33	0.692	-0.105	3.776	0.01	0.007	0	23.6	19.8	77.8	94	82	0	39	36
2015	12	13	23	25	33	0.725	-0.135	3.776	0.01	0.007	0	22.4	18.9	78.3	91	80	0	39	36
2015	12	13	23	35	33	0.702	-0.121	3.776	0.01	0.007	0	21.9	18.5	78.7	91	79	0	40	36
2015	12	13	23	45	33	0.682	-0.105	3.776	0.01	0.007	0	22.4	18.5	77.4	91	79	0	39	36
2015	12	13	23	55	33	0.696	-0.121	3.776	0.01	0.007	0	22.4	19.4	77.4	92	81	0	40	36
2015	12	14	0	5	33	0.719	-0.092	3.776	0.01	0.007	0	21.5	18.5	76.5	90	79	0	40	36
2015	12	14	0	15	33	0.699	-0.115	3.776	0.01	0.007	0	21.5	18.5	69.7	90	79	0	40	36
2015	12	14	0	25	33	0.669	-0.092	3.776	0.013	0.01	0	22.8	18.9	76.5	92	80	0	39	36
2015	12	14	0	35	33	0.682	-0.128	3.776	0.01	0.007	0	22.8	18.9	75.7	92	80	0	39	36
2015	12	14	0	45	33	0.676	-0.105	3.776	0.01	0.007	0	21.9	18.5	77.8	91	79	0	40	36
2015	12	14	0	55	33	0.696	-0.108	3.78	0.01	0.007	0	21.9	18.5	77.8	90	79	0	39	36
2015	12	14	1	5	33	0.692	-0.089	3.776	0.01	0.007	0	22.4	18.9	58.9	91	80	0	39	36
2015	12	14	1	15	33	0.689	-0.128	3.776	0.01	0.007	0	22.4	18.5	66.7	91	80	0	39	37
2015	12	14	1	25	33	0.689	-0.098	3.776	0.013	0.01	0	21.9	18.1	63.2	91	79	0	40	37
2015	12	14	1	35	33	0.669	-0.128	3.776	0.01	0.007	0	22.4	18.5	65.8	91	79	0	39	36
2015	12	14	1	45	33	0.653	-0.082	3.776	0.01	0.007	0	22.4	18.9	58.9	91	80	0	39	36
2015	12	14	1	55	33	0.709	-0.125	3.78	0.01	0.007	0	22.8	18.5	77.4	91	80	0	38	37
2015	12	14	2	5	33	0.673	-0.115	3.78	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	14	2	15	33	0.692	-0.138	3.78	0.01	0.007	0	21.9	18.1	74.8	90	78	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	2	25	33	0.725	-0.082	3.776	0.01	0.007	0	21.9	18.1	52.9	90	79	0	39	37
2015	12	14	2	35	33	0.682	-0.095	3.776	0.01	0.007	0	21.9	18.9	51.6	91	80	0	40	36
2015	12	14	2	45	33	0.699	-0.072	3.776	0.01	0.007	0	22.8	19.4	51.2	93	81	0	40	36
2015	12	14	2	55	33	0.692	-0.102	3.78	0.01	0.007	0	23.6	20.2	50.7	95	83	0	40	36
2015	12	14	3	5	33	0.709	-0.115	3.78	0.01	0.007	0	24.1	20.2	50.3	95	83	0	39	36
2015	12	14	3	15	33	0.732	-0.098	3.78	0.01	0.007	0	23.6	20.2	50.3	95	83	0	40	36
2015	12	14	3	25	33	0.696	-0.112	3.78	0.01	0.007	0	23.6	19.8	51.6	94	83	0	39	37
2015	12	14	3	35	33	0.709	-0.098	3.78	0.01	0.007	0	24.5	20.6	51.2	96	84	0	39	36
2015	12	14	3	45	33	0.679	-0.072	3.78	0.01	0.007	0	23.2	19.8	51.2	93	82	0	39	36
2015	12	14	3	55	33	0.659	-0.121	3.78	0.01	0.007	0	23.6	20.2	53.3	94	83	0	39	36
2015	12	14	4	5	33	0.728	-0.089	3.78	0.01	0.007	0	23.2	19.4	51.6	93	81	0	39	36
2015	12	14	4	15	33	0.682	-0.102	3.78	0.01	0.007	0	22.8	19.4	52.5	92	81	0	39	36
2015	12	14	4	25	33	0.686	-0.112	3.78	0.01	0.007	0	22.4	18.9	65.4	91	80	0	39	36
2015	12	14	4	35	33	0.673	-0.115	3.78	0.013	0.01	0	22.8	18.5	50.3	92	80	0	39	37
2015	12	14	4	45	33	0.656	-0.092	3.78	0.01	0.007	0	22.4	18.9	53.3	91	80	0	39	36
2015	12	14	4	55	33	0.636	-0.098	3.78	0.01	0.007	0	22.4	18.9	66.2	91	80	0	39	36
2015	12	14	5	5	33	0.666	-0.102	3.78	0.01	0.007	0	21.9	18.5	64.5	90	80	0	39	37
2015	12	14	5	15	33	0.663	-0.108	3.78	0.01	0.007	0	21.9	18.1	71.8	90	79	0	39	37
2015	12	14	5	25	33	0.712	-0.112	3.783	0.01	0.007	0	22.8	18.9	75.7	92	80	0	39	36
2015	12	14	5	35	33	0.673	-0.082	3.783	0.01	0.007	0	21.9	18.5	75.3	90	79	0	39	36
2015	12	14	5	45	33	0.682	-0.128	3.78	0.01	0.007	0	21.9	18.1	75.7	90	78	0	39	36
2015	12	14	5	55	33	0.699	-0.092	3.78	0.01	0.007	0	22.4	18.9	76.1	92	80	0	40	36
2015	12	14	6	5	33	0.682	-0.112	3.78	0.01	0.007	0	22.4	18.5	75.7	91	79	0	39	36
2015	12	14	6	15	33	0.666	-0.118	3.78	0.01	0.007	0	22.4	18.5	75.3	91	79	0	39	36
2015	12	14	6	25	33	0.669	-0.121	3.783	0.01	0.007	0	22.4	18.5	75.7	91	79	0	39	36
2015	12	14	6	35	33	0.646	-0.115	3.783	0.01	0.007	0	21.5	18.1	75.3	90	78	0	40	36
2015	12	14	6	45	33	0.65	-0.095	3.78	0.01	0.007	0	21.5	18.1	62.8	90	79	0	40	37
2015	12	14	6	55	33	0.705	-0.115	3.78	0.013	0.01	0	22.4	18.5	74.8	91	79	0	39	36
2015	12	14	7	5	33	0.686	-0.075	3.78	0.01	0.007	0	21.9	18.5	75.7	90	79	0	39	36
2015	12	14	7	15	33	0.702	-0.121	3.78	0.01	0.007	0	21.5	18.1	75.3	89	78	0	39	36
2015	12	14	7	25	33	0.663	-0.082	3.78	0.01	0.007	0	21.5	18.1	74.8	89	78	0	39	36
2015	12	14	7	35	33	0.669	-0.102	3.78	0.01	0.007	0	21.5	18.5	70.5	90	79	0	40	36
2015	12	14	7	45	33	0.673	-0.118	3.78	0.01	0.007	0	24.5	21.1	51.2	97	86	0	40	37
2015	12	14	7	55	33	0.699	-0.082	3.78	0.01	0.007	0	23.6	20.6	51.2	95	84	0	40	36
2015	12	14	8	5	33	0.689	-0.098	3.78	0.01	0.007	0	24.1	20.6	50.3	95	84	0	39	36
2015	12	14	8	15	33	0.659	-0.079	3.78	0.01	0.007	0	23.2	19.8	51.2	93	82	0	39	36
2015	12	14	8	25	33	0.709	-0.092	3.78	0.013	0.01	0	23.6	19.8	49.9	93	83	0	38	37
2015	12	14	8	35	33	0.689	-0.072	3.78	0.013	0.01	0	23.2	19.8	52.9	93	82	0	39	36
2015	12	14	8	45	33	0.692	-0.098	3.783	0.016	0.013	0	23.2	19.4	49	94	82	0	40	37
2015	12	14	8	55	33	0.705	-0.105	3.783	0.01	0.007	0	24.1	20.2	50.7	96	84	0	40	37
2015	12	14	9	5	33	0.682	-0.095	3.783	0.01	0.007	0	25.8	21.9	62.4	99	87	0	39	36
2015	12	14	9	15	33	0.715	-0.092	3.783	0.01	0.007	0	27.5	24.1	53.3	104	92	0	40	36
2015	12	14	9	25	33	0.666	-0.085	3.783	0.01	0.007	0	27.5	23.2	50.7	103	91	0	39	37
2015	12	14	9	35	33	0.679	-0.128	3.783	0.01	0.007	0	28.4	24.5	49.9	105	93	0	39	36
2015	12	14	9	45	33	0.741	-0.098	3.783	0.01	0.007	0	28.8	24.5	50.7	106	94	0	39	37
2015	12	14	9	55	33	0.722	-0.105	3.786	0.013	0.01	0	27.5	23.6	46.9	103	91	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	10	5	33	0.702	-0.089	3.786	0.01	0.007	0	29.2	24.9	48.6	107	95	0	39	37
2015	12	14	10	15	33	0.692	-0.095	3.786	0.01	0.007	0	28	23.6	50.7	104	92	0	39	37
2015	12	14	10	25	33	0.715	-0.115	3.786	0.016	0.013	0	27.5	23.6	53.3	103	92	0	39	37
2015	12	14	10	35	33	0.705	-0.098	3.786	0.01	0.007	0	27.1	22.8	54.6	102	90	0	39	37
2015	12	14	10	45	33	0.709	-0.112	3.786	0.01	0.007	0	26.2	21.9	54.6	100	88	0	39	37
2015	12	14	10	55	33	0.699	-0.108	3.789	0.01	0.007	0	25.4	21.9	48.6	98	87	0	39	36
2015	12	14	11	5	33	0.673	-0.069	3.786	0.013	0.01	0	25.8	22.8	51.6	100	89	0	40	36
2015	12	14	11	15	33	0.705	-0.098	3.789	0.01	0.007	0	27.5	23.6	51.6	103	92	0	39	37
2015	12	14	11	25	33	0.715	-0.125	3.786	0.01	0.007	0	28	23.6	51.2	104	92	0	39	37
2015	12	14	11	35	33	0.692	-0.102	3.789	0.01	0.007	0	28.8	24.5	48.6	106	94	0	39	37
2015	12	14	11	45	33	0.712	-0.092	3.786	0.01	0.007	0	29.2	24.9	51.6	107	95	0	39	37
2015	12	14	11	55	33	0.676	-0.079	3.789	0.01	0.007	0	28	24.5	49.9	104	93	0	39	36
2015	12	14	12	5	33	0.728	-0.085	3.786	0.01	0.007	0	28	24.1	48.6	104	92	0	39	36
2015	12	14	12	15	33	0.702	-0.079	3.789	0.01	0.007	0	27.5	23.6	49	104	92	0	40	37
2015	12	14	12	25	33	0.689	-0.098	3.789	0.01	0.007	0	28	23.6	50.3	104	92	0	39	37
2015	12	14	12	35	33	0.656	-0.089	3.789	0.01	0.007	0	28.4	24.1	53.8	104	92	0	38	36
2015	12	14	12	45	33	0.659	-0.089	3.789	0.01	0.007	0	28.4	24.1	49.9	104	92	0	38	36
2015	12	14	12	55	33	0.709	-0.095	3.789	0.01	0.007	0	27.5	24.1	47.3	103	92	0	39	36
2015	12	14	13	5	33	0.692	-0.085	3.789	0.013	0.01	0	27.5	24.1	49.5	103	92	0	39	36
2015	12	14	13	15	33	0.686	-0.095	3.786	0.01	0.007	0	27.1	22.8	50.3	102	90	0	39	37
2015	12	14	13	25	33	0.686	-0.075	3.789	0.01	0.007	0	27.1	22.8	49	102	90	0	39	37
2015	12	14	13	35	33	0.692	-0.112	3.786	0.01	0.007	0	25.8	22.4	49	99	88	0	39	36
2015	12	14	13	45	33	0.679	-0.092	3.786	0.01	0.007	0	25.4	21.9	52.5	98	87	0	39	36
2015	12	14	13	55	33	0.653	-0.092	3.786	0.01	0.007	0	25.8	21.9	53.3	99	87	0	39	36
2015	12	14	14	5	33	0.679	-0.092	3.786	0.01	0.007	0	25.4	21.5	49.9	98	86	0	39	36
2015	12	14	14	15	33	0.686	-0.095	3.786	0.01	0.007	0	25.8	21.5	50.7	98	87	0	38	37
2015	12	14	14	25	33	0.745	-0.085	3.786	0.01	0.007	0	25.4	21.1	48.2	98	86	0	39	37
2015	12	14	14	35	33	0.676	-0.075	3.786	0.013	0.01	0	25.8	22.4	52.5	100	88	0	40	36
2015	12	14	14	45	33	0.712	-0.098	3.786	0.01	0.007	0	33.1	29.2	55.5	116	104	0	39	36
2015	12	14	14	55	33	0.696	-0.075	3.786	0.013	0.01	0	31	27.1	50.3	111	99	0	39	36
2015	12	14	15	5	33	0.643	-0.095	3.786	0.01	0.007	0	26.2	21.9	49.5	100	88	0	39	37
2015	12	14	15	15	33	0.712	-0.089	3.783	0.01	0.007	0	29.2	25.4	49.5	107	95	0	39	36
2015	12	14	15	25	33	0.682	-0.075	3.783	0.01	0.007	0	25.4	21.5	49.9	98	86	0	39	36
2015	12	14	15	35	33	0.679	-0.102	3.786	0.013	0.01	0	24.5	20.2	49.9	97	84	0	40	37
2015	12	14	15	45	33	0.709	-0.085	3.786	0.013	0.01	0	23.6	20.2	49.9	95	83	0	40	36
2015	12	14	15	55	33	0.682	-0.102	3.783	0.01	0.007	0	23.6	19.8	49.5	95	83	0	40	37
2015	12	14	16	5	33	0.692	-0.089	3.783	0.01	0.007	0	24.1	20.6	52	96	84	0	40	36
2015	12	14	16	15	33	0.676	-0.112	3.783	0.01	0.007	0	23.2	19.4	52.9	93	81	0	39	36
2015	12	14	16	25	33	0.666	-0.115	3.783	0.013	0.01	0	23.2	19.8	52.9	93	82	0	39	36
2015	12	14	16	35	33	0.702	-0.095	3.783	0.01	0.007	0	23.2	19.4	53.3	93	82	0	39	37
2015	12	14	16	45	33	0.669	-0.112	3.786	0.01	0.007	0	23.2	19.8	49.5	93	82	0	39	36
2015	12	14	16	55	33	0.673	-0.089	3.783	0.01	0.007	0	22.8	19.4	52.9	93	82	0	40	37
2015	12	14	17	5	33	0.689	-0.089	3.783	0.01	0.007	0	23.2	19.4	49	94	82	0	40	37
2015	12	14	17	15	33	0.656	-0.092	3.783	0.01	0.007	0	24.1	20.2	51.6	95	83	0	39	36
2015	12	14	17	25	33	0.682	-0.075	3.783	0.01	0.007	0	23.2	18.9	49.9	93	81	0	39	37
2015	12	14	17	35	33	0.709	-0.079	3.783	0.01	0.007	0	23.2	20.2	49.5	93	82	0	39	35

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	14	17	45	33	0.656	-0.062	3.786	0.013	0.01	0	23.6	20.2	52.5	95	83	0	40	36
2015	12	14	17	55	33	0.696	-0.102	3.786	0.01	0.007	0	23.6	20.2	47.7	94	83	0	39	36
2015	12	14	18	5	33	0.659	-0.085	3.783	0.01	0.007	0	24.9	21.5	49.9	97	86	0	39	36
2015	12	14	18	15	33	0.682	-0.089	3.783	0.016	0.013	0	24.5	21.1	50.3	96	85	0	39	36
2015	12	14	18	25	33	0.676	-0.085	3.786	0.01	0.007	0	24.1	20.2	50.7	95	84	0	39	37
2015	12	14	18	35	33	0.653	-0.128	3.786	0.01	0.007	0	24.1	20.2	71	95	83	0	39	36
2015	12	14	18	45	33	0.656	-0.075	3.783	0.01	0.007	0	22.8	19.4	51.6	93	82	0	40	37
2015	12	14	18	55	33	0.705	-0.082	3.786	0.01	0.007	0	23.2	19.8	49.9	93	82	0	39	36
2015	12	14	19	5	33	0.656	-0.092	3.786	0.01	0.007	0	23.2	19.4	49.5	93	82	0	39	37
2015	12	14	19	15	33	0.666	-0.079	3.786	0.01	0.007	0	23.2	19.4	62.4	93	81	0	39	36
2015	12	14	19	25	33	0.659	-0.102	3.786	0.01	0.007	0	22.8	19.4	59.3	92	81	0	39	36
2015	12	14	19	35	33	0.682	-0.079	3.786	0.01	0.007	0	22.4	18.9	69.7	92	81	0	40	37
2015	12	14	19	45	33	0.682	-0.095	3.786	0.01	0.007	0	22.4	18.9	70.1	91	80	0	39	36
2015	12	14	19	55	33	0.663	-0.075	3.786	0.01	0.007	0	22.4	18.9	62.4	91	80	0	39	36
2015	12	14	20	5	33	0.696	-0.085	3.789	0.01	0.007	0	22.8	19.8	55.5	93	82	0	40	36
2015	12	14	20	15	33	0.692	-0.115	3.786	0.01	0.007	0	22.4	18.9	53.3	91	80	0	39	36
2015	12	14	20	25	33	0.682	-0.092	3.786	0.01	0.007	0	23.2	19.8	50.7	93	82	0	39	36
2015	12	14	20	35	33	0.679	-0.131	3.786	0.01	0.007	0	22.8	19.8	52.5	93	82	0	40	36
2015	12	14	20	45	33	0.656	-0.089	3.786	0.01	0.007	0	23.2	19.8	49.5	93	82	0	39	36
2015	12	14	20	55	33	0.669	-0.128	3.786	0.01	0.007	0	22.8	19.4	51.2	92	81	0	39	36
2015	12	14	21	5	33	0.673	-0.102	3.786	0.01	0.007	0	23.2	19.8	53.3	93	81	0	39	35
2015	12	14	21	15	33	0.696	-0.105	3.789	0.013	0.01	0	21.9	18.9	62.4	91	80	0	40	36
2015	12	14	21	25	33	0.669	-0.075	3.786	0.01	0.007	0	22.4	18.5	53.8	91	80	0	39	37
2015	12	14	21	35	33	0.656	-0.128	3.789	0.01	0.007	0	21.9	18.5	66.2	91	80	0	40	37
2015	12	14	21	45	33	0.705	-0.115	3.789	0.01	0.007	0	22.4	18.9	66.7	91	80	0	39	36
2015	12	14	21	55	33	0.646	-0.115	3.789	0.01	0.007	0	22.8	18.5	73.1	92	80	0	39	37
2015	12	14	22	5	33	0.689	-0.128	3.786	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	14	22	15	33	0.663	-0.115	3.789	0.01	0.007	0	21.9	18.1	73.1	91	78	0	40	36
2015	12	14	22	25	33	0.692	-0.128	3.789	0.013	0.01	0	21.9	18.1	73.5	90	78	0	39	36
2015	12	14	22	35	33	0.692	-0.131	3.789	0.01	0.007	0	21.9	18.1	73.1	90	78	0	39	36
2015	12	14	22	45	33	0.705	-0.118	3.789	0.01	0.007	0	21.9	18.1	71.8	90	78	0	39	36
2015	12	14	22	55	33	0.705	-0.125	3.789	0.01	0.007	0	21.5	17.2	72.2	89	77	0	39	37
2015	12	14	23	5	33	0.676	-0.112	3.789	0.01	0.007	0	21.5	18.1	72.2	89	78	0	39	36
2015	12	14	23	15	33	0.686	-0.115	3.789	0.01	0.007	0	21.5	17.6	72.7	89	77	0	39	36
2015	12	14	23	25	33	0.676	-0.112	3.789	0.01	0.007	0	21.9	18.1	72.2	90	78	0	39	36
2015	12	14	23	35	33	0.666	-0.089	3.793	0.01	0.007	0	21.5	17.2	72.7	89	77	0	39	37
2015	12	14	23	45	33	0.689	-0.138	3.793	0.01	0.007	0	21.1	18.1	73.1	88	77	0	39	35
2015	12	14	23	55	33	0.719	-0.128	3.793	0.01	0.007	0	20.6	17.2	73.1	88	77	0	40	37
2015	12	15	0	5	33	0.679	-0.089	3.796	0.016	0.016	0	21.1	17.6	72.7	88	77	0	39	36
2015	12	15	0	15	33	0.692	-0.115	3.796	0.01	0.007	0	20.6	17.2	73.1	88	76	0	40	36
2015	12	15	0	25	33	0.689	-0.125	3.796	0.01	0.007	0	20.6	17.2	74	87	77	0	39	37
2015	12	15	0	35	33	0.682	-0.128	3.796	0.01	0.007	0	20.6	17.6	74	88	77	0	40	36
2015	12	15	0	45	33	0.682	-0.125	3.796	0.01	0.007	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	15	0	55	33	0.748	-0.141	3.799	0.013	0.01	0	21.1	17.2	74.4	88	77	0	39	37
2015	12	15	1	5	33	0.689	-0.125	3.793	0.01	0.007	0	21.1	17.2	69.2	88	77	0	39	37
2015	12	15	1	15	33	0.702	-0.108	3.796	0.01	0.007	0	21.9	18.1	73.1	90	78	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	1	25	33	0.663	-0.098	3.796	0.01	0.007	0	21.1	18.1	65.8	89	78	0	40	36
2015	12	15	1	35	33	0.676	-0.135	3.799	0.01	0.007	0	21.1	17.2	75.3	89	77	0	40	37
2015	12	15	1	45	33	0.666	-0.121	3.799	0.013	0.01	0	21.5	17.6	73.5	89	77	0	39	36
2015	12	15	1	55	33	0.702	-0.125	3.799	0.01	0.007	0	21.1	17.2	74.8	88	76	0	39	36
2015	12	15	2	5	33	0.715	-0.115	3.799	0.01	0.007	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	15	2	15	33	0.679	-0.128	3.796	0.01	0.007	0	21.5	18.1	57.6	89	78	0	39	36
2015	12	15	2	25	33	0.679	-0.105	3.799	0.01	0.007	0	20.6	17.2	70.1	88	77	0	40	37
2015	12	15	2	35	33	0.673	-0.092	3.799	0.01	0.007	0	21.1	17.6	74.4	88	77	0	39	36
2015	12	15	2	45	33	0.646	-0.108	3.799	0.01	0.007	0	21.5	17.6	65.8	89	78	0	39	37
2015	12	15	2	55	33	0.679	-0.128	3.799	0.01	0.007	0	21.1	17.2	60.6	88	77	0	39	37
2015	12	15	3	5	33	0.702	-0.105	3.799	0.01	0.007	0	21.1	17.2	71.8	88	77	0	39	37
2015	12	15	3	15	33	0.666	-0.108	3.799	0.013	0.01	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	15	3	25	33	0.646	-0.115	3.799	0.01	0.007	0	21.1	17.2	76.1	88	76	0	39	36
2015	12	15	3	35	33	0.676	-0.121	3.799	0.01	0.007	0	20.2	17.2	76.1	87	76	0	40	36
2015	12	15	3	45	33	0.689	-0.125	3.802	0.013	0.01	0	21.1	17.2	77	88	77	0	39	37
2015	12	15	3	55	33	0.696	-0.115	3.802	0.01	0.007	0	20.2	17.2	75.7	87	76	0	40	36
2015	12	15	4	5	33	0.679	-0.121	3.802	0.01	0.007	0	20.6	17.6	71.4	88	77	0	40	36
2015	12	15	4	15	33	0.686	-0.148	3.802	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	15	4	25	33	0.663	-0.089	3.802	0.013	0.01	0	20.2	16.8	77	87	75	0	40	36
2015	12	15	4	35	33	0.65	-0.128	3.802	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	15	4	45	33	0.712	-0.115	3.802	0.01	0.007	0	21.1	17.2	77	88	76	0	39	36
2015	12	15	4	55	33	0.689	-0.092	3.802	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	15	5	5	33	0.679	-0.115	3.802	0.013	0.01	0	20.6	16.8	77.4	88	77	0	40	38
2015	12	15	5	15	33	0.689	-0.112	3.802	0.01	0.007	0	20.6	17.2	77.4	88	76	0	40	36
2015	12	15	5	25	33	0.64	-0.108	3.802	0.01	0.007	0	20.6	17.2	77	87	76	0	39	36
2015	12	15	5	35	33	0.679	-0.102	3.802	0.01	0.007	0	20.2	17.2	77.4	87	76	0	40	36
2015	12	15	5	45	33	0.659	-0.102	3.802	0.013	0.01	0	20.6	17.6	64.9	88	77	0	40	36
2015	12	15	5	55	33	0.669	-0.102	3.802	0.01	0.007	0	20.2	17.6	62.8	87	77	0	40	36
2015	12	15	6	5	33	0.666	-0.115	3.802	0.01	0.007	0	21.9	17.6	73.1	90	78	0	39	37
2015	12	15	6	15	33	0.666	-0.115	3.802	0.01	0.007	0	21.5	17.6	61.9	89	78	0	39	37
2015	12	15	6	25	33	0.682	-0.098	3.802	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	15	6	35	33	0.666	-0.102	3.806	0.01	0.007	0	21.5	17.6	70.5	89	78	0	39	37
2015	12	15	6	45	33	0.689	-0.105	3.802	0.01	0.007	0	24.5	20.6	67.5	97	85	0	40	37
2015	12	15	6	55	33	0.728	-0.118	3.802	0.01	0.007	0	26.2	21.9	72.2	100	88	0	39	37
2015	12	15	7	5	33	0.696	-0.112	3.806	0.01	0.007	0	23.6	19.8	65.4	94	83	0	39	37
2015	12	15	7	15	33	0.65	-0.125	3.802	0.01	0.007	0	22.4	18.5	64.1	91	80	0	39	37
2015	12	15	7	25	33	0.712	-0.105	3.806	0.013	0.01	0	21.5	18.5	67.1	89	79	0	39	36
2015	12	15	7	35	33	0.679	-0.079	3.802	0.01	0.007	0	22.4	18.5	54.2	91	80	0	39	37
2015	12	15	7	45	33	0.712	-0.105	3.806	0.01	0.007	0	29.7	25.4	68.4	108	96	0	39	37
2015	12	15	7	55	33	0.696	-0.121	3.802	0.01	0.007	0	24.5	20.6	55	96	85	0	39	37
2015	12	15	8	5	33	0.715	-0.089	3.806	0.016	0.016	0	23.2	19.8	51.6	94	83	0	40	37
2015	12	15	8	15	33	0.673	-0.125	3.806	0.01	0.007	0	23.6	19.4	53.3	94	82	0	39	37
2015	12	15	8	25	33	0.696	-0.079	3.806	0.01	0.007	0	27.5	23.6	58.9	103	91	0	39	36
2015	12	15	8	35	33	0.679	-0.105	3.806	0.013	0.01	0	23.2	19.8	57.6	93	82	0	39	36
2015	12	15	8	45	33	0.686	-0.144	3.809	0.01	0.007	0	27.1	22.8	67.5	102	90	0	39	37
2015	12	15	8	55	33	0.689	-0.108	3.806	0.01	0.007	0	22.8	19.4	57.2	92	81	0	39	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	9	5	33	0.705	-0.095	3.809	0.01	0.007	0	21.9	18.9	50.7	91	80	0	40	36
2015	12	15	9	15	33	0.689	-0.092	3.809	0.01	0.007	0	22.4	18.9	50.3	91	80	0	39	36
2015	12	15	9	25	33	0.702	-0.089	3.809	0.01	0.007	0	22.8	18.9	50.7	93	81	0	40	37
2015	12	15	9	35	33	0.686	-0.105	3.809	0.013	0.01	0	24.5	21.1	47.7	96	85	0	39	36
2015	12	15	9	45	33	0.719	-0.089	3.809	0.01	0.007	0	27.1	23.2	49.9	102	91	0	39	37
2015	12	15	9	55	33	0.692	-0.112	3.812	0.01	0.007	0	27.5	23.6	49	104	92	0	40	37
2015	12	15	10	5	33	0.709	-0.118	3.812	0.01	0.007	0	29.2	25.4	48.6	108	96	0	40	37
2015	12	15	10	15	33	0.741	-0.118	3.809	0.01	0.007	0	31.4	27.5	47.3	112	100	0	39	36
2015	12	15	10	25	33	0.745	-0.082	3.812	0.01	0.007	0	32.7	28.4	46	115	103	0	39	37
2015	12	15	10	35	33	0.699	-0.082	3.812	0.01	0.007	0	34.4	30.5	47.3	119	107	0	39	36
2015	12	15	10	45	33	0.738	-0.069	3.812	0.01	0.007	0	34	29.7	48.2	118	105	0	39	36
2015	12	15	10	55	33	0.709	-0.089	3.816	0.01	0.007	0	33.5	28.8	47.3	117	104	0	39	37
2015	12	15	11	5	33	0.751	-0.098	3.812	0.01	0.007	0	33.1	29.7	49	117	105	0	40	36
2015	12	15	11	15	33	0.679	-0.098	3.812	0.01	0.007	0	32.7	29.2	46.4	116	104	0	40	36
2015	12	15	11	25	33	0.699	-0.108	3.816	0.013	0.01	0	33.5	28.4	47.7	116	103	0	38	37
2015	12	15	11	35	33	0.692	-0.095	3.816	0.01	0.007	0	32.3	28.8	48.2	114	103	0	39	36
2015	12	15	11	45	33	0.715	-0.108	3.816	0.01	0.007	0	32.3	27.5	48.6	114	101	0	39	37
2015	12	15	11	55	33	0.699	-0.092	3.816	0.01	0.007	0	30.5	27.1	48.2	111	99	0	40	36
2015	12	15	12	5	33	0.725	-0.089	3.816	0.01	0.007	0	30.1	25.8	50.7	109	97	0	39	37
2015	12	15	12	15	33	0.719	-0.085	3.819	0.01	0.007	0	28.8	25.4	47.7	107	95	0	40	36
2015	12	15	12	25	33	0.705	-0.075	3.819	0.01	0.007	0	28.4	24.5	48.6	106	94	0	40	37
2015	12	15	12	35	33	0.702	-0.075	3.819	0.01	0.007	0	28	24.1	49	104	92	0	39	36
2015	12	15	12	45	33	0.682	-0.072	3.816	0.01	0.007	0	33.5	28.8	47.3	117	104	0	39	37
2015	12	15	12	55	33	0.732	-0.089	3.819	0.01	0.007	0	31.4	27.1	47.3	112	100	0	39	37
2015	12	15	13	5	33	0.728	-0.089	3.819	0.01	0.007	0	31	27.5	47.7	112	100	0	40	36
2015	12	15	13	15	33	0.699	-0.075	3.819	0.01	0.007	0	31	27.1	47.7	111	99	0	39	36
2015	12	15	13	25	33	0.719	-0.089	3.819	0.01	0.007	0	28.4	24.1	48.6	105	93	0	39	37
2015	12	15	13	35	33	0.719	-0.089	3.819	0.013	0.01	0	28.4	24.1	49	105	93	0	39	37
2015	12	15	13	45	33	0.705	-0.085	3.819	0.01	0.007	0	27.5	23.6	48.2	103	91	0	39	36
2015	12	15	13	55	33	0.705	-0.072	3.819	0.01	0.007	0	27.1	23.2	49.5	102	90	0	39	36
2015	12	15	14	5	33	0.692	-0.095	3.822	0.01	0.007	0	28.4	24.5	48.6	105	93	0	39	36
2015	12	15	14	15	33	0.715	-0.092	3.819	0.01	0.007	0	27.1	23.2	49	102	90	0	39	36
2015	12	15	14	25	33	0.738	-0.115	3.822	0.01	0.007	0	26.7	23.2	47.3	102	90	0	40	36
2015	12	15	14	35	33	0.741	-0.072	3.822	0.013	0.01	0	29.2	24.9	48.6	107	94	0	39	36
2015	12	15	14	45	33	0.715	-0.089	3.822	0.013	0.01	0	26.7	22.8	49.9	101	89	0	39	36
2015	12	15	14	55	33	0.741	-0.072	3.822	0.013	0.01	0	26.7	22.8	48.6	102	90	0	40	37
2015	12	15	15	5	33	0.715	-0.112	3.822	0.01	0.007	0	26.7	22.4	48.2	100	88	0	38	36
2015	12	15	15	15	33	0.709	-0.098	3.822	0.01	0.007	0	25.8	21.9	49	99	87	0	39	36
2015	12	15	15	25	33	0.686	-0.059	3.822	0.01	0.007	0	24.5	21.1	48.6	96	85	0	39	36
2015	12	15	15	35	33	0.728	-0.089	3.822	0.01	0.007	0	24.5	21.1	49	97	85	0	40	36
2015	12	15	15	45	33	0.696	-0.085	3.822	0.013	0.01	0	24.9	21.1	49.9	97	85	0	39	36
2015	12	15	15	55	33	0.686	-0.115	3.822	0.01	0.007	0	24.1	19.8	50.7	95	83	0	39	37
2015	12	15	16	5	33	0.669	-0.115	3.825	0.01	0.007	0	24.5	20.6	52	96	85	0	39	37
2015	12	15	16	15	33	0.623	-0.079	3.825	0.013	0.01	0	24.1	20.2	58	95	83	0	39	36
2015	12	15	16	25	33	0.689	-0.105	3.825	0.01	0.007	0	22.8	19.8	53.8	93	82	0	40	36
2015	12	15	16	35	33	0.702	-0.105	3.825	0.01	0.007	0	24.5	20.2	55.9	96	84	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	15	16	45	33	0.689	-0.098	3.825	0.013	0.01	0	27.5	23.6	53.8	103	91	0	39	36
2015	12	15	16	55	33	0.702	-0.102	3.825	0.01	0.007	0	24.1	20.2	58	95	84	0	39	37
2015	12	15	17	5	33	0.627	-0.121	3.829	0.01	0.007	0	24.9	21.1	41.3	97	85	0	39	36
2015	12	15	17	15	33	0.614	-0.141	3.829	0.01	0.007	0	24.5	19.8	50.7	95	82	0	38	36
2015	12	15	17	25	33	0.676	-0.105	3.835	0.01	0.007	0	22.8	18.9	75.3	92	81	0	39	37
2015	12	15	17	35	33	0.692	-0.118	3.829	0.01	0.007	0	22.4	18.9	52.5	92	81	0	40	37
2015	12	15	17	45	33	0.679	-0.095	3.832	0.01	0.007	0	23.2	19.4	66.2	93	81	0	39	36
2015	12	15	17	55	33	0.696	-0.095	3.832	0.01	0.007	0	22.4	18.5	72.7	91	80	0	39	37
2015	12	15	18	5	33	0.696	-0.075	3.829	0.01	0.007	0	22.4	18.5	51.2	91	80	0	39	37
2015	12	15	18	15	33	0.673	-0.118	3.825	0.01	0.007	0	22.4	19.4	48.2	92	81	0	40	36
2015	12	15	18	25	33	0.663	-0.092	3.835	0.01	0.007	0	22.8	19.4	71.4	92	81	0	39	36
2015	12	15	18	35	33	0.689	-0.095	3.832	0.01	0.007	0	21.9	18.9	65.8	91	80	0	40	36
2015	12	15	18	45	33	0.705	-0.089	3.835	0.01	0.007	0	22.4	18.9	75.3	92	81	0	40	37
2015	12	15	18	55	33	0.689	-0.105	3.832	0.01	0.007	0	23.2	19.4	65.8	93	82	0	39	37
2015	12	15	19	5	33	0.673	-0.092	3.835	0.01	0.007	0	22.8	20.2	75.3	93	83	0	40	36
2015	12	15	19	15	33	0.699	-0.102	3.835	0.01	0.007	0	22.4	19.4	75.7	92	81	0	40	36
2015	12	15	19	25	33	0.656	-0.098	3.835	0.01	0.007	0	21.5	18.9	75.7	90	80	0	40	36
2015	12	15	19	35	33	0.653	-0.108	3.835	0.01	0.007	0	22.4	18.5	65.4	91	80	0	39	37
2015	12	15	19	45	33	0.676	-0.085	3.835	0.01	0.007	0	22.4	18.5	73.1	91	80	0	39	37
2015	12	15	19	55	33	0.666	-0.115	3.835	0.01	0.007	0	22.4	18.1	75.7	91	79	0	39	37
2015	12	15	20	5	33	0.666	-0.115	3.835	0.01	0.007	0	21.5	18.5	72.7	90	79	0	40	36
2015	12	15	20	15	33	0.666	-0.089	3.835	0.01	0.007	0	22.4	19.4	63.6	91	81	0	39	36
2015	12	15	20	25	33	0.656	-0.082	3.835	0.01	0.007	0	22.4	18.5	74	91	80	0	39	37
2015	12	15	20	35	33	0.699	-0.072	3.835	0.013	0.01	0	21.5	18.1	74	89	79	0	39	37
2015	12	15	20	45	33	0.653	-0.092	3.835	0.01	0.007	0	21.5	18.1	75.3	89	78	0	39	36
2015	12	15	20	55	33	0.663	-0.072	3.835	0.01	0.007	0	21.5	17.6	75.3	89	78	0	39	37
2015	12	15	21	5	33	0.64	-0.089	3.835	0.01	0.007	0	21.1	18.1	75.3	89	78	0	40	36
2015	12	15	21	15	33	0.676	-0.075	3.835	0.01	0.007	0	21.9	18.1	74.8	90	79	0	39	37
2015	12	15	21	25	33	0.702	-0.102	3.835	0.013	0.01	0	21.9	18.1	74.4	90	79	0	39	37
2015	12	15	21	35	33	0.676	-0.102	3.835	0.01	0.007	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	15	21	45	33	0.646	-0.098	3.835	0.01	0.007	0	22.4	18.9	76.1	91	79	0	39	35
2015	12	15	21	55	33	0.627	-0.102	3.835	0.013	0.01	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	15	22	5	33	0.682	-0.108	3.835	0.01	0.007	0	21.9	18.1	76.1	90	79	0	39	37
2015	12	15	22	15	33	0.676	-0.102	3.839	0.01	0.007	0	21.9	18.5	77	90	79	0	39	36
2015	12	15	22	25	33	0.666	-0.102	3.835	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	15	22	35	33	0.633	-0.075	3.835	0.01	0.007	0	21.1	17.6	74.4	89	78	0	40	37
2015	12	15	22	45	33	0.702	-0.092	3.835	0.01	0.007	0	21.5	17.6	72.7	89	77	0	39	36
2015	12	15	22	55	33	0.636	-0.085	3.835	0.013	0.01	0	21.1	17.6	72.2	89	78	0	40	37
2015	12	15	23	5	33	0.659	-0.089	3.835	0.01	0.007	0	20.6	17.2	70.1	88	77	0	40	37
2015	12	15	23	15	33	0.64	-0.128	3.835	0.01	0.007	0	21.5	18.1	76.1	89	78	0	39	36
2015	12	15	23	25	33	0.663	-0.115	3.839	0.01	0.007	0	21.5	18.1	77	89	79	0	39	37
2015	12	15	23	35	33	0.646	-0.072	3.839	0.01	0.007	0	21.1	18.1	78.3	89	78	0	40	36
2015	12	15	23	45	33	0.636	-0.102	3.839	0.016	0.013	0	21.5	18.1	77	89	79	0	39	37
2015	12	15	23	55	33	0.62	-0.039	3.839	0.01	0.007	0	21.9	18.5	77.4	91	80	0	40	37
2015	12	16	0	5	33	0.65	-0.102	3.839	0.01	0.007	0	21.9	18.5	77.4	90	80	0	39	37
2015	12	16	0	15	33	0.702	-0.089	3.839	0.01	0.007	0	21.1	17.6	76.1	88	78	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	0	25	33	0.676	-0.085	3.835	0.01	0.007	0	21.1	18.1	74	89	78	0	40	36
2015	12	16	0	35	33	0.663	-0.062	3.839	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	16	0	45	33	0.65	-0.085	3.839	0.013	0.01	0	21.1	18.1	77	89	78	0	40	36
2015	12	16	0	55	33	0.643	-0.059	3.839	0.01	0.007	0	21.1	17.6	77	88	78	0	39	37
2015	12	16	1	5	33	0.679	-0.052	3.839	0.01	0.007	0	20.6	17.6	76.1	87	78	0	39	37
2015	12	16	1	15	33	0.676	-0.075	3.839	0.01	0.007	0	21.5	18.1	74.4	89	79	0	39	37
2015	12	16	1	25	33	0.725	-0.115	3.839	0.01	0.007	0	24.5	20.6	74.8	96	85	0	39	37
2015	12	16	1	35	33	0.699	-0.075	3.839	0.01	0.007	0	22.4	19.4	74.4	91	81	0	39	36
2015	12	16	1	45	33	0.689	-0.043	3.839	0.01	0.007	0	22.8	18.9	76.1	92	81	0	39	37
2015	12	16	1	55	33	0.666	-0.089	3.839	0.01	0.007	0	22.4	18.9	74.4	91	80	0	39	36
2015	12	16	2	5	33	0.679	-0.089	3.839	0.013	0.01	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	16	2	15	33	0.699	-0.069	3.839	0.01	0.007	0	22.4	18.9	76.1	92	81	0	40	37
2015	12	16	2	25	33	0.686	-0.089	3.839	0.01	0.007	0	23.6	20.2	75.7	94	83	0	39	36
2015	12	16	2	35	33	0.633	-0.069	3.839	0.01	0.007	0	21.9	18.1	77.8	90	79	0	39	37
2015	12	16	2	45	33	0.673	-0.062	3.839	0.01	0.007	0	20.6	18.5	78.3	88	79	0	40	36
2015	12	16	2	55	33	0.659	-0.062	3.839	0.01	0.007	0	20.6	18.1	78.7	88	78	0	40	36
2015	12	16	3	5	33	0.65	-0.046	3.839	0.01	0.007	0	21.1	18.1	78.3	89	79	0	40	37
2015	12	16	3	15	33	0.646	-0.062	3.839	0.013	0.01	0	21.1	18.5	78.3	88	79	0	39	36
2015	12	16	3	25	33	0.656	-0.092	3.842	0.01	0.007	0	20.6	17.6	78.3	87	78	0	39	37
2015	12	16	3	35	33	0.673	-0.072	3.842	0.013	0.01	0	21.1	18.1	78.7	88	78	0	39	36
2015	12	16	3	45	33	0.65	-0.056	3.839	0.01	0.007	0	20.2	17.2	78.3	87	77	0	40	37
2015	12	16	3	55	33	0.653	-0.059	3.839	0.01	0.007	0	21.5	17.6	77.8	89	78	0	39	37
2015	12	16	4	5	33	0.63	-0.072	3.839	0.01	0.007	0	21.5	18.1	78.3	89	79	0	39	37
2015	12	16	4	15	33	0.682	-0.092	3.839	0.01	0.007	0	20.6	17.6	77.4	88	78	0	40	37
2015	12	16	4	25	33	0.673	-0.066	3.839	0.01	0.007	0	20.2	17.6	77	87	78	0	40	37
2015	12	16	4	35	33	0.692	-0.075	3.839	0.01	0.007	0	21.5	17.6	76.5	88	78	0	38	37
2015	12	16	4	45	33	0.656	-0.052	3.842	0.01	0.007	0	20.6	18.1	77.4	88	78	0	40	36
2015	12	16	4	55	33	0.666	-0.046	3.842	0.01	0.007	0	21.1	17.6	77	88	78	0	39	37
2015	12	16	5	5	33	0.679	-0.062	3.839	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	16	5	15	33	0.63	-0.066	3.839	0.01	0.007	0	20.6	17.2	77	87	77	0	39	37
2015	12	16	5	25	33	0.666	-0.092	3.842	0.013	0.01	0	21.1	17.2	77	88	77	0	39	37
2015	12	16	5	35	33	0.682	-0.085	3.839	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	16	5	45	33	0.666	-0.098	3.839	0.01	0.007	0	21.1	17.6	77	88	78	0	39	37
2015	12	16	5	55	33	0.682	-0.062	3.842	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	16	6	5	33	0.669	-0.052	3.842	0.01	0.007	0	20.6	17.6	77	88	78	0	40	37
2015	12	16	6	15	33	0.682	-0.079	3.839	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	16	6	25	33	0.669	-0.075	3.839	0.01	0.007	0	21.9	18.1	76.5	90	79	0	39	37
2015	12	16	6	35	33	0.682	-0.089	3.842	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	16	6	45	33	0.682	-0.046	3.839	0.01	0.007	0	22.4	18.9	75.3	91	80	0	39	36
2015	12	16	6	55	33	0.646	-0.043	3.842	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	16	7	5	33	0.63	-0.049	3.842	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	16	7	15	33	0.686	-0.072	3.842	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	16	7	25	33	0.663	-0.052	3.839	0.013	0.01	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	16	7	35	33	0.692	-0.066	3.842	0.01	0.007	0	20.6	17.6	74.8	88	78	0	40	37
2015	12	16	7	45	33	0.643	-0.066	3.842	0.016	0.013	0	21.1	18.1	75.7	89	79	0	40	37
2015	12	16	7	55	33	0.663	-0.059	3.842	0.013	0.01	0	20.6	17.6	75.3	88	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	8	5	33	0.673	-0.095	3.842	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	16	8	15	33	0.65	-0.066	3.842	0.01	0.007	0	21.1	17.6	75.7	88	78	0	39	37
2015	12	16	8	25	33	0.692	-0.072	3.842	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	16	8	35	33	0.63	-0.102	3.842	0.013	0.01	0	21.5	18.1	75.7	89	79	0	39	37
2015	12	16	8	45	33	0.643	-0.085	3.842	0.01	0.007	0	21.5	17.6	75.3	89	78	0	39	37
2015	12	16	8	55	33	0.656	-0.062	3.845	0.01	0.007	0	21.1	18.5	75.3	89	79	0	40	36
2015	12	16	9	5	33	0.646	-0.066	3.845	0.01	0.007	0	21.1	18.5	74.8	89	79	0	40	36
2015	12	16	9	15	33	0.65	-0.072	3.845	0.01	0.007	0	21.1	18.5	74.8	89	79	0	40	36
2015	12	16	9	25	33	0.682	-0.052	3.845	0.01	0.007	0	21.9	18.9	75.7	91	81	0	40	37
2015	12	16	9	35	33	0.696	-0.075	3.845	0.01	0.007	0	24.9	21.1	75.3	97	86	0	39	37
2015	12	16	9	45	33	0.666	-0.056	3.848	0.01	0.007	0	21.9	19.4	74.8	91	81	0	40	36
2015	12	16	9	55	33	0.666	-0.056	3.845	0.01	0.007	0	22.4	18.5	74.8	91	80	0	39	37
2015	12	16	10	5	33	0.669	-0.059	3.848	0.01	0.007	0	21.5	18.5	74.4	90	80	0	40	37
2015	12	16	10	15	33	0.633	-0.092	3.848	0.01	0.007	0	21.5	18.1	74.8	89	79	0	39	37
2015	12	16	10	25	33	0.663	-0.043	3.848	0.01	0.007	0	21.1	18.1	74.8	88	78	0	39	36
2015	12	16	10	35	33	0.669	-0.085	3.848	0.013	0.01	0	21.1	18.1	73.5	89	79	0	40	37
2015	12	16	10	45	33	0.62	-0.066	3.848	0.01	0.007	0	21.1	18.1	74.8	88	79	0	39	37
2015	12	16	10	55	33	0.65	-0.062	3.848	0.01	0.007	0	21.1	18.1	74.4	89	79	0	40	37
2015	12	16	11	5	33	0.636	-0.043	3.848	0.01	0.007	0	20.6	18.5	74.8	88	79	0	40	36
2015	12	16	11	15	33	0.669	-0.079	3.848	0.01	0.007	0	20.6	18.5	74	88	79	0	40	36
2015	12	16	11	25	33	0.676	-0.092	3.852	0.01	0.007	0	21.9	18.5	74.8	90	80	0	39	37
2015	12	16	11	35	33	0.63	-0.039	3.852	0.01	0.007	0	21.1	18.5	74.4	89	80	0	40	37
2015	12	16	11	45	33	0.679	-0.059	3.852	0.01	0.007	0	21.9	18.5	74.4	90	80	0	39	37
2015	12	16	11	55	33	0.653	-0.049	3.852	0.01	0.007	0	21.5	18.5	74.4	90	80	0	40	37
2015	12	16	12	5	33	0.63	-0.052	3.852	0.01	0.007	0	21.5	18.5	74	89	80	0	39	37
2015	12	16	12	15	33	0.65	-0.039	3.855	0.01	0.007	0	21.9	18.9	74	90	80	0	39	36
2015	12	16	12	25	33	0.627	-0.052	3.852	0.01	0.007	0	21.9	18.5	73.5	90	80	0	39	37
2015	12	16	12	35	33	0.656	-0.052	3.852	0.01	0.007	0	20.6	18.1	73.1	88	79	0	40	37
2015	12	16	12	45	33	0.636	-0.052	3.855	0.013	0.01	0	21.1	18.9	73.5	89	80	0	40	36
2015	12	16	12	55	33	0.643	-0.052	3.855	0.013	0.01	0	21.1	18.1	72.2	89	80	0	40	38
2015	12	16	13	5	33	0.656	-0.046	3.858	0.01	0.007	0	21.5	18.9	72.7	90	80	0	40	36
2015	12	16	13	15	33	0.646	-0.046	3.862	0.01	0.007	0	21.5	18.9	73.1	90	80	0	40	36
2015	12	16	13	25	33	0.646	-0.082	3.862	0.01	0.007	0	21.5	18.5	72.7	90	80	0	40	37
2015	12	16	13	35	33	0.686	-0.095	3.865	0.01	0.007	0	21.1	18.1	73.1	89	79	0	40	37
2015	12	16	13	45	33	0.653	-0.112	3.865	0.01	0.007	0	21.9	18.1	73.5	90	79	0	39	37
2015	12	16	13	55	33	0.65	-0.075	3.865	0.01	0.007	0	21.1	18.1	74	89	79	0	40	37
2015	12	16	14	5	33	0.656	-0.082	3.868	0.013	0.01	0	21.1	18.5	73.5	89	79	0	40	36
2015	12	16	14	15	33	0.712	-0.075	3.868	0.01	0.007	0	24.5	21.1	74	96	85	0	39	36
2015	12	16	14	25	33	0.689	-0.089	3.868	0.01	0.007	0	23.2	19.4	74	93	82	0	39	37
2015	12	16	14	35	33	0.673	-0.075	3.865	0.01	0.007	0	23.2	19.8	63.6	94	83	0	40	37
2015	12	16	14	45	33	0.692	-0.066	3.865	0.01	0.007	0	23.2	20.2	53.8	94	83	0	40	36
2015	12	16	14	55	33	0.607	-0.108	3.865	0.01	0.007	0	22.8	18.9	55	92	81	0	39	37
2015	12	16	15	5	33	0.682	-0.079	3.865	0.01	0.007	0	26.7	22.4	54.6	101	89	0	39	37
2015	12	16	15	15	33	0.699	-0.079	3.865	0.01	0.007	0	25.4	21.1	54.2	98	86	0	39	37
2015	12	16	15	25	33	0.673	-0.066	3.868	0.01	0.007	0	23.2	19.4	58.5	93	82	0	39	37
2015	12	16	15	35	33	0.659	-0.075	3.865	0.013	0.01	0	21.5	18.5	51.6	90	79	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	15	45	33	0.646	-0.095	3.868	0.01	0.007	0	20.6	17.6	64.1	88	78	0	40	37
2015	12	16	15	55	33	0.627	-0.075	3.868	0.013	0.01	0	20.2	17.6	73.5	87	78	0	40	37
2015	12	16	16	5	33	0.636	-0.026	3.868	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	16	16	15	33	0.696	-0.056	3.868	0.01	0.007	0	20.2	17.2	77.4	87	77	0	40	37
2015	12	16	16	25	33	0.663	-0.079	3.868	0.01	0.007	0	20.2	17.2	77	87	77	0	40	37
2015	12	16	16	35	33	0.745	-0.075	3.868	0.01	0.007	0	19.8	17.2	77	86	77	0	40	37
2015	12	16	16	45	33	0.64	-0.075	3.871	0.01	0.007	0	21.5	18.1	77.8	89	79	0	39	37
2015	12	16	16	55	33	0.702	-0.089	3.871	0.01	0.007	0	21.1	17.2	77.4	88	77	0	39	37
2015	12	16	17	5	33	0.676	-0.082	3.871	0.01	0.007	0	21.1	18.1	77.4	89	79	0	40	37
2015	12	16	17	15	33	0.587	-0.049	3.871	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	16	17	25	33	0.666	-0.082	3.871	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	16	17	35	33	0.699	-0.069	3.871	0.01	0.007	0	20.2	17.2	77.4	87	77	0	40	37
2015	12	16	17	45	33	0.676	-0.056	3.871	0.01	0.007	0	20.6	17.6	77.4	88	78	0	40	37
2015	12	16	17	55	33	0.682	-0.062	3.871	0.01	0.007	0	20.6	17.6	77.8	87	77	0	39	36
2015	12	16	18	5	33	0.696	-0.062	3.871	0.01	0.007	0	20.6	17.6	77.4	88	78	0	40	37
2015	12	16	18	15	33	0.653	-0.085	3.871	0.01	0.007	0	21.5	17.2	77.8	89	78	0	39	38
2015	12	16	18	25	33	0.679	-0.062	3.871	0.01	0.007	0	20.6	17.2	77.4	88	77	0	40	37
2015	12	16	18	35	33	0.659	-0.072	3.871	0.01	0.007	0	21.1	18.1	77	88	78	0	39	36
2015	12	16	18	45	33	0.643	-0.052	3.871	0.01	0.007	0	21.1	18.1	76.5	88	78	0	39	36
2015	12	16	18	55	33	0.673	-0.062	3.871	0.01	0.007	0	20.6	17.2	77	87	77	0	39	37
2015	12	16	19	5	33	0.659	-0.082	3.871	0.01	0.007	0	20.2	17.6	77	87	77	0	40	36
2015	12	16	19	15	33	0.682	-0.056	3.871	0.01	0.007	0	21.1	17.6	77.4	88	78	0	39	37
2015	12	16	19	25	33	0.682	-0.075	3.871	0.013	0.01	0	21.1	17.2	77.8	88	77	0	39	37
2015	12	16	19	35	33	0.656	-0.062	3.871	0.01	0.007	0	20.6	17.6	77	88	78	0	40	37
2015	12	16	19	45	33	0.63	-0.102	3.871	0.01	0.007	0	21.5	17.6	68.8	89	78	0	39	37
2015	12	16	19	55	33	0.689	-0.075	3.871	0.01	0.007	0	21.9	18.1	77.4	90	78	0	39	36
2015	12	16	20	5	33	0.682	-0.069	3.871	0.01	0.007	0	21.5	18.1	76.5	90	79	0	40	37
2015	12	16	20	15	33	0.64	-0.098	3.871	0.013	0.01	0	20.6	17.6	68.8	88	78	0	40	37
2015	12	16	20	25	33	0.692	-0.105	3.871	0.01	0.007	0	23.6	19.8	76.1	94	83	0	39	37
2015	12	16	20	35	33	0.712	-0.098	3.871	0.01	0.007	0	30.5	26.2	76.5	111	98	0	40	37
2015	12	16	20	45	33	0.696	-0.092	3.871	0.01	0.007	0	34	30.1	71.8	119	106	0	40	36
2015	12	16	20	55	33	0.712	-0.092	3.871	0.01	0.007	0	31.8	27.5	73.5	114	101	0	40	37
2015	12	16	21	5	33	0.732	-0.098	3.871	0.01	0.007	0	28	24.1	76.5	105	92	0	40	36
2015	12	16	21	15	33	0.715	-0.069	3.871	0.01	0.007	0	25.4	20.6	76.5	99	86	0	40	38
2015	12	16	21	25	33	0.712	-0.075	3.871	0.01	0.007	0	23.6	19.8	76.5	95	83	0	40	37
2015	12	16	21	35	33	0.712	-0.125	3.871	0.01	0.007	0	23.6	18.9	76.1	94	82	0	39	38
2015	12	16	21	45	33	0.692	-0.069	3.871	0.01	0.007	0	22.8	18.5	76.5	93	81	0	40	38
2015	12	16	21	55	33	0.689	-0.089	3.871	0.013	0.01	0	21.9	18.5	76.1	91	79	0	40	36
2015	12	16	22	5	33	0.669	-0.069	3.871	0.01	0.007	0	21.5	18.1	76.5	90	79	0	40	37
2015	12	16	22	15	33	0.682	-0.069	3.871	0.01	0.007	0	22.4	18.5	76.5	91	80	0	39	37
2015	12	16	22	25	33	0.696	-0.075	3.871	0.01	0.007	0	21.9	18.1	76.5	91	79	0	40	37
2015	12	16	22	35	33	0.696	-0.066	3.871	0.01	0.007	0	21.5	18.1	76.5	89	79	0	39	37
2015	12	16	22	45	33	0.702	-0.075	3.871	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	16	22	55	33	0.699	-0.069	3.871	0.01	0.007	0	21.9	18.1	76.1	90	79	0	39	37
2015	12	16	23	5	33	0.719	-0.085	3.871	0.01	0.007	0	22.4	18.9	75.7	92	80	0	40	36
2015	12	16	23	15	33	0.705	-0.075	3.871	0.01	0.007	0	21.5	18.1	75.7	89	79	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	16	23	25	33	0.679	-0.082	3.871	0.01	0.007	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	16	23	35	33	0.702	-0.082	3.871	0.01	0.007	0	20.6	17.6	75.3	88	78	0	40	37
2015	12	16	23	45	33	0.699	-0.079	3.871	0.01	0.007	0	21.1	17.6	75.7	88	78	0	39	37
2015	12	16	23	55	33	0.679	-0.075	3.871	0.013	0.01	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	17	0	5	33	0.696	-0.089	3.871	0.01	0.007	0	21.1	17.6	76.1	88	78	0	39	37
2015	12	17	0	15	33	0.656	-0.085	3.871	0.01	0.007	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	17	0	25	33	0.715	-0.075	3.871	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	17	0	35	33	0.646	-0.085	3.871	0.01	0.007	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	17	0	45	33	0.712	-0.102	3.871	0.01	0.007	0	21.1	17.2	74.8	89	78	0	40	38
2015	12	17	0	55	33	0.689	-0.089	3.871	0.01	0.007	0	21.5	17.6	75.3	89	78	0	39	37
2015	12	17	1	5	33	0.676	-0.066	3.871	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	17	1	15	33	0.686	-0.075	3.871	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	17	1	25	33	0.653	-0.059	3.871	0.01	0.007	0	20.6	18.1	74.8	88	78	0	40	36
2015	12	17	1	35	33	0.676	-0.062	3.871	0.01	0.007	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	17	1	45	33	0.689	-0.072	3.871	0.01	0.007	0	20.6	17.6	74.4	88	77	0	40	36
2015	12	17	1	55	33	0.676	-0.059	3.871	0.01	0.007	0	21.1	17.2	74.4	89	78	0	40	38
2015	12	17	2	5	33	0.725	-0.062	3.871	0.01	0.007	0	21.1	17.2	74.8	89	78	0	40	38
2015	12	17	2	15	33	0.65	-0.039	3.871	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	17	2	25	33	0.669	-0.062	3.871	0.01	0.007	0	21.1	17.6	74.4	89	78	0	40	37
2015	12	17	2	35	33	0.682	-0.069	3.875	0.01	0.007	0	21.1	17.6	74.8	88	78	0	39	37
2015	12	17	2	45	33	0.689	-0.089	3.871	0.01	0.007	0	21.1	17.2	74	89	78	0	40	38
2015	12	17	2	55	33	0.692	-0.085	3.871	0.01	0.007	0	21.9	18.5	74	91	80	0	40	37
2015	12	17	3	5	33	0.679	-0.089	3.871	0.01	0.007	0	21.5	18.1	74.4	90	79	0	40	37
2015	12	17	3	15	33	0.712	-0.075	3.871	0.01	0.007	0	21.5	18.5	74	90	80	0	40	37
2015	12	17	3	25	33	0.656	-0.079	3.871	0.01	0.007	0	21.1	18.1	73.5	89	79	0	40	37
2015	12	17	3	35	33	0.699	-0.062	3.871	0.01	0.007	0	21.1	17.6	73.5	89	78	0	40	37
2015	12	17	3	45	33	0.686	-0.089	3.871	0.01	0.007	0	20.6	18.1	74.4	88	78	0	40	36
2015	12	17	3	55	33	0.676	-0.108	3.871	0.016	0.013	0	21.1	17.6	74	88	78	0	39	37
2015	12	17	4	5	33	0.679	-0.075	3.871	0.013	0.01	0	21.1	17.6	73.5	89	78	0	40	37
2015	12	17	4	15	33	0.699	-0.105	3.871	0.01	0.007	0	21.5	17.2	73.1	89	77	0	39	37
2015	12	17	4	25	33	0.705	-0.075	3.871	0.01	0.007	0	21.1	18.5	74	89	79	0	40	36
2015	12	17	4	35	33	0.65	-0.082	3.871	0.01	0.007	0	21.5	17.6	73.5	90	79	0	40	38
2015	12	17	4	45	33	0.696	-0.082	3.871	0.01	0.007	0	20.6	17.2	73.1	88	77	0	40	37
2015	12	17	4	55	33	0.653	-0.066	3.871	0.01	0.007	0	21.1	17.6	73.1	89	78	0	40	37
2015	12	17	5	5	33	0.692	-0.079	3.871	0.01	0.007	0	21.5	17.6	73.1	89	78	0	39	37
2015	12	17	5	15	33	0.686	-0.069	3.871	0.01	0.007	0	21.1	17.6	73.5	89	78	0	40	37
2015	12	17	5	25	33	0.666	-0.069	3.871	0.013	0.01	0	21.5	18.1	72.7	89	79	0	39	37
2015	12	17	5	35	33	0.696	-0.082	3.871	0.01	0.007	0	21.1	18.1	72.7	89	78	0	40	36
2015	12	17	5	45	33	0.682	-0.072	3.871	0.01	0.007	0	20.6	17.6	72.2	88	78	0	40	37
2015	12	17	5	55	33	0.669	-0.075	3.871	0.01	0.007	0	21.5	17.6	72.2	89	78	0	39	37
2015	12	17	6	5	33	0.682	-0.095	3.875	0.01	0.007	0	21.1	18.1	71.8	89	79	0	40	37
2015	12	17	6	15	33	0.686	-0.059	3.875	0.01	0.007	0	21.5	18.5	72.2	90	79	0	40	36
2015	12	17	6	25	33	0.673	-0.075	3.875	0.01	0.007	0	21.5	17.6	72.7	90	79	0	40	38
2015	12	17	6	35	33	0.702	-0.072	3.875	0.01	0.007	0	21.5	18.5	72.2	90	80	0	40	37
2015	12	17	6	45	33	0.705	-0.102	3.875	0.01	0.007	0	21.9	18.5	72.2	91	80	0	40	37
2015	12	17	6	55	33	0.696	-0.089	3.875	0.01	0.007	0	21.5	18.5	71.8	90	80	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	7	5	33	0.689	-0.121	3.875	0.016	0.013	0	21.9	18.1	71.4	90	79	0	39	37
2015	12	17	7	15	33	0.692	-0.105	3.878	0.01	0.007	0	21.5	18.5	71.8	90	80	0	40	37
2015	12	17	7	25	33	0.719	-0.108	3.875	0.01	0.007	0	21.5	17.6	71.8	90	79	0	40	38
2015	12	17	7	35	33	0.65	-0.095	3.878	0.01	0.007	0	22.4	18.9	72.2	92	81	0	40	37
2015	12	17	7	45	33	0.722	-0.115	3.878	0.01	0.007	0	21.9	18.5	71.8	91	80	0	40	37
2015	12	17	7	55	33	0.705	-0.085	3.878	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	17	8	5	33	0.699	-0.098	3.878	0.01	0.007	0	21.5	18.5	71.8	90	80	0	40	37
2015	12	17	8	15	33	0.732	-0.092	3.881	0.01	0.007	0	21.5	18.5	72.2	90	80	0	40	37
2015	12	17	8	25	33	0.692	-0.115	3.878	0.01	0.007	0	21.5	18.1	72.2	90	79	0	40	37
2015	12	17	8	35	33	0.673	-0.102	3.878	0.01	0.007	0	21.5	18.5	72.2	90	80	0	40	37
2015	12	17	8	45	33	0.745	-0.082	3.881	0.01	0.007	0	21.5	17.6	72.7	90	79	0	40	38
2015	12	17	8	55	33	0.722	-0.095	3.878	0.01	0.007	0	21.5	18.5	72.7	90	80	0	40	37
2015	12	17	9	5	33	0.702	-0.095	3.881	0.01	0.007	0	21.9	18.9	72.2	90	80	0	39	36
2015	12	17	9	15	33	0.715	-0.098	3.881	0.01	0.007	0	22.4	18.9	71.4	91	81	0	39	37
2015	12	17	9	25	33	0.709	-0.072	3.881	0.01	0.007	0	21.9	18.9	71.8	91	81	0	40	37
2015	12	17	9	35	33	0.719	-0.098	3.881	0.01	0.007	0	22.4	19.4	72.2	92	82	0	40	37
2015	12	17	9	45	33	0.702	-0.066	3.881	0.01	0.007	0	22.8	18.9	72.2	92	81	0	39	37
2015	12	17	9	55	33	0.696	-0.102	3.881	0.01	0.007	0	21.5	18.9	73.1	90	81	0	40	37
2015	12	17	10	5	33	0.722	-0.112	3.881	0.01	0.007	0	21.9	18.5	73.1	91	80	0	40	37
2015	12	17	10	15	33	0.689	-0.108	3.885	0.01	0.007	0	21.9	18.9	72.7	91	81	0	40	37
2015	12	17	10	25	33	0.712	-0.112	3.885	0.013	0.01	0	21.5	18.5	73.1	90	80	0	40	37
2015	12	17	10	35	33	0.686	-0.082	3.885	0.01	0.007	0	21.5	18.5	72.2	90	80	0	40	37
2015	12	17	10	45	33	0.692	-0.062	3.881	0.01	0.007	0	21.5	18.9	72.7	90	80	0	40	36
2015	12	17	10	55	33	0.679	-0.092	3.885	0.01	0.007	0	22.4	18.5	72.7	91	80	0	39	37
2015	12	17	11	5	33	0.699	-0.059	3.885	0.01	0.007	0	21.5	18.1	72.2	90	79	0	40	37
2015	12	17	11	15	33	0.699	-0.079	3.885	0.01	0.007	0	22.4	18.9	72.7	91	81	0	39	37
2015	12	17	11	25	33	0.679	-0.095	3.885	0.01	0.007	0	21.9	19.4	72.2	91	81	0	40	36
2015	12	17	11	35	33	0.689	-0.135	3.885	0.01	0.007	0	21.5	18.1	72.2	90	79	0	40	37
2015	12	17	11	45	33	0.679	-0.112	3.881	0.013	0.01	0	21.9	18.1	71.8	90	79	0	39	37
2015	12	17	11	55	33	0.719	-0.115	3.885	0.01	0.007	0	24.9	21.1	71	98	87	0	40	38
2015	12	17	12	5	33	0.728	-0.098	3.885	0.01	0.007	0	24.9	21.1	72.7	97	86	0	39	37
2015	12	17	12	15	33	0.709	-0.105	3.888	0.01	0.007	0	25.8	22.4	72.7	100	89	0	40	37
2015	12	17	12	25	33	0.712	-0.128	3.891	0.01	0.007	0	24.5	20.6	73.1	96	85	0	39	37
2015	12	17	12	35	33	0.725	-0.095	3.888	0.01	0.007	0	23.6	19.8	72.7	94	83	0	39	37
2015	12	17	12	45	33	0.702	-0.098	3.891	0.01	0.007	0	22.8	18.9	73.5	92	81	0	39	37
2015	12	17	12	55	33	0.679	-0.092	3.891	0.01	0.007	0	21.9	18.5	73.5	91	80	0	40	37
2015	12	17	13	5	33	0.666	-0.082	3.891	0.01	0.007	0	21.5	18.1	73.5	90	80	0	40	38
2015	12	17	13	15	33	0.702	-0.095	3.891	0.01	0.007	0	21.5	18.5	72.7	90	80	0	40	37
2015	12	17	13	25	33	0.689	-0.062	3.891	0.01	0.007	0	21.5	18.5	73.1	90	80	0	40	37
2015	12	17	13	35	33	0.689	-0.118	3.894	0.01	0.007	0	21.5	18.9	72.7	90	81	0	40	37
2015	12	17	13	45	33	0.679	-0.075	3.894	0.01	0.007	0	21.5	18.5	74	89	80	0	39	37
2015	12	17	13	55	33	0.682	-0.115	3.894	0.01	0.007	0	21.5	18.9	75.3	90	80	0	40	36
2015	12	17	14	5	33	0.699	-0.108	3.894	0.01	0.007	0	21.9	18.9	74.4	91	81	0	40	37
2015	12	17	14	15	33	0.732	-0.098	3.894	0.01	0.007	0	22.4	18.5	74	91	80	0	39	37
2015	12	17	14	25	33	0.679	-0.092	3.894	0.01	0.007	0	21.5	18.5	74.8	90	80	0	40	37
2015	12	17	14	35	33	0.679	-0.108	3.894	0.01	0.007	0	21.5	17.6	69.7	89	79	0	39	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	14	45	33	0.689	-0.098	3.894	0.01	0.007	0	21.1	18.1	73.5	89	79	0	40	37
2015	12	17	14	55	33	0.676	-0.082	3.894	0.01	0.007	0	22.4	18.9	67.5	91	81	0	39	37
2015	12	17	15	5	33	0.689	-0.105	3.894	0.01	0.007	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	17	15	15	33	0.653	-0.082	3.894	0.01	0.007	0	21.9	18.5	72.7	91	80	0	40	37
2015	12	17	15	25	33	0.702	-0.098	3.891	0.01	0.007	0	23.2	19.8	59.3	94	83	0	40	37
2015	12	17	15	35	33	0.728	-0.089	3.891	0.01	0.007	0	23.2	19.4	55	94	82	0	40	37
2015	12	17	15	45	33	0.699	-0.085	3.894	0.01	0.007	0	21.5	18.1	64.9	90	79	0	40	37
2015	12	17	15	55	33	0.663	-0.098	3.894	0.01	0.007	0	21.1	18.5	76.1	89	79	0	40	36
2015	12	17	16	5	33	0.725	-0.102	3.894	0.013	0.01	0	24.1	20.2	76.5	96	84	0	40	37
2015	12	17	16	15	33	0.702	-0.092	3.894	0.01	0.007	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	17	16	25	33	0.679	-0.092	3.894	0.01	0.007	0	21.9	18.1	76.1	90	79	0	39	37
2015	12	17	16	35	33	0.702	-0.112	3.894	0.01	0.007	0	20.6	17.6	76.1	88	78	0	40	37
2015	12	17	16	45	33	0.679	-0.066	3.894	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	17	16	55	33	0.669	-0.075	3.894	0.01	0.007	0	21.1	17.2	76.1	88	77	0	39	37
2015	12	17	17	5	33	0.692	-0.079	3.894	0.01	0.007	0	21.1	17.6	77	89	78	0	40	37
2015	12	17	17	15	33	0.669	-0.056	3.894	0.01	0.007	0	21.1	17.6	76.5	88	78	0	39	37
2015	12	17	17	25	33	0.679	-0.118	3.894	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	17	17	35	33	0.689	-0.098	3.894	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	17	17	45	33	0.682	-0.069	3.894	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	17	17	55	33	0.676	-0.092	3.894	0.01	0.007	0	20.6	17.6	76.1	88	78	0	40	37
2015	12	17	18	5	33	0.699	-0.079	3.894	0.01	0.007	0	21.1	18.1	76.1	88	78	0	39	36
2015	12	17	18	15	33	0.679	-0.082	3.894	0.01	0.007	0	20.6	17.2	76.5	87	77	0	39	37
2015	12	17	18	25	33	0.676	-0.105	3.894	0.01	0.007	0	20.6	17.6	77	87	78	0	39	37
2015	12	17	18	35	33	0.712	-0.112	3.898	0.016	0.013	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	17	18	45	33	0.702	-0.089	3.894	0.01	0.007	0	20.2	17.6	77	87	78	0	40	37
2015	12	17	18	55	33	0.689	-0.121	3.898	0.01	0.007	0	20.6	17.6	77	87	78	0	39	37
2015	12	17	19	5	33	0.719	-0.141	3.894	0.013	0.01	0	20.2	17.6	77	87	77	0	40	36
2015	12	17	19	15	33	0.686	-0.092	3.898	0.01	0.007	0	21.1	17.6	76.5	88	78	0	39	37
2015	12	17	19	25	33	0.699	-0.112	3.894	0.01	0.007	0	21.5	18.1	76.1	89	79	0	39	37
2015	12	17	19	35	33	0.686	-0.095	3.894	0.01	0.007	0	20.2	17.6	76.5	87	78	0	40	37
2015	12	17	19	45	33	0.712	-0.112	3.894	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	17	19	55	33	0.705	-0.102	3.898	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	17	20	5	33	0.696	-0.112	3.894	0.013	0.01	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	17	20	15	33	0.738	-0.135	3.898	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	17	20	25	33	0.676	-0.121	3.894	0.01	0.007	0	20.2	17.6	76.5	87	78	0	40	37
2015	12	17	20	35	33	0.686	-0.079	3.898	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	17	20	45	33	0.676	-0.079	3.898	0.013	0.01	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	17	20	55	33	0.705	-0.075	3.898	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	17	21	5	33	0.709	-0.098	3.898	0.013	0.01	0	20.6	16.8	77.4	87	76	0	39	37
2015	12	17	21	15	33	0.669	-0.066	3.894	0.01	0.007	0	20.2	17.2	77	87	77	0	40	37
2015	12	17	21	25	33	0.669	-0.075	3.898	0.01	0.007	0	20.2	16.8	77	87	76	0	40	37
2015	12	17	21	35	33	0.666	-0.072	3.898	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	17	21	45	33	0.728	-0.089	3.898	0.01	0.007	0	29.2	24.9	77	108	95	0	40	37
2015	12	17	21	55	33	0.709	-0.098	3.898	0.01	0.007	0	25.8	21.5	77	99	87	0	39	37
2015	12	17	22	5	33	0.722	-0.075	3.898	0.01	0.007	0	22.4	18.9	77	92	81	0	40	37
2015	12	17	22	15	33	0.686	-0.102	3.898	0.01	0.007	0	21.1	17.6	77	89	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	17	22	25	33	0.686	-0.072	3.898	0.01	0.007	0	21.5	17.6	77	89	78	0	39	37
2015	12	17	22	35	33	0.676	-0.085	3.898	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	17	22	45	33	0.712	-0.079	3.898	0.01	0.007	0	21.5	17.6	76.5	90	78	0	40	37
2015	12	17	22	55	33	0.64	-0.069	3.898	0.01	0.007	0	20.6	16.8	77	88	77	0	40	38
2015	12	17	23	5	33	0.666	-0.079	3.898	0.01	0.007	0	21.5	17.2	77.8	89	77	0	39	37
2015	12	17	23	15	33	0.686	-0.131	3.898	0.01	0.007	0	20.6	17.6	77	88	77	0	40	36
2015	12	17	23	25	33	0.738	-0.095	3.898	0.013	0.01	0	20.2	16.8	77.4	87	76	0	40	37
2015	12	17	23	35	33	0.646	-0.069	3.898	0.013	0.01	0	21.5	17.6	76.5	89	78	0	39	37
2015	12	17	23	45	33	0.699	-0.075	3.898	0.01	0.007	0	20.6	16.8	77	88	77	0	40	38
2015	12	17	23	55	33	0.702	-0.105	3.898	0.01	0.007	0	21.1	18.1	77	89	78	0	40	36
2015	12	18	0	5	33	0.643	-0.082	3.898	0.01	0.007	0	21.1	17.2	77.4	88	77	0	39	37
2015	12	18	0	15	33	0.686	-0.072	3.898	0.013	0.01	0	20.6	16.8	77	87	76	0	39	37
2015	12	18	0	25	33	0.669	-0.056	3.898	0.01	0.007	0	20.6	17.6	77	88	77	0	40	36
2015	12	18	0	35	33	0.679	-0.049	3.898	0.01	0.007	0	20.6	17.2	77.4	88	77	0	40	37
2015	12	18	0	45	33	0.709	-0.098	3.898	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	18	0	55	33	0.673	-0.072	3.898	0.01	0.007	0	21.1	16.8	77	88	77	0	39	38
2015	12	18	1	5	33	0.673	-0.098	3.898	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	18	1	15	33	0.666	-0.085	3.898	0.01	0.007	0	20.2	16.8	76.1	87	77	0	40	38
2015	12	18	1	25	33	0.679	-0.102	3.898	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	18	1	35	33	0.656	-0.072	3.898	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	18	1	45	33	0.663	-0.092	3.898	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	18	1	55	33	0.699	-0.049	3.898	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	18	2	5	33	0.659	-0.075	3.898	0.01	0.007	0	21.1	17.6	76.1	88	78	0	39	37
2015	12	18	2	15	33	0.682	-0.069	3.898	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	18	2	25	33	0.656	-0.062	3.898	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	18	2	35	33	0.669	-0.092	3.898	0.01	0.007	0	20.6	18.1	76.1	88	78	0	40	36
2015	12	18	2	45	33	0.712	-0.095	3.898	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	18	2	55	33	0.659	-0.066	3.898	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	18	3	5	33	0.659	-0.062	3.898	0.01	0.007	0	21.1	17.6	75.7	88	78	0	39	37
2015	12	18	3	15	33	0.659	-0.092	3.898	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	18	3	25	33	0.63	-0.043	3.898	0.01	0.007	0	21.1	18.5	75.7	89	79	0	40	36
2015	12	18	3	35	33	0.689	-0.062	3.898	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	18	3	45	33	0.699	-0.085	3.898	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	18	3	55	33	0.669	-0.082	3.898	0.01	0.007	0	21.1	17.2	75.3	89	78	0	40	38
2015	12	18	4	5	33	0.682	-0.069	3.898	0.01	0.007	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	18	4	15	33	0.666	-0.079	3.898	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	18	4	25	33	0.696	-0.072	3.898	0.01	0.007	0	21.5	17.6	75.3	90	78	0	40	37
2015	12	18	4	35	33	0.673	-0.062	3.898	0.01	0.007	0	21.1	18.1	76.1	89	79	0	40	37
2015	12	18	4	45	33	0.686	-0.085	3.898	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	18	4	55	33	0.659	-0.095	3.898	0.01	0.007	0	21.5	17.6	75.3	90	78	0	40	37
2015	12	18	5	5	33	0.686	-0.085	3.898	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	18	5	15	33	0.673	-0.072	3.901	0.01	0.007	0	21.5	17.2	74.4	90	78	0	40	38
2015	12	18	5	25	33	0.669	-0.085	3.898	0.01	0.007	0	21.1	17.6	74.8	89	79	0	40	38
2015	12	18	5	35	33	0.646	-0.069	3.901	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	18	5	45	33	0.653	-0.085	3.901	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	18	5	55	33	0.659	-0.069	3.901	0.01	0.007	0	20.6	17.2	74.8	88	78	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	6	5	33	0.673	-0.079	3.901	0.01	0.007	0	20.6	17.2	74.4	88	77	0	40	37
2015	12	18	6	15	33	0.702	-0.095	3.901	0.01	0.007	0	20.6	17.2	74.8	88	77	0	40	37
2015	12	18	6	25	33	0.676	-0.072	3.901	0.013	0.01	0	21.5	17.6	74.4	89	78	0	39	37
2015	12	18	6	35	33	0.636	-0.075	3.904	0.01	0.007	0	21.1	17.6	74.4	89	78	0	40	37
2015	12	18	6	45	33	0.682	-0.072	3.901	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	18	6	55	33	0.676	-0.062	3.904	0.01	0.007	0	20.6	17.6	73.5	88	78	0	40	37
2015	12	18	7	5	33	0.666	-0.049	3.904	0.01	0.007	0	21.1	17.2	74	89	78	0	40	38
2015	12	18	7	15	33	0.666	-0.069	3.904	0.01	0.007	0	20.6	16.8	73.5	88	77	0	40	38
2015	12	18	7	25	33	0.659	-0.052	3.904	0.01	0.007	0	21.1	17.6	73.5	89	78	0	40	37
2015	12	18	7	35	33	0.689	-0.082	3.904	0.01	0.007	0	23.6	19.8	73.1	95	83	0	40	37
2015	12	18	7	45	33	0.689	-0.098	3.904	0.01	0.007	0	24.1	20.2	72.7	96	84	0	40	37
2015	12	18	7	55	33	0.709	-0.072	3.904	0.01	0.007	0	25.4	21.1	74	98	86	0	39	37
2015	12	18	8	5	33	0.682	-0.098	3.904	0.01	0.007	0	25.4	21.9	73.5	99	87	0	40	36
2015	12	18	8	15	33	0.732	-0.108	3.907	0.01	0.007	0	27.5	23.6	73.5	104	92	0	40	37
2015	12	18	8	25	33	0.679	-0.062	3.907	0.01	0.007	0	24.1	20.2	73.5	96	84	0	40	37
2015	12	18	8	35	33	0.636	-0.098	3.907	0.01	0.007	0	21.5	18.5	73.1	90	81	0	40	38
2015	12	18	8	45	33	0.686	-0.069	3.907	0.01	0.007	0	22.4	19.4	73.5	92	82	0	40	37
2015	12	18	8	55	33	0.646	-0.049	3.907	0.01	0.007	0	24.5	20.6	74	97	86	0	40	38
2015	12	18	9	5	33	0.673	-0.062	3.907	0.01	0.007	0	22.8	19.4	74	93	82	0	40	37
2015	12	18	9	15	33	0.636	-0.075	3.907	0.01	0.007	0	22.4	18.9	74	91	81	0	39	37
2015	12	18	9	25	33	0.646	-0.085	3.907	0.01	0.007	0	22.4	18.9	74.4	91	81	0	39	37
2015	12	18	9	35	33	0.676	-0.052	3.907	0.01	0.007	0	21.1	18.5	74.4	89	79	0	40	36
2015	12	18	9	45	33	0.686	-0.089	3.911	0.01	0.007	0	21.5	18.5	74.4	89	79	0	39	36
2015	12	18	9	55	33	0.64	-0.062	3.907	0.01	0.007	0	21.1	17.6	73.1	89	79	0	40	38
2015	12	18	10	5	33	0.709	-0.059	3.911	0.01	0.007	0	21.1	17.6	74	89	78	0	40	37
2015	12	18	10	15	33	0.666	-0.072	3.911	0.01	0.007	0	20.6	17.6	74	88	78	0	40	37
2015	12	18	10	25	33	0.696	-0.092	3.911	0.01	0.007	0	21.1	17.6	74.4	89	79	0	40	38
2015	12	18	10	35	33	0.666	-0.056	3.911	0.01	0.007	0	21.5	17.2	74.8	89	78	0	39	38
2015	12	18	10	45	33	0.653	-0.102	3.907	0.01	0.007	0	21.1	18.1	74.4	89	79	0	40	37
2015	12	18	10	55	33	0.673	-0.062	3.911	0.01	0.007	0	20.6	17.6	73.5	88	78	0	40	37
2015	12	18	11	5	33	0.64	-0.043	3.911	0.01	0.007	0	21.1	18.1	74.4	89	79	0	40	37
2015	12	18	11	15	33	0.65	-0.082	3.911	0.013	0.01	0	21.5	18.9	72.7	90	80	0	40	36
2015	12	18	11	25	33	0.709	-0.072	3.911	0.01	0.007	0	21.1	18.5	74	89	79	0	40	36
2015	12	18	11	35	33	0.679	-0.089	3.911	0.01	0.007	0	21.1	18.1	74	89	79	0	40	37
2015	12	18	11	45	33	0.682	-0.072	3.911	0.01	0.007	0	21.9	18.5	73.1	90	80	0	39	37
2015	12	18	11	55	33	0.666	-0.092	3.911	0.01	0.007	0	21.9	18.1	74	90	79	0	39	37
2015	12	18	12	5	33	0.676	-0.089	3.911	0.01	0.007	0	21.1	18.1	74	89	79	0	40	37
2015	12	18	12	15	33	0.656	-0.072	3.911	0.01	0.007	0	21.5	18.1	74	90	79	0	40	37
2015	12	18	12	25	33	0.692	-0.089	3.911	0.01	0.007	0	21.9	18.1	68.4	90	79	0	39	37
2015	12	18	12	35	33	0.669	-0.066	3.911	0.01	0.007	0	21.9	18.5	67.1	90	80	0	39	37
2015	12	18	12	45	33	0.669	-0.066	3.911	0.013	0.01	0	21.5	18.9	62.4	90	81	0	40	37
2015	12	18	12	55	33	0.64	-0.056	3.907	0.01	0.007	0	21.9	18.9	54.2	91	81	0	40	37
2015	12	18	13	5	33	0.673	-0.085	3.907	0.01	0.007	0	25.4	21.5	55.9	99	87	0	40	37
2015	12	18	13	15	33	0.719	-0.095	3.907	0.01	0.007	0	26.2	22.4	49.9	101	89	0	40	37
2015	12	18	13	25	33	0.676	-0.062	3.907	0.01	0.007	0	24.5	20.2	48.2	96	84	0	39	37
2015	12	18	13	35	33	0.65	-0.052	3.907	0.01	0.007	0	23.6	19.4	49.9	94	83	0	39	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	13	45	33	0.633	-0.049	3.911	0.01	0.007	0	23.2	19.8	45.2	94	83	0	40	37
2015	12	18	13	55	33	0.62	-0.079	3.911	0.01	0.007	0	23.2	19.8	52.5	94	83	0	40	37
2015	12	18	14	5	33	0.643	-0.066	3.911	0.01	0.007	0	23.2	19.4	46.9	94	82	0	40	37
2015	12	18	14	15	33	0.65	-0.052	3.911	0.01	0.007	0	23.6	19.4	48.6	94	82	0	39	37
2015	12	18	14	25	33	0.669	-0.072	3.907	0.01	0.007	0	22.8	19.4	49.5	93	82	0	40	37
2015	12	18	14	35	33	0.653	-0.049	3.911	0.01	0.007	0	22.8	19.4	49.9	93	82	0	40	37
2015	12	18	14	45	33	0.64	-0.069	3.911	0.01	0.007	0	23.2	19.4	52	93	82	0	39	37
2015	12	18	14	55	33	0.682	-0.072	3.911	0.013	0.01	0	23.2	18.9	49.5	93	82	0	39	38
2015	12	18	15	5	33	0.653	-0.072	3.907	0.01	0.007	0	22.8	19.4	49.5	93	82	0	40	37
2015	12	18	15	15	33	0.646	-0.072	3.911	0.01	0.007	0	22.8	19.4	49	93	82	0	40	37
2015	12	18	15	25	33	0.636	-0.075	3.911	0.01	0.007	0	22.4	19.4	49.9	92	82	0	40	37
2015	12	18	15	35	33	0.656	-0.089	3.907	0.01	0.007	0	22.8	18.9	55	93	81	0	40	37
2015	12	18	15	45	33	0.656	-0.085	3.911	0.01	0.007	0	22.8	18.9	58.5	93	81	0	40	37
2015	12	18	15	55	33	0.725	-0.108	3.914	0.01	0.007	0	24.5	20.6	72.7	97	85	0	40	37
2015	12	18	16	5	33	0.705	-0.115	3.917	0.01	0.007	0	23.6	19.4	72.7	94	82	0	39	37
2015	12	18	16	15	33	0.709	-0.079	3.917	0.01	0.007	0	22.4	18.9	72.7	92	81	0	40	37
2015	12	18	16	25	33	0.689	-0.098	3.914	0.01	0.007	0	22.4	18.9	72.2	92	81	0	40	37
2015	12	18	16	35	33	0.676	-0.069	3.917	0.01	0.007	0	21.9	18.9	73.1	91	80	0	40	36
2015	12	18	16	45	33	0.712	-0.089	3.917	0.01	0.007	0	21.9	18.9	72.7	91	80	0	40	36
2015	12	18	16	55	33	0.656	-0.079	3.917	0.01	0.007	0	21.5	18.1	72.2	90	79	0	40	37
2015	12	18	17	5	33	0.709	-0.085	3.917	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	18	17	15	33	0.696	-0.075	3.921	0.01	0.007	0	22.4	18.5	73.1	91	80	0	39	37
2015	12	18	17	25	33	0.699	-0.072	3.917	0.01	0.007	0	21.5	18.5	72.2	90	80	0	40	37
2015	12	18	17	35	33	0.673	-0.082	3.917	0.01	0.007	0	21.9	18.1	72.2	91	80	0	40	38
2015	12	18	17	45	33	0.702	-0.095	3.917	0.01	0.007	0	21.9	18.5	71.8	91	80	0	40	37
2015	12	18	17	55	33	0.692	-0.095	3.917	0.01	0.007	0	21.9	18.5	72.7	91	80	0	40	37
2015	12	18	18	5	33	0.689	-0.098	3.917	0.01	0.007	0	21.1	18.5	72.2	90	80	0	41	37
2015	12	18	18	15	33	0.689	-0.062	3.921	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	18	18	25	33	0.709	-0.089	3.917	0.01	0.007	0	21.9	18.1	72.2	90	79	0	39	37
2015	12	18	18	35	33	0.696	-0.049	3.917	0.01	0.007	0	21.9	18.1	72.2	90	79	0	39	37
2015	12	18	18	45	33	0.669	-0.112	3.921	0.01	0.007	0	22.4	18.1	72.7	91	79	0	39	37
2015	12	18	18	55	33	0.692	-0.131	3.921	0.01	0.007	0	21.5	17.6	72.2	90	78	0	40	37
2015	12	18	19	5	33	0.659	-0.072	3.917	0.01	0.007	0	21.5	18.5	71.8	90	79	0	40	36
2015	12	18	19	15	33	0.705	-0.075	3.921	0.01	0.007	0	21.9	18.1	72.7	91	80	0	40	38
2015	12	18	19	25	33	0.682	-0.075	3.921	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	18	19	35	33	0.696	-0.072	3.921	0.01	0.007	0	21.9	18.1	72.2	90	79	0	39	37
2015	12	18	19	45	33	0.682	-0.095	3.917	0.01	0.007	0	21.5	18.1	72.2	90	79	0	40	37
2015	12	18	19	55	33	0.699	-0.098	3.921	0.01	0.007	0	21.5	17.6	72.7	90	78	0	40	37
2015	12	18	20	5	33	0.682	-0.095	3.921	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	18	20	15	33	0.676	-0.098	3.921	0.01	0.007	0	21.1	17.6	72.2	89	78	0	40	37
2015	12	18	20	25	33	0.656	-0.079	3.921	0.013	0.01	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	18	20	35	33	0.705	-0.105	3.921	0.01	0.007	0	21.5	17.6	73.1	90	79	0	40	38
2015	12	18	20	45	33	0.669	-0.066	3.921	0.01	0.007	0	21.5	18.1	73.5	90	79	0	40	37
2015	12	18	20	55	33	0.656	-0.069	3.921	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	18	21	5	33	0.659	-0.079	3.921	0.013	0.01	0	21.5	18.1	74	90	79	0	40	37
2015	12	18	21	15	33	0.732	-0.118	3.921	0.013	0.01	0	23.6	19.8	74	94	83	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	18	21	25	33	0.715	-0.092	3.921	0.01	0.007	0	22.8	18.9	73.5	93	81	0	40	37
2015	12	18	21	35	33	0.709	-0.059	3.921	0.01	0.007	0	22.4	18.1	73.1	91	79	0	39	37
2015	12	18	21	45	33	0.682	-0.112	3.921	0.01	0.007	0	25.4	21.5	73.1	99	87	0	40	37
2015	12	18	21	55	33	0.732	-0.049	3.921	0.01	0.007	0	23.2	19.8	74	94	82	0	40	36
2015	12	18	22	5	33	0.709	-0.095	3.921	0.01	0.007	0	22.4	18.9	73.1	92	81	0	40	37
2015	12	18	22	15	33	0.673	-0.056	3.921	0.01	0.007	0	22.8	19.4	72.2	93	82	0	40	37
2015	12	18	22	25	33	0.699	-0.062	3.924	0.01	0.007	0	22.4	18.5	74	91	80	0	39	37
2015	12	18	22	35	33	0.696	-0.072	3.924	0.013	0.01	0	21.5	17.6	74	90	78	0	40	37
2015	12	18	22	45	33	0.669	-0.072	3.924	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	18	22	55	33	0.65	-0.069	3.924	0.01	0.007	0	21.5	17.6	73.1	89	78	0	39	37
2015	12	18	23	5	33	0.64	-0.059	3.924	0.01	0.007	0	21.9	18.1	74.8	90	79	0	39	37
2015	12	18	23	15	33	0.646	-0.066	3.924	0.01	0.007	0	21.1	18.5	74.4	89	79	0	40	36
2015	12	18	23	25	33	0.686	-0.079	3.924	0.01	0.007	0	21.5	17.6	74.8	90	78	0	40	37
2015	12	18	23	35	33	0.699	-0.072	3.924	0.01	0.007	0	21.9	18.5	74.4	91	80	0	40	37
2015	12	18	23	45	33	0.692	-0.043	3.924	0.01	0.007	0	21.1	17.6	74.4	88	78	0	39	37
2015	12	18	23	55	33	0.633	-0.036	3.924	0.01	0.007	0	21.5	17.6	75.3	90	79	0	40	38
2015	12	19	0	5	33	0.696	-0.095	3.924	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	19	0	15	33	0.63	-0.059	3.924	0.01	0.007	0	21.9	18.5	74.8	91	80	0	40	37
2015	12	19	0	25	33	0.669	-0.052	3.927	0.013	0.01	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	19	0	35	33	0.705	-0.059	3.924	0.01	0.007	0	20.6	17.6	75.3	88	78	0	40	37
2015	12	19	0	45	33	0.699	-0.092	3.927	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	19	0	55	33	0.696	-0.082	3.927	0.01	0.007	0	20.6	17.6	75.7	88	77	0	40	36
2015	12	19	1	5	33	0.689	-0.085	3.927	0.016	0.013	0	21.1	17.2	75.3	88	77	0	39	37
2015	12	19	1	15	33	0.686	-0.052	3.924	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	19	1	25	33	0.669	-0.079	3.927	0.01	0.007	0	21.1	18.1	75.7	89	78	0	40	36
2015	12	19	1	35	33	0.656	-0.062	3.927	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	19	1	45	33	0.669	-0.089	3.927	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	19	1	55	33	0.686	-0.049	3.927	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	19	2	5	33	0.656	-0.072	3.927	0.01	0.007	0	21.1	17.2	76.5	89	77	0	40	37
2015	12	19	2	15	33	0.699	-0.039	3.927	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	19	2	25	33	0.692	-0.115	3.927	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	19	2	35	33	0.682	-0.062	3.93	0.01	0.007	0	21.1	18.1	76.1	89	78	0	40	36
2015	12	19	2	45	33	0.673	-0.075	3.927	0.01	0.007	0	20.6	17.6	76.1	88	77	0	40	36
2015	12	19	2	55	33	0.653	-0.092	3.93	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	19	3	5	33	0.659	-0.085	3.93	0.01	0.007	0	21.1	17.2	76.5	89	77	0	40	37
2015	12	19	3	15	33	0.65	-0.059	3.927	0.016	0.013	0	21.1	17.2	76.5	89	77	0	40	37
2015	12	19	3	25	33	0.669	-0.092	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	19	3	35	33	0.705	-0.079	3.93	0.01	0.007	0	21.5	16.8	77	89	77	0	39	38
2015	12	19	3	45	33	0.65	-0.085	3.93	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	19	3	55	33	0.633	-0.089	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	19	4	5	33	0.705	-0.085	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	19	4	15	33	0.659	-0.079	3.93	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	19	4	25	33	0.702	-0.085	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	19	4	35	33	0.669	-0.098	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	19	4	45	33	0.663	-0.082	3.93	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	19	4	55	33	0.686	-0.089	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	5	5	33	0.686	-0.069	3.93	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	19	5	15	33	0.62	-0.089	3.93	0.01	0.007	0	20.2	17.2	75.7	87	76	0	40	36
2015	12	19	5	25	33	0.633	-0.059	3.93	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	19	5	35	33	0.669	-0.059	3.93	0.01	0.007	0	20.6	16.8	75.3	88	77	0	40	38
2015	12	19	5	45	33	0.65	-0.089	3.93	0.013	0.01	0	20.2	16.8	75.7	87	77	0	40	38
2015	12	19	5	55	33	0.623	-0.059	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	19	6	5	33	0.623	-0.039	3.93	0.01	0.007	0	20.2	17.6	76.1	87	77	0	40	36
2015	12	19	6	15	33	0.636	-0.049	3.93	0.013	0.01	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	19	6	25	33	0.653	-0.066	3.93	0.01	0.007	0	19.8	16.8	75.3	87	77	0	41	38
2015	12	19	6	35	33	0.653	-0.056	3.93	0.01	0.007	0	20.6	16.8	75.3	87	76	0	39	37
2015	12	19	6	45	33	0.679	-0.072	3.93	0.01	0.007	0	20.6	16.8	75.7	87	76	0	39	37
2015	12	19	6	55	33	0.633	-0.049	3.93	0.01	0.007	0	20.6	17.2	75.3	87	77	0	39	37
2015	12	19	7	5	33	0.669	-0.072	3.934	0.01	0.007	0	20.6	17.2	75.7	87	77	0	39	37
2015	12	19	7	15	33	0.682	-0.062	3.93	0.013	0.01	0	19.8	16.3	75.3	86	74	0	40	36
2015	12	19	7	25	33	0.682	-0.062	3.93	0.013	0.01	0	21.1	18.1	74.4	89	78	0	40	36
2015	12	19	7	35	33	0.699	-0.108	3.934	0.01	0.007	0	22.4	18.5	75.3	92	80	0	40	37
2015	12	19	7	45	33	0.673	-0.089	3.934	0.01	0.007	0	20.6	16.8	75.3	88	77	0	40	38
2015	12	19	7	55	33	0.659	-0.056	3.934	0.01	0.007	0	20.6	16.8	74.8	88	77	0	40	38
2015	12	19	8	5	33	0.656	-0.069	3.934	0.01	0.007	0	20.6	17.6	74.8	88	78	0	40	37
2015	12	19	8	15	33	0.696	-0.062	3.934	0.01	0.007	0	20.6	17.6	74.8	88	78	0	40	37
2015	12	19	8	25	33	0.646	-0.066	3.934	0.01	0.007	0	21.5	18.5	74.8	90	80	0	40	37
2015	12	19	8	35	33	0.686	-0.062	3.934	0.01	0.007	0	21.1	17.6	74.8	88	78	0	39	37
2015	12	19	8	45	33	0.692	-0.072	3.934	0.01	0.007	0	20.6	18.1	75.3	88	78	0	40	36
2015	12	19	8	55	33	0.666	-0.069	3.934	0.01	0.007	0	20.2	17.2	74.8	87	77	0	40	37
2015	12	19	9	5	33	0.64	-0.089	3.934	0.01	0.007	0	20.2	18.1	75.7	87	78	0	40	36
2015	12	19	9	15	33	0.63	-0.062	3.934	0.01	0.007	0	20.6	17.2	75.3	87	77	0	39	37
2015	12	19	9	25	33	0.666	-0.059	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	19	9	35	33	0.659	-0.056	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	19	9	45	33	0.65	-0.075	3.934	0.01	0.007	0	20.6	17.6	74.8	88	78	0	40	37
2015	12	19	9	55	33	0.673	-0.059	3.937	0.01	0.007	0	20.2	17.6	75.3	87	78	0	40	37
2015	12	19	10	5	33	0.614	-0.079	3.937	0.01	0.007	0	20.6	18.1	75.7	88	78	0	40	36
2015	12	19	10	15	33	0.669	-0.089	3.937	0.013	0.01	0	20.6	17.6	75.3	88	78	0	40	37
2015	12	19	10	25	33	0.65	-0.072	3.937	0.01	0.007	0	20.2	17.6	75.7	87	78	0	40	37
2015	12	19	10	35	33	0.663	-0.095	3.937	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	19	10	45	33	0.653	-0.049	3.937	0.01	0.007	0	20.6	17.6	75.3	88	78	0	40	37
2015	12	19	10	55	33	0.653	-0.046	3.937	0.01	0.007	0	20.6	18.1	76.1	88	78	0	40	36
2015	12	19	11	5	33	0.669	-0.062	3.937	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	19	11	15	33	0.623	-0.049	3.937	0.01	0.007	0	21.5	18.1	76.1	89	79	0	39	37
2015	12	19	11	25	33	0.653	-0.059	3.937	0.01	0.007	0	20.6	18.5	75.7	88	79	0	40	36
2015	12	19	11	35	33	0.653	-0.105	3.937	0.01	0.007	0	21.5	18.1	76.5	89	79	0	39	37
2015	12	19	11	45	33	0.646	-0.052	3.937	0.01	0.007	0	21.1	18.9	76.1	89	80	0	40	36
2015	12	19	11	55	33	0.663	-0.102	3.937	0.01	0.007	0	21.1	18.1	76.1	89	79	0	40	37
2015	12	19	12	5	33	0.686	-0.089	3.937	0.013	0.01	0	21.1	18.1	76.1	88	78	0	39	36
2015	12	19	12	15	33	0.712	-0.098	3.937	0.01	0.007	0	20.2	17.6	76.1	87	78	0	40	37
2015	12	19	12	25	33	0.614	-0.052	3.937	0.01	0.007	0	20.2	17.2	76.1	87	78	0	40	38
2015	12	19	12	35	33	0.614	-0.039	3.937	0.01	0.007	0	20.2	17.2	76.1	86	77	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	12	45	33	0.646	-0.085	3.934	0.01	0.007	0	21.1	18.1	77	89	79	0	40	37
2015	12	19	12	55	33	0.656	-0.049	3.937	0.01	0.007	0	20.6	18.1	76.5	88	79	0	40	37
2015	12	19	13	5	33	0.646	-0.059	3.937	0.013	0.01	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	19	13	15	33	0.63	-0.069	3.937	0.01	0.007	0	21.1	18.9	75.7	89	80	0	40	36
2015	12	19	13	25	33	0.65	-0.072	3.937	0.013	0.01	0	21.1	18.1	76.5	89	79	0	40	37
2015	12	19	13	35	33	0.65	-0.059	3.937	0.01	0.007	0	22.4	18.9	76.5	91	81	0	39	37
2015	12	19	13	45	33	0.686	-0.089	3.937	0.01	0.007	0	21.9	18.9	74.4	91	81	0	40	37
2015	12	19	13	55	33	0.682	-0.052	3.937	0.01	0.007	0	21.9	18.5	75.7	90	80	0	39	37
2015	12	19	14	5	33	0.663	-0.049	3.937	0.01	0.007	0	21.1	18.1	76.1	89	79	0	40	37
2015	12	19	14	15	33	0.699	-0.046	3.934	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	19	14	25	33	0.696	-0.092	3.937	0.01	0.007	0	21.5	18.5	75.7	90	79	0	40	36
2015	12	19	14	35	33	0.663	-0.069	3.934	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	19	14	45	33	0.669	-0.082	3.934	0.01	0.007	0	21.1	17.6	75.7	89	79	0	40	38
2015	12	19	14	55	33	0.673	-0.082	3.934	0.01	0.007	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	19	15	5	33	0.646	-0.085	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	19	15	15	33	0.679	-0.108	3.934	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	19	15	25	33	0.669	-0.072	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	19	15	35	33	0.689	-0.085	3.934	0.013	0.01	0	21.5	17.2	75.7	89	78	0	39	38
2015	12	19	15	45	33	0.666	-0.079	3.93	0.01	0.007	0	22.8	18.9	55	93	81	0	40	37
2015	12	19	15	55	33	0.617	-0.062	3.93	0.01	0.007	0	24.5	20.6	50.7	97	85	0	40	37
2015	12	19	16	5	33	0.653	-0.072	3.934	0.01	0.007	0	23.6	19.4	51.2	94	82	0	39	37
2015	12	19	16	15	33	0.702	-0.085	3.934	0.01	0.007	0	22.4	18.5	73.5	92	81	0	40	38
2015	12	19	16	25	33	0.696	-0.075	3.934	0.01	0.007	0	21.9	18.5	74.4	91	80	0	40	37
2015	12	19	16	35	33	0.673	-0.043	3.934	0.01	0.007	0	21.5	18.1	74.8	90	79	0	40	37
2015	12	19	16	45	33	0.659	-0.072	3.934	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	19	16	55	33	0.692	-0.049	3.934	0.01	0.007	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	19	17	5	33	0.689	-0.049	3.934	0.01	0.007	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	19	17	15	33	0.679	-0.075	3.934	0.01	0.007	0	21.1	18.1	74.4	89	78	0	40	36
2015	12	19	17	25	33	0.673	-0.062	3.934	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	19	17	35	33	0.663	-0.082	3.934	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	19	17	45	33	0.699	-0.082	3.934	0.01	0.007	0	21.5	18.1	74.8	90	79	0	40	37
2015	12	19	17	55	33	0.666	-0.052	3.934	0.01	0.007	0	21.5	18.1	74.4	90	79	0	40	37
2015	12	19	18	5	33	0.689	-0.049	3.934	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	19	18	15	33	0.669	-0.082	3.934	0.01	0.007	0	22.4	18.1	75.7	91	79	0	39	37
2015	12	19	18	25	33	0.65	-0.072	3.934	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	19	18	35	33	0.669	-0.092	3.934	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	19	18	45	33	0.702	-0.095	3.934	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	19	18	55	33	0.705	-0.085	3.934	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	19	19	5	33	0.653	-0.072	3.934	0.01	0.007	0	21.9	18.1	75.3	91	79	0	40	37
2015	12	19	19	15	33	0.673	-0.075	3.934	0.01	0.007	0	21.5	18.5	76.1	90	80	0	40	37
2015	12	19	19	25	33	0.646	-0.062	3.934	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	19	19	35	33	0.682	-0.052	3.934	0.01	0.007	0	22.4	18.5	75.7	91	81	0	39	38
2015	12	19	19	45	33	0.686	-0.072	3.934	0.01	0.007	0	22.8	18.1	75.7	92	80	0	39	38
2015	12	19	19	55	33	0.725	-0.092	3.934	0.01	0.007	0	29.2	24.5	75.3	108	94	0	40	37
2015	12	19	20	5	33	0.712	-0.079	3.934	0.01	0.007	0	24.5	20.2	76.5	97	85	0	40	38
2015	12	19	20	15	33	0.682	-0.069	3.934	0.01	0.007	0	22.8	19.4	75.7	93	82	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	19	20	25	33	0.643	-0.049	3.934	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	19	20	35	33	0.673	-0.072	3.934	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	19	20	45	33	0.682	-0.062	3.934	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	19	20	55	33	0.696	-0.098	3.934	0.01	0.007	0	21.1	17.6	76.1	89	79	0	40	38
2015	12	19	21	5	33	0.696	-0.072	3.934	0.01	0.007	0	20.6	17.6	76.5	89	78	0	41	37
2015	12	19	21	15	33	0.682	-0.075	3.934	0.013	0.01	0	21.5	18.1	76.1	89	79	0	39	37
2015	12	19	21	25	33	0.669	-0.039	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	19	21	35	33	0.686	-0.052	3.93	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	19	21	45	33	0.646	-0.049	3.934	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	19	21	55	33	0.65	-0.043	3.934	0.01	0.007	0	21.1	18.1	76.1	89	79	0	40	37
2015	12	19	22	5	33	0.64	-0.043	3.934	0.01	0.007	0	21.1	17.2	76.5	89	78	0	40	38
2015	12	19	22	15	33	0.663	-0.072	3.934	0.01	0.007	0	21.1	18.1	76.5	89	78	0	40	36
2015	12	19	22	25	33	0.689	-0.082	3.934	0.01	0.007	0	21.5	18.1	76.1	90	78	0	40	36
2015	12	19	22	35	33	0.682	-0.043	3.93	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	19	22	45	33	0.653	-0.062	3.93	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	19	22	55	33	0.686	-0.069	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	19	23	5	33	0.659	-0.095	3.93	0.013	0.01	0	20.6	17.2	77	88	77	0	40	37
2015	12	19	23	15	33	0.663	-0.085	3.934	0.01	0.007	0	21.1	17.6	77	89	78	0	40	37
2015	12	19	23	25	33	0.719	-0.069	3.93	0.01	0.007	0	21.9	18.1	77	91	79	0	40	37
2015	12	19	23	35	33	0.682	-0.062	3.93	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	19	23	45	33	0.696	-0.098	3.93	0.01	0.007	0	20.6	17.6	77	88	78	0	40	37
2015	12	19	23	55	33	0.669	-0.102	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	0	5	33	0.712	-0.098	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	0	15	33	0.653	-0.108	3.93	0.013	0.01	0	21.1	17.2	76.5	89	78	0	40	38
2015	12	20	0	25	33	0.643	-0.098	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	0	35	33	0.666	-0.098	3.93	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	20	0	45	33	0.663	-0.098	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	0	55	33	0.646	-0.092	3.93	0.01	0.007	0	20.6	17.2	77.4	88	77	0	40	37
2015	12	20	1	5	33	0.702	-0.079	3.93	0.01	0.007	0	21.1	17.2	76.1	88	77	0	39	37
2015	12	20	1	15	33	0.673	-0.098	3.93	0.01	0.007	0	20.2	16.8	77	87	76	0	40	37
2015	12	20	1	25	33	0.682	-0.105	3.93	0.013	0.01	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	1	35	33	0.659	-0.069	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	1	45	33	0.617	-0.112	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	1	55	33	0.64	-0.062	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	2	5	33	0.623	-0.098	3.93	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	2	15	33	0.646	-0.079	3.93	0.01	0.007	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	20	2	25	33	0.65	-0.089	3.93	0.01	0.007	0	20.6	17.2	76.5	87	77	0	39	37
2015	12	20	2	35	33	0.682	-0.105	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	2	45	33	0.633	-0.079	3.93	0.01	0.007	0	20.6	17.2	77	87	77	0	39	37
2015	12	20	2	55	33	0.653	-0.092	3.93	0.016	0.013	0	20.6	16.8	76.5	88	76	0	40	37
2015	12	20	3	5	33	0.63	-0.085	3.93	0.01	0.007	0	20.6	16.8	77.4	88	76	0	40	37
2015	12	20	3	15	33	0.659	-0.072	3.93	0.01	0.007	0	20.2	16.3	76.5	87	76	0	40	38
2015	12	20	3	25	33	0.666	-0.105	3.93	0.01	0.007	0	20.2	17.2	77	87	76	0	40	36
2015	12	20	3	35	33	0.62	-0.075	3.93	0.01	0.007	0	20.6	16.3	77	88	76	0	40	38
2015	12	20	3	45	33	0.656	-0.089	3.93	0.01	0.007	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	20	3	55	33	0.643	-0.108	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	4	5	33	0.663	-0.098	3.93	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	20	4	15	33	0.673	-0.085	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	20	4	25	33	0.646	-0.059	3.93	0.01	0.007	0	20.2	16.3	76.5	87	76	0	40	38
2015	12	20	4	35	33	0.659	-0.089	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	4	45	33	0.676	-0.059	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	20	4	55	33	0.679	-0.085	3.93	0.01	0.007	0	20.2	16.3	76.5	87	76	0	40	38
2015	12	20	5	5	33	0.656	-0.098	3.93	0.01	0.007	0	20.6	16.8	76.5	87	76	0	39	37
2015	12	20	5	15	33	0.633	-0.069	3.93	0.01	0.007	0	20.6	16.8	76.5	87	77	0	39	38
2015	12	20	5	25	33	0.663	-0.108	3.93	0.01	0.007	0	19.8	16.8	76.5	86	76	0	40	37
2015	12	20	5	35	33	0.673	-0.062	3.93	0.01	0.007	0	19.8	16.8	77	86	76	0	40	37
2015	12	20	5	45	33	0.653	-0.112	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	20	5	55	33	0.633	-0.049	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	6	5	33	0.623	-0.098	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	6	15	33	0.627	-0.082	3.93	0.01	0.007	0	21.1	16.8	76.5	88	77	0	39	38
2015	12	20	6	25	33	0.705	-0.085	3.93	0.01	0.007	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	20	6	35	33	0.64	-0.079	3.93	0.013	0.01	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	20	6	45	33	0.682	-0.085	3.93	0.01	0.007	0	20.2	16.3	76.1	87	76	0	40	38
2015	12	20	6	55	33	0.659	-0.062	3.93	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	20	7	5	33	0.633	-0.089	3.93	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	20	7	15	33	0.663	-0.108	3.934	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	20	7	25	33	0.614	-0.069	3.93	0.01	0.007	0	19.8	16.3	76.1	86	76	0	40	38
2015	12	20	7	35	33	0.636	-0.072	3.934	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	20	7	45	33	0.696	-0.085	3.93	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	7	55	33	0.614	-0.062	3.934	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	8	5	33	0.659	-0.085	3.934	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	8	15	33	0.623	-0.089	3.934	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	8	25	33	0.63	-0.112	3.934	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	20	8	35	33	0.663	-0.092	3.934	0.01	0.007	0	19.8	16.3	74.8	86	76	0	40	38
2015	12	20	8	45	33	0.689	-0.098	3.934	0.013	0.01	0	19.4	16.8	75.3	85	76	0	40	37
2015	12	20	8	55	33	0.646	-0.082	3.934	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	9	5	33	0.636	-0.075	3.934	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	20	9	15	33	0.62	-0.059	3.937	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	9	25	33	0.62	-0.062	3.934	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	20	9	35	33	0.61	-0.062	3.934	0.01	0.007	0	19.8	16.3	75.3	86	76	0	40	38
2015	12	20	9	45	33	0.62	-0.059	3.934	0.01	0.007	0	20.6	16.3	75.7	87	76	0	39	38
2015	12	20	9	55	33	0.65	-0.085	3.937	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	20	10	5	33	0.65	-0.098	3.937	0.01	0.007	0	20.6	17.2	75.7	87	76	0	39	36
2015	12	20	10	15	33	0.65	-0.075	3.937	0.01	0.007	0	19.4	16.8	75.7	85	76	0	40	37
2015	12	20	10	25	33	0.633	-0.072	3.937	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	20	10	35	33	0.666	-0.095	3.937	0.01	0.007	0	19.4	16.3	76.1	85	76	0	40	38
2015	12	20	10	45	33	0.63	-0.105	3.937	0.01	0.007	0	19.8	16.3	75.7	86	75	0	40	37
2015	12	20	10	55	33	0.676	-0.059	3.937	0.01	0.007	0	19.8	16.8	76.5	86	76	0	40	37
2015	12	20	11	5	33	0.617	-0.056	3.937	0.01	0.007	0	19.8	17.2	75.7	86	77	0	40	37
2015	12	20	11	15	33	0.627	-0.075	3.937	0.01	0.007	0	20.2	16.8	76.1	87	77	0	40	38
2015	12	20	11	25	33	0.666	-0.059	3.937	0.01	0.007	0	19.8	17.2	76.1	86	77	0	40	37
2015	12	20	11	35	33	0.623	-0.049	3.937	0.01	0.007	0	19.8	16.3	75.7	86	75	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	11	45	33	0.623	-0.082	3.937	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	11	55	33	0.656	-0.043	3.937	0.01	0.007	0	20.6	16.8	76.5	87	76	0	39	37
2015	12	20	12	5	33	0.633	-0.072	3.937	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	20	12	15	33	0.64	-0.059	3.937	0.01	0.007	0	19.8	17.2	75.7	86	77	0	40	37
2015	12	20	12	25	33	0.673	-0.062	3.937	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	20	12	35	33	0.646	-0.069	3.94	0.01	0.007	0	19.8	17.2	75.7	86	77	0	40	37
2015	12	20	12	45	33	0.623	-0.089	3.94	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	20	12	55	33	0.669	-0.036	3.94	0.01	0.007	0	19.8	16.8	75.7	86	76	0	40	37
2015	12	20	13	5	33	0.666	-0.085	3.94	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	20	13	15	33	0.64	-0.043	3.94	0.01	0.007	0	20.2	17.6	76.1	87	77	0	40	36
2015	12	20	13	25	33	0.656	-0.052	3.937	0.01	0.007	0	19.8	17.2	75.7	86	77	0	40	37
2015	12	20	13	35	33	0.659	-0.062	3.937	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	20	13	45	33	0.656	-0.062	3.937	0.01	0.007	0	20.6	17.6	74.8	88	78	0	40	37
2015	12	20	13	55	33	0.65	-0.069	3.937	0.01	0.007	0	20.2	16.8	74.8	87	77	0	40	38
2015	12	20	14	5	33	0.623	-0.098	3.937	0.013	0.01	0	20.6	17.2	74.8	88	77	0	40	37
2015	12	20	14	15	33	0.63	-0.069	3.937	0.013	0.01	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	14	25	33	0.663	-0.069	3.937	0.01	0.007	0	21.1	17.2	74	88	77	0	39	37
2015	12	20	14	35	33	0.636	-0.062	3.934	0.01	0.007	0	21.5	18.5	55.9	90	80	0	40	37
2015	12	20	14	45	33	0.663	-0.069	3.934	0.01	0.007	0	20.6	17.2	68.4	88	78	0	40	38
2015	12	20	14	55	33	0.686	-0.052	3.934	0.01	0.007	0	19.8	16.3	61.1	86	76	0	40	38
2015	12	20	15	5	33	0.62	-0.075	3.934	0.01	0.007	0	20.2	17.2	56.3	87	77	0	40	37
2015	12	20	15	15	33	0.633	-0.072	3.934	0.01	0.007	0	21.1	18.1	52.9	89	79	0	40	37
2015	12	20	15	25	33	0.656	-0.049	3.934	0.016	0.013	0	20.6	17.2	72.7	88	77	0	40	37
2015	12	20	15	35	33	0.656	-0.089	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	20	15	45	33	0.636	-0.056	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	20	15	55	33	0.686	-0.059	3.934	0.01	0.007	0	22.4	18.5	76.1	92	81	0	40	38
2015	12	20	16	5	33	0.653	-0.066	3.934	0.01	0.007	0	21.5	17.6	76.5	89	78	0	39	37
2015	12	20	16	15	33	0.646	-0.072	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	20	16	25	33	0.679	-0.072	3.934	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	20	16	35	33	0.643	-0.056	3.934	0.01	0.007	0	21.1	17.2	76.5	89	78	0	40	38
2015	12	20	16	45	33	0.617	-0.098	3.934	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	20	16	55	33	0.659	-0.062	3.934	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	20	17	5	33	0.686	-0.085	3.934	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	20	17	15	33	0.646	-0.043	3.934	0.01	0.007	0	20.2	16.8	76.1	87	77	0	40	38
2015	12	20	17	25	33	0.623	-0.049	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	20	17	35	33	0.663	-0.098	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	20	17	45	33	0.627	-0.049	3.934	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	20	17	55	33	0.653	-0.072	3.934	0.01	0.007	0	20.6	17.6	76.1	87	77	0	39	36
2015	12	20	18	5	33	0.646	-0.052	3.934	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	20	18	15	33	0.62	-0.089	3.934	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	18	25	33	0.679	-0.075	3.934	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	20	18	35	33	0.679	-0.049	3.934	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	20	18	45	33	0.633	-0.085	3.934	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	20	18	55	33	0.62	-0.069	3.934	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	20	19	5	33	0.581	-0.072	3.934	0.01	0.007	0	20.2	17.2	76.5	87	77	0	40	37
2015	12	20	19	15	33	0.682	-0.072	3.934	0.01	0.007	0	20.2	16.8	76.1	87	77	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	20	19	25	33	0.673	-0.098	3.934	0.01	0.007	0	20.6	17.6	76.1	88	77	0	40	36
2015	12	20	19	35	33	0.646	-0.066	3.934	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	20	19	45	33	0.653	-0.085	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	20	19	55	33	0.653	-0.046	3.934	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	20	20	5	33	0.65	-0.095	3.934	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	20	20	15	33	0.646	-0.072	3.934	0.01	0.007	0	20.6	17.2	76.1	87	77	0	39	37
2015	12	20	20	25	33	0.65	-0.105	3.93	0.013	0.01	0	20.2	16.8	76.5	87	76	0	40	37
2015	12	20	20	35	33	0.597	-0.098	3.93	0.01	0.007	0	20.2	16.8	75.7	87	77	0	40	38
2015	12	20	20	45	33	0.64	-0.089	3.934	0.013	0.01	0	19.8	16.8	76.5	86	76	0	40	37
2015	12	20	20	55	33	0.643	-0.095	3.934	0.01	0.007	0	20.2	16.3	76.5	87	76	0	40	38
2015	12	20	21	5	33	0.614	-0.079	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	20	21	15	33	0.656	-0.069	3.934	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	21	25	33	0.633	-0.079	3.934	0.01	0.007	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	20	21	35	33	0.633	-0.075	3.934	0.013	0.01	0	20.6	16.3	75.3	88	76	0	40	38
2015	12	20	21	45	33	0.636	-0.082	3.93	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	20	21	55	33	0.659	-0.089	3.93	0.01	0.007	0	20.6	16.3	76.1	87	76	0	39	38
2015	12	20	22	5	33	0.646	-0.082	3.93	0.01	0.007	0	20.6	17.6	75.7	88	77	0	40	36
2015	12	20	22	15	33	0.643	-0.085	3.934	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	20	22	25	33	0.669	-0.062	3.934	0.01	0.007	0	20.6	17.2	75.3	87	77	0	39	37
2015	12	20	22	35	33	0.682	-0.072	3.93	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	20	22	45	33	0.623	-0.105	3.93	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	20	22	55	33	0.679	-0.082	3.93	0.01	0.007	0	19.8	16.8	75.7	87	76	0	41	37
2015	12	20	23	5	33	0.633	-0.085	3.93	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	20	23	15	33	0.627	-0.082	3.93	0.01	0.007	0	20.6	17.6	75.7	88	77	0	40	36
2015	12	20	23	25	33	0.65	-0.059	3.93	0.01	0.007	0	20.2	17.2	75.7	87	76	0	40	36
2015	12	20	23	35	33	0.656	-0.052	3.93	0.01	0.007	0	20.6	16.8	75.7	88	77	0	40	38
2015	12	20	23	45	33	0.633	-0.089	3.93	0.01	0.007	0	20.6	16.8	75.7	87	76	0	39	37
2015	12	20	23	55	33	0.61	-0.066	3.93	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	21	0	5	33	0.604	-0.085	3.93	0.013	0.01	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	21	0	15	33	0.669	-0.056	3.93	0.01	0.007	0	20.6	17.2	75.7	87	77	0	39	37
2015	12	21	0	25	33	0.61	-0.095	3.93	0.01	0.007	0	20.2	16.3	75.3	87	76	0	40	38
2015	12	21	0	35	33	0.643	-0.072	3.93	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	21	0	45	33	0.656	-0.085	3.93	0.01	0.007	0	20.2	16.8	75.3	86	76	0	39	37
2015	12	21	0	55	33	0.617	-0.066	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	1	5	33	0.623	-0.079	3.93	0.01	0.007	0	21.1	17.2	75.3	88	77	0	39	37
2015	12	21	1	15	33	0.623	-0.085	3.93	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	21	1	25	33	0.623	-0.079	3.93	0.01	0.007	0	20.6	16.3	75.7	87	75	0	39	37
2015	12	21	1	35	33	0.636	-0.066	3.93	0.01	0.007	0	20.2	16.8	75.3	87	76	0	40	37
2015	12	21	1	45	33	0.666	-0.089	3.93	0.013	0.01	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	1	55	33	0.643	-0.102	3.93	0.013	0.01	0	20.2	16.8	75.3	87	76	0	40	37
2015	12	21	2	5	33	0.614	-0.085	3.93	0.01	0.007	0	20.6	16.3	75.7	88	76	0	40	38
2015	12	21	2	15	33	0.659	-0.098	3.93	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	2	25	33	0.633	-0.069	3.93	0.01	0.007	0	20.2	16.3	75.7	87	76	0	40	38
2015	12	21	2	35	33	0.627	-0.072	3.93	0.01	0.007	0	20.2	16.3	75.7	86	76	0	39	38
2015	12	21	2	45	33	0.636	-0.092	3.93	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	21	2	55	33	0.669	-0.049	3.934	0.01	0.007	0	19.8	16.3	75.7	86	75	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	3	5	33	0.62	-0.062	3.93	0.016	0.013	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	21	3	15	33	0.666	-0.112	3.93	0.01	0.007	0	19.8	16.8	74	86	76	0	40	37
2015	12	21	3	25	33	0.614	-0.059	3.934	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	21	3	35	33	0.656	-0.095	3.93	0.01	0.007	0	20.2	16.8	75.3	87	76	0	40	37
2015	12	21	3	45	33	0.63	-0.085	3.93	0.01	0.007	0	20.2	16.8	75.3	86	76	0	39	37
2015	12	21	3	55	33	0.633	-0.075	3.93	0.01	0.007	0	19.8	16.8	75.7	87	76	0	41	37
2015	12	21	4	5	33	0.633	-0.056	3.93	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	21	4	15	33	0.636	-0.056	3.934	0.01	0.007	0	20.2	16.3	75.3	87	75	0	40	37
2015	12	21	4	25	33	0.659	-0.089	3.93	0.01	0.007	0	20.6	17.2	76.1	87	76	0	39	36
2015	12	21	4	35	33	0.63	-0.075	3.93	0.01	0.007	0	20.6	16.8	75.3	87	76	0	39	37
2015	12	21	4	45	33	0.65	-0.089	3.93	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	21	4	55	33	0.633	-0.102	3.934	0.01	0.007	0	19.8	16.3	75.3	86	76	0	40	38
2015	12	21	5	5	33	0.627	-0.082	3.93	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	21	5	15	33	0.633	-0.049	3.934	0.01	0.007	0	20.2	16.8	74.8	87	77	0	40	38
2015	12	21	5	25	33	0.633	-0.075	3.934	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	21	5	35	33	0.656	-0.095	3.934	0.01	0.007	0	20.2	16.8	74	86	75	0	39	36
2015	12	21	5	45	33	0.633	-0.072	3.934	0.01	0.007	0	19.4	16.8	74.8	85	75	0	40	36
2015	12	21	5	55	33	0.607	-0.066	3.934	0.01	0.007	0	20.2	16.8	75.3	86	76	0	39	37
2015	12	21	6	5	33	0.617	-0.049	3.934	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	21	6	15	33	0.61	-0.098	3.934	0.01	0.007	0	20.6	16.8	74.8	87	76	0	39	37
2015	12	21	6	25	33	0.643	-0.085	3.934	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	21	6	35	33	0.659	-0.105	3.934	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	21	6	45	33	0.63	-0.075	3.934	0.01	0.007	0	20.2	17.2	75.7	87	76	0	40	36
2015	12	21	6	55	33	0.666	-0.069	3.934	0.01	0.007	0	21.5	17.6	70.5	90	78	0	40	37
2015	12	21	7	5	33	0.669	-0.115	3.934	0.01	0.007	0	25.4	21.1	73.1	98	85	0	39	36
2015	12	21	7	15	33	0.633	-0.082	3.934	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	21	7	25	33	0.61	-0.112	3.934	0.01	0.007	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	21	7	35	33	0.633	-0.075	3.934	0.01	0.007	0	20.2	16.3	74.8	86	75	0	39	37
2015	12	21	7	45	33	0.65	-0.098	3.934	0.01	0.007	0	19.4	16.3	74.8	85	75	0	40	37
2015	12	21	7	55	33	0.653	-0.082	3.934	0.013	0.01	0	19.8	15.9	75.3	85	74	0	39	37
2015	12	21	8	5	33	0.62	-0.075	3.934	0.01	0.007	0	19.8	15.9	74.8	86	75	0	40	38
2015	12	21	8	15	33	0.627	-0.098	3.934	0.01	0.007	0	19.4	16.3	75.3	85	75	0	40	37
2015	12	21	8	25	33	0.62	-0.069	3.934	0.01	0.007	0	19.4	16.3	74.8	85	75	0	40	37
2015	12	21	8	35	33	0.623	-0.089	3.934	0.01	0.007	0	19.8	16.8	74.8	86	75	0	40	36
2015	12	21	8	45	33	0.627	-0.112	3.934	0.01	0.007	0	19.8	16.3	72.7	86	76	0	40	38
2015	12	21	8	55	33	0.627	-0.056	3.937	0.01	0.007	0	19.8	17.2	74.8	86	77	0	40	37
2015	12	21	9	5	33	0.656	-0.069	3.937	0.01	0.007	0	19.8	17.2	75.7	86	77	0	40	37
2015	12	21	9	15	33	0.627	-0.082	3.937	0.01	0.007	0	19.8	16.3	75.3	86	76	0	40	38
2015	12	21	9	25	33	0.64	-0.062	3.937	0.01	0.007	0	19.8	16.8	74.8	86	76	0	40	37
2015	12	21	9	35	33	0.597	-0.079	3.937	0.01	0.007	0	19.8	17.6	75.3	86	77	0	40	36
2015	12	21	9	45	33	0.627	-0.043	3.937	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	21	9	55	33	0.587	-0.089	3.937	0.01	0.007	0	19.8	17.2	75.3	86	77	0	40	37
2015	12	21	10	5	33	0.64	-0.095	3.937	0.01	0.007	0	19.8	16.3	75.7	85	75	0	39	37
2015	12	21	10	15	33	0.614	-0.085	3.937	0.01	0.007	0	20.2	16.8	75.3	86	76	0	39	37
2015	12	21	10	25	33	0.646	-0.095	3.937	0.01	0.007	0	19.4	15.9	69.7	85	75	0	40	38
2015	12	21	10	35	33	0.65	-0.089	3.937	0.01	0.007	0	19.4	15.9	70.1	85	75	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	10	45	33	0.636	-0.062	3.937	0.01	0.007	0	19.8	16.8	72.7	86	76	0	40	37
2015	12	21	10	55	33	0.64	-0.062	3.937	0.01	0.007	0	19.8	16.8	72.7	86	76	0	40	37
2015	12	21	11	5	33	0.623	-0.066	3.937	0.01	0.007	0	20.2	16.8	74.8	86	76	0	39	37
2015	12	21	11	15	33	0.636	-0.052	3.937	0.01	0.007	0	21.9	18.1	75.3	90	79	0	39	37
2015	12	21	11	25	33	0.653	-0.082	3.937	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	11	35	33	0.669	-0.075	3.937	0.01	0.007	0	19.8	16.8	68.4	86	76	0	40	37
2015	12	21	11	45	33	0.702	-0.079	3.937	0.01	0.007	0	25.4	22.4	74.4	99	88	0	40	36
2015	12	21	11	55	33	0.673	-0.098	3.937	0.01	0.007	0	24.5	20.2	67.9	97	85	0	40	38
2015	12	21	12	5	33	0.666	-0.079	3.937	0.01	0.007	0	22.4	18.1	65.4	91	80	0	39	38
2015	12	21	12	15	33	0.673	-0.082	3.934	0.01	0.007	0	22.8	18.9	58.9	93	81	0	40	37
2015	12	21	12	25	33	0.636	-0.066	3.934	0.01	0.007	0	21.1	18.1	71.4	89	78	0	40	36
2015	12	21	12	35	33	0.623	-0.075	3.937	0.01	0.007	0	20.6	17.2	74	88	77	0	40	37
2015	12	21	12	45	33	0.679	-0.082	3.934	0.01	0.007	0	20.2	16.8	73.1	87	77	0	40	38
2015	12	21	12	55	33	0.633	-0.066	3.937	0.01	0.007	0	20.6	17.6	67.1	88	78	0	40	37
2015	12	21	13	5	33	0.646	-0.069	3.937	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	21	13	15	33	0.643	-0.066	3.934	0.013	0.01	0	20.6	17.2	70.5	87	77	0	39	37
2015	12	21	13	25	33	0.623	-0.085	3.937	0.01	0.007	0	20.6	16.8	75.3	88	77	0	40	38
2015	12	21	13	35	33	0.646	-0.085	3.934	0.01	0.007	0	20.6	16.8	75.7	87	76	0	39	37
2015	12	21	13	45	33	0.646	-0.112	3.937	0.01	0.007	0	21.1	17.2	76.5	88	77	0	39	37
2015	12	21	13	55	33	0.696	-0.092	3.937	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	14	5	33	0.656	-0.052	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	14	15	33	0.633	-0.072	3.937	0.01	0.007	0	20.2	16.3	75.3	87	76	0	40	38
2015	12	21	14	25	33	0.682	-0.079	3.937	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	21	14	35	33	0.705	-0.092	3.934	0.01	0.007	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	21	14	45	33	0.663	-0.082	3.937	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	21	14	55	33	0.646	-0.049	3.934	0.01	0.007	0	20.2	16.8	75.7	86	76	0	39	37
2015	12	21	15	5	33	0.679	-0.085	3.934	0.01	0.007	0	19.8	16.8	76.1	86	76	0	40	37
2015	12	21	15	15	33	0.689	-0.082	3.934	0.01	0.007	0	24.1	19.8	75.7	95	83	0	39	37
2015	12	21	15	25	33	0.686	-0.062	3.934	0.01	0.007	0	22.4	18.9	75.7	92	81	0	40	37
2015	12	21	15	35	33	0.748	-0.079	3.934	0.013	0.01	0	28.8	24.5	76.1	106	94	0	39	37
2015	12	21	15	45	33	0.696	-0.098	3.934	0.01	0.007	0	23.6	20.2	74.8	95	84	0	40	37
2015	12	21	15	55	33	0.719	-0.108	3.934	0.01	0.007	0	21.9	18.5	75.7	91	81	0	40	38
2015	12	21	16	5	33	0.676	-0.059	3.934	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	21	16	15	33	0.682	-0.085	3.934	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37
2015	12	21	16	25	33	0.689	-0.102	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	16	35	33	0.666	-0.095	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	21	16	45	33	0.673	-0.066	3.934	0.01	0.007	0	21.1	18.1	75.7	89	78	0	40	36
2015	12	21	16	55	33	0.666	-0.072	3.934	0.01	0.007	0	21.1	18.1	75.7	89	78	0	40	36
2015	12	21	17	5	33	0.653	-0.072	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	17	15	33	0.673	-0.085	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	17	25	33	0.659	-0.075	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	21	17	35	33	0.682	-0.066	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	17	45	33	0.692	-0.089	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	21	17	55	33	0.646	-0.075	3.934	0.013	0.01	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	21	18	5	33	0.659	-0.072	3.934	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	21	18	15	33	0.686	-0.089	3.934	0.01	0.007	0	21.1	17.2	75.3	89	77	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	21	18	25	33	0.689	-0.092	3.934	0.01	0.007	0	21.1	17.2	75.3	88	77	0	39	37
2015	12	21	18	35	33	0.679	-0.075	3.934	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	21	18	45	33	0.653	-0.082	3.934	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	21	18	55	33	0.682	-0.108	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	19	5	33	0.692	-0.105	3.937	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	19	15	33	0.682	-0.072	3.934	0.01	0.007	0	20.2	16.3	75.3	87	76	0	40	38
2015	12	21	19	25	33	0.653	-0.082	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	19	35	33	0.666	-0.079	3.937	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	21	19	45	33	0.673	-0.092	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	19	55	33	0.676	-0.072	3.934	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	21	20	5	33	0.673	-0.098	3.934	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	21	20	15	33	0.669	-0.098	3.934	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	21	20	25	33	0.673	-0.059	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	20	35	33	0.686	-0.062	3.934	0.013	0.01	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	21	20	45	33	0.663	-0.046	3.934	0.013	0.01	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	21	20	55	33	0.673	-0.075	3.934	0.016	0.013	0	20.6	17.2	74.8	88	77	0	40	37
2015	12	21	21	5	33	0.709	-0.085	3.934	0.016	0.013	0	20.6	17.2	75.7	87	77	0	39	37
2015	12	21	21	15	33	0.633	-0.075	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	21	21	25	33	0.656	-0.069	3.934	0.01	0.007	0	20.6	17.2	74.8	87	77	0	39	37
2015	12	21	21	35	33	0.646	-0.102	3.934	0.01	0.007	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	21	21	45	33	0.659	-0.069	3.934	0.01	0.007	0	20.2	17.6	75.7	87	77	0	40	36
2015	12	21	21	55	33	0.689	-0.075	3.934	0.01	0.007	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	21	22	5	33	0.653	-0.075	3.937	0.01	0.007	0	20.6	17.6	76.1	88	77	0	40	36
2015	12	21	22	15	33	0.689	-0.085	3.934	0.01	0.007	0	20.6	17.6	75.3	88	77	0	40	36
2015	12	21	22	25	33	0.65	-0.095	3.934	0.01	0.007	0	20.2	17.2	75.3	87	77	0	40	37
2015	12	21	22	35	33	0.686	-0.062	3.934	0.013	0.01	0	20.6	17.2	74.4	88	77	0	40	37
2015	12	21	22	45	33	0.673	-0.092	3.937	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	22	55	33	0.653	-0.056	3.937	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	21	23	5	33	0.666	-0.072	3.934	0.01	0.007	0	20.6	17.2	75.7	87	77	0	39	37
2015	12	21	23	15	33	0.692	-0.059	3.934	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	21	23	25	33	0.686	-0.098	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	21	23	35	33	0.669	-0.108	3.934	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	21	23	45	33	0.65	-0.095	3.934	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	21	23	55	33	0.659	-0.082	3.934	0.01	0.007	0	20.6	16.8	75.7	88	77	0	40	38
2015	12	22	0	5	33	0.623	-0.095	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	22	0	15	33	0.689	-0.085	3.934	0.01	0.007	0	20.2	17.2	76.1	88	77	0	41	37
2015	12	22	0	25	33	0.696	-0.095	3.934	0.013	0.01	0	20.6	17.6	76.1	88	78	0	40	37
2015	12	22	0	35	33	0.669	-0.128	3.934	0.01	0.007	0	21.1	17.2	75.7	89	78	0	40	38
2015	12	22	0	45	33	0.673	-0.105	3.934	0.01	0.007	0	21.5	17.6	74.8	89	78	0	39	37
2015	12	22	0	55	33	0.679	-0.082	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	22	1	5	33	0.669	-0.082	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	22	1	15	33	0.676	-0.085	3.934	0.013	0.01	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	1	25	33	0.679	-0.062	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	22	1	35	33	0.696	-0.095	3.934	0.01	0.007	0	20.6	16.8	75.7	88	77	0	40	38
2015	12	22	1	45	33	0.666	-0.095	3.934	0.01	0.007	0	21.1	17.2	75.7	89	77	0	40	37
2015	12	22	1	55	33	0.699	-0.108	3.934	0.01	0.007	0	21.1	17.6	75.3	89	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	2	5	33	0.682	-0.115	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	2	15	33	0.679	-0.098	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	22	2	25	33	0.722	-0.079	3.934	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	22	2	35	33	0.646	-0.079	3.934	0.01	0.007	0	21.1	17.6	75.3	89	77	0	40	36
2015	12	22	2	45	33	0.682	-0.069	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	2	55	33	0.679	-0.082	3.934	0.01	0.007	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	22	3	5	33	0.659	-0.066	3.934	0.01	0.007	0	20.6	17.2	75.3	88	78	0	40	38
2015	12	22	3	15	33	0.65	-0.069	3.934	0.01	0.007	0	21.1	17.6	74.8	88	77	0	39	36
2015	12	22	3	25	33	0.682	-0.062	3.934	0.01	0.007	0	21.1	17.2	76.1	88	77	0	39	37
2015	12	22	3	35	33	0.61	-0.075	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	3	45	33	0.65	-0.095	3.934	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	22	3	55	33	0.656	-0.062	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	22	4	5	33	0.653	-0.062	3.934	0.01	0.007	0	21.1	18.1	75.3	89	78	0	40	36
2015	12	22	4	15	33	0.64	-0.062	3.934	0.013	0.01	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	22	4	25	33	0.682	-0.079	3.934	0.013	0.01	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	4	35	33	0.659	-0.095	3.934	0.01	0.007	0	21.5	17.6	75.7	89	78	0	39	37
2015	12	22	4	45	33	0.656	-0.095	3.934	0.01	0.007	0	21.1	17.2	75.7	89	78	0	40	38
2015	12	22	4	55	33	0.659	-0.075	3.934	0.01	0.007	0	20.6	17.6	75.3	88	77	0	40	36
2015	12	22	5	5	33	0.64	-0.062	3.934	0.01	0.007	0	20.6	17.2	74.8	88	77	0	40	37
2015	12	22	5	15	33	0.64	-0.089	3.934	0.013	0.01	0	21.1	17.2	74.8	88	77	0	39	37
2015	12	22	5	25	33	0.666	-0.062	3.934	0.01	0.007	0	20.2	17.2	76.1	87	77	0	40	37
2015	12	22	5	35	33	0.666	-0.105	3.934	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	22	5	45	33	0.643	-0.108	3.934	0.01	0.007	0	20.6	17.2	75.3	88	77	0	40	37
2015	12	22	5	55	33	0.663	-0.102	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	6	5	33	0.669	-0.108	3.934	0.01	0.007	0	20.2	16.8	71.8	87	76	0	40	37
2015	12	22	6	15	33	0.61	-0.085	3.934	0.01	0.007	0	21.1	17.2	75.3	89	77	0	40	37
2015	12	22	6	25	33	0.63	-0.075	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	6	35	33	0.646	-0.085	3.934	0.01	0.007	0	20.6	16.8	75.3	88	77	0	40	38
2015	12	22	6	45	33	0.653	-0.072	3.934	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	6	55	33	0.623	-0.092	3.934	0.01	0.007	0	22.4	18.5	75.3	92	80	0	40	37
2015	12	22	7	5	33	0.702	-0.108	3.937	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	22	7	15	33	0.61	-0.102	3.934	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	22	7	25	33	0.673	-0.069	3.934	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	22	7	35	33	0.653	-0.082	3.934	0.01	0.007	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	22	7	45	33	0.682	-0.089	3.934	0.01	0.007	0	20.2	16.3	76.5	87	76	0	40	38
2015	12	22	7	55	33	0.656	-0.112	3.937	0.013	0.01	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	22	8	5	33	0.666	-0.072	3.937	0.01	0.007	0	20.6	17.6	75.7	88	78	0	40	37
2015	12	22	8	15	33	0.676	-0.079	3.937	0.013	0.01	0	20.6	17.2	72.7	88	77	0	40	37
2015	12	22	8	25	33	0.614	-0.075	3.937	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	22	8	35	33	0.666	-0.062	3.937	0.01	0.007	0	20.6	16.8	74.4	88	77	0	40	38
2015	12	22	8	45	33	0.643	-0.098	3.937	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	22	8	55	33	0.663	-0.062	3.937	0.01	0.007	0	21.1	17.2	71	88	77	0	39	37
2015	12	22	9	5	33	0.65	-0.059	3.937	0.013	0.01	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	22	9	15	33	0.65	-0.059	3.937	0.01	0.007	0	20.6	17.6	76.5	88	78	0	40	37
2015	12	22	9	25	33	0.63	-0.089	3.937	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	22	9	35	33	0.636	-0.082	3.937	0.013	0.01	0	20.6	17.6	76.1	88	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	9	45	33	0.673	-0.089	3.937	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	22	9	55	33	0.65	-0.085	3.937	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	22	10	5	33	0.636	-0.069	3.94	0.01	0.007	0	20.6	17.2	74	88	78	0	40	38
2015	12	22	10	15	33	0.64	-0.059	3.94	0.013	0.01	0	20.6	17.6	74	88	78	0	40	37
2015	12	22	10	25	33	0.656	-0.079	3.94	0.01	0.007	0	22.4	18.5	76.1	92	80	0	40	37
2015	12	22	10	35	33	0.676	-0.062	3.94	0.01	0.007	0	21.1	17.6	76.5	89	79	0	40	38
2015	12	22	10	45	33	0.61	-0.075	3.94	0.013	0.01	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	22	10	55	33	0.633	-0.046	3.94	0.01	0.007	0	21.5	18.1	76.1	89	79	0	39	37
2015	12	22	11	5	33	0.666	-0.062	3.94	0.01	0.007	0	21.5	18.5	67.9	90	80	0	40	37
2015	12	22	11	15	33	0.673	-0.059	3.944	0.01	0.007	0	22.8	19.8	76.5	93	83	0	40	37
2015	12	22	11	25	33	0.682	-0.095	3.944	0.01	0.007	0	29.2	24.9	76.1	108	95	0	40	37
2015	12	22	11	35	33	0.666	-0.112	3.944	0.01	0.007	0	23.6	19.8	74.4	95	83	0	40	37
2015	12	22	11	45	33	0.666	-0.075	3.94	0.01	0.007	0	21.9	18.9	66.7	91	81	0	40	37
2015	12	22	11	55	33	0.653	-0.075	3.94	0.01	0.007	0	21.5	18.5	58	90	80	0	40	37
2015	12	22	12	5	33	0.63	-0.062	3.94	0.013	0.01	0	21.5	18.1	71.8	90	79	0	40	37
2015	12	22	12	15	33	0.663	-0.085	3.94	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	22	12	25	33	0.679	-0.098	3.94	0.01	0.007	0	22.4	18.9	71	92	81	0	40	37
2015	12	22	12	35	33	0.636	-0.075	3.94	0.01	0.007	0	22.4	18.9	77	92	81	0	40	37
2015	12	22	12	45	33	0.689	-0.052	3.94	0.01	0.007	0	21.5	18.5	75.7	90	80	0	40	37
2015	12	22	12	55	33	0.709	-0.059	3.94	0.01	0.007	0	23.6	20.2	64.1	95	84	0	40	37
2015	12	22	13	5	33	0.656	-0.105	3.94	0.01	0.007	0	26.2	22.4	69.2	101	89	0	40	37
2015	12	22	13	15	33	0.732	-0.075	3.94	0.01	0.007	0	26.2	21.5	71.8	100	87	0	39	37
2015	12	22	13	25	33	0.682	-0.089	3.94	0.01	0.007	0	24.9	20.6	67.5	98	86	0	40	38
2015	12	22	13	35	33	0.735	-0.072	3.94	0.01	0.007	0	25.4	21.1	67.1	98	86	0	39	37
2015	12	22	13	45	33	0.696	-0.098	3.937	0.01	0.007	0	27.5	23.6	64.9	103	92	0	39	37
2015	12	22	13	55	33	0.738	-0.098	3.937	0.01	0.007	0	30.1	25.4	54.2	109	96	0	39	37
2015	12	22	14	5	33	0.719	-0.079	3.937	0.01	0.007	0	29.7	24.9	52.5	109	95	0	40	37
2015	12	22	14	15	33	0.725	-0.095	3.937	0.01	0.007	0	31.4	26.7	50.3	113	99	0	40	37
2015	12	22	14	25	33	0.732	-0.118	3.934	0.01	0.007	0	36.5	31.8	47.7	124	111	0	39	37
2015	12	22	14	35	33	0.728	-0.079	3.937	0.01	0.007	0	40	35.7	47.7	133	120	0	40	37
2015	12	22	14	45	33	0.751	-0.108	3.93	0.013	0.01	0	40.4	35.7	43	133	120	0	39	37
2015	12	22	14	55	33	0.725	-0.079	3.934	0.01	0.007	0	40	35.3	46.9	133	120	0	40	38
2015	12	22	15	5	33	0.712	-0.102	3.934	0.01	0.007	0	39.6	35.3	47.7	132	119	0	40	37
2015	12	22	15	15	33	0.725	-0.072	3.934	0.01	0.007	0	40.4	36.1	44.3	134	121	0	40	37
2015	12	22	15	25	33	0.741	-0.082	3.934	0.016	0.013	0	40.4	36.5	44.7	134	122	0	40	37
2015	12	22	15	35	33	0.702	-0.098	3.934	0.01	0.007	0	40.4	36.1	51.2	134	121	0	40	37
2015	12	22	15	45	33	0.761	-0.115	3.934	0.01	0.007	0	38.7	34	49.9	130	116	0	40	37
2015	12	22	15	55	33	0.745	-0.069	3.934	0.013	0.01	0	37.4	33.5	49.9	127	114	0	40	36
2015	12	22	16	5	33	0.732	-0.098	3.934	0.01	0.007	0	38.7	33.1	49.9	129	115	0	39	38
2015	12	22	16	15	33	0.712	-0.075	3.934	0.01	0.007	0	36.5	32.3	52.5	125	112	0	40	37
2015	12	22	16	25	33	0.751	-0.092	3.934	0.01	0.007	0	37	32.7	48.2	126	113	0	40	37
2015	12	22	16	35	33	0.696	-0.075	3.934	0.01	0.007	0	36.5	32.3	61.1	125	112	0	40	37
2015	12	22	16	45	33	0.735	-0.089	3.934	0.01	0.007	0	36.1	31.4	60.6	124	110	0	40	37
2015	12	22	16	55	33	0.725	-0.098	3.934	0.01	0.007	0	34.8	31	54.2	121	108	0	40	36
2015	12	22	17	5	33	0.738	-0.092	3.934	0.01	0.007	0	34	30.1	54.2	119	106	0	40	36
2015	12	22	17	15	33	0.719	-0.089	3.934	0.01	0.007	0	32.7	28.4	52.9	116	103	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	22	17	25	33	0.719	-0.089	3.937	0.01	0.007	0	31.4	26.7	74	112	99	0	39	37
2015	12	22	17	35	33	0.689	-0.089	3.937	0.01	0.007	0	30.5	25.8	74	110	96	0	39	36
2015	12	22	17	45	33	0.689	-0.102	3.937	0.01	0.007	0	28.8	24.5	71	107	94	0	40	37
2015	12	22	17	55	33	0.738	-0.105	3.937	0.01	0.007	0	28.8	24.5	68.4	107	94	0	40	37
2015	12	22	18	5	33	0.712	-0.112	3.937	0.01	0.007	0	29.2	24.9	63.6	108	95	0	40	37
2015	12	22	18	15	33	0.748	-0.066	3.934	0.01	0.007	0	29.2	24.5	50.7	107	94	0	39	37
2015	12	22	18	25	33	0.722	-0.059	3.93	0.01	0.007	0	30.5	25.8	46.4	110	97	0	39	37
2015	12	22	18	35	33	0.741	-0.102	3.93	0.01	0.007	0	30.5	26.2	45.6	111	98	0	40	37
2015	12	22	18	45	33	0.735	-0.085	3.937	0.01	0.007	0	30.5	26.2	69.7	111	98	0	40	37
2015	12	22	18	55	33	0.722	-0.112	3.937	0.01	0.007	0	28.8	24.1	74.4	106	93	0	39	37
2015	12	22	19	5	33	0.728	-0.131	3.937	0.01	0.007	0	27.5	23.6	76.5	104	92	0	40	37
2015	12	22	19	15	33	0.732	-0.108	3.937	0.01	0.007	0	27.1	21.9	71.4	102	89	0	39	38
2015	12	22	19	25	33	0.709	-0.089	3.934	0.01	0.007	0	26.7	22.8	49.9	102	90	0	40	37
2015	12	22	19	35	33	0.709	-0.089	3.937	0.01	0.007	0	26.7	22.4	74	101	89	0	39	37
2015	12	22	19	45	33	0.676	-0.098	3.937	0.013	0.01	0	26.2	21.9	72.7	101	88	0	40	37
2015	12	22	19	55	33	0.682	-0.105	3.937	0.013	0.01	0	26.2	21.9	71.8	100	88	0	39	37
2015	12	22	20	5	33	0.725	-0.075	3.937	0.01	0.007	0	25.8	21.9	66.7	100	88	0	40	37
2015	12	22	20	15	33	0.719	-0.121	3.937	0.013	0.01	0	25.4	21.5	74.4	99	87	0	40	37
2015	12	22	20	25	33	0.702	-0.115	3.937	0.01	0.007	0	25.4	21.5	74.4	99	87	0	40	37
2015	12	22	20	35	33	0.705	-0.108	3.934	0.01	0.007	0	25.8	21.5	64.9	100	87	0	40	37
2015	12	22	20	45	33	0.732	-0.118	3.934	0.01	0.007	0	25.8	21.5	59.3	99	87	0	39	37
2015	12	22	20	55	33	0.738	-0.092	3.934	0.01	0.007	0	25.8	21.5	50.3	100	87	0	40	37
2015	12	22	21	5	33	0.676	-0.075	3.934	0.01	0.007	0	26.2	21.9	52.9	101	88	0	40	37
2015	12	22	21	15	33	0.719	-0.089	3.934	0.013	0.01	0	25.8	21.9	53.8	100	88	0	40	37
2015	12	22	21	25	33	0.725	-0.075	3.937	0.01	0.007	0	25.8	21.1	73.5	99	86	0	39	37
2015	12	22	21	35	33	0.696	-0.102	3.934	0.01	0.007	0	25.8	21.9	49	100	88	0	40	37
2015	12	22	21	45	33	0.682	-0.079	3.93	0.01	0.007	0	26.2	21.9	46.4	100	88	0	39	37
2015	12	22	21	55	33	0.725	-0.085	3.934	0.01	0.007	0	25.8	21.1	55.5	100	87	0	40	38
2015	12	22	22	5	33	0.692	-0.095	3.934	0.01	0.007	0	26.2	21.9	52	100	88	0	39	37
2015	12	22	22	15	33	0.738	-0.115	3.93	0.01	0.007	0	28.4	24.1	49.5	106	93	0	40	37
2015	12	22	22	25	33	0.748	-0.135	3.934	0.01	0.007	0	29.2	24.5	70.5	108	94	0	40	37
2015	12	22	22	35	33	0.725	-0.112	3.934	0.01	0.007	0	29.2	24.5	72.7	107	94	0	39	37
2015	12	22	22	45	33	0.719	-0.095	3.937	0.01	0.007	0	27.1	23.2	71	103	91	0	40	37
2015	12	22	22	55	33	0.699	-0.118	3.934	0.01	0.007	0	26.7	22.4	74.4	102	89	0	40	37
2015	12	22	23	5	33	0.712	-0.098	3.937	0.01	0.007	0	26.2	22.4	71.4	101	89	0	40	37
2015	12	22	23	15	33	0.699	-0.095	3.934	0.01	0.007	0	25.8	21.5	58.5	99	87	0	39	37
2015	12	22	23	25	33	0.715	-0.102	3.937	0.01	0.007	0	26.7	21.9	76.5	101	88	0	39	37
2015	12	22	23	35	33	0.728	-0.079	3.934	0.01	0.007	0	24.9	20.6	58.5	98	85	0	40	37
2015	12	22	23	45	33	0.696	-0.102	3.937	0.01	0.007	0	25.8	21.9	66.2	100	88	0	40	37
2015	12	22	23	55	33	0.702	-0.082	3.937	0.01	0.007	0	26.2	21.5	71.4	100	87	0	39	37
2015	12	23	0	5	33	0.679	-0.075	3.937	0.01	0.007	0	25.4	21.5	74.8	99	87	0	40	37
2015	12	23	0	15	33	0.715	-0.108	3.937	0.013	0.01	0	31.8	27.5	76.1	113	100	0	39	36
2015	12	23	0	25	33	0.741	-0.102	3.937	0.01	0.007	0	29.7	24.5	74.8	109	95	0	40	38
2015	12	23	0	35	33	0.725	-0.085	3.934	0.01	0.007	0	26.7	22.4	57.6	102	89	0	40	37
2015	12	23	0	45	33	0.702	-0.095	3.937	0.01	0.007	0	25.8	22.4	70.5	100	88	0	40	36
2015	12	23	0	55	33	0.689	-0.089	3.937	0.01	0.007	0	25.8	21.5	72.2	99	87	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	1	5	33	0.725	-0.098	3.937	0.01	0.007	0	25.4	21.1	65.4	99	86	0	40	37
2015	12	23	1	15	33	0.686	-0.092	3.937	0.01	0.007	0	24.9	20.6	66.2	97	85	0	39	37
2015	12	23	1	25	33	0.673	-0.105	3.937	0.01	0.007	0	24.9	21.9	69.7	98	87	0	40	36
2015	12	23	1	35	33	0.751	-0.082	3.934	0.01	0.007	0	25.8	21.5	53.8	100	87	0	40	37
2015	12	23	1	45	33	0.689	-0.108	3.934	0.01	0.007	0	29.2	24.9	50.3	107	94	0	39	36
2015	12	23	1	55	33	0.702	-0.131	3.93	0.01	0.007	0	38.7	33.1	44.7	129	114	0	39	37
2015	12	23	2	5	33	0.745	-0.105	3.93	0.01	0.007	0	34.4	29.7	46.4	119	106	0	39	37
2015	12	23	2	15	33	0.764	-0.125	3.93	0.01	0.007	0	37.4	33.5	44.3	127	114	0	40	36
2015	12	23	2	25	33	0.712	-0.098	3.934	0.01	0.007	0	36.5	31.8	47.3	125	111	0	40	37
2015	12	23	2	35	33	0.669	-0.089	3.934	0.01	0.007	0	35.7	31	47.3	123	109	0	40	37
2015	12	23	2	45	33	0.722	-0.102	3.93	0.01	0.007	0	34	29.2	46	118	105	0	39	37
2015	12	23	2	55	33	0.735	-0.098	3.934	0.01	0.007	0	34.8	30.5	47.3	121	108	0	40	37
2015	12	23	3	5	33	0.755	-0.115	3.934	0.01	0.007	0	33.5	28.4	48.2	117	103	0	39	37
2015	12	23	3	15	33	0.699	-0.059	3.934	0.01	0.007	0	31.4	27.1	58.5	113	100	0	40	37
2015	12	23	3	25	33	0.728	-0.105	3.937	0.01	0.007	0	30.5	25.8	61.1	110	97	0	39	37
2015	12	23	3	35	33	0.732	-0.102	3.934	0.01	0.007	0	29.7	24.9	49.5	108	95	0	39	37
2015	12	23	3	45	33	0.748	-0.125	3.937	0.01	0.007	0	29.2	24.9	56.8	108	95	0	40	37
2015	12	23	3	55	33	0.722	-0.072	3.934	0.01	0.007	0	28.4	24.1	49.5	106	93	0	40	37
2015	12	23	4	5	33	0.751	-0.069	3.93	0.01	0.007	0	28.4	23.6	46.9	105	92	0	39	37
2015	12	23	4	15	33	0.696	-0.075	3.934	0.01	0.007	0	28	23.6	51.2	105	92	0	40	37
2015	12	23	4	25	33	0.719	-0.079	3.934	0.01	0.007	0	27.1	22.8	49	102	90	0	39	37
2015	12	23	4	35	33	0.751	-0.079	3.934	0.01	0.007	0	26.2	22.4	50.7	101	89	0	40	37
2015	12	23	4	45	33	0.728	-0.062	3.934	0.01	0.007	0	26.2	21.9	48.2	101	88	0	40	37
2015	12	23	4	55	33	0.719	-0.121	3.934	0.01	0.007	0	25.8	21.9	53.8	100	87	0	40	36
2015	12	23	5	5	33	0.738	-0.092	3.937	0.01	0.007	0	25.4	21.5	73.5	99	87	0	40	37
2015	12	23	5	15	33	0.699	-0.095	3.937	0.01	0.007	0	24.5	20.6	49.5	97	86	0	40	38
2015	12	23	5	25	33	0.65	-0.108	3.934	0.01	0.007	0	24.5	20.2	55.5	97	85	0	40	38
2015	12	23	5	35	33	0.676	-0.092	3.934	0.01	0.007	0	24.5	20.2	48.6	96	84	0	39	37
2015	12	23	5	45	33	0.702	-0.075	3.937	0.01	0.007	0	23.6	19.8	64.5	95	83	0	40	37
2015	12	23	5	55	33	0.712	-0.098	3.937	0.01	0.007	0	24.1	20.2	69.7	96	84	0	40	37
2015	12	23	6	5	33	0.676	-0.112	3.937	0.01	0.007	0	23.6	19.8	72.2	95	83	0	40	37
2015	12	23	6	15	33	0.676	-0.075	3.937	0.01	0.007	0	23.6	19.8	72.2	94	83	0	39	37
2015	12	23	6	25	33	0.65	-0.102	3.937	0.01	0.007	0	23.2	19.4	75.3	94	82	0	40	37
2015	12	23	6	35	33	0.686	-0.066	3.937	0.01	0.007	0	23.6	18.9	76.1	94	82	0	39	38
2015	12	23	6	45	33	0.696	-0.075	3.937	0.01	0.007	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	23	6	55	33	0.653	-0.089	3.937	0.01	0.007	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	23	7	5	33	0.686	-0.056	3.937	0.01	0.007	0	22.8	18.9	76.1	93	81	0	40	37
2015	12	23	7	15	33	0.676	-0.072	3.937	0.01	0.007	0	23.2	18.9	76.5	93	81	0	39	37
2015	12	23	7	25	33	0.679	-0.075	3.937	0.01	0.007	0	22.8	19.4	77	93	82	0	40	37
2015	12	23	7	35	33	0.676	-0.072	3.937	0.01	0.007	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	23	7	45	33	0.643	-0.03	3.937	0.01	0.007	0	22.8	18.9	77	93	81	0	40	37
2015	12	23	7	55	33	0.62	-0.069	3.937	0.01	0.007	0	22.8	18.9	77	92	81	0	39	37
2015	12	23	8	5	33	0.689	-0.072	3.937	0.01	0.007	0	22.8	19.4	77	92	81	0	39	36
2015	12	23	8	15	33	0.692	-0.059	3.937	0.013	0.01	0	22.8	18.9	76.1	92	81	0	39	37
2015	12	23	8	25	33	0.64	-0.062	3.94	0.01	0.007	0	22.8	19.4	77	93	82	0	40	37
2015	12	23	8	35	33	0.653	-0.059	3.937	0.01	0.007	0	22.8	18.9	77	92	81	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	8	45	33	0.663	-0.036	3.937	0.01	0.007	0	22.4	18.9	76.5	92	81	0	40	37
2015	12	23	8	55	33	0.656	-0.033	3.94	0.01	0.007	0	22.4	18.9	76.1	92	82	0	40	38
2015	12	23	9	5	33	0.653	-0.052	3.937	0.01	0.007	0	22.4	19.4	76.1	92	82	0	40	37
2015	12	23	9	15	33	0.646	-0.043	3.94	0.01	0.007	0	22.8	19.8	76.1	93	82	0	40	36
2015	12	23	9	25	33	0.623	-0.089	3.94	0.01	0.007	0	22.8	19.8	76.1	92	82	0	39	36
2015	12	23	9	35	33	0.65	-0.066	3.94	0.01	0.007	0	22.4	18.9	76.1	92	82	0	40	38
2015	12	23	9	45	33	0.682	-0.062	3.94	0.01	0.007	0	22.8	19.4	76.5	92	81	0	39	36
2015	12	23	9	55	33	0.63	-0.052	3.94	0.01	0.007	0	22.4	19.4	74.8	92	81	0	40	36
2015	12	23	10	5	33	0.669	-0.036	3.94	0.01	0.007	0	22.4	18.9	74	92	81	0	40	37
2015	12	23	10	15	33	0.696	-0.066	3.94	0.01	0.007	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	23	10	25	33	0.646	-0.049	3.94	0.01	0.007	0	22.8	18.9	71.4	92	81	0	39	37
2015	12	23	10	35	33	0.702	-0.089	3.94	0.01	0.007	0	22.8	19.4	72.7	93	82	0	40	37
2015	12	23	10	45	33	0.673	-0.052	3.94	0.013	0.01	0	22.8	19.8	60.2	92	82	0	39	36
2015	12	23	10	55	33	0.659	-0.082	3.94	0.01	0.007	0	23.2	19.8	65.4	93	82	0	39	36
2015	12	23	11	5	33	0.719	-0.082	3.94	0.01	0.007	0	22.8	19.8	58.5	93	82	0	40	36
2015	12	23	11	15	33	0.679	-0.049	3.94	0.01	0.007	0	23.2	19.8	64.9	93	83	0	39	37
2015	12	23	11	25	33	0.682	-0.052	3.944	0.01	0.007	0	23.6	20.2	71.8	95	84	0	40	37
2015	12	23	11	35	33	0.676	-0.062	3.94	0.01	0.007	0	23.2	19.8	63.2	94	83	0	40	37
2015	12	23	11	45	33	0.673	-0.079	3.944	0.01	0.007	0	23.6	20.2	66.7	95	84	0	40	37
2015	12	23	11	55	33	0.656	-0.052	3.94	0.01	0.007	0	24.1	20.6	68.4	96	84	0	40	36
2015	12	23	12	5	33	0.62	-0.062	3.94	0.01	0.007	0	24.1	19.8	63.2	95	84	0	39	38
2015	12	23	12	15	33	0.646	-0.085	3.94	0.01	0.007	0	23.6	19.8	71	94	83	0	39	37
2015	12	23	12	25	33	0.643	-0.069	3.944	0.01	0.007	0	23.2	19.8	70.5	94	83	0	40	37
2015	12	23	12	35	33	0.705	-0.056	3.94	0.013	0.01	0	23.2	19.4	72.2	93	82	0	39	37
2015	12	23	12	45	33	0.699	-0.052	3.94	0.01	0.007	0	23.2	19.8	70.5	93	83	0	39	37
2015	12	23	12	55	33	0.669	-0.075	3.94	0.01	0.007	0	22.8	19.4	71.4	93	82	0	40	37
2015	12	23	13	5	33	0.636	-0.085	3.94	0.01	0.007	0	23.2	19.4	74.4	93	82	0	39	37
2015	12	23	13	15	33	0.679	-0.069	3.94	0.01	0.007	0	22.8	19.4	74	92	82	0	39	37
2015	12	23	13	25	33	0.686	-0.075	3.94	0.01	0.007	0	22.4	18.9	73.1	92	81	0	40	37
2015	12	23	13	35	33	0.669	-0.062	3.94	0.01	0.007	0	22.4	18.9	75.3	92	81	0	40	37
2015	12	23	13	45	33	0.643	-0.066	3.94	0.01	0.007	0	21.9	18.9	74.8	91	81	0	40	37
2015	12	23	13	55	33	0.676	-0.056	3.94	0.01	0.007	0	22.4	18.9	74.4	92	81	0	40	37
2015	12	23	14	5	33	0.646	-0.095	3.94	0.01	0.007	0	21.9	18.5	74.4	91	80	0	40	37
2015	12	23	14	15	33	0.669	-0.052	3.94	0.01	0.007	0	22.4	18.5	72.2	91	80	0	39	37
2015	12	23	14	25	33	0.659	-0.075	3.94	0.01	0.007	0	21.9	18.5	76.1	90	80	0	39	37
2015	12	23	14	35	33	0.643	-0.098	3.94	0.01	0.007	0	22.4	18.5	76.1	91	80	0	39	37
2015	12	23	14	45	33	0.63	-0.085	3.94	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	23	14	55	33	0.666	-0.092	3.94	0.01	0.007	0	21.5	18.1	76.5	90	79	0	40	37
2015	12	23	15	5	33	0.62	-0.095	3.94	0.01	0.007	0	21.5	18.5	74.8	90	80	0	40	37
2015	12	23	15	15	33	0.643	-0.075	3.94	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	23	15	25	33	0.646	-0.069	3.94	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	23	15	35	33	0.656	-0.102	3.94	0.01	0.007	0	21.5	18.1	75.7	90	79	0	40	37
2015	12	23	15	45	33	0.63	-0.075	3.937	0.01	0.007	0	21.9	18.5	76.1	90	80	0	39	37
2015	12	23	15	55	33	0.65	-0.108	3.937	0.01	0.007	0	26.7	22.4	76.1	101	88	0	39	36
2015	12	23	16	5	33	0.728	-0.108	3.937	0.01	0.007	0	28.4	23.6	76.1	105	92	0	39	37
2015	12	23	16	15	33	0.676	-0.072	3.937	0.01	0.007	0	24.1	20.2	76.1	96	84	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	23	16	25	33	0.623	-0.075	3.937	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	23	16	35	33	0.633	-0.082	3.94	0.01	0.007	0	22.4	18.5	75.7	91	80	0	39	37
2015	12	23	16	45	33	0.656	-0.056	3.937	0.01	0.007	0	21.5	18.9	76.1	90	80	0	40	36
2015	12	23	16	55	33	0.61	-0.069	3.937	0.01	0.007	0	22.4	18.5	76.1	91	80	0	39	37
2015	12	23	17	5	33	0.62	-0.062	3.937	0.01	0.007	0	21.9	18.5	75.7	90	80	0	39	37
2015	12	23	17	15	33	0.663	-0.069	3.937	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	23	17	25	33	0.643	-0.069	3.937	0.01	0.007	0	22.4	18.1	65.8	91	79	0	39	37
2015	12	23	17	35	33	0.627	-0.079	3.937	0.01	0.007	0	21.5	18.1	76.1	90	79	0	40	37
2015	12	23	17	45	33	0.604	-0.089	3.937	0.01	0.007	0	22.4	18.1	75.7	91	79	0	39	37
2015	12	23	17	55	33	0.636	-0.069	3.937	0.013	0.01	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	23	18	5	33	0.64	-0.075	3.937	0.01	0.007	0	21.5	18.1	76.5	90	79	0	40	37
2015	12	23	18	15	33	0.61	-0.075	3.937	0.01	0.007	0	21.5	18.5	75.7	90	80	0	40	37
2015	12	23	18	25	33	0.604	-0.082	3.937	0.01	0.007	0	21.9	18.1	76.5	90	79	0	39	37
2015	12	23	18	35	33	0.633	-0.062	3.937	0.013	0.01	0	21.9	17.6	76.1	90	79	0	39	38
2015	12	23	18	45	33	0.679	-0.098	3.937	0.01	0.007	0	21.5	18.1	73.5	90	80	0	40	38
2015	12	23	18	55	33	0.656	-0.112	3.937	0.01	0.007	0	25.8	21.9	76.1	100	88	0	40	37
2015	12	23	19	5	33	0.636	-0.069	3.937	0.01	0.007	0	23.6	19.8	75.3	94	83	0	39	37
2015	12	23	19	15	33	0.617	-0.102	3.937	0.01	0.007	0	23.2	19.4	73.1	94	82	0	40	37
2015	12	23	19	25	33	0.61	-0.089	3.937	0.01	0.007	0	22.8	19.4	75.7	92	81	0	39	36
2015	12	23	19	35	33	0.627	-0.049	3.937	0.01	0.007	0	21.9	18.1	76.5	91	80	0	40	38
2015	12	23	19	45	33	0.636	-0.085	3.937	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	23	19	55	33	0.646	-0.085	3.937	0.013	0.01	0	22.4	18.9	76.5	92	81	0	40	37
2015	12	23	20	5	33	0.669	-0.079	3.937	0.013	0.01	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	23	20	15	33	0.574	-0.079	3.937	0.01	0.007	0	22.4	18.5	75.7	91	80	0	39	37
2015	12	23	20	25	33	0.669	-0.089	3.937	0.01	0.007	0	22.8	19.8	75.7	93	83	0	40	37
2015	12	23	20	35	33	0.663	-0.079	3.937	0.01	0.007	0	22.4	18.5	75.7	92	80	0	40	37
2015	12	23	20	45	33	0.604	-0.112	3.937	0.01	0.007	0	22.4	19.4	75.7	92	81	0	40	36
2015	12	23	20	55	33	0.65	-0.066	3.937	0.01	0.007	0	21.5	18.1	65.8	90	79	0	40	37
2015	12	23	21	5	33	0.633	-0.072	3.937	0.01	0.007	0	22.8	18.5	69.2	92	80	0	39	37
2015	12	23	21	15	33	0.696	-0.072	3.934	0.01	0.007	0	22.4	18.9	53.3	92	80	0	40	36
2015	12	23	21	25	33	0.64	-0.112	3.937	0.01	0.007	0	22.8	19.4	76.1	92	81	0	39	36
2015	12	23	21	35	33	0.663	-0.085	3.937	0.01	0.007	0	21.9	18.5	75.3	91	80	0	40	37
2015	12	23	21	45	33	0.597	-0.098	3.937	0.01	0.007	0	22.4	18.1	76.1	92	80	0	40	38
2015	12	23	21	55	33	0.63	-0.085	3.937	0.01	0.007	0	21.9	18.9	76.1	91	80	0	40	36
2015	12	23	22	5	33	0.663	-0.089	3.937	0.01	0.007	0	21.5	18.1	74.4	90	79	0	40	37
2015	12	23	22	15	33	0.715	-0.085	3.937	0.01	0.007	0	23.2	19.8	76.5	94	83	0	40	37
2015	12	23	22	25	33	0.65	-0.112	3.937	0.01	0.007	0	24.1	19.8	76.5	95	83	0	39	37
2015	12	23	22	35	33	0.636	-0.075	3.937	0.01	0.007	0	22.4	18.5	76.1	92	80	0	40	37
2015	12	23	22	45	33	0.64	-0.072	3.937	0.01	0.007	0	21.9	18.5	74.4	91	80	0	40	37
2015	12	23	22	55	33	0.653	-0.102	3.937	0.01	0.007	0	21.9	18.5	76.5	90	79	0	39	36
2015	12	23	23	5	33	0.633	-0.138	3.937	0.01	0.007	0	21.9	18.1	77	90	79	0	39	37
2015	12	23	23	15	33	0.659	-0.092	3.937	0.01	0.007	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	23	23	25	33	0.64	-0.102	3.934	0.013	0.01	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	23	23	35	33	0.6	-0.112	3.937	0.01	0.007	0	21.9	17.6	76.5	90	78	0	39	37
2015	12	23	23	45	33	0.633	-0.102	3.937	0.01	0.007	0	21.5	18.1	76.5	90	78	0	40	36
2015	12	23	23	55	33	0.64	-0.108	3.937	0.013	0.01	0	21.1	18.1	77	89	78	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	0	5	33	0.659	-0.092	3.937	0.01	0.007	0	21.1	17.2	76.1	89	77	0	40	37
2015	12	24	0	15	33	0.627	-0.102	3.934	0.01	0.007	0	21.5	17.2	76.5	89	77	0	39	37
2015	12	24	0	25	33	0.617	-0.115	3.937	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	0	35	33	0.623	-0.072	3.934	0.01	0.007	0	21.5	17.6	76.5	90	78	0	40	37
2015	12	24	0	45	33	0.617	-0.089	3.934	0.01	0.007	0	21.5	18.5	76.5	90	79	0	40	36
2015	12	24	0	55	33	0.62	-0.043	3.937	0.013	0.01	0	21.9	18.1	76.1	91	79	0	40	37
2015	12	24	1	5	33	0.617	-0.089	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	1	15	33	0.607	-0.092	3.934	0.01	0.007	0	21.9	17.6	76.5	90	78	0	39	37
2015	12	24	1	25	33	0.65	-0.062	3.934	0.01	0.007	0	21.5	17.2	76.5	89	77	0	39	37
2015	12	24	1	35	33	0.627	-0.092	3.934	0.01	0.007	0	21.5	17.2	76.1	90	77	0	40	37
2015	12	24	1	45	33	0.604	-0.085	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	1	55	33	0.617	-0.098	3.934	0.01	0.007	0	21.9	17.6	76.5	90	78	0	39	37
2015	12	24	2	5	33	0.627	-0.089	3.934	0.01	0.007	0	21.1	17.6	77	89	78	0	40	37
2015	12	24	2	15	33	0.597	-0.102	3.934	0.01	0.007	0	21.9	17.6	76.5	90	78	0	39	37
2015	12	24	2	25	33	0.62	-0.105	3.934	0.01	0.007	0	21.5	17.6	77	89	78	0	39	37
2015	12	24	2	35	33	0.627	-0.072	3.934	0.01	0.007	0	21.1	17.6	77	89	78	0	40	37
2015	12	24	2	45	33	0.673	-0.095	3.934	0.01	0.007	0	21.1	17.2	71	88	77	0	39	37
2015	12	24	2	55	33	0.614	-0.095	3.934	0.01	0.007	0	21.9	17.6	77	91	78	0	40	37
2015	12	24	3	5	33	0.676	-0.095	3.934	0.01	0.007	0	21.5	17.2	76.5	90	78	0	40	38
2015	12	24	3	15	33	0.614	-0.105	3.934	0.013	0.01	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	3	25	33	0.604	-0.089	3.934	0.013	0.01	0	21.1	17.6	77	89	78	0	40	37
2015	12	24	3	35	33	0.594	-0.112	3.934	0.01	0.007	0	22.4	18.1	77.4	91	79	0	39	37
2015	12	24	3	45	33	0.614	-0.105	3.934	0.013	0.01	0	21.5	17.6	77.4	90	78	0	40	37
2015	12	24	3	55	33	0.643	-0.112	3.934	0.01	0.007	0	21.9	17.6	77.4	90	78	0	39	37
2015	12	24	4	5	33	0.584	-0.079	3.934	0.01	0.007	0	21.5	17.6	77.4	90	78	0	40	37
2015	12	24	4	15	33	0.614	-0.115	3.934	0.01	0.007	0	21.5	17.6	77.8	90	78	0	40	37
2015	12	24	4	25	33	0.61	-0.049	3.934	0.01	0.007	0	21.5	17.6	77.8	90	78	0	40	37
2015	12	24	4	35	33	0.673	-0.069	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	4	45	33	0.623	-0.121	3.934	0.01	0.007	0	21.5	17.2	77	90	77	0	40	37
2015	12	24	4	55	33	0.653	-0.085	3.934	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	5	5	33	0.63	-0.105	3.934	0.01	0.007	0	21.5	17.6	77.4	90	78	0	40	37
2015	12	24	5	15	33	0.663	-0.082	3.934	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	5	25	33	0.656	-0.115	3.93	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	5	35	33	0.653	-0.102	3.93	0.013	0.01	0	21.9	18.1	77.4	90	79	0	39	37
2015	12	24	5	45	33	0.673	-0.079	3.93	0.01	0.007	0	21.5	17.2	77.4	90	78	0	40	38
2015	12	24	5	55	33	0.623	-0.112	3.93	0.01	0.007	0	21.5	17.6	77.8	90	78	0	40	37
2015	12	24	6	5	33	0.669	-0.102	3.934	0.01	0.007	0	21.5	18.1	77.4	90	79	0	40	37
2015	12	24	6	15	33	0.659	-0.092	3.934	0.01	0.007	0	21.9	18.5	77	90	79	0	39	36
2015	12	24	6	25	33	0.689	-0.085	3.93	0.013	0.01	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	6	35	33	0.738	-0.105	3.934	0.01	0.007	0	21.5	17.2	76.5	89	77	0	39	37
2015	12	24	6	45	33	0.62	-0.095	3.934	0.01	0.007	0	21.9	18.5	77.8	91	80	0	40	37
2015	12	24	6	55	33	0.659	-0.112	3.934	0.01	0.007	0	24.5	20.2	77.8	96	84	0	39	37
2015	12	24	7	5	33	0.646	-0.082	3.93	0.01	0.007	0	22.8	18.9	76.1	93	81	0	40	37
2015	12	24	7	15	33	0.676	-0.072	3.934	0.01	0.007	0	22.8	18.5	77.8	92	80	0	39	37
2015	12	24	7	25	33	0.669	-0.092	3.93	0.01	0.007	0	22.8	18.5	77	93	80	0	40	37
2015	12	24	7	35	33	0.699	-0.135	3.934	0.01	0.007	0	24.5	20.6	76.5	97	85	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	7	45	33	0.689	-0.112	3.934	0.013	0.01	0	28.8	24.5	77	107	94	0	40	37
2015	12	24	7	55	33	0.696	-0.108	3.934	0.01	0.007	0	25.8	21.5	76.5	100	87	0	40	37
2015	12	24	8	5	33	0.696	-0.108	3.934	0.01	0.007	0	26.2	21.5	76.5	100	87	0	39	37
2015	12	24	8	15	33	0.659	-0.105	3.934	0.01	0.007	0	24.1	19.8	77	95	83	0	39	37
2015	12	24	8	25	33	0.656	-0.112	3.934	0.01	0.007	0	24.9	20.6	77.4	98	85	0	40	37
2015	12	24	8	35	33	0.656	-0.085	3.934	0.01	0.007	0	23.2	19.4	76.5	93	82	0	39	37
2015	12	24	8	45	33	0.656	-0.059	3.934	0.01	0.007	0	24.1	19.8	60.6	95	83	0	39	37
2015	12	24	8	55	33	0.673	-0.112	3.934	0.013	0.01	0	21.9	18.5	77.8	91	80	0	40	37
2015	12	24	9	5	33	0.623	-0.082	3.934	0.013	0.01	0	21.9	18.5	61.5	91	80	0	40	37
2015	12	24	9	15	33	0.669	-0.085	3.934	0.01	0.007	0	21.9	18.5	68.4	91	80	0	40	37
2015	12	24	9	25	33	0.673	-0.069	3.934	0.01	0.007	0	21.5	18.1	61.5	90	79	0	40	37
2015	12	24	9	35	33	0.614	-0.075	3.934	0.01	0.007	0	21.5	18.5	47.7	90	80	0	40	37
2015	12	24	9	45	33	0.653	-0.092	3.934	0.01	0.007	0	22.4	18.9	56.8	92	82	0	40	38
2015	12	24	9	55	33	0.623	-0.082	3.934	0.01	0.007	0	21.9	18.5	56.3	91	80	0	40	37
2015	12	24	10	5	33	0.64	-0.043	3.934	0.013	0.01	0	21.5	18.1	55	90	79	0	40	37
2015	12	24	10	15	33	0.65	-0.072	3.937	0.01	0.007	0	21.9	18.5	63.2	91	80	0	40	37
2015	12	24	10	25	33	0.682	-0.085	3.937	0.01	0.007	0	21.9	18.1	52	91	80	0	40	38
2015	12	24	10	35	33	0.64	-0.059	3.937	0.01	0.007	0	21.5	17.6	54.6	90	79	0	40	38
2015	12	24	10	45	33	0.663	-0.089	3.937	0.01	0.007	0	21.9	18.5	49	91	80	0	40	37
2015	12	24	10	55	33	0.653	-0.062	3.937	0.01	0.007	0	21.9	18.9	55.5	91	80	0	40	36
2015	12	24	11	5	33	0.669	-0.066	3.937	0.01	0.007	0	21.9	18.9	49.5	91	81	0	40	37
2015	12	24	11	15	33	0.587	-0.059	3.937	0.01	0.007	0	22.4	19.4	47.3	92	82	0	40	37
2015	12	24	11	25	33	0.663	-0.085	3.937	0.01	0.007	0	21.9	18.9	58.5	91	80	0	40	36
2015	12	24	11	35	33	0.663	-0.112	3.94	0.01	0.007	0	22.8	18.5	64.5	92	81	0	39	38
2015	12	24	11	45	33	0.653	-0.089	3.937	0.01	0.007	0	22.8	18.9	52.5	92	82	0	39	38
2015	12	24	11	55	33	0.627	-0.062	3.937	0.01	0.007	0	23.2	19.8	46	93	83	0	39	37
2015	12	24	12	5	33	0.64	-0.089	3.937	0.01	0.007	0	22.4	18.9	53.3	92	81	0	40	37
2015	12	24	12	15	33	0.627	-0.069	3.937	0.01	0.007	0	22.8	19.4	46.9	93	82	0	40	37
2015	12	24	12	25	33	0.623	-0.072	3.937	0.01	0.007	0	22.8	19.8	46.4	93	82	0	40	36
2015	12	24	12	35	33	0.6	-0.062	3.934	0.01	0.007	0	23.6	19.8	45.2	94	83	0	39	37
2015	12	24	12	45	33	0.679	-0.072	3.937	0.01	0.007	0	26.7	22.8	43.4	102	90	0	40	37
2015	12	24	12	55	33	0.666	-0.089	3.937	0.01	0.007	0	25.4	21.5	46.4	99	87	0	40	37
2015	12	24	13	5	33	0.669	-0.066	3.937	0.01	0.007	0	23.6	20.2	49	95	84	0	40	37
2015	12	24	13	15	33	0.663	-0.079	3.937	0.01	0.007	0	23.2	19.4	51.6	93	82	0	39	37
2015	12	24	13	25	33	0.6	-0.089	3.937	0.01	0.007	0	23.2	18.9	48.2	93	81	0	39	37
2015	12	24	13	35	33	0.673	-0.072	3.937	0.01	0.007	0	23.2	19.4	57.6	94	82	0	40	37
2015	12	24	13	45	33	0.656	-0.102	3.937	0.01	0.007	0	22.8	19.4	63.6	93	81	0	40	36
2015	12	24	13	55	33	0.741	-0.108	3.937	0.016	0.013	0	33.5	28.8	48.6	118	104	0	40	37
2015	12	24	14	5	33	0.709	-0.098	3.937	0.01	0.007	0	27.1	22.8	61.5	103	90	0	40	37
2015	12	24	14	15	33	0.692	-0.089	3.937	0.01	0.007	0	24.9	21.1	74	98	86	0	40	37
2015	12	24	14	25	33	0.673	-0.089	3.94	0.01	0.007	0	24.9	20.2	75.3	97	84	0	39	37
2015	12	24	14	35	33	0.676	-0.085	3.937	0.016	0.013	0	27.5	22.8	59.8	104	91	0	40	38
2015	12	24	14	45	33	0.712	-0.112	3.94	0.01	0.007	0	28.8	24.5	65.4	107	94	0	40	37
2015	12	24	14	55	33	0.663	-0.098	3.94	0.01	0.007	0	24.5	19.8	75.7	96	83	0	39	37
2015	12	24	15	5	33	0.689	-0.072	3.937	0.01	0.007	0	22.8	19.4	53.3	93	82	0	40	37
2015	12	24	15	15	33	0.643	-0.072	3.937	0.013	0.01	0	22.4	18.1	72.2	92	80	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	15	25	33	0.666	-0.069	3.937	0.01	0.007	0	21.9	18.1	71.4	91	79	0	40	37
2015	12	24	15	35	33	0.669	-0.118	3.94	0.01	0.007	0	21.9	18.5	75.3	91	79	0	40	36
2015	12	24	15	45	33	0.676	-0.072	3.94	0.01	0.007	0	22.4	18.5	76.5	92	80	0	40	37
2015	12	24	15	55	33	0.663	-0.062	3.937	0.01	0.007	0	22.4	18.1	68.4	91	80	0	39	38
2015	12	24	16	5	33	0.65	-0.085	3.94	0.01	0.007	0	22.8	18.9	77	92	80	0	39	36
2015	12	24	16	15	33	0.679	-0.072	3.94	0.01	0.007	0	21.5	18.1	73.1	90	79	0	40	37
2015	12	24	16	25	33	0.659	-0.108	3.937	0.01	0.007	0	21.9	18.1	75.3	90	79	0	39	37
2015	12	24	16	35	33	0.617	-0.056	3.937	0.01	0.007	0	21.9	17.6	57.2	90	78	0	39	37
2015	12	24	16	45	33	0.659	-0.082	3.94	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	16	55	33	0.666	-0.072	3.94	0.01	0.007	0	21.9	17.6	72.7	90	78	0	39	37
2015	12	24	17	5	33	0.663	-0.095	3.94	0.01	0.007	0	22.4	17.6	77.8	91	78	0	39	37
2015	12	24	17	15	33	0.65	-0.082	3.94	0.01	0.007	0	21.9	18.1	77	91	79	0	40	37
2015	12	24	17	25	33	0.686	-0.082	3.94	0.01	0.007	0	21.1	17.6	66.7	89	78	0	40	37
2015	12	24	17	35	33	0.656	-0.105	3.94	0.01	0.007	0	22.4	17.6	77	91	78	0	39	37
2015	12	24	17	45	33	0.676	-0.112	3.94	0.01	0.007	0	22.4	18.1	77.4	92	79	0	40	37
2015	12	24	17	55	33	0.659	-0.072	3.94	0.01	0.007	0	22.4	17.6	77	91	78	0	39	37
2015	12	24	18	5	33	0.617	-0.102	3.94	0.01	0.007	0	22.4	17.6	75.7	91	78	0	39	37
2015	12	24	18	15	33	0.65	-0.098	3.94	0.01	0.007	0	21.9	17.6	77.4	91	78	0	40	37
2015	12	24	18	25	33	0.673	-0.079	3.94	0.01	0.007	0	22.4	17.6	77.4	91	78	0	39	37
2015	12	24	18	35	33	0.679	-0.085	3.94	0.01	0.007	0	21.9	17.6	75.3	91	78	0	40	37
2015	12	24	18	45	33	0.653	-0.098	3.94	0.013	0.01	0	21.5	18.1	74.8	90	79	0	40	37
2015	12	24	18	55	33	0.719	-0.098	3.94	0.01	0.007	0	21.1	18.1	61.5	89	78	0	40	36
2015	12	24	19	5	33	0.656	-0.085	3.94	0.01	0.007	0	21.9	18.9	61.5	91	80	0	40	36
2015	12	24	19	15	33	0.666	-0.079	3.94	0.01	0.007	0	23.2	19.4	61.1	93	82	0	39	37
2015	12	24	19	25	33	0.659	-0.082	3.937	0.01	0.007	0	22.8	18.9	52.5	92	81	0	39	37
2015	12	24	19	35	33	0.65	-0.102	3.94	0.01	0.007	0	22.4	18.5	76.1	92	80	0	40	37
2015	12	24	19	45	33	0.679	-0.095	3.94	0.01	0.007	0	22.4	18.5	62.8	92	81	0	40	38
2015	12	24	19	55	33	0.676	-0.075	3.937	0.01	0.007	0	23.6	19.8	47.3	95	83	0	40	37
2015	12	24	20	5	33	0.699	-0.112	3.94	0.01	0.007	0	25.4	20.6	58.5	98	86	0	39	38
2015	12	24	20	15	33	0.679	-0.089	3.94	0.01	0.007	0	24.1	20.6	74.8	96	84	0	40	36
2015	12	24	20	25	33	0.653	-0.108	3.94	0.01	0.007	0	22.8	18.9	77	93	81	0	40	37
2015	12	24	20	35	33	0.666	-0.072	3.94	0.01	0.007	0	22.4	18.5	65.4	92	80	0	40	37
2015	12	24	20	45	33	0.682	-0.105	3.94	0.01	0.007	0	22.8	18.5	76.5	92	80	0	39	37
2015	12	24	20	55	33	0.65	-0.066	3.94	0.01	0.007	0	21.5	18.5	77.4	90	79	0	40	36
2015	12	24	21	5	33	0.666	-0.108	3.94	0.01	0.007	0	21.9	18.1	77.4	91	79	0	40	37
2015	12	24	21	15	33	0.646	-0.079	3.94	0.01	0.007	0	21.5	18.1	77.8	90	79	0	40	37
2015	12	24	21	25	33	0.659	-0.108	3.94	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	24	21	35	33	0.666	-0.079	3.94	0.01	0.007	0	22.4	18.1	73.1	91	79	0	39	37
2015	12	24	21	45	33	0.673	-0.079	3.94	0.01	0.007	0	21.1	17.6	71	89	78	0	40	37
2015	12	24	21	55	33	0.686	-0.098	3.94	0.01	0.007	0	22.8	19.4	76.1	93	81	0	40	36
2015	12	24	22	5	33	0.636	-0.095	3.94	0.01	0.007	0	21.5	18.1	77.4	90	79	0	40	37
2015	12	24	22	15	33	0.676	-0.082	3.94	0.01	0.007	0	21.1	17.6	77.4	89	78	0	40	37
2015	12	24	22	25	33	0.64	-0.098	3.94	0.01	0.007	0	21.5	17.6	78.3	89	78	0	39	37
2015	12	24	22	35	33	0.617	-0.098	3.94	0.013	0.01	0	21.1	17.6	77.4	89	78	0	40	37
2015	12	24	22	45	33	0.659	-0.112	3.94	0.01	0.007	0	21.5	17.2	77	89	77	0	39	37
2015	12	24	22	55	33	0.646	-0.085	3.94	0.01	0.007	0	21.5	17.6	77.8	90	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	24	23	5	33	0.636	-0.085	3.94	0.01	0.007	0	21.1	17.2	77.4	89	77	0	40	37
2015	12	24	23	15	33	0.64	-0.118	3.94	0.01	0.007	0	21.9	17.6	77	90	78	0	39	37
2015	12	24	23	25	33	0.643	-0.089	3.94	0.01	0.007	0	21.1	18.1	76.5	89	78	0	40	36
2015	12	24	23	35	33	0.623	-0.098	3.94	0.01	0.007	0	21.1	17.6	76.5	89	78	0	40	37
2015	12	24	23	45	33	0.669	-0.066	3.94	0.01	0.007	0	21.1	18.1	77	89	78	0	40	36
2015	12	24	23	55	33	0.646	-0.089	3.94	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	25	0	5	33	0.666	-0.092	3.94	0.01	0.007	0	21.1	17.6	75.7	89	78	0	40	37
2015	12	25	0	15	33	0.653	-0.066	3.94	0.01	0.007	0	20.6	17.2	73.1	88	78	0	40	38
2015	12	25	0	25	33	0.62	-0.075	3.94	0.01	0.007	0	21.5	17.6	76.1	89	78	0	39	37
2015	12	25	0	35	33	0.646	-0.079	3.94	0.01	0.007	0	21.5	17.6	76.5	89	78	0	39	37
2015	12	25	0	45	33	0.614	-0.036	3.94	0.01	0.007	0	21.5	17.6	76.5	89	78	0	39	37
2015	12	25	0	55	33	0.696	-0.098	3.94	0.01	0.007	0	21.1	17.2	77	89	77	0	40	37
2015	12	25	1	5	33	0.676	-0.072	3.94	0.01	0.007	0	21.1	17.2	77	88	77	0	39	37
2015	12	25	1	15	33	0.659	-0.062	3.94	0.01	0.007	0	21.1	17.2	76.5	89	77	0	40	37
2015	12	25	1	25	33	0.63	-0.085	3.94	0.01	0.007	0	21.1	17.6	76.5	88	77	0	39	36
2015	12	25	1	35	33	0.666	-0.098	3.94	0.01	0.007	0	23.6	18.5	74.8	94	81	0	39	38
2015	12	25	1	45	33	0.62	-0.049	3.94	0.01	0.007	0	23.2	18.5	75.3	94	81	0	40	38
2015	12	25	1	55	33	0.699	-0.075	3.94	0.01	0.007	0	24.1	19.8	76.5	96	82	0	40	36
2015	12	25	2	5	33	0.702	-0.089	3.94	0.01	0.007	0	22.8	18.5	76.5	92	80	0	39	37
2015	12	25	2	15	33	0.636	-0.085	3.94	0.01	0.007	0	22.4	18.1	77.4	91	79	0	39	37
2015	12	25	2	25	33	0.676	-0.079	3.94	0.01	0.007	0	21.9	18.1	77.4	90	78	0	39	36
2015	12	25	2	35	33	0.659	-0.092	3.94	0.01	0.007	0	21.1	17.2	77	89	77	0	40	37
2015	12	25	2	45	33	0.65	-0.066	3.94	0.01	0.007	0	21.1	17.2	77	89	77	0	40	37
2015	12	25	2	55	33	0.666	-0.056	3.94	0.01	0.007	0	21.1	17.2	77.4	89	77	0	40	37
2015	12	25	3	5	33	0.636	-0.085	3.94	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	25	3	15	33	0.653	-0.102	3.94	0.01	0.007	0	21.1	16.8	77.4	88	76	0	39	37
2015	12	25	3	25	33	0.659	-0.102	3.937	0.01	0.007	0	20.6	16.8	77.4	87	76	0	39	37
2015	12	25	3	35	33	0.64	-0.085	3.937	0.01	0.007	0	21.5	17.6	77	90	78	0	40	37
2015	12	25	3	45	33	0.679	-0.089	3.94	0.01	0.007	0	20.2	17.2	77	87	77	0	40	37
2015	12	25	3	55	33	0.633	-0.056	3.937	0.01	0.007	0	20.6	17.2	76.5	87	77	0	39	37
2015	12	25	4	5	33	0.64	-0.089	3.937	0.01	0.007	0	20.6	17.2	76.5	88	77	0	40	37
2015	12	25	4	15	33	0.65	-0.062	3.937	0.01	0.007	0	20.2	17.6	76.1	87	77	0	40	36
2015	12	25	4	25	33	0.646	-0.059	3.937	0.01	0.007	0	20.6	17.2	77	88	77	0	40	37
2015	12	25	4	35	33	0.663	-0.072	3.937	0.01	0.007	0	20.6	16.8	76.5	88	77	0	40	38
2015	12	25	4	45	33	0.663	-0.082	3.937	0.01	0.007	0	20.2	16.8	76.1	87	76	0	40	37
2015	12	25	4	55	33	0.666	-0.069	3.937	0.01	0.007	0	21.1	17.2	76.1	88	77	0	39	37
2015	12	25	5	5	33	0.636	-0.052	3.937	0.01	0.007	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	25	5	15	33	0.63	-0.052	3.937	0.013	0.01	0	20.6	16.8	76.5	88	76	0	40	37
2015	12	25	5	25	33	0.656	-0.062	3.937	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	25	5	35	33	0.676	-0.052	3.937	0.01	0.007	0	20.2	16.8	77	87	76	0	40	37
2015	12	25	5	45	33	0.663	-0.072	3.937	0.013	0.01	0	20.6	16.8	76.5	88	76	0	40	37
2015	12	25	5	55	33	0.65	-0.092	3.937	0.01	0.007	0	20.2	16.8	76.1	87	77	0	40	38
2015	12	25	6	5	33	0.62	-0.062	3.937	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	25	6	15	33	0.646	-0.049	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37
2015	12	25	6	25	33	0.63	-0.062	3.934	0.01	0.007	0	20.2	17.6	76.1	87	77	0	40	36
2015	12	25	6	35	33	0.663	-0.102	3.934	0.01	0.007	0	20.6	17.2	76.1	88	77	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	6	45	33	0.607	-0.066	3.934	0.01	0.007	0	21.1	17.6	76.1	89	78	0	40	37
2015	12	25	6	55	33	0.673	-0.052	3.934	0.01	0.007	0	22.4	18.5	76.1	92	81	0	40	38
2015	12	25	7	5	33	0.702	-0.115	3.934	0.013	0.01	0	26.7	21.9	75.7	102	88	0	40	37
2015	12	25	7	15	33	0.673	-0.098	3.934	0.01	0.007	0	24.1	21.1	75.3	96	85	0	40	36
2015	12	25	7	25	33	0.646	-0.082	3.934	0.01	0.007	0	21.5	18.1	76.5	90	79	0	40	37
2015	12	25	7	35	33	0.702	-0.085	3.934	0.01	0.007	0	22.8	19.4	76.5	92	81	0	39	36
2015	12	25	7	45	33	0.696	-0.075	3.934	0.01	0.007	0	21.9	18.5	75.7	91	80	0	40	37
2015	12	25	7	55	33	0.679	-0.098	3.934	0.01	0.007	0	23.6	20.2	76.5	95	84	0	40	37
2015	12	25	8	5	33	0.686	-0.089	3.934	0.01	0.007	0	23.2	19.8	77	94	83	0	40	37
2015	12	25	8	15	33	0.676	-0.095	3.934	0.01	0.007	0	22.4	18.9	74.8	92	81	0	40	37
2015	12	25	8	25	33	0.669	-0.062	3.934	0.01	0.007	0	23.6	20.2	76.1	96	84	0	41	37
2015	12	25	8	35	33	0.699	-0.072	3.934	0.01	0.007	0	23.2	18.9	76.1	93	82	0	39	38
2015	12	25	8	45	33	0.745	-0.079	3.934	0.01	0.007	0	26.2	21.9	76.1	101	89	0	40	38
2015	12	25	8	55	33	0.663	-0.082	3.934	0.01	0.007	0	23.6	20.6	76.1	95	84	0	40	36
2015	12	25	9	5	33	0.673	-0.075	3.937	0.01	0.007	0	21.9	18.5	77.4	91	80	0	40	37
2015	12	25	9	15	33	0.617	-0.066	3.937	0.01	0.007	0	21.9	18.5	77	91	80	0	40	37
2015	12	25	9	25	33	0.663	-0.066	3.937	0.01	0.007	0	21.1	18.1	76.5	89	79	0	40	37
2015	12	25	9	35	33	0.627	-0.062	3.937	0.01	0.007	0	21.1	17.6	76.1	88	78	0	39	37
2015	12	25	9	45	33	0.65	-0.066	3.937	0.01	0.007	0	21.5	18.1	74.8	90	79	0	40	37
2015	12	25	9	55	33	0.732	-0.108	3.937	0.01	0.007	0	28.4	24.9	76.1	106	94	0	40	36
2015	12	25	10	5	33	0.686	-0.095	3.937	0.01	0.007	0	23.6	19.8	76.1	95	83	0	40	37
2015	12	25	10	15	33	0.643	-0.075	3.937	0.01	0.007	0	22.8	18.9	76.1	92	81	0	39	37
2015	12	25	10	25	33	0.699	-0.049	3.94	0.01	0.007	0	22.4	18.9	75.7	92	81	0	40	37
2015	12	25	10	35	33	0.673	-0.069	3.937	0.01	0.007	0	23.2	19.8	75.7	94	83	0	40	37
2015	12	25	10	45	33	0.699	-0.059	3.94	0.01	0.007	0	24.1	20.6	75.3	95	84	0	39	36
2015	12	25	10	55	33	0.722	-0.102	3.94	0.01	0.007	0	25.4	21.1	74.8	98	86	0	39	37
2015	12	25	11	5	33	0.666	-0.072	3.94	0.01	0.007	0	22.8	19.8	76.1	93	83	0	40	37
2015	12	25	11	15	33	0.725	-0.115	3.94	0.01	0.007	0	26.7	22.8	75.3	102	90	0	40	37
2015	12	25	11	25	33	0.712	-0.092	3.94	0.01	0.007	0	29.2	24.9	76.1	108	95	0	40	37
2015	12	25	11	35	33	0.676	-0.098	3.94	0.01	0.007	0	25.8	21.9	75.7	100	88	0	40	37
2015	12	25	11	45	33	0.761	-0.115	3.94	0.01	0.007	0	31.4	27.1	77	113	100	0	40	37
2015	12	25	11	55	33	0.702	-0.098	3.94	0.01	0.007	0	31	27.1	75.3	112	100	0	40	37
2015	12	25	12	5	33	0.715	-0.085	3.94	0.01	0.007	0	25.4	21.5	76.1	99	87	0	40	37
2015	12	25	12	15	33	0.676	-0.089	3.94	0.01	0.007	0	24.1	20.2	75.7	95	84	0	39	37
2015	12	25	12	25	33	0.689	-0.059	3.94	0.01	0.007	0	24.1	20.6	76.5	96	85	0	40	37
2015	12	25	12	35	33	0.653	-0.062	3.94	0.01	0.007	0	24.1	20.6	76.1	96	85	0	40	37
2015	12	25	12	45	33	0.712	-0.108	3.94	0.01	0.007	0	24.5	21.1	76.1	96	85	0	39	36
2015	12	25	12	55	33	0.702	-0.079	3.94	0.01	0.007	0	28.8	24.9	73.5	107	94	0	40	36
2015	12	25	13	5	33	0.699	-0.085	3.94	0.013	0.01	0	31.8	27.5	66.2	114	101	0	40	37
2015	12	25	13	15	33	0.712	-0.095	3.94	0.01	0.007	0	27.1	23.2	56.3	103	91	0	40	37
2015	12	25	13	25	33	0.679	-0.092	3.94	0.01	0.007	0	29.2	24.9	50.7	108	95	0	40	37
2015	12	25	13	35	33	0.673	-0.079	3.94	0.01	0.007	0	25.8	21.9	53.3	99	88	0	39	37
2015	12	25	13	45	33	0.715	-0.085	3.94	0.01	0.007	0	27.5	22.8	54.6	103	91	0	39	38
2015	12	25	13	55	33	0.715	-0.079	3.94	0.01	0.007	0	26.7	22.8	58	102	90	0	40	37
2015	12	25	14	5	33	0.676	-0.089	3.94	0.01	0.007	0	24.5	20.6	54.6	97	85	0	40	37
2015	12	25	14	15	33	0.689	-0.062	3.94	0.01	0.007	0	23.6	19.8	55.5	95	84	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	14	25	33	0.676	-0.049	3.937	0.01	0.007	0	23.6	20.2	51.6	95	83	0	40	36
2015	12	25	14	35	33	0.689	-0.043	3.937	0.01	0.007	0	23.6	21.1	47.3	95	85	0	40	36
2015	12	25	14	45	33	0.643	-0.072	3.94	0.01	0.007	0	25.4	21.1	49	98	86	0	39	37
2015	12	25	14	55	33	0.679	-0.082	3.937	0.01	0.007	0	25.4	20.6	48.6	98	85	0	39	37
2015	12	25	15	5	33	0.676	-0.066	3.94	0.01	0.007	0	24.5	20.6	49	97	85	0	40	37
2015	12	25	15	15	33	0.686	-0.066	3.937	0.01	0.007	0	24.1	20.2	51.2	96	84	0	40	37
2015	12	25	15	25	33	0.705	-0.082	3.937	0.013	0.01	0	24.1	20.2	49.9	96	84	0	40	37
2015	12	25	15	35	33	0.663	-0.075	3.937	0.01	0.007	0	24.1	20.6	48.6	95	84	0	39	36
2015	12	25	15	45	33	0.676	-0.085	3.937	0.01	0.007	0	23.2	18.9	55.9	94	82	0	40	38
2015	12	25	15	55	33	0.676	-0.049	3.937	0.013	0.01	0	22.8	19.4	50.3	93	82	0	40	37
2015	12	25	16	5	33	0.722	-0.085	3.94	0.01	0.007	0	22.8	18.5	70.1	92	80	0	39	37
2015	12	25	16	15	33	0.656	-0.072	3.94	0.01	0.007	0	21.5	18.1	65.8	90	79	0	40	37
2015	12	25	16	25	33	0.673	-0.062	3.94	0.01	0.007	0	21.5	17.6	76.1	90	79	0	40	38
2015	12	25	16	35	33	0.676	-0.062	3.94	0.01	0.007	0	21.5	17.6	75.7	90	78	0	40	37
2015	12	25	16	45	33	0.712	-0.059	3.937	0.01	0.007	0	21.1	18.1	57.2	89	79	0	40	37
2015	12	25	16	55	33	0.673	-0.052	3.937	0.01	0.007	0	21.9	18.5	52	91	80	0	40	37
2015	12	25	17	5	33	0.64	-0.062	3.937	0.01	0.007	0	23.6	19.4	53.3	94	82	0	39	37
2015	12	25	17	15	33	0.676	-0.059	3.937	0.01	0.007	0	21.9	18.9	56.8	91	80	0	40	36
2015	12	25	17	25	33	0.682	-0.072	3.94	0.01	0.007	0	21.5	18.1	72.7	90	79	0	40	37
2015	12	25	17	35	33	0.699	-0.069	3.94	0.01	0.007	0	21.5	17.2	76.1	90	78	0	40	38
2015	12	25	17	45	33	0.663	-0.062	3.94	0.01	0.007	0	21.9	18.5	76.1	91	80	0	40	37
2015	12	25	17	55	33	0.696	-0.098	3.94	0.01	0.007	0	21.9	18.5	76.5	91	79	0	40	36
2015	12	25	18	5	33	0.692	-0.072	3.94	0.01	0.007	0	21.9	18.1	75.7	90	79	0	39	37
2015	12	25	18	15	33	0.659	-0.056	3.94	0.01	0.007	0	21.1	17.2	76.1	89	78	0	40	38
2015	12	25	18	25	33	0.663	-0.079	3.94	0.01	0.007	0	21.1	17.2	75.7	89	78	0	40	38
2015	12	25	18	35	33	0.663	-0.089	3.94	0.01	0.007	0	21.1	17.6	74.8	89	78	0	40	37
2015	12	25	18	45	33	0.699	-0.059	3.94	0.01	0.007	0	20.6	17.6	72.2	88	78	0	40	37
2015	12	25	18	55	33	0.673	-0.069	3.94	0.01	0.007	0	21.1	17.6	63.2	89	78	0	40	37
2015	12	25	19	5	33	0.676	-0.036	3.937	0.01	0.007	0	21.1	17.6	50.3	89	79	0	40	38
2015	12	25	19	15	33	0.663	-0.089	3.937	0.01	0.007	0	24.5	20.6	48.6	96	84	0	39	36
2015	12	25	19	25	33	0.705	-0.089	3.937	0.01	0.007	0	25.8	21.5	47.7	99	87	0	39	37
2015	12	25	19	35	33	0.659	-0.089	3.937	0.01	0.007	0	24.9	20.6	49	97	85	0	39	37
2015	12	25	19	45	33	0.676	-0.059	3.937	0.01	0.007	0	24.9	21.1	50.3	98	86	0	40	37
2015	12	25	19	55	33	0.719	-0.085	3.937	0.01	0.007	0	24.5	20.6	48.2	97	85	0	40	37
2015	12	25	20	5	33	0.659	-0.075	3.937	0.01	0.007	0	24.5	20.6	49.9	97	85	0	40	37
2015	12	25	20	15	33	0.696	-0.082	3.937	0.01	0.007	0	23.6	19.8	51.2	95	83	0	40	37
2015	12	25	20	25	33	0.663	-0.066	3.937	0.01	0.007	0	22.8	19.4	64.1	93	82	0	40	37
2015	12	25	20	35	33	0.712	-0.075	3.94	0.01	0.007	0	22.4	18.9	74.8	92	80	0	40	36
2015	12	25	20	45	33	0.676	-0.069	3.94	0.013	0.01	0	21.5	18.1	73.5	90	79	0	40	37
2015	12	25	20	55	33	0.64	-0.072	3.94	0.01	0.007	0	21.5	18.5	65.8	90	79	0	40	36
2015	12	25	21	5	33	0.656	-0.049	3.94	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	25	21	15	33	0.65	-0.01	3.937	0.01	0.007	0	21.1	17.6	74.4	89	78	0	40	37
2015	12	25	21	25	33	0.699	-0.066	3.937	0.01	0.007	0	21.5	18.1	57.2	90	79	0	40	37
2015	12	25	21	35	33	0.663	-0.046	3.937	0.01	0.007	0	21.5	18.1	63.2	90	79	0	40	37
2015	12	25	21	45	33	0.65	-0.049	3.937	0.01	0.007	0	21.9	18.1	67.9	90	79	0	39	37
2015	12	25	21	55	33	0.65	-0.062	3.937	0.01	0.007	0	21.1	18.5	58	89	79	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	25	22	5	33	0.666	-0.069	3.937	0.01	0.007	0	21.9	17.6	51.6	91	79	0	40	38
2015	12	25	22	15	33	0.666	-0.036	3.937	0.01	0.007	0	21.5	18.1	54.2	90	79	0	40	37
2015	12	25	22	25	33	0.676	-0.075	3.937	0.01	0.007	0	22.8	19.4	46.4	93	82	0	40	37
2015	12	25	22	35	33	0.676	-0.085	3.937	0.01	0.007	0	24.9	21.5	49	98	87	0	40	37
2015	12	25	22	45	33	0.673	-0.069	3.937	0.01	0.007	0	24.1	21.1	52.9	96	85	0	40	36
2015	12	25	22	55	33	0.646	-0.072	3.937	0.01	0.007	0	23.6	19.8	49	95	83	0	40	37
2015	12	25	23	5	33	0.682	-0.072	3.937	0.01	0.007	0	23.2	19.4	63.2	93	82	0	39	37
2015	12	25	23	15	33	0.663	-0.075	3.937	0.01	0.007	0	21.9	18.9	59.3	91	81	0	40	37
2015	12	25	23	25	33	0.656	-0.072	3.937	0.01	0.007	0	21.9	18.5	72.2	90	80	0	39	37
2015	12	25	23	35	33	0.676	-0.079	3.937	0.01	0.007	0	21.5	18.1	64.5	89	79	0	39	37
2015	12	25	23	45	33	0.679	-0.082	3.937	0.01	0.007	0	21.1	17.2	67.1	89	78	0	40	38
2015	12	25	23	55	33	0.673	-0.043	3.937	0.01	0.007	0	20.6	18.1	73.5	88	78	0	40	36
2015	12	26	0	5	33	0.659	-0.062	3.937	0.01	0.007	0	21.1	17.2	71.8	89	78	0	40	38
2015	12	26	0	15	33	0.656	-0.069	3.937	0.01	0.007	0	20.6	17.6	70.5	88	78	0	40	37
2015	12	26	0	25	33	0.663	-0.075	3.937	0.01	0.007	0	21.1	17.6	70.1	89	78	0	40	37
2015	12	26	0	35	33	0.663	-0.069	3.937	0.013	0.01	0	20.6	16.8	66.2	88	77	0	40	38
2015	12	26	0	45	33	0.669	-0.075	3.937	0.01	0.007	0	21.1	17.6	64.1	88	78	0	39	37
2015	12	26	0	55	33	0.65	-0.052	3.937	0.01	0.007	0	20.6	17.6	68.4	88	78	0	40	37
2015	12	26	1	5	33	0.682	-0.052	3.937	0.01	0.007	0	20.6	17.2	67.1	88	78	0	40	38
2015	12	26	1	15	33	0.63	-0.079	3.937	0.01	0.007	0	21.5	18.1	64.5	90	79	0	40	37
2015	12	26	1	25	33	0.636	-0.092	3.937	0.01	0.007	0	21.5	18.1	68.4	90	79	0	40	37
2015	12	26	1	35	33	0.682	-0.085	3.937	0.01	0.007	0	20.6	17.6	66.7	88	78	0	40	37
2015	12	26	1	45	33	0.679	-0.075	3.937	0.01	0.007	0	21.1	17.2	71.4	88	77	0	39	37
2015	12	26	1	55	33	0.669	-0.082	3.937	0.01	0.007	0	21.5	17.6	72.7	89	78	0	39	37
2015	12	26	2	5	33	0.692	-0.079	3.934	0.01	0.007	0	21.1	17.2	67.9	88	77	0	39	37
2015	12	26	2	15	33	0.676	-0.069	3.937	0.01	0.007	0	20.6	17.6	64.1	88	78	0	40	37
2015	12	26	2	25	33	0.646	-0.062	3.934	0.01	0.007	0	20.6	17.6	62.4	88	78	0	40	37
2015	12	26	2	35	33	0.689	-0.082	3.937	0.01	0.007	0	21.1	17.2	63.6	88	77	0	39	37
2015	12	26	2	45	33	0.686	-0.075	3.934	0.01	0.007	0	21.5	18.1	55	89	78	0	39	36
2015	12	26	2	55	33	0.682	-0.072	3.937	0.01	0.007	0	21.1	18.1	55	89	79	0	40	37
2015	12	26	3	5	33	0.663	-0.079	3.934	0.01	0.007	0	21.5	17.6	50.7	90	79	0	40	38
2015	12	26	3	15	33	0.689	-0.062	3.934	0.01	0.007	0	22.4	18.5	52.9	91	80	0	39	37
2015	12	26	3	25	33	0.617	-0.056	3.934	0.01	0.007	0	21.9	18.5	49.9	91	80	0	40	37
2015	12	26	3	35	33	0.702	-0.069	3.934	0.01	0.007	0	21.9	18.5	50.7	91	80	0	40	37
2015	12	26	3	45	33	0.65	-0.095	3.934	0.01	0.007	0	21.9	18.5	52	91	80	0	40	37
2015	12	26	3	55	33	0.692	-0.043	3.934	0.01	0.007	0	22.4	18.5	48.6	92	80	0	40	37
2015	12	26	4	5	33	0.676	-0.069	3.934	0.01	0.007	0	23.2	19.8	48.6	94	83	0	40	37
2015	12	26	4	15	33	0.679	-0.102	3.934	0.01	0.007	0	24.5	19.8	46.9	96	84	0	39	38
2015	12	26	4	25	33	0.692	-0.085	3.934	0.01	0.007	0	24.5	20.2	48.2	97	85	0	40	38
2015	12	26	4	35	33	0.719	-0.089	3.934	0.01	0.007	0	24.9	20.6	50.7	98	86	0	40	38
2015	12	26	4	45	33	0.709	-0.069	3.934	0.01	0.007	0	24.5	20.6	51.2	97	85	0	40	37
2015	12	26	4	55	33	0.689	-0.108	3.937	0.01	0.007	0	24.9	20.6	54.2	97	85	0	39	37
2015	12	26	5	5	33	0.709	-0.118	3.937	0.01	0.007	0	24.1	20.2	51.2	96	84	0	40	37
2015	12	26	5	15	33	0.709	-0.098	3.937	0.013	0.01	0	23.6	19.8	59.3	95	84	0	40	38
2015	12	26	5	25	33	0.659	-0.082	3.937	0.01	0.007	0	23.2	19.4	55.9	94	82	0	40	37
2015	12	26	5	35	33	0.663	-0.085	3.937	0.01	0.007	0	22.8	19.4	55	93	82	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	5	45	33	0.659	-0.092	3.937	0.01	0.007	0	22.4	18.9	56.8	92	81	0	40	37
2015	12	26	5	55	33	0.636	-0.072	3.934	0.01	0.007	0	22.4	18.9	51.6	92	81	0	40	37
2015	12	26	6	5	33	0.673	-0.043	3.937	0.01	0.007	0	21.9	19.4	67.1	91	81	0	40	36
2015	12	26	6	15	33	0.696	-0.085	3.937	0.01	0.007	0	21.9	18.1	55.9	91	79	0	40	37
2015	12	26	6	25	33	0.65	-0.062	3.934	0.01	0.007	0	21.5	18.5	51.6	90	80	0	40	37
2015	12	26	6	35	33	0.65	-0.098	3.937	0.01	0.007	0	21.9	18.5	52	91	80	0	40	37
2015	12	26	6	45	33	0.696	-0.075	3.937	0.01	0.007	0	22.8	18.9	50.7	93	81	0	40	37
2015	12	26	6	55	33	0.715	-0.066	3.937	0.01	0.007	0	24.1	20.2	52	96	84	0	40	37
2015	12	26	7	5	33	0.702	-0.085	3.937	0.01	0.007	0	23.6	19.8	53.3	95	83	0	40	37
2015	12	26	7	15	33	0.709	-0.102	3.937	0.01	0.007	0	24.5	21.1	71	97	85	0	40	36
2015	12	26	7	25	33	0.705	-0.085	3.937	0.01	0.007	0	26.2	21.9	74	100	88	0	39	37
2015	12	26	7	35	33	0.696	-0.115	3.94	0.01	0.007	0	23.2	19.8	74.4	94	83	0	40	37
2015	12	26	7	45	33	0.709	-0.085	3.94	0.01	0.007	0	21.9	18.9	71.4	91	81	0	40	37
2015	12	26	7	55	33	0.673	-0.085	3.94	0.01	0.007	0	21.9	18.1	74	91	80	0	40	38
2015	12	26	8	5	33	0.686	-0.085	3.94	0.01	0.007	0	30.1	26.2	72.7	110	98	0	40	37
2015	12	26	8	15	33	0.659	-0.085	3.94	0.01	0.007	0	23.2	19.8	73.1	94	83	0	40	37
2015	12	26	8	25	33	0.653	-0.049	3.94	0.01	0.007	0	21.5	18.9	67.1	90	81	0	40	37
2015	12	26	8	35	33	0.682	-0.085	3.94	0.013	0.01	0	21.5	18.5	55	90	80	0	40	37
2015	12	26	8	45	33	0.646	-0.069	3.94	0.01	0.007	0	21.5	18.5	55.9	90	80	0	40	37
2015	12	26	8	55	33	0.682	-0.105	3.94	0.01	0.007	0	22.4	18.9	57.2	92	81	0	40	37
2015	12	26	9	5	33	0.673	-0.069	3.94	0.013	0.01	0	21.9	18.9	67.5	91	81	0	40	37
2015	12	26	9	15	33	0.604	-0.105	3.94	0.01	0.007	0	22.4	18.9	51.2	92	81	0	40	37
2015	12	26	9	25	33	0.663	-0.056	3.944	0.01	0.007	0	21.9	18.9	58.9	91	81	0	40	37
2015	12	26	9	35	33	0.689	-0.082	3.944	0.01	0.007	0	22.4	18.9	59.3	91	81	0	39	37
2015	12	26	9	45	33	0.646	-0.059	3.944	0.01	0.007	0	23.2	19.4	52.5	94	82	0	40	37
2015	12	26	9	55	33	0.676	-0.072	3.944	0.01	0.007	0	22.8	19.4	50.3	93	82	0	40	37
2015	12	26	10	5	33	0.696	-0.072	3.944	0.01	0.007	0	24.1	20.6	49	96	84	0	40	36
2015	12	26	10	15	33	0.702	-0.072	3.944	0.01	0.007	0	24.1	20.2	47.7	96	84	0	40	37
2015	12	26	10	25	33	0.663	-0.066	3.944	0.01	0.007	0	24.1	20.2	50.7	96	84	0	40	37
2015	12	26	10	35	33	0.719	-0.085	3.944	0.01	0.007	0	24.1	20.6	48.2	96	85	0	40	37
2015	12	26	10	45	33	0.663	-0.095	3.944	0.01	0.007	0	24.9	20.6	49	97	86	0	39	38
2015	12	26	10	55	33	0.673	-0.085	3.944	0.01	0.007	0	24.9	20.6	47.3	98	86	0	40	38
2015	12	26	11	5	33	0.679	-0.082	3.944	0.01	0.007	0	25.4	21.5	52	98	86	0	39	36
2015	12	26	11	15	33	0.659	-0.092	3.947	0.01	0.007	0	26.2	22.4	58	100	89	0	39	37
2015	12	26	11	25	33	0.679	-0.062	3.947	0.01	0.007	0	25.8	21.9	49	100	89	0	40	38
2015	12	26	11	35	33	0.696	-0.082	3.947	0.01	0.007	0	27.1	22.8	46.9	103	91	0	40	38
2015	12	26	11	45	33	0.676	-0.108	3.947	0.01	0.007	0	26.2	22.8	55	101	90	0	40	37
2015	12	26	11	55	33	0.692	-0.043	3.95	0.01	0.007	0	26.2	22.8	46.4	101	90	0	40	37
2015	12	26	12	5	33	0.689	-0.092	3.947	0.01	0.007	0	29.2	25.4	52	108	96	0	40	37
2015	12	26	12	15	33	0.712	-0.082	3.947	0.01	0.007	0	32.3	28	46.9	115	102	0	40	37
2015	12	26	12	25	33	0.682	-0.085	3.95	0.01	0.007	0	28	24.1	50.7	105	93	0	40	37
2015	12	26	12	35	33	0.722	-0.105	3.95	0.01	0.007	0	27.5	23.6	48.2	104	92	0	40	37
2015	12	26	12	45	33	0.692	-0.072	3.95	0.01	0.007	0	28	23.2	52	104	91	0	39	37
2015	12	26	12	55	33	0.679	-0.049	3.95	0.01	0.007	0	27.1	23.2	46.4	103	91	0	40	37
2015	12	26	13	5	33	0.682	-0.095	3.95	0.01	0.007	0	27.5	23.6	47.3	104	92	0	40	37
2015	12	26	13	15	33	0.689	-0.092	3.953	0.01	0.007	0	26.7	23.2	48.2	102	91	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	13	25	33	0.699	-0.062	3.953	0.01	0.007	0	26.7	22.8	46.4	102	90	0	40	37
2015	12	26	13	35	33	0.738	-0.066	3.957	0.01	0.007	0	26.7	22.4	46	101	89	0	39	37
2015	12	26	13	45	33	0.722	-0.075	3.953	0.013	0.01	0	25.8	21.9	46	100	88	0	40	37
2015	12	26	13	55	33	0.699	-0.049	3.957	0.01	0.007	0	26.2	21.9	46	101	88	0	40	37
2015	12	26	14	5	33	0.699	-0.082	3.957	0.013	0.01	0	26.7	22.8	45.6	101	90	0	39	37
2015	12	26	14	15	33	0.679	-0.092	3.957	0.01	0.007	0	26.7	22.8	45.6	102	90	0	40	37
2015	12	26	14	25	33	0.679	-0.092	3.957	0.01	0.007	0	26.7	22.4	47.7	101	89	0	39	37
2015	12	26	14	35	33	0.722	-0.079	3.957	0.01	0.007	0	25.8	21.9	46.9	100	88	0	40	37
2015	12	26	14	45	33	0.719	-0.085	3.96	0.01	0.007	0	26.2	21.5	48.2	100	88	0	39	38
2015	12	26	14	55	33	0.682	-0.089	3.96	0.01	0.007	0	25.8	21.9	46	100	88	0	40	37
2015	12	26	15	5	33	0.679	-0.049	3.96	0.01	0.007	0	25.4	21.5	48.2	99	87	0	40	37
2015	12	26	15	15	33	0.735	-0.075	3.96	0.01	0.007	0	24.9	21.5	45.6	98	87	0	40	37
2015	12	26	15	25	33	0.689	-0.082	3.96	0.01	0.007	0	24.9	21.5	46	97	86	0	39	36
2015	12	26	15	35	33	0.715	-0.092	3.96	0.01	0.007	0	24.9	21.1	46.4	98	86	0	40	37
2015	12	26	15	45	33	0.673	-0.092	3.96	0.01	0.007	0	24.9	20.6	48.2	97	85	0	39	37
2015	12	26	15	55	33	0.699	-0.072	3.96	0.01	0.007	0	24.1	20.2	48.6	96	84	0	40	37
2015	12	26	16	5	33	0.686	-0.072	3.963	0.016	0.013	0	23.2	19.4	51.2	93	82	0	39	37
2015	12	26	16	15	33	0.673	-0.049	3.963	0.01	0.007	0	22.8	18.9	50.3	92	81	0	39	37
2015	12	26	16	25	33	0.699	-0.069	3.963	0.01	0.007	0	21.9	18.5	51.2	91	80	0	40	37
2015	12	26	16	35	33	0.63	-0.069	3.967	0.01	0.007	0	22.8	18.5	57.6	92	80	0	39	37
2015	12	26	16	45	33	0.653	-0.056	3.963	0.01	0.007	0	21.5	18.9	50.7	91	80	0	41	36
2015	12	26	16	55	33	0.666	-0.095	3.963	0.01	0.007	0	21.9	18.5	52.5	91	80	0	40	37
2015	12	26	17	5	33	0.699	-0.059	3.967	0.01	0.007	0	21.5	18.5	73.5	90	80	0	40	37
2015	12	26	17	15	33	0.689	-0.092	3.967	0.01	0.007	0	21.1	18.5	72.7	89	80	0	40	37
2015	12	26	17	25	33	0.679	-0.098	3.967	0.01	0.007	0	22.4	18.5	73.5	91	81	0	39	38
2015	12	26	17	35	33	0.643	-0.082	3.967	0.01	0.007	0	22.4	18.9	74.8	92	81	0	40	37
2015	12	26	17	45	33	0.61	-0.079	3.967	0.01	0.007	0	21.9	19.4	75.7	91	82	0	40	37
2015	12	26	17	55	33	0.64	-0.069	3.967	0.013	0.01	0	21.9	18.5	75.3	90	80	0	39	37
2015	12	26	18	5	33	0.663	-0.085	3.967	0.01	0.007	0	21.1	18.1	74	89	79	0	40	37
2015	12	26	18	15	33	0.686	-0.102	3.967	0.01	0.007	0	22.8	19.4	73.5	93	82	0	40	37
2015	12	26	18	25	33	0.663	-0.098	3.97	0.01	0.007	0	22.4	19.4	75.3	92	82	0	40	37
2015	12	26	18	35	33	0.676	-0.062	3.97	0.01	0.007	0	21.5	18.5	76.5	90	80	0	40	37
2015	12	26	18	45	33	0.663	-0.079	3.97	0.01	0.007	0	21.5	18.5	76.1	90	80	0	40	37
2015	12	26	18	55	33	0.643	-0.082	3.97	0.01	0.007	0	21.9	18.5	72.2	90	80	0	39	37
2015	12	26	19	5	33	0.63	-0.095	3.97	0.016	0.013	0	21.5	18.1	71.4	90	79	0	40	37
2015	12	26	19	15	33	0.656	-0.089	3.967	0.01	0.007	0	21.5	18.5	60.2	90	80	0	40	37
2015	12	26	19	25	33	0.682	-0.089	3.97	0.01	0.007	0	21.1	18.1	75.3	89	79	0	40	37
2015	12	26	19	35	33	0.656	-0.072	3.97	0.01	0.007	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	26	19	45	33	0.659	-0.075	3.97	0.01	0.007	0	21.1	18.5	74.8	89	80	0	40	37
2015	12	26	19	55	33	0.617	-0.092	3.97	0.01	0.007	0	21.5	18.5	74	89	80	0	39	37
2015	12	26	20	5	33	0.584	-0.095	3.97	0.01	0.007	0	20.6	18.5	71.4	88	80	0	40	37
2015	12	26	20	15	33	0.614	-0.089	3.97	0.01	0.007	0	20.6	18.5	74.8	88	80	0	40	37
2015	12	26	20	25	33	0.64	-0.085	3.97	0.01	0.007	0	20.6	18.1	75.3	88	79	0	40	37
2015	12	26	20	35	33	0.663	-0.036	3.97	0.01	0.007	0	21.1	18.5	71.4	89	80	0	40	37
2015	12	26	20	45	33	0.686	-0.062	3.967	0.01	0.007	0	21.1	18.5	72.7	89	80	0	40	37
2015	12	26	20	55	33	0.64	-0.049	3.97	0.01	0.007	0	21.1	18.1	72.2	89	80	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	26	21	5	33	0.617	-0.085	3.97	0.01	0.007	0	21.5	18.5	70.5	90	80	0	40	37
2015	12	26	21	15	33	0.633	-0.049	3.967	0.01	0.007	0	21.5	18.5	71.8	89	80	0	39	37
2015	12	26	21	25	33	0.614	-0.095	3.967	0.01	0.007	0	21.5	17.6	73.1	89	79	0	39	38
2015	12	26	21	35	33	0.633	-0.082	3.967	0.01	0.007	0	20.2	18.1	73.1	87	79	0	40	37
2015	12	26	21	45	33	0.591	-0.108	3.967	0.01	0.007	0	21.1	18.1	71	89	79	0	40	37
2015	12	26	21	55	33	0.6	-0.085	3.967	0.013	0.01	0	21.1	18.5	68.8	89	80	0	40	37
2015	12	26	22	5	33	0.574	-0.098	3.967	0.01	0.007	0	22.8	18.9	63.2	92	81	0	39	37
2015	12	26	22	15	33	0.633	-0.085	3.967	0.01	0.007	0	21.1	18.5	71.4	89	80	0	40	37
2015	12	26	22	25	33	0.607	-0.118	3.967	0.01	0.007	0	22.4	18.5	76.5	91	81	0	39	38
2015	12	26	22	35	33	0.627	-0.108	3.967	0.01	0.007	0	21.9	18.9	76.5	90	80	0	39	36
2015	12	26	22	45	33	0.633	-0.095	3.967	0.01	0.007	0	21.5	18.5	76.5	90	80	0	40	37
2015	12	26	22	55	33	0.643	-0.098	3.97	0.01	0.007	0	21.1	18.9	76.5	89	80	0	40	36
2015	12	26	23	5	33	0.646	-0.085	3.97	0.01	0.007	0	20.6	18.5	76.5	88	80	0	40	37
2015	12	26	23	15	33	0.627	-0.102	3.967	0.013	0.01	0	21.5	18.5	77	89	80	0	39	37
2015	12	26	23	25	33	0.604	-0.089	3.967	0.01	0.007	0	21.5	18.5	76.5	90	80	0	40	37
2015	12	26	23	35	33	0.643	-0.085	3.967	0.013	0.01	0	21.1	18.5	76.5	89	80	0	40	37
2015	12	26	23	45	33	0.656	-0.085	3.967	0.01	0.007	0	20.6	18.1	75.7	88	79	0	40	37
2015	12	26	23	55	33	0.61	-0.135	3.967	0.01	0.007	0	21.1	18.5	76.5	89	80	0	40	37
2015	12	27	0	5	33	0.627	-0.102	3.967	0.01	0.007	0	21.1	18.1	76.5	89	80	0	40	38
2015	12	27	0	15	33	0.633	-0.102	3.967	0.01	0.007	0	20.2	18.5	77	87	80	0	40	37
2015	12	27	0	25	33	0.61	-0.085	3.967	0.01	0.007	0	20.2	18.9	76.1	88	80	0	41	36
2015	12	27	0	35	33	0.614	-0.138	3.967	0.016	0.016	0	20.6	18.1	76.1	88	79	0	40	37
2015	12	27	0	45	33	0.607	-0.092	3.963	0.01	0.007	0	20.6	18.5	75.7	88	80	0	40	37
2015	12	27	0	55	33	0.604	-0.148	3.967	0.01	0.007	0	20.6	18.1	75.7	88	79	0	40	37
2015	12	27	1	5	33	0.607	-0.098	3.963	0.01	0.007	0	20.6	18.1	76.1	88	79	0	40	37
2015	12	27	1	15	33	0.659	-0.089	3.963	0.01	0.007	0	20.6	18.1	75.7	88	79	0	40	37
2015	12	27	1	25	33	0.64	-0.089	3.963	0.01	0.007	0	20.6	18.5	76.1	88	80	0	40	37
2015	12	27	1	35	33	0.643	-0.121	3.963	0.01	0.007	0	21.1	18.9	75.7	89	81	0	40	37
2015	12	27	1	45	33	0.627	-0.125	3.963	0.01	0.007	0	21.1	18.5	75.7	88	80	0	39	37
2015	12	27	1	55	33	0.656	-0.131	3.963	0.01	0.007	0	20.2	18.1	75.3	87	79	0	40	37
2015	12	27	2	5	33	0.666	-0.125	3.963	0.01	0.007	0	21.5	18.9	75.3	90	81	0	40	37
2015	12	27	2	15	33	0.656	-0.128	3.963	0.016	0.013	0	24.1	21.5	74.8	96	87	0	40	37
2015	12	27	2	25	33	0.669	-0.108	3.963	0.01	0.007	0	22.8	20.2	74.8	93	84	0	40	37
2015	12	27	2	35	33	0.673	-0.112	3.963	0.01	0.007	0	21.5	19.4	75.3	90	82	0	40	37
2015	12	27	2	45	33	0.666	-0.112	3.963	0.01	0.007	0	21.5	18.9	74.8	90	81	0	40	37
2015	12	27	2	55	33	0.673	-0.105	3.963	0.01	0.007	0	21.5	18.5	75.3	90	80	0	40	37
2015	12	27	3	5	33	0.646	-0.108	3.96	0.01	0.007	0	21.1	18.5	74.4	89	80	0	40	37
2015	12	27	3	15	33	0.627	-0.092	3.96	0.01	0.007	0	21.5	18.5	74.4	90	80	0	40	37
2015	12	27	3	25	33	0.666	-0.148	3.96	0.01	0.007	0	20.6	18.5	74.8	88	80	0	40	37
2015	12	27	3	35	33	0.627	-0.112	3.96	0.01	0.007	0	21.1	18.5	74.4	89	80	0	40	37
2015	12	27	3	45	33	0.643	-0.098	3.96	0.01	0.007	0	20.6	18.5	74.4	88	80	0	40	37
2015	12	27	3	55	33	0.643	-0.112	3.96	0.01	0.007	0	21.1	18.5	74.8	89	80	0	40	37
2015	12	27	4	5	33	0.669	-0.098	3.96	0.01	0.007	0	21.1	18.5	74	89	80	0	40	37
2015	12	27	4	15	33	0.604	-0.098	3.96	0.01	0.007	0	20.6	18.1	74	88	79	0	40	37
2015	12	27	4	25	33	0.656	-0.108	3.96	0.01	0.007	0	20.2	18.1	74.4	87	79	0	40	37
2015	12	27	4	35	33	0.673	-0.112	3.96	0.013	0.01	0	20.2	18.5	74.4	87	79	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	4	45	33	0.627	-0.098	3.96	0.01	0.007	0	20.6	18.1	74.4	87	79	0	39	37
2015	12	27	4	55	33	0.633	-0.085	3.96	0.013	0.01	0	20.2	18.1	74.4	87	79	0	40	37
2015	12	27	5	5	33	0.61	-0.135	3.96	0.01	0.007	0	20.2	17.6	74	87	78	0	40	37
2015	12	27	5	15	33	0.63	-0.115	3.96	0.01	0.007	0	20.2	18.1	74	87	79	0	40	37
2015	12	27	5	25	33	0.633	-0.118	3.96	0.01	0.007	0	20.2	18.1	73.5	87	79	0	40	37
2015	12	27	5	35	33	0.65	-0.072	3.96	0.01	0.007	0	20.6	18.1	74.4	88	79	0	40	37
2015	12	27	5	45	33	0.643	-0.105	3.96	0.01	0.007	0	20.2	17.2	74	87	78	0	40	38
2015	12	27	5	55	33	0.65	-0.089	3.96	0.01	0.007	0	19.8	18.1	73.5	86	79	0	40	37
2015	12	27	6	5	33	0.65	-0.105	3.96	0.01	0.007	0	20.2	16.8	73.5	87	77	0	40	38
2015	12	27	6	15	33	0.623	-0.085	3.96	0.01	0.007	0	19.4	17.6	73.5	85	78	0	40	37
2015	12	27	6	25	33	0.607	-0.115	3.96	0.01	0.007	0	19.8	17.2	73.5	86	78	0	40	38
2015	12	27	6	35	33	0.643	-0.095	3.96	0.01	0.007	0	20.2	17.6	74	87	78	0	40	37
2015	12	27	6	45	33	0.669	-0.105	3.96	0.01	0.007	0	20.6	17.6	73.5	87	78	0	39	37
2015	12	27	6	55	33	0.636	-0.092	3.96	0.01	0.007	0	19.8	17.6	74	86	78	0	40	37
2015	12	27	7	5	33	0.666	-0.112	3.96	0.01	0.007	0	23.2	20.6	74	94	85	0	40	37
2015	12	27	7	15	33	0.682	-0.115	3.96	0.01	0.007	0	24.1	21.1	73.5	96	86	0	40	37
2015	12	27	7	25	33	0.673	-0.092	3.96	0.01	0.007	0	24.9	21.9	73.5	98	88	0	40	37
2015	12	27	7	35	33	0.689	-0.121	3.96	0.01	0.007	0	24.9	21.5	74	98	88	0	40	38
2015	12	27	7	45	33	0.673	-0.092	3.96	0.01	0.007	0	22.4	19.8	74.4	92	83	0	40	37
2015	12	27	7	55	33	0.692	-0.098	3.96	0.01	0.007	0	22.4	19.8	73.1	92	83	0	40	37
2015	12	27	8	5	33	0.663	-0.112	3.96	0.01	0.007	0	21.9	19.8	73.5	91	83	0	40	37
2015	12	27	8	15	33	0.669	-0.118	3.957	0.01	0.007	0	23.6	21.1	72.7	95	86	0	40	37
2015	12	27	8	25	33	0.679	-0.062	3.957	0.01	0.007	0	21.9	18.9	73.1	91	81	0	40	37
2015	12	27	8	35	33	0.646	-0.112	3.957	0.01	0.007	0	20.6	17.6	72.2	88	79	0	40	38
2015	12	27	8	45	33	0.62	-0.075	3.957	0.013	0.01	0	20.6	18.1	72.2	88	79	0	40	37
2015	12	27	8	55	33	0.607	-0.112	3.957	0.01	0.007	0	21.1	17.6	72.2	89	79	0	40	38
2015	12	27	9	5	33	0.653	-0.085	3.957	0.013	0.01	0	20.2	18.1	71.8	87	79	0	40	37
2015	12	27	9	15	33	0.64	-0.105	3.957	0.01	0.007	0	20.6	17.6	71.8	88	78	0	40	37
2015	12	27	9	25	33	0.633	-0.125	3.957	0.01	0.007	0	20.2	18.1	71.8	87	79	0	40	37
2015	12	27	9	35	33	0.656	-0.115	3.953	0.01	0.007	0	20.6	17.6	71.8	88	78	0	40	37
2015	12	27	9	45	33	0.682	-0.105	3.95	0.01	0.007	0	20.6	17.6	71.8	88	79	0	40	38
2015	12	27	9	55	33	0.627	-0.056	3.953	0.01	0.007	0	20.6	18.1	71.4	88	79	0	40	37
2015	12	27	10	5	33	0.607	-0.082	3.95	0.01	0.007	0	20.6	17.6	71.4	88	78	0	40	37
2015	12	27	10	15	33	0.607	-0.098	3.95	0.01	0.007	0	20.2	18.1	71.8	87	79	0	40	37
2015	12	27	10	25	33	0.597	-0.085	3.953	0.01	0.007	0	20.2	17.6	71.8	87	78	0	40	37
2015	12	27	10	35	33	0.64	-0.095	3.95	0.01	0.007	0	20.6	17.6	71.8	88	78	0	40	37
2015	12	27	10	45	33	0.623	-0.079	3.953	0.013	0.01	0	20.6	18.1	71.4	88	79	0	40	37
2015	12	27	10	55	33	0.623	-0.108	3.953	0.01	0.007	0	20.6	18.1	71.4	88	79	0	40	37
2015	12	27	11	5	33	0.587	-0.089	3.96	0.01	0.007	0	20.6	17.2	72.2	88	78	0	40	38
2015	12	27	11	15	33	0.587	-0.098	3.96	0.01	0.007	0	20.6	18.1	72.2	88	79	0	40	37
2015	12	27	11	25	33	0.617	-0.102	3.963	0.01	0.007	0	20.6	17.6	72.7	88	78	0	40	37
2015	12	27	11	35	33	0.584	-0.105	3.963	0.01	0.007	0	21.5	18.1	72.2	89	79	0	39	37
2015	12	27	11	45	33	0.63	-0.089	3.963	0.01	0.007	0	20.6	18.1	72.7	88	79	0	40	37
2015	12	27	11	55	33	0.623	-0.118	3.967	0.01	0.007	0	20.6	17.6	70.1	87	79	0	39	38
2015	12	27	12	5	33	0.561	-0.092	3.963	0.01	0.007	0	20.6	18.1	61.9	87	79	0	39	37
2015	12	27	12	15	33	0.61	-0.069	3.963	0.01	0.007	0	19.8	17.6	52.5	86	78	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	12	25	33	0.561	-0.062	3.963	0.013	0.01	0	20.2	18.1	51.6	87	79	0	40	37
2015	12	27	12	35	33	0.61	-0.066	3.963	0.01	0.007	0	20.2	18.1	54.2	87	79	0	40	37
2015	12	27	12	45	33	0.604	-0.049	3.963	0.01	0.007	0	20.6	18.5	48.6	87	80	0	39	37
2015	12	27	12	55	33	0.587	-0.072	3.963	0.01	0.007	0	20.6	18.5	53.3	88	80	0	40	37
2015	12	27	13	5	33	0.61	-0.079	3.967	0.01	0.007	0	20.2	18.1	60.2	87	79	0	40	37
2015	12	27	13	15	33	0.594	-0.079	3.967	0.013	0.01	0	20.6	18.5	68.4	88	80	0	40	37
2015	12	27	13	25	33	0.623	-0.115	3.967	0.01	0.007	0	19.8	18.1	64.5	86	78	0	40	36
2015	12	27	13	35	33	0.659	-0.115	3.967	0.01	0.007	0	24.1	21.1	63.2	95	86	0	39	37
2015	12	27	13	45	33	0.63	-0.075	3.967	0.01	0.007	0	21.5	19.4	52	90	82	0	40	37
2015	12	27	13	55	33	0.538	-0.092	3.963	0.01	0.007	0	22.4	19.4	49.5	91	82	0	39	37
2015	12	27	14	5	33	0.591	-0.115	3.963	0.01	0.007	0	25.4	21.9	49.5	99	88	0	40	37
2015	12	27	14	15	33	0.646	-0.092	3.967	0.01	0.007	0	23.2	20.2	51.6	94	85	0	40	38
2015	12	27	14	25	33	0.614	-0.098	3.967	0.01	0.007	0	22.8	20.2	52	93	84	0	40	37
2015	12	27	14	35	33	0.584	-0.125	3.967	0.01	0.007	0	21.9	19.8	53.8	91	82	0	40	36
2015	12	27	14	45	33	0.61	-0.105	3.967	0.01	0.007	0	21.5	18.5	54.2	90	81	0	40	38
2015	12	27	14	55	33	0.604	-0.112	3.967	0.01	0.007	0	22.4	19.8	56.3	92	82	0	40	36
2015	12	27	15	5	33	0.584	-0.095	3.967	0.013	0.01	0	21.5	19.4	47.7	90	82	0	40	37
2015	12	27	15	15	33	0.64	-0.125	3.97	0.01	0.007	0	21.1	18.9	55.9	89	81	0	40	37
2015	12	27	15	25	33	0.656	-0.079	3.97	0.01	0.007	0	22.4	19.4	56.8	91	82	0	39	37
2015	12	27	15	35	33	0.61	-0.085	3.97	0.01	0.007	0	22.4	18.9	54.2	92	82	0	40	38
2015	12	27	15	45	33	0.6	-0.112	3.967	0.01	0.007	0	21.1	18.9	54.6	89	81	0	40	37
2015	12	27	15	55	33	0.653	-0.082	3.97	0.01	0.007	0	21.1	18.5	60.6	89	80	0	40	37
2015	12	27	16	5	33	0.61	-0.089	3.97	0.01	0.007	0	21.1	18.9	75.7	89	81	0	40	37
2015	12	27	16	15	33	0.617	-0.082	3.97	0.01	0.007	0	21.1	18.5	75.7	88	80	0	39	37
2015	12	27	16	25	33	0.633	-0.095	3.97	0.01	0.007	0	21.9	18.5	75.3	90	81	0	39	38
2015	12	27	16	35	33	0.64	-0.112	3.97	0.013	0.01	0	21.5	19.4	75.3	90	81	0	40	36
2015	12	27	16	45	33	0.604	-0.089	3.97	0.01	0.007	0	21.5	18.1	75.3	90	80	0	40	38
2015	12	27	16	55	33	0.643	-0.066	3.97	0.013	0.01	0	20.2	18.5	75.3	87	80	0	40	37
2015	12	27	17	5	33	0.666	-0.059	3.973	0.01	0.007	0	21.5	18.1	75.3	90	79	0	40	37
2015	12	27	17	15	33	0.673	-0.075	3.973	0.01	0.007	0	21.5	18.1	75.3	90	80	0	40	38
2015	12	27	17	25	33	0.627	-0.098	3.97	0.01	0.007	0	21.9	18.1	74.8	90	79	0	39	37
2015	12	27	17	35	33	0.627	-0.066	3.973	0.01	0.007	0	21.1	17.6	74.4	89	78	0	40	37
2015	12	27	17	45	33	0.646	-0.082	3.973	0.01	0.007	0	20.6	18.1	74.4	88	79	0	40	37
2015	12	27	17	55	33	0.646	-0.069	3.973	0.01	0.007	0	20.6	18.1	74.8	88	79	0	40	37
2015	12	27	18	5	33	0.581	-0.049	3.973	0.01	0.007	0	20.6	18.5	74.4	88	80	0	40	37
2015	12	27	18	15	33	0.627	-0.072	3.973	0.013	0.01	0	20.6	18.1	74	88	79	0	40	37
2015	12	27	18	25	33	0.65	-0.079	3.976	0.01	0.007	0	20.6	18.1	74.8	88	79	0	40	37
2015	12	27	18	35	33	0.6	-0.049	3.973	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	27	18	45	33	0.574	-0.072	3.973	0.01	0.007	0	21.1	18.5	74.4	89	79	0	40	36
2015	12	27	18	55	33	0.6	-0.075	3.973	0.01	0.007	0	20.6	17.6	74.4	88	78	0	40	37
2015	12	27	19	5	33	0.623	-0.056	3.973	0.01	0.007	0	20.6	18.1	73.5	88	79	0	40	37
2015	12	27	19	15	33	0.633	-0.069	3.976	0.01	0.007	0	21.1	18.1	74.4	88	79	0	39	37
2015	12	27	19	25	33	0.659	-0.072	3.976	0.016	0.013	0	20.6	18.1	73.5	88	79	0	40	37
2015	12	27	19	35	33	0.62	-0.075	3.976	0.01	0.007	0	20.6	18.1	72.7	88	79	0	40	37
2015	12	27	19	45	33	0.607	-0.092	3.976	0.01	0.007	0	20.6	17.6	73.5	88	78	0	40	37
2015	12	27	19	55	33	0.62	-0.079	3.976	0.01	0.007	0	20.6	17.2	73.1	88	77	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	27	20	5	33	0.604	-0.085	3.976	0.013	0.01	0	21.1	18.1	72.7	89	79	0	40	37
2015	12	27	20	15	33	0.659	-0.095	3.976	0.01	0.007	0	21.1	17.6	72.7	89	78	0	40	37
2015	12	27	20	25	33	0.571	-0.102	3.976	0.01	0.007	0	21.5	17.6	72.2	89	78	0	39	37
2015	12	27	20	35	33	0.604	-0.075	3.976	0.01	0.007	0	20.6	17.6	72.2	88	78	0	40	37
2015	12	27	20	45	33	0.548	-0.108	3.98	0.01	0.007	0	21.9	18.1	71.8	90	79	0	39	37
2015	12	27	20	55	33	0.581	-0.138	3.98	0.01	0.007	0	21.1	17.6	71.4	89	78	0	40	37
2015	12	27	21	5	33	0.663	-0.098	3.98	0.01	0.007	0	21.5	17.6	61.5	90	78	0	40	37
2015	12	27	21	15	33	0.604	-0.135	3.98	0.01	0.007	0	21.1	17.6	71.4	89	78	0	40	37
2015	12	27	21	25	33	0.633	-0.108	3.983	0.013	0.01	0	21.5	17.6	65.8	90	78	0	40	37
2015	12	27	21	35	33	0.659	-0.098	3.983	0.01	0.007	0	21.1	17.6	71	89	78	0	40	37
2015	12	27	21	45	33	0.659	-0.085	3.983	0.01	0.007	0	20.6	17.2	71.8	88	78	0	40	38
2015	12	27	21	55	33	0.633	-0.089	3.986	0.01	0.007	0	20.6	17.2	71	88	77	0	40	37
2015	12	27	22	5	33	0.617	-0.062	3.99	0.013	0.01	0	20.6	17.2	71	88	77	0	40	37
2015	12	27	22	15	33	0.64	-0.095	3.99	0.013	0.01	0	20.6	17.2	71.8	88	77	0	40	37
2015	12	27	22	25	33	0.65	-0.105	3.993	0.013	0.01	0	20.2	17.6	72.7	87	77	0	40	36
2015	12	27	22	35	33	0.623	-0.089	3.993	0.01	0.007	0	21.1	17.6	72.7	88	78	0	39	37
2015	12	27	22	45	33	0.617	-0.092	3.993	0.01	0.007	0	20.2	17.2	72.7	87	77	0	40	37
2015	12	27	22	55	33	0.627	-0.098	3.993	0.01	0.007	0	20.6	17.6	72.2	88	78	0	40	37
2015	12	27	23	5	33	0.643	-0.098	3.996	0.016	0.013	0	20.2	17.2	73.5	87	77	0	40	37
2015	12	27	23	15	33	0.633	-0.095	3.996	0.01	0.007	0	20.2	17.2	73.1	86	77	0	39	37
2015	12	27	23	25	33	0.623	-0.105	3.996	0.016	0.013	0	20.6	17.2	73.5	87	77	0	39	37
2015	12	27	23	35	33	0.597	-0.115	3.996	0.01	0.007	0	20.2	17.6	74	87	77	0	40	36
2015	12	27	23	45	33	0.614	-0.115	3.996	0.01	0.007	0	19.8	16.3	74	86	76	0	40	38
2015	12	27	23	55	33	0.597	-0.098	3.996	0.01	0.007	0	19.8	17.2	74.4	86	77	0	40	37
2015	12	28	0	5	33	0.6	-0.108	3.996	0.013	0.01	0	20.2	17.2	74.8	87	77	0	40	37
2015	12	28	0	15	33	0.545	-0.151	3.999	0.01	0.007	0	20.2	16.8	74	87	76	0	40	37
2015	12	28	0	25	33	0.594	-0.085	3.996	0.013	0.01	0	20.2	16.8	73.5	87	76	0	40	37
2015	12	28	0	35	33	0.568	-0.135	3.999	0.013	0.01	0	20.2	16.8	74.8	87	76	0	40	37
2015	12	28	0	45	33	0.564	-0.128	3.999	0.01	0.007	0	20.2	16.8	75.3	87	76	0	40	37
2015	12	28	0	55	33	0.571	-0.098	3.999	0.01	0.007	0	21.1	17.2	75.3	89	77	0	40	37
2015	12	28	1	5	33	0.574	-0.138	3.999	0.016	0.013	0	20.2	16.3	75.7	87	76	0	40	38
2015	12	28	1	15	33	0.577	-0.138	3.999	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	28	1	25	33	0.531	-0.118	3.999	0.01	0.007	0	19.8	16.8	75.3	86	76	0	40	37
2015	12	28	1	35	33	0.614	-0.115	3.999	0.01	0.007	0	20.2	17.2	75.7	87	77	0	40	37
2015	12	28	1	45	33	0.548	-0.161	3.999	0.013	0.01	0	20.6	16.8	76.1	87	76	0	39	37
2015	12	28	1	55	33	0.564	-0.138	3.999	0.01	0.007	0	20.2	16.8	75.7	87	76	0	40	37
2015	12	28	2	5	33	0.607	-0.095	3.999	0.01	0.007	0	20.6	16.8	76.1	88	76	0	40	37
2015	12	28	2	15	33	0.623	-0.098	4.003	0.01	0.007	0	20.6	16.8	76.1	88	77	0	40	38
2015	12	28	2	25	33	0.633	-0.075	4.003	0.01	0.007	0	21.5	17.2	76.5	90	77	0	40	37
2015	12	28	2	35	33	0.551	-0.131	4.003	0.013	0.01	0	20.6	17.2	75.7	88	77	0	40	37
2015	12	28	2	45	33	0.558	-0.115	4.003	0.01	0.007	0	21.1	17.2	75.7	88	77	0	39	37
2015	12	28	2	55	33	0.584	-0.066	4.003	0.016	0.013	0	22.8	19.4	76.5	92	82	0	39	37
2015	12	28	3	5	33	0.568	-0.138	4.003	0.01	0.007	0	21.5	16.8	75.7	90	76	0	40	37
2015	12	28	3	15	33	0.607	-0.062	4.003	0.01	0.007	0	21.9	17.2	75.3	91	77	0	40	37
2015	12	28	3	25	33	0.581	-0.092	4.003	0.01	0.007	0	21.9	16.8	76.1	91	77	0	40	38
2015	12	28	3	35	33	0.646	-0.108	4.003	0.013	0.01	0	22.8	18.9	76.5	92	81	0	39	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	3	45	33	0.472	-0.151	4.003	0.01	0.007	0	23.2	17.6	74.8	94	78	0	40	37
2015	12	28	3	55	33	0.561	-0.033	4.003	0.01	0.007	0	22.8	17.6	76.1	93	78	0	40	37
2015	12	28	4	5	33	0.558	-0.023	4.003	0.01	0.007	0	23.2	17.6	76.1	93	78	0	39	37
2015	12	28	4	15	33	0.614	-0.095	4.003	0.016	0.013	0	22.4	18.9	69.7	92	81	0	40	37
2015	12	28	4	25	33	0.584	-0.049	4.006	0.01	0.007	0	22.8	17.6	71	93	78	0	40	37
2015	12	28	4	35	33	0.417	-0.141	4.009	0.01	0.007	0	22.4	18.5	58	92	79	0	40	36
2015	12	28	4	45	33	0.571	-0.325	4.006	0.01	0.007	0	22.8	18.5	64.1	93	80	0	40	37
2015	12	28	4	55	33	0.568	-0.105	4.006	0.01	0.007	0	22.4	17.6	64.9	92	78	0	40	37
2015	12	28	5	5	33	0.591	-0.062	4.003	0.01	0.007	0	22.8	18.9	67.1	93	81	0	40	37
2015	12	28	5	15	33	0.489	-0.079	4.009	0.01	0.007	0	22.4	18.5	70.1	92	80	0	40	37
2015	12	28	5	25	33	0.656	-0.085	4.003	0.013	0.01	0	22.8	18.9	74	92	81	0	39	37
2015	12	28	5	35	33	0.446	-0.19	4.003	0.016	0.013	0	22.4	18.5	66.7	92	80	0	40	37
2015	12	28	5	45	33	0.364	-0.22	3.999	0.01	0.007	0	22.4	18.9	72.2	92	81	0	40	37
2015	12	28	5	55	33	0.62	-0.098	4.003	0.013	0.01	0	22.4	18.9	71.4	92	81	0	40	37
2015	12	28	6	5	33	0.571	-0.062	3.996	0.013	0.01	0	22.4	18.9	68.4	92	81	0	40	37
2015	12	28	6	15	33	0.61	-0.066	3.999	0.013	0.01	0	21.9	18.5	74.8	91	81	0	40	38
2015	12	28	6	25	33	0.492	-0.089	3.996	0.01	0.007	0	21.9	18.9	58.9	91	81	0	40	37
2015	12	28	6	35	33	0.653	-0.098	3.996	0.013	0.01	0	21.9	18.5	75.3	91	81	0	40	38
2015	12	28	6	45	33	0.614	-0.062	3.999	0.01	0.007	0	21.9	18.9	71.4	91	81	0	40	37
2015	12	28	6	55	33	0.463	-0.036	3.999	0.01	0.007	0	21.5	18.9	79.1	90	81	0	40	37
2015	12	28	7	5	33	0.643	-0.092	3.996	0.01	0.007	0	21.9	18.9	81.7	91	81	0	40	37
2015	12	28	7	15	33	0.623	-0.089	3.986	0.013	0.01	0	22.8	19.4	79.1	93	82	0	40	37
2015	12	28	7	25	33	0.659	-0.079	3.996	0.01	0.007	0	25.8	21.5	83.4	99	87	0	39	37
2015	12	28	7	35	33	0.738	-0.089	3.98	0.013	0.01	0	25.8	21.9	80	100	89	0	40	38
2015	12	28	7	45	33	0.62	-0.092	3.983	0.01	0.007	0	25.4	21.5	81.3	99	88	0	40	38
2015	12	28	7	55	33	0.702	-0.098	3.976	0.013	0.01	0	27.5	23.2	83.8	104	92	0	40	38
2015	12	28	8	5	33	0.65	-0.095	3.976	0.016	0.013	0	27.5	23.2	84.3	104	91	0	40	37
2015	12	28	8	15	33	0.696	-0.085	3.98	0.013	0.01	0	27.5	24.1	81.7	104	93	0	40	37
2015	12	28	8	25	33	0.696	-0.108	3.976	0.016	0.013	0	27.5	24.1	83	104	93	0	40	37
2015	12	28	8	35	33	0.719	-0.105	3.986	0.01	0.007	0	25.8	22.4	81.3	100	89	0	40	37
2015	12	28	8	45	33	0.656	-0.102	3.98	0.01	0.007	0	24.5	21.1	82.1	97	86	0	40	37
2015	12	28	8	55	33	0.715	-0.085	3.98	0.013	0.01	0	28.4	24.5	83.4	106	94	0	40	37
2015	12	28	9	5	33	0.705	-0.108	3.983	0.01	0.007	0	27.5	22.8	84.3	103	91	0	39	38
2015	12	28	9	15	33	0.705	-0.125	3.973	0.01	0.007	0	24.5	21.1	83	97	86	0	40	37
2015	12	28	9	25	33	0.669	-0.121	3.98	0.013	0.01	0	24.1	21.1	72.7	96	86	0	40	37
2015	12	28	9	35	33	0.656	-0.131	3.986	0.013	0.01	0	24.1	20.2	71.8	96	85	0	40	38
2015	12	28	9	45	33	0.682	-0.125	3.986	0.013	0.01	0	24.1	21.5	70.1	96	86	0	40	36
2015	12	28	9	55	33	0.666	-0.072	3.983	0.016	0.016	0	24.9	21.1	76.1	97	87	0	39	38
2015	12	28	10	5	33	0.686	-0.069	3.976	0.016	0.013	0	24.5	21.1	84.7	97	86	0	40	37
2015	12	28	10	15	33	0.653	-0.098	3.976	0.01	0.007	0	24.1	20.6	86.9	96	85	0	40	37
2015	12	28	10	25	33	0.673	-0.125	3.98	0.01	0.007	0	24.5	21.1	87.3	97	86	0	40	37
2015	12	28	10	35	33	0.663	-0.089	3.98	0.013	0.01	0	24.1	20.6	87.3	96	85	0	40	37
2015	12	28	10	45	33	0.686	-0.089	3.983	0.016	0.013	0	24.5	20.6	87.3	96	85	0	39	37
2015	12	28	10	55	33	0.699	-0.089	3.98	0.016	0.013	0	25.4	21.1	89.4	98	87	0	39	38
2015	12	28	11	5	33	0.686	-0.102	3.976	0.013	0.01	0	24.5	21.1	87.3	97	87	0	40	38
2015	12	28	11	15	33	0.719	-0.098	3.98	0.013	0.01	0	24.9	21.5	86.4	98	87	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	11	25	33	0.728	-0.085	3.98	0.01	0.007	0	24.9	21.9	86	98	88	0	40	37
2015	12	28	11	35	33	0.692	-0.098	3.983	0.01	0.007	0	24.9	20.6	83	98	86	0	40	38
2015	12	28	11	45	33	0.413	0.082	3.98	0.01	0.007	0	24.1	20.6	83.4	96	85	0	40	37
2015	12	28	11	55	33	0.646	-0.089	3.99	0.013	0.01	0	23.2	20.2	77.4	94	84	0	40	37
2015	12	28	12	5	33	0.676	-0.098	3.993	0.01	0.007	0	23.6	20.2	78.3	95	84	0	40	37
2015	12	28	12	15	33	0.705	-0.102	3.986	0.01	0.007	0	24.9	21.1	79.6	98	87	0	40	38
2015	12	28	12	25	33	0.64	-0.062	3.983	0.013	0.01	0	24.5	21.1	76.5	97	86	0	40	37
2015	12	28	12	35	33	0.65	-0.072	3.986	0.013	0.01	0	24.1	20.2	76.5	95	84	0	39	37
2015	12	28	12	45	33	0.722	-0.135	3.986	0.01	0.007	0	23.6	19.8	71.8	94	83	0	39	37
2015	12	28	12	55	33	0.682	-0.121	3.99	0.016	0.013	0	23.6	20.2	71	95	84	0	40	37
2015	12	28	13	5	33	0.686	-0.105	3.99	0.013	0.01	0	24.1	20.2	67.9	96	85	0	40	38
2015	12	28	13	15	33	0.614	-0.079	3.996	0.01	0.007	0	23.2	19.8	68.8	94	83	0	40	37
2015	12	28	13	25	33	0.594	-0.052	3.986	0.013	0.01	0	23.2	19.8	70.5	94	84	0	40	38
2015	12	28	13	35	33	0.577	-0.095	3.99	0.01	0.007	0	23.6	21.1	64.1	95	86	0	40	37
2015	12	28	13	45	33	0.673	-0.112	3.999	0.013	0.01	0	23.2	20.2	84.7	94	84	0	40	37
2015	12	28	13	55	33	0.495	-0.102	4.003	0.01	0.007	0	23.6	20.2	86	95	85	0	40	38
2015	12	28	14	5	33	0.512	-0.108	4.003	0.01	0.007	0	23.2	20.6	85.1	94	85	0	40	37
2015	12	28	14	15	33	0.476	-0.092	4.006	0.01	0.007	0	23.6	20.2	83.8	95	84	0	40	37
2015	12	28	14	25	33	0.443	-0.095	4.006	0.01	0.007	0	24.5	21.1	82.6	97	86	0	40	37
2015	12	28	14	35	33	0.518	-0.151	4.006	0.01	0.007	0	24.1	20.6	79.6	96	85	0	40	37
2015	12	28	14	45	33	0.518	-0.144	4.006	0.01	0.007	0	24.1	20.2	77.4	95	84	0	39	37
2015	12	28	14	55	33	0.522	-0.105	4.003	0.01	0.007	0	23.6	20.2	75.7	95	84	0	40	37
2015	12	28	15	5	33	0.525	-0.131	3.996	0.01	0.007	0	25.8	21.5	76.5	99	87	0	39	37
2015	12	28	15	15	33	0.486	-0.108	3.999	0.01	0.007	0	25.4	21.5	76.1	99	87	0	40	37
2015	12	28	15	25	33	0.499	-0.148	3.999	0.01	0.007	0	24.5	21.1	77.8	97	86	0	40	37
2015	12	28	15	35	33	0.463	-0.121	3.996	0.01	0.007	0	24.9	21.1	76.5	97	86	0	39	37
2015	12	28	15	45	33	0.535	-0.131	3.993	0.013	0.01	0	24.1	20.6	75.3	96	85	0	40	37
2015	12	28	15	55	33	0.509	-0.089	3.993	0.016	0.013	0	24.1	20.2	76.1	96	84	0	40	37
2015	12	28	16	5	33	0.492	-0.151	3.993	0.01	0.007	0	23.6	20.2	75.7	95	84	0	40	37
2015	12	28	16	15	33	0.515	-0.095	3.99	0.01	0.007	0	24.5	20.6	75.3	97	85	0	40	37
2015	12	28	16	25	33	0.558	-0.085	3.993	0.01	0.007	0	24.5	20.6	67.5	97	85	0	40	37
2015	12	28	16	35	33	0.512	-0.089	3.99	0.01	0.007	0	24.1	20.6	72.2	96	85	0	40	37
2015	12	28	16	45	33	0.558	-0.112	3.986	0.01	0.007	0	24.1	20.6	73.1	96	85	0	40	37
2015	12	28	16	55	33	0.463	-0.141	3.983	0.01	0.007	0	23.6	20.2	73.5	95	84	0	40	37
2015	12	28	17	5	33	0.525	-0.141	3.983	0.01	0.007	0	26.2	22.8	75.3	101	91	0	40	38
2015	12	28	17	15	33	0.62	-0.102	3.976	0.01	0.007	0	32.3	28.4	74.4	115	104	0	40	38
2015	12	28	17	25	33	0.715	-0.125	3.98	0.013	0.01	0	28.8	25.8	77.8	107	97	0	40	37
2015	12	28	17	35	33	0.699	-0.075	3.963	0.01	0.007	0	32.7	29.7	70.1	116	106	0	40	37
2015	12	28	17	45	33	0.686	-0.105	3.96	0.013	0.01	0	24.5	21.1	71.8	97	86	0	40	37
2015	12	28	17	55	33	0.702	-0.108	3.95	0.01	0.007	0	24.5	20.6	63.6	97	86	0	40	38
2015	12	28	18	5	33	0.705	-0.092	3.944	0.013	0.01	0	24.1	20.6	58.5	96	85	0	40	37
2015	12	28	18	15	33	0.696	-0.108	3.94	0.016	0.013	0	23.6	20.6	58.5	95	85	0	40	37
2015	12	28	18	25	33	0.682	-0.102	3.94	0.013	0.01	0	23.2	20.2	57.2	95	85	0	41	38
2015	12	28	18	35	33	0.653	-0.098	3.944	0.013	0.01	0	23.6	20.2	54.6	95	84	0	40	37
2015	12	28	18	45	33	0.666	-0.069	3.947	0.013	0.01	0	23.6	20.2	54.6	95	84	0	40	37
2015	12	28	18	55	33	0.679	-0.092	3.947	0.013	0.01	0	24.1	19.8	52.9	95	84	0	39	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	28	19	5	33	0.699	-0.098	3.95	0.013	0.01	0	24.5	20.2	52.9	96	85	0	39	38
2015	12	28	19	15	33	0.682	-0.072	3.95	0.016	0.013	0	23.6	20.2	51.2	95	84	0	40	37
2015	12	28	19	25	33	0.699	-0.102	3.95	0.013	0.01	0	23.6	20.2	50.7	95	84	0	40	37
2015	12	28	19	35	33	0.679	-0.121	3.947	0.013	0.01	0	23.2	19.8	52.5	94	84	0	40	38
2015	12	28	19	45	33	0.696	-0.098	3.947	0.01	0.007	0	23.2	20.2	51.6	94	84	0	40	37
2015	12	28	19	55	33	0.686	-0.098	3.944	0.013	0.01	0	23.2	20.2	51.2	94	84	0	40	37
2015	12	28	20	5	33	0.705	-0.072	3.95	0.013	0.01	0	23.2	20.2	54.6	94	84	0	40	37
2015	12	28	20	15	33	0.666	-0.121	3.95	0.013	0.01	0	23.2	19.8	51.6	94	83	0	40	37
2015	12	28	20	25	33	0.676	-0.085	3.95	0.013	0.01	0	23.2	19.8	55	94	83	0	40	37
2015	12	28	20	35	33	0.659	-0.095	3.95	0.01	0.007	0	23.6	19.8	52	95	83	0	40	37
2015	12	28	20	45	33	0.673	-0.085	3.95	0.01	0.007	0	23.6	20.2	52.5	95	84	0	40	37
2015	12	28	20	55	33	0.659	-0.082	3.947	0.01	0.007	0	22.8	20.2	55.5	94	83	0	41	36
2015	12	28	21	5	33	0.682	-0.082	3.947	0.01	0.007	0	23.2	19.8	54.2	94	83	0	40	37
2015	12	28	21	15	33	0.558	-0.049	3.953	0.01	0.007	0	22.4	19.4	57.2	92	82	0	40	37
2015	12	28	21	25	33	0.692	-0.112	3.953	0.01	0.007	0	22.8	19.8	61.1	93	83	0	40	37
2015	12	28	21	35	33	0.686	-0.079	3.947	0.01	0.007	0	24.1	20.6	58.5	96	85	0	40	37
2015	12	28	21	45	33	0.643	-0.089	3.95	0.013	0.01	0	23.6	20.2	61.5	95	84	0	40	37
2015	12	28	21	55	33	0.689	-0.112	3.947	0.01	0.007	0	22.8	19.8	59.8	93	83	0	40	37
2015	12	28	22	5	33	0.666	-0.095	3.95	0.013	0.01	0	24.1	19.8	55.9	96	84	0	40	38
2015	12	28	22	15	33	0.679	-0.082	3.95	0.01	0.007	0	22.8	19.4	56.3	93	83	0	40	38
2015	12	28	22	25	33	0.679	-0.072	3.95	0.013	0.01	0	23.6	20.2	62.4	95	84	0	40	37
2015	12	28	22	35	33	0.659	-0.115	3.947	0.013	0.01	0	22.8	19.8	62.4	93	83	0	40	37
2015	12	28	22	45	33	0.499	-0.079	3.953	0.01	0.007	0	22.8	18.9	63.6	93	82	0	40	38
2015	12	28	22	55	33	0.64	-0.049	3.953	0.013	0.01	0	22.8	19.4	64.1	93	83	0	40	38
2015	12	28	23	5	33	0.63	-0.043	3.95	0.016	0.013	0	22.8	19.8	59.3	93	83	0	40	37
2015	12	28	23	15	33	0.646	-0.049	3.953	0.013	0.01	0	23.2	19.8	61.5	94	83	0	40	37
2015	12	28	23	25	33	0.646	-0.052	3.95	0.013	0.01	0	22.8	19.8	57.6	93	83	0	40	37
2015	12	28	23	35	33	0.659	-0.079	3.953	0.013	0.01	0	23.6	20.2	55.5	95	84	0	40	37
2015	12	28	23	45	33	0.643	-0.098	3.963	0.013	0.01	0	23.6	20.2	56.8	95	84	0	40	37
2015	12	28	23	55	33	0.594	-0.128	3.957	0.01	0.007	0	23.2	19.8	54.2	94	83	0	40	37
2015	12	29	0	5	33	0.669	-0.092	3.96	0.01	0.007	0	22.8	19.8	52	93	83	0	40	37
2015	12	29	0	15	33	0.755	-0.115	3.963	0.01	0.007	0	23.6	19.4	51.2	94	83	0	39	38
2015	12	29	0	25	33	0.574	-0.154	3.967	0.013	0.01	0	23.6	19.8	54.2	95	83	0	40	37
2015	12	29	0	35	33	0.676	-0.085	3.97	0.01	0.007	0	23.6	20.2	47.3	94	84	0	39	37
2015	12	29	0	45	33	0.715	-0.108	3.967	0.013	0.01	0	23.6	20.2	47.7	94	83	0	39	36
2015	12	29	0	55	33	0.709	-0.082	3.967	0.013	0.01	0	23.2	19.8	53.3	94	83	0	40	37
2015	12	29	1	5	33	0.42	-0.059	3.963	0.01	0.007	0	22.4	18.9	52.9	92	82	0	40	38
2015	12	29	1	15	33	0.669	-0.062	3.957	0.013	0.01	0	23.6	20.2	51.2	94	84	0	39	37
2015	12	29	1	25	33	0.509	-0.059	3.957	0.01	0.007	0	22.8	20.2	56.8	93	83	0	40	36
2015	12	29	1	35	33	0.682	-0.085	3.963	0.01	0.007	0	22.8	19.8	61.5	93	83	0	40	37
2015	12	29	1	45	33	0.643	-0.046	3.963	0.013	0.01	0	22.8	18.9	64.1	93	82	0	40	38
2015	12	29	1	55	33	0.636	-0.049	3.96	0.013	0.01	0	23.2	19.8	62.4	94	83	0	40	37
2015	12	29	2	5	33	0.669	-0.049	3.957	0.013	0.01	0	23.6	20.2	63.2	95	84	0	40	37
2015	12	29	2	15	33	0.682	-0.128	3.957	0.013	0.01	0	22.8	19.8	63.6	93	83	0	40	37
2015	12	29	2	25	33	0.551	-0.052	3.963	0.016	0.016	0	22.8	19.4	64.1	94	82	0	41	37
2015	12	29	2	35	33	0.643	-0.112	3.96	0.016	0.013	0	22.8	19.4	63.6	93	83	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	2	45	33	0.659	-0.062	3.963	0.016	0.016	0	23.2	19.8	69.2	94	83	0	40	37
2015	12	29	2	55	33	0.548	-0.144	3.963	0.01	0.007	0	22.8	19.4	70.5	93	82	0	40	37
2015	12	29	3	5	33	0.594	-0.062	3.967	0.013	0.01	0	22.8	19.8	68.4	93	83	0	40	37
2015	12	29	3	15	33	0.666	-0.112	3.967	0.016	0.013	0	23.2	19.8	71	94	83	0	40	37
2015	12	29	3	25	33	0.686	-0.085	3.967	0.013	0.01	0	22.8	19.8	74.8	93	83	0	40	37
2015	12	29	3	35	33	0.696	-0.079	3.97	0.01	0.007	0	22.8	19.8	68.4	93	83	0	40	37
2015	12	29	3	45	33	0.62	-0.105	3.97	0.013	0.01	0	22.8	19.4	67.9	92	82	0	39	37
2015	12	29	3	55	33	0.636	-0.075	3.97	0.013	0.01	0	22.8	19.8	67.9	93	83	0	40	37
2015	12	29	4	5	33	0.679	-0.085	3.973	0.016	0.013	0	22.8	19.4	66.2	93	83	0	40	38
2015	12	29	4	15	33	0.627	-0.072	3.97	0.016	0.013	0	22.8	19.4	62.8	93	82	0	40	37
2015	12	29	4	25	33	0.669	-0.072	3.976	0.013	0.01	0	22.4	19.4	70.5	92	82	0	40	37
2015	12	29	4	35	33	0.65	-0.125	3.976	0.013	0.01	0	22.8	19.8	64.5	93	83	0	40	37
2015	12	29	4	45	33	0.64	-0.121	3.97	0.016	0.013	0	23.2	19.4	66.2	94	82	0	40	37
2015	12	29	4	55	33	0.692	-0.118	3.97	0.013	0.01	0	22.8	19.4	69.7	93	82	0	40	37
2015	12	29	5	5	33	0.39	-0.075	3.973	0.013	0.01	0	22.4	18.9	61.1	92	81	0	40	37
2015	12	29	5	15	33	0.676	-0.072	3.973	0.016	0.013	0	23.2	19.4	65.4	93	82	0	39	37
2015	12	29	5	25	33	0.64	-0.072	3.976	0.013	0.01	0	22.8	18.9	68.4	93	82	0	40	38
2015	12	29	5	35	33	0.65	-0.062	3.973	0.013	0.01	0	22.4	18.9	66.2	92	82	0	40	38
2015	12	29	5	45	33	0.623	-0.043	3.97	0.013	0.01	0	22.8	19.4	67.1	92	82	0	39	37
2015	12	29	5	55	33	0.63	-0.092	3.97	0.016	0.016	0	22.8	19.4	69.7	93	82	0	40	37
2015	12	29	6	5	33	0.656	-0.108	3.973	0.013	0.01	0	22.8	19.4	68.8	93	82	0	40	37
2015	12	29	6	15	33	0.63	-0.069	3.97	0.013	0.01	0	22.8	19.4	64.1	93	82	0	40	37
2015	12	29	6	25	33	0.646	-0.079	3.97	0.01	0.007	0	22.8	18.9	67.5	93	82	0	40	38
2015	12	29	6	35	33	0.548	-0.03	3.973	0.01	0.007	0	22.4	18.9	71	92	82	0	40	38
2015	12	29	6	45	33	0.656	-0.079	3.973	0.01	0.007	0	22.8	19.4	63.2	93	82	0	40	37
2015	12	29	6	55	33	0.627	-0.046	3.97	0.013	0.01	0	23.2	19.4	69.2	93	82	0	39	37
2015	12	29	7	5	33	0.64	-0.072	3.97	0.01	0.007	0	22.4	19.4	67.9	92	82	0	40	37
2015	12	29	7	15	33	0.594	-0.128	3.967	0.013	0.01	0	22.8	19.4	67.5	93	82	0	40	37
2015	12	29	7	25	33	0.623	-0.036	3.967	0.013	0.01	0	22.8	19.4	67.1	93	82	0	40	37
2015	12	29	7	35	33	0.663	-0.066	3.967	0.016	0.013	0	24.5	21.5	68.8	97	87	0	40	37
2015	12	29	7	45	33	0.63	-0.105	3.963	0.016	0.013	0	25.4	21.1	76.1	99	87	0	40	38
2015	12	29	7	55	33	0.682	-0.118	3.967	0.013	0.01	0	25.4	21.1	70.5	98	86	0	39	37
2015	12	29	8	5	33	0.689	-0.072	3.953	0.013	0.01	0	26.7	22.8	77	101	90	0	39	37
2015	12	29	8	15	33	0.712	-0.105	3.953	0.016	0.013	0	27.5	22.8	76.1	103	91	0	39	38
2015	12	29	8	25	33	0.669	-0.092	3.953	0.013	0.01	0	26.7	22.8	76.5	102	91	0	40	38
2015	12	29	8	35	33	0.715	-0.108	3.95	0.01	0.007	0	27.1	23.2	74.4	103	91	0	40	37
2015	12	29	8	45	33	0.64	-0.069	3.944	0.013	0.01	0	25.8	21.9	71.8	100	88	0	40	37
2015	12	29	8	55	33	0.673	-0.092	3.95	0.016	0.013	0	26.2	22.4	72.7	101	89	0	40	37
2015	12	29	9	5	33	0.715	-0.118	3.947	0.016	0.013	0	26.7	22.8	67.5	101	90	0	39	37
2015	12	29	9	15	33	0.656	-0.062	3.953	0.013	0.01	0	25.4	21.9	70.1	99	88	0	40	37
2015	12	29	9	25	33	0.453	-0.026	3.953	0.013	0.01	0	25.4	21.1	69.7	98	85	0	39	36
2015	12	29	9	35	33	0.646	-0.112	3.953	0.016	0.013	0	25.8	22.4	66.7	100	89	0	40	37
2015	12	29	9	45	33	0.659	-0.089	3.953	0.01	0.007	0	24.5	21.1	60.2	97	86	0	40	37
2015	12	29	9	55	33	0.682	-0.105	3.953	0.016	0.013	0	24.1	20.6	61.9	96	85	0	40	37
2015	12	29	10	5	33	0.653	-0.092	3.947	0.01	0.007	0	23.6	19.8	63.2	95	84	0	40	38
2015	12	29	10	15	33	0.679	-0.108	3.953	0.013	0.01	0	23.6	20.2	60.6	95	84	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	10	25	33	0.531	-0.148	3.96	0.01	0.007	0	23.6	20.6	61.5	95	85	0	40	37
2015	12	29	10	35	33	0.63	-0.075	3.95	0.013	0.01	0	23.6	20.6	61.5	95	84	0	40	36
2015	12	29	10	45	33	0.663	-0.128	3.947	0.013	0.01	0	23.6	19.8	67.9	95	84	0	40	38
2015	12	29	10	55	33	0.676	-0.105	3.95	0.013	0.01	0	23.6	20.2	67.5	95	84	0	40	37
2015	12	29	11	5	33	0.646	-0.098	3.95	0.013	0.01	0	23.2	20.2	61.5	94	84	0	40	37
2015	12	29	11	15	33	0.633	-0.095	3.953	0.013	0.01	0	23.2	20.2	57.2	94	84	0	40	37
2015	12	29	11	25	33	0.722	-0.151	3.957	0.013	0.01	0	31	26.7	57.2	111	99	0	39	37
2015	12	29	11	35	33	0.712	-0.108	3.953	0.01	0.007	0	32.3	28	59.3	115	102	0	40	37
2015	12	29	11	45	33	0.679	-0.118	3.95	0.013	0.01	0	24.5	21.5	61.5	97	87	0	40	37
2015	12	29	11	55	33	0.666	-0.125	3.953	0.013	0.01	0	24.9	21.1	62.4	98	86	0	40	37
2015	12	29	12	5	33	0.673	-0.121	3.95	0.016	0.016	0	24.5	21.9	54.6	97	87	0	40	36
2015	12	29	12	15	33	0.728	-0.115	3.97	0.01	0.007	0	27.5	23.6	47.7	104	92	0	40	37
2015	12	29	12	25	33	0.732	-0.121	3.953	0.016	0.013	0	27.1	23.2	55.9	103	91	0	40	37
2015	12	29	12	35	33	0.617	-0.108	3.957	0.013	0.01	0	25.4	21.9	66.2	99	88	0	40	37
2015	12	29	12	45	33	0.646	-0.092	3.953	0.013	0.01	0	24.1	20.6	60.6	96	86	0	40	38
2015	12	29	12	55	33	0.659	-0.138	3.963	0.016	0.013	0	24.5	20.6	51.2	96	85	0	39	37
2015	12	29	13	5	33	0.65	-0.125	3.953	0.013	0.01	0	24.5	20.2	51.6	97	85	0	40	38
2015	12	29	13	15	33	0.666	-0.098	3.953	0.01	0.007	0	24.1	20.6	56.3	96	85	0	40	37
2015	12	29	13	25	33	0.682	-0.105	3.953	0.016	0.013	0	24.9	20.6	62.4	97	85	0	39	37
2015	12	29	13	35	33	0.522	0.046	3.953	0.013	0.01	0	24.5	21.5	63.6	97	86	0	40	36
2015	12	29	13	45	33	0.646	-0.098	3.953	0.016	0.016	0	24.5	20.6	58.9	96	85	0	39	37
2015	12	29	13	55	33	0.499	-0.079	3.967	0.01	0.007	0	24.5	21.1	57.2	97	86	0	40	37
2015	12	29	14	5	33	0.679	-0.092	3.963	0.013	0.01	0	24.1	20.6	57.6	96	86	0	40	38
2015	12	29	14	15	33	0.65	-0.069	3.953	0.013	0.01	0	24.5	20.6	59.3	97	85	0	40	37
2015	12	29	14	25	33	0.663	-0.066	3.95	0.013	0.01	0	24.5	21.1	61.1	96	86	0	39	37
2015	12	29	14	35	33	0.499	-0.033	3.953	0.01	0.007	0	24.5	21.1	62.8	97	86	0	40	37
2015	12	29	14	45	33	0.518	0.036	3.953	0.01	0.007	0	24.9	21.5	58.9	97	87	0	39	37
2015	12	29	14	55	33	0.633	-0.062	3.96	0.016	0.013	0	24.5	21.5	53.8	97	86	0	40	36
2015	12	29	15	5	33	0.682	-0.039	3.976	0.01	0.007	0	24.5	20.2	50.7	97	85	0	40	38
2015	12	29	15	15	33	0.659	-0.056	3.96	0.013	0.01	0	24.1	21.1	55.9	96	86	0	40	37
2015	12	29	15	25	33	0.643	-0.066	3.96	0.013	0.01	0	24.1	20.6	56.3	96	85	0	40	37
2015	12	29	15	35	33	0.673	-0.118	3.95	0.013	0.01	0	23.6	20.2	56.3	95	84	0	40	37
2015	12	29	15	45	33	0.617	-0.075	3.953	0.013	0.01	0	24.1	20.2	53.8	95	84	0	39	37
2015	12	29	15	55	33	0.686	-0.036	3.957	0.016	0.013	0	24.1	20.6	60.6	96	85	0	40	37
2015	12	29	16	5	33	0.738	-0.105	3.947	0.016	0.013	0	25.4	21.5	61.1	99	87	0	40	37
2015	12	29	16	15	33	0.663	-0.072	3.957	0.016	0.013	0	25.4	21.9	62.8	100	88	0	41	37
2015	12	29	16	25	33	0.656	-0.089	3.953	0.013	0.01	0	24.1	20.2	58.9	96	84	0	40	37
2015	12	29	16	35	33	0.63	-0.052	3.957	0.016	0.013	0	23.6	20.2	60.2	95	84	0	40	37
2015	12	29	16	45	33	0.646	-0.079	3.953	0.016	0.013	0	23.2	19.8	55.9	94	83	0	40	37
2015	12	29	16	55	33	0.633	-0.049	3.953	0.016	0.013	0	23.2	19.8	52	94	83	0	40	37
2015	12	29	17	5	33	0.646	-0.062	3.967	0.013	0.01	0	23.2	19.4	48.2	94	83	0	40	38
2015	12	29	17	15	33	0.679	-0.098	3.963	0.013	0.01	0	23.6	19.8	49.9	94	83	0	39	37
2015	12	29	17	25	33	0.62	-0.105	3.957	0.016	0.013	0	23.2	19.8	52.5	94	83	0	40	37
2015	12	29	17	35	33	0.64	-0.072	3.953	0.01	0.007	0	23.2	19.8	55.5	94	83	0	40	37
2015	12	29	17	45	33	0.61	-0.085	3.96	0.016	0.013	0	23.2	19.8	58.9	94	83	0	40	37
2015	12	29	17	55	33	0.623	-0.098	3.957	0.013	0.01	0	23.2	19.8	58.5	94	83	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	29	18	5	33	0.679	-0.075	3.96	0.016	0.013	0	23.6	20.6	59.8	95	84	0	40	36
2015	12	29	18	15	33	0.646	-0.052	3.957	0.013	0.01	0	23.2	19.8	64.5	94	83	0	40	37
2015	12	29	18	25	33	0.682	-0.075	3.97	0.016	0.013	0	23.2	19.4	63.6	94	83	0	40	38
2015	12	29	18	35	33	0.627	-0.056	3.967	0.016	0.013	0	23.2	19.8	77	94	83	0	40	37
2015	12	29	18	45	33	0.6	-0.082	3.97	0.013	0.01	0	23.2	19.8	69.7	94	83	0	40	37
2015	12	29	18	55	33	0.663	-0.072	3.973	0.016	0.013	0	23.2	19.8	68.4	94	83	0	40	37
2015	12	29	19	5	33	0.41	-0.033	3.967	0.01	0.007	0	23.6	18.9	64.5	94	81	0	39	37
2015	12	29	19	15	33	0.633	-0.079	3.963	0.016	0.013	0	23.2	19.8	61.9	94	83	0	40	37
2015	12	29	19	25	33	0.63	-0.049	3.967	0.013	0.01	0	23.2	19.8	67.1	94	83	0	40	37
2015	12	29	19	35	33	0.643	-0.056	3.96	0.016	0.013	0	23.2	19.8	71.4	94	83	0	40	37
2015	12	29	19	45	33	0.643	-0.098	3.967	0.013	0.01	0	23.2	19.8	72.2	94	83	0	40	37
2015	12	29	19	55	33	0.682	-0.095	3.97	0.016	0.013	0	23.6	19.4	68.4	95	83	0	40	38
2015	12	29	20	5	33	0.646	-0.085	3.967	0.016	0.013	0	23.2	19.8	65.8	94	83	0	40	37
2015	12	29	20	15	33	0.518	-0.203	3.967	0.01	0.007	0	23.2	19.4	73.5	94	82	0	40	37
2015	12	29	20	25	33	0.643	-0.056	3.963	0.016	0.013	0	23.6	19.8	69.7	95	84	0	40	38
2015	12	29	20	35	33	0.646	-0.079	3.953	0.016	0.013	0	23.2	19.8	64.5	94	83	0	40	37
2015	12	29	20	45	33	0.679	-0.098	3.96	0.013	0.01	0	23.2	19.8	63.2	94	83	0	40	37
2015	12	29	20	55	33	0.666	-0.121	3.963	0.013	0.01	0	23.6	19.8	75.7	94	83	0	39	37
2015	12	29	21	5	33	0.62	-0.089	3.953	0.013	0.01	0	22.8	19.8	73.5	93	83	0	40	37
2015	12	29	21	15	33	0.443	-0.016	3.96	0.01	0.007	0	22.8	18.5	65.8	93	81	0	40	38
2015	12	29	21	25	33	0.636	-0.049	3.947	0.016	0.013	0	22.8	19.4	68.4	93	82	0	40	37
2015	12	29	21	35	33	0.515	-0.184	3.953	0.013	0.01	0	22.4	19.4	77	92	82	0	40	37
2015	12	29	21	45	33	0.633	-0.102	3.947	0.013	0.01	0	22.8	19.4	73.5	93	82	0	40	37
2015	12	29	21	55	33	0.653	-0.112	3.95	0.016	0.013	0	23.2	19.4	65.8	94	82	0	40	37
2015	12	29	22	5	33	0.643	-0.121	3.947	0.013	0.01	0	22.8	18.9	78.7	93	82	0	40	38
2015	12	29	22	15	33	0.656	-0.108	3.944	0.013	0.01	0	22.8	19.4	72.2	93	82	0	40	37
2015	12	29	22	25	33	0.604	-0.036	3.95	0.016	0.013	0	23.2	19.4	63.6	93	82	0	39	37
2015	12	29	22	35	33	0.636	-0.075	3.94	0.016	0.013	0	23.2	19.8	77.8	94	83	0	40	37
2015	12	29	22	45	33	0.597	-0.062	3.944	0.016	0.016	0	22.8	19.4	75.3	93	82	0	40	37
2015	12	29	22	55	33	0.627	-0.092	3.944	0.016	0.013	0	22.8	19.8	65.8	93	83	0	40	37
2015	12	29	23	5	33	0.633	-0.098	3.937	0.013	0.01	0	23.6	18.9	77.4	94	82	0	39	38
2015	12	29	23	15	33	0.679	-0.108	3.937	0.01	0.007	0	22.8	19.8	77	93	83	0	40	37
2015	12	29	23	25	33	0.646	-0.082	3.94	0.01	0.007	0	23.2	19.8	68.4	94	83	0	40	37
2015	12	29	23	35	33	0.63	-0.112	3.934	0.013	0.01	0	22.8	19.4	76.1	93	82	0	40	37
2015	12	29	23	45	33	0.61	-0.066	3.934	0.013	0.01	0	23.2	19.4	76.1	93	82	0	39	37
2015	12	29	23	55	33	0.636	-0.066	3.94	0.016	0.013	0	23.2	19.4	71.4	94	83	0	40	38
2015	12	30	0	5	33	0.61	-0.098	3.93	0.016	0.013	0	23.2	19.4	76.5	94	82	0	40	37
2015	12	30	0	15	33	0.594	-0.059	3.934	0.016	0.013	0	23.2	20.2	76.1	94	83	0	40	36
2015	12	30	0	25	33	0.656	-0.062	3.934	0.016	0.016	0	22.8	19.4	68.8	93	82	0	40	37
2015	12	30	0	35	33	0.63	-0.069	3.927	0.016	0.013	0	23.2	18.9	75.7	94	82	0	40	38
2015	12	30	0	45	33	0.643	-0.131	3.93	0.016	0.013	0	23.6	19.8	74.8	95	84	0	40	38
2015	12	30	0	55	33	0.607	-0.089	3.93	0.013	0.01	0	22.8	19.8	68.8	93	83	0	40	37
2015	12	30	1	5	33	0.594	-0.072	3.927	0.01	0.007	0	23.2	19.8	79.1	94	83	0	40	37
2015	12	30	1	15	33	0.607	-0.075	3.924	0.016	0.016	0	23.2	19.8	70.1	94	83	0	40	37
2015	12	30	1	25	33	0.62	-0.082	3.93	0.016	0.013	0	22.8	19.4	76.1	93	82	0	40	37
2015	12	30	1	35	33	0.659	-0.069	3.917	0.016	0.013	0	23.2	19.8	77.8	94	83	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	1	45	33	0.604	-0.075	3.921	0.016	0.016	0	23.2	19.8	68.4	94	83	0	40	37
2015	12	30	1	55	33	0.607	-0.056	3.914	0.013	0.01	0	23.2	19.8	75.3	94	83	0	40	37
2015	12	30	2	5	33	0.633	-0.095	3.924	0.016	0.016	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	30	2	15	33	0.587	-0.079	3.921	0.013	0.01	0	23.2	19.4	72.2	93	82	0	39	37
2015	12	30	2	25	33	0.607	-0.062	3.914	0.016	0.013	0	23.2	19.4	78.3	94	82	0	40	37
2015	12	30	2	35	33	0.531	-0.161	3.917	0.016	0.013	0	23.2	19.8	71	94	83	0	40	37
2015	12	30	2	45	33	0.564	-0.046	3.907	0.016	0.016	0	23.2	19.8	76.5	94	83	0	40	37
2015	12	30	2	55	33	0.633	-0.036	3.911	0.013	0.01	0	23.2	19.4	77	94	82	0	40	37
2015	12	30	3	5	33	0.577	-0.075	3.911	0.013	0.01	0	23.6	19.8	70.1	94	83	0	39	37
2015	12	30	3	15	33	0.594	-0.069	3.904	0.013	0.01	0	23.2	19.8	76.1	94	83	0	40	37
2015	12	30	3	25	33	0.591	-0.092	3.907	0.013	0.01	0	22.8	19.4	72.7	93	82	0	40	37
2015	12	30	3	35	33	0.636	-0.102	3.904	0.016	0.013	0	23.2	19.4	76.1	94	82	0	40	37
2015	12	30	3	45	33	0.633	-0.059	3.904	0.016	0.013	0	22.8	19.8	76.5	93	83	0	40	37
2015	12	30	3	55	33	0.63	-0.098	3.911	0.013	0.01	0	23.2	19.4	70.1	94	82	0	40	37
2015	12	30	4	5	33	0.62	-0.115	3.901	0.016	0.016	0	23.2	19.4	78.3	93	82	0	39	37
2015	12	30	4	15	33	0.666	-0.062	3.901	0.016	0.013	0	23.2	19.4	74	94	82	0	40	37
2015	12	30	4	25	33	0.568	-0.066	3.901	0.016	0.013	0	23.2	19.4	72.7	93	82	0	39	37
2015	12	30	4	35	33	0.571	-0.062	3.898	0.016	0.016	0	22.8	18.9	78.7	93	82	0	40	38
2015	12	30	4	45	33	0.643	-0.112	3.904	0.016	0.013	0	22.8	19.4	74.4	93	82	0	40	37
2015	12	30	4	55	33	0.673	-0.144	3.898	0.016	0.016	0	22.8	19.4	76.5	93	82	0	40	37
2015	12	30	5	5	33	0.469	-0.164	3.898	0.01	0.007	0	22.8	19.4	76.5	93	83	0	40	38
2015	12	30	5	15	33	0.597	-0.075	3.898	0.013	0.01	0	23.2	19.4	75.3	94	83	0	40	38
2015	12	30	5	25	33	0.531	-0.18	3.894	0.01	0.007	0	23.6	19.8	75.7	94	83	0	39	37
2015	12	30	5	35	33	0.663	-0.108	3.898	0.01	0.007	0	23.2	18.9	73.1	94	82	0	40	38
2015	12	30	5	45	33	0.61	-0.075	3.891	0.013	0.01	0	22.8	19.4	76.1	93	82	0	40	37
2015	12	30	5	55	33	0.646	-0.138	3.891	0.016	0.016	0	22.8	19.4	76.1	93	82	0	40	37
2015	12	30	6	5	33	0.61	-0.052	3.891	0.013	0.01	0	22.8	19.4	72.2	93	82	0	40	37
2015	12	30	6	15	33	0.495	-0.036	3.881	0.013	0.01	0	22.4	18.9	73.5	92	81	0	40	37
2015	12	30	6	25	33	0.518	-0.026	3.888	0.01	0.007	0	23.2	19.8	71.8	94	83	0	40	37
2015	12	30	6	35	33	0.545	-0.049	3.878	0.016	0.013	0	23.2	19.4	74.4	93	82	0	39	37
2015	12	30	6	45	33	0.653	-0.121	3.881	0.016	0.013	0	22.8	18.9	73.5	93	82	0	40	38
2015	12	30	6	55	33	0.62	-0.118	3.881	0.013	0.01	0	22.8	19.4	71.4	93	82	0	40	37
2015	12	30	7	5	33	0.577	-0.049	3.875	0.016	0.016	0	23.6	19.8	74.4	94	83	0	39	37
2015	12	30	7	15	33	0.62	-0.062	3.878	0.013	0.01	0	22.8	20.2	71.8	93	83	0	40	36
2015	12	30	7	25	33	0.531	-0.013	3.878	0.016	0.016	0	22.8	19.4	75.3	93	82	0	40	37
2015	12	30	7	35	33	0.6	-0.151	3.875	0.013	0.01	0	21.9	19.4	75.7	92	82	0	41	37
2015	12	30	7	45	33	0.587	-0.105	3.875	0.013	0.01	0	23.2	19.8	72.2	94	83	0	40	37
2015	12	30	7	55	33	0.597	-0.062	3.875	0.016	0.013	0	22.8	19.4	75.3	93	83	0	40	38
2015	12	30	8	5	33	0.607	-0.062	3.871	0.016	0.013	0	22.8	19.8	75.7	93	83	0	40	37
2015	12	30	8	15	33	0.276	0	3.871	0.016	0.013	0	24.1	19.8	71.8	95	84	0	39	38
2015	12	30	8	25	33	0.584	-0.098	3.865	0.016	0.013	0	23.2	20.2	75.7	94	84	0	40	37
2015	12	30	8	35	33	0.63	-0.105	3.862	0.016	0.013	0	23.2	20.2	74	94	84	0	40	37
2015	12	30	8	45	33	0.61	-0.066	3.862	0.013	0.01	0	22.8	19.8	77.4	93	83	0	40	37
2015	12	30	8	55	33	0.6	-0.049	3.862	0.016	0.016	0	23.2	20.2	74.4	94	84	0	40	37
2015	12	30	9	5	33	0.262	-0.056	3.865	0.013	0.01	0	23.6	19.8	74.8	94	83	0	39	37
2015	12	30	9	15	33	0.594	-0.075	3.862	0.013	0.01	0	23.6	20.2	74	95	84	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	9	25	33	0.545	-0.118	3.858	0.013	0.01	0	23.2	20.2	72.2	94	84	0	40	37
2015	12	30	9	35	33	0.617	-0.125	3.858	0.016	0.016	0	23.2	20.6	71	94	84	0	40	36
2015	12	30	9	45	33	0.433	-0.089	3.858	0.013	0.01	0	24.1	19.4	67.9	95	83	0	39	38
2015	12	30	9	55	33	0.568	-0.069	3.842	0.016	0.016	0	23.6	20.2	63.2	95	84	0	40	37
2015	12	30	10	5	33	0.65	-0.089	3.845	0.016	0.013	0	24.1	20.6	61.5	95	84	0	39	36
2015	12	30	10	15	33	0.597	-0.079	3.852	0.013	0.01	0	23.6	20.2	62.4	95	85	0	40	38
2015	12	30	10	25	33	0.574	-0.072	3.855	0.016	0.013	0	23.2	20.2	65.4	94	84	0	40	37
2015	12	30	10	35	33	0.623	-0.075	3.848	0.016	0.016	0	23.6	20.2	61.5	95	84	0	40	37
2015	12	30	10	45	33	0.636	-0.102	3.848	0.016	0.016	0	24.1	20.6	57.2	96	85	0	40	37
2015	12	30	10	55	33	0.61	-0.115	3.848	0.013	0.01	0	24.5	21.1	59.8	97	86	0	40	37
2015	12	30	11	5	33	0.623	-0.105	3.852	0.013	0.01	0	24.1	20.2	59.8	96	85	0	40	38
2015	12	30	11	15	33	0.64	-0.105	3.858	0.013	0.01	0	23.6	20.2	59.8	95	84	0	40	37
2015	12	30	11	25	33	0.669	-0.135	3.862	0.013	0.01	0	24.9	21.5	63.2	98	87	0	40	37
2015	12	30	11	35	33	0.627	-0.108	3.858	0.013	0.01	0	25.8	22.8	57.6	100	89	0	40	36
2015	12	30	11	45	33	0.623	-0.121	3.865	0.013	0.01	0	24.9	20.6	60.6	98	86	0	40	38
2015	12	30	11	55	33	0.604	-0.115	3.865	0.016	0.013	0	25.4	22.8	60.6	99	89	0	40	36
2015	12	30	12	5	33	0.633	-0.075	3.865	0.016	0.016	0	25.4	21.9	63.2	99	88	0	40	37
2015	12	30	12	15	33	0.607	-0.082	3.868	0.013	0.01	0	23.6	20.6	62.4	96	85	0	41	37
2015	12	30	12	25	33	0.62	-0.118	3.868	0.013	0.01	0	24.5	20.6	64.5	96	85	0	39	37
2015	12	30	12	35	33	0.597	-0.069	3.871	0.013	0.01	0	24.1	19.8	63.2	96	83	0	40	37
2015	12	30	12	45	33	0.607	-0.075	3.875	0.013	0.01	0	24.1	21.1	65.8	96	86	0	40	37
2015	12	30	12	55	33	0.623	-0.059	3.875	0.013	0.01	0	24.5	20.6	64.5	96	85	0	39	37
2015	12	30	13	5	33	0.63	-0.131	3.875	0.016	0.016	0	24.1	20.2	66.2	95	84	0	39	37
2015	12	30	13	15	33	0.633	-0.072	3.845	0.02	0.016	0	24.5	20.2	58.9	97	85	0	40	38
2015	12	30	13	25	33	0.633	-0.089	3.816	0.016	0.013	0	24.1	20.6	41.7	96	85	0	40	37
2015	12	30	13	42	15	0.6	-0.075	3.842	0.016	0.013	0	24.5	20.6	60.2	97	85	0	40	37
2015	12	30	13	52	15	0.584	-0.056	3.848	0.016	0.013	0	24.1	17.6	54.6	96	79	0	40	38
2015	12	30	14	2	15	0.587	-0.079	3.852	0.013	0.01	0	23.6	20.6	57.6	95	85	0	40	37
2015	12	30	14	12	15	0.591	-0.082	3.852	0.016	0.013	0	24.1	20.6	60.2	96	85	0	40	37
2015	12	30	14	22	15	0.636	-0.082	3.845	0.02	0.016	0	24.1	20.2	57.6	96	84	0	40	37
2015	12	30	14	32	15	0.62	-0.138	3.871	0.013	0.01	0	23.6	19.8	55.9	95	84	0	40	38
2015	12	30	14	42	15	0.61	-0.144	3.855	0.013	0.01	0	23.6	19.8	58.5	95	83	0	40	37
2015	12	30	14	52	15	0.633	-0.098	3.848	0.016	0.013	0	24.1	20.6	60.2	96	85	0	40	37
2015	12	30	15	2	15	0.636	-0.085	3.855	0.016	0.013	0	23.6	20.2	58	95	84	0	40	37
2015	12	30	15	12	15	0.62	-0.075	3.855	0.01	0.007	0	23.2	19.8	54.2	94	84	0	40	38
2015	12	30	15	22	15	0.594	-0.131	3.858	0.016	0.016	0	24.1	20.6	62.8	96	85	0	40	37
2015	12	30	15	32	15	0.64	-0.085	3.858	0.016	0.016	0	23.6	19.8	60.6	95	83	0	40	37
2015	12	30	15	42	15	0.594	-0.121	3.862	0.016	0.013	0	23.6	19.8	58.5	95	83	0	40	37
2015	12	30	15	52	15	0.614	-0.095	3.858	0.016	0.013	0	23.2	19.8	63.6	94	83	0	40	37
2015	12	30	16	2	15	0.646	-0.112	3.865	0.016	0.013	0	23.2	19.8	65.8	94	83	0	40	37
2015	12	30	16	12	15	0.62	-0.075	3.858	0.016	0.016	0	23.2	19.4	63.2	93	82	0	39	37
2015	12	30	16	22	15	0.653	-0.075	3.858	0.013	0.01	0	23.2	19.4	61.1	94	82	0	40	37
2015	12	30	16	32	15	0.604	-0.079	3.862	0.013	0.01	0	22.8	19.8	60.2	93	83	0	40	37
2015	12	30	16	42	15	0.61	-0.085	3.858	0.016	0.013	0	23.2	18.9	62.4	94	82	0	40	38
2015	12	30	16	52	15	0.607	-0.112	3.862	0.016	0.013	0	22.8	19.4	61.9	93	82	0	40	37
2015	12	30	17	2	15	0.502	-0.187	3.858	0.013	0.01	0	23.2	17.2	63.6	94	77	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	30	17	12	15	0.512	-0.118	3.862	0.013	0.01	0	23.2	17.2	63.2	94	77	0	40	37
2015	12	30	17	22	15	0.627	-0.135	3.858	0.01	0.007	0	22.8	19.4	63.2	93	82	0	40	37
2015	12	30	17	32	15	0.62	-0.098	3.858	0.013	0.01	0	23.2	19.4	64.5	93	82	0	39	37
2015	12	30	17	42	15	0.607	-0.125	3.855	0.013	0.01	0	22.8	19.4	61.1	93	82	0	40	37
2015	12	30	17	52	15	0.551	-0.203	3.858	0.013	0.01	0	23.2	17.6	61.9	94	77	0	40	36
2015	12	30	18	2	15	0.682	-0.089	3.865	0.016	0.013	0	22.8	19.4	64.1	93	82	0	40	37
2015	12	30	18	12	15	0.63	-0.105	3.868	0.013	0.01	0	22.8	19.8	62.4	93	83	0	40	37
2015	12	30	18	22	15	0.663	-0.121	3.868	0.016	0.013	0	23.2	19.4	60.2	94	82	0	40	37
2015	12	30	18	32	15	0.656	-0.141	3.862	0.016	0.013	0	22.8	19.8	59.8	93	82	0	40	36
2015	12	30	18	42	15	0.653	-0.108	3.862	0.013	0.01	0	22.8	19.4	58.9	93	82	0	40	37
2015	12	30	18	52	15	0.505	-0.121	3.855	0.01	0.007	0	23.6	18.5	55	95	80	0	40	37
2015	12	30	19	2	15	0.518	-0.131	3.855	0.01	0.007	0	23.6	18.5	55.5	95	80	0	40	37
2015	12	30	19	12	15	0.538	-0.151	3.858	0.013	0.01	0	22.4	17.2	60.2	93	78	0	41	38
2015	12	30	19	22	15	0.666	-0.105	3.865	0.013	0.01	0	23.2	19.8	58.5	94	83	0	40	37
2015	12	30	19	32	15	0.656	-0.112	3.858	0.013	0.01	0	22.4	19.8	56.3	93	83	0	41	37
2015	12	30	19	42	15	0.643	-0.089	3.855	0.013	0.01	0	22.4	19.4	57.6	93	82	0	41	37
2015	12	30	19	52	15	0.577	-0.095	3.858	0.016	0.016	0	22.8	19.4	57.2	93	83	0	40	38
2015	12	30	20	2	15	0.636	-0.098	3.862	0.013	0.01	0	23.2	19.8	57.2	94	83	0	40	37
2015	12	30	20	12	15	0.571	-0.059	3.858	0.016	0.016	0	23.2	19.4	52	93	83	0	39	38
2015	12	30	20	22	15	0.486	-0.092	3.858	0.013	0.01	0	23.6	18.1	46.4	95	79	0	40	37
2015	12	30	20	32	15	0.594	-0.066	3.865	0.016	0.013	0	23.2	19.4	44.7	94	83	0	40	38
2015	12	30	20	42	15	0.666	-0.026	3.865	0.016	0.013	0	23.2	19.8	51.2	94	83	0	40	37
2015	12	30	20	52	15	0.62	-0.062	3.858	0.016	0.013	0	22.8	19.8	51.2	93	83	0	40	37
2015	12	30	21	2	15	0.659	-0.089	3.865	0.016	0.016	0	23.2	19.8	55.9	94	83	0	40	37
2015	12	30	21	12	15	0.659	-0.089	3.865	0.013	0.01	0	22.8	19.4	54.6	93	82	0	40	37
2015	12	30	21	22	15	0.732	-0.112	3.865	0.01	0.007	0	22.8	19.4	58.9	93	82	0	40	37
2015	12	30	21	32	15	0.682	-0.108	3.858	0.016	0.013	0	23.2	18.9	59.3	93	82	0	39	38
2015	12	30	21	42	15	0.689	-0.085	3.865	0.013	0.01	0	23.2	19.4	63.6	94	82	0	40	37
2015	12	30	21	52	15	0.663	-0.056	3.865	0.013	0.01	0	22.8	19.4	67.1	93	82	0	40	37
2015	12	30	22	2	15	0.617	-0.075	3.868	0.01	0.007	0	22.8	18.9	67.9	93	81	0	40	37
2015	12	30	22	12	15	0.702	-0.115	3.868	0.013	0.01	0	22.8	19.4	70.5	93	82	0	40	37
2015	12	30	22	22	15	0.666	-0.161	3.868	0.01	0.007	0	23.6	20.6	67.1	95	84	0	40	36
2015	12	30	22	32	15	0.407	-0.223	3.865	0.013	0.01	0	23.6	18.5	66.2	95	80	0	40	37
2015	12	30	22	42	15	0.702	-0.085	3.862	0.01	0.007	0	25.8	21.1	61.1	99	87	0	39	38
2015	12	30	22	52	15	0.669	-0.059	3.862	0.01	0.007	0	23.2	19.4	66.7	94	82	0	40	37
2015	12	30	23	2	15	0.669	-0.072	3.855	0.01	0.007	0	23.2	18.9	66.2	94	82	0	40	38
2015	12	30	23	12	15	0.676	-0.095	3.855	0.01	0.007	0	23.2	19.4	64.9	94	82	0	40	37
2015	12	30	23	22	15	0.6	-0.072	3.852	0.01	0.007	0	23.6	19.8	67.9	94	83	0	39	37
2015	12	30	23	32	15	0.682	-0.098	3.858	0.013	0.01	0	23.2	19.4	62.8	94	82	0	40	37
2015	12	30	23	42	15	0.692	-0.085	3.858	0.01	0.007	0	23.6	19.8	64.9	95	83	0	40	37
2015	12	30	23	52	15	0.607	-0.075	3.858	0.01	0.007	0	23.6	19.8	64.1	95	83	0	40	37
2015	12	31	0	2	15	0.676	-0.059	3.855	0.01	0.007	0	23.2	19.4	59.3	94	82	0	40	37
2015	12	31	0	12	15	0.676	-0.089	3.855	0.01	0.007	0	23.2	19.4	64.5	94	82	0	40	37
2015	12	31	0	22	15	0.669	-0.072	3.845	0.013	0.01	0	23.6	19.8	62.8	95	83	0	40	37
2015	12	31	0	32	15	0.679	-0.046	3.848	0.01	0.007	0	24.5	20.2	66.7	97	84	0	40	37
2015	12	31	0	42	15	0.653	-0.082	3.855	0.013	0.01	0	23.6	19.8	71.4	95	83	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	0	52	15	0.702	-0.095	3.852	0.01	0.007	0	24.1	20.2	66.2	96	84	0	40	37
2015	12	31	1	2	15	0.646	-0.049	3.858	0.01	0.007	0	23.2	18.9	64.1	94	81	0	40	37
2015	12	31	1	12	15	0.659	-0.069	3.862	0.013	0.01	0	23.6	19.4	61.1	95	82	0	40	37
2015	12	31	1	22	15	0.732	-0.105	3.862	0.013	0.01	0	23.2	18.5	61.5	94	81	0	40	38
2015	12	31	1	32	15	0.646	-0.072	3.858	0.013	0.01	0	22.8	18.9	64.1	93	81	0	40	37
2015	12	31	1	42	15	0.709	-0.092	3.852	0.01	0.007	0	23.6	19.4	67.9	95	82	0	40	37
2015	12	31	1	52	15	0.64	-0.098	3.858	0.01	0.007	0	23.6	19.4	68.8	95	82	0	40	37
2015	12	31	2	2	15	0.653	-0.075	3.852	0.01	0.007	0	23.6	19.8	70.5	95	83	0	40	37
2015	12	31	2	12	15	0.682	-0.059	3.855	0.01	0.007	0	23.2	18.9	68.8	94	81	0	40	37
2015	12	31	2	22	15	0.692	-0.095	3.852	0.013	0.01	0	23.6	19.8	67.9	95	83	0	40	37
2015	12	31	2	32	15	0.669	-0.069	3.855	0.013	0.01	0	23.6	19.4	69.7	94	82	0	39	37
2015	12	31	2	42	15	0.669	-0.085	3.845	0.013	0.01	0	23.6	18.9	70.1	95	82	0	40	38
2015	12	31	2	52	15	0.673	-0.102	3.845	0.013	0.01	0	23.6	19.8	71	95	83	0	40	37
2015	12	31	3	2	15	0.656	-0.098	3.842	0.01	0.007	0	23.6	19.4	73.5	95	83	0	40	38
2015	12	31	3	12	15	0.705	-0.095	3.845	0.01	0.007	0	24.1	19.4	74	96	83	0	40	38
2015	12	31	3	22	15	0.659	-0.085	3.852	0.01	0.007	0	23.6	19.8	73.5	95	83	0	40	37
2015	12	31	3	32	15	0.669	-0.082	3.858	0.013	0.01	0	23.2	19.4	74.8	94	82	0	40	37
2015	12	31	3	42	15	0.689	-0.092	3.855	0.01	0.007	0	23.6	19.4	73.1	95	82	0	40	37
2015	12	31	3	52	15	0.663	-0.112	3.848	0.01	0.007	0	24.1	19.8	72.2	95	82	0	39	36
2015	12	31	4	2	15	0.696	-0.082	3.852	0.01	0.007	0	23.6	19.8	69.2	95	83	0	40	37
2015	12	31	4	12	15	0.65	-0.069	3.852	0.013	0.01	0	23.6	19.8	66.7	95	83	0	40	37
2015	12	31	4	22	15	0.643	-0.092	3.858	0.01	0.007	0	23.6	19.4	64.9	94	82	0	39	37
2015	12	31	4	32	15	0.659	-0.089	3.858	0.013	0.01	0	23.2	18.9	67.1	94	81	0	40	37
2015	12	31	4	42	15	0.659	-0.062	3.858	0.01	0.007	0	23.2	19.8	68.8	94	82	0	40	36
2015	12	31	4	52	15	0.702	-0.089	3.858	0.013	0.01	0	23.2	19.4	69.2	94	82	0	40	37
2015	12	31	5	2	15	0.643	-0.095	3.855	0.01	0.007	0	23.2	19.8	65.4	94	82	0	40	36
2015	12	31	5	12	15	0.679	-0.102	3.855	0.01	0.007	0	23.2	19.4	65.4	94	81	0	40	36
2015	12	31	5	22	15	0.646	-0.135	3.858	0.01	0.007	0	22.8	18.5	67.9	93	81	0	40	38
2015	12	31	5	32	15	0.663	-0.118	3.855	0.01	0.007	0	23.2	19.4	61.9	94	82	0	40	37
2015	12	31	5	42	15	0.63	-0.108	3.852	0.013	0.01	0	23.2	19.4	58	94	82	0	40	37
2015	12	31	5	52	15	0.666	-0.095	3.858	0.016	0.013	0	23.2	18.5	55.5	93	81	0	39	38
2015	12	31	6	2	15	0.725	-0.118	3.845	0.01	0.007	0	22.8	18.5	50.3	93	81	0	40	38
2015	12	31	6	12	15	0.682	-0.102	3.858	0.013	0.01	0	23.2	19.4	47.3	94	81	0	40	36
2015	12	31	6	22	15	0.659	-0.075	3.852	0.01	0.007	0	23.2	18.9	52.5	94	82	0	40	38
2015	12	31	6	32	15	0.653	-0.092	3.855	0.01	0.007	0	23.2	18.5	47.3	94	81	0	40	38
2015	12	31	6	42	15	0.686	-0.072	3.845	0.016	0.013	0	23.2	19.4	47.7	94	82	0	40	37
2015	12	31	6	52	15	0.709	-0.082	3.839	0.013	0.01	0	23.6	19.4	49	94	82	0	39	37
2015	12	31	7	2	15	0.692	-0.098	3.835	0.01	0.007	0	23.2	19.4	52	94	82	0	40	37
2015	12	31	7	12	15	0.689	-0.092	3.842	0.01	0.007	0	23.6	19.8	54.2	95	83	0	40	37
2015	12	31	7	22	15	0.728	-0.085	3.839	0.013	0.01	0	25.4	21.5	51.2	99	87	0	40	37
2015	12	31	7	32	15	0.682	-0.075	3.842	0.013	0.01	0	26.2	21.9	57.6	101	88	0	40	37
2015	12	31	7	42	15	0.728	-0.089	3.839	0.01	0.007	0	25.8	21.1	55.5	100	87	0	40	38
2015	12	31	7	52	15	0.702	-0.089	3.839	0.01	0.007	0	26.2	21.9	60.6	101	88	0	40	37
2015	12	31	8	2	15	0.686	-0.095	3.832	0.013	0.01	0	26.7	22.4	63.6	102	89	0	40	37
2015	12	31	8	12	15	0.705	-0.085	3.835	0.016	0.013	0	27.5	23.2	60.2	104	91	0	40	37
2015	12	31	8	22	15	0.732	-0.108	3.832	0.016	0.013	0	25.8	21.9	58.9	100	87	0	40	36

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	8	32	15	0.659	-0.092	3.829	0.01	0.007	0	24.5	20.6	60.2	97	85	0	40	37
2015	12	31	8	42	15	0.699	-0.102	3.829	0.013	0.01	0	24.9	21.5	63.2	98	87	0	40	37
2015	12	31	8	52	15	0.722	-0.059	3.825	0.01	0.007	0	27.1	22.8	60.6	103	90	0	40	37
2015	12	31	9	2	15	0.705	-0.115	3.825	0.01	0.007	0	26.2	22.4	59.3	101	89	0	40	37
2015	12	31	9	12	15	0.728	-0.089	3.825	0.013	0.01	0	26.2	22.4	60.6	101	89	0	40	37
2015	12	31	9	22	15	0.673	-0.085	3.829	0.013	0.01	0	26.2	21.9	59.3	101	88	0	40	37
2015	12	31	9	32	15	0.666	-0.095	3.819	0.01	0.007	0	27.1	22.8	58.5	103	90	0	40	37
2015	12	31	9	42	15	0.699	-0.112	3.819	0.013	0.01	0	24.9	20.6	55.9	98	86	0	40	38
2015	12	31	9	52	15	0.696	-0.072	3.812	0.013	0.01	0	26.2	22.4	51.2	101	89	0	40	37
2015	12	31	10	2	15	0.696	-0.098	3.822	0.013	0.01	0	31	25.8	46.9	111	97	0	39	37
2015	12	31	10	12	15	0.725	-0.085	3.816	0.01	0.007	0	28.4	23.6	43.9	106	93	0	40	38
2015	12	31	10	22	15	0.732	-0.079	3.812	0.01	0.007	0	28.4	23.6	42.6	106	92	0	40	37
2015	12	31	10	32	15	0.735	-0.095	3.816	0.013	0.01	0	28	23.2	43.9	105	91	0	40	37
2015	12	31	10	42	15	0.722	-0.105	3.825	0.01	0.007	0	27.5	23.2	47.7	104	91	0	40	37
2015	12	31	10	52	15	0.712	-0.062	3.819	0.01	0.007	0	27.5	22.8	48.6	104	91	0	40	38
2015	12	31	11	2	15	0.682	-0.089	3.819	0.01	0.007	0	27.1	22.8	49.5	103	90	0	40	37
2015	12	31	11	12	15	0.669	-0.072	3.816	0.01	0.007	0	26.7	22.4	47.7	102	89	0	40	37
2015	12	31	11	22	15	0.699	-0.102	3.809	0.013	0.01	0	24.9	21.5	48.6	98	86	0	40	36
2015	12	31	11	32	15	0.636	-0.082	3.816	0.016	0.013	0	25.8	21.9	49.5	99	88	0	39	37
2015	12	31	11	42	15	0.676	-0.112	3.819	0.01	0.007	0	27.1	22.4	50.7	103	90	0	40	38
2015	12	31	11	52	15	0.686	-0.085	3.819	0.013	0.01	0	26.7	22.8	47.3	102	90	0	40	37
2015	12	31	12	2	15	0.725	-0.085	3.822	0.013	0.01	0	28.4	23.2	48.6	105	91	0	39	37
2015	12	31	12	12	15	0.696	-0.112	3.835	0.01	0.007	0	25.4	21.1	54.2	99	87	0	40	38
2015	12	31	12	22	15	0.692	-0.105	3.825	0.016	0.013	0	28	23.2	48.2	105	91	0	40	37
2015	12	31	12	32	15	0.699	-0.098	3.832	0.016	0.013	0	26.7	22.4	44.3	102	89	0	40	37
2015	12	31	12	42	15	0.705	-0.082	3.825	0.013	0.01	0	25.4	21.5	40	99	87	0	40	37
2015	12	31	12	52	15	0.686	-0.085	3.829	0.016	0.013	0	26.2	21.9	44.7	100	87	0	39	36
2015	12	31	13	2	15	0.709	-0.115	3.832	0.013	0.01	0	25.4	21.5	44.3	99	87	0	40	37
2015	12	31	13	12	15	0.732	-0.144	3.829	0.013	0.01	0	28.4	24.1	43.9	106	93	0	40	37
2015	12	31	13	22	15	0.696	-0.072	3.835	0.01	0.007	0	27.5	22.8	48.2	103	90	0	39	37
2015	12	31	13	32	15	0.696	-0.108	3.839	0.01	0.007	0	27.1	22.8	44.3	102	90	0	39	37
2015	12	31	13	42	15	0.673	-0.098	3.835	0.01	0.007	0	25.4	21.5	52.9	99	87	0	40	37
2015	12	31	13	52	15	0.725	-0.102	3.829	0.01	0.007	0	24.9	21.1	53.8	98	86	0	40	37
2015	12	31	14	2	15	0.719	-0.079	3.839	0.01	0.007	0	24.9	21.1	54.2	98	86	0	40	37
2015	12	31	14	12	15	0.686	-0.075	3.829	0.013	0.01	0	24.5	19.8	54.2	97	84	0	40	38
2015	12	31	14	22	15	0.682	-0.072	3.825	0.01	0.007	0	24.9	20.2	46	98	85	0	40	38
2015	12	31	14	32	15	0.709	-0.102	3.835	0.013	0.01	0	24.1	19.8	47.3	96	84	0	40	38
2015	12	31	14	42	15	0.65	-0.105	3.839	0.01	0.007	0	23.6	19.8	47.3	95	84	0	40	38
2015	12	31	14	52	15	0.696	-0.049	3.842	0.01	0.007	0	24.1	20.6	53.3	95	84	0	39	36
2015	12	31	15	2	15	0.722	-0.062	3.839	0.01	0.007	0	24.1	20.2	50.7	95	84	0	39	37
2015	12	31	15	12	15	0.712	-0.069	3.839	0.013	0.01	0	23.6	19.8	52.9	95	84	0	40	38
2015	12	31	15	22	15	0.705	-0.092	3.842	0.01	0.007	0	24.1	20.2	52.5	96	84	0	40	37
2015	12	31	15	32	15	0.686	-0.026	3.839	0.013	0.01	0	23.6	20.6	50.7	95	84	0	40	36
2015	12	31	15	42	15	0.669	-0.092	3.842	0.01	0.007	0	23.6	19.8	52.9	94	83	0	39	37
2015	12	31	15	52	15	0.699	-0.082	3.839	0.013	0.01	0	23.2	19.8	48.6	94	83	0	40	37
2015	12	31	16	2	15	0.666	-0.072	3.835	0.013	0.01	0	22.8	19.4	45.6	93	82	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	16	12	15	0.682	-0.072	3.852	0.016	0.013	0	23.2	19.4	42.1	94	82	0	40	37
2015	12	31	16	22	15	0.663	-0.108	3.862	0.01	0.007	0	22.8	18.9	45.6	93	82	0	40	38
2015	12	31	16	32	15	0.656	-0.098	3.858	0.01	0.007	0	22.8	19.4	42.1	93	82	0	40	37
2015	12	31	16	42	15	0.682	-0.036	3.848	0.01	0.007	0	22.8	18.9	43	93	82	0	40	38
2015	12	31	16	52	15	0.669	-0.079	3.855	0.013	0.01	0	22.4	18.9	45.2	92	81	0	40	37
2015	12	31	17	2	15	0.65	-0.085	3.852	0.01	0.007	0	22.8	19.4	48.6	93	82	0	40	37
2015	12	31	17	12	15	0.666	-0.072	3.852	0.01	0.007	0	22.8	19.4	45.2	93	82	0	40	37
2015	12	31	17	22	15	0.659	-0.062	3.848	0.01	0.007	0	23.2	19.4	42.6	94	82	0	40	37
2015	12	31	17	32	15	0.722	-0.072	3.845	0.016	0.013	0	23.6	19.8	43.9	94	83	0	39	37
2015	12	31	17	42	15	0.696	-0.121	3.852	0.01	0.007	0	23.2	20.2	45.2	94	83	0	40	36
2015	12	31	17	52	15	0.663	-0.075	3.842	0.01	0.007	0	23.2	19.4	46	94	82	0	40	37
2015	12	31	18	2	15	0.646	-0.108	3.845	0.01	0.007	0	23.2	19.8	45.2	94	83	0	40	37
2015	12	31	18	12	15	0.682	-0.043	3.855	0.013	0.01	0	23.6	19.8	45.6	95	83	0	40	37
2015	12	31	18	22	15	0.673	-0.092	3.842	0.01	0.007	0	22.4	19.8	46	94	83	0	42	37
2015	12	31	18	32	15	0.699	-0.112	3.842	0.01	0.007	0	23.6	19.8	50.3	96	84	0	41	38
2015	12	31	18	42	15	0.722	-0.115	3.839	0.013	0.01	0	23.2	19.8	50.7	95	83	0	41	37
2015	12	31	18	52	15	0.719	-0.095	3.839	0.01	0.007	0	22.8	19.4	54.6	94	83	0	41	38
2015	12	31	19	2	15	0.656	-0.085	3.848	0.01	0.007	0	23.2	19.8	54.2	95	83	0	41	37
2015	12	31	19	12	15	0.673	-0.098	3.835	0.013	0.01	0	23.6	19.4	56.8	95	82	0	40	37
2015	12	31	19	22	15	0.705	-0.125	3.845	0.01	0.007	0	23.2	19.8	61.9	94	83	0	40	37
2015	12	31	19	32	15	0.715	-0.115	3.842	0.016	0.016	0	24.1	20.2	65.4	96	84	0	40	37
2015	12	31	19	42	15	0.696	-0.085	3.835	0.01	0.007	0	24.1	20.2	64.1	95	84	0	39	37
2015	12	31	19	52	15	0.689	-0.075	3.842	0.013	0.01	0	25.4	21.1	64.9	99	86	0	40	37
2015	12	31	20	2	15	0.699	-0.102	3.839	0.013	0.01	0	23.6	19.4	65.8	95	83	0	40	38
2015	12	31	20	12	15	0.732	-0.085	3.835	0.01	0.007	0	23.6	19.4	64.5	95	83	0	40	38
2015	12	31	20	22	15	0.673	-0.105	3.839	0.016	0.013	0	23.6	19.8	62.4	95	83	0	40	37
2015	12	31	20	32	15	0.666	-0.062	3.839	0.01	0.007	0	23.6	19.8	62.8	95	83	0	40	37
2015	12	31	20	42	15	0.699	-0.066	3.842	0.013	0.01	0	24.1	19.4	62.8	95	82	0	39	37
2015	12	31	20	52	15	0.679	-0.125	3.839	0.01	0.007	0	23.6	19.8	62.4	95	83	0	40	37
2015	12	31	21	2	15	0.679	-0.082	3.842	0.016	0.013	0	23.6	19.4	61.9	95	83	0	40	38
2015	12	31	21	12	15	0.679	-0.108	3.858	0.01	0.007	0	23.2	18.9	57.2	94	82	0	40	38
2015	12	31	21	22	15	0.663	-0.112	3.858	0.01	0.007	0	23.2	18.9	57.6	94	81	0	40	37
2015	12	31	21	32	15	0.692	-0.089	3.842	0.01	0.007	0	23.6	18.9	52.5	94	82	0	39	38
2015	12	31	21	42	15	0.702	-0.098	3.848	0.013	0.01	0	23.6	19.4	54.2	95	82	0	40	37
2015	12	31	21	52	15	0.659	-0.115	3.848	0.01	0.007	0	23.6	19.4	57.2	94	82	0	39	37
2015	12	31	22	2	15	0.715	-0.089	3.848	0.01	0.007	0	23.6	19.4	58.9	95	82	0	40	37
2015	12	31	22	12	15	0.682	-0.098	3.839	0.01	0.007	0	23.2	19.4	51.6	94	82	0	40	37
2015	12	31	22	22	15	0.709	-0.121	3.839	0.01	0.007	0	23.6	18.9	54.6	94	82	0	39	38
2015	12	31	22	32	15	0.702	-0.115	3.842	0.013	0.01	0	23.2	19.4	58.9	94	82	0	40	37
2015	12	31	22	42	15	0.653	-0.118	3.842	0.01	0.007	0	23.6	19.8	58.9	95	83	0	40	37
2015	12	31	22	52	15	0.663	-0.174	3.839	0.013	0.01	0	22.8	19.4	55.5	93	82	0	40	37
2015	12	31	23	2	15	0.686	-0.095	3.839	0.01	0.007	0	22.4	19.4	58.5	92	82	0	40	37
2015	12	31	23	12	15	0.663	-0.135	3.835	0.016	0.013	0	22.8	19.8	60.6	93	82	0	40	36
2015	12	31	23	22	15	0.692	-0.121	3.835	0.01	0.007	0	22.4	19.8	59.3	92	83	0	40	37
2015	12	31	23	32	15	0.673	-0.112	3.839	0.013	0.01	0	22.4	19.8	57.2	92	82	0	40	36
2015	12	31	23	42	15	0.715	-0.118	3.835	0.013	0.01	0	22.4	18.9	61.1	92	82	0	40	38

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	12	31	23	52	15	0.689	-0.092	3.835	0.016	0.013	0	23.2	19.8	61.1	94	83	0	40	37

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	0	5	33	37	0	0	0	0	0	0	0	33.44	0	0	11.8
2015	12	1	0	15	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	1	0	25	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	1	0	35	33	37	0	0	0	0	0	0	0	33.4	0	0	11.8
2015	12	1	0	45	33	37	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	1	0	55	33	38	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	1	1	5	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	1	1	15	33	38	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	1	1	25	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	1	1	35	33	37	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	1	1	45	33	37	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	1	1	55	33	38	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	1	2	5	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	1	2	15	33	38	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	1	2	25	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	1	2	35	33	37	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	1	2	45	33	38	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	1	2	55	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	1	3	5	33	37	0	0	0	0	0	0	0	33.12	0	0	11.6
2015	12	1	3	15	33	37	0	0	0	0	0	0	0	33.08	0	0	11.6
2015	12	1	3	25	33	37	0	0	0	0	0	0	0	33.06	0	0	11.6
2015	12	1	3	35	33	37	0	0	0	0	0	0	0	33.03	0	0	11.6
2015	12	1	3	45	33	38	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	1	3	55	33	38	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	1	4	5	33	37	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	1	4	15	33	37	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	1	4	25	33	37	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	1	4	35	33	37	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	1	4	45	33	37	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	1	4	55	33	38	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	1	5	5	33	37	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	1	5	15	33	37	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	1	5	25	33	38	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	1	5	35	33	37	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	1	5	45	33	38	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	1	5	55	33	37	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	1	6	5	33	38	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	1	6	15	33	38	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	1	6	25	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	1	6	35	33	37	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	1	6	45	33	37	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	1	6	55	33	38	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	1	7	5	33	38	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	1	7	15	33	37	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	1	7	25	33	38	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	1	7	35	33	38	0	0	0	0	0	0	0	32.41	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	7	45	33	38	0	0	0	0	0	0	0	32.43	0	0	12.4
2015	12	1	7	55	33	37	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	1	8	5	33	38	0	0	0	0	0	0	0	32.49	0	0	12.8
2015	12	1	8	15	33	38	0	0	0	0	0	0	0	32.5	0	0	12.8
2015	12	1	8	25	33	38	0	0	0	0	0	0	0	32.54	0	0	13
2015	12	1	8	35	33	38	0	0	0	0	0	0	0	32.58	0	0	13
2015	12	1	8	45	33	38	0	0	0	0	0	0	0	32.63	0	0	13
2015	12	1	8	55	33	38	0	0	0	0	0	0	0	32.67	0	0	13.2
2015	12	1	9	5	33	38	0	0	0	0	0	0	0	32.72	0	0	13.2
2015	12	1	9	15	33	38	0	0	0	0	0	0	0	32.77	0	0	13.2
2015	12	1	9	25	33	38	0	0	0	0	0	0	0	32.81	0	0	13.2
2015	12	1	9	35	33	38	0	0	0	0	0	0	0	32.85	0	0	13.2
2015	12	1	9	45	33	38	0	0	0	0	0	0	0	32.9	0	0	13.2
2015	12	1	9	55	33	37	0	0	0	0	0	0	0	32.97	0	0	13.4
2015	12	1	10	5	33	37	0	0	0	0	0	0	0	33.01	0	0	13.4
2015	12	1	10	15	33	37	0	0	0	0	0	0	0	33.06	0	0	13.4
2015	12	1	10	25	33	37	0	0	0	0	0	0	0	33.08	0	0	13.4
2015	12	1	10	35	33	37	0	0	0	0	0	0	0	33.12	0	0	13.4
2015	12	1	10	45	33	38	0	0	0	0	0	0	0	33.17	0	0	13.4
2015	12	1	10	55	33	37	0	0	0	0	0	0	0	33.19	0	0	13.8
2015	12	1	11	5	33	38	0	0	0	0	0	0	0	33.24	0	0	13.8
2015	12	1	11	15	33	37	0	0	0	0	0	0	0	33.24	0	0	13.8
2015	12	1	11	25	33	37	0	0	0	0	0	0	0	33.28	0	0	13.8
2015	12	1	11	35	33	37	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	1	11	45	33	37	0	0	0	0	0	0	0	33.3	0	0	13.8
2015	12	1	11	55	33	37	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	1	12	5	33	37	0	0	0	0	0	0	0	33.37	0	0	13.8
2015	12	1	12	15	33	37	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	1	12	25	33	37	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	1	12	35	33	37	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	1	12	45	33	38	0	0	0	0	0	0	0	33.33	0	0	13.8
2015	12	1	12	55	33	37	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	1	13	5	33	38	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	1	13	15	33	38	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	1	13	25	33	38	0	0	0	0	0	0	0	33.4	0	0	13.6
2015	12	1	13	35	33	37	0	0	0	0	0	0	0	33.4	0	0	13.6
2015	12	1	13	45	33	37	0	0	0	0	0	0	0	33.4	0	0	13.6
2015	12	1	13	55	33	38	0	0	0	0	0	0	0	33.4	0	0	13.6
2015	12	1	14	5	33	38	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	1	14	15	33	37	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	1	14	25	33	38	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	1	14	35	33	37	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	1	14	45	33	37	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	1	14	55	33	38	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	1	15	5	33	37	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	1	15	15	33	37	0	0	0	0	0	0	0	33.3	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	15	25	33	37	0	0	0	0	0	0	0	33.3	0	0	13.6
2015	12	1	15	35	33	37	0	0	0	0	0	0	0	33.28	0	0	12.8
2015	12	1	15	45	33	36	0	0	0	0	0	0	0	33.28	0	0	12.2
2015	12	1	15	55	33	37	0	0	0	0	0	0	0	33.28	0	0	12.2
2015	12	1	16	5	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	16	15	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	16	25	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	16	35	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	16	45	33	38	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	16	55	33	38	0	0	0	0	0	0	0	33.28	0	0	12
2015	12	1	17	5	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	17	15	33	38	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	17	25	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	17	35	33	38	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	17	45	33	37	0	0	0	0	0	0	0	33.3	0	0	12
2015	12	1	17	55	33	37	0	0	0	0	0	0	0	33.28	0	0	12
2015	12	1	18	5	33	37	0	0	0	0	0	0	0	33.28	0	0	12
2015	12	1	18	15	33	37	0	0	0	0	0	0	0	33.28	0	0	12
2015	12	1	18	25	33	37	0	0	0	0	0	0	0	33.26	0	0	12
2015	12	1	18	35	33	38	0	0	0	0	0	0	0	33.26	0	0	12
2015	12	1	18	45	33	38	0	0	0	0	0	0	0	33.26	0	0	12
2015	12	1	18	55	33	37	0	0	0	0	0	0	0	33.24	0	0	12
2015	12	1	19	5	33	38	0	0	0	0	0	0	0	33.22	0	0	12
2015	12	1	19	15	33	38	0	0	0	0	0	0	0	33.22	0	0	12
2015	12	1	19	25	33	38	0	0	0	0	0	0	0	33.21	0	0	12
2015	12	1	19	35	33	37	0	0	0	0	0	0	0	33.19	0	0	12
2015	12	1	19	45	33	37	0	0	0	0	0	0	0	33.19	0	0	12
2015	12	1	19	55	33	37	0	0	0	0	0	0	0	33.17	0	0	12
2015	12	1	20	5	33	37	0	0	0	0	0	0	0	33.15	0	0	12
2015	12	1	20	15	33	37	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	1	20	25	33	37	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	1	20	35	33	37	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	1	20	45	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	1	20	55	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	1	21	5	33	38	6	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	1	21	15	33	38	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	1	21	25	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	1	21	35	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	1	21	45	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	1	21	55	33	38	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	1	22	5	33	37	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	1	22	15	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	1	22	25	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	1	22	35	33	37	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	1	22	45	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	1	22	55	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	1	23	5	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	1	23	15	33	37	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	1	23	25	33	38	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	1	23	35	33	37	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	1	23	45	33	36	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	1	23	55	33	38	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	2	0	5	33	38	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	2	0	15	33	37	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	2	0	25	33	38	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	2	0	35	33	38	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	2	0	45	33	37	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	2	0	55	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	2	1	5	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	2	1	15	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	2	1	25	33	38	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	2	1	35	33	37	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	2	1	45	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	2	1	55	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	2	2	5	33	37	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	2	2	15	33	37	8	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	2	2	25	33	37	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	2	2	35	33	37	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	2	2	45	33	38	0	0	0	0	0	0	0	32.76	0	0	11.8
2015	12	2	2	55	33	38	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	2	3	5	33	37	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	2	3	15	33	37	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	2	3	25	33	37	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	2	3	35	33	38	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	2	3	45	33	37	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	2	3	55	33	38	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	2	4	5	33	38	0	0	0	0	0	0	0	32.63	0	0	11.6
2015	12	2	4	15	33	37	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	2	4	25	33	38	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	2	4	35	33	38	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	2	4	45	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	2	4	55	33	37	0	0	0	0	0	0	0	32.54	0	0	11.6
2015	12	2	5	5	33	37	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	2	5	15	33	37	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	2	5	25	33	37	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	2	5	35	33	37	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	2	5	45	33	38	2	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	2	5	55	33	38	0	0	0	0	0	0	0	32.43	0	0	11.6
2015	12	2	6	5	33	38	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	2	6	15	33	37	0	0	0	0	0	0	0	32.4	0	0	11.6
2015	12	2	6	25	33	38	0	0	0	0	0	0	0	32.38	0	0	11.6
2015	12	2	6	35	33	38	0	0	0	0	0	0	0	32.36	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	6	45	33	38	0	0	0	0	0	0	0	32.32	0	0	11.6
2015	12	2	6	55	33	37	0	0	0	0	0	0	0	32.32	0	0	11.6
2015	12	2	7	5	33	37	0	0	0	0	0	0	0	32.31	0	0	11.6
2015	12	2	7	15	33	37	0	0	0	0	0	0	0	32.31	0	0	11.6
2015	12	2	7	25	33	37	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	2	7	35	33	37	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	2	7	45	33	38	0	0	0	0	0	0	0	32.32	0	0	12.4
2015	12	2	7	55	33	37	0	0	0	0	0	0	0	32.34	0	0	12.6
2015	12	2	8	5	33	37	0	0	0	0	0	0	0	32.4	0	0	12.6
2015	12	2	8	15	33	37	0	0	0	0	0	0	0	32.45	0	0	12.8
2015	12	2	8	25	33	38	0	0	0	0	0	0	0	32.5	0	0	12.8
2015	12	2	8	35	33	37	0	0	0	0	0	0	0	32.56	0	0	13
2015	12	2	8	45	33	37	0	0	0	0	0	0	0	32.59	0	0	13
2015	12	2	8	55	33	37	0	0	0	0	0	0	0	32.67	0	0	13
2015	12	2	9	5	33	37	0	0	0	0	0	0	0	32.72	0	0	13
2015	12	2	9	15	33	38	0	0	0	0	0	0	0	32.77	0	0	13
2015	12	2	9	25	33	38	0	0	0	0	0	0	0	32.83	0	0	13
2015	12	2	9	35	33	37	0	0	0	0	0	0	0	32.9	0	0	13
2015	12	2	9	45	33	37	0	0	0	0	0	0	0	32.95	0	0	13
2015	12	2	9	55	33	38	0	0	0	0	0	0	0	33.01	0	0	13.2
2015	12	2	10	5	33	38	0	0	0	0	0	0	0	33.06	0	0	13.2
2015	12	2	10	15	33	37	0	0	0	0	0	0	0	33.12	0	0	13
2015	12	2	10	25	33	38	0	0	0	0	0	0	0	33.06	0	0	13
2015	12	2	10	35	33	38	0	0	0	0	0	0	0	33.12	0	0	13.2
2015	12	2	10	45	33	37	0	0	0	0	0	0	0	33.15	0	0	13
2015	12	2	10	55	33	38	0	0	0	0	0	0	0	33.22	0	0	13.2
2015	12	2	11	5	33	37	0	0	0	0	0	0	0	33.3	0	0	13.2
2015	12	2	11	15	33	38	0	0	0	0	0	0	0	33.22	0	0	13.4
2015	12	2	11	25	33	38	0	0	0	0	0	0	0	33.3	0	0	13.2
2015	12	2	11	35	33	38	0	0	0	0	0	0	0	33.3	0	0	13.2
2015	12	2	11	45	33	37	0	0	0	0	0	0	0	33.31	0	0	13.8
2015	12	2	11	55	33	37	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	2	12	5	33	38	0	0	0	0	0	0	0	33.39	0	0	13.8
2015	12	2	12	15	33	37	0	0	0	0	0	0	0	33.4	0	0	13.8
2015	12	2	12	25	33	38	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	2	12	35	33	38	0	0	0	0	0	0	0	33.4	0	0	13.6
2015	12	2	12	45	33	37	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	2	12	55	33	38	0	0	0	0	0	0	0	33.28	0	0	13.6
2015	12	2	13	5	33	37	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	2	13	15	33	37	0	0	0	0	0	0	0	33.35	0	0	13.6
2015	12	2	13	25	33	37	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	2	13	35	33	38	0	0	0	0	0	0	0	33.31	0	0	13.6
2015	12	2	13	45	33	37	0	0	0	0	0	0	0	33.3	0	0	13.6
2015	12	2	13	55	33	37	0	0	0	0	0	0	0	33.33	0	0	13.6
2015	12	2	14	5	33	38	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	2	14	15	33	37	0	0	0	0	0	0	0	33.35	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	14	25	33	37	0	0	0	0	0	0	0	33.37	0	0	13.6
2015	12	2	14	35	33	37	0	0	0	0	0	0	0	33.39	0	0	13.6
2015	12	2	14	45	33	37	0	0	0	0	0	0	0	33.39	0	0	12.6
2015	12	2	14	55	33	37	0	0	0	0	0	0	0	33.35	0	0	12.2
2015	12	2	15	5	33	38	0	0	0	0	0	0	0	33.35	0	0	12.4
2015	12	2	15	15	33	37	0	0	0	0	0	0	0	33.35	0	0	12.4
2015	12	2	15	25	33	37	0	0	0	0	0	0	0	33.37	0	0	13
2015	12	2	15	35	33	37	0	0	0	0	0	0	0	33.35	0	0	12.4
2015	12	2	15	45	33	38	0	0	0	0	0	0	0	33.35	0	0	12.2
2015	12	2	15	55	33	37	0	0	0	0	0	0	0	33.33	0	0	12.2
2015	12	2	16	5	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	16	15	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	16	25	33	38	0	0	0	0	0	0	0	33.33	0	0	12
2015	12	2	16	35	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	16	45	33	38	0	0	0	0	0	0	0	33.33	0	0	12
2015	12	2	16	55	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	17	5	33	38	0	0	0	0	0	0	0	33.33	0	0	12
2015	12	2	17	15	33	38	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	17	25	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	17	35	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	17	45	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	17	55	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	18	5	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	18	15	33	37	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	18	25	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	18	35	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	18	45	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	18	55	33	38	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	19	5	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	19	15	33	37	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	2	19	25	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	19	35	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	19	45	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	19	55	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	20	5	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	20	15	33	37	0	0	0	0	0	0	0	33.35	0	0	12
2015	12	2	20	25	33	36	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	2	20	35	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	2	20	45	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	2	20	55	33	38	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	2	21	5	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	2	21	15	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	2	21	25	33	38	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	2	21	35	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	2	21	45	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	2	21	55	33	38	0	0	0	0	0	0	0	33.3	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	2	22	5	33	37	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	2	22	15	33	37	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	2	22	25	33	37	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	2	22	35	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	2	22	45	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	2	22	55	33	38	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	2	23	5	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	2	23	15	33	38	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	2	23	25	33	38	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	2	23	35	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	2	23	45	33	38	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	2	23	55	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	3	0	5	33	38	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	3	0	15	33	37	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	3	0	25	33	37	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	3	0	35	33	38	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	3	0	45	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	3	0	55	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	3	1	5	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	3	1	15	33	38	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	3	1	25	33	37	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	3	1	35	33	37	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	3	1	45	33	37	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	3	1	55	33	38	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	3	2	5	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	3	2	15	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	3	2	25	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	3	2	35	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	3	2	45	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	3	2	55	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	3	3	5	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	3	3	15	33	37	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	3	3	25	33	38	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	3	3	35	33	37	0	0	0	0	0	0	0	32.99	0	0	11.6
2015	12	3	3	45	33	38	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	3	3	55	33	37	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	3	4	5	33	37	0	0	0	0	0	0	0	32.94	0	0	11.6
2015	12	3	4	15	33	37	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	3	4	25	33	37	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	3	4	35	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	3	4	45	33	37	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	3	4	55	33	37	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	3	5	5	33	37	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	3	5	15	33	37	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	3	5	25	33	37	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	3	5	35	33	37	0	0	0	0	0	0	0	32.76	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	5	45	33	37	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	3	5	55	33	37	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	3	6	5	33	38	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	3	6	15	33	37	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	3	6	25	33	37	0	0	0	0	0	0	0	32.63	0	0	11.6
2015	12	3	6	35	33	38	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	3	6	45	33	38	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	3	6	55	33	37	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	3	7	5	33	38	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	3	7	15	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	3	7	25	33	37	0	0	0	0	0	0	0	32.54	0	0	11.8
2015	12	3	7	35	33	38	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	3	7	45	33	38	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	3	7	55	33	37	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	3	8	5	33	37	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	3	8	15	33	38	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	3	8	25	33	38	0	0	0	0	0	0	0	32.65	0	0	12.6
2015	12	3	8	35	33	37	0	0	0	0	0	0	0	32.72	0	0	12.8
2015	12	3	8	45	33	38	0	0	0	0	0	0	0	32.74	0	0	12.8
2015	12	3	8	55	33	38	0	0	0	0	0	0	0	32.67	0	0	12.4
2015	12	3	9	5	33	38	0	0	0	0	0	0	0	32.74	0	0	12.8
2015	12	3	9	15	33	37	0	0	0	0	0	0	0	32.83	0	0	13
2015	12	3	9	25	33	37	0	0	0	0	0	0	0	32.9	0	0	13
2015	12	3	9	35	33	38	0	0	0	0	0	0	0	32.97	0	0	13
2015	12	3	9	45	33	37	0	0	0	0	0	0	0	33.04	0	0	13.2
2015	12	3	9	55	33	38	0	0	0	0	0	0	0	33.06	0	0	13
2015	12	3	10	5	33	38	0	0	0	0	0	0	0	33.03	0	0	13
2015	12	3	10	15	33	37	0	0	0	0	0	0	0	33.1	0	0	13
2015	12	3	10	25	33	37	0	0	0	0	0	0	0	33.22	0	0	13
2015	12	3	10	35	33	37	0	0	0	0	0	0	0	33.15	0	0	13
2015	12	3	10	45	33	37	0	0	0	0	0	0	0	33.12	0	0	12.6
2015	12	3	10	55	33	38	0	0	0	0	0	0	0	32.99	0	0	12.6
2015	12	3	11	5	33	38	0	0	0	0	0	0	0	33.19	0	0	12.8
2015	12	3	11	15	33	38	0	0	0	0	0	0	0	33.15	0	0	12.6
2015	12	3	11	25	33	38	0	0	0	0	0	0	0	33.15	0	0	12.8
2015	12	3	11	35	33	38	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	3	11	45	33	37	0	0	0	0	0	0	0	33.26	0	0	12.8
2015	12	3	11	55	33	37	0	0	0	0	0	0	0	33.37	0	0	13
2015	12	3	12	5	33	37	0	0	0	0	0	0	0	33.44	0	0	13.4
2015	12	3	12	15	33	38	0	0	0	0	0	0	0	33.48	0	0	13.4
2015	12	3	12	25	33	37	0	0	0	0	0	0	0	33.49	0	0	13.6
2015	12	3	12	35	33	37	0	0	0	0	0	0	0	33.51	0	0	13.6
2015	12	3	12	45	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	12	55	33	38	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	13	5	33	37	0	0	0	0	0	0	0	33.51	0	0	12.8
2015	12	3	13	15	33	38	0	0	0	0	0	0	0	33.49	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	13	25	33	38	0	0	0	0	0	0	0	33.55	0	0	13.6
2015	12	3	13	35	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	13	45	33	37	0	0	0	0	0	0	0	33.49	0	0	13.6
2015	12	3	13	55	33	38	0	0	0	0	0	0	0	33.51	0	0	13.6
2015	12	3	14	5	33	38	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	14	15	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	14	25	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	14	35	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	14	45	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	14	55	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	3	15	5	33	37	0	0	0	0	0	0	0	33.51	0	0	12.4
2015	12	3	15	15	33	38	0	0	0	0	0	0	0	33.48	0	0	13.4
2015	12	3	15	25	33	37	0	0	0	0	0	0	0	33.48	0	0	12.2
2015	12	3	15	35	33	37	0	0	0	0	0	0	0	33.48	0	0	12.2
2015	12	3	15	45	33	38	0	0	0	0	0	0	0	33.48	0	0	12.2
2015	12	3	15	55	33	37	0	0	0	0	0	0	0	33.48	0	0	12
2015	12	3	16	5	33	38	0	0	0	0	0	0	0	33.49	0	0	12
2015	12	3	16	15	33	37	0	0	0	0	0	0	0	33.49	0	0	12
2015	12	3	16	25	33	36	0	0	0	0	0	0	0	33.49	0	0	12
2015	12	3	16	35	33	37	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	3	16	45	33	37	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	3	16	55	33	38	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	3	17	5	33	37	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	3	17	15	33	38	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	3	17	25	33	37	0	0	0	0	0	0	0	33.57	0	0	12
2015	12	3	17	35	33	37	0	0	0	0	0	0	0	33.58	0	0	12
2015	12	3	17	45	33	37	0	0	0	0	0	0	0	33.58	0	0	12
2015	12	3	17	55	33	37	0	0	0	0	0	0	0	33.58	0	0	12
2015	12	3	18	5	33	38	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	3	18	15	33	37	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	3	18	25	33	38	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	3	18	35	33	37	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	3	18	45	33	38	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	3	18	55	33	37	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	3	19	5	33	37	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	3	19	15	33	37	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	3	19	25	33	37	0	0	0	0	0	0	0	33.66	0	0	12
2015	12	3	19	35	33	37	0	0	0	0	0	0	0	33.67	0	0	12
2015	12	3	19	45	33	37	0	0	0	0	0	0	0	33.67	0	0	12
2015	12	3	19	55	33	37	0	0	0	0	0	0	0	33.67	0	0	12
2015	12	3	20	5	33	38	0	0	0	0	0	0	0	33.69	0	0	12
2015	12	3	20	15	33	37	0	0	0	0	0	0	0	33.69	0	0	12
2015	12	3	20	25	33	37	0	0	0	0	0	0	0	33.71	0	0	12
2015	12	3	20	35	33	37	0	0	0	0	0	0	0	33.71	0	0	12
2015	12	3	20	45	33	37	0	0	0	0	0	0	0	33.73	0	0	12
2015	12	3	20	55	33	38	0	0	0	0	0	0	0	33.76	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	3	21	5	33	37	0	0	0	0	0	0	0	33.76	0	0	12
2015	12	3	21	15	33	38	0	0	0	0	0	0	0	33.78	0	0	12
2015	12	3	21	25	33	38	0	0	0	0	0	0	0	33.8	0	0	12
2015	12	3	21	35	33	37	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	3	21	45	33	37	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	3	21	55	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	3	22	5	33	37	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	3	22	15	33	38	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	3	22	25	33	37	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	3	22	35	33	37	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	3	22	45	33	38	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	3	22	55	33	37	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	3	23	5	33	37	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	3	23	15	33	38	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	3	23	25	33	37	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	3	23	35	33	37	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	3	23	45	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	3	23	55	33	37	0	0	0	0	0	0	0	34.11	0	0	11.8
2015	12	4	0	5	33	38	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	4	0	15	33	37	0	0	0	0	0	0	0	34.14	0	0	11.8
2015	12	4	0	25	33	38	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	4	0	35	33	37	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	4	0	45	33	37	0	0	0	0	0	0	0	34.2	0	0	11.8
2015	12	4	0	55	33	38	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	4	1	5	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	4	1	15	33	37	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	4	1	25	33	38	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	4	1	35	33	38	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	4	1	45	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	4	1	55	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	4	2	5	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	2	15	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	2	25	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	2	35	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	2	45	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	2	55	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	3	5	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	3	15	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	3	25	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	3	35	33	38	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	4	3	45	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	4	3	55	33	37	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	4	4	5	33	38	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	4	4	15	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	4	4	25	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	4	4	35	33	38	0	0	0	0	0	0	0	34.2	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	4	45	33	37	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	4	4	55	33	37	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	4	5	5	33	37	0	0	0	0	0	0	0	34.14	0	0	11.8
2015	12	4	5	15	33	38	0	0	0	0	0	0	0	34.14	0	0	11.6
2015	12	4	5	25	33	38	0	0	0	0	0	0	0	34.12	0	0	11.6
2015	12	4	5	35	33	36	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	4	5	45	33	37	0	0	0	0	0	0	0	34.09	0	0	11.6
2015	12	4	5	55	33	37	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	4	6	5	33	38	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	4	6	15	33	36	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	4	6	25	33	37	0	0	0	0	0	0	0	34.03	0	0	11.6
2015	12	4	6	35	33	37	0	0	0	0	0	0	0	34.02	0	0	11.6
2015	12	4	6	45	33	37	0	0	0	0	0	0	0	34	0	0	11.6
2015	12	4	6	55	33	37	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	4	7	5	33	37	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	4	7	15	33	38	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	4	7	25	33	37	0	0	0	0	0	0	0	33.93	0	0	11.8
2015	12	4	7	35	33	38	0	0	0	0	0	0	0	33.94	0	0	12
2015	12	4	7	45	33	37	0	0	0	0	0	0	0	33.96	0	0	12.2
2015	12	4	7	55	33	37	0	0	0	0	0	0	0	33.98	0	0	12.4
2015	12	4	8	5	33	37	0	0	0	0	0	0	0	34.02	0	0	12.4
2015	12	4	8	15	33	38	0	0	0	0	0	0	0	34.03	0	0	12.6
2015	12	4	8	25	33	38	0	0	0	0	0	0	0	34.09	0	0	12.6
2015	12	4	8	35	33	37	0	0	0	0	0	0	0	34.12	0	0	12.6
2015	12	4	8	45	33	37	0	0	0	0	0	0	0	34.16	0	0	12.6
2015	12	4	8	55	33	37	0	0	0	0	0	0	0	34.23	0	0	12.8
2015	12	4	9	5	33	37	0	0	0	0	0	0	0	34.29	0	0	12.8
2015	12	4	9	15	33	37	0	0	0	0	0	0	0	34.34	0	0	12.8
2015	12	4	9	25	33	37	0	0	0	0	0	0	0	34.38	0	0	12.8
2015	12	4	9	35	33	37	0	0	0	0	0	0	0	34.41	0	0	12.8
2015	12	4	9	45	33	38	0	0	0	0	0	0	0	34.47	0	0	12.8
2015	12	4	9	55	33	37	2	0	0	0	0	0	0	34.52	0	0	12.8
2015	12	4	10	5	33	38	0	0	0	0	0	0	0	34.57	0	0	12.8
2015	12	4	10	15	33	37	0	0	0	0	0	0	0	34.63	0	0	12.8
2015	12	4	10	25	33	37	0	0	0	0	0	0	0	34.66	0	0	12.8
2015	12	4	10	35	33	38	0	0	0	0	0	0	0	34.7	0	0	12.8
2015	12	4	10	45	33	37	0	0	0	0	0	0	0	34.75	0	0	12.8
2015	12	4	10	55	33	37	0	0	0	0	0	0	0	34.77	0	0	13
2015	12	4	11	5	33	37	0	0	0	0	0	0	0	34.81	0	0	13
2015	12	4	11	15	33	37	0	0	0	0	0	0	0	34.84	0	0	13
2015	12	4	11	25	33	37	0	0	0	0	0	0	0	34.88	0	0	13.2
2015	12	4	11	35	33	37	0	0	0	0	0	0	0	34.9	0	0	13.6
2015	12	4	11	45	33	37	0	0	0	0	0	0	0	34.93	0	0	13.6
2015	12	4	11	55	33	37	0	0	0	0	0	0	0	34.92	0	0	13.6
2015	12	4	12	5	33	37	0	0	0	0	0	0	0	34.93	0	0	13.6
2015	12	4	12	15	33	37	0	0	0	0	0	0	0	34.93	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	12	25	33	38	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	12	35	33	37	0	0	0	0	0	0	0	34.97	0	0	13.6
2015	12	4	12	45	33	38	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	12	55	33	37	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	13	5	33	37	0	0	0	0	0	0	0	34.97	0	0	13.6
2015	12	4	13	15	33	37	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	13	25	33	37	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	13	35	33	37	0	0	0	0	0	0	0	34.95	0	0	13.6
2015	12	4	13	45	33	37	0	0	0	0	0	0	0	34.92	0	0	13.6
2015	12	4	13	55	33	38	0	0	0	0	0	0	0	34.92	0	0	13.6
2015	12	4	14	5	33	38	0	0	0	0	0	0	0	34.93	0	0	13.6
2015	12	4	14	15	33	37	0	0	0	0	0	0	0	34.93	0	0	13.4
2015	12	4	14	25	33	37	0	0	0	0	0	0	0	34.92	0	0	13.4
2015	12	4	14	35	33	37	0	0	0	0	0	0	0	34.9	0	0	13.4
2015	12	4	14	45	33	37	0	0	0	0	0	0	0	34.86	0	0	13.4
2015	12	4	14	55	33	37	0	0	0	0	0	0	0	34.86	0	0	13.4
2015	12	4	15	5	33	37	0	0	0	0	0	0	0	34.84	0	0	13.4
2015	12	4	15	15	33	37	0	0	0	0	0	0	0	34.83	0	0	13.4
2015	12	4	15	25	33	38	0	0	0	0	0	0	0	34.79	0	0	13.4
2015	12	4	15	35	33	37	0	0	0	0	0	0	0	34.79	0	0	12.6
2015	12	4	15	45	33	38	0	0	0	0	0	0	0	34.79	0	0	12.2
2015	12	4	15	55	33	37	0	0	0	0	0	0	0	34.77	0	0	12.2
2015	12	4	16	5	33	37	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	4	16	15	33	37	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	4	16	25	33	37	0	0	0	0	0	0	0	34.77	0	0	12
2015	12	4	16	35	33	37	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	4	16	45	33	37	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	4	16	55	33	37	0	0	0	0	0	0	0	34.75	0	0	12
2015	12	4	17	5	33	37	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	4	17	15	33	38	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	4	17	25	33	37	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	4	17	35	33	37	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	4	17	45	33	37	0	0	0	0	0	0	0	34.74	0	0	12
2015	12	4	17	55	33	36	0	0	0	0	0	0	0	34.72	0	0	12
2015	12	4	18	5	33	37	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	4	18	15	33	37	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	4	18	25	33	36	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	4	18	35	33	37	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	4	18	45	33	37	0	0	0	0	0	0	0	34.65	0	0	12
2015	12	4	18	55	33	37	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	4	19	5	33	37	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	4	19	15	33	37	0	0	0	0	0	0	0	34.61	0	0	12
2015	12	4	19	25	33	37	0	0	0	0	0	0	0	34.59	0	0	12
2015	12	4	19	35	33	38	0	0	0	0	0	0	0	34.57	0	0	12
2015	12	4	19	45	33	38	0	0	0	0	0	0	0	34.56	0	0	12
2015	12	4	19	55	33	37	0	0	0	0	0	0	0	34.54	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	4	20	5	33	37	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	4	20	15	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	4	20	25	33	38	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	4	20	35	33	37	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	4	20	45	33	37	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	4	20	55	33	37	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	4	21	5	33	37	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	4	21	15	33	37	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	4	21	25	33	37	0	0	0	0	0	0	0	34.43	0	0	11.8
2015	12	4	21	35	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	4	21	45	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	4	21	55	33	37	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	4	22	5	33	38	12	0	0	0	0	0	0	34.38	0	0	11.8
2015	12	4	22	15	33	37	0	0	0	0	0	0	0	34.38	0	0	11.8
2015	12	4	22	25	33	38	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	4	22	35	33	38	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	4	22	45	33	38	0	0	0	0	0	0	0	34.34	0	0	11.8
2015	12	4	22	55	33	37	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	4	23	5	33	37	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	4	23	15	33	38	0	0	0	0	0	0	0	34.3	0	0	11.8
2015	12	4	23	25	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	23	35	33	36	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	4	23	45	33	37	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	4	23	55	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	5	0	5	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	5	0	15	33	38	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	5	0	25	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	5	0	35	33	37	0	0	0	0	0	0	0	34.2	0	0	11.8
2015	12	5	0	45	33	38	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	5	0	55	33	36	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	5	1	5	33	38	0	0	0	0	0	0	0	34.14	0	0	11.8
2015	12	5	1	15	33	37	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	5	1	25	33	38	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	5	1	35	33	38	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	5	1	45	33	37	0	0	0	0	0	0	0	34.11	0	0	11.8
2015	12	5	1	55	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	2	5	33	38	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	5	2	15	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	2	25	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	2	35	33	39	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	5	2	45	33	36	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	5	2	55	33	37	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	5	3	5	33	38	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	5	3	15	33	38	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	5	3	25	33	37	0	0	0	0	0	0	0	33.91	0	0	11.6
2015	12	5	3	35	33	38	0	0	0	0	0	0	0	33.91	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	3	45	33	37	0	0	0	0	0	0	0	33.89	0	0	11.6
2015	12	5	3	55	33	38	0	0	0	0	0	0	0	33.85	0	0	11.6
2015	12	5	4	5	33	37	0	0	0	0	0	0	0	33.84	0	0	11.6
2015	12	5	4	15	33	36	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	5	4	25	33	37	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	5	4	35	33	38	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	5	4	45	33	37	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	5	4	55	33	38	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	5	5	5	33	37	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	5	5	15	33	37	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	5	5	25	33	38	0	0	0	0	0	0	0	33.62	0	0	11.6
2015	12	5	5	35	33	37	0	0	0	0	0	0	0	33.58	0	0	11.6
2015	12	5	5	45	33	37	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	5	5	55	33	38	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	5	6	5	33	37	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	5	6	15	33	37	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	5	6	25	33	37	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	5	6	35	33	37	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	5	6	45	33	36	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	5	6	55	33	38	0	0	0	0	0	0	0	33.39	0	0	11.6
2015	12	5	7	5	33	37	0	0	0	0	0	0	0	33.37	0	0	11.6
2015	12	5	7	15	33	37	0	0	0	0	0	0	0	33.33	0	0	11.6
2015	12	5	7	25	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	5	7	35	33	38	0	0	0	0	0	0	0	33.33	0	0	12
2015	12	5	7	45	33	37	0	0	0	0	0	0	0	33.33	0	0	12.2
2015	12	5	7	55	33	38	0	0	0	0	0	0	0	33.35	0	0	12.4
2015	12	5	8	5	33	37	0	0	0	0	0	0	0	33.35	0	0	12.4
2015	12	5	8	15	33	38	0	0	0	0	0	0	0	33.39	0	0	12.6
2015	12	5	8	25	33	37	0	0	0	0	0	0	0	33.44	0	0	12.8
2015	12	5	8	35	33	37	0	0	0	0	0	0	0	33.46	0	0	12.8
2015	12	5	8	45	33	37	0	0	0	0	0	0	0	33.51	0	0	13
2015	12	5	8	55	33	38	0	0	0	0	0	0	0	33.53	0	0	12.8
2015	12	5	9	5	33	37	0	0	0	0	0	0	0	33.58	0	0	13
2015	12	5	9	15	33	38	0	0	0	0	0	0	0	33.67	0	0	13.2
2015	12	5	9	25	33	38	0	0	0	0	0	0	0	33.71	0	0	12.8
2015	12	5	9	35	33	37	0	0	0	0	0	0	0	33.71	0	0	13
2015	12	5	9	45	33	37	0	0	0	0	0	0	0	33.69	0	0	12.8
2015	12	5	9	55	33	38	0	0	0	0	0	0	0	33.78	0	0	13.4
2015	12	5	10	5	33	37	0	0	0	0	0	0	0	33.87	0	0	13.2
2015	12	5	10	15	33	37	0	0	0	0	0	0	0	33.93	0	0	13.2
2015	12	5	10	25	33	38	0	0	0	0	0	0	0	33.93	0	0	12.8
2015	12	5	10	35	33	38	0	0	0	0	0	0	0	33.91	0	0	13.2
2015	12	5	10	45	33	37	0	0	0	0	0	0	0	33.98	0	0	13.2
2015	12	5	10	55	33	37	0	0	0	0	0	0	0	34	0	0	12.8
2015	12	5	11	5	33	37	0	0	0	0	0	0	0	33.82	0	0	12.6
2015	12	5	11	15	33	38	0	0	0	0	0	0	0	33.87	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	11	25	33	37	0	0	0	0	0	0	0	34.02	0	0	13.6
2015	12	5	11	35	33	38	0	0	0	0	0	0	0	33.98	0	0	12.8
2015	12	5	11	45	33	37	0	0	0	0	0	0	0	34.02	0	0	13
2015	12	5	11	55	33	37	0	0	0	0	0	0	0	34.16	0	0	13.2
2015	12	5	12	5	33	38	0	0	0	0	0	0	0	34.18	0	0	13
2015	12	5	12	15	33	37	0	0	0	0	0	0	0	34.21	0	0	13.4
2015	12	5	12	25	33	38	0	0	0	0	0	0	0	34.3	0	0	13.6
2015	12	5	12	35	33	37	0	0	0	0	0	0	0	34.32	0	0	13.6
2015	12	5	12	45	33	37	0	0	0	0	0	0	0	34.23	0	0	13
2015	12	5	12	55	33	38	0	0	0	0	0	0	0	34.18	0	0	12.6
2015	12	5	13	5	33	37	0	0	0	0	0	0	0	34.16	0	0	12.6
2015	12	5	13	15	33	37	0	0	0	0	0	0	0	34.18	0	0	13.4
2015	12	5	13	25	33	37	0	0	0	0	0	0	0	34.23	0	0	13.6
2015	12	5	13	35	33	38	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	13	45	33	38	0	0	0	0	0	0	0	34.29	0	0	13.6
2015	12	5	13	55	33	37	0	0	0	0	0	0	0	34.29	0	0	13.6
2015	12	5	14	5	33	38	0	0	0	0	0	0	0	34.3	0	0	13.6
2015	12	5	14	15	33	38	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	14	25	33	37	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	14	35	33	38	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	14	45	33	37	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	14	55	33	37	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	15	5	33	38	0	0	0	0	0	0	0	34.27	0	0	13.6
2015	12	5	15	15	33	37	0	0	0	0	0	0	0	34.25	0	0	13.6
2015	12	5	15	25	33	37	0	0	0	0	0	0	0	34.21	0	0	13.2
2015	12	5	15	35	33	37	0	0	0	0	0	0	0	34.21	0	0	12.2
2015	12	5	15	45	33	38	0	0	0	0	0	0	0	34.21	0	0	12.2
2015	12	5	15	55	33	38	0	0	0	0	0	0	0	34.2	0	0	12.2
2015	12	5	16	5	33	37	0	0	0	0	0	0	0	34.2	0	0	12.2
2015	12	5	16	15	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	16	25	33	38	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	16	35	33	38	0	0	0	0	0	0	0	34.2	0	0	12
2015	12	5	16	45	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	16	55	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	17	5	33	38	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	17	15	33	38	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	17	25	33	37	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	17	35	33	38	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	17	45	33	37	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	17	55	33	37	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	18	5	33	37	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	18	15	33	38	0	0	0	0	0	0	0	34.23	0	0	12
2015	12	5	18	25	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	18	35	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	18	45	33	37	0	0	0	0	0	0	0	34.21	0	0	12
2015	12	5	18	55	33	37	0	0	0	0	0	0	0	34.2	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	5	19	5	33	37	0	0	0	0	0	0	0	34.18	0	0	12
2015	12	5	19	15	33	37	0	0	0	0	0	0	0	34.18	0	0	12
2015	12	5	19	25	33	37	0	0	0	0	0	0	0	34.18	0	0	12
2015	12	5	19	35	33	37	0	0	0	0	0	0	0	34.16	0	0	12
2015	12	5	19	45	33	37	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	5	19	55	33	38	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	5	20	5	33	37	0	0	0	0	0	0	0	34.12	0	0	12
2015	12	5	20	15	33	37	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	5	20	25	33	38	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	5	20	35	33	37	0	0	0	0	0	0	0	34.11	0	0	11.8
2015	12	5	20	45	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	20	55	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	21	5	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	21	15	33	37	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	5	21	25	33	37	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	21	35	33	37	0	0	0	0	0	0	0	34.07	0	0	11.8
2015	12	5	21	45	33	38	0	0	0	0	0	0	0	34.09	0	0	11.8
2015	12	5	21	55	33	38	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	22	5	33	37	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	22	15	33	37	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	22	25	33	38	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	22	35	33	36	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	22	45	33	38	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	22	55	33	38	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	5	23	5	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	23	15	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	23	25	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	23	35	33	37	0	0	0	0	0	0	0	34.03	0	0	11.8
2015	12	5	23	45	33	38	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	5	23	55	33	37	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	6	0	5	33	37	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	6	0	15	33	37	0	0	0	0	0	0	0	34	0	0	11.8
2015	12	6	0	25	33	38	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	6	0	35	33	37	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	6	0	45	33	37	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	6	0	55	33	37	0	0	0	0	0	0	0	33.96	0	0	11.8
2015	12	6	1	5	33	38	0	0	0	0	0	0	0	33.94	0	0	11.8
2015	12	6	1	15	33	37	0	0	0	0	0	0	0	33.93	0	0	11.8
2015	12	6	1	25	33	37	0	0	0	0	0	0	0	33.93	0	0	11.8
2015	12	6	1	35	33	37	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	6	1	45	33	37	0	0	0	0	0	0	0	33.89	0	0	11.8
2015	12	6	1	55	33	36	0	0	0	0	0	0	0	33.89	0	0	11.8
2015	12	6	2	5	33	38	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	6	2	15	33	38	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	6	2	25	33	37	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	6	2	35	33	37	0	0	0	0	0	0	0	33.84	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	2	45	33	37	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	6	2	55	33	37	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	6	3	5	33	37	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	6	3	15	33	37	0	0	0	0	0	0	0	33.8	0	0	11.6
2015	12	6	3	25	33	37	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	6	3	35	33	37	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	6	3	45	33	37	0	0	0	0	0	0	0	33.75	0	0	11.6
2015	12	6	3	55	33	37	0	0	0	0	0	0	0	33.75	0	0	11.6
2015	12	6	4	5	33	37	0	0	0	0	0	0	0	33.73	0	0	11.6
2015	12	6	4	15	33	37	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	6	4	25	33	37	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	6	4	35	33	37	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	6	4	45	33	37	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	6	4	55	33	36	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	6	5	5	33	37	0	0	0	0	0	0	0	33.62	0	0	11.6
2015	12	6	5	15	33	37	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	6	5	25	33	37	0	0	0	0	0	0	0	33.58	0	0	11.6
2015	12	6	5	35	33	37	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	6	5	45	33	37	0	0	0	0	0	0	0	33.53	0	0	11.6
2015	12	6	5	55	33	37	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	6	6	5	33	37	0	0	0	0	0	0	0	33.48	0	0	11.6
2015	12	6	6	15	33	37	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	6	6	25	33	37	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	6	6	35	33	38	0	0	0	0	0	0	0	33.4	0	0	11.6
2015	12	6	6	45	33	38	0	0	0	0	0	0	0	33.37	0	0	11.6
2015	12	6	6	55	33	38	0	0	0	0	0	0	0	33.33	0	0	11.6
2015	12	6	7	5	33	38	0	0	0	0	0	0	0	33.31	0	0	11.6
2015	12	6	7	15	33	37	0	0	0	0	0	0	0	33.3	0	0	11.6
2015	12	6	7	25	33	38	0	0	0	0	0	0	0	33.26	0	0	11.6
2015	12	6	7	35	33	38	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	6	7	45	33	37	0	0	0	0	0	0	0	33.26	0	0	12
2015	12	6	7	55	33	37	0	0	0	0	0	0	0	33.26	0	0	12.2
2015	12	6	8	5	33	37	0	0	0	0	0	0	0	33.26	0	0	12.2
2015	12	6	8	15	33	37	0	0	0	0	0	0	0	33.28	0	0	12.6
2015	12	6	8	25	33	37	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	6	8	35	33	37	0	0	0	0	0	0	0	33.39	0	0	13
2015	12	6	8	45	33	38	0	0	0	0	0	0	0	33.42	0	0	13
2015	12	6	8	55	33	37	0	0	0	0	0	0	0	33.48	0	0	13
2015	12	6	9	5	33	38	0	0	0	0	0	0	0	33.51	0	0	13.2
2015	12	6	9	15	33	37	0	0	0	0	0	0	0	33.55	0	0	13.2
2015	12	6	9	25	33	38	0	0	0	0	0	0	0	33.62	0	0	13.2
2015	12	6	9	35	33	37	0	0	0	0	0	0	0	33.67	0	0	13.2
2015	12	6	9	45	33	37	0	0	0	0	0	0	0	33.76	0	0	13.4
2015	12	6	9	55	33	38	0	0	0	0	0	0	0	33.82	0	0	13.2
2015	12	6	10	5	33	37	0	0	0	0	0	0	0	33.85	0	0	13.2
2015	12	6	10	15	33	37	0	0	0	0	0	0	0	33.87	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	10	25	33	38	0	0	0	0	0	0	0	33.91	0	0	13
2015	12	6	10	35	33	37	0	0	0	0	0	0	0	33.85	0	0	13
2015	12	6	10	45	33	38	0	0	0	0	0	0	0	33.84	0	0	12.8
2015	12	6	10	55	33	37	0	0	0	0	0	0	0	33.8	0	0	12.8
2015	12	6	11	5	33	38	0	0	0	0	0	0	0	33.71	0	0	12.6
2015	12	6	11	15	33	37	0	0	0	0	0	0	0	33.75	0	0	13
2015	12	6	11	25	33	37	0	0	0	0	0	0	0	33.93	0	0	13
2015	12	6	11	35	33	37	0	0	0	0	0	0	0	33.93	0	0	12.8
2015	12	6	11	45	33	37	0	0	0	0	0	0	0	33.85	0	0	12.6
2015	12	6	11	55	33	37	0	0	0	0	0	0	0	33.87	0	0	12.8
2015	12	6	12	5	33	37	0	0	0	0	0	0	0	33.91	0	0	12.8
2015	12	6	12	15	33	37	0	0	0	0	0	0	0	33.85	0	0	12.8
2015	12	6	12	25	33	37	0	0	0	0	0	0	0	33.84	0	0	12.6
2015	12	6	12	35	33	37	0	0	0	0	0	0	0	33.76	0	0	12.6
2015	12	6	12	45	33	37	0	0	0	0	0	0	0	33.76	0	0	12.6
2015	12	6	12	55	33	37	0	0	0	0	0	0	0	33.78	0	0	12.8
2015	12	6	13	5	33	37	0	0	0	0	0	0	0	33.87	0	0	13.8
2015	12	6	13	15	33	37	0	0	0	0	0	0	0	33.94	0	0	13.8
2015	12	6	13	25	33	37	0	0	0	0	0	0	0	33.94	0	0	13.8
2015	12	6	13	35	33	37	0	0	0	0	0	0	0	33.94	0	0	13.8
2015	12	6	13	45	33	38	0	0	0	0	0	0	0	33.94	0	0	13.8
2015	12	6	13	55	33	37	0	0	0	0	0	0	0	33.93	0	0	13.8
2015	12	6	14	5	33	38	0	0	0	0	0	0	0	33.91	0	0	13.6
2015	12	6	14	15	33	37	0	0	0	0	0	0	0	33.87	0	0	13.6
2015	12	6	14	25	33	37	0	0	0	0	0	0	0	33.87	0	0	13.6
2015	12	6	14	35	33	37	0	0	0	0	0	0	0	33.87	0	0	13.6
2015	12	6	14	45	33	38	0	0	0	0	0	0	0	33.82	0	0	13.6
2015	12	6	14	55	33	37	0	0	0	0	0	0	0	33.8	0	0	13.6
2015	12	6	15	5	33	38	0	0	0	0	0	0	0	33.76	0	0	13.6
2015	12	6	15	15	33	37	0	0	0	0	0	0	0	33.73	0	0	13.6
2015	12	6	15	25	33	37	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	6	15	35	33	37	0	0	0	0	0	0	0	33.66	0	0	12.2
2015	12	6	15	45	33	37	0	0	0	0	0	0	0	33.67	0	0	12.2
2015	12	6	15	55	33	38	0	0	0	0	0	0	0	33.66	0	0	12.2
2015	12	6	16	5	33	37	0	0	0	0	0	0	0	33.66	0	0	12
2015	12	6	16	15	33	37	0	0	0	0	0	0	0	33.64	0	0	12
2015	12	6	16	25	33	36	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	6	16	35	33	37	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	6	16	45	33	37	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	6	16	55	33	38	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	6	17	5	33	37	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	6	17	15	33	37	0	0	0	0	0	0	0	33.62	0	0	12
2015	12	6	17	25	33	37	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	6	17	35	33	37	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	6	17	45	33	37	0	0	0	0	0	0	0	33.6	0	0	12
2015	12	6	17	55	33	37	0	0	0	0	0	0	0	33.58	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	6	18	5	33	38	0	0	0	0	0	0	0	33.57	0	0	12
2015	12	6	18	15	33	37	0	0	0	0	0	0	0	33.57	0	0	12
2015	12	6	18	25	33	38	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	6	18	35	33	37	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	6	18	45	33	38	0	0	0	0	0	0	0	33.55	0	0	12
2015	12	6	18	55	33	37	0	0	0	0	0	0	0	33.53	0	0	12
2015	12	6	19	5	33	37	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	6	19	15	33	37	0	0	0	0	0	0	0	33.51	0	0	12
2015	12	6	19	25	33	38	0	0	0	0	0	0	0	33.49	0	0	12
2015	12	6	19	35	33	37	0	0	0	0	0	0	0	33.48	0	0	12
2015	12	6	19	45	33	37	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	6	19	55	33	37	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	6	20	5	33	38	0	0	0	0	0	0	0	33.44	0	0	11.8
2015	12	6	20	15	33	38	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	6	20	25	33	38	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	6	20	35	33	37	0	0	0	0	0	0	0	33.4	0	0	11.8
2015	12	6	20	45	33	37	0	0	0	0	0	0	0	33.4	0	0	11.8
2015	12	6	20	55	33	38	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	6	21	5	33	38	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	6	21	15	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	6	21	25	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	6	21	35	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	6	21	45	33	38	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	6	21	55	33	38	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	6	22	5	33	38	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	6	22	15	33	38	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	6	22	25	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	6	22	35	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	6	22	45	33	37	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	6	22	55	33	38	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	6	23	5	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	6	23	15	33	37	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	6	23	25	33	38	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	6	23	35	33	37	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	6	23	45	33	38	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	6	23	55	33	38	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	7	0	5	33	37	1	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	7	0	15	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	7	0	25	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	7	0	35	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	7	0	45	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	7	0	55	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	7	1	5	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	7	1	15	33	37	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	7	1	25	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	7	1	35	33	38	0	0	0	0	0	0	0	33.01	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	1	45	33	37	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	7	1	55	33	37	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	7	2	5	33	37	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	7	2	15	33	38	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	7	2	25	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	7	2	35	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	7	2	45	33	38	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	7	2	55	33	37	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	7	3	5	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	7	3	15	33	37	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	7	3	25	33	38	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	7	3	35	33	38	0	0	0	0	0	0	0	32.81	0	0	11.8
2015	12	7	3	45	33	37	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	7	3	55	33	37	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	7	4	5	33	37	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	7	4	15	33	38	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	7	4	25	33	38	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	7	4	35	33	38	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	7	4	45	33	38	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	7	4	55	33	37	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	7	5	5	33	38	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	7	5	15	33	38	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	7	5	25	33	37	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	7	5	35	33	37	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	7	5	45	33	38	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	7	5	55	33	37	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	7	6	5	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	7	6	15	33	37	0	0	0	0	0	0	0	32.54	0	0	11.6
2015	12	7	6	25	33	38	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	7	6	35	33	38	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	7	6	45	33	38	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	7	6	55	33	37	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	7	7	5	33	38	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	7	7	15	33	37	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	7	7	25	33	37	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	7	7	35	33	37	0	0	0	0	0	0	0	32.49	0	0	12
2015	12	7	7	45	33	38	0	0	0	0	0	0	0	32.52	0	0	12.2
2015	12	7	7	55	33	37	0	0	0	0	0	0	0	32.54	0	0	12.2
2015	12	7	8	5	33	37	0	0	0	0	0	0	0	32.56	0	0	12.2
2015	12	7	8	15	33	38	0	0	0	0	0	0	0	32.65	0	0	12.6
2015	12	7	8	25	33	38	0	0	0	0	0	0	0	32.74	0	0	12.8
2015	12	7	8	35	33	37	0	0	0	0	0	0	0	32.81	0	0	12.8
2015	12	7	8	45	33	38	0	0	0	0	0	0	0	32.88	0	0	12.8
2015	12	7	8	55	33	37	0	0	0	0	0	0	0	32.92	0	0	12.8
2015	12	7	9	5	33	38	0	0	0	0	0	0	0	32.95	0	0	12.8
2015	12	7	9	15	33	38	0	0	0	0	0	0	0	33.01	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	9	25	33	37	0	0	0	0	0	0	0	33.08	0	0	12.8
2015	12	7	9	35	33	37	0	0	0	0	0	0	0	33.15	0	0	13
2015	12	7	9	45	33	37	0	0	0	0	0	0	0	33.21	0	0	13
2015	12	7	9	55	33	37	0	0	0	0	0	0	0	33.28	0	0	13
2015	12	7	10	5	33	38	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	7	10	15	33	38	0	0	0	0	0	0	0	33.33	0	0	12.8
2015	12	7	10	25	33	37	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	7	10	35	33	37	0	0	0	0	0	0	0	33.31	0	0	12.8
2015	12	7	10	45	33	37	0	0	0	0	0	0	0	33.42	0	0	13
2015	12	7	10	55	33	37	0	0	0	0	0	0	0	33.33	0	0	12.6
2015	12	7	11	5	33	37	0	0	0	0	0	0	0	33.49	0	0	13
2015	12	7	11	15	33	37	0	0	0	0	0	0	0	33.55	0	0	13
2015	12	7	11	25	33	37	0	0	0	0	0	0	0	33.49	0	0	12.8
2015	12	7	11	35	33	38	0	0	0	0	0	0	0	33.44	0	0	12.6
2015	12	7	11	45	33	38	0	0	0	0	0	0	0	33.46	0	0	12.6
2015	12	7	11	55	33	38	0	0	0	0	0	0	0	33.46	0	0	12.6
2015	12	7	12	5	33	37	0	0	0	0	0	0	0	33.39	0	0	12.6
2015	12	7	12	15	33	38	0	0	0	0	0	0	0	33.4	0	0	12.8
2015	12	7	12	25	33	37	0	0	0	0	0	0	0	33.57	0	0	13
2015	12	7	12	35	33	37	0	0	0	0	0	0	0	33.62	0	0	13.6
2015	12	7	12	45	33	37	0	0	0	0	0	0	0	33.62	0	0	12.8
2015	12	7	12	55	33	37	0	0	0	0	0	0	0	33.53	0	0	12.6
2015	12	7	13	5	33	37	0	0	0	0	0	0	0	33.53	0	0	13.2
2015	12	7	13	15	33	38	0	0	0	0	0	0	0	33.6	0	0	13.6
2015	12	7	13	25	33	37	0	0	0	0	0	0	0	33.62	0	0	13.6
2015	12	7	13	35	33	38	0	0	0	0	0	0	0	33.64	0	0	13.6
2015	12	7	13	45	33	37	0	0	0	0	0	0	0	33.64	0	0	13.6
2015	12	7	13	55	33	37	0	0	0	0	0	0	0	33.58	0	0	13.6
2015	12	7	14	5	33	37	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	7	14	15	33	38	0	0	0	0	0	0	0	33.53	0	0	13.6
2015	12	7	14	25	33	37	0	0	0	0	0	0	0	33.53	0	0	13
2015	12	7	14	35	33	37	0	0	0	0	0	0	0	33.55	0	0	12.8
2015	12	7	14	45	33	37	0	0	0	0	0	0	0	33.51	0	0	12.6
2015	12	7	14	55	33	37	0	0	0	0	0	0	0	33.48	0	0	12.4
2015	12	7	15	5	33	38	0	0	0	0	0	0	0	33.46	0	0	12.2
2015	12	7	15	15	33	37	0	0	0	0	0	0	0	33.44	0	0	12.2
2015	12	7	15	25	33	38	0	0	0	0	0	0	0	33.44	0	0	12.2
2015	12	7	15	35	33	37	0	0	0	0	0	0	0	33.44	0	0	12.2
2015	12	7	15	45	33	37	0	0	0	0	0	0	0	33.42	0	0	12.2
2015	12	7	15	55	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	16	5	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	16	15	33	37	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	7	16	25	33	37	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	7	16	35	33	38	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	7	16	45	33	37	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	7	16	55	33	37	0	0	0	0	0	0	0	33.4	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	7	17	5	33	38	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	17	15	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	17	25	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	17	35	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	17	45	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	17	55	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	18	5	33	37	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	7	18	15	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	18	25	33	37	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	7	18	35	33	38	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	7	18	45	33	38	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	7	18	55	33	37	0	0	0	0	0	0	0	33.46	0	0	12
2015	12	7	19	5	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	19	15	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	19	25	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	19	35	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	7	19	45	33	38	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	19	55	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	20	5	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	7	20	15	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	7	20	25	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	7	20	35	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	7	20	45	33	38	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	7	20	55	33	38	0	0	0	0	0	0	0	33.4	0	0	11.8
2015	12	7	21	5	33	38	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	7	21	15	33	37	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	7	21	25	33	38	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	7	21	35	33	37	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	21	45	33	38	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	21	55	33	37	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	22	5	33	38	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	22	15	33	38	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	22	25	33	37	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	22	35	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	7	22	45	33	37	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	7	22	55	33	38	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	7	23	5	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	7	23	15	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	7	23	25	33	38	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	7	23	35	33	38	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	7	23	45	33	38	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	7	23	55	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	8	0	5	33	38	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	8	0	15	33	37	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	8	0	25	33	38	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	8	0	35	33	37	0	0	0	0	0	0	0	33.28	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	0	45	33	37	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	8	0	55	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	8	1	5	33	38	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	8	1	15	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	8	1	25	33	37	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	8	1	35	33	37	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	8	1	45	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	8	1	55	33	37	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	8	2	5	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	8	2	15	33	38	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	8	2	25	33	37	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	8	2	35	33	38	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	8	2	45	33	38	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	8	2	55	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	8	3	5	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	8	3	15	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	8	3	25	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	8	3	35	33	37	0	0	0	0	0	0	0	33.04	0	0	11.6
2015	12	8	3	45	33	37	0	0	0	0	0	0	0	33.04	0	0	11.6
2015	12	8	3	55	33	38	0	0	0	0	0	0	0	33.04	0	0	11.6
2015	12	8	4	5	33	37	0	0	0	0	0	0	0	33.03	0	0	11.6
2015	12	8	4	15	33	38	0	0	0	0	0	0	0	33.01	0	0	11.6
2015	12	8	4	25	33	38	0	0	0	0	0	0	0	32.99	0	0	11.6
2015	12	8	4	35	33	38	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	8	4	45	33	37	0	0	0	0	0	0	0	32.97	0	0	11.6
2015	12	8	4	55	33	37	0	0	0	0	0	0	0	32.95	0	0	11.6
2015	12	8	5	5	33	37	0	0	0	0	0	0	0	32.94	0	0	11.6
2015	12	8	5	15	33	37	0	0	0	0	0	0	0	32.94	0	0	11.6
2015	12	8	5	25	33	38	0	0	0	0	0	0	0	32.92	0	0	11.6
2015	12	8	5	35	33	37	0	0	0	0	0	0	0	32.9	0	0	11.6
2015	12	8	5	45	33	37	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	8	5	55	33	38	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	8	6	5	33	38	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	8	6	15	33	38	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	8	6	25	33	38	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	8	6	35	33	37	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	8	6	45	33	38	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	8	6	55	33	38	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	8	7	5	33	37	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	8	7	15	33	38	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	8	7	25	33	37	0	0	0	0	0	0	0	32.81	0	0	11.8
2015	12	8	7	35	33	38	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	8	7	45	33	38	0	0	0	0	0	0	0	32.86	0	0	12
2015	12	8	7	55	33	38	0	0	0	0	0	0	0	32.9	0	0	12.2
2015	12	8	8	5	33	37	0	0	0	0	0	0	0	32.94	0	0	12.2
2015	12	8	8	15	33	38	0	0	0	0	0	0	0	32.95	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	8	25	33	37	0	0	0	0	0	0	0	33.04	0	0	12.6
2015	12	8	8	35	33	37	0	0	0	0	0	0	0	33.12	0	0	12.6
2015	12	8	8	45	33	38	0	0	0	0	0	0	0	33.15	0	0	12.6
2015	12	8	8	55	33	37	0	0	0	0	0	0	0	33.19	0	0	12.6
2015	12	8	9	5	33	37	0	0	0	0	0	0	0	33.24	0	0	12.6
2015	12	8	9	15	33	37	0	0	0	0	0	0	0	33.31	0	0	12.6
2015	12	8	9	25	33	38	0	0	0	0	0	0	0	33.37	0	0	12.8
2015	12	8	9	35	33	38	0	0	0	0	0	0	0	33.4	0	0	12.6
2015	12	8	9	45	33	38	0	0	0	0	0	0	0	33.42	0	0	12.6
2015	12	8	9	55	33	37	0	0	0	0	0	0	0	33.44	0	0	12.6
2015	12	8	10	5	33	38	0	0	0	0	0	0	0	33.51	0	0	12.8
2015	12	8	10	15	33	38	0	0	0	0	0	0	0	33.58	0	0	12.8
2015	12	8	10	25	33	38	0	0	0	0	0	0	0	33.66	0	0	12.8
2015	12	8	10	35	33	37	0	0	0	0	0	0	0	33.71	0	0	12.8
2015	12	8	10	45	33	38	0	0	0	0	0	0	0	33.82	0	0	12.8
2015	12	8	10	55	33	37	0	0	0	0	0	0	0	33.89	0	0	13
2015	12	8	11	5	33	37	0	0	0	0	0	0	0	33.93	0	0	13
2015	12	8	11	15	33	38	0	0	0	0	0	0	0	33.96	0	0	13
2015	12	8	11	25	33	37	0	0	0	0	0	0	0	34	0	0	12.8
2015	12	8	11	35	33	37	0	0	0	0	0	0	0	34.02	0	0	12.8
2015	12	8	11	45	33	38	0	0	0	0	0	0	0	34.05	0	0	12.8
2015	12	8	11	55	33	37	0	0	0	0	0	0	0	34.03	0	0	12.8
2015	12	8	12	5	33	37	0	0	0	0	0	0	0	33.84	0	0	12.4
2015	12	8	12	15	33	37	0	0	0	0	0	0	0	33.75	0	0	12.4
2015	12	8	12	25	33	36	0	0	0	0	0	0	0	33.73	0	0	12.4
2015	12	8	12	35	33	37	0	0	0	0	0	0	0	33.76	0	0	12.6
2015	12	8	12	45	33	37	0	0	0	0	0	0	0	33.8	0	0	12.6
2015	12	8	12	55	33	37	0	0	0	0	0	0	0	33.8	0	0	12.4
2015	12	8	13	5	33	38	0	0	0	0	0	0	0	33.82	0	0	12.6
2015	12	8	13	15	33	37	0	0	0	0	0	0	0	33.84	0	0	12.6
2015	12	8	13	25	33	37	0	0	0	0	0	0	0	33.85	0	0	12.6
2015	12	8	13	35	33	37	0	0	0	0	0	0	0	33.87	0	0	12.6
2015	12	8	13	45	33	38	0	0	0	0	0	0	0	33.89	0	0	12.6
2015	12	8	13	55	33	37	0	0	0	0	0	0	0	33.89	0	0	12.6
2015	12	8	14	5	33	37	0	0	0	0	0	0	0	33.89	0	0	12.4
2015	12	8	14	15	33	38	0	0	0	0	0	0	0	33.89	0	0	12.4
2015	12	8	14	25	33	37	0	0	0	0	0	0	0	33.87	0	0	12.4
2015	12	8	14	35	33	37	0	0	0	0	0	0	0	33.85	0	0	12.4
2015	12	8	14	45	33	37	0	0	0	0	0	0	0	33.84	0	0	12.2
2015	12	8	14	55	33	37	0	0	0	0	0	0	0	33.82	0	0	12.2
2015	12	8	15	5	33	37	0	0	0	0	0	0	0	33.8	0	0	12.2
2015	12	8	15	15	33	38	0	0	0	0	0	0	0	33.82	0	0	12.2
2015	12	8	15	25	33	37	0	0	0	0	0	0	0	33.8	0	0	12.2
2015	12	8	15	35	33	37	0	0	0	0	0	0	0	33.8	0	0	12.2
2015	12	8	15	45	33	37	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	15	55	33	38	0	0	0	0	0	0	0	33.82	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	16	5	33	38	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	16	15	33	38	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	16	25	33	36	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	16	35	33	38	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	16	45	33	37	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	8	16	55	33	38	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	8	17	5	33	37	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	8	17	15	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	8	17	25	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	8	17	35	33	37	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	8	17	45	33	37	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	8	17	55	33	37	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	8	18	5	33	37	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	8	18	15	33	37	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	18	25	33	38	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	18	35	33	37	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	18	45	33	38	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	18	55	33	37	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	19	5	33	38	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	19	15	33	38	0	0	0	0	0	0	0	33.91	0	0	12
2015	12	8	19	25	33	38	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	8	19	35	33	37	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	8	19	45	33	37	0	0	0	0	0	0	0	33.91	0	0	11.8
2015	12	8	19	55	33	37	0	0	0	0	0	0	0	33.89	0	0	11.8
2015	12	8	20	5	33	37	0	0	0	0	0	0	0	33.89	0	0	11.8
2015	12	8	20	15	33	38	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	8	20	25	33	37	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	8	20	35	33	37	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	8	20	45	33	37	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	8	20	55	33	37	0	0	0	0	0	0	0	33.87	0	0	11.8
2015	12	8	21	5	33	37	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	8	21	15	33	37	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	8	21	25	33	37	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	8	21	35	33	37	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	21	45	33	37	0	0	0	0	0	0	0	33.85	0	0	11.8
2015	12	8	21	55	33	37	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	22	5	33	38	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	22	15	33	37	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	22	25	33	38	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	22	35	33	38	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	8	22	45	33	38	0	0	0	0	0	0	0	33.84	0	0	11.8
2015	12	8	22	55	33	37	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	8	23	5	33	37	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	8	23	15	33	37	0	0	0	0	0	0	0	33.82	0	0	11.8
2015	12	8	23	25	33	37	0	0	0	0	0	0	0	33.8	0	0	11.8
2015	12	8	23	35	33	38	0	0	0	0	0	0	0	33.8	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	8	23	45	33	37	0	0	0	0	0	0	0	33.8	0	0	11.8
2015	12	8	23	55	33	37	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	9	0	5	33	38	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	9	0	15	33	38	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	9	0	25	33	37	0	0	0	0	0	0	0	33.78	0	0	11.8
2015	12	9	0	35	33	37	0	0	0	0	0	0	0	33.76	0	0	11.8
2015	12	9	0	45	33	38	0	0	0	0	0	0	0	33.76	0	0	11.8
2015	12	9	0	55	33	37	0	0	0	0	0	0	0	33.76	0	0	11.8
2015	12	9	1	5	33	37	0	0	0	0	0	0	0	33.75	0	0	11.8
2015	12	9	1	15	33	37	0	0	0	0	0	0	0	33.75	0	0	11.8
2015	12	9	1	25	33	37	0	0	0	0	0	0	0	33.73	0	0	11.8
2015	12	9	1	35	33	38	0	0	0	0	0	0	0	33.73	0	0	11.8
2015	12	9	1	45	33	37	0	0	0	0	0	0	0	33.73	0	0	11.8
2015	12	9	1	55	33	37	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	9	2	5	33	37	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	9	2	15	33	37	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	9	2	25	33	38	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	9	2	35	33	38	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	9	2	45	33	37	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	9	2	55	33	38	0	0	0	0	0	0	0	33.67	0	0	11.6
2015	12	9	3	5	33	37	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	9	3	15	33	37	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	9	3	25	33	38	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	9	3	35	33	37	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	9	3	45	33	37	0	0	0	0	0	0	0	33.62	0	0	11.6
2015	12	9	3	55	33	37	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	9	4	5	33	37	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	9	4	15	33	38	0	0	0	0	0	0	0	33.58	0	0	11.6
2015	12	9	4	25	33	38	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	9	4	35	33	37	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	9	4	45	33	38	0	0	0	0	0	0	0	33.57	0	0	11.6
2015	12	9	4	55	33	37	0	0	0	0	0	0	0	33.55	0	0	11.6
2015	12	9	5	5	33	38	0	0	0	0	0	0	0	33.53	0	0	11.6
2015	12	9	5	15	33	37	0	0	0	0	0	0	0	33.53	0	0	11.6
2015	12	9	5	25	33	38	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	9	5	35	33	38	0	0	0	0	0	0	0	33.51	0	0	11.6
2015	12	9	5	45	33	37	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	9	5	55	33	38	0	0	0	0	0	0	0	33.49	0	0	11.6
2015	12	9	6	5	33	37	0	0	0	0	0	0	0	33.48	0	0	11.6
2015	12	9	6	15	33	37	0	0	0	0	0	0	0	33.48	0	0	11.6
2015	12	9	6	25	33	37	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	9	6	35	33	37	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	9	6	45	33	37	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	9	6	55	33	38	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	9	7	5	33	38	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	9	7	15	33	37	0	0	0	0	0	0	0	33.42	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	7	25	33	37	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	9	7	35	33	38	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	9	7	45	33	38	0	0	0	0	0	0	0	33.42	0	0	11.6
2015	12	9	7	55	33	38	0	0	0	0	0	0	0	33.44	0	0	11.6
2015	12	9	8	5	33	38	0	0	0	0	0	0	0	33.46	0	0	11.6
2015	12	9	8	15	33	38	0	0	0	0	0	0	0	33.48	0	0	11.8
2015	12	9	8	25	33	37	0	0	0	0	0	0	0	33.49	0	0	11.8
2015	12	9	8	35	33	37	0	0	0	0	0	0	0	33.57	0	0	12
2015	12	9	8	45	33	37	0	0	0	0	0	0	0	33.66	0	0	12.2
2015	12	9	8	55	33	37	0	0	0	0	0	0	0	33.71	0	0	12.4
2015	12	9	9	5	33	37	0	0	0	0	0	0	0	33.75	0	0	12.4
2015	12	9	9	15	33	37	0	0	0	0	0	0	0	33.76	0	0	12.6
2015	12	9	9	25	33	36	0	0	0	0	0	0	0	33.82	0	0	12.6
2015	12	9	9	35	33	37	0	0	0	0	0	0	0	33.89	0	0	12.8
2015	12	9	9	45	33	37	0	0	0	0	0	0	0	33.96	0	0	12.8
2015	12	9	9	55	33	37	0	0	0	0	0	0	0	33.96	0	0	12.6
2015	12	9	10	5	33	38	0	0	0	0	0	0	0	34.11	0	0	12.8
2015	12	9	10	15	33	37	0	0	0	0	0	0	0	34.09	0	0	12.8
2015	12	9	10	25	33	37	0	0	0	0	0	0	0	34.2	0	0	13
2015	12	9	10	35	33	37	0	0	0	0	0	0	0	34.32	0	0	13
2015	12	9	10	45	33	37	0	0	0	0	0	0	0	34.41	0	0	13
2015	12	9	10	55	33	37	0	0	0	0	0	0	0	34.47	0	0	13
2015	12	9	11	5	33	38	0	0	0	0	0	0	0	34.41	0	0	12.8
2015	12	9	11	15	33	37	0	0	0	0	0	0	0	34.39	0	0	12.8
2015	12	9	11	25	33	38	0	0	0	0	0	0	0	34.43	0	0	12.8
2015	12	9	11	35	33	38	0	0	0	0	0	0	0	34.47	0	0	12.8
2015	12	9	11	45	33	36	0	0	0	0	0	0	0	34.48	0	0	12.8
2015	12	9	11	55	33	37	0	0	0	0	0	0	0	34.47	0	0	12.8
2015	12	9	12	5	33	37	0	0	0	0	0	0	0	34.52	0	0	12.8
2015	12	9	12	15	33	37	0	0	0	0	0	0	0	34.57	0	0	13.2
2015	12	9	12	25	33	37	0	0	0	0	0	0	0	34.63	0	0	13
2015	12	9	12	35	33	37	0	0	0	0	0	0	0	34.74	0	0	13.4
2015	12	9	12	45	33	37	0	0	0	0	0	0	0	34.79	0	0	13.4
2015	12	9	12	55	33	38	0	0	0	0	0	0	0	34.79	0	0	13.4
2015	12	9	13	5	33	37	0	0	0	0	0	0	0	34.81	0	0	13.4
2015	12	9	13	15	33	37	0	0	0	0	0	0	0	34.83	0	0	13.4
2015	12	9	13	25	33	37	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	9	13	35	33	38	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	9	13	45	33	38	0	0	0	0	0	0	0	34.79	0	0	13.4
2015	12	9	13	55	33	37	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	9	14	5	33	37	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	9	14	15	33	37	0	0	0	0	0	0	0	34.77	0	0	13.4
2015	12	9	14	25	33	37	0	0	0	0	0	0	0	34.72	0	0	13.4
2015	12	9	14	35	33	38	0	0	0	0	0	0	0	34.7	0	0	13.4
2015	12	9	14	45	33	37	0	0	0	0	0	0	0	34.7	0	0	13.4
2015	12	9	14	55	33	38	0	0	0	0	0	0	0	34.66	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	15	5	33	37	0	0	0	0	0	0	0	34.63	0	0	12.8
2015	12	9	15	15	33	38	0	0	0	0	0	0	0	34.61	0	0	12.4
2015	12	9	15	25	33	37	0	0	0	0	0	0	0	34.59	0	0	12.4
2015	12	9	15	35	33	38	0	0	0	0	0	0	0	34.59	0	0	12.2
2015	12	9	15	45	33	37	0	0	0	0	0	0	0	34.59	0	0	12.2
2015	12	9	15	55	33	37	0	0	0	0	0	0	0	34.57	0	0	12.2
2015	12	9	16	5	33	37	0	0	0	0	0	0	0	34.56	0	0	12.2
2015	12	9	16	15	33	37	0	0	0	0	0	0	0	34.56	0	0	12
2015	12	9	16	25	33	38	0	0	0	0	0	0	0	34.56	0	0	12
2015	12	9	16	35	33	37	0	0	0	0	0	0	0	34.57	0	0	12
2015	12	9	16	45	33	37	0	0	0	0	0	0	0	34.57	0	0	12
2015	12	9	16	55	33	37	0	0	0	0	0	0	0	34.59	0	0	12
2015	12	9	17	5	33	37	0	0	0	0	0	0	0	34.61	0	0	12
2015	12	9	17	15	33	36	0	0	0	0	0	0	0	34.61	0	0	12
2015	12	9	17	25	33	38	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	17	35	33	38	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	17	45	33	37	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	9	17	55	33	36	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	9	18	5	33	37	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	18	15	33	37	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	18	25	33	37	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	18	35	33	38	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	9	18	45	33	37	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	9	18	55	33	37	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	9	19	5	33	37	0	0	0	0	0	0	0	34.7	0	0	12
2015	12	9	19	15	33	38	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	19	25	33	37	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	19	35	33	37	0	0	0	0	0	0	0	34.68	0	0	12
2015	12	9	19	45	33	37	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	9	19	55	33	37	0	0	0	0	0	0	0	34.66	0	0	12
2015	12	9	20	5	33	38	0	0	0	0	0	0	0	34.65	0	0	12
2015	12	9	20	15	33	37	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	20	25	33	38	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	20	35	33	37	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	20	45	33	37	0	0	0	0	0	0	0	34.63	0	0	12
2015	12	9	20	55	33	38	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	9	21	5	33	37	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	9	21	15	33	37	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	9	21	25	33	37	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	9	21	35	33	37	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	9	21	45	33	37	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	9	21	55	33	37	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	9	22	5	33	37	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	9	22	15	33	37	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	9	22	25	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	9	22	35	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	9	22	45	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	9	22	55	33	37	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	9	23	5	33	38	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	9	23	15	33	38	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	9	23	25	33	38	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	9	23	35	33	37	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	9	23	45	33	37	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	9	23	55	33	38	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	10	0	5	33	37	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	10	0	15	33	37	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	10	0	25	33	37	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	10	0	35	33	38	0	0	0	0	0	0	0	34.43	0	0	11.8
2015	12	10	0	45	33	38	0	0	0	0	0	0	0	34.43	0	0	11.8
2015	12	10	0	55	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	10	1	5	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	10	1	15	33	37	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	10	1	25	33	37	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	10	1	35	33	37	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	10	1	45	33	37	0	0	0	0	0	0	0	34.39	0	0	11.8
2015	12	10	1	55	33	38	0	0	0	0	0	0	0	34.38	0	0	11.8
2015	12	10	2	5	33	37	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	10	2	15	33	37	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	10	2	25	33	37	0	0	0	0	0	0	0	34.34	0	0	11.8
2015	12	10	2	35	33	37	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	10	2	45	33	37	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	10	2	55	33	38	0	0	0	0	0	0	0	34.3	0	0	11.8
2015	12	10	3	5	33	38	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	10	3	15	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	10	3	25	33	38	0	0	0	0	0	0	0	34.27	0	0	11.8
2015	12	10	3	35	33	37	0	0	0	0	0	0	0	34.25	0	0	11.8
2015	12	10	3	45	33	37	0	0	0	0	0	0	0	34.23	0	0	11.8
2015	12	10	3	55	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	10	4	5	33	37	0	0	0	0	0	0	0	34.21	0	0	11.8
2015	12	10	4	15	33	38	0	0	0	0	0	0	0	34.2	0	0	11.8
2015	12	10	4	25	33	37	0	0	0	0	0	0	0	34.18	0	0	11.8
2015	12	10	4	35	33	38	0	0	0	0	0	0	0	34.16	0	0	11.8
2015	12	10	4	45	33	37	0	0	0	0	0	0	0	34.14	0	0	11.8
2015	12	10	4	55	33	38	0	0	0	0	0	0	0	34.12	0	0	11.8
2015	12	10	5	5	33	37	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	10	5	15	33	38	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	10	5	25	33	37	0	0	0	0	0	0	0	34.09	0	0	11.6
2015	12	10	5	35	33	37	0	0	0	0	0	0	0	34.07	0	0	11.6
2015	12	10	5	45	33	38	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	10	5	55	33	37	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	10	6	5	33	38	0	0	0	0	0	0	0	34.03	0	0	11.6
2015	12	10	6	15	33	37	0	0	0	0	0	0	0	34.02	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	6	25	33	37	0	0	0	0	0	0	0	34	0	0	11.6
2015	12	10	6	35	33	38	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	10	6	45	33	38	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	10	6	55	33	37	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	10	7	5	33	37	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	10	7	15	33	38	0	0	0	0	0	0	0	33.96	0	0	11.6
2015	12	10	7	25	33	37	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	10	7	35	33	37	0	0	0	0	0	0	0	33.98	0	0	11.8
2015	12	10	7	45	33	37	0	0	0	0	0	0	0	34.02	0	0	11.8
2015	12	10	7	55	33	37	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	10	8	5	33	38	0	0	0	0	0	0	0	34.05	0	0	11.8
2015	12	10	8	15	33	37	0	0	0	0	0	0	0	34.11	0	0	12
2015	12	10	8	25	33	37	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	10	8	35	33	37	0	0	0	0	0	0	0	34.14	0	0	12
2015	12	10	8	45	33	37	0	0	0	0	0	0	0	34.21	0	0	12.2
2015	12	10	8	55	33	37	0	0	0	0	0	0	0	34.36	0	0	12.4
2015	12	10	9	5	33	37	0	0	0	0	0	0	0	34.39	0	0	12.4
2015	12	10	9	15	33	37	0	0	0	0	0	0	0	34.34	0	0	12.2
2015	12	10	9	25	33	38	0	0	0	0	0	0	0	34.3	0	0	12.2
2015	12	10	9	35	33	37	0	0	0	0	0	0	0	34.36	0	0	12.4
2015	12	10	9	45	33	38	0	0	0	0	0	0	0	34.45	0	0	12.4
2015	12	10	9	55	33	37	0	0	0	0	0	0	0	34.68	0	0	12.8
2015	12	10	10	5	33	37	0	0	0	0	0	0	0	34.83	0	0	12.8
2015	12	10	10	15	33	37	0	0	0	0	0	0	0	35.01	0	0	12.8
2015	12	10	10	25	33	37	0	0	0	0	0	0	0	34.97	0	0	12.6
2015	12	10	10	35	33	37	0	0	0	0	0	0	0	34.79	0	0	12.4
2015	12	10	10	45	33	38	0	0	0	0	0	0	0	34.66	0	0	12.4
2015	12	10	10	55	33	38	0	0	0	0	0	0	0	34.65	0	0	12.4
2015	12	10	11	5	33	37	0	0	0	0	0	0	0	34.61	0	0	12.2
2015	12	10	11	15	33	38	0	0	0	0	0	0	0	34.61	0	0	12.2
2015	12	10	11	25	33	37	0	0	0	0	0	0	0	34.63	0	0	12.2
2015	12	10	11	35	33	37	0	0	0	0	0	0	0	34.7	0	0	12.4
2015	12	10	11	45	33	37	0	0	0	0	0	0	0	34.74	0	0	12.4
2015	12	10	11	55	33	38	0	0	0	0	0	0	0	34.81	0	0	12.4
2015	12	10	12	5	33	38	0	0	0	0	0	0	0	34.86	0	0	12.4
2015	12	10	12	15	33	37	0	0	0	0	0	0	0	34.9	0	0	12.4
2015	12	10	12	25	33	37	0	0	0	0	0	0	0	34.93	0	0	12.4
2015	12	10	12	35	33	37	0	0	0	0	0	0	0	34.93	0	0	12.4
2015	12	10	12	45	33	38	0	0	0	0	0	0	0	34.95	0	0	12.2
2015	12	10	12	55	33	38	0	0	0	0	0	0	0	34.93	0	0	12.2
2015	12	10	13	5	33	37	0	0	0	0	0	0	0	34.95	0	0	12.2
2015	12	10	13	15	33	37	0	0	0	0	0	0	0	34.95	0	0	12.2
2015	12	10	13	25	33	37	0	0	0	0	0	0	0	34.97	0	0	12.2
2015	12	10	13	35	33	37	0	0	0	0	0	0	0	35.01	0	0	12.2
2015	12	10	13	45	33	37	0	0	0	0	0	0	0	34.99	0	0	12.2
2015	12	10	13	55	33	38	0	0	0	0	0	0	0	35.02	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	14	5	33	37	0	0	0	0	0	0	0	35.04	0	0	12
2015	12	10	14	15	33	37	0	0	0	0	0	0	0	35.1	0	0	12.2
2015	12	10	14	25	33	37	0	0	0	0	0	0	0	35.13	0	0	12.2
2015	12	10	14	35	33	38	0	0	0	0	0	0	0	35.19	0	0	12
2015	12	10	14	45	33	37	0	0	0	0	0	0	0	35.2	0	0	12
2015	12	10	14	55	33	37	0	0	0	0	0	0	0	35.24	0	0	12
2015	12	10	15	5	33	38	0	0	0	0	0	0	0	35.26	0	0	12
2015	12	10	15	15	33	37	0	0	0	0	0	0	0	35.29	0	0	12
2015	12	10	15	25	33	37	0	0	0	0	0	0	0	35.31	0	0	12
2015	12	10	15	35	33	37	0	0	0	0	0	0	0	35.33	0	0	12
2015	12	10	15	45	33	36	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	10	15	55	33	37	0	0	0	0	0	0	0	35.35	0	0	12
2015	12	10	16	5	33	37	0	0	0	0	0	0	0	35.37	0	0	12
2015	12	10	16	15	33	37	0	0	0	0	0	0	0	35.38	0	0	12
2015	12	10	16	25	33	37	0	0	0	0	0	0	0	35.42	0	0	12
2015	12	10	16	35	33	37	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	10	16	45	33	38	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	10	16	55	33	37	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	10	17	5	33	37	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	10	17	15	33	37	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	10	17	25	33	38	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	10	17	35	33	37	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	10	17	45	33	37	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	10	17	55	33	37	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	10	18	5	33	37	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	10	18	15	33	37	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	10	18	25	33	37	0	0	0	0	0	0	0	35.69	0	0	11.8
2015	12	10	18	35	33	37	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	10	18	45	33	37	0	0	0	0	0	0	0	35.73	0	0	11.8
2015	12	10	18	55	33	37	0	0	0	0	0	0	0	35.74	0	0	11.8
2015	12	10	19	5	33	37	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	10	19	15	33	38	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	10	19	25	33	37	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	10	19	35	33	37	0	0	0	0	0	0	0	35.8	0	0	11.8
2015	12	10	19	45	33	37	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	10	19	55	33	37	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	10	20	5	33	37	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	10	20	15	33	37	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	10	20	25	33	37	0	0	0	0	0	0	0	35.87	0	0	11.8
2015	12	10	20	35	33	37	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	10	20	45	33	37	0	0	0	0	0	0	0	35.89	0	0	11.8
2015	12	10	20	55	33	37	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	10	21	5	33	37	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	10	21	15	33	37	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	10	21	25	33	37	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	10	21	35	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	10	21	45	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	10	21	55	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	10	22	5	33	37	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	10	22	15	33	37	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	10	22	25	33	37	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	10	22	35	33	37	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	10	22	45	33	36	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	10	22	55	33	37	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	10	23	5	33	37	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	10	23	15	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	10	23	25	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	10	23	35	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	10	23	45	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	10	23	55	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	11	0	5	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	11	0	15	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	11	0	25	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	0	35	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	0	45	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	0	55	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	1	5	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	1	15	33	38	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	1	25	33	36	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	1	35	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	1	45	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	1	55	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	2	5	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	11	2	15	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	2	25	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	11	2	35	33	37	0	0	0	0	0	0	0	36.1	0	0	11.6
2015	12	11	2	45	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	11	2	55	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	11	3	5	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	11	3	15	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	11	3	25	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	11	3	35	33	37	0	0	0	0	0	0	0	36.07	0	0	11.6
2015	12	11	3	45	33	37	0	0	0	0	0	0	0	36.07	0	0	11.6
2015	12	11	3	55	33	36	0	0	0	0	0	0	0	36.05	0	0	11.6
2015	12	11	4	5	33	37	0	0	0	0	0	0	0	36.05	0	0	11.6
2015	12	11	4	15	33	37	0	0	0	0	0	0	0	36.05	0	0	11.6
2015	12	11	4	25	33	37	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	11	4	35	33	37	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	11	4	45	33	37	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	11	4	55	33	37	0	0	0	0	0	0	0	36.01	0	0	11.6
2015	12	11	5	5	33	38	0	0	0	0	0	0	0	36.01	0	0	11.6
2015	12	11	5	15	33	37	0	0	0	0	0	0	0	36.01	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	5	25	33	37	0	0	0	0	0	0	0	36	0	0	11.6
2015	12	11	5	35	33	37	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	11	5	45	33	37	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	11	5	55	33	37	0	0	0	0	0	0	0	35.96	0	0	11.6
2015	12	11	6	5	33	37	0	0	0	0	0	0	0	35.96	0	0	11.6
2015	12	11	6	15	33	37	0	0	0	0	0	0	0	35.96	0	0	11.6
2015	12	11	6	25	33	37	0	0	0	0	0	0	0	35.94	0	0	11.6
2015	12	11	6	35	33	37	0	0	0	0	0	0	0	35.92	0	0	11.6
2015	12	11	6	45	33	37	0	0	0	0	0	0	0	35.92	0	0	11.6
2015	12	11	6	55	33	37	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	11	7	5	33	37	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	11	7	15	33	37	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	11	7	25	33	38	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	11	7	35	33	38	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	11	7	45	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	11	7	55	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	11	8	5	33	37	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	11	8	15	33	37	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	11	8	25	33	37	0	0	0	0	0	0	0	36.21	0	0	12.2
2015	12	11	8	35	33	37	0	0	0	0	0	0	0	36.25	0	0	12.2
2015	12	11	8	45	33	36	0	0	0	0	0	0	0	36.21	0	0	12
2015	12	11	8	55	33	38	0	0	0	0	0	0	0	36.16	0	0	12
2015	12	11	9	5	33	38	0	0	0	0	0	0	0	36.34	0	0	12.4
2015	12	11	9	15	33	37	0	0	0	0	0	0	0	36.48	0	0	12.6
2015	12	11	9	25	33	38	0	0	0	0	0	0	0	36.55	0	0	12.6
2015	12	11	9	35	33	37	0	0	0	0	0	0	0	36.68	0	0	12.6
2015	12	11	9	45	33	37	0	0	0	0	0	0	0	36.73	0	0	12.6
2015	12	11	9	55	33	37	0	0	0	0	0	0	0	36.81	0	0	12.6
2015	12	11	10	5	33	37	0	0	0	0	0	0	0	36.82	0	0	12.6
2015	12	11	10	15	33	37	0	0	0	0	0	0	0	36.72	0	0	12.4
2015	12	11	10	25	33	37	0	0	0	0	0	0	0	36.7	0	0	12.6
2015	12	11	10	35	33	37	0	0	0	0	0	0	0	36.75	0	0	12.6
2015	12	11	10	45	33	37	0	0	0	0	0	0	0	36.73	0	0	12.6
2015	12	11	10	55	33	36	0	0	0	0	0	0	0	36.84	0	0	12.6
2015	12	11	11	5	33	37	0	0	0	0	0	0	0	37.06	0	0	12.8
2015	12	11	11	15	33	36	0	0	0	0	0	0	0	37.11	0	0	12.6
2015	12	11	11	25	33	36	0	0	0	0	0	0	0	37.18	0	0	12.8
2015	12	11	11	35	33	37	0	0	0	0	0	0	0	37.24	0	0	12.8
2015	12	11	11	45	33	37	0	0	0	0	0	0	0	37.33	0	0	12.8
2015	12	11	11	55	33	37	0	0	0	0	0	0	0	37.33	0	0	12.8
2015	12	11	12	5	33	38	0	0	0	0	0	0	0	37.35	0	0	12.8
2015	12	11	12	15	33	37	0	0	0	0	0	0	0	37.35	0	0	12.6
2015	12	11	12	25	33	37	0	0	0	0	0	0	0	37.2	0	0	12.6
2015	12	11	12	35	33	37	0	0	0	0	0	0	0	37.31	0	0	12.8
2015	12	11	12	45	33	37	0	0	0	0	0	0	0	37.35	0	0	12.6
2015	12	11	12	55	33	37	0	0	0	0	0	0	0	37.31	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	13	5	33	37	0	0	0	0	0	0	0	37.27	0	0	12.6
2015	12	11	13	15	33	37	0	0	0	0	0	0	0	37.26	0	0	12.6
2015	12	11	13	25	33	37	0	0	0	0	0	0	0	37.26	0	0	12.6
2015	12	11	13	35	33	37	0	0	0	0	0	0	0	37.24	0	0	12.6
2015	12	11	13	45	33	36	0	0	0	0	0	0	0	37.22	0	0	12.6
2015	12	11	13	55	33	36	0	0	0	0	0	0	0	37.24	0	0	12.6
2015	12	11	14	5	33	36	0	0	0	0	0	0	0	37.2	0	0	12.6
2015	12	11	14	15	33	37	0	0	0	0	0	0	0	37.2	0	0	12.6
2015	12	11	14	25	33	37	0	0	0	0	0	0	0	37.18	0	0	12.6
2015	12	11	14	35	33	37	0	0	0	0	0	0	0	37.13	0	0	12.4
2015	12	11	14	45	33	36	34	0	0	0	0	0	0	37.09	0	0	12.4
2015	12	11	14	55	33	37	0	0	0	0	0	0	0	37.09	0	0	12.4
2015	12	11	15	5	33	37	0	0	0	0	0	0	0	37.09	0	0	12.4
2015	12	11	15	15	33	37	0	0	0	0	0	0	0	37.08	0	0	12.4
2015	12	11	15	25	33	37	0	0	0	0	0	0	0	37.06	0	0	12.4
2015	12	11	15	35	33	37	0	0	0	0	0	0	0	37.04	0	0	12.2
2015	12	11	15	45	33	37	0	0	0	0	0	0	0	37	0	0	12.2
2015	12	11	15	55	33	36	0	0	0	0	0	0	0	37	0	0	12.2
2015	12	11	16	5	33	36	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	16	15	33	37	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	16	25	33	36	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	16	35	33	37	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	16	45	33	36	0	0	0	0	0	0	0	36.97	0	0	12
2015	12	11	16	55	33	37	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	17	5	33	36	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	17	15	33	37	0	0	0	0	0	0	0	36.99	0	0	12
2015	12	11	17	25	33	36	0	0	0	0	0	0	0	37	0	0	12
2015	12	11	17	35	33	37	0	0	0	0	0	0	0	37	0	0	12
2015	12	11	17	45	33	37	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	17	55	33	37	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	18	5	33	37	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	18	15	33	37	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	18	25	33	36	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	18	35	33	37	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	11	18	45	33	38	0	0	0	0	0	0	0	37.02	0	0	12
2015	12	11	18	55	33	37	0	0	0	0	0	0	0	37.04	0	0	12
2015	12	11	19	5	33	37	0	0	0	0	0	0	0	37	0	0	12
2015	12	11	19	15	33	36	0	0	0	0	0	0	0	37	0	0	12
2015	12	11	19	25	33	37	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	11	19	35	33	37	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	11	19	45	33	37	0	0	0	0	0	0	0	37	0	0	11.8
2015	12	11	19	55	33	37	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	11	20	5	33	37	0	0	0	0	0	0	0	36.99	0	0	11.8
2015	12	11	20	15	33	37	0	0	0	0	0	0	0	36.97	0	0	11.8
2015	12	11	20	25	33	36	0	0	0	0	0	0	0	36.95	0	0	11.8
2015	12	11	20	35	33	37	0	0	0	0	0	0	0	36.93	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	11	20	45	33	37	0	0	0	0	0	0	0	36.93	0	0	11.8
2015	12	11	20	55	33	37	0	0	0	0	0	0	0	36.9	0	0	11.8
2015	12	11	21	5	33	37	0	0	0	0	0	0	0	36.9	0	0	11.8
2015	12	11	21	15	33	36	0	0	0	0	0	0	0	36.88	0	0	11.8
2015	12	11	21	25	33	36	0	0	0	0	0	0	0	36.86	0	0	11.8
2015	12	11	21	35	33	37	0	0	0	0	0	0	0	36.84	0	0	11.8
2015	12	11	21	45	33	37	0	0	0	0	0	0	0	36.82	0	0	11.8
2015	12	11	21	55	33	37	0	0	0	0	0	0	0	36.81	0	0	11.8
2015	12	11	22	5	33	36	0	0	0	0	0	0	0	36.79	0	0	11.8
2015	12	11	22	15	33	37	0	0	0	0	0	0	0	36.77	0	0	11.8
2015	12	11	22	25	33	37	0	0	0	0	0	0	0	36.75	0	0	11.8
2015	12	11	22	35	33	36	0	0	0	0	0	0	0	36.75	0	0	11.8
2015	12	11	22	45	33	36	0	0	0	0	0	0	0	36.73	0	0	11.8
2015	12	11	22	55	33	36	0	0	0	0	0	0	0	36.72	0	0	11.8
2015	12	11	23	5	33	38	0	0	0	0	0	0	0	36.7	0	0	11.8
2015	12	11	23	15	33	37	0	0	0	0	0	0	0	36.68	0	0	11.8
2015	12	11	23	25	33	37	0	0	0	0	0	0	0	36.66	0	0	11.8
2015	12	11	23	35	33	38	0	0	0	0	0	0	0	36.64	0	0	11.8
2015	12	11	23	45	33	37	0	0	0	0	0	0	0	36.64	0	0	11.8
2015	12	11	23	55	33	37	0	0	0	0	0	0	0	36.63	0	0	11.8
2015	12	12	0	5	33	36	0	0	0	0	0	0	0	36.61	0	0	11.8
2015	12	12	0	15	33	37	0	0	0	0	0	0	0	36.59	0	0	11.8
2015	12	12	0	25	33	37	0	0	0	0	0	0	0	36.57	0	0	11.8
2015	12	12	0	35	33	37	0	0	0	0	0	0	0	36.57	0	0	11.8
2015	12	12	0	45	33	37	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	12	0	55	33	37	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	12	1	5	33	37	0	0	0	0	0	0	0	36.54	0	0	11.8
2015	12	12	1	15	33	37	0	0	0	0	0	0	0	36.52	0	0	11.8
2015	12	12	1	25	33	37	0	0	0	0	0	0	0	36.5	0	0	11.8
2015	12	12	1	35	33	37	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	12	1	45	33	36	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	12	1	55	33	37	0	0	0	0	0	0	0	36.46	0	0	11.8
2015	12	12	2	5	33	36	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	12	2	15	33	37	0	0	0	0	0	0	0	36.43	0	0	11.8
2015	12	12	2	25	33	37	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	12	2	35	33	37	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	12	2	45	33	37	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	12	2	55	33	37	0	0	0	0	0	0	0	36.36	0	0	11.8
2015	12	12	3	5	33	37	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	12	3	15	33	37	0	0	0	0	0	0	0	36.32	0	0	11.8
2015	12	12	3	25	33	37	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	12	3	35	33	37	0	0	0	0	0	0	0	36.28	0	0	11.8
2015	12	12	3	45	33	37	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	12	3	55	33	37	0	0	0	0	0	0	0	36.23	0	0	11.6
2015	12	12	4	5	33	36	0	0	0	0	0	0	0	36.21	0	0	11.6
2015	12	12	4	15	33	37	0	0	0	0	0	0	0	36.21	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	4	25	33	37	0	0	0	0	0	0	0	36.18	0	0	11.6
2015	12	12	4	35	33	37	0	0	0	0	0	0	0	36.16	0	0	11.6
2015	12	12	4	45	33	37	0	0	0	0	0	0	0	36.12	0	0	11.6
2015	12	12	4	55	33	37	0	0	0	0	0	0	0	36.1	0	0	11.6
2015	12	12	5	5	33	37	0	0	0	0	0	0	0	36.09	0	0	11.6
2015	12	12	5	15	33	37	0	0	0	0	0	0	0	36.07	0	0	11.6
2015	12	12	5	25	33	36	0	0	0	0	0	0	0	36.03	0	0	11.6
2015	12	12	5	35	33	37	0	0	0	0	0	0	0	36.01	0	0	11.6
2015	12	12	5	45	33	37	0	0	0	0	0	0	0	35.98	0	0	11.6
2015	12	12	5	55	33	37	0	0	0	0	0	0	0	35.96	0	0	11.6
2015	12	12	6	5	33	37	0	0	0	0	0	0	0	35.92	0	0	11.6
2015	12	12	6	15	33	37	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	12	6	25	33	38	0	0	0	0	0	0	0	35.89	0	0	11.6
2015	12	12	6	35	33	37	0	0	0	0	0	0	0	35.85	0	0	11.6
2015	12	12	6	45	33	37	0	0	0	0	0	0	0	35.85	0	0	11.6
2015	12	12	6	55	33	36	0	0	0	0	0	0	0	35.82	0	0	11.6
2015	12	12	7	5	33	37	0	0	0	0	0	0	0	35.8	0	0	11.6
2015	12	12	7	15	33	36	0	0	0	0	0	0	0	35.78	0	0	11.6
2015	12	12	7	25	33	37	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	12	7	35	33	37	0	0	0	0	0	0	0	35.8	0	0	12
2015	12	12	7	45	33	37	0	0	0	0	0	0	0	35.8	0	0	12.2
2015	12	12	7	55	33	38	0	0	0	0	0	0	0	35.85	0	0	12.4
2015	12	12	8	5	33	37	0	0	0	0	0	0	0	35.89	0	0	12.4
2015	12	12	8	15	33	37	0	0	0	0	0	0	0	35.92	0	0	12.6
2015	12	12	8	25	33	37	0	0	0	0	0	0	0	36	0	0	12.6
2015	12	12	8	35	33	37	0	0	0	0	0	0	0	36.07	0	0	12.8
2015	12	12	8	45	33	37	0	0	0	0	0	0	0	36.14	0	0	12.8
2015	12	12	8	55	33	37	0	0	0	0	0	0	0	36.19	0	0	12.8
2015	12	12	9	5	33	37	0	0	0	0	0	0	0	36.28	0	0	12.8
2015	12	12	9	15	33	37	0	0	0	0	0	0	0	36.32	0	0	12.8
2015	12	12	9	25	33	37	0	0	0	0	0	0	0	36.37	0	0	13
2015	12	12	9	35	33	37	0	0	0	0	0	0	0	36.45	0	0	13
2015	12	12	9	45	33	38	0	0	0	0	0	0	0	36.54	0	0	13
2015	12	12	9	55	33	37	0	0	0	0	0	0	0	36.61	0	0	13
2015	12	12	10	5	33	37	0	0	0	0	0	0	0	36.64	0	0	13.2
2015	12	12	10	15	33	37	0	0	0	0	0	0	0	36.72	0	0	13.2
2015	12	12	10	25	33	37	0	0	0	0	0	0	0	36.77	0	0	13.2
2015	12	12	10	35	33	37	0	0	0	0	0	0	0	36.79	0	0	13.4
2015	12	12	10	45	33	37	0	0	0	0	0	0	0	36.84	0	0	13.4
2015	12	12	10	55	33	37	0	0	0	0	0	0	0	36.88	0	0	13.6
2015	12	12	11	5	33	37	0	0	0	0	0	0	0	36.88	0	0	13.8
2015	12	12	11	15	33	37	0	0	0	0	0	0	0	36.93	0	0	13.8
2015	12	12	11	25	33	37	0	0	0	0	0	0	0	36.9	0	0	13.8
2015	12	12	11	35	33	37	0	0	0	0	0	0	0	36.93	0	0	13.8
2015	12	12	11	45	33	36	0	0	0	0	0	0	0	36.95	0	0	13.8
2015	12	12	11	55	33	36	0	0	0	0	0	0	0	36.97	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	12	5	33	37	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	12	12	15	33	37	0	0	0	0	0	0	0	36.99	0	0	13.8
2015	12	12	12	25	33	36	0	0	0	0	0	0	0	36.99	0	0	13.8
2015	12	12	12	35	33	37	0	0	0	0	0	0	0	36.99	0	0	13.8
2015	12	12	12	45	33	37	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	12	12	55	33	37	0	0	0	0	0	0	0	36.86	0	0	13.8
2015	12	12	13	5	33	36	0	0	0	0	0	0	0	36.99	0	0	13.8
2015	12	12	13	15	33	37	0	0	0	0	0	0	0	36.93	0	0	13.8
2015	12	12	13	25	33	37	0	0	0	0	0	0	0	36.88	0	0	13.8
2015	12	12	13	35	33	36	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	12	13	45	33	37	0	0	0	0	0	0	0	36.95	0	0	13.8
2015	12	12	13	55	33	37	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	12	14	5	33	37	0	0	0	0	0	0	0	36.97	0	0	13.8
2015	12	12	14	15	33	37	0	0	0	0	0	0	0	36.95	0	0	13.8
2015	12	12	14	25	33	38	0	0	0	0	0	0	0	36.91	0	0	13.8
2015	12	12	14	35	33	37	0	0	0	0	0	0	0	36.9	0	0	13.8
2015	12	12	14	45	33	37	0	0	0	0	0	0	0	36.79	0	0	13.2
2015	12	12	14	55	33	37	0	0	0	0	0	0	0	36.52	0	0	12.8
2015	12	12	15	5	33	37	0	0	0	0	0	0	0	36.48	0	0	12.6
2015	12	12	15	15	33	37	0	0	0	0	0	0	0	36.46	0	0	12.6
2015	12	12	15	25	33	37	0	0	0	0	0	0	0	36.46	0	0	12.4
2015	12	12	15	35	33	37	0	0	0	0	0	0	0	36.48	0	0	12.2
2015	12	12	15	45	33	37	0	0	0	0	0	0	0	36.48	0	0	12.2
2015	12	12	15	55	33	37	0	0	0	0	0	0	0	36.5	0	0	12.2
2015	12	12	16	5	33	37	0	0	0	0	0	0	0	36.52	0	0	12.2
2015	12	12	16	15	33	36	0	0	0	0	0	0	0	36.54	0	0	12
2015	12	12	16	25	33	37	0	0	0	0	0	0	0	36.55	0	0	12
2015	12	12	16	35	33	37	0	0	0	0	0	0	0	36.55	0	0	12
2015	12	12	16	45	33	37	0	0	0	0	0	0	0	36.57	0	0	12
2015	12	12	16	55	33	36	0	0	0	0	0	0	0	36.57	0	0	12
2015	12	12	17	5	33	37	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	12	17	15	33	37	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	12	17	25	33	37	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	12	17	35	33	36	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	12	17	45	33	37	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	17	55	33	36	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	18	5	33	37	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	18	15	33	37	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	18	25	33	37	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	18	35	33	37	0	0	0	0	0	0	0	36.63	0	0	12
2015	12	12	18	45	33	38	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	12	18	55	33	37	0	0	0	0	0	0	0	36.61	0	0	12
2015	12	12	19	5	33	37	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	12	19	15	33	37	0	0	0	0	0	0	0	36.59	0	0	12
2015	12	12	19	25	33	37	0	0	0	0	0	0	0	36.57	0	0	12
2015	12	12	19	35	33	36	0	0	0	0	0	0	0	36.57	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	12	19	45	33	37	0	0	0	0	0	0	0	36.55	0	0	12
2015	12	12	19	55	33	36	0	0	0	0	0	0	0	36.54	0	0	12
2015	12	12	20	5	33	36	0	0	0	0	0	0	0	36.54	0	0	12
2015	12	12	20	15	33	36	0	0	0	0	0	0	0	36.54	0	0	12
2015	12	12	20	25	33	37	0	0	0	0	0	0	0	36.52	0	0	12
2015	12	12	20	35	33	37	0	0	0	0	0	0	0	36.5	0	0	12
2015	12	12	20	45	33	38	0	0	0	0	0	0	0	36.48	0	0	12
2015	12	12	20	55	33	38	0	0	0	0	0	0	0	36.48	0	0	11.8
2015	12	12	21	5	33	37	0	0	0	0	0	0	0	36.46	0	0	11.8
2015	12	12	21	15	33	37	0	0	0	0	0	0	0	36.45	0	0	11.8
2015	12	12	21	25	33	37	0	0	0	0	0	0	0	36.43	0	0	11.8
2015	12	12	21	35	33	36	0	0	0	0	0	0	0	36.41	0	0	11.8
2015	12	12	21	45	33	37	0	0	0	0	0	0	0	36.41	0	0	11.8
2015	12	12	21	55	33	37	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	12	22	5	33	37	0	0	0	0	0	0	0	36.39	0	0	11.8
2015	12	12	22	15	33	37	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	12	22	25	33	37	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	12	22	35	33	37	0	0	0	0	0	0	0	36.37	0	0	11.8
2015	12	12	22	45	33	37	0	0	0	0	0	0	0	36.36	0	0	11.8
2015	12	12	22	55	33	36	0	0	0	0	0	0	0	36.36	0	0	11.8
2015	12	12	23	5	33	37	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	12	23	15	33	37	0	0	0	0	0	0	0	36.34	0	0	11.8
2015	12	12	23	25	33	37	0	0	0	0	0	0	0	36.32	0	0	11.8
2015	12	12	23	35	33	36	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	12	23	45	33	37	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	12	23	55	33	37	0	0	0	0	0	0	0	36.3	0	0	11.8
2015	12	13	0	5	33	37	0	0	0	0	0	0	0	36.28	0	0	11.8
2015	12	13	0	15	33	36	0	0	0	0	0	0	0	36.27	0	0	11.8
2015	12	13	0	25	33	37	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	13	0	35	33	36	0	0	0	0	0	0	0	36.25	0	0	11.8
2015	12	13	0	45	33	37	0	0	0	0	0	0	0	36.21	0	0	11.8
2015	12	13	0	55	33	37	0	0	0	0	0	0	0	36.19	0	0	11.8
2015	12	13	1	5	33	37	0	0	0	0	0	0	0	36.18	0	0	11.8
2015	12	13	1	15	33	36	0	0	0	0	0	0	0	36.16	0	0	11.8
2015	12	13	1	25	33	36	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	1	35	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	1	45	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	13	1	55	33	36	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	13	2	5	33	37	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	13	2	15	33	37	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	13	2	25	33	37	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	13	2	35	33	37	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	13	2	45	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	13	2	55	33	36	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	13	3	5	33	38	0	0	0	0	0	0	0	35.91	0	0	11.8
2015	12	13	3	15	33	38	0	0	0	0	0	0	0	35.89	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	3	25	33	37	0	0	0	0	0	0	0	35.85	0	0	11.8
2015	12	13	3	35	33	37	0	0	0	0	0	0	0	35.83	0	0	11.8
2015	12	13	3	45	33	37	0	0	0	0	0	0	0	35.82	0	0	11.8
2015	12	13	3	55	33	37	0	0	0	0	0	0	0	35.78	0	0	11.8
2015	12	13	4	5	33	36	0	0	0	0	0	0	0	35.76	0	0	11.8
2015	12	13	4	15	33	37	0	0	0	0	0	0	0	35.71	0	0	11.8
2015	12	13	4	25	33	37	0	0	0	0	0	0	0	35.69	0	0	11.8
2015	12	13	4	35	33	37	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	13	4	45	33	37	0	0	0	0	0	0	0	35.64	0	0	11.8
2015	12	13	4	55	33	38	0	0	0	0	0	0	0	35.6	0	0	11.8
2015	12	13	5	5	33	38	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	13	5	15	33	37	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	13	5	25	33	37	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	13	5	35	33	37	0	0	0	0	0	0	0	35.49	0	0	11.6
2015	12	13	5	45	33	37	0	0	0	0	0	0	0	35.46	0	0	11.6
2015	12	13	5	55	33	37	0	0	0	0	0	0	0	35.42	0	0	11.6
2015	12	13	6	5	33	37	0	0	0	0	0	0	0	35.4	0	0	11.6
2015	12	13	6	15	33	37	0	0	0	0	0	0	0	35.37	0	0	11.6
2015	12	13	6	25	33	37	0	0	0	0	0	0	0	35.35	0	0	11.6
2015	12	13	6	35	33	37	0	0	0	0	0	0	0	35.31	0	0	11.6
2015	12	13	6	45	33	37	0	0	0	0	0	0	0	35.29	0	0	11.6
2015	12	13	6	55	33	37	0	0	0	0	0	0	0	35.28	0	0	11.6
2015	12	13	7	5	33	37	0	0	0	0	0	0	0	35.24	0	0	11.6
2015	12	13	7	15	33	37	0	0	0	0	0	0	0	35.22	0	0	11.6
2015	12	13	7	25	33	37	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	13	7	35	33	37	0	0	0	0	0	0	0	35.19	0	0	12
2015	12	13	7	45	33	37	0	0	0	0	0	0	0	35.2	0	0	12.2
2015	12	13	7	55	33	38	0	0	0	0	0	0	0	35.22	0	0	12.4
2015	12	13	8	5	33	37	0	0	0	0	0	0	0	35.26	0	0	12.4
2015	12	13	8	15	33	37	0	0	0	0	0	0	0	35.29	0	0	12.6
2015	12	13	8	25	33	37	0	0	0	0	0	0	0	35.33	0	0	12.8
2015	12	13	8	35	33	37	0	0	0	0	0	0	0	35.38	0	0	12.8
2015	12	13	8	45	33	37	0	0	0	0	0	0	0	35.44	0	0	12.8
2015	12	13	8	55	33	38	0	0	0	0	0	0	0	35.49	0	0	13
2015	12	13	9	5	33	37	0	0	0	0	0	0	0	35.55	0	0	13
2015	12	13	9	15	33	37	0	0	0	0	0	0	0	35.6	0	0	13
2015	12	13	9	25	33	38	0	0	0	0	0	0	0	35.65	0	0	13
2015	12	13	9	35	33	37	0	0	0	0	0	0	0	35.67	0	0	13
2015	12	13	9	45	33	37	0	0	0	0	0	0	0	35.71	0	0	12.8
2015	12	13	9	55	33	37	0	0	0	0	0	0	0	35.73	0	0	13.2
2015	12	13	10	5	33	37	0	0	0	0	0	0	0	35.82	0	0	13.2
2015	12	13	10	15	33	37	0	0	0	0	0	0	0	35.8	0	0	13.2
2015	12	13	10	25	33	37	0	0	0	0	0	0	0	35.89	0	0	13.2
2015	12	13	10	35	33	37	0	0	0	0	0	0	0	35.83	0	0	12.6
2015	12	13	10	45	33	37	0	0	0	0	0	0	0	35.8	0	0	13.2
2015	12	13	10	55	33	37	0	0	0	0	0	0	0	35.87	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	11	5	33	38	0	0	0	0	0	0	0	35.98	0	0	13.8
2015	12	13	11	15	33	38	0	0	0	0	0	0	0	36.01	0	0	13
2015	12	13	11	25	33	37	0	0	0	0	0	0	0	36.01	0	0	13.4
2015	12	13	11	35	33	37	0	0	0	0	0	0	0	36.03	0	0	13.6
2015	12	13	11	45	33	37	0	0	0	0	0	0	0	36.05	0	0	13.8
2015	12	13	11	55	33	37	0	0	0	0	0	0	0	36.12	0	0	13.8
2015	12	13	12	5	33	37	0	0	0	0	0	0	0	36.12	0	0	13.8
2015	12	13	12	15	33	37	0	0	0	0	0	0	0	36.14	0	0	13.6
2015	12	13	12	25	33	37	0	0	0	0	0	0	0	36.1	0	0	13.6
2015	12	13	12	35	33	38	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	13	12	45	33	37	0	0	0	0	0	0	0	35.91	0	0	12.4
2015	12	13	12	55	33	37	0	0	0	0	0	0	0	35.82	0	0	12.6
2015	12	13	13	5	33	37	0	0	0	0	0	0	0	35.76	0	0	12.4
2015	12	13	13	15	33	37	0	0	0	0	0	0	0	35.73	0	0	12.2
2015	12	13	13	25	33	37	0	0	0	0	0	0	0	35.69	0	0	12.2
2015	12	13	13	35	33	37	0	0	0	0	0	0	0	35.67	0	0	12.2
2015	12	13	13	45	33	37	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	13	13	55	33	37	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	13	14	5	33	38	0	0	0	0	0	0	0	35.65	0	0	12.2
2015	12	13	14	15	33	37	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	13	14	25	33	37	0	0	0	0	0	0	0	35.64	0	0	12
2015	12	13	14	35	33	37	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	13	14	45	33	37	0	0	0	0	0	0	0	35.67	0	0	12
2015	12	13	14	55	33	37	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	13	15	5	33	36	0	0	0	0	0	0	0	35.73	0	0	12
2015	12	13	15	15	33	37	0	0	0	0	0	0	0	35.73	0	0	12
2015	12	13	15	25	33	37	0	0	0	0	0	0	0	35.74	0	0	12
2015	12	13	15	35	33	38	0	0	0	0	0	0	0	35.78	0	0	12
2015	12	13	15	45	33	37	0	0	0	0	0	0	0	35.8	0	0	12
2015	12	13	15	55	33	37	0	0	0	0	0	0	0	35.82	0	0	12
2015	12	13	16	5	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	13	16	15	33	36	0	0	0	0	0	0	0	35.87	0	0	12
2015	12	13	16	25	33	37	0	0	0	0	0	0	0	35.91	0	0	12
2015	12	13	16	35	33	36	0	0	0	0	0	0	0	35.92	0	0	12
2015	12	13	16	45	33	37	0	0	0	0	0	0	0	35.94	0	0	12
2015	12	13	16	55	33	37	0	0	0	0	0	0	0	35.96	0	0	12
2015	12	13	17	5	33	37	0	0	0	0	0	0	0	35.98	0	0	12
2015	12	13	17	15	33	37	0	0	0	0	0	0	0	36	0	0	12
2015	12	13	17	25	33	37	0	0	0	0	0	0	0	36.01	0	0	12
2015	12	13	17	35	33	37	0	0	0	0	0	0	0	36.03	0	0	12
2015	12	13	17	45	33	37	0	0	0	0	0	0	0	36.05	0	0	12
2015	12	13	17	55	33	38	0	0	0	0	0	0	0	36.07	0	0	12
2015	12	13	18	5	33	37	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	13	18	15	33	37	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	13	18	25	33	37	0	0	0	0	0	0	0	36.09	0	0	12
2015	12	13	18	35	33	37	0	0	0	0	0	0	0	36.1	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	13	18	45	33	36	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	13	18	55	33	37	0	0	0	0	0	0	0	36.1	0	0	12
2015	12	13	19	5	33	37	0	0	0	0	0	0	0	36.12	0	0	12
2015	12	13	19	15	33	37	0	0	0	0	0	0	0	36.12	0	0	12
2015	12	13	19	25	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	19	35	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	19	45	33	36	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	19	55	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	20	5	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	20	15	33	38	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	20	25	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	13	20	35	33	36	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	20	45	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	20	55	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	5	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	15	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	25	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	35	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	45	33	36	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	21	55	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	22	5	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	22	15	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	22	25	33	37	0	0	0	0	0	0	0	36.14	0	0	11.8
2015	12	13	22	35	33	36	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	22	45	33	37	0	0	0	0	0	0	0	36.12	0	0	11.8
2015	12	13	22	55	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	13	23	5	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	13	23	15	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	13	23	25	33	37	0	0	0	0	0	0	0	36.1	0	0	11.8
2015	12	13	23	35	33	37	0	0	0	0	0	0	0	36.09	0	0	11.8
2015	12	13	23	45	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	13	23	55	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	14	0	5	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	14	0	15	33	37	0	0	0	0	0	0	0	36.07	0	0	11.8
2015	12	14	0	25	33	36	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	14	0	35	33	37	0	0	0	0	0	0	0	36.05	0	0	11.8
2015	12	14	0	45	33	37	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	14	0	55	33	37	0	0	0	0	0	0	0	36.03	0	0	11.8
2015	12	14	1	5	33	37	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	14	1	15	33	37	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	14	1	25	33	37	0	0	0	0	0	0	0	36.01	0	0	11.8
2015	12	14	1	35	33	37	0	0	0	0	0	0	0	36	0	0	11.8
2015	12	14	1	45	33	37	0	0	0	0	0	0	0	35.98	0	0	11.8
2015	12	14	1	55	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	14	2	5	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8
2015	12	14	2	15	33	37	0	0	0	0	0	0	0	35.96	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	2	25	33	37	0	0	0	0	0	0	0	35.94	0	0	11.8
2015	12	14	2	35	33	37	0	0	0	0	0	0	0	35.92	0	0	11.8
2015	12	14	2	45	33	36	0	0	0	0	0	0	0	35.91	0	0	11.6
2015	12	14	2	55	33	36	0	0	0	0	0	0	0	35.89	0	0	11.6
2015	12	14	3	5	33	37	0	0	0	0	0	0	0	35.89	0	0	11.6
2015	12	14	3	15	33	37	0	0	0	0	0	0	0	35.87	0	0	11.6
2015	12	14	3	25	33	37	0	0	0	0	0	0	0	35.85	0	0	11.6
2015	12	14	3	35	33	37	0	0	0	0	0	0	0	35.82	0	0	11.6
2015	12	14	3	45	33	37	0	0	0	0	0	0	0	35.82	0	0	11.6
2015	12	14	3	55	33	37	0	0	0	0	0	0	0	35.8	0	0	11.6
2015	12	14	4	5	33	37	0	0	0	0	0	0	0	35.78	0	0	11.6
2015	12	14	4	15	33	37	0	0	0	0	0	0	0	35.76	0	0	11.6
2015	12	14	4	25	33	37	0	0	0	0	0	0	0	35.74	0	0	11.6
2015	12	14	4	35	33	38	0	0	0	0	0	0	0	35.73	0	0	11.6
2015	12	14	4	45	33	37	0	0	0	0	0	0	0	35.71	0	0	11.6
2015	12	14	4	55	33	36	0	0	0	0	0	0	0	35.69	0	0	11.6
2015	12	14	5	5	33	37	0	0	0	0	0	0	0	35.67	0	0	11.6
2015	12	14	5	15	33	37	0	0	0	0	0	0	0	35.65	0	0	11.6
2015	12	14	5	25	33	37	0	0	0	0	0	0	0	35.64	0	0	11.6
2015	12	14	5	35	33	37	0	0	0	0	0	0	0	35.62	0	0	11.6
2015	12	14	5	45	33	37	0	0	0	0	0	0	0	35.6	0	0	11.6
2015	12	14	5	55	33	37	0	0	0	0	0	0	0	35.58	0	0	11.6
2015	12	14	6	5	33	37	0	0	0	0	0	0	0	35.56	0	0	11.6
2015	12	14	6	15	33	36	0	0	0	0	0	0	0	35.55	0	0	11.6
2015	12	14	6	25	33	37	0	0	0	0	0	0	0	35.51	0	0	11.6
2015	12	14	6	35	33	37	0	0	0	0	0	0	0	35.49	0	0	11.6
2015	12	14	6	45	33	37	0	0	0	0	0	0	0	35.47	0	0	11.6
2015	12	14	6	55	33	37	0	0	0	0	0	0	0	35.46	0	0	11.6
2015	12	14	7	5	33	37	0	0	0	0	0	0	0	35.44	0	0	11.6
2015	12	14	7	15	33	37	0	0	0	0	0	0	0	35.44	0	0	11.6
2015	12	14	7	25	33	37	0	0	0	0	0	0	0	35.42	0	0	11.8
2015	12	14	7	35	33	38	0	0	0	0	0	0	0	35.4	0	0	12
2015	12	14	7	45	33	37	0	0	0	0	0	0	0	35.44	0	0	12
2015	12	14	7	55	33	37	0	0	0	0	0	0	0	35.46	0	0	12.2
2015	12	14	8	5	33	37	0	0	0	0	0	0	0	35.49	0	0	12.4
2015	12	14	8	15	33	37	0	0	0	0	0	0	0	35.53	0	0	12.4
2015	12	14	8	25	33	37	0	0	0	0	0	0	0	35.56	0	0	12.6
2015	12	14	8	35	33	37	0	0	0	0	0	0	0	35.62	0	0	12.6
2015	12	14	8	45	33	37	0	0	0	0	0	0	0	35.64	0	0	12.6
2015	12	14	8	55	33	36	0	0	0	0	0	0	0	35.67	0	0	12.8
2015	12	14	9	5	33	37	0	0	0	0	0	0	0	35.73	0	0	12.8
2015	12	14	9	15	33	37	0	0	0	0	0	0	0	35.78	0	0	12.8
2015	12	14	9	25	33	37	0	0	0	0	0	0	0	35.82	0	0	12.8
2015	12	14	9	35	33	38	0	0	0	0	0	0	0	35.89	0	0	12.8
2015	12	14	9	45	33	37	0	0	0	0	0	0	0	35.92	0	0	12.8
2015	12	14	9	55	33	37	0	0	0	0	0	0	0	35.98	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	10	5	33	37	0	0	0	0	0	0	0	36	0	0	12.8
2015	12	14	10	15	33	36	0	0	0	0	0	0	0	36.07	0	0	12.8
2015	12	14	10	25	33	37	0	0	0	0	0	0	0	36.1	0	0	13
2015	12	14	10	35	33	37	0	0	0	0	0	0	0	36.1	0	0	13
2015	12	14	10	45	33	37	0	0	0	0	0	0	0	36.12	0	0	13
2015	12	14	10	55	33	38	0	0	0	0	0	0	0	36.18	0	0	13
2015	12	14	11	5	33	36	3	0	0	0	0	0	0	36.18	0	0	13.2
2015	12	14	11	15	33	37	0	0	0	0	0	0	0	36.23	0	0	13.2
2015	12	14	11	25	33	37	0	0	0	0	0	0	0	36.25	0	0	13.4
2015	12	14	11	35	33	38	0	0	0	0	0	0	0	36.25	0	0	13.6
2015	12	14	11	45	33	37	0	0	0	0	0	0	0	36.3	0	0	14
2015	12	14	11	55	33	37	0	0	0	0	0	0	0	36.28	0	0	14
2015	12	14	12	5	33	37	0	0	0	0	0	0	0	36.3	0	0	14
2015	12	14	12	15	33	37	0	0	0	0	0	0	0	36.28	0	0	14
2015	12	14	12	25	33	37	0	0	0	0	0	0	0	36.3	0	0	14
2015	12	14	12	35	33	37	0	0	0	0	0	0	0	36.28	0	0	14
2015	12	14	12	45	33	37	0	0	0	0	0	0	0	36.28	0	0	14
2015	12	14	12	55	33	37	0	0	0	0	0	0	0	36.28	0	0	13.2
2015	12	14	13	5	33	37	0	0	0	0	0	0	0	36.27	0	0	13.4
2015	12	14	13	15	33	37	0	0	0	0	0	0	0	36.19	0	0	13.4
2015	12	14	13	25	33	36	0	0	0	0	0	0	0	36.19	0	0	14
2015	12	14	13	35	33	36	0	0	0	0	0	0	0	36.16	0	0	13.4
2015	12	14	13	45	33	37	0	0	0	0	0	0	0	36.03	0	0	12.4
2015	12	14	13	55	33	36	0	0	0	0	0	0	0	36.03	0	0	13.8
2015	12	14	14	5	33	38	0	0	0	0	0	0	0	36.07	0	0	14
2015	12	14	14	15	33	37	0	0	0	0	0	0	0	36.07	0	0	14
2015	12	14	14	25	33	37	0	0	0	0	0	0	0	36.07	0	0	14
2015	12	14	14	35	33	37	0	0	0	0	0	0	0	36.07	0	0	14
2015	12	14	14	45	33	37	0	0	0	0	0	0	0	36.03	0	0	14
2015	12	14	14	55	33	36	0	0	0	0	0	0	0	36.01	0	0	14
2015	12	14	15	5	33	37	0	0	0	0	0	0	0	35.96	0	0	13.6
2015	12	14	15	15	33	37	0	0	0	0	0	0	0	35.92	0	0	12.8
2015	12	14	15	25	33	36	0	0	0	0	0	0	0	35.91	0	0	12.4
2015	12	14	15	35	33	37	0	0	0	0	0	0	0	35.89	0	0	12.2
2015	12	14	15	45	33	36	0	0	0	0	0	0	0	35.87	0	0	12.2
2015	12	14	15	55	33	37	0	0	0	0	0	0	0	35.87	0	0	12
2015	12	14	16	5	33	36	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	16	15	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	16	25	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	16	35	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	16	45	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	16	55	33	36	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	14	17	5	33	37	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	14	17	15	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	17	25	33	37	0	0	0	0	0	0	0	35.85	0	0	12
2015	12	14	17	35	33	37	0	0	0	0	0	0	0	35.85	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	14	17	45	33	37	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	14	17	55	33	37	0	0	0	0	0	0	0	35.83	0	0	12
2015	12	14	18	5	33	37	0	0	0	0	0	0	0	35.82	0	0	12
2015	12	14	18	15	33	37	0	0	0	0	0	0	0	35.82	0	0	12
2015	12	14	18	25	33	38	0	0	0	0	0	0	0	35.82	0	0	12
2015	12	14	18	35	33	37	0	0	0	0	0	0	0	35.8	0	0	12
2015	12	14	18	45	33	37	0	0	0	0	0	0	0	35.78	0	0	12
2015	12	14	18	55	33	37	0	0	0	0	0	0	0	35.78	0	0	12
2015	12	14	19	5	33	37	0	0	0	0	0	0	0	35.76	0	0	12
2015	12	14	19	15	33	37	0	0	0	0	0	0	0	35.74	0	0	12
2015	12	14	19	25	33	37	0	0	0	0	0	0	0	35.74	0	0	12
2015	12	14	19	35	33	38	0	0	0	0	0	0	0	35.73	0	0	12
2015	12	14	19	45	33	37	0	0	0	0	0	0	0	35.71	0	0	12
2015	12	14	19	55	33	37	0	0	0	0	0	0	0	35.69	0	0	12
2015	12	14	20	5	33	38	0	0	0	0	0	0	0	35.67	0	0	11.8
2015	12	14	20	15	33	37	0	0	0	0	0	0	0	35.65	0	0	11.8
2015	12	14	20	25	33	37	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	14	20	35	33	37	0	0	0	0	0	0	0	35.62	0	0	11.8
2015	12	14	20	45	33	37	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	14	20	55	33	37	0	0	0	0	0	0	0	35.58	0	0	11.8
2015	12	14	21	5	33	37	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	14	21	15	33	37	0	0	0	0	0	0	0	35.55	0	0	11.8
2015	12	14	21	25	33	36	0	0	0	0	0	0	0	35.53	0	0	11.8
2015	12	14	21	35	33	36	0	0	0	0	0	0	0	35.51	0	0	11.8
2015	12	14	21	45	33	37	0	0	0	0	0	0	0	35.49	0	0	11.8
2015	12	14	21	55	33	37	0	0	0	0	0	0	0	35.47	0	0	11.8
2015	12	14	22	5	33	37	0	0	0	0	0	0	0	35.46	0	0	11.8
2015	12	14	22	15	33	37	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	14	22	25	33	37	0	0	0	0	0	0	0	35.44	0	0	11.8
2015	12	14	22	35	33	37	0	0	0	0	0	0	0	35.42	0	0	11.8
2015	12	14	22	45	33	38	0	0	0	0	0	0	0	35.4	0	0	11.8
2015	12	14	22	55	33	37	0	0	0	0	0	0	0	35.38	0	0	11.8
2015	12	14	23	5	33	37	0	0	0	0	0	0	0	35.37	0	0	11.8
2015	12	14	23	15	33	38	0	0	0	0	0	0	0	35.35	0	0	11.8
2015	12	14	23	25	33	37	0	0	0	0	0	0	0	35.33	0	0	11.8
2015	12	14	23	35	33	38	0	0	0	0	0	0	0	35.33	0	0	11.8
2015	12	14	23	45	33	37	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	14	23	55	33	37	0	0	0	0	0	0	0	35.29	0	0	11.8
2015	12	15	0	5	33	38	0	0	0	0	0	0	0	35.28	0	0	11.8
2015	12	15	0	15	33	37	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	15	0	25	33	37	0	0	0	0	0	0	0	35.26	0	0	11.8
2015	12	15	0	35	33	37	0	0	0	0	0	0	0	35.22	0	0	11.8
2015	12	15	0	45	33	36	0	0	0	0	0	0	0	35.2	0	0	11.8
2015	12	15	0	55	33	37	0	0	0	0	0	0	0	35.19	0	0	11.8
2015	12	15	1	5	33	37	0	0	0	0	0	0	0	35.17	0	0	11.8
2015	12	15	1	15	33	38	0	0	0	0	0	0	0	35.17	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	1	25	33	37	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	15	1	35	33	36	0	0	0	0	0	0	0	35.13	0	0	11.8
2015	12	15	1	45	33	38	0	0	0	0	0	0	0	35.11	0	0	11.8
2015	12	15	1	55	33	37	0	0	0	0	0	0	0	35.1	0	0	11.8
2015	12	15	2	5	33	37	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	15	2	15	33	37	0	0	0	0	0	0	0	35.08	0	0	11.8
2015	12	15	2	25	33	37	0	0	0	0	0	0	0	35.06	0	0	11.8
2015	12	15	2	35	33	37	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	15	2	45	33	37	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	15	2	55	33	37	0	0	0	0	0	0	0	35.02	0	0	11.8
2015	12	15	3	5	33	38	0	0	0	0	0	0	0	35.01	0	0	11.8
2015	12	15	3	15	33	37	0	0	0	0	0	0	0	34.99	0	0	11.8
2015	12	15	3	25	33	37	0	0	0	0	0	0	0	34.97	0	0	11.8
2015	12	15	3	35	33	37	0	0	0	0	0	0	0	34.95	0	0	11.8
2015	12	15	3	45	33	36	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	15	3	55	33	37	0	0	0	0	0	0	0	34.93	0	0	11.8
2015	12	15	4	5	33	37	0	0	0	0	0	0	0	34.92	0	0	11.8
2015	12	15	4	15	33	37	0	0	0	0	0	0	0	34.9	0	0	11.8
2015	12	15	4	25	33	37	0	0	0	0	0	0	0	34.88	0	0	11.8
2015	12	15	4	35	33	37	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	15	4	45	33	36	0	0	0	0	0	0	0	34.84	0	0	11.8
2015	12	15	4	55	33	37	0	0	0	0	0	0	0	34.83	0	0	11.6
2015	12	15	5	5	33	37	0	0	0	0	0	0	0	34.81	0	0	11.6
2015	12	15	5	15	33	38	0	0	0	0	0	0	0	34.79	0	0	11.6
2015	12	15	5	25	33	38	0	0	0	0	0	0	0	34.75	0	0	11.6
2015	12	15	5	35	33	37	0	0	0	0	0	0	0	34.75	0	0	11.6
2015	12	15	5	45	33	37	0	0	0	0	0	0	0	34.74	0	0	11.6
2015	12	15	5	55	33	38	0	0	0	0	0	0	0	34.72	0	0	11.6
2015	12	15	6	5	33	37	0	0	0	0	0	0	0	34.68	0	0	11.6
2015	12	15	6	15	33	37	0	0	0	0	0	0	0	34.68	0	0	11.6
2015	12	15	6	25	33	37	0	0	0	0	0	0	0	34.65	0	0	11.6
2015	12	15	6	35	33	37	0	0	0	0	0	0	0	34.63	0	0	11.6
2015	12	15	6	45	33	38	0	0	0	0	0	0	0	34.63	0	0	11.6
2015	12	15	6	55	33	37	0	0	0	0	0	0	0	34.61	0	0	11.6
2015	12	15	7	5	33	37	0	0	0	0	0	0	0	34.61	0	0	11.6
2015	12	15	7	15	33	37	0	0	0	0	0	0	0	34.59	0	0	11.6
2015	12	15	7	25	33	38	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	15	7	35	33	38	0	0	0	0	0	0	0	34.59	0	0	12
2015	12	15	7	45	33	37	0	0	0	0	0	0	0	34.59	0	0	12
2015	12	15	7	55	33	37	0	0	0	0	0	0	0	34.63	0	0	12.2
2015	12	15	8	5	33	37	0	0	0	0	0	0	0	34.66	0	0	12.4
2015	12	15	8	15	33	38	0	0	0	0	0	0	0	34.7	0	0	12.6
2015	12	15	8	25	33	37	0	0	0	0	0	0	0	34.74	0	0	12.6
2015	12	15	8	35	33	37	0	0	0	0	0	0	0	34.77	0	0	12.8
2015	12	15	8	45	33	38	0	0	0	0	0	0	0	34.81	0	0	12.8
2015	12	15	8	55	33	37	0	0	0	0	0	0	0	34.88	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	9	5	33	37	0	0	0	0	0	0	0	34.92	0	0	12.8
2015	12	15	9	15	33	37	0	0	0	0	0	0	0	34.99	0	0	13
2015	12	15	9	25	33	37	0	0	0	0	0	0	0	35.02	0	0	13
2015	12	15	9	35	33	38	0	0	0	0	0	0	0	35.06	0	0	13
2015	12	15	9	45	33	37	0	0	0	0	0	0	0	35.11	0	0	13.2
2015	12	15	9	55	33	37	0	0	0	0	0	0	0	35.15	0	0	13.2
2015	12	15	10	5	33	36	0	0	0	0	0	0	0	35.17	0	0	13.2
2015	12	15	10	15	33	37	0	0	0	0	0	0	0	35.2	0	0	13.2
2015	12	15	10	25	33	37	0	0	0	0	0	0	0	35.24	0	0	13.4
2015	12	15	10	35	33	37	0	0	0	0	0	0	0	35.28	0	0	13.4
2015	12	15	10	45	33	37	0	0	0	0	0	0	0	35.31	0	0	13.6
2015	12	15	10	55	33	37	0	0	0	0	0	0	0	35.33	0	0	14
2015	12	15	11	5	33	37	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	15	11	15	33	38	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	15	11	25	33	37	1	0	0	0	0	0	0	35.4	0	0	14
2015	12	15	11	35	33	37	0	0	0	0	0	0	0	35.42	0	0	14
2015	12	15	11	45	33	37	0	0	0	0	0	0	0	35.44	0	0	14
2015	12	15	11	55	33	37	0	0	0	0	0	0	0	35.44	0	0	14
2015	12	15	12	5	33	36	0	0	0	0	0	0	0	35.46	0	0	14
2015	12	15	12	15	33	37	0	0	0	0	0	0	0	35.46	0	0	14
2015	12	15	12	25	33	37	0	0	0	0	0	0	0	35.47	0	0	14
2015	12	15	12	35	33	37	0	0	0	0	0	0	0	35.44	0	0	14
2015	12	15	12	45	33	37	0	0	0	0	0	0	0	35.46	0	0	14
2015	12	15	12	55	33	37	0	0	0	0	0	0	0	35.42	0	0	14
2015	12	15	13	5	33	38	0	0	0	0	0	0	0	35.4	0	0	14
2015	12	15	13	15	33	36	0	0	0	0	0	0	0	35.38	0	0	14
2015	12	15	13	25	33	36	0	0	0	0	0	0	0	35.37	0	0	14
2015	12	15	13	35	33	38	0	0	0	0	0	0	0	35.35	0	0	14
2015	12	15	13	45	33	36	0	0	0	0	0	0	0	35.33	0	0	14
2015	12	15	13	55	33	37	0	0	0	0	0	0	0	35.31	0	0	14
2015	12	15	14	5	33	37	0	0	0	0	0	0	0	35.28	0	0	14
2015	12	15	14	15	33	37	0	0	0	0	0	0	0	35.24	0	0	14
2015	12	15	14	25	33	38	0	0	0	0	0	0	0	35.2	0	0	14
2015	12	15	14	35	33	37	0	0	0	0	0	0	0	35.19	0	0	14
2015	12	15	14	45	33	37	0	0	0	0	0	0	0	35.13	0	0	14
2015	12	15	14	55	33	37	0	0	0	0	0	0	0	35.13	0	0	14
2015	12	15	15	5	33	37	0	0	0	0	0	0	0	35.08	0	0	14
2015	12	15	15	15	33	37	0	0	0	0	0	0	0	35.02	0	0	14
2015	12	15	15	25	33	37	0	0	0	0	0	0	0	35.01	0	0	12.8
2015	12	15	15	35	33	37	0	0	0	0	0	0	0	34.99	0	0	12.4
2015	12	15	15	45	33	37	0	0	0	0	0	0	0	34.97	0	0	12.2
2015	12	15	15	55	33	37	0	0	0	0	0	0	0	34.97	0	0	12.2
2015	12	15	16	5	33	37	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	16	15	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	16	25	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	16	35	33	37	0	0	0	0	0	0	0	34.95	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	15	16	45	33	37	0	0	0	0	0	0	0	34.93	0	0	12
2015	12	15	16	55	33	38	0	0	0	0	0	0	0	34.93	0	0	12
2015	12	15	17	5	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	17	15	33	37	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	17	25	33	37	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	17	35	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	17	45	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	17	55	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	18	5	33	37	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	18	15	33	38	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	18	25	33	37	0	0	0	0	0	0	0	34.97	0	0	12
2015	12	15	18	35	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	18	45	33	37	0	0	0	0	0	0	0	34.93	0	0	12
2015	12	15	18	55	33	37	0	0	0	0	0	0	0	34.95	0	0	12
2015	12	15	19	5	33	37	0	0	0	0	0	0	0	34.93	0	0	12
2015	12	15	19	15	33	37	0	0	0	0	0	0	0	34.92	0	0	12
2015	12	15	19	25	33	37	0	0	0	0	0	0	0	34.92	0	0	12
2015	12	15	19	35	33	37	0	0	0	0	0	0	0	34.9	0	0	12
2015	12	15	19	45	33	37	0	0	0	0	0	0	0	34.9	0	0	12
2015	12	15	19	55	33	37	0	0	0	0	0	0	0	34.88	0	0	12
2015	12	15	20	5	33	37	0	0	0	0	0	0	0	34.86	0	0	12
2015	12	15	20	15	33	38	0	0	0	0	0	0	0	34.86	0	0	11.8
2015	12	15	20	25	33	38	0	0	0	0	0	0	0	34.84	0	0	11.8
2015	12	15	20	35	33	38	0	0	0	0	0	0	0	34.83	0	0	11.8
2015	12	15	20	45	33	37	0	0	0	0	0	0	0	34.81	0	0	11.8
2015	12	15	20	55	33	38	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	15	21	5	33	37	0	0	0	0	0	0	0	34.79	0	0	11.8
2015	12	15	21	15	33	38	0	0	0	0	0	0	0	34.77	0	0	11.8
2015	12	15	21	25	33	37	0	0	0	0	0	0	0	34.75	0	0	11.8
2015	12	15	21	35	33	37	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	15	21	45	33	37	0	0	0	0	0	0	0	34.74	0	0	11.8
2015	12	15	21	55	33	37	0	0	0	0	0	0	0	34.72	0	0	11.8
2015	12	15	22	5	33	37	0	0	0	0	0	0	0	34.7	0	0	11.8
2015	12	15	22	15	33	37	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	15	22	25	33	37	0	0	0	0	0	0	0	34.68	0	0	11.8
2015	12	15	22	35	33	38	0	0	0	0	0	0	0	34.66	0	0	11.8
2015	12	15	22	45	33	37	0	0	0	0	0	0	0	34.65	0	0	11.8
2015	12	15	22	55	33	37	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	15	23	5	33	37	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	15	23	15	33	38	0	0	0	0	0	0	0	34.61	0	0	11.8
2015	12	15	23	25	33	38	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	15	23	35	33	37	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	15	23	45	33	37	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	15	23	55	33	37	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	16	0	5	33	37	0	0	0	0	0	0	0	34.59	0	0	11.8
2015	12	16	0	15	33	37	0	0	0	0	0	0	0	34.59	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	0	25	33	37	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	16	0	35	33	37	0	0	0	0	0	0	0	34.57	0	0	11.8
2015	12	16	0	45	33	37	0	0	0	0	0	0	0	34.56	0	0	11.8
2015	12	16	0	55	33	37	0	0	0	0	0	0	0	34.54	0	0	11.8
2015	12	16	1	5	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	16	1	15	33	37	0	0	0	0	0	0	0	34.52	0	0	11.8
2015	12	16	1	25	33	38	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	16	1	35	33	37	0	0	0	0	0	0	0	34.5	0	0	11.8
2015	12	16	1	45	33	37	0	0	0	0	0	0	0	34.48	0	0	11.8
2015	12	16	1	55	33	37	0	0	0	0	0	0	0	34.47	0	0	11.8
2015	12	16	2	5	33	38	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	16	2	15	33	36	0	0	0	0	0	0	0	34.45	0	0	11.8
2015	12	16	2	25	33	38	0	0	0	0	0	0	0	34.43	0	0	11.8
2015	12	16	2	35	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	16	2	45	33	37	0	0	0	0	0	0	0	34.41	0	0	11.8
2015	12	16	2	55	33	37	0	0	0	0	0	0	0	34.38	0	0	11.8
2015	12	16	3	5	33	37	0	0	0	0	0	0	0	34.38	0	0	11.8
2015	12	16	3	15	33	37	0	0	0	0	0	0	0	34.36	0	0	11.8
2015	12	16	3	25	33	37	0	0	0	0	0	0	0	34.32	0	0	11.8
2015	12	16	3	35	33	37	0	0	0	0	0	0	0	34.3	0	0	11.8
2015	12	16	3	45	33	37	0	0	0	0	0	0	0	34.29	0	0	11.8
2015	12	16	3	55	33	37	0	0	0	0	0	0	0	34.27	0	0	11.6
2015	12	16	4	5	33	37	0	0	0	0	0	0	0	34.23	0	0	11.6
2015	12	16	4	15	33	37	0	0	0	0	0	0	0	34.21	0	0	11.6
2015	12	16	4	25	33	37	0	0	0	0	0	0	0	34.18	0	0	11.6
2015	12	16	4	35	33	37	0	0	0	0	0	0	0	34.16	0	0	11.6
2015	12	16	4	45	33	37	0	0	0	0	0	0	0	34.12	0	0	11.6
2015	12	16	4	55	33	37	0	0	0	0	0	0	0	34.11	0	0	11.6
2015	12	16	5	5	33	37	0	0	0	0	0	0	0	34.05	0	0	11.6
2015	12	16	5	15	33	37	0	0	0	0	0	0	0	34.03	0	0	11.6
2015	12	16	5	25	33	37	0	0	0	0	0	0	0	33.98	0	0	11.6
2015	12	16	5	35	33	38	0	0	0	0	0	0	0	33.94	0	0	11.6
2015	12	16	5	45	33	37	0	0	0	0	0	0	0	33.93	0	0	11.6
2015	12	16	5	55	33	37	0	0	0	0	0	0	0	33.87	0	0	11.6
2015	12	16	6	5	33	37	0	0	0	0	0	0	0	33.85	0	0	11.6
2015	12	16	6	15	33	37	0	0	0	0	0	0	0	33.82	0	0	11.6
2015	12	16	6	25	33	37	0	0	0	0	0	0	0	33.78	0	0	11.6
2015	12	16	6	35	33	37	0	0	0	0	0	0	0	33.76	0	0	11.6
2015	12	16	6	45	33	37	0	0	0	0	0	0	0	33.71	0	0	11.6
2015	12	16	6	55	33	37	0	0	0	0	0	0	0	33.69	0	0	11.6
2015	12	16	7	5	33	37	0	0	0	0	0	0	0	33.66	0	0	11.6
2015	12	16	7	15	33	38	0	0	0	0	0	0	0	33.64	0	0	11.6
2015	12	16	7	25	33	38	0	0	0	0	0	0	0	33.6	0	0	11.6
2015	12	16	7	35	33	38	0	0	0	0	0	0	0	33.58	0	0	12
2015	12	16	7	45	33	37	0	0	0	0	0	0	0	33.58	0	0	12.2
2015	12	16	7	55	33	37	0	0	0	0	0	0	0	33.6	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	8	5	33	37	0	0	0	0	0	0	0	33.58	0	0	12.2
2015	12	16	8	15	33	37	0	0	0	0	0	0	0	33.53	0	0	12.2
2015	12	16	8	25	33	37	0	0	0	0	0	0	0	33.6	0	0	12.6
2015	12	16	8	35	33	37	0	0	0	0	0	0	0	33.67	0	0	12.8
2015	12	16	8	45	33	37	0	0	0	0	0	0	0	33.71	0	0	13
2015	12	16	8	55	33	37	0	0	0	0	0	0	0	33.76	0	0	13.2
2015	12	16	9	5	33	38	0	0	0	0	0	0	0	33.82	0	0	13.2
2015	12	16	9	15	33	38	0	0	0	0	0	0	0	33.87	0	0	13.2
2015	12	16	9	25	33	37	0	0	0	0	0	0	0	33.94	0	0	13.4
2015	12	16	9	35	33	37	0	0	0	0	0	0	0	34	0	0	13.4
2015	12	16	9	45	33	37	0	0	0	0	0	0	0	34.03	0	0	13.4
2015	12	16	9	55	33	37	0	0	0	0	0	0	0	34.11	0	0	13.4
2015	12	16	10	5	33	37	0	0	0	0	0	0	0	34.16	0	0	13.4
2015	12	16	10	15	33	37	0	0	0	0	0	0	0	34.23	0	0	13.4
2015	12	16	10	25	33	37	0	0	0	0	0	0	0	34.29	0	0	13.6
2015	12	16	10	35	33	37	0	0	0	0	0	0	0	34.34	0	0	13.6
2015	12	16	10	45	33	37	0	0	0	0	0	0	0	34.39	0	0	13.6
2015	12	16	10	55	33	37	0	0	0	0	0	0	0	34.43	0	0	14
2015	12	16	11	5	33	37	0	0	0	0	0	0	0	34.47	0	0	14
2015	12	16	11	15	33	37	0	0	0	0	0	0	0	34.5	0	0	14
2015	12	16	11	25	33	37	0	0	0	0	0	0	0	34.5	0	0	14
2015	12	16	11	35	33	37	0	0	0	0	0	0	0	34.52	0	0	14
2015	12	16	11	45	33	37	0	0	0	0	0	0	0	34.56	0	0	13.8
2015	12	16	11	55	33	37	0	0	0	0	0	0	0	34.56	0	0	13.8
2015	12	16	12	5	33	37	0	0	0	0	0	0	0	34.59	0	0	13.8
2015	12	16	12	15	33	37	0	0	0	0	0	0	0	34.59	0	0	13.8
2015	12	16	12	25	33	37	0	0	0	0	0	0	0	34.57	0	0	13.8
2015	12	16	12	35	33	38	0	0	0	0	0	0	0	34.57	0	0	13.8
2015	12	16	12	45	33	37	0	0	0	0	0	0	0	34.57	0	0	13.8
2015	12	16	12	55	33	37	0	0	0	0	0	0	0	34.56	0	0	13.8
2015	12	16	13	5	33	37	0	0	0	0	0	0	0	34.54	0	0	13.8
2015	12	16	13	15	33	37	0	0	0	0	0	0	0	34.5	0	0	13.8
2015	12	16	13	25	33	37	0	0	0	0	0	0	0	34.52	0	0	13.8
2015	12	16	13	35	33	37	0	0	0	0	0	0	0	34.47	0	0	13.8
2015	12	16	13	45	33	37	0	0	0	0	0	0	0	34.43	0	0	13.8
2015	12	16	13	55	33	37	0	0	0	0	0	0	0	34.41	0	0	13.8
2015	12	16	14	5	33	37	0	0	0	0	0	0	0	34.38	0	0	13.8
2015	12	16	14	15	33	37	0	0	0	0	0	0	0	34.34	0	0	13.8
2015	12	16	14	25	33	37	0	0	0	0	0	0	0	34.29	0	0	13.8
2015	12	16	14	35	33	37	0	0	0	0	0	0	0	34.25	0	0	13.8
2015	12	16	14	45	33	37	0	0	0	0	0	0	0	34.2	0	0	13.8
2015	12	16	14	55	33	37	0	0	0	0	0	0	0	34.16	0	0	13.8
2015	12	16	15	5	33	37	0	0	0	0	0	0	0	34.09	0	0	13.8
2015	12	16	15	15	33	37	0	0	0	0	0	0	0	34.03	0	0	13.8
2015	12	16	15	25	33	37	0	0	0	0	0	0	0	33.98	0	0	12.8
2015	12	16	15	35	33	38	0	0	0	0	0	0	0	33.94	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	15	45	33	37	0	0	0	0	0	0	0	33.93	0	0	12.2
2015	12	16	15	55	33	38	0	0	0	0	0	0	0	33.91	0	0	12.2
2015	12	16	16	5	33	37	0	0	0	0	0	0	0	33.89	0	0	12.2
2015	12	16	16	15	33	37	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	16	16	25	33	37	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	16	16	35	33	37	0	0	0	0	0	0	0	33.89	0	0	12
2015	12	16	16	45	33	37	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	16	16	55	33	37	0	0	0	0	0	0	0	33.87	0	0	12
2015	12	16	17	5	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	17	15	33	38	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	17	25	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	17	35	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	17	45	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	17	55	33	37	0	0	0	0	0	0	0	33.85	0	0	12
2015	12	16	18	5	33	37	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	16	18	15	33	37	0	0	0	0	0	0	0	33.84	0	0	12
2015	12	16	18	25	33	38	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	16	18	35	33	38	0	0	0	0	0	0	0	33.82	0	0	12
2015	12	16	18	45	33	37	0	0	0	0	0	0	0	33.8	0	0	12
2015	12	16	18	55	33	38	0	0	0	0	0	0	0	33.78	0	0	12
2015	12	16	19	5	33	38	0	0	0	0	0	0	0	33.78	0	0	12
2015	12	16	19	15	33	38	0	0	0	0	0	0	0	33.76	0	0	12
2015	12	16	19	25	33	36	0	0	0	0	0	0	0	33.75	0	0	12
2015	12	16	19	35	33	37	0	0	0	0	0	0	0	33.73	0	0	12
2015	12	16	19	45	33	37	0	0	0	0	0	0	0	33.71	0	0	11.8
2015	12	16	19	55	33	37	0	0	0	0	0	0	0	33.69	0	0	11.8
2015	12	16	20	5	33	37	0	0	0	0	0	0	0	33.67	0	0	11.8
2015	12	16	20	15	33	37	0	0	0	0	0	0	0	33.67	0	0	11.8
2015	12	16	20	25	33	38	0	0	0	0	0	0	0	33.64	0	0	11.8
2015	12	16	20	35	33	37	0	0	0	0	0	0	0	33.62	0	0	11.8
2015	12	16	20	45	33	37	0	0	0	0	0	0	0	33.6	0	0	11.8
2015	12	16	20	55	33	38	0	0	0	0	0	0	0	33.58	0	0	11.8
2015	12	16	21	5	33	37	0	0	0	0	0	0	0	33.55	0	0	11.8
2015	12	16	21	15	33	38	0	0	0	0	0	0	0	33.53	0	0	11.8
2015	12	16	21	25	33	37	0	0	0	0	0	0	0	33.51	0	0	11.8
2015	12	16	21	35	33	38	0	0	0	0	0	0	0	33.49	0	0	11.8
2015	12	16	21	45	33	38	0	0	0	0	0	0	0	33.46	0	0	11.8
2015	12	16	21	55	33	38	0	0	0	0	0	0	0	33.44	0	0	11.8
2015	12	16	22	5	33	37	0	0	0	0	0	0	0	33.42	0	0	11.8
2015	12	16	22	15	33	37	0	0	0	0	0	0	0	33.39	0	0	11.8
2015	12	16	22	25	33	37	0	0	0	0	0	0	0	33.37	0	0	11.8
2015	12	16	22	35	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	16	22	45	33	38	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	16	22	55	33	37	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	16	23	5	33	38	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	16	23	15	33	37	0	0	0	0	0	0	0	33.26	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	16	23	25	33	38	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	16	23	35	33	38	0	0	0	0	0	0	0	33.21	0	0	11.8
2015	12	16	23	45	33	37	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	16	23	55	33	37	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	17	0	5	33	37	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	17	0	15	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	17	0	25	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	17	0	35	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	17	0	45	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	17	0	55	33	37	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	17	1	5	33	38	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	17	1	15	33	37	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	17	1	25	33	37	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	17	1	35	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	17	1	45	33	38	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	17	1	55	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	17	2	5	33	38	0	0	0	0	0	0	0	32.81	0	0	11.8
2015	12	17	2	15	33	37	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	17	2	25	33	37	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	17	2	35	33	37	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	17	2	45	33	37	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	17	2	55	33	38	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	17	3	5	33	37	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	17	3	15	33	37	0	0	0	0	0	0	0	32.61	0	0	11.6
2015	12	17	3	25	33	38	0	0	0	0	0	0	0	32.58	0	0	11.6
2015	12	17	3	35	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	17	3	45	33	37	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	17	3	55	33	37	0	0	0	0	0	0	0	32.49	0	0	11.6
2015	12	17	4	5	33	38	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	17	4	15	33	37	0	0	0	0	0	0	0	32.43	0	0	11.6
2015	12	17	4	25	33	36	0	0	0	0	0	0	0	32.4	0	0	11.6
2015	12	17	4	35	33	37	0	0	0	0	0	0	0	32.36	0	0	11.6
2015	12	17	4	45	33	38	0	0	0	0	0	0	0	32.34	0	0	11.6
2015	12	17	4	55	33	38	0	0	0	0	0	0	0	32.31	0	0	11.6
2015	12	17	5	5	33	37	0	0	0	0	0	0	0	32.27	0	0	11.6
2015	12	17	5	15	33	37	0	0	0	0	0	0	0	32.25	0	0	11.6
2015	12	17	5	25	33	38	0	0	0	0	0	0	0	32.23	0	0	11.6
2015	12	17	5	35	33	38	0	0	0	0	0	0	0	32.2	0	0	11.6
2015	12	17	5	45	33	38	0	0	0	0	0	0	0	32.18	0	0	11.6
2015	12	17	5	55	33	37	0	0	0	0	0	0	0	32.16	0	0	11.6
2015	12	17	6	5	33	38	0	0	0	0	0	0	0	32.14	0	0	11.6
2015	12	17	6	15	33	38	0	0	0	0	0	0	0	32.13	0	0	11.6
2015	12	17	6	25	33	37	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	17	6	35	33	38	0	0	0	0	0	0	0	32.09	0	0	11.6
2015	12	17	6	45	33	38	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	17	6	55	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	7	5	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	17	7	15	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	17	7	25	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	17	7	35	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	17	7	45	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	17	7	55	33	37	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	17	8	5	33	38	0	0	0	0	0	0	0	32.09	0	0	12.6
2015	12	17	8	15	33	38	0	0	0	0	0	0	0	32.13	0	0	12.8
2015	12	17	8	25	33	38	0	0	0	0	0	0	0	32.18	0	0	12.8
2015	12	17	8	35	33	38	0	0	0	0	0	0	0	32.23	0	0	13
2015	12	17	8	45	33	37	0	0	0	0	0	0	0	32.29	0	0	13.2
2015	12	17	8	55	33	37	0	0	0	0	0	0	0	32.34	0	0	13.2
2015	12	17	9	5	33	38	0	0	0	0	0	0	0	32.4	0	0	13.2
2015	12	17	9	15	33	38	0	0	0	0	0	0	0	32.47	0	0	13.4
2015	12	17	9	25	33	38	0	0	0	0	0	0	0	32.52	0	0	13.4
2015	12	17	9	35	33	37	0	0	0	0	0	0	0	32.59	0	0	13.4
2015	12	17	9	45	33	38	0	0	0	0	0	0	0	32.67	0	0	13.4
2015	12	17	9	55	33	37	0	0	0	0	0	0	0	32.72	0	0	13.4
2015	12	17	10	5	33	37	0	0	0	0	0	0	0	32.76	0	0	13.4
2015	12	17	10	15	33	38	0	0	0	0	0	0	0	32.81	0	0	13.4
2015	12	17	10	25	33	37	0	0	0	0	0	0	0	32.86	0	0	13.4
2015	12	17	10	35	33	37	0	0	0	0	0	0	0	32.92	0	0	13.6
2015	12	17	10	45	33	38	0	0	0	0	0	0	0	32.95	0	0	13.6
2015	12	17	10	55	33	38	0	0	0	0	0	0	0	32.97	0	0	13.8
2015	12	17	11	5	33	37	0	0	0	0	0	0	0	32.94	0	0	13
2015	12	17	11	15	33	38	0	0	0	0	0	0	0	32.94	0	0	13.8
2015	12	17	11	25	33	38	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	17	11	35	33	38	0	0	0	0	0	0	0	33.01	0	0	13.6
2015	12	17	11	45	33	38	0	0	0	0	0	0	0	32.99	0	0	13.6
2015	12	17	11	55	33	38	0	0	0	0	0	0	0	33.01	0	0	13.8
2015	12	17	12	5	33	37	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	17	12	15	33	37	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	17	12	25	33	38	0	0	0	0	0	0	0	33.04	0	0	13.4
2015	12	17	12	35	33	38	0	0	0	0	0	0	0	33.04	0	0	13.8
2015	12	17	12	45	33	37	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	17	12	55	33	37	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	17	13	5	33	37	0	0	0	0	0	0	0	33.06	0	0	13.8
2015	12	17	13	15	33	37	0	0	0	0	0	0	0	33.04	0	0	13.8
2015	12	17	13	25	33	38	0	0	0	0	0	0	0	33.03	0	0	13.8
2015	12	17	13	35	33	38	0	0	0	0	0	0	0	32.97	0	0	13.8
2015	12	17	13	45	33	38	0	0	0	0	0	0	0	32.95	0	0	13.6
2015	12	17	13	55	33	37	0	0	0	0	0	0	0	32.9	0	0	13.6
2015	12	17	14	5	33	37	0	0	0	0	0	0	0	32.88	0	0	13.6
2015	12	17	14	15	33	38	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	17	14	25	33	37	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	17	14	35	33	37	0	0	0	0	0	0	0	32.83	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	14	45	33	38	0	0	0	0	0	0	0	32.76	0	0	13
2015	12	17	14	55	33	37	0	0	0	0	0	0	0	32.74	0	0	13.6
2015	12	17	15	5	33	38	0	0	0	0	0	0	0	32.7	0	0	13.6
2015	12	17	15	15	33	38	0	0	0	0	0	0	0	32.67	0	0	12.8
2015	12	17	15	25	33	37	0	0	0	0	0	0	0	32.63	0	0	12.8
2015	12	17	15	35	33	37	0	0	0	0	0	0	0	32.61	0	0	12.4
2015	12	17	15	45	33	37	0	0	0	0	0	0	0	32.59	0	0	12.4
2015	12	17	15	55	33	38	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	16	5	33	37	0	0	0	0	0	0	0	32.58	0	0	12.2
2015	12	17	16	15	33	37	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	16	25	33	38	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	16	35	33	38	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	16	45	33	37	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	16	55	33	38	0	0	0	0	0	0	0	32.56	0	0	12
2015	12	17	17	5	33	37	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	17	15	33	37	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	17	25	33	37	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	17	35	33	37	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	17	45	33	38	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	17	55	33	38	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	18	5	33	38	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	18	15	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	18	25	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	18	35	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	18	45	33	37	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	17	18	55	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	5	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	15	33	38	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	25	33	38	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	35	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	45	33	38	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	19	55	33	38	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	17	20	5	33	38	0	0	0	0	0	0	0	32.58	0	0	12
2015	12	17	20	15	33	38	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	17	20	25	33	38	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	17	20	35	33	37	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	17	20	45	33	38	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	17	20	55	33	37	0	0	0	0	0	0	0	32.54	0	0	11.8
2015	12	17	21	5	33	37	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	17	21	15	33	38	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	17	21	25	33	38	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	17	21	35	33	37	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	17	21	45	33	38	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	17	21	55	33	38	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	17	22	5	33	38	0	0	0	0	0	0	0	32.45	0	0	11.8
2015	12	17	22	15	33	37	0	0	0	0	0	0	0	32.45	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	17	22	25	33	38	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	17	22	35	33	37	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	17	22	45	33	38	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	17	22	55	33	38	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	17	23	5	33	37	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	17	23	15	33	38	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	17	23	25	33	38	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	17	23	35	33	38	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	17	23	45	33	37	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	17	23	55	33	38	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	18	0	5	33	37	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	18	0	15	33	38	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	18	0	25	33	37	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	18	0	35	33	37	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	18	0	45	33	38	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	18	0	55	33	37	0	0	0	0	0	0	0	32.2	0	0	11.8
2015	12	18	1	5	33	37	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	18	1	15	33	38	0	0	0	0	0	0	0	32.16	0	0	11.8
2015	12	18	1	25	33	38	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	18	1	35	33	38	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	18	1	45	33	37	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	18	1	55	33	37	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	18	2	5	33	38	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	18	2	15	33	37	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	18	2	25	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	2	35	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	18	2	45	33	37	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	18	2	55	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	18	3	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	18	3	15	33	37	0	0	0	0	0	0	0	31.93	0	0	11.6
2015	12	18	3	25	33	38	0	0	0	0	0	0	0	31.93	0	0	11.6
2015	12	18	3	35	33	37	0	0	0	0	0	0	0	31.91	0	0	11.6
2015	12	18	3	45	33	38	0	0	0	0	0	0	0	31.87	0	0	11.6
2015	12	18	3	55	33	38	0	0	0	0	0	0	0	31.87	0	0	11.6
2015	12	18	4	5	33	37	0	0	0	0	0	0	0	31.86	0	0	11.6
2015	12	18	4	15	33	37	0	0	0	0	0	0	0	31.86	0	0	11.6
2015	12	18	4	25	33	38	0	0	0	0	0	0	0	31.84	0	0	11.6
2015	12	18	4	35	33	37	0	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	18	4	45	33	37	0	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	18	4	55	33	38	0	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	18	5	5	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	5	15	33	39	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	5	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	5	35	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	5	45	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	5	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	6	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	6	15	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	6	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	6	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	6	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	6	55	33	39	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	7	5	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	18	7	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	7	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	18	7	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	18	7	45	33	39	0	0	0	0	0	0	0	31.84	0	0	12
2015	12	18	7	55	33	37	0	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	18	8	5	33	37	0	0	0	0	0	0	0	31.93	0	0	12.6
2015	12	18	8	15	33	37	0	0	0	0	0	0	0	31.98	0	0	12.8
2015	12	18	8	25	33	38	0	0	0	0	0	0	0	32.04	0	0	12.8
2015	12	18	8	35	33	38	0	0	0	0	0	0	0	32.13	0	0	13
2015	12	18	8	45	33	38	0	0	0	0	0	0	0	32.18	0	0	13
2015	12	18	8	55	33	38	0	0	0	0	0	0	0	32.25	0	0	13
2015	12	18	9	5	33	38	0	0	0	0	0	0	0	32.31	0	0	13.2
2015	12	18	9	15	33	38	0	0	0	0	0	0	0	32.38	0	0	13.2
2015	12	18	9	25	33	37	0	0	0	0	0	0	0	32.41	0	0	13.2
2015	12	18	9	35	33	38	0	0	0	0	0	0	0	32.49	0	0	13.2
2015	12	18	9	45	33	37	0	0	0	0	0	0	0	32.56	0	0	13.2
2015	12	18	9	55	33	38	0	0	0	0	0	0	0	32.59	0	0	13.2
2015	12	18	10	5	33	38	0	0	0	0	0	0	0	32.65	0	0	13.4
2015	12	18	10	15	33	38	0	0	0	0	0	0	0	32.68	0	0	13.4
2015	12	18	10	25	33	38	0	0	0	0	0	0	0	32.72	0	0	13.4
2015	12	18	10	35	33	37	0	0	0	0	0	0	0	32.76	0	0	13.4
2015	12	18	10	45	33	37	0	0	0	0	0	0	0	32.79	0	0	13.6
2015	12	18	10	55	33	37	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	18	11	5	33	37	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	18	11	15	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	18	11	25	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	18	11	35	33	38	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	18	11	45	33	38	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	18	11	55	33	37	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	18	12	5	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	18	12	15	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	18	12	25	33	38	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	18	12	35	33	38	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	18	12	45	33	38	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	18	12	55	33	37	0	0	0	0	0	0	0	32.77	0	0	13.8
2015	12	18	13	5	33	38	0	0	0	0	0	0	0	32.74	0	0	13.8
2015	12	18	13	15	33	37	0	0	0	0	0	0	0	32.7	0	0	13.8
2015	12	18	13	25	33	37	0	0	0	0	0	0	0	32.67	0	0	13.8
2015	12	18	13	35	33	38	0	0	0	0	0	0	0	32.65	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	13	45	33	38	0	0	0	0	0	0	0	32.61	0	0	13.8
2015	12	18	13	55	33	37	0	0	0	0	0	0	0	32.56	0	0	13.8
2015	12	18	14	5	33	38	0	0	0	0	0	0	0	32.52	0	0	13.8
2015	12	18	14	15	33	37	0	0	0	0	0	0	0	32.49	0	0	13.8
2015	12	18	14	25	33	38	0	0	0	0	0	0	0	32.43	0	0	13.8
2015	12	18	14	35	33	38	0	0	0	0	0	0	0	32.38	0	0	13.8
2015	12	18	14	45	33	38	0	0	0	0	0	0	0	32.32	0	0	13.8
2015	12	18	14	55	33	38	0	0	0	0	0	0	0	32.29	0	0	13.8
2015	12	18	15	5	33	37	0	0	0	0	0	0	0	32.23	0	0	13.8
2015	12	18	15	15	33	37	0	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	18	15	25	33	38	0	0	0	0	0	0	0	32.13	0	0	13
2015	12	18	15	35	33	37	0	0	0	0	0	0	0	32.09	0	0	12.4
2015	12	18	15	45	33	38	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	18	15	55	33	37	0	0	0	0	0	0	0	32.02	0	0	12.2
2015	12	18	16	5	33	37	0	0	0	0	0	0	0	32.02	0	0	12.2
2015	12	18	16	15	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	18	16	25	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	16	35	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	16	45	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	16	55	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	17	5	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	17	15	33	37	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	17	25	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	17	35	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	18	17	45	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	17	55	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	18	5	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	18	15	33	37	0	0	0	0	0	0	0	32	0	0	12
2015	12	18	18	25	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	18	18	35	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	18	45	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	18	55	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	5	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	15	33	37	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	25	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	35	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	45	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	19	55	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	18	20	5	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	18	20	15	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	18	20	25	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	18	20	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	18	20	45	33	37	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	18	20	55	33	38	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	18	21	5	33	37	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	18	21	15	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	18	21	25	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	18	21	35	33	38	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	18	21	45	33	38	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	18	21	55	33	36	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	18	22	5	33	38	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	18	22	15	33	38	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	18	22	25	33	38	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	18	22	35	33	37	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	18	22	45	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	18	22	55	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	18	23	5	33	37	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	18	23	15	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	18	23	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	18	23	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	18	23	45	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	18	23	55	33	37	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	0	5	33	37	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	0	15	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	0	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	0	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	0	45	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	0	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	1	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	2	5	33	37	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	2	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	2	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	2	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	2	45	33	38	0	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	19	2	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	19	3	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	3	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	3	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	3	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	3	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	3	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	4	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	4	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	4	25	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	4	35	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	4	45	33	38	0	0	0	0	0	0	0	31.77	0	0	11.6
2015	12	19	4	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	5	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	5	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	5	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	5	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	5	45	33	38	0	0	0	0	0	0	0	31.77	0	0	11.6
2015	12	19	5	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	6	5	33	38	0	0	0	0	0	0	0	31.77	0	0	11.6
2015	12	19	6	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	6	25	33	38	0	0	0	0	0	0	0	31.77	0	0	11.6
2015	12	19	6	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	6	45	33	37	0	0	0	0	0	0	0	31.77	0	0	11.6
2015	12	19	6	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	7	5	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	7	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	19	7	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	19	7	35	33	37	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	19	7	45	33	38	0	0	0	0	0	0	0	31.82	0	0	12
2015	12	19	7	55	33	37	0	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	19	8	5	33	38	0	0	0	0	0	0	0	31.91	0	0	12.4
2015	12	19	8	15	33	38	0	0	0	0	0	0	0	31.96	0	0	12.6
2015	12	19	8	25	33	38	0	0	0	0	0	0	0	32.04	0	0	12.8
2015	12	19	8	35	33	38	0	0	0	0	0	0	0	32.09	0	0	13
2015	12	19	8	45	33	38	0	0	0	0	0	0	0	32.14	0	0	13
2015	12	19	8	55	33	38	0	0	0	0	0	0	0	32.22	0	0	13
2015	12	19	9	5	33	37	0	0	0	0	0	0	0	32.27	0	0	13.2
2015	12	19	9	15	33	38	0	0	0	0	0	0	0	32.34	0	0	13.2
2015	12	19	9	25	33	38	0	0	0	0	0	0	0	32.4	0	0	13
2015	12	19	9	35	33	38	0	0	0	0	0	0	0	32.45	0	0	13.2
2015	12	19	9	45	33	38	0	0	0	0	0	0	0	32.5	0	0	13.2
2015	12	19	9	55	33	38	0	0	0	0	0	0	0	32.56	0	0	13.4
2015	12	19	10	5	33	37	0	0	0	0	0	0	0	32.61	0	0	13.2
2015	12	19	10	15	33	38	0	0	0	0	0	0	0	32.68	0	0	13.4
2015	12	19	10	25	33	37	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	19	10	35	33	37	0	0	0	0	0	0	0	32.79	0	0	13.6
2015	12	19	10	45	33	37	0	0	0	0	0	0	0	32.81	0	0	13.4
2015	12	19	10	55	33	37	0	0	0	0	0	0	0	32.83	0	0	13.6
2015	12	19	11	5	33	38	0	0	0	0	0	0	0	32.81	0	0	13.6
2015	12	19	11	15	33	37	0	0	0	0	0	0	0	32.81	0	0	13.8
2015	12	19	11	25	33	38	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	19	11	35	33	37	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	19	11	45	33	38	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	19	11	55	33	37	0	0	0	0	0	0	0	32.94	0	0	13.8
2015	12	19	12	5	33	37	0	0	0	0	0	0	0	32.85	0	0	13.6
2015	12	19	12	15	33	37	0	0	0	0	0	0	0	32.77	0	0	13
2015	12	19	12	25	33	37	0	0	0	0	0	0	0	32.63	0	0	12.4
2015	12	19	12	35	33	38	0	0	0	0	0	0	0	32.52	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	12	45	33	37	0	0	0	0	0	0	0	32.58	0	0	13.8
2015	12	19	12	55	33	38	0	0	0	0	0	0	0	32.72	0	0	13.8
2015	12	19	13	5	33	37	0	0	0	0	0	0	0	32.65	0	0	12.6
2015	12	19	13	15	33	38	0	0	0	0	0	0	0	32.56	0	0	13.6
2015	12	19	13	25	33	37	0	0	0	0	0	0	0	32.59	0	0	13.8
2015	12	19	13	35	33	37	0	0	0	0	0	0	0	32.63	0	0	13.8
2015	12	19	13	45	33	38	0	0	0	0	0	0	0	32.67	0	0	13.8
2015	12	19	13	55	33	38	0	0	0	0	0	0	0	32.65	0	0	13.6
2015	12	19	14	5	33	38	0	0	0	0	0	0	0	32.56	0	0	12.8
2015	12	19	14	15	33	38	0	0	0	0	0	0	0	32.45	0	0	12.4
2015	12	19	14	25	33	38	0	0	0	0	0	0	0	32.36	0	0	12.4
2015	12	19	14	35	33	38	0	0	0	0	0	0	0	32.34	0	0	12.6
2015	12	19	14	45	33	38	0	0	0	0	0	0	0	32.31	0	0	12.4
2015	12	19	14	55	33	38	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	19	15	5	33	37	0	0	0	0	0	0	0	32.14	0	0	12.2
2015	12	19	15	15	33	37	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	19	15	25	33	38	0	0	0	0	0	0	0	32.09	0	0	12.2
2015	12	19	15	35	33	37	0	0	0	0	0	0	0	32.04	0	0	12.2
2015	12	19	15	45	33	38	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	19	15	55	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	16	5	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	16	15	33	37	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	19	16	25	33	38	0	0	0	0	0	0	0	31.95	0	0	12
2015	12	19	16	35	33	38	0	0	0	0	0	0	0	31.93	0	0	12
2015	12	19	16	45	33	38	0	0	0	0	0	0	0	31.91	0	0	12
2015	12	19	16	55	33	38	0	0	0	0	0	0	0	31.89	0	0	12
2015	12	19	17	5	33	38	0	0	0	0	0	0	0	31.89	0	0	12
2015	12	19	17	15	33	38	0	0	0	0	0	0	0	31.91	0	0	12
2015	12	19	17	25	33	37	0	0	0	0	0	0	0	31.91	0	0	12
2015	12	19	17	35	33	38	0	0	0	0	0	0	0	31.89	0	0	12
2015	12	19	17	45	33	37	0	0	0	0	0	0	0	31.91	0	0	12
2015	12	19	17	55	33	38	0	0	0	0	0	0	0	31.91	0	0	12
2015	12	19	18	5	33	37	0	0	0	0	0	0	0	31.93	0	0	12
2015	12	19	18	15	33	37	0	0	0	0	0	0	0	31.93	0	0	12
2015	12	19	18	25	33	37	0	0	0	0	0	0	0	31.95	0	0	12
2015	12	19	18	35	33	38	0	0	0	0	0	0	0	31.95	0	0	12
2015	12	19	18	45	33	38	0	0	0	0	0	0	0	31.96	0	0	12
2015	12	19	18	55	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	19	5	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	19	15	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	19	25	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	19	19	35	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	19	45	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	19	19	55	33	38	0	0	0	0	0	0	0	32	0	0	12
2015	12	19	20	5	33	37	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	20	15	33	37	0	0	0	0	0	0	0	32	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	19	20	25	33	38	0	0	0	0	0	0	0	31.98	0	0	12
2015	12	19	20	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	19	20	45	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	19	20	55	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	19	21	5	33	37	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	19	21	15	33	37	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	21	25	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	19	21	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	21	45	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	21	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	22	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	22	15	33	38	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	19	22	25	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	19	22	35	33	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	19	22	45	33	38	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	19	22	55	33	37	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	19	23	5	33	37	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	19	23	15	33	37	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	19	23	25	33	38	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	19	23	35	33	38	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	19	23	45	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	19	23	55	33	38	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	20	0	5	33	38	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	20	0	15	33	38	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	20	0	25	33	38	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	20	0	35	33	37	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	20	0	45	33	37	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	20	0	55	33	37	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	20	1	5	33	39	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	20	1	15	33	37	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	1	25	33	37	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	1	35	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	1	45	33	37	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	1	55	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	2	5	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	2	15	33	37	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	20	2	25	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	20	2	35	33	37	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	2	45	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	20	2	55	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	20	3	5	33	37	0	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	20	3	15	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	3	25	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	3	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	3	45	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	3	55	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	4	5	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	4	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	4	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	4	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	4	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	4	55	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	5	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	5	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	5	25	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	5	35	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	5	45	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	5	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	25	33	36	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	6	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	7	5	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	7	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	20	7	25	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	20	7	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	20	7	45	33	37	0	0	0	0	0	0	0	31.84	0	0	12
2015	12	20	7	55	33	38	0	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	20	8	5	33	38	0	0	0	0	0	0	0	31.95	0	0	12.4
2015	12	20	8	15	33	38	0	0	0	0	0	0	0	32	0	0	12.6
2015	12	20	8	25	33	38	0	0	0	0	0	0	0	32.04	0	0	12.6
2015	12	20	8	35	33	38	0	0	0	0	0	0	0	32.13	0	0	12.6
2015	12	20	8	45	33	38	0	0	0	0	0	0	0	32.13	0	0	12.6
2015	12	20	8	55	33	38	0	0	0	0	0	0	0	32.11	0	0	12.4
2015	12	20	9	5	33	38	0	0	0	0	0	0	0	32.13	0	0	12.8
2015	12	20	9	15	33	38	0	0	0	0	0	0	0	32.29	0	0	12.6
2015	12	20	9	25	33	38	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	20	9	35	33	38	0	0	0	0	0	0	0	32.18	0	0	12.4
2015	12	20	9	45	33	38	0	0	0	0	0	0	0	32.22	0	0	12.6
2015	12	20	9	55	33	37	0	0	0	0	0	0	0	32.45	0	0	12.8
2015	12	20	10	5	33	38	0	0	0	0	0	0	0	32.4	0	0	12.8
2015	12	20	10	15	33	37	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	20	10	25	33	38	0	0	0	0	0	0	0	32.43	0	0	12.6
2015	12	20	10	35	33	37	0	0	0	0	0	0	0	32.5	0	0	12.6
2015	12	20	10	45	33	38	0	0	0	0	0	0	0	32.38	0	0	12.4
2015	12	20	10	55	33	37	0	0	0	0	0	0	0	32.31	0	0	12.4
2015	12	20	11	5	33	38	0	0	0	0	0	0	0	32.41	0	0	12.8
2015	12	20	11	15	33	38	0	0	0	0	0	0	0	32.59	0	0	13
2015	12	20	11	25	33	38	0	0	0	0	0	0	0	32.77	0	0	13
2015	12	20	11	35	33	38	0	0	0	0	0	0	0	32.63	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	11	45	33	38	0	0	0	0	0	0	0	32.68	0	0	12.6
2015	12	20	11	55	33	37	0	0	0	0	0	0	0	32.59	0	0	12.6
2015	12	20	12	5	33	38	0	0	0	0	0	0	0	32.52	0	0	12.6
2015	12	20	12	15	33	38	0	0	0	0	0	0	0	32.63	0	0	13
2015	12	20	12	25	33	37	0	0	0	0	0	0	0	32.72	0	0	13
2015	12	20	12	35	33	38	0	0	0	0	0	0	0	32.77	0	0	13
2015	12	20	12	45	33	38	0	0	0	0	0	0	0	32.85	0	0	13
2015	12	20	12	55	33	38	0	0	0	0	0	0	0	32.81	0	0	12.8
2015	12	20	13	5	33	38	0	0	0	0	0	0	0	32.77	0	0	13
2015	12	20	13	15	33	38	0	0	0	0	0	0	0	32.77	0	0	12.8
2015	12	20	13	25	33	37	0	0	0	0	0	0	0	32.74	0	0	13
2015	12	20	13	35	33	38	0	0	0	0	0	0	0	32.7	0	0	13
2015	12	20	13	45	33	38	0	0	0	0	0	0	0	32.65	0	0	12.6
2015	12	20	13	55	33	38	0	0	0	0	0	0	0	32.58	0	0	12.8
2015	12	20	14	5	33	38	0	0	0	0	0	0	0	32.56	0	0	12.8
2015	12	20	14	15	33	37	0	0	0	0	0	0	0	32.54	0	0	13
2015	12	20	14	25	33	38	0	0	0	0	0	0	0	32.5	0	0	13
2015	12	20	14	35	33	38	0	0	0	0	0	0	0	32.45	0	0	13
2015	12	20	14	45	33	38	0	0	0	0	0	0	0	32.38	0	0	13.2
2015	12	20	14	55	33	38	0	0	0	0	0	0	0	32.32	0	0	12.4
2015	12	20	15	5	33	38	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	20	15	15	33	37	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	20	15	25	33	37	0	0	0	0	0	0	0	32.13	0	0	12.2
2015	12	20	15	35	33	38	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	20	15	45	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	15	55	33	37	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	16	5	33	37	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	16	15	33	38	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	16	25	33	38	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	16	35	33	37	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	16	45	33	38	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	16	55	33	38	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	20	17	5	33	38	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	17	15	33	38	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	17	25	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	17	35	33	38	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	20	17	45	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	17	55	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	5	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	15	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	25	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	35	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	45	33	37	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	18	55	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	20	19	5	33	38	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	20	19	15	33	38	0	0	0	0	0	0	0	32.07	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	20	19	25	33	38	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	20	19	35	33	37	0	0	0	0	0	0	0	32.05	0	0	11.8
2015	12	20	19	45	33	38	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	20	19	55	33	38	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	20	20	5	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	20	20	15	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	20	25	33	37	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	20	20	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	20	20	45	33	37	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	20	20	55	33	37	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	20	21	5	33	37	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	20	21	15	33	37	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	20	21	25	33	37	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	20	21	35	33	39	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	20	21	45	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	20	21	55	33	38	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	20	22	5	33	38	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	20	22	15	33	38	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	20	22	25	33	37	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	20	22	35	33	37	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	22	45	33	38	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	22	55	33	38	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	20	23	5	33	37	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	23	15	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	23	25	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	23	35	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	20	23	45	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	20	23	55	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	21	0	5	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	21	0	15	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	21	0	25	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	21	0	35	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	21	0	45	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	21	0	55	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	21	1	5	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	21	1	15	33	38	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	21	1	25	33	37	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	21	1	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	1	45	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	1	55	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	2	5	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	2	15	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	2	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	2	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	2	45	33	37	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	2	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	3	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	3	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	3	25	33	39	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	3	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	3	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	3	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	25	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	4	55	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	35	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	5	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	5	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	15	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	25	33	38	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	35	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	45	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	6	55	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	7	5	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	7	15	33	37	0	0	0	0	0	0	0	31.78	0	0	11.6
2015	12	21	7	25	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	7	35	33	38	0	0	0	0	0	0	0	31.8	0	0	11.6
2015	12	21	7	45	33	38	0	0	0	0	0	0	0	31.82	0	0	11.6
2015	12	21	7	55	33	38	0	0	0	0	0	0	0	31.86	0	0	11.6
2015	12	21	8	5	33	37	0	0	0	0	0	0	0	31.89	0	0	11.6
2015	12	21	8	15	33	37	0	0	0	0	0	0	0	31.91	0	0	11.6
2015	12	21	8	25	33	37	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	21	8	35	33	39	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	21	8	45	33	38	0	0	0	0	0	0	0	32.05	0	0	12.2
2015	12	21	8	55	33	38	0	0	0	0	0	0	0	32.22	0	0	12.8
2015	12	21	9	5	33	37	0	0	0	0	0	0	0	32.34	0	0	13
2015	12	21	9	15	33	38	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	9	25	33	38	0	0	0	0	0	0	0	32.27	0	0	12.6
2015	12	21	9	35	33	38	0	0	0	0	0	0	0	32.38	0	0	13
2015	12	21	9	45	33	37	0	0	0	0	0	0	0	32.5	0	0	13
2015	12	21	9	55	33	37	0	0	0	0	0	0	0	32.59	0	0	13
2015	12	21	10	5	33	38	0	0	0	0	0	0	0	32.52	0	0	12.6
2015	12	21	10	15	33	38	0	0	0	0	0	0	0	32.47	0	0	12.6
2015	12	21	10	25	33	38	0	0	0	0	0	0	0	32.45	0	0	12.6
2015	12	21	10	35	33	38	0	0	0	0	0	0	0	32.43	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	10	45	33	38	0	0	0	0	0	0	0	32.4	0	0	12.6
2015	12	21	10	55	33	38	0	0	0	0	0	0	0	32.5	0	0	12.6
2015	12	21	11	5	33	38	0	0	0	0	0	0	0	32.43	0	0	12.4
2015	12	21	11	15	33	38	0	0	0	0	0	0	0	32.38	0	0	12.4
2015	12	21	11	25	33	38	0	0	0	0	0	0	0	32.36	0	0	12.4
2015	12	21	11	35	33	37	0	0	0	0	0	0	0	32.38	0	0	12.4
2015	12	21	11	45	33	39	0	0	0	0	0	0	0	32.34	0	0	12.4
2015	12	21	11	55	33	38	0	0	0	0	0	0	0	32.32	0	0	12.4
2015	12	21	12	5	33	38	0	0	0	0	0	0	0	32.31	0	0	12.4
2015	12	21	12	15	33	38	0	0	0	0	0	0	0	32.29	0	0	12.4
2015	12	21	12	25	33	38	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	12	35	33	38	0	0	0	0	0	0	0	32.25	0	0	12.2
2015	12	21	12	45	33	38	0	0	0	0	0	0	0	32.25	0	0	12.4
2015	12	21	12	55	33	38	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	13	5	33	38	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	13	15	33	38	0	0	0	0	0	0	0	32.27	0	0	12.4
2015	12	21	13	25	33	38	0	0	0	0	0	0	0	32.25	0	0	12.2
2015	12	21	13	35	33	38	0	0	0	0	0	0	0	32.23	0	0	12.2
2015	12	21	13	45	33	37	0	0	0	0	0	0	0	32.2	0	0	12.2
2015	12	21	13	55	33	38	0	0	0	0	0	0	0	32.22	0	0	12.2
2015	12	21	14	5	33	38	0	0	0	0	0	0	0	32.23	0	0	12.4
2015	12	21	14	15	33	38	0	0	0	0	0	0	0	32.25	0	0	12.2
2015	12	21	14	25	33	38	0	0	0	0	0	0	0	32.22	0	0	12.2
2015	12	21	14	35	33	37	0	0	0	0	0	0	0	32.2	0	0	12.2
2015	12	21	14	45	33	37	0	0	0	0	0	0	0	32.18	0	0	12.2
2015	12	21	14	55	33	38	0	0	0	0	0	0	0	32.14	0	0	12.2
2015	12	21	15	5	33	37	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	15	15	33	38	0	0	0	0	0	0	0	32.13	0	0	12
2015	12	21	15	25	33	38	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	15	35	33	37	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	15	45	33	38	0	0	0	0	0	0	0	32.09	0	0	12
2015	12	21	15	55	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	21	16	5	33	38	0	0	0	0	0	0	0	32.07	0	0	12
2015	12	21	16	15	33	38	0	0	0	0	0	0	0	32.05	0	0	12
2015	12	21	16	25	33	38	0	0	0	0	0	0	0	32.04	0	0	12
2015	12	21	16	35	33	37	0	0	0	0	0	0	0	32.02	0	0	12
2015	12	21	16	45	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	16	55	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	17	5	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	17	15	33	37	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	17	25	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	17	35	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	17	45	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	17	55	33	37	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	18	5	33	37	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	21	18	15	33	38	0	0	0	0	0	0	0	32	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	21	18	25	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	18	35	33	38	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	18	45	33	37	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	18	55	33	37	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	19	5	33	37	0	0	0	0	0	0	0	32.02	0	0	11.8
2015	12	21	19	15	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	19	25	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	21	19	35	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	19	45	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	19	55	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	21	20	5	33	37	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	21	20	15	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	20	25	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	20	35	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	20	45	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	20	55	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	21	5	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	21	15	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	21	25	33	38	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	21	35	33	38	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	21	45	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	21	21	55	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	22	5	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	22	15	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	22	25	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	22	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	22	45	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	21	22	55	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	23	5	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	23	15	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	23	25	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	23	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	21	23	45	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	21	23	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	0	5	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	0	15	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	0	25	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	0	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	0	45	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	0	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	1	5	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	1	15	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	1	25	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	1	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	1	45	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	1	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	2	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	2	15	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	2	25	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	2	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	2	45	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	2	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	3	5	33	38	0	0	0	0	0	0	0	31.95	0	0	11.6
2015	12	22	3	15	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	3	25	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	3	35	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	3	45	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	3	55	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	15	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	25	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	35	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	45	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	4	55	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	5	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	5	15	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	5	25	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	5	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	5	45	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	5	55	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	6	5	33	38	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	22	6	15	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	6	25	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	6	35	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	6	45	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	6	55	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	7	5	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	7	15	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	22	7	25	33	38	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	22	7	35	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	22	7	45	33	37	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	22	7	55	33	38	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	22	8	5	33	38	0	0	0	0	0	0	0	32.16	0	0	12
2015	12	22	8	15	33	38	0	0	0	0	0	0	0	32.2	0	0	12
2015	12	22	8	25	33	37	0	0	0	0	0	0	0	32.23	0	0	12
2015	12	22	8	35	33	38	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	22	8	45	33	38	0	0	0	0	0	0	0	32.27	0	0	12
2015	12	22	8	55	33	38	0	0	0	0	0	0	0	32.34	0	0	12
2015	12	22	9	5	33	37	0	0	0	0	0	0	0	32.36	0	0	12
2015	12	22	9	15	33	37	0	0	0	0	0	0	0	32.41	0	0	12.2
2015	12	22	9	25	33	38	0	0	0	0	0	0	0	32.47	0	0	12.4
2015	12	22	9	35	33	38	0	0	0	0	0	0	0	32.54	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	9	45	33	38	0	0	0	0	0	0	0	32.52	0	0	12.2
2015	12	22	9	55	33	38	0	0	0	0	0	0	0	32.54	0	0	12.4
2015	12	22	10	5	33	38	0	0	0	0	0	0	0	32.72	0	0	12.6
2015	12	22	10	15	33	38	0	0	0	0	0	0	0	32.81	0	0	12.6
2015	12	22	10	25	33	37	0	0	0	0	0	0	0	32.77	0	0	12.6
2015	12	22	10	35	33	37	0	0	0	0	0	0	0	32.85	0	0	12.6
2015	12	22	10	45	33	37	0	0	0	0	0	0	0	32.92	0	0	12.6
2015	12	22	10	55	33	38	0	0	0	0	0	0	0	33.03	0	0	12.8
2015	12	22	11	5	33	37	0	0	0	0	0	0	0	33.1	0	0	12.8
2015	12	22	11	15	33	38	0	0	0	0	0	0	0	33.13	0	0	12.6
2015	12	22	11	25	33	38	0	0	0	0	0	0	0	33.17	0	0	12.6
2015	12	22	11	35	33	38	0	0	0	0	0	0	0	33.15	0	0	12.6
2015	12	22	11	45	33	38	0	0	0	0	0	0	0	33.19	0	0	12.6
2015	12	22	11	55	33	37	0	0	0	0	0	0	0	33.19	0	0	12.6
2015	12	22	12	5	33	37	0	0	0	0	0	0	0	33.22	0	0	12.6
2015	12	22	12	15	33	37	0	0	0	0	0	0	0	33.24	0	0	12.6
2015	12	22	12	25	33	38	0	0	0	0	0	0	0	33.21	0	0	12.6
2015	12	22	12	35	33	37	0	0	0	0	0	0	0	33.21	0	0	12.6
2015	12	22	12	45	33	38	0	0	0	0	0	0	0	33.15	0	0	12.6
2015	12	22	12	55	33	37	0	0	0	0	0	0	0	33.04	0	0	12.4
2015	12	22	13	5	33	38	0	0	0	0	0	0	0	32.99	0	0	12.4
2015	12	22	13	15	33	37	0	0	0	0	0	0	0	32.88	0	0	12.2
2015	12	22	13	25	33	37	0	0	0	0	0	0	0	32.83	0	0	12.4
2015	12	22	13	35	33	38	0	0	0	0	0	0	0	32.9	0	0	12.4
2015	12	22	13	45	33	37	0	0	0	0	0	0	0	32.9	0	0	12.4
2015	12	22	13	55	33	37	0	0	0	0	0	0	0	32.88	0	0	12.2
2015	12	22	14	5	33	38	0	0	0	0	0	0	0	32.9	0	0	12.4
2015	12	22	14	15	33	38	0	0	0	0	0	0	0	32.9	0	0	12.2
2015	12	22	14	25	33	37	0	0	0	0	0	0	0	32.85	0	0	12.2
2015	12	22	14	35	33	39	0	0	0	0	0	0	0	32.83	0	0	12.2
2015	12	22	14	45	33	37	0	0	0	0	0	0	0	32.85	0	0	12.4
2015	12	22	14	55	33	37	0	0	0	0	0	0	0	32.86	0	0	12.2
2015	12	22	15	5	33	37	0	0	0	0	0	0	0	32.88	0	0	12.2
2015	12	22	15	15	33	38	0	0	0	0	0	0	0	32.9	0	0	12.2
2015	12	22	15	25	33	37	0	0	0	0	0	0	0	32.88	0	0	12.2
2015	12	22	15	35	33	37	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	22	15	45	33	37	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	22	15	55	33	37	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	22	16	5	33	38	0	0	0	0	0	0	0	32.92	0	0	12
2015	12	22	16	15	33	37	0	0	0	0	0	0	0	32.94	0	0	12
2015	12	22	16	25	33	37	0	0	0	0	0	0	0	32.94	0	0	12
2015	12	22	16	35	33	37	0	0	0	0	0	0	0	32.95	0	0	12
2015	12	22	16	45	33	37	0	0	0	0	0	0	0	32.97	0	0	12
2015	12	22	16	55	33	37	0	0	0	0	0	0	0	32.99	0	0	12
2015	12	22	17	5	33	37	0	0	0	0	0	0	0	32.99	0	0	12
2015	12	22	17	15	33	37	0	0	0	0	0	0	0	32.99	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	22	17	25	33	37	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	17	35	33	38	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	17	45	33	38	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	17	55	33	37	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	18	5	33	37	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	18	15	33	37	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	18	25	33	38	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	18	35	33	37	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	18	45	33	37	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	22	18	55	33	38	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	19	5	33	37	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	19	15	33	38	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	22	19	25	33	38	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	22	19	35	33	38	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	22	19	45	33	37	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	22	19	55	33	38	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	22	20	5	33	38	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	22	20	15	33	37	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	22	20	25	33	37	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	22	20	35	33	37	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	22	20	45	33	37	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	22	20	55	33	38	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	22	21	5	33	37	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	22	21	15	33	38	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	22	21	25	33	38	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	22	21	35	33	39	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	22	21	45	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	21	55	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	22	5	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	22	15	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	22	25	33	37	1	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	22	35	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	22	45	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	22	55	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	23	5	33	37	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	23	15	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	23	25	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	23	35	33	37	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	22	23	45	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	22	23	55	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	5	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	15	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	25	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	35	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	45	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	0	55	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	1	5	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	1	15	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	23	1	25	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	1	35	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	23	1	45	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	1	55	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	2	5	33	38	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	23	2	15	33	38	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	23	2	25	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	2	35	33	37	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	2	45	33	37	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	2	55	33	38	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	23	3	5	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	3	15	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	3	25	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	3	35	33	38	0	0	0	0	0	0	0	32.88	0	0	11.6
2015	12	23	3	45	33	37	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	23	3	55	33	38	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	23	4	5	33	38	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	23	4	15	33	37	0	0	0	0	0	0	0	32.86	0	0	11.6
2015	12	23	4	25	33	37	0	0	0	0	0	0	0	32.85	0	0	11.6
2015	12	23	4	35	33	37	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	23	4	45	33	37	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	23	4	55	33	38	0	0	0	0	0	0	0	32.83	0	0	11.6
2015	12	23	5	5	33	38	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	23	5	15	33	38	0	0	0	0	0	0	0	32.81	0	0	11.6
2015	12	23	5	25	33	37	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	23	5	35	33	38	0	0	0	0	0	0	0	32.79	0	0	11.6
2015	12	23	5	45	33	38	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	23	5	55	33	37	0	0	0	0	0	0	0	32.77	0	0	11.6
2015	12	23	6	5	33	37	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	23	6	15	33	37	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	23	6	25	33	38	0	0	0	0	0	0	0	32.74	0	0	11.6
2015	12	23	6	35	33	38	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	23	6	45	33	37	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	23	6	55	33	37	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	23	7	5	33	38	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	23	7	15	33	37	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	23	7	25	33	38	0	0	0	0	0	0	0	32.67	0	0	11.6
2015	12	23	7	35	33	37	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	23	7	45	33	38	0	0	0	0	0	0	0	32.65	0	0	12
2015	12	23	7	55	33	37	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	23	8	5	33	38	0	0	0	0	0	0	0	32.72	0	0	12.2
2015	12	23	8	15	33	38	0	0	0	0	0	0	0	32.74	0	0	12.2
2015	12	23	8	25	33	38	0	0	0	0	0	0	0	32.79	0	0	12.4
2015	12	23	8	35	33	38	0	0	0	0	0	0	0	32.85	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	8	45	33	38	0	0	0	0	0	0	0	32.88	0	0	12.4
2015	12	23	8	55	33	37	0	0	0	0	0	0	0	32.94	0	0	12.4
2015	12	23	9	5	33	37	0	0	0	0	0	0	0	32.99	0	0	12.4
2015	12	23	9	15	33	38	0	0	0	0	0	0	0	33.03	0	0	12.6
2015	12	23	9	25	33	37	0	0	0	0	0	0	0	33.08	0	0	12.6
2015	12	23	9	35	33	37	0	0	0	0	0	0	0	33.13	0	0	12.6
2015	12	23	9	45	33	37	0	0	0	0	0	0	0	33.19	0	0	12.6
2015	12	23	9	55	33	37	0	0	0	0	0	0	0	33.24	0	0	12.6
2015	12	23	10	5	33	37	0	0	0	0	0	0	0	33.28	0	0	12.6
2015	12	23	10	15	33	37	0	0	0	0	0	0	0	33.31	0	0	12.6
2015	12	23	10	25	33	37	0	0	0	0	0	0	0	33.35	0	0	12.6
2015	12	23	10	35	33	38	0	0	0	0	0	0	0	33.4	0	0	12.6
2015	12	23	10	45	33	38	0	0	0	0	0	0	0	33.44	0	0	12.6
2015	12	23	10	55	33	37	0	0	0	0	0	0	0	33.48	0	0	12.6
2015	12	23	11	5	33	38	0	0	0	0	0	0	0	33.51	0	0	12.6
2015	12	23	11	15	33	38	0	0	0	0	0	0	0	33.53	0	0	12.6
2015	12	23	11	25	33	37	0	0	0	0	0	0	0	33.58	0	0	12.6
2015	12	23	11	35	33	38	0	0	0	0	0	0	0	33.58	0	0	12.6
2015	12	23	11	45	33	37	0	0	0	0	0	0	0	33.6	0	0	12.6
2015	12	23	11	55	33	37	0	0	0	0	0	0	0	33.62	0	0	12.6
2015	12	23	12	5	33	38	0	0	0	0	0	0	0	33.64	0	0	12.6
2015	12	23	12	15	33	37	0	0	0	0	0	0	0	33.64	0	0	12.6
2015	12	23	12	25	33	37	0	0	0	0	0	0	0	33.66	0	0	12.6
2015	12	23	12	35	33	38	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	23	12	45	33	37	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	23	12	55	33	37	0	0	0	0	0	0	0	33.69	0	0	12.6
2015	12	23	13	5	33	37	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	23	13	15	33	37	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	23	13	25	33	37	0	0	0	0	0	0	0	33.67	0	0	12.6
2015	12	23	13	35	33	37	0	0	0	0	0	0	0	33.66	0	0	12.6
2015	12	23	13	45	33	37	0	0	0	0	0	0	0	33.66	0	0	12.6
2015	12	23	13	55	33	38	0	0	0	0	0	0	0	33.64	0	0	12.4
2015	12	23	14	5	33	38	0	0	0	0	0	0	0	33.62	0	0	12.6
2015	12	23	14	15	33	38	0	0	0	0	0	0	0	33.6	0	0	12.4
2015	12	23	14	25	33	37	0	0	0	0	0	0	0	33.53	0	0	12.4
2015	12	23	14	35	33	37	0	0	0	0	0	0	0	33.51	0	0	12.2
2015	12	23	14	45	33	37	0	0	0	0	0	0	0	33.49	0	0	12.2
2015	12	23	14	55	33	37	0	0	0	0	0	0	0	33.49	0	0	12.2
2015	12	23	15	5	33	37	0	0	0	0	0	0	0	33.49	0	0	12.2
2015	12	23	15	15	33	38	0	0	0	0	0	0	0	33.48	0	0	12.2
2015	12	23	15	25	33	38	0	0	0	0	0	0	0	33.48	0	0	12.2
2015	12	23	15	35	33	37	0	0	0	0	0	0	0	33.46	0	0	12.2
2015	12	23	15	45	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	15	55	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	16	5	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	16	15	33	37	0	0	0	0	0	0	0	33.44	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	23	16	25	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	16	35	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	16	45	33	37	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	16	55	33	37	2	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	17	5	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	17	15	33	38	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	17	25	33	38	0	0	0	0	0	0	0	33.44	0	0	12
2015	12	23	17	35	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	17	45	33	38	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	17	55	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	18	5	33	37	0	0	0	0	0	0	0	33.42	0	0	12
2015	12	23	18	15	33	38	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	23	18	25	33	37	0	0	0	0	0	0	0	33.4	0	0	12
2015	12	23	18	35	33	38	0	0	0	0	0	0	0	33.39	0	0	12
2015	12	23	18	45	33	38	0	0	0	0	0	0	0	33.39	0	0	12
2015	12	23	18	55	33	37	0	0	0	0	0	0	0	33.37	0	0	12
2015	12	23	19	5	33	37	0	0	0	0	0	0	0	33.35	0	0	11.8
2015	12	23	19	15	33	37	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	23	19	25	33	38	0	0	0	0	0	0	0	33.33	0	0	11.8
2015	12	23	19	35	33	37	0	0	0	0	0	0	0	33.31	0	0	11.8
2015	12	23	19	45	33	38	0	0	0	0	0	0	0	33.3	0	0	11.8
2015	12	23	19	55	33	37	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	23	20	5	33	38	0	0	0	0	0	0	0	33.28	0	0	11.8
2015	12	23	20	15	33	38	0	0	0	0	0	0	0	33.26	0	0	11.8
2015	12	23	20	25	33	38	0	0	0	0	0	0	0	33.24	0	0	11.8
2015	12	23	20	35	33	37	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	23	20	45	33	38	0	0	0	0	0	0	0	33.22	0	0	11.8
2015	12	23	20	55	33	38	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	23	21	5	33	38	0	0	0	0	0	0	0	33.19	0	0	11.8
2015	12	23	21	15	33	37	0	0	0	0	0	0	0	33.17	0	0	11.8
2015	12	23	21	25	33	38	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	23	21	35	33	38	0	0	0	0	0	0	0	33.15	0	0	11.8
2015	12	23	21	45	33	37	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	23	21	55	33	36	0	0	0	0	0	0	0	33.13	0	0	11.8
2015	12	23	22	5	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	23	22	15	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	23	22	25	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	23	22	35	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	23	22	45	33	38	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	23	22	55	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	23	23	5	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	23	23	15	33	38	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	23	23	25	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	23	23	35	33	37	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	23	23	45	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	23	23	55	33	38	0	0	0	0	0	0	0	33.03	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	0	5	33	38	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	24	0	15	33	38	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	24	0	25	33	37	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	24	0	35	33	38	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	24	0	45	33	38	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	24	0	55	33	38	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	24	1	5	33	38	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	24	1	15	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	24	1	25	33	38	0	0	0	0	0	0	0	32.85	0	0	11.8
2015	12	24	1	35	33	39	0	0	0	0	0	0	0	32.81	0	0	11.8
2015	12	24	1	45	33	37	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	24	1	55	33	38	0	0	0	0	0	0	0	32.76	0	0	11.8
2015	12	24	2	5	33	37	0	0	0	0	0	0	0	32.74	0	0	11.8
2015	12	24	2	15	33	37	0	0	0	0	0	0	0	32.7	0	0	11.8
2015	12	24	2	25	33	37	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	24	2	35	33	38	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	24	2	45	33	37	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	24	2	55	33	38	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	24	3	5	33	37	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	24	3	15	33	37	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	24	3	25	33	37	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	24	3	35	33	37	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	24	3	45	33	38	0	0	0	0	0	0	0	32.43	0	0	11.6
2015	12	24	3	55	33	37	0	0	0	0	0	0	0	32.4	0	0	11.6
2015	12	24	4	5	33	37	0	0	0	0	0	0	0	32.36	0	0	11.6
2015	12	24	4	15	33	37	0	0	0	0	0	0	0	32.34	0	0	11.6
2015	12	24	4	25	33	37	0	0	0	0	0	0	0	32.31	0	0	11.6
2015	12	24	4	35	33	39	0	0	0	0	0	0	0	32.27	0	0	11.6
2015	12	24	4	45	33	38	0	0	0	0	0	0	0	32.23	0	0	11.6
2015	12	24	4	55	33	38	0	0	0	0	0	0	0	32.2	0	0	11.6
2015	12	24	5	5	33	37	0	0	0	0	0	0	0	32.18	0	0	11.6
2015	12	24	5	15	33	38	0	0	0	0	0	0	0	32.16	0	0	11.6
2015	12	24	5	25	33	38	0	0	0	0	0	0	0	32.13	0	0	11.6
2015	12	24	5	35	33	37	0	0	0	0	0	0	0	32.11	0	0	11.6
2015	12	24	5	45	33	37	0	0	0	0	0	0	0	32.09	0	0	11.6
2015	12	24	5	55	33	38	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	24	6	5	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	24	6	15	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	24	6	25	33	38	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	24	6	35	33	38	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	24	6	45	33	37	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	24	6	55	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	24	7	5	33	38	0	0	0	0	0	0	0	31.95	0	0	11.6
2015	12	24	7	15	33	37	0	0	0	0	0	0	0	31.95	0	0	11.6
2015	12	24	7	25	33	38	0	0	0	0	0	0	0	31.93	0	0	11.6
2015	12	24	7	35	33	38	0	0	0	0	0	0	0	31.93	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	7	45	33	37	0	0	0	0	0	0	0	31.93	0	0	12
2015	12	24	7	55	33	37	0	0	0	0	0	0	0	31.96	0	0	12.2
2015	12	24	8	5	33	38	0	0	0	0	0	0	0	31.98	0	0	12.4
2015	12	24	8	15	33	38	0	0	0	0	0	0	0	32.02	0	0	12.4
2015	12	24	8	25	33	38	0	0	0	0	0	0	0	32.09	0	0	12.6
2015	12	24	8	35	33	38	0	0	0	0	0	0	0	32.14	0	0	12.6
2015	12	24	8	45	33	37	0	0	0	0	0	0	0	32.18	0	0	12.8
2015	12	24	8	55	33	37	0	0	0	0	0	0	0	32.23	0	0	12.8
2015	12	24	9	5	33	38	0	0	0	0	0	0	0	32.29	0	0	13
2015	12	24	9	15	33	38	0	0	0	0	0	0	0	32.36	0	0	13
2015	12	24	9	25	33	37	0	0	0	0	0	0	0	32.4	0	0	13.2
2015	12	24	9	35	33	38	0	0	0	0	0	0	0	32.43	0	0	13.2
2015	12	24	9	45	33	38	0	0	0	0	0	0	0	32.49	0	0	13.2
2015	12	24	9	55	33	38	0	0	0	0	0	0	0	32.52	0	0	13.4
2015	12	24	10	5	33	37	0	0	0	0	0	0	0	32.56	0	0	13.4
2015	12	24	10	15	33	38	0	0	0	0	0	0	0	32.61	0	0	13.4
2015	12	24	10	25	33	38	0	0	0	0	0	0	0	32.67	0	0	13.4
2015	12	24	10	35	33	38	0	0	0	0	0	0	0	32.68	0	0	13.6
2015	12	24	10	45	33	38	0	0	0	0	0	0	0	32.72	0	0	13.6
2015	12	24	10	55	33	38	0	0	0	0	0	0	0	32.76	0	0	13.8
2015	12	24	11	5	33	37	0	0	0	0	0	0	0	32.79	0	0	13.8
2015	12	24	11	15	33	37	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	24	11	25	33	37	0	0	0	0	0	0	0	32.85	0	0	13.8
2015	12	24	11	35	33	37	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	24	11	45	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	24	11	55	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	24	12	5	33	37	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	24	12	15	33	37	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	24	12	25	33	38	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	24	12	35	33	38	0	0	0	0	0	0	0	32.9	0	0	13.8
2015	12	24	12	45	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	24	12	55	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	24	13	5	33	38	0	0	0	0	0	0	0	32.86	0	0	13.4
2015	12	24	13	15	33	38	0	0	0	0	0	0	0	32.79	0	0	13.2
2015	12	24	13	25	33	38	0	0	0	0	0	0	0	32.77	0	0	12.8
2015	12	24	13	35	33	38	0	0	0	0	0	0	0	32.76	0	0	12.8
2015	12	24	13	45	33	37	0	0	0	0	0	0	0	32.7	0	0	12.6
2015	12	24	13	55	33	37	0	0	0	0	0	0	0	32.68	0	0	12.4
2015	12	24	14	5	33	37	0	0	0	0	0	0	0	32.65	0	0	12.4
2015	12	24	14	15	33	38	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	24	14	25	33	38	0	0	0	0	0	0	0	32.63	0	0	12.2
2015	12	24	14	35	33	38	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	24	14	45	33	38	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	24	14	55	33	38	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	24	15	5	33	37	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	24	15	15	33	37	0	0	0	0	0	0	0	32.63	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	15	25	33	37	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	24	15	35	33	38	0	0	0	0	0	0	0	32.67	0	0	12
2015	12	24	15	45	33	38	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	24	15	55	33	38	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	24	16	5	33	37	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	24	16	15	33	38	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	24	16	25	33	38	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	24	16	35	33	37	0	0	0	0	0	0	0	32.77	0	0	12
2015	12	24	16	45	33	37	0	0	0	0	0	0	0	32.81	0	0	12
2015	12	24	16	55	33	37	0	0	0	0	0	0	0	32.83	0	0	12
2015	12	24	17	5	33	37	0	0	0	0	0	0	0	32.85	0	0	12
2015	12	24	17	15	33	38	0	0	0	0	0	0	0	32.86	0	0	12
2015	12	24	17	25	33	38	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	24	17	35	33	38	0	0	0	0	0	0	0	32.9	0	0	12
2015	12	24	17	45	33	37	0	0	0	0	0	0	0	32.94	0	0	12
2015	12	24	17	55	33	37	0	0	0	0	0	0	0	32.94	0	0	12
2015	12	24	18	5	33	37	0	0	0	0	0	0	0	32.95	0	0	12
2015	12	24	18	15	33	38	0	0	0	0	0	0	0	32.97	0	0	12
2015	12	24	18	25	33	37	0	0	0	0	0	0	0	32.99	0	0	12
2015	12	24	18	35	33	38	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	24	18	45	33	38	0	0	0	0	0	0	0	33.01	0	0	12
2015	12	24	18	55	33	38	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	24	19	5	33	37	0	0	0	0	0	0	0	33.03	0	0	12
2015	12	24	19	15	33	38	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	24	19	25	33	37	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	24	19	35	33	37	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	24	19	45	33	37	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	24	19	55	33	37	0	0	0	0	0	0	0	33.04	0	0	12
2015	12	24	20	5	33	38	0	0	0	0	0	0	0	33.06	0	0	12
2015	12	24	20	15	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	24	20	25	33	37	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	24	20	35	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	24	20	45	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	24	20	55	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	21	5	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	21	15	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	24	21	25	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	21	35	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	21	45	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	21	55	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	22	5	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	24	22	15	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	22	25	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	24	22	35	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	24	22	45	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	24	22	55	33	37	0	0	0	0	0	0	0	33.12	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	24	23	5	33	38	0	0	0	0	0	0	0	33.12	0	0	11.8
2015	12	24	23	15	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	23	25	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	23	35	33	38	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	23	45	33	37	0	0	0	0	0	0	0	33.1	0	0	11.8
2015	12	24	23	55	33	38	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	25	0	5	33	38	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	25	0	15	33	37	0	0	0	0	0	0	0	33.08	0	0	11.8
2015	12	25	0	25	33	38	0	0	0	0	0	0	0	33.06	0	0	11.8
2015	12	25	0	35	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	25	0	45	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	25	0	55	33	38	0	0	0	0	0	0	0	33.04	0	0	11.8
2015	12	25	1	5	33	37	0	0	0	0	0	0	0	33.03	0	0	11.8
2015	12	25	1	15	33	38	0	0	0	0	0	0	0	33.01	0	0	11.8
2015	12	25	1	25	33	38	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	25	1	35	33	38	0	0	0	0	0	0	0	32.99	0	0	11.8
2015	12	25	1	45	33	38	0	0	0	0	0	0	0	32.97	0	0	11.8
2015	12	25	1	55	33	37	0	0	0	0	0	0	0	32.95	0	0	11.8
2015	12	25	2	5	33	38	0	0	0	0	0	0	0	32.94	0	0	11.8
2015	12	25	2	15	33	37	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	25	2	25	33	37	0	0	0	0	0	0	0	32.92	0	0	11.8
2015	12	25	2	35	33	38	0	0	0	0	0	0	0	32.9	0	0	11.8
2015	12	25	2	45	33	38	0	0	0	0	0	0	0	32.88	0	0	11.8
2015	12	25	2	55	33	37	0	0	0	0	0	0	0	32.86	0	0	11.8
2015	12	25	3	5	33	37	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	25	3	15	33	37	0	0	0	0	0	0	0	32.83	0	0	11.8
2015	12	25	3	25	33	37	0	0	0	0	0	0	0	32.79	0	0	11.8
2015	12	25	3	35	33	37	0	0	0	0	0	0	0	32.76	0	0	11.6
2015	12	25	3	45	33	38	0	0	0	0	0	0	0	32.72	0	0	11.6
2015	12	25	3	55	33	38	0	0	0	0	0	0	0	32.7	0	0	11.6
2015	12	25	4	5	33	38	0	0	0	0	0	0	0	32.68	0	0	11.6
2015	12	25	4	15	33	38	0	0	0	0	0	0	0	32.65	0	0	11.6
2015	12	25	4	25	33	37	0	0	0	0	0	0	0	32.63	0	0	11.6
2015	12	25	4	35	33	38	0	0	0	0	0	0	0	32.59	0	0	11.6
2015	12	25	4	45	33	38	0	0	0	0	0	0	0	32.56	0	0	11.6
2015	12	25	4	55	33	38	0	0	0	0	0	0	0	32.52	0	0	11.6
2015	12	25	5	5	33	38	0	0	0	0	0	0	0	32.5	0	0	11.6
2015	12	25	5	15	33	38	0	0	0	0	0	0	0	32.47	0	0	11.6
2015	12	25	5	25	33	38	0	0	0	0	0	0	0	32.45	0	0	11.6
2015	12	25	5	35	33	37	0	0	0	0	0	0	0	32.41	0	0	11.6
2015	12	25	5	45	33	37	0	0	0	0	0	0	0	32.4	0	0	11.6
2015	12	25	5	55	33	38	0	0	0	0	0	0	0	32.36	0	0	11.6
2015	12	25	6	5	33	38	0	0	0	0	0	0	0	32.34	0	0	11.6
2015	12	25	6	15	33	38	0	0	0	0	0	0	0	32.31	0	0	11.6
2015	12	25	6	25	33	37	0	0	0	0	0	0	0	32.29	0	0	11.6
2015	12	25	6	35	33	37	0	0	0	0	0	0	0	32.25	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	6	45	33	38	0	0	0	0	0	0	0	32.22	0	0	11.6
2015	12	25	6	55	33	38	0	0	0	0	0	0	0	32.2	0	0	11.6
2015	12	25	7	5	33	38	0	0	0	0	0	0	0	32.18	0	0	11.6
2015	12	25	7	15	33	38	0	0	0	0	0	0	0	32.14	0	0	11.6
2015	12	25	7	25	33	37	0	0	0	0	0	0	0	32.14	0	0	11.6
2015	12	25	7	35	33	38	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	25	7	45	33	38	0	0	0	0	0	0	0	32.11	0	0	12
2015	12	25	7	55	33	37	0	0	0	0	0	0	0	32.11	0	0	12.2
2015	12	25	8	5	33	37	0	0	0	0	0	0	0	32.13	0	0	12.4
2015	12	25	8	15	33	37	0	0	0	0	0	0	0	32.14	0	0	12.4
2015	12	25	8	25	33	38	0	0	0	0	0	0	0	32.16	0	0	12.6
2015	12	25	8	35	33	38	0	0	0	0	0	0	0	32.2	0	0	12.8
2015	12	25	8	45	33	38	0	0	0	0	0	0	0	32.22	0	0	12.8
2015	12	25	8	55	33	39	0	0	0	0	0	0	0	32.27	0	0	12.8
2015	12	25	9	5	33	37	0	0	0	0	0	0	0	32.31	0	0	13
2015	12	25	9	15	33	37	0	0	0	0	0	0	0	32.34	0	0	13
2015	12	25	9	25	33	38	0	0	0	0	0	0	0	32.4	0	0	13
2015	12	25	9	35	33	38	0	0	0	0	0	0	0	32.43	0	0	13.2
2015	12	25	9	45	33	37	0	0	0	0	0	0	0	32.49	0	0	13.2
2015	12	25	9	55	33	38	0	0	0	0	0	0	0	32.52	0	0	13.2
2015	12	25	10	5	33	39	0	0	0	0	0	0	0	32.58	0	0	13.2
2015	12	25	10	15	33	38	0	0	0	0	0	0	0	32.59	0	0	13.2
2015	12	25	10	25	33	38	0	0	0	0	0	0	0	32.63	0	0	13.4
2015	12	25	10	35	33	37	0	0	0	0	0	0	0	32.67	0	0	13.4
2015	12	25	10	45	33	37	0	0	0	0	0	0	0	32.7	0	0	13.4
2015	12	25	10	55	33	38	0	0	0	0	0	0	0	32.74	0	0	13.8
2015	12	25	11	5	33	37	0	0	0	0	0	0	0	32.76	0	0	14
2015	12	25	11	15	33	38	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	25	11	25	33	38	0	0	0	0	0	0	0	32.79	0	0	14
2015	12	25	11	35	33	37	0	0	0	0	0	0	0	32.81	0	0	14
2015	12	25	11	45	33	37	0	0	0	0	0	0	0	32.83	0	0	14
2015	12	25	11	55	33	38	0	0	0	0	0	0	0	32.86	0	0	14
2015	12	25	12	5	33	38	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	25	12	15	33	37	0	0	0	0	0	0	0	32.88	0	0	14
2015	12	25	12	25	33	37	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	25	12	35	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	25	12	45	33	38	0	0	0	0	0	0	0	32.88	0	0	13.8
2015	12	25	12	55	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	25	13	5	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	25	13	15	33	37	0	0	0	0	0	0	0	32.85	0	0	13.8
2015	12	25	13	25	33	38	0	0	0	0	0	0	0	32.86	0	0	13.8
2015	12	25	13	35	33	37	0	0	0	0	0	0	0	32.85	0	0	13.8
2015	12	25	13	45	33	37	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	25	13	55	33	38	0	0	0	0	0	0	0	32.83	0	0	13.8
2015	12	25	14	5	33	38	0	0	0	0	0	0	0	32.76	0	0	13.8
2015	12	25	14	15	33	38	0	0	0	0	0	0	0	32.77	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	14	25	33	37	0	0	0	0	0	0	0	32.77	0	0	13.8
2015	12	25	14	35	33	38	0	0	0	0	0	0	0	32.79	0	0	13.8
2015	12	25	14	45	33	37	0	0	0	0	0	0	0	32.76	0	0	12.4
2015	12	25	14	55	33	38	0	0	0	0	0	0	0	32.72	0	0	12.4
2015	12	25	15	5	33	37	0	0	0	0	0	0	0	32.68	0	0	12.4
2015	12	25	15	15	33	38	0	0	0	0	0	0	0	32.65	0	0	12.2
2015	12	25	15	25	33	38	0	0	0	0	0	0	0	32.63	0	0	12.4
2015	12	25	15	35	33	38	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	25	15	45	33	38	0	0	0	0	0	0	0	32.61	0	0	12.2
2015	12	25	15	55	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	25	16	5	33	37	0	0	0	0	0	0	0	32.59	0	0	12
2015	12	25	16	15	33	38	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	25	16	25	33	37	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	25	16	35	33	38	0	0	0	0	0	0	0	32.61	0	0	12
2015	12	25	16	45	33	38	0	0	0	0	0	0	0	32.63	0	0	12
2015	12	25	16	55	33	37	0	0	0	0	0	0	0	32.65	0	0	12
2015	12	25	17	5	33	38	0	0	0	0	0	0	0	32.65	0	0	12
2015	12	25	17	15	33	37	0	0	0	0	0	0	0	32.67	0	0	12
2015	12	25	17	25	33	38	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	25	17	35	33	38	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	25	17	45	33	38	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	25	17	55	33	38	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	18	5	33	38	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	18	15	33	38	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	18	25	33	37	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	18	35	33	38	0	0	0	0	0	0	0	32.74	0	0	12
2015	12	25	18	45	33	38	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	18	55	33	37	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	19	5	33	38	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	19	15	33	37	0	0	0	0	0	0	0	32.72	0	0	12
2015	12	25	19	25	33	38	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	25	19	35	33	37	0	0	0	0	0	0	0	32.7	0	0	12
2015	12	25	19	45	33	38	0	0	0	0	0	0	0	32.68	0	0	12
2015	12	25	19	55	33	38	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	25	20	5	33	38	0	0	0	0	0	0	0	32.68	0	0	11.8
2015	12	25	20	15	33	37	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	25	20	25	33	38	0	0	0	0	0	0	0	32.67	0	0	11.8
2015	12	25	20	35	33	37	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	25	20	45	33	38	0	0	0	0	0	0	0	32.65	0	0	11.8
2015	12	25	20	55	33	37	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	25	21	5	33	38	0	0	0	0	0	0	0	32.63	0	0	11.8
2015	12	25	21	15	33	38	0	0	0	0	0	0	0	32.61	0	0	11.8
2015	12	25	21	25	33	37	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	25	21	35	33	38	0	0	0	0	0	0	0	32.59	0	0	11.8
2015	12	25	21	45	33	37	0	0	0	0	0	0	0	32.58	0	0	11.8
2015	12	25	21	55	33	38	0	0	0	0	0	0	0	32.56	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	25	22	5	33	37	0	0	0	0	0	0	0	32.54	0	0	11.8
2015	12	25	22	15	33	38	0	0	0	0	0	0	0	32.56	0	0	11.8
2015	12	25	22	25	33	38	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	25	22	35	33	37	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	25	22	45	33	37	0	0	0	0	0	0	0	32.52	0	0	11.8
2015	12	25	22	55	33	37	0	0	0	0	0	0	0	32.5	0	0	11.8
2015	12	25	23	5	33	37	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	25	23	15	33	38	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	25	23	25	33	38	0	0	0	0	0	0	0	32.49	0	0	11.8
2015	12	25	23	35	33	38	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	25	23	45	33	38	0	0	0	0	0	0	0	32.47	0	0	11.8
2015	12	25	23	55	33	37	0	0	0	0	0	0	0	32.45	0	0	11.8
2015	12	26	0	5	33	38	0	0	0	0	0	0	0	32.45	0	0	11.8
2015	12	26	0	15	33	38	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	26	0	25	33	38	0	0	0	0	0	0	0	32.43	0	0	11.8
2015	12	26	0	35	33	38	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	26	0	45	33	37	0	0	0	0	0	0	0	32.41	0	0	11.8
2015	12	26	0	55	33	37	0	0	0	0	0	0	0	32.4	0	0	11.8
2015	12	26	1	5	33	38	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	26	1	15	33	37	0	0	0	0	0	0	0	32.38	0	0	11.8
2015	12	26	1	25	33	38	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	26	1	35	33	38	0	0	0	0	0	0	0	32.36	0	0	11.8
2015	12	26	1	45	33	38	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	26	1	55	33	38	0	0	0	0	0	0	0	32.34	0	0	11.8
2015	12	26	2	5	33	38	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	26	2	15	33	37	0	0	0	0	0	0	0	32.32	0	0	11.8
2015	12	26	2	25	33	37	0	0	0	0	0	0	0	32.31	0	0	11.8
2015	12	26	2	35	33	37	0	0	0	0	0	0	0	32.29	0	0	11.8
2015	12	26	2	45	33	38	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	26	2	55	33	38	0	0	0	0	0	0	0	32.27	0	0	11.8
2015	12	26	3	5	33	38	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	26	3	15	33	37	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	26	3	25	33	38	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	26	3	35	33	38	0	0	0	0	0	0	0	32.2	0	0	11.8
2015	12	26	3	45	33	37	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	26	3	55	33	38	0	0	0	0	0	0	0	32.16	0	0	11.8
2015	12	26	4	5	33	37	2	0	0	0	0	0	0	32.16	0	0	11.8
2015	12	26	4	15	33	38	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	26	4	25	33	38	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	26	4	35	33	37	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	26	4	45	33	37	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	26	4	55	33	38	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	26	5	5	33	38	0	0	0	0	0	0	0	32.05	0	0	11.6
2015	12	26	5	15	33	38	0	0	0	0	0	0	0	32.04	0	0	11.6
2015	12	26	5	25	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6
2015	12	26	5	35	33	37	0	0	0	0	0	0	0	32.02	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	5	45	33	37	0	0	0	0	0	0	0	32	0	0	11.6
2015	12	26	5	55	33	38	0	0	0	0	0	0	0	31.98	0	0	11.6
2015	12	26	6	5	33	37	0	0	0	0	0	0	0	31.96	0	0	11.6
2015	12	26	6	15	33	37	0	0	0	0	0	0	0	31.95	0	0	11.6
2015	12	26	6	25	33	37	0	0	0	0	0	0	0	31.95	0	0	11.6
2015	12	26	6	35	33	38	0	0	0	0	0	0	0	31.93	0	0	11.6
2015	12	26	6	45	33	38	0	0	0	0	0	0	0	31.91	0	0	11.6
2015	12	26	6	55	33	38	0	0	0	0	0	0	0	31.91	0	0	11.6
2015	12	26	7	5	33	38	0	0	0	0	0	0	0	31.89	0	0	11.6
2015	12	26	7	15	33	37	0	0	0	0	0	0	0	31.89	0	0	11.6
2015	12	26	7	25	33	37	0	0	0	0	0	0	0	31.89	0	0	11.6
2015	12	26	7	35	33	37	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	26	7	45	33	38	0	0	0	0	0	0	0	31.89	0	0	12
2015	12	26	7	55	33	38	0	0	0	0	0	0	0	31.91	0	0	12.2
2015	12	26	8	5	33	38	0	0	0	0	0	0	0	31.93	0	0	12.4
2015	12	26	8	15	33	37	0	0	0	0	0	0	0	31.96	0	0	12.4
2015	12	26	8	25	33	38	0	0	0	0	0	0	0	32	0	0	12.6
2015	12	26	8	35	33	36	0	0	0	0	0	0	0	32.04	0	0	12.6
2015	12	26	8	45	33	37	0	0	0	0	0	0	0	32.05	0	0	12.6
2015	12	26	8	55	33	37	0	0	0	0	0	0	0	32.09	0	0	12.8
2015	12	26	9	5	33	38	0	0	0	0	0	0	0	32.13	0	0	12.8
2015	12	26	9	15	33	38	0	0	0	0	0	0	0	32.18	0	0	12.8
2015	12	26	9	25	33	37	0	0	0	0	0	0	0	32.22	0	0	12.8
2015	12	26	9	35	33	37	0	0	0	0	0	0	0	32.23	0	0	12.8
2015	12	26	9	45	33	38	0	0	0	0	0	0	0	32.27	0	0	13
2015	12	26	9	55	33	37	0	0	0	0	0	0	0	32.29	0	0	13
2015	12	26	10	5	33	37	0	0	0	0	0	0	0	32.32	0	0	13
2015	12	26	10	15	33	38	0	0	0	0	0	0	0	32.32	0	0	13
2015	12	26	10	25	33	38	0	0	0	0	0	0	0	32.38	0	0	13.2
2015	12	26	10	35	33	38	0	0	0	0	0	0	0	32.4	0	0	13.2
2015	12	26	10	45	33	37	0	0	0	0	0	0	0	32.43	0	0	13.4
2015	12	26	10	55	33	38	0	0	0	0	0	0	0	32.45	0	0	13.6
2015	12	26	11	5	33	37	0	0	0	0	0	0	0	32.49	0	0	14
2015	12	26	11	15	33	38	0	0	0	0	0	0	0	32.49	0	0	14
2015	12	26	11	25	33	37	0	0	0	0	0	0	0	32.52	0	0	14
2015	12	26	11	35	33	37	0	0	0	0	0	0	0	32.52	0	0	14
2015	12	26	11	45	33	37	0	0	0	0	0	0	0	32.54	0	0	14
2015	12	26	11	55	33	38	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	26	12	5	33	38	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	26	12	15	33	38	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	12	25	33	38	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	12	35	33	37	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	12	45	33	37	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	12	55	33	38	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	13	5	33	38	0	0	0	0	0	0	0	32.58	0	0	14
2015	12	26	13	15	33	37	0	0	0	0	0	0	0	32.58	0	0	14

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	13	25	33	37	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	26	13	35	33	38	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	26	13	45	33	38	0	0	0	0	0	0	0	32.56	0	0	14
2015	12	26	13	55	33	37	0	0	0	0	0	0	0	32.52	0	0	14
2015	12	26	14	5	33	38	4	0	0	0	0	0	0	32.52	0	0	14
2015	12	26	14	15	33	38	1	0	0	0	0	0	0	32.5	0	0	14
2015	12	26	14	25	33	37	0	0	0	0	0	0	0	32.5	0	0	14
2015	12	26	14	35	33	38	0	0	0	0	0	0	0	32.49	0	0	14
2015	12	26	14	45	33	37	0	0	0	0	0	0	0	32.45	0	0	14
2015	12	26	14	55	33	38	0	0	0	0	0	0	0	32.43	0	0	14
2015	12	26	15	5	33	38	0	0	0	0	0	0	0	32.41	0	0	14
2015	12	26	15	15	33	38	0	0	0	0	0	0	0	32.38	0	0	13.4
2015	12	26	15	25	33	38	0	0	0	0	0	0	0	32.34	0	0	12.6
2015	12	26	15	35	33	38	0	0	0	0	0	0	0	32.34	0	0	12.4
2015	12	26	15	45	33	37	0	0	0	0	0	0	0	32.32	0	0	12.4
2015	12	26	15	55	33	37	0	0	0	0	0	0	0	32.32	0	0	12.2
2015	12	26	16	5	33	38	0	0	0	0	0	0	0	32.31	0	0	12.2
2015	12	26	16	15	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	16	25	33	38	0	0	0	0	0	0	0	32.32	0	0	12
2015	12	26	16	35	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	16	45	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	16	55	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	17	5	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	17	15	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	17	25	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	17	35	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	17	45	33	37	0	0	0	0	0	0	0	32.32	0	0	12
2015	12	26	17	55	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	5	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	15	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	25	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	35	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	45	33	37	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	18	55	33	38	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	26	19	5	33	38	0	0	0	0	0	0	0	32.31	0	0	12
2015	12	26	19	15	33	38	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	26	19	25	33	38	0	0	0	0	0	0	0	32.29	0	0	12
2015	12	26	19	35	33	37	0	0	0	0	0	0	0	32.27	0	0	12
2015	12	26	19	45	33	38	0	0	0	0	0	0	0	32.27	0	0	12
2015	12	26	19	55	33	38	0	0	0	0	0	0	0	32.27	0	0	12
2015	12	26	20	5	33	38	0	0	0	0	0	0	0	32.25	0	0	11.8
2015	12	26	20	15	33	38	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	26	20	25	33	37	0	0	0	0	0	0	0	32.23	0	0	11.8
2015	12	26	20	35	33	38	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	26	20	45	33	37	0	0	0	0	0	0	0	32.22	0	0	11.8
2015	12	26	20	55	33	37	0	0	0	0	0	0	0	32.2	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	26	21	5	33	38	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	26	21	15	33	38	0	0	0	0	0	0	0	32.18	0	0	11.8
2015	12	26	21	25	33	38	0	0	0	0	0	0	0	32.16	0	0	11.8
2015	12	26	21	35	33	37	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	26	21	45	33	37	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	26	21	55	33	38	0	0	0	0	0	0	0	32.14	0	0	11.8
2015	12	26	22	5	33	37	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	26	22	15	33	37	0	0	0	0	0	0	0	32.13	0	0	11.8
2015	12	26	22	25	33	38	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	26	22	35	33	37	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	26	22	45	33	38	0	0	0	0	0	0	0	32.11	0	0	11.8
2015	12	26	22	55	33	38	0	0	0	0	0	0	0	32.09	0	0	11.8
2015	12	26	23	5	33	38	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	26	23	15	33	37	0	0	0	0	0	0	0	32.07	0	0	11.8
2015	12	26	23	25	33	37	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	26	23	35	33	37	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	26	23	45	33	38	0	0	0	0	0	0	0	32.04	0	0	11.8
2015	12	26	23	55	33	37	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	27	0	5	33	38	0	0	0	0	0	0	0	32	0	0	11.8
2015	12	27	0	15	33	37	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	27	0	25	33	38	0	0	0	0	0	0	0	31.98	0	0	11.8
2015	12	27	0	35	33	38	0	0	0	0	0	0	0	31.96	0	0	11.8
2015	12	27	0	45	33	38	0	0	0	0	0	0	0	31.95	0	0	11.8
2015	12	27	0	55	33	38	0	0	0	0	0	0	0	31.93	0	0	11.8
2015	12	27	1	5	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	27	1	15	33	37	0	0	0	0	0	0	0	31.91	0	0	11.8
2015	12	27	1	25	33	37	0	0	0	0	0	0	0	31.89	0	0	11.8
2015	12	27	1	35	33	38	0	0	0	0	0	0	0	31.87	0	0	11.8
2015	12	27	1	45	33	38	0	0	0	0	0	0	0	31.86	0	0	11.8
2015	12	27	1	55	33	38	0	0	0	0	0	0	0	31.84	0	0	11.8
2015	12	27	2	5	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	27	2	15	33	38	0	0	0	0	0	0	0	31.82	0	0	11.8
2015	12	27	2	25	33	37	0	0	0	0	0	0	0	31.8	0	0	11.8
2015	12	27	2	35	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	27	2	45	33	38	0	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	27	2	55	33	37	0	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	27	3	5	33	38	0	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	27	3	15	33	38	0	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	27	3	25	33	37	0	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	27	3	35	33	37	0	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	27	3	45	33	38	0	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	27	3	55	33	37	0	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	27	4	5	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	4	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	4	25	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	4	35	33	38	0	0	0	0	0	0	0	31.69	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	4	45	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	4	55	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	5	5	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	5	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	5	25	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	5	35	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	5	45	33	38	0	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	27	5	55	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	6	5	33	38	0	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	27	6	15	33	38	0	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	27	6	25	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	6	35	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	6	45	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	6	55	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	7	5	33	37	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	7	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	27	7	25	33	38	0	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	27	7	35	33	38	0	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	27	7	45	33	37	0	0	0	0	0	0	0	31.75	0	0	12
2015	12	27	7	55	33	38	0	0	0	0	0	0	0	31.77	0	0	12.2
2015	12	27	8	5	33	37	0	0	0	0	0	0	0	31.8	0	0	12.4
2015	12	27	8	15	33	38	0	0	0	0	0	0	0	31.84	0	0	12.6
2015	12	27	8	25	33	37	0	0	0	0	0	0	0	31.87	0	0	12.8
2015	12	27	8	35	33	38	0	0	0	0	0	0	0	31.91	0	0	12.8
2015	12	27	8	45	33	38	0	0	0	0	0	0	0	31.95	0	0	13
2015	12	27	8	55	33	37	0	0	0	0	0	0	0	32	0	0	13.2
2015	12	27	9	5	33	38	0	0	0	0	0	0	0	32.02	0	0	13.2
2015	12	27	9	15	33	38	0	0	0	0	0	0	0	32.07	0	0	13.4
2015	12	27	9	25	33	38	0	0	0	0	0	0	0	32.13	0	0	13.4
2015	12	27	9	35	33	38	0	0	0	0	0	0	0	32.14	0	0	13.4
2015	12	27	9	45	33	38	0	0	0	0	0	0	0	32.16	0	0	13.4
2015	12	27	9	55	33	38	0	0	0	0	0	0	0	32.22	0	0	13.4
2015	12	27	10	5	33	37	0	0	0	0	0	0	0	32.23	0	0	13.4
2015	12	27	10	15	33	37	0	0	0	0	0	0	0	32.25	0	0	13.6
2015	12	27	10	25	33	38	0	0	0	0	0	0	0	32.29	0	0	13.4
2015	12	27	10	35	33	38	0	0	0	0	0	0	0	32.29	0	0	13.4
2015	12	27	10	45	33	38	0	0	0	0	0	0	0	32.31	0	0	13.6
2015	12	27	10	55	33	37	0	0	0	0	0	0	0	32.34	0	0	14
2015	12	27	11	5	33	37	0	0	0	0	0	0	0	32.38	0	0	14
2015	12	27	11	15	33	38	0	0	0	0	0	0	0	32.36	0	0	13.8
2015	12	27	11	25	33	38	0	0	0	0	0	0	0	32.36	0	0	13.8
2015	12	27	11	35	33	38	0	0	0	0	0	0	0	32.4	0	0	13.8
2015	12	27	11	45	33	38	0	0	0	0	0	0	0	32.36	0	0	13.8
2015	12	27	11	55	33	37	0	0	0	0	0	0	0	32.36	0	0	13.8
2015	12	27	12	5	33	37	0	0	0	0	0	0	0	32.38	0	0	13.8
2015	12	27	12	15	33	37	0	0	0	0	0	0	0	32.36	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	12	25	33	37	0	0	0	0	0	0	0	32.31	0	0	13.8
2015	12	27	12	35	33	38	0	0	0	0	0	0	0	32.32	0	0	13.8
2015	12	27	12	45	33	37	0	0	0	0	0	0	0	32.31	0	0	13.8
2015	12	27	12	55	33	38	0	0	0	0	0	0	0	32.27	0	0	13.8
2015	12	27	13	5	33	37	0	0	0	0	0	0	0	32.27	0	0	13.8
2015	12	27	13	15	33	38	0	0	0	0	0	0	0	32.27	0	0	13.8
2015	12	27	13	25	33	38	0	0	0	0	0	0	0	32.27	0	0	13.8
2015	12	27	13	35	33	38	0	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	27	13	45	33	38	0	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	27	13	55	33	37	0	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	27	14	5	33	38	0	0	0	0	0	0	0	32.16	0	0	13.8
2015	12	27	14	15	33	38	0	0	0	0	0	0	0	32.14	0	0	13.8
2015	12	27	14	25	33	38	0	0	0	0	0	0	0	32.13	0	0	13.8
2015	12	27	14	35	33	37	0	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	27	14	45	33	37	0	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	27	14	55	33	38	0	0	0	0	0	0	0	32.02	0	0	12.4
2015	12	27	15	5	33	38	0	0	0	0	0	0	0	31.98	0	0	13
2015	12	27	15	15	33	38	0	0	0	0	0	0	0	31.96	0	0	12.4
2015	12	27	15	25	33	38	0	0	0	0	0	0	0	31.93	0	0	13.8
2015	12	27	15	35	33	38	0	0	0	0	0	0	0	31.91	0	0	13
2015	12	27	15	45	33	38	0	0	0	0	0	0	0	31.89	0	0	12.4
2015	12	27	15	55	33	38	0	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	27	16	5	33	38	0	0	0	0	0	0	0	31.84	0	0	12.2
2015	12	27	16	15	33	38	0	0	0	0	0	0	0	31.82	0	0	12
2015	12	27	16	25	33	38	0	0	0	0	0	0	0	31.8	0	0	12
2015	12	27	16	35	33	38	0	0	0	0	0	0	0	31.8	0	0	12
2015	12	27	16	45	33	38	0	0	0	0	0	0	0	31.78	0	0	12
2015	12	27	16	55	33	38	0	0	0	0	0	0	0	31.77	0	0	12
2015	12	27	17	5	33	38	0	0	0	0	0	0	0	31.77	0	0	12
2015	12	27	17	15	33	38	0	0	0	0	0	0	0	31.75	0	0	12
2015	12	27	17	25	33	38	0	0	0	0	0	0	0	31.75	0	0	12
2015	12	27	17	35	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	17	45	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	17	55	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	5	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	15	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	25	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	35	33	37	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	45	33	38	0	0	0	0	0	0	0	31.73	0	0	12
2015	12	27	18	55	33	37	0	0	0	0	0	0	0	31.71	0	0	12
2015	12	27	19	5	33	38	0	0	0	0	0	0	0	31.71	0	0	12
2015	12	27	19	15	33	37	0	0	0	0	0	0	0	31.71	0	0	12
2015	12	27	19	25	33	38	0	0	0	0	0	0	0	31.71	0	0	12
2015	12	27	19	35	33	38	0	0	0	0	0	0	0	31.71	0	0	12
2015	12	27	19	45	33	37	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	19	55	33	37	0	0	0	0	0	0	0	31.71	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	27	20	5	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	20	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	20	25	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	20	35	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	20	45	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	20	55	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	5	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	25	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	35	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	45	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	21	55	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	22	5	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	22	15	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	22	25	33	37	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	22	35	33	37	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	22	45	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	27	22	55	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	23	5	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	23	15	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	23	25	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	23	35	33	38	0	0	0	0	0	0	0	31.68	0	0	11.8
2015	12	27	23	45	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	27	23	55	33	38	11	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	0	5	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	0	15	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	0	25	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	0	35	33	38	12	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	0	45	33	37	47	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	0	55	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	1	5	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	1	15	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	1	25	33	38	0	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	1	35	33	38	23	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	1	45	33	37	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	1	55	33	38	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	2	5	33	37	0	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	2	15	33	38	13	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	28	2	25	33	37	27	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	2	35	33	38	18	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	2	45	33	38	14	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	2	55	33	37	76	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	3	5	33	38	42	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	3	15	33	38	18	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	3	25	33	37	24	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	3	35	33	37	106	0	0	0	0	0	0	31.69	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	3	45	33	38	34	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	3	55	33	38	19	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	4	5	33	38	6	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	4	15	33	38	84	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	4	25	33	38	23	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	4	35	33	38	46	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	4	45	33	38	42	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	4	55	33	37	4	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	5	5	33	38	116	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	5	15	33	38	31	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	5	25	33	38	68	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	28	5	35	33	37	14	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	5	45	33	38	45	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	5	55	33	38	122	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	5	33	38	81	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	15	33	38	116	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	25	33	38	37	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	35	33	38	70	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	45	33	39	67	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	6	55	33	37	14	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	7	5	33	37	99	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	7	15	33	37	108	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	28	7	25	33	37	111	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	28	7	35	33	37	149	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	7	45	33	38	38	0	0	0	0	0	0	31.73	0	0	12
2015	12	28	7	55	33	37	118	0	0	0	0	0	0	31.77	0	0	12.2
2015	12	28	8	5	33	38	82	0	0	0	0	0	0	31.77	0	0	12.4
2015	12	28	8	15	33	38	99	0	0	0	0	0	0	31.8	0	0	12.6
2015	12	28	8	25	33	38	129	0	0	0	0	0	0	31.82	0	0	12.8
2015	12	28	8	35	33	38	107	0	0	0	0	0	0	31.87	0	0	13
2015	12	28	8	45	33	38	109	0	0	0	0	0	0	31.91	0	0	13
2015	12	28	8	55	33	38	150	0	0	0	0	0	0	31.95	0	0	13.2
2015	12	28	9	5	33	38	143	0	0	0	0	0	0	31.98	0	0	13.2
2015	12	28	9	15	33	38	75	0	0	0	0	0	0	32	0	0	13.4
2015	12	28	9	25	33	39	135	0	0	0	0	0	0	32.02	0	0	13.4
2015	12	28	9	35	33	38	196	0	0	0	0	0	0	32.04	0	0	13.4
2015	12	28	9	45	33	37	147	0	0	0	0	0	0	32.09	0	0	13.4
2015	12	28	9	55	33	39	197	0	0	0	0	0	0	32.09	0	0	13.4
2015	12	28	10	5	33	38	200	0	0	0	0	0	0	32.14	0	0	13.6
2015	12	28	10	15	33	38	150	0	0	0	0	0	0	32.18	0	0	13.6
2015	12	28	10	25	33	38	104	0	0	0	0	0	0	32.23	0	0	13.6
2015	12	28	10	35	33	37	109	0	0	0	0	0	0	32.23	0	0	13.8
2015	12	28	10	45	33	37	59	0	0	0	0	0	0	32.23	0	0	13.4
2015	12	28	10	55	33	38	182	0	0	0	0	0	0	32.22	0	0	14
2015	12	28	11	5	33	37	80	0	0	0	0	0	0	32.2	0	0	14
2015	12	28	11	15	33	38	137	0	0	0	0	0	0	32.27	0	0	14

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	11	25	33	37	186	0	0	0	0	0	0	32.29	0	0	14
2015	12	28	11	35	33	38	200	0	0	0	0	0	0	32.23	0	0	12.6
2015	12	28	11	45	33	38	45	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	28	11	55	33	38	64	0	0	0	0	0	0	32.32	0	0	13.6
2015	12	28	12	5	33	38	103	0	0	0	0	0	0	32.29	0	0	13
2015	12	28	12	15	33	38	137	0	0	0	0	0	0	32.27	0	0	14
2015	12	28	12	25	33	38	77	0	0	0	0	0	0	32.22	0	0	14
2015	12	28	12	35	33	38	188	0	0	0	0	0	0	32.22	0	0	13.6
2015	12	28	12	45	33	37	172	0	0	0	0	0	0	32.09	0	0	12.4
2015	12	28	12	55	33	38	58	0	0	0	0	0	0	32.05	0	0	12.8
2015	12	28	13	5	33	37	150	0	0	0	0	0	0	32.04	0	0	12.6
2015	12	28	13	15	33	38	131	0	0	0	0	0	0	32.02	0	0	12.4
2015	12	28	13	25	33	38	67	0	0	0	0	0	0	31.98	0	0	12.4
2015	12	28	13	35	33	38	50	0	0	0	0	0	0	31.95	0	0	12.2
2015	12	28	13	45	33	37	58	0	0	0	0	0	0	31.91	0	0	12.2
2015	12	28	13	55	33	37	2	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	28	14	5	33	37	6	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	28	14	15	33	38	0	0	0	0	0	0	0	31.91	0	0	12.2
2015	12	28	14	25	33	38	0	0	0	0	0	0	0	31.93	0	0	12.4
2015	12	28	14	35	33	38	0	0	0	0	0	0	0	31.95	0	0	12.4
2015	12	28	14	45	33	38	0	0	0	0	0	0	0	31.91	0	0	12.2
2015	12	28	14	55	33	38	0	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	28	15	5	33	38	26	0	0	0	0	0	0	31.89	0	0	12.2
2015	12	28	15	15	33	38	42	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	28	15	25	33	38	8	0	0	0	0	0	0	31.87	0	0	12.2
2015	12	28	15	35	33	38	9	0	0	0	0	0	0	31.86	0	0	12.2
2015	12	28	15	45	33	38	0	0	0	0	0	0	0	31.84	0	0	12
2015	12	28	15	55	33	38	0	0	0	0	0	0	0	31.82	0	0	12
2015	12	28	16	5	33	38	0	0	0	0	0	0	0	31.8	0	0	12
2015	12	28	16	15	33	37	0	0	0	0	0	0	0	31.78	0	0	12
2015	12	28	16	25	33	38	0	0	0	0	0	0	0	31.78	0	0	12
2015	12	28	16	35	33	37	5	0	0	0	0	0	0	31.77	0	0	12
2015	12	28	16	45	33	38	0	0	0	0	0	0	0	31.77	0	0	12
2015	12	28	16	55	33	38	3	0	0	0	0	0	0	31.77	0	0	12
2015	12	28	17	5	33	38	9	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	17	15	33	37	13	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	17	25	33	38	73	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	17	35	33	37	18	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	17	45	33	38	100	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	17	55	33	38	112	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	18	5	33	38	100	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	18	15	33	38	86	0	0	0	0	0	0	31.73	0	0	12
2015	12	28	18	25	33	38	63	0	0	0	0	0	0	31.75	0	0	12
2015	12	28	18	35	33	38	104	0	0	0	0	0	0	31.73	0	0	12
2015	12	28	18	45	33	38	100	0	0	0	0	0	0	31.73	0	0	12
2015	12	28	18	55	33	38	99	0	0	0	0	0	0	31.73	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	28	19	5	33	38	84	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	19	15	33	38	100	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	19	25	33	38	166	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	19	35	33	38	100	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	19	45	33	38	96	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	19	55	33	37	100	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	20	5	33	38	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	20	15	33	37	114	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	20	25	33	38	62	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	20	35	33	37	126	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	20	45	33	38	115	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	20	55	33	38	138	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	5	33	38	127	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	15	33	38	33	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	25	33	37	86	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	35	33	37	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	45	33	38	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	21	55	33	37	104	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	22	5	33	38	160	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	22	15	33	38	112	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	22	25	33	38	109	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	22	35	33	38	105	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	22	45	33	38	49	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	22	55	33	39	146	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	23	5	33	38	200	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	28	23	15	33	38	61	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	23	25	33	38	130	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	23	35	33	37	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	23	45	33	37	82	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	28	23	55	33	38	43	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	0	5	33	38	173	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	0	15	33	38	18	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	0	25	33	38	6	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	0	35	33	38	136	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	0	45	33	38	111	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	0	55	33	38	116	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	1	5	33	37	21	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	1	15	33	38	101	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	1	25	33	38	47	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	1	35	33	38	125	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	1	45	33	37	59	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	1	55	33	37	134	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	2	5	33	38	94	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	2	15	33	38	52	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	2	25	33	38	35	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	2	35	33	38	112	0	0	0	0	0	0	31.71	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	2	45	33	37	113	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	2	55	33	38	12	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	5	33	37	155	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	15	33	38	103	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	25	33	37	58	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	35	33	37	89	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	45	33	37	139	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	3	55	33	38	56	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	5	33	37	121	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	15	33	38	76	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	25	33	37	60	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	35	33	38	109	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	45	33	38	121	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	4	55	33	38	170	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	5	33	38	9	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	15	33	38	115	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	25	33	37	150	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	35	33	38	179	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	45	33	37	55	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	5	55	33	38	198	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	6	5	33	38	66	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	6	15	33	38	113	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	6	25	33	38	65	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	6	35	33	37	43	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	6	45	33	39	143	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	6	55	33	37	134	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	7	5	33	38	112	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	7	15	33	38	40	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	29	7	25	33	38	67	0	0	0	0	0	0	31.73	0	0	11.6
2015	12	29	7	35	33	38	57	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	7	45	33	38	144	0	0	0	0	0	0	31.73	0	0	12
2015	12	29	7	55	33	38	87	0	0	0	0	0	0	31.75	0	0	12.2
2015	12	29	8	5	33	38	145	0	0	0	0	0	0	31.77	0	0	12.2
2015	12	29	8	15	33	38	73	0	0	0	0	0	0	31.78	0	0	12.4
2015	12	29	8	25	33	37	125	0	0	0	0	0	0	31.8	0	0	12.6
2015	12	29	8	35	33	38	200	0	0	0	0	0	0	31.82	0	0	12.6
2015	12	29	8	45	33	37	200	0	0	0	0	0	0	31.84	0	0	12.8
2015	12	29	8	55	33	37	200	0	0	0	0	0	0	31.86	0	0	12.8
2015	12	29	9	5	33	38	149	0	0	0	0	0	0	31.89	0	0	12.8
2015	12	29	9	15	33	38	191	0	0	0	0	0	0	31.91	0	0	12.8
2015	12	29	9	25	33	37	49	0	0	0	0	0	0	31.93	0	0	12.8
2015	12	29	9	35	33	38	135	0	0	0	0	0	0	31.95	0	0	12.8
2015	12	29	9	45	33	37	180	0	0	0	0	0	0	31.96	0	0	12.8
2015	12	29	9	55	33	38	105	0	0	0	0	0	0	31.98	0	0	12.8
2015	12	29	10	5	33	38	105	0	0	0	0	0	0	32	0	0	13
2015	12	29	10	15	33	38	96	0	0	0	0	0	0	32.04	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	10	25	33	38	12	0	0	0	0	0	0	32.04	0	0	13
2015	12	29	10	35	33	38	136	0	0	0	0	0	0	32.07	0	0	13
2015	12	29	10	45	33	38	138	0	0	0	0	0	0	32.05	0	0	13
2015	12	29	10	55	33	38	100	0	0	0	0	0	0	32.09	0	0	13
2015	12	29	11	5	33	37	128	0	0	0	0	0	0	32.11	0	0	13.2
2015	12	29	11	15	33	37	129	0	0	0	0	0	0	32.11	0	0	13.2
2015	12	29	11	25	33	38	144	0	0	0	0	0	0	32.13	0	0	13.2
2015	12	29	11	35	33	38	156	0	0	0	0	0	0	32.13	0	0	13.4
2015	12	29	11	45	33	37	155	0	0	0	0	0	0	32.13	0	0	13.8
2015	12	29	11	55	33	38	140	0	0	0	0	0	0	32.13	0	0	13.8
2015	12	29	12	5	33	38	193	0	0	0	0	0	0	32.13	0	0	14
2015	12	29	12	15	33	38	66	0	0	0	0	0	0	32.14	0	0	14
2015	12	29	12	25	33	37	76	0	0	0	0	0	0	32.14	0	0	14
2015	12	29	12	35	33	38	62	0	0	0	0	0	0	32.13	0	0	14
2015	12	29	12	45	33	38	73	0	0	0	0	0	0	32.13	0	0	14
2015	12	29	12	55	33	38	118	0	0	0	0	0	0	32.13	0	0	13.8
2015	12	29	13	5	33	38	55	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	29	13	15	33	37	61	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	29	13	25	33	38	80	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	29	13	35	33	38	44	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	29	13	45	33	38	92	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	29	13	55	33	38	38	0	0	0	0	0	0	32.05	0	0	13.8
2015	12	29	14	5	33	38	183	0	0	0	0	0	0	32.04	0	0	13.8
2015	12	29	14	15	33	38	118	0	0	0	0	0	0	32.02	0	0	13.8
2015	12	29	14	25	33	38	200	0	0	0	0	0	0	32	0	0	13.8
2015	12	29	14	35	33	38	48	0	0	0	0	0	0	31.98	0	0	13.8
2015	12	29	14	45	33	37	50	0	0	0	0	0	0	31.96	0	0	13.8
2015	12	29	14	55	33	38	200	0	0	0	0	0	0	31.95	0	0	13.8
2015	12	29	15	5	33	38	200	0	0	0	0	0	0	31.91	0	0	13.8
2015	12	29	15	15	33	38	100	0	0	0	0	0	0	31.89	0	0	13.4
2015	12	29	15	25	33	37	132	0	0	0	0	0	0	31.86	0	0	12.6
2015	12	29	15	35	33	38	200	0	0	0	0	0	0	31.82	0	0	12.4
2015	12	29	15	45	33	38	165	0	0	0	0	0	0	31.82	0	0	12.4
2015	12	29	15	55	33	37	200	0	0	0	0	0	0	31.8	0	0	12.2
2015	12	29	16	5	33	38	200	0	0	0	0	0	0	31.78	0	0	12.2
2015	12	29	16	15	33	37	200	0	0	0	0	0	0	31.78	0	0	12
2015	12	29	16	25	33	38	193	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	16	35	33	37	155	0	0	0	0	0	0	31.78	0	0	12
2015	12	29	16	45	33	38	139	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	16	55	33	39	71	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	17	5	33	38	129	0	0	0	0	0	0	31.75	0	0	12
2015	12	29	17	15	33	38	136	0	0	0	0	0	0	31.75	0	0	12
2015	12	29	17	25	33	38	168	0	0	0	0	0	0	31.75	0	0	12
2015	12	29	17	35	33	38	127	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	17	45	33	38	74	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	17	55	33	38	178	0	0	0	0	0	0	31.75	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	29	18	5	33	38	102	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	18	15	33	37	33	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	18	25	33	38	142	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	18	35	33	37	60	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	18	45	33	37	142	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	18	55	33	38	132	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	19	5	33	38	26	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	19	15	33	37	124	0	0	0	0	0	0	31.77	0	0	12
2015	12	29	19	25	33	38	135	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	29	19	35	33	38	176	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	29	19	45	33	38	135	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	19	55	33	38	106	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	29	20	5	33	37	52	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	29	20	15	33	38	35	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	29	20	25	33	38	126	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	20	35	33	38	151	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	20	45	33	38	178	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	20	55	33	37	145	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	21	5	33	38	120	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	21	15	33	38	19	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	21	25	33	38	183	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	21	35	33	38	18	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	21	45	33	37	157	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	21	55	33	38	200	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	29	22	5	33	37	131	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	22	15	33	38	182	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	22	25	33	37	167	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	22	35	33	38	200	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	22	45	33	37	123	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	22	55	33	37	200	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	23	5	33	38	88	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	23	15	33	38	200	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	23	25	33	37	154	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	29	23	35	33	38	190	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	23	45	33	38	182	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	29	23	55	33	38	200	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	5	33	38	97	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	15	33	38	182	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	25	33	38	200	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	35	33	37	150	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	45	33	37	82	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	0	55	33	38	138	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	1	5	33	37	147	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	1	15	33	37	166	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	1	25	33	38	131	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	1	35	33	38	196	0	0	0	0	0	0	31.71	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	1	45	33	37	106	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	30	1	55	33	38	167	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	2	5	33	38	146	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	2	15	33	38	157	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	2	25	33	38	154	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	2	35	33	38	43	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	2	45	33	38	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	2	55	33	38	173	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	3	5	33	38	153	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	3	15	33	38	177	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	3	25	33	38	101	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	3	35	33	38	200	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	3	45	33	37	132	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	3	55	33	39	136	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	4	5	33	38	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	4	15	33	37	74	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	4	25	33	38	94	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	4	35	33	38	119	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	4	45	33	38	176	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	4	55	33	38	117	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	5	5	33	38	7	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	5	15	33	37	78	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	5	25	33	38	40	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	5	35	33	38	73	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	5	45	33	38	151	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	5	55	33	38	126	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	6	5	33	38	120	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	6	15	33	38	31	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	6	25	33	38	17	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	6	35	33	38	100	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	6	45	33	38	153	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	6	55	33	38	81	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	7	5	33	38	100	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	7	15	33	38	40	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	30	7	25	33	37	100	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	30	7	35	33	38	43	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	7	45	33	37	82	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	7	55	33	38	52	0	0	0	0	0	0	31.73	0	0	12.2
2015	12	30	8	5	33	37	166	0	0	0	0	0	0	31.75	0	0	12.4
2015	12	30	8	15	33	37	24	0	0	0	0	0	0	31.77	0	0	12.6
2015	12	30	8	25	33	38	100	0	0	0	0	0	0	31.78	0	0	12.8
2015	12	30	8	35	33	38	112	0	0	0	0	0	0	31.8	0	0	13
2015	12	30	8	45	33	38	160	0	0	0	0	0	0	31.82	0	0	13
2015	12	30	8	55	33	38	190	0	0	0	0	0	0	31.86	0	0	13.2
2015	12	30	9	5	33	37	37	0	0	0	0	0	0	31.87	0	0	13.2
2015	12	30	9	15	33	38	103	0	0	0	0	0	0	31.89	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	9	25	33	38	58	0	0	0	0	0	0	31.91	0	0	13.4
2015	12	30	9	35	33	37	106	0	0	0	0	0	0	31.93	0	0	13.4
2015	12	30	9	45	33	38	25	0	0	0	0	0	0	31.96	0	0	13.4
2015	12	30	9	55	33	38	137	0	0	0	0	0	0	31.96	0	0	13.4
2015	12	30	10	5	33	38	200	0	0	0	0	0	0	32	0	0	13.6
2015	12	30	10	15	33	37	190	0	0	0	0	0	0	32.02	0	0	13.6
2015	12	30	10	25	33	37	84	0	0	0	0	0	0	32.02	0	0	13.6
2015	12	30	10	35	33	38	108	0	0	0	0	0	0	32.04	0	0	13.6
2015	12	30	10	45	33	38	125	0	0	0	0	0	0	32.04	0	0	14
2015	12	30	10	55	33	38	200	0	0	0	0	0	0	32.04	0	0	14
2015	12	30	11	5	33	37	70	0	0	0	0	0	0	32.07	0	0	14
2015	12	30	11	15	33	38	58	0	0	0	0	0	0	32.07	0	0	14
2015	12	30	11	25	33	38	100	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	30	11	35	33	38	174	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	30	11	45	33	38	102	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	11	55	33	38	128	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	5	33	38	131	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	15	33	38	74	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	25	33	37	72	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	35	33	38	13	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	45	33	37	114	0	0	0	0	0	0	32.11	0	0	13.8
2015	12	30	12	55	33	37	132	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	30	13	5	33	37	122	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	30	13	15	33	38	66	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	30	13	25	33	38	63	0	0	0	0	0	0	32.07	0	0	13.6
2015	12	30	13	42	15	38	72	0	0	0	0	0	0	32.04	0	0	13.6
2015	12	30	13	52	15	37	1	0	0	0	0	0	0	32.02	0	0	13.6
2015	12	30	14	2	15	37	126	0	0	0	0	0	0	32.02	0	0	13.8
2015	12	30	14	12	15	38	100	0	0	0	0	0	0	32	0	0	13.8
2015	12	30	14	22	15	38	89	0	0	0	0	0	0	31.98	0	0	13.8
2015	12	30	14	32	15	37	122	0	0	0	0	0	0	31.96	0	0	13.8
2015	12	30	14	42	15	38	123	0	0	0	0	0	0	31.93	0	0	13.6
2015	12	30	14	52	15	38	80	0	0	0	0	0	0	31.91	0	0	13.8
2015	12	30	15	2	15	37	112	0	0	0	0	0	0	31.89	0	0	13.8
2015	12	30	15	12	15	38	66	0	0	0	0	0	0	31.87	0	0	13.8
2015	12	30	15	22	15	38	78	0	0	0	0	0	0	31.86	0	0	13.8
2015	12	30	15	32	15	38	95	0	0	0	0	0	0	31.82	0	0	12.8
2015	12	30	15	42	15	38	135	0	0	0	0	0	0	31.8	0	0	12.4
2015	12	30	15	52	15	38	169	0	0	0	0	0	0	31.8	0	0	12.4
2015	12	30	16	2	15	37	93	0	0	0	0	0	0	31.78	0	0	12.2
2015	12	30	16	12	15	38	116	0	0	0	0	0	0	31.78	0	0	12.2
2015	12	30	16	22	15	38	200	0	0	0	0	0	0	31.77	0	0	12
2015	12	30	16	32	15	38	200	0	0	0	0	0	0	31.77	0	0	12
2015	12	30	16	42	15	38	170	0	0	0	0	0	0	31.75	0	0	12
2015	12	30	16	52	15	37	165	0	0	0	0	0	0	31.75	0	0	12
2015	12	30	17	2	15	38	29	0	0	0	0	0	0	31.75	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	30	17	12	15	38	8	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	17	22	15	38	100	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	17	32	15	37	81	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	17	42	15	38	54	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	17	52	15	38	28	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	18	2	15	38	110	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	18	12	15	37	176	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	18	22	15	38	89	0	0	0	0	0	0	31.71	0	0	12
2015	12	30	18	32	15	38	112	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	18	42	15	38	118	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	18	52	15	38	46	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	19	2	15	38	29	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	19	12	15	38	28	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	19	22	15	39	128	0	0	0	0	0	0	31.73	0	0	12
2015	12	30	19	32	15	38	103	0	0	0	0	0	0	31.71	0	0	12
2015	12	30	19	42	15	38	63	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	19	52	15	38	136	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	20	2	15	38	177	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	30	20	12	15	37	100	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	20	22	15	38	21	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	20	32	15	38	52	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	20	42	15	37	103	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	20	52	15	38	111	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	30	21	2	15	38	105	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	30	21	12	15	38	119	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	21	22	15	37	105	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	30	21	32	15	39	133	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	21	42	15	37	63	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	21	52	15	38	110	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	2	15	38	162	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	12	15	37	130	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	22	15	38	81	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	32	15	38	42	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	42	15	38	125	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	22	52	15	38	167	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	23	2	15	38	139	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	23	12	15	38	84	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	23	22	15	37	121	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	23	32	15	38	109	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	30	23	42	15	38	119	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	30	23	52	15	38	122	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	31	0	2	15	37	162	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	0	12	15	38	95	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	0	22	15	37	86	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	0	32	15	37	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	0	42	15	37	124	0	0	0	0	0	0	31.71	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	0	52	15	38	92	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	31	1	2	15	37	86	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	31	1	12	15	37	100	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	1	22	15	38	74	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	1	32	15	38	181	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	1	42	15	38	164	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	1	52	15	37	87	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	2	2	15	37	161	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	31	2	12	15	38	142	0	0	0	0	0	0	31.69	0	0	11.8
2015	12	31	2	22	15	38	99	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	2	32	15	38	98	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	2	42	15	38	93	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	2	52	15	37	182	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	3	2	15	38	183	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	3	12	15	37	200	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	3	22	15	38	105	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	3	32	15	39	142	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	3	42	15	38	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	3	52	15	38	170	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	2	15	38	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	12	15	37	124	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	22	15	38	188	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	32	15	37	140	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	42	15	38	99	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	4	52	15	38	87	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	5	2	15	38	123	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	5	12	15	37	101	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	5	22	15	37	179	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	5	32	15	38	109	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	5	42	15	38	158	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	5	52	15	37	55	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	6	2	15	37	195	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	6	12	15	37	133	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	6	22	15	38	164	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	6	32	15	38	109	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	6	42	15	37	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	6	52	15	38	163	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	7	2	15	38	147	0	0	0	0	0	0	31.69	0	0	11.6
2015	12	31	7	12	15	38	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	7	22	15	37	200	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	7	32	15	37	172	0	0	0	0	0	0	31.71	0	0	11.6
2015	12	31	7	42	15	37	133	0	0	0	0	0	0	31.71	0	0	11.8
2015	12	31	7	52	15	38	126	0	0	0	0	0	0	31.73	0	0	12
2015	12	31	8	2	15	38	161	0	0	0	0	0	0	31.77	0	0	12.2
2015	12	31	8	12	15	38	166	0	0	0	0	0	0	31.78	0	0	12.4
2015	12	31	8	22	15	38	123	0	0	0	0	0	0	31.8	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	8	32	15	38	155	0	0	0	0	0	0	31.82	0	0	12.8
2015	12	31	8	42	15	37	182	0	0	0	0	0	0	31.86	0	0	12.8
2015	12	31	8	52	15	38	171	0	0	0	0	0	0	31.87	0	0	13
2015	12	31	9	2	15	38	171	0	0	0	0	0	0	31.91	0	0	13
2015	12	31	9	12	15	38	200	0	0	0	0	0	0	31.95	0	0	13
2015	12	31	9	22	15	38	100	0	0	0	0	0	0	31.98	0	0	13
2015	12	31	9	32	15	37	178	0	0	0	0	0	0	32.02	0	0	13
2015	12	31	9	42	15	38	144	0	0	0	0	0	0	32.02	0	0	13.2
2015	12	31	9	52	15	38	97	0	0	0	0	0	0	32.05	0	0	13.2
2015	12	31	10	2	15	38	102	0	0	0	0	0	0	32.07	0	0	13.2
2015	12	31	10	12	15	38	154	0	0	0	0	0	0	32.09	0	0	13.2
2015	12	31	10	22	15	38	200	0	0	0	0	0	0	32.11	0	0	13.2
2015	12	31	10	32	15	38	200	0	0	0	0	0	0	32.11	0	0	13.4
2015	12	31	10	42	15	38	125	0	0	0	0	0	0	32.13	0	0	13.4
2015	12	31	10	52	15	38	123	0	0	0	0	0	0	32.14	0	0	13.4
2015	12	31	11	2	15	37	199	0	0	0	0	0	0	32.16	0	0	13.8
2015	12	31	11	12	15	39	200	0	0	0	0	0	0	32.16	0	0	13.8
2015	12	31	11	22	15	38	169	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	31	11	32	15	38	160	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	31	11	42	15	38	191	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	31	11	52	15	38	170	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	31	12	2	15	38	200	0	0	0	0	0	0	32.23	0	0	13.8
2015	12	31	12	12	15	38	171	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	31	12	22	15	38	200	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	31	12	32	15	38	140	0	0	0	0	0	0	32.2	0	0	13.8
2015	12	31	12	42	15	38	200	0	0	0	0	0	0	32.22	0	0	13.8
2015	12	31	12	52	15	37	117	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	31	13	2	15	38	200	0	0	0	0	0	0	32.18	0	0	13.8
2015	12	31	13	12	15	38	197	0	0	0	0	0	0	32.16	0	0	13.8
2015	12	31	13	22	15	37	177	0	0	0	0	0	0	32.14	0	0	13.8
2015	12	31	13	32	15	38	77	0	0	0	0	0	0	32.14	0	0	13.8
2015	12	31	13	42	15	37	200	0	0	0	0	0	0	32.13	0	0	13.6
2015	12	31	13	52	15	38	200	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	31	14	2	15	38	152	0	0	0	0	0	0	32.09	0	0	13.8
2015	12	31	14	12	15	38	131	0	0	0	0	0	0	32.07	0	0	13.8
2015	12	31	14	22	15	38	200	0	0	0	0	0	0	32.04	0	0	13.8
2015	12	31	14	32	15	38	88	0	0	0	0	0	0	32.02	0	0	13.8
2015	12	31	14	42	15	38	180	0	0	0	0	0	0	32	0	0	13.6
2015	12	31	14	52	15	37	120	0	0	0	0	0	0	31.96	0	0	13.8
2015	12	31	15	2	15	38	171	0	0	0	0	0	0	31.93	0	0	13.8
2015	12	31	15	12	15	38	122	0	0	0	0	0	0	31.91	0	0	13.8
2015	12	31	15	22	15	38	140	0	0	0	0	0	0	31.87	0	0	13.8
2015	12	31	15	32	15	38	194	0	0	0	0	0	0	31.84	0	0	13.2
2015	12	31	15	42	15	37	102	0	0	0	0	0	0	31.82	0	0	12.4
2015	12	31	15	52	15	38	200	0	0	0	0	0	0	31.8	0	0	12.4
2015	12	31	16	2	15	38	200	0	0	0	0	0	0	31.8	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	16	12	15	38	200	0	0	0	0	0	0	31.78	0	0	12.2
2015	12	31	16	22	15	38	200	0	0	0	0	0	0	31.78	0	0	12
2015	12	31	16	32	15	38	176	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	16	42	15	37	200	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	16	52	15	39	200	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	2	15	37	125	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	12	15	38	173	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	22	15	38	200	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	32	15	38	143	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	42	15	38	182	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	17	52	15	38	125	0	0	0	0	0	0	31.75	0	0	12
2015	12	31	18	2	15	38	131	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	18	12	15	38	169	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	18	22	15	38	155	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	18	32	15	38	200	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	18	42	15	38	158	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	18	52	15	39	154	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	19	2	15	37	200	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	19	12	15	38	200	0	0	0	0	0	0	31.78	0	0	12
2015	12	31	19	22	15	38	177	0	0	0	0	0	0	31.78	0	0	12
2015	12	31	19	32	15	38	131	0	0	0	0	0	0	31.77	0	0	12
2015	12	31	19	42	15	38	157	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	31	19	52	15	38	136	0	0	0	0	0	0	31.78	0	0	12
2015	12	31	20	2	15	38	200	0	0	0	0	0	0	31.78	0	0	12
2015	12	31	20	12	15	38	173	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	31	20	22	15	38	167	0	0	0	0	0	0	31.78	0	0	11.8
2015	12	31	20	32	15	38	200	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	20	42	15	37	200	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	20	52	15	38	200	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	21	2	15	37	200	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	21	12	15	37	114	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	21	22	15	38	157	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	21	32	15	38	91	0	0	0	0	0	0	31.77	0	0	11.8
2015	12	31	21	42	15	37	132	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	21	52	15	38	52	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	2	15	37	144	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	12	15	38	200	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	22	15	38	170	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	32	15	38	135	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	42	15	38	132	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	22	52	15	37	95	0	0	0	0	0	0	31.75	0	0	11.8
2015	12	31	23	2	15	38	178	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	31	23	12	15	38	145	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	31	23	22	15	38	197	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	31	23	32	15	37	156	0	0	0	0	0	0	31.73	0	0	11.8
2015	12	31	23	42	15	38	200	0	0	0	0	0	0	31.73	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	12	31	23	52	15	38	128	0	0	0	0	0	0	31.73	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	0	5	33	0.3	4.6	0.86	97.3	96.6798	78.6496
2015	12	1	0	15	33	0.3	4.6	0.86	98.6	96.6798	78.6496
2015	12	1	0	25	33	0.3	4.6	0.86	99.4	96.6798	78.6496
2015	12	1	0	35	33	0.3	4.6	0.88	98.3	96.6798	80.7753
2015	12	1	0	45	33	0.3	4.6	0.86	98.2	96.6798	78.346
2015	12	1	0	55	33	0.3	4.6	0.87	98.5	96.6798	79.5606
2015	12	1	1	5	33	0.3	4.6	0.88	100.7	96.6798	80.168
2015	12	1	1	15	33	0.3	4.6	0.84	98.9	96.6798	77.1313
2015	12	1	1	25	33	0.3	4.6	0.84	99.2	96.6798	76.524
2015	12	1	1	35	33	0.3	4.6	0.84	97.6	96.6798	77.435
2015	12	1	1	45	33	0.3	4.6	0.82	100.4	96.6798	74.3984
2015	12	1	1	55	33	0.3	4.6	0.86	99.6	96.6798	78.6497
2015	12	1	2	5	33	0.3	4.6	0.84	97.8	96.6142	77.3804
2015	12	1	2	15	33	0.3	4.6	0.85	100	96.6142	77.6838
2015	12	1	2	25	33	0.3	4.6	0.85	96.9	96.6142	77.6839
2015	12	1	2	35	33	0.3	4.6	0.83	99.1	96.6798	75.9168
2015	12	1	2	45	33	0.3	4.6	0.85	99.8	96.6142	77.6839
2015	12	1	2	55	33	0.3	4.6	0.88	99	96.6142	80.1115
2015	12	1	3	5	33	0.3	4.6	0.85	99.1	96.6142	77.9874
2015	12	1	3	15	33	0.3	4.6	0.88	98.6	96.6142	80.7185
2015	12	1	3	25	33	0.3	4.6	0.87	99.6	96.6142	79.2012
2015	12	1	3	35	33	0.3	4.6	0.86	99.9	96.6142	78.5944
2015	12	1	3	45	33	0.3	4.6	0.86	98.6	96.6142	78.5944
2015	12	1	3	55	33	0.3	4.6	0.83	99.1	96.6142	75.8633
2015	12	1	4	5	33	0.3	4.6	0.83	99.1	96.6142	76.1668
2015	12	1	4	15	33	0.3	4.6	0.84	100.6	96.6142	76.4703
2015	12	1	4	25	33	0.3	4.6	0.84	99.7	96.6142	76.1668
2015	12	1	4	35	33	0.3	4.6	0.86	98.1	96.5486	78.5389
2015	12	1	4	45	33	0.3	4.6	0.86	98.6	96.5486	78.2357
2015	12	1	4	55	33	0.3	4.6	0.86	97.9	96.5486	78.5389
2015	12	1	5	5	33	0.3	4.6	0.85	97.1	96.5486	77.6293
2015	12	1	5	15	33	0.3	4.6	0.88	97.7	96.5486	80.9649
2015	12	1	5	25	33	0.3	4.6	0.87	97.2	96.5486	79.4487
2015	12	1	5	35	33	0.3	4.6	0.86	97.9	96.5486	78.539
2015	12	1	5	45	33	0.3	4.6	0.88	99.9	96.5486	79.752
2015	12	1	5	55	33	0.3	4.6	0.91	99.5	96.5486	83.0877
2015	12	1	6	5	33	0.3	4.6	0.84	99.7	96.5486	76.4164
2015	12	1	6	15	33	0.3	4.6	0.88	99.4	96.5486	80.6618
2015	12	1	6	25	33	0.3	4.6	0.87	98.3	96.5486	79.1456
2015	12	1	6	35	33	0.3	4.6	0.87	100	96.483	79.0897
2015	12	1	6	45	33	0.3	4.6	0.85	100	96.5486	77.6295
2015	12	1	6	55	33	0.3	4.6	0.86	99.5	96.483	78.1806
2015	12	1	7	5	33	0.3	4.6	0.85	98.5	96.483	77.2716
2015	12	1	7	15	33	0.3	4.6	0.87	97.8	96.483	79.6958
2015	12	1	7	25	33	0.3	4.6	0.86	99	96.483	78.1807
2015	12	1	7	35	33	0.3	4.6	0.84	98.6	96.483	76.3625

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	7	45	33	0.3	4.6	0.91	99.6	96.483	82.423
2015	12	1	7	55	33	0.3	4.6	0.85	98.5	96.483	77.2716
2015	12	1	8	5	33	0.3	4.6	0.86	99	96.483	78.1806
2015	12	1	8	15	33	0.3	4.6	0.89	99.7	96.5486	81.2684
2015	12	1	8	25	33	0.3	4.6	0.88	98.6	96.5486	80.3586
2015	12	1	8	35	33	0.3	4.6	0.86	97.5	96.483	78.4836
2015	12	1	8	45	33	0.3	4.6	0.87	99.4	96.5486	79.1456
2015	12	1	8	55	33	0.3	4.6	0.85	99.3	96.5486	77.9326
2015	12	1	9	5	33	0.3	4.6	0.86	98.5	96.5486	78.8423
2015	12	1	9	15	33	0.3	4.6	0.84	99.9	96.5486	76.7196
2015	12	1	9	25	33	0.3	4.6	0.88	97.5	96.5486	80.3584
2015	12	1	9	35	33	0.3	4.6	0.85	96.9	96.5486	77.6292
2015	12	1	9	45	33	0.3	4.6	0.86	99.2	96.5486	78.5389
2015	12	1	9	55	33	0.3	4.6	0.89	100.2	96.5486	80.9647
2015	12	1	10	5	33	0.3	4.6	0.84	99.9	96.5486	76.1129
2015	12	1	10	15	33	0.3	4.6	0.84	101	96.5486	76.4161
2015	12	1	10	25	33	0.3	4.6	0.86	97.9	96.6142	78.5943
2015	12	1	10	35	33	0.3	4.6	0.87	98.9	96.5486	79.4484
2015	12	1	10	45	33	0.3	4.6	0.87	96.5	96.6142	80.415
2015	12	1	10	55	33	0.3	4.6	0.88	97.7	96.6142	80.7184
2015	12	1	11	5	33	0.3	4.6	0.89	97.4	96.6142	81.9322
2015	12	1	11	15	33	0.3	4.6	0.89	98.2	96.6142	81.6287
2015	12	1	11	25	33	0.3	4.6	0.82	98.3	96.6142	74.6493
2015	12	1	11	35	33	0.3	4.6	0.83	96.6	96.5486	76.1127
2015	12	1	11	45	33	0.3	4.6	0.86	98.6	96.5486	78.2353
2015	12	1	11	55	33	0.3	4.6	0.9	98.6	96.5486	81.8742
2015	12	1	12	5	33	0.3	4.6	0.84	97.8	96.5486	77.3255
2015	12	1	12	15	33	0.3	4.6	0.87	98.3	96.5486	79.4482
2015	12	1	12	25	33	0.3	4.6	0.83	98.7	96.5486	75.5061
2015	12	1	12	35	33	0.3	4.6	0.85	99.5	96.5486	77.932
2015	12	1	12	45	33	0.3	4.6	0.87	99.1	96.5486	79.7515
2015	12	1	12	55	33	0.3	4.6	0.84	101	96.5486	76.4158
2015	12	1	13	5	33	0.3	4.6	0.84	98.4	96.5486	76.4158
2015	12	1	13	15	33	0.3	4.6	0.85	98.9	96.5486	77.6288
2015	12	1	13	25	33	0.3	4.6	0.85	99.8	96.5486	77.3255
2015	12	1	13	35	33	0.3	4.6	0.86	99.7	96.5486	77.932
2015	12	1	13	45	33	0.3	4.6	0.86	97.9	96.5486	78.5385
2015	12	1	13	55	33	0.3	4.6	0.84	98.1	96.5486	77.0223
2015	12	1	14	5	33	0.3	4.6	0.87	99.7	96.5486	79.4482
2015	12	1	14	15	33	0.3	4.6	0.89	97.8	96.483	81.5131
2015	12	1	14	25	33	0.3	4.6	0.89	98	96.483	81.8162
2015	12	1	14	35	33	0.3	4.6	0.88	98.6	96.483	80.3011
2015	12	1	14	45	33	0.3	4.6	0.84	98	96.483	77.2708
2015	12	1	14	55	33	0.3	4.6	0.86	98.6	96.483	78.4829
2015	12	1	15	5	33	0.3	4.6	0.83	97.7	96.483	75.7557
2015	12	1	15	15	33	0.3	4.6	0.84	98	96.483	77.2709

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	15	25	33	0.3	4.6	0.82	97.1	96.483	75.1497
2015	12	1	15	35	33	0.3	4.6	0.88	96.4	96.483	80.9072
2015	12	1	15	45	33	0.3	4.6	0.84	96.2	96.483	77.5739
2015	12	1	15	55	33	0.3	4.6	0.84	98.1	96.483	76.3618
2015	12	1	16	5	33	0.3	4.6	0.86	97	96.483	79.089
2015	12	1	16	15	33	0.3	4.6	0.87	97.2	96.4173	79.6386
2015	12	1	16	25	33	0.3	4.6	0.84	97.8	96.483	77.2709
2015	12	1	16	35	33	0.3	4.6	0.83	98.4	96.4173	75.7021
2015	12	1	16	45	33	0.3	4.6	0.89	98.3	96.483	80.9072
2015	12	1	16	55	33	0.3	4.6	0.85	100.5	96.483	76.9679
2015	12	1	17	5	33	0.3	4.6	0.85	98.5	96.483	77.2709
2015	12	1	17	15	33	0.3	4.6	0.85	98.4	96.4173	77.8218
2015	12	1	17	25	33	0.3	4.6	0.85	98.5	96.483	77.2709
2015	12	1	17	35	33	0.3	4.6	0.86	98.6	96.483	78.483
2015	12	1	17	45	33	0.3	4.6	0.88	99.4	96.4173	80.547
2015	12	1	17	55	33	0.3	4.6	0.84	98.6	96.483	76.3618
2015	12	1	18	5	33	0.3	4.6	0.86	98.3	96.4173	78.4274
2015	12	1	18	15	33	0.3	4.6	0.87	98.9	96.4173	79.6386
2015	12	1	18	25	33	0.3	4.6	0.83	98.6	96.4173	76.005
2015	12	1	18	35	33	0.3	4.6	0.86	99.4	96.483	78.786
2015	12	1	18	45	33	0.3	4.6	0.83	98.7	96.483	75.4528
2015	12	1	18	55	33	0.3	4.6	0.86	97.7	96.4173	78.7302
2015	12	1	19	5	33	0.3	4.6	0.87	97.8	96.4173	79.6387
2015	12	1	19	15	33	0.3	4.6	0.84	97.8	96.4173	77.2162
2015	12	1	19	25	33	0.3	4.6	0.87	98.9	96.483	79.3921
2015	12	1	19	35	33	0.3	4.6	0.86	98.5	96.4173	78.7303
2015	12	1	19	45	33	0.3	4.6	0.87	97.6	96.4173	79.3359
2015	12	1	19	55	33	0.3	4.6	0.87	99.5	96.4173	79.3359
2015	12	1	20	5	33	0.3	4.6	0.84	98.5	96.4173	76.9135
2015	12	1	20	15	33	0.3	4.6	0.86	100.1	96.4173	77.8219
2015	12	1	20	25	33	0.3	4.6	0.88	98.8	96.4173	80.2444
2015	12	1	20	35	33	0.3	4.6	0.88	100.1	96.4173	80.2444
2015	12	1	20	45	33	0.3	4.6	0.86	98.8	96.4173	78.1247
2015	12	1	20	55	33	0.3	4.6	0.89	98.3	96.4173	80.85
2015	12	1	21	5	33	0.3	4.6	0.86	99	96.4173	78.4276
2015	12	1	21	15	33	0.3	4.6	0.83	98.8	96.4173	76.0051
2015	12	1	21	25	33	0.3	4.6	0.83	97.9	96.4173	76.0051
2015	12	1	21	35	33	0.3	4.6	0.82	98.1	96.4173	74.4911
2015	12	1	21	45	33	0.3	4.6	0.88	97.9	96.4173	80.5472
2015	12	1	21	55	33	0.3	4.6	0.87	98.4	96.4173	79.6388
2015	12	1	22	5	33	0.3	4.6	0.86	99.9	96.4173	78.1248
2015	12	1	22	15	33	0.3	4.6	0.86	98.5	96.4173	78.7304
2015	12	1	22	25	33	0.3	4.6	0.83	98.2	96.3517	75.9513
2015	12	1	22	35	33	0.3	4.6	0.83	99.4	96.4173	75.3995
2015	12	1	22	45	33	0.3	4.6	0.87	100.2	96.4173	79.0332
2015	12	1	22	55	33	0.3	4.6	0.91	99.4	96.3517	82.6083

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	1	23	5	33	0.3	4.6	0.9	98.8	96.3517	81.7006
2015	12	1	23	15	33	0.3	4.6	0.87	98.5	96.4173	79.0332
2015	12	1	23	25	33	0.3	4.6	0.88	98.6	96.4173	80.5473
2015	12	1	23	35	33	0.3	4.6	0.89	100	96.4173	80.8501
2015	12	1	23	45	33	0.3	4.6	0.86	97.9	96.4173	79.0333
2015	12	1	23	55	33	0.3	4.6	0.86	98.6	96.3517	78.3721
2015	12	2	0	5	33	0.3	4.6	0.91	97.5	96.3517	82.911
2015	12	2	0	15	33	0.3	4.6	0.87	98	96.3517	79.2798
2015	12	2	0	25	33	0.3	4.6	0.83	99.3	96.3517	75.9513
2015	12	2	0	35	33	0.3	4.6	0.87	97.8	96.3517	79.5825
2015	12	2	0	45	33	0.3	4.6	0.85	97.6	96.3517	77.4643
2015	12	2	0	55	33	0.3	4.6	0.88	98.6	96.3517	79.8851
2015	12	2	1	5	33	0.3	4.6	0.87	98	96.3517	79.2799
2015	12	2	1	15	33	0.3	4.6	0.89	98.1	96.3517	81.0955
2015	12	2	1	25	33	0.3	4.6	0.88	100.3	96.3517	79.8851
2015	12	2	1	35	33	0.3	4.6	0.9	97.4	96.3517	82.0033
2015	12	2	1	45	33	0.3	4.6	0.8	97.3	96.2861	73.1761
2015	12	2	1	55	33	0.3	4.6	0.89	99.8	96.3517	80.4903
2015	12	2	2	5	33	0.3	4.6	0.83	97.9	96.3517	75.9514
2015	12	2	2	15	33	0.3	4.6	0.89	100.4	96.3517	80.4903
2015	12	2	2	25	33	0.3	4.6	0.89	98.1	96.2861	81.0381
2015	12	2	2	35	33	0.3	4.6	0.87	98.7	96.2861	78.9214
2015	12	2	2	45	33	0.3	4.6	0.87	99.1	96.2861	78.9214
2015	12	2	2	55	33	0.3	4.6	0.87	98.7	96.2861	79.2238
2015	12	2	3	5	33	0.3	4.6	0.83	99.4	96.2861	75.2929
2015	12	2	3	15	33	0.3	4.6	0.84	100.2	96.2861	75.8977
2015	12	2	3	25	33	0.3	4.6	0.86	99	96.2861	78.6191
2015	12	2	3	35	33	0.3	4.6	0.87	98.7	96.2861	78.9215
2015	12	2	3	45	33	0.3	4.6	0.87	100.8	96.2205	78.8655
2015	12	2	3	55	33	0.3	4.6	0.89	99.1	96.2861	81.0382
2015	12	2	4	5	33	0.3	4.6	0.87	98.9	96.2861	79.5263
2015	12	2	4	15	33	0.3	4.6	0.86	100.5	96.2205	78.2612
2015	12	2	4	25	33	0.3	4.6	0.86	100.4	96.2205	77.6569
2015	12	2	4	35	33	0.3	4.6	0.87	99.3	96.2205	79.1677
2015	12	2	4	45	33	0.3	4.6	0.84	97.4	96.2205	77.0526
2015	12	2	4	55	33	0.3	4.6	0.88	96.9	96.2205	80.0743
2015	12	2	5	5	33	0.3	4.6	0.86	98.5	96.2205	78.5635
2015	12	2	5	15	33	0.3	4.3	0.84	98	96.1549	76.9979
2015	12	2	5	25	33	0.3	4.6	0.86	97.9	96.2205	78.2613
2015	12	2	5	35	33	0.3	4.6	0.87	96.7	96.2205	79.7722
2015	12	2	5	45	33	0.3	4.6	0.86	97	96.2205	78.2614
2015	12	2	5	55	33	0.3	4.3	0.85	97.5	96.1549	77.6019
2015	12	2	6	5	33	0.3	4.3	0.85	98.7	96.1549	77.2999
2015	12	2	6	15	33	0.3	4.3	0.85	99.8	96.1549	77.3
2015	12	2	6	25	33	0.3	4.3	0.87	96.7	96.1549	79.1117
2015	12	2	6	35	33	0.3	4.3	0.86	99.7	96.0892	77.8485

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	6	45	33	0.3	4.3	0.85	97.8	96.1549	77.602
2015	12	2	6	55	33	0.3	4.3	0.86	100.4	96.0892	77.5468
2015	12	2	7	5	33	0.3	4.3	0.85	97.1	96.1549	77.3
2015	12	2	7	15	33	0.3	4.3	0.87	98.2	96.1549	79.4137
2015	12	2	7	25	33	0.3	4.3	0.84	99.2	96.0892	76.3399
2015	12	2	7	35	33	0.3	4.3	0.85	99.5	96.0892	77.2451
2015	12	2	7	45	33	0.3	4.3	0.87	98	96.0892	79.0555
2015	12	2	7	55	33	0.3	4.3	0.81	98.4	96.0892	73.6242
2015	12	2	8	5	33	0.3	4.3	0.85	99.5	96.0892	77.5468
2015	12	2	8	15	33	0.3	4.3	0.85	98.5	96.0236	76.8885
2015	12	2	8	25	33	0.3	4.3	0.85	98.4	96.0236	77.4915
2015	12	2	8	35	33	0.3	4.3	0.85	99.6	96.0892	76.9432
2015	12	2	8	45	33	0.3	4.3	0.85	98.2	96.0892	77.5466
2015	12	2	8	55	33	0.3	4.3	0.87	100	96.0892	78.4518
2015	12	2	9	5	33	0.3	4.3	0.84	100.3	96.0892	76.3396
2015	12	2	9	15	33	0.3	4.3	0.81	96.8	96.0892	73.6239
2015	12	2	9	25	33	0.3	4.3	0.82	99.2	96.0892	74.2273
2015	12	2	9	35	33	0.3	4.3	0.84	99	96.0892	76.3394
2015	12	2	9	45	33	0.3	4.3	0.87	99.8	96.0892	78.7533
2015	12	2	9	55	33	0.3	4.3	0.87	99.4	96.0892	78.7532
2015	12	2	10	5	33	0.3	4.3	0.84	100.5	96.0892	76.3393
2015	12	2	10	15	33	0.3	4.3	0.81	98.6	96.0892	73.9253
2015	12	2	10	25	33	0.3	4.3	0.87	101.1	96.0892	78.7532
2015	12	2	10	35	33	0.3	4.3	0.83	101.2	96.0892	74.5288
2015	12	2	10	45	33	0.3	4.3	0.89	99.5	96.0892	81.167
2015	12	2	10	55	33	0.3	4.3	0.86	97.9	96.0892	78.4513
2015	12	2	11	5	33	0.3	4.3	0.86	99.9	96.0892	78.1495
2015	12	2	11	15	33	0.3	4.3	0.85	98.4	96.0892	77.5461
2015	12	2	11	25	33	0.3	4.3	0.84	98.1	96.0892	76.6408
2015	12	2	11	35	33	0.3	4.3	0.83	99.5	96.0892	75.4339
2015	12	2	11	45	33	0.3	4.3	0.82	97.6	96.0892	74.8304
2015	12	2	11	55	33	0.3	4.3	0.85	97.1	96.0892	77.8477
2015	12	2	12	5	33	0.3	4.3	0.81	97.7	96.0892	73.9251
2015	12	2	12	15	33	0.3	4.3	0.85	98.7	96.0892	77.2442
2015	12	2	12	25	33	0.3	4.3	0.87	99.5	96.0892	79.0546
2015	12	2	12	35	33	0.3	4.3	0.84	98	96.0892	76.9425
2015	12	2	12	45	33	0.3	4.3	0.86	97.5	96.0892	78.1495
2015	12	2	12	55	33	0.3	4.3	0.84	97.8	96.0892	76.6408
2015	12	2	13	5	33	0.3	4.3	0.84	98.5	96.0236	76.5863
2015	12	2	13	15	33	0.3	4.3	0.83	97.1	96.0236	75.3802
2015	12	2	13	25	33	0.3	4.3	0.84	99.5	96.0236	75.9832
2015	12	2	13	35	33	0.3	4.3	0.87	100	96.0236	78.9985
2015	12	2	13	45	33	0.3	4.3	0.87	99.5	96.0236	79.3
2015	12	2	13	55	33	0.3	4.3	0.82	98.3	96.0236	74.7772
2015	12	2	14	5	33	0.3	4.3	0.88	97.9	96.0236	80.2045
2015	12	2	14	15	33	0.3	4.3	0.81	97	96.0236	74.1741

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	14	25	33	0.3	4.3	0.9	99	96.0236	81.4106
2015	12	2	14	35	33	0.3	4.3	0.83	97.7	96.0236	75.3802
2015	12	2	14	45	33	0.3	4.3	0.87	97.8	96.0236	78.9984
2015	12	2	14	55	33	0.3	4.3	0.87	99.1	96.0236	79.3
2015	12	2	15	5	33	0.3	4.3	0.82	98.3	96.0236	74.4756
2015	12	2	15	15	33	0.3	4.3	0.85	98.7	96.0236	77.1893
2015	12	2	15	25	33	0.3	4.3	0.86	97	96.0236	78.0939
2015	12	2	15	35	33	0.3	4.3	0.84	97.4	95.958	76.5318
2015	12	2	15	45	33	0.3	4.3	0.84	96.5	95.958	76.5318
2015	12	2	15	55	33	0.3	4.3	0.86	98.6	95.958	77.737
2015	12	2	16	5	33	0.3	4.3	0.85	98.9	95.958	76.8331
2015	12	2	16	15	33	0.3	4.3	0.86	98.8	95.958	77.737
2015	12	2	16	25	33	0.3	4.3	0.87	98.7	95.958	78.6409
2015	12	2	16	35	33	0.3	4.3	0.82	97.6	95.958	74.7239
2015	12	2	16	45	33	0.3	4.3	0.86	99.2	95.958	77.737
2015	12	2	16	55	33	0.3	4.3	0.84	97.2	95.958	76.8331
2015	12	2	17	5	33	0.3	4.3	0.85	97.8	95.958	77.4357
2015	12	2	17	15	33	0.3	4.3	0.86	97.5	95.958	78.0383
2015	12	2	17	25	33	0.3	4.3	0.86	99	95.958	78.3396
2015	12	2	17	35	33	0.3	4.3	0.84	98	95.958	76.8331
2015	12	2	17	45	33	0.3	4.3	0.87	97.2	95.958	78.9422
2015	12	2	17	55	33	0.3	4.3	0.82	98.3	95.958	74.7239
2015	12	2	18	5	33	0.3	4.3	0.86	97.9	95.958	78.3396
2015	12	2	18	15	33	0.3	4.3	0.85	97.6	95.958	77.1344
2015	12	2	18	25	33	0.3	4.3	0.86	97.2	95.958	78.3396
2015	12	2	18	35	33	0.3	4.3	0.84	97.4	95.958	76.5318
2015	12	2	18	45	33	0.3	4.3	0.83	99.1	95.958	75.0252
2015	12	2	18	55	33	0.3	4.3	0.8	98.3	95.958	72.3135
2015	12	2	19	5	33	0.3	4.3	0.85	98.5	95.958	76.8331
2015	12	2	19	15	33	0.3	4.3	0.83	98.2	95.958	75.3265
2015	12	2	19	25	33	0.3	4.3	0.87	98.5	95.958	78.6409
2015	12	2	19	35	33	0.3	4.3	0.86	97.9	95.8924	78.2838
2015	12	2	19	45	33	0.3	4.3	0.8	99	95.958	72.3135
2015	12	2	19	55	33	0.3	4.3	0.84	99.7	95.958	75.6279
2015	12	2	20	5	33	0.3	4.3	0.86	99.2	95.8924	77.9827
2015	12	2	20	15	33	0.3	4.3	0.87	98.9	95.8924	78.886
2015	12	2	20	25	33	0.3	4.3	0.84	98.1	95.8924	75.8751
2015	12	2	20	35	33	0.3	4.3	0.86	97.9	95.8924	77.9827
2015	12	2	20	45	33	0.3	4.3	0.88	97.3	95.8924	80.0904
2015	12	2	20	55	33	0.3	4.3	0.86	97.7	95.958	78.3396
2015	12	2	21	5	33	0.3	4.3	0.86	97	95.8924	78.2838
2015	12	2	21	15	33	0.3	4.3	0.84	99.9	95.8924	75.8751
2015	12	2	21	25	33	0.3	4.3	0.86	96.8	95.8924	78.5849
2015	12	2	21	35	33	0.3	4.3	0.79	96.2	95.8924	71.9609
2015	12	2	21	45	33	0.3	4.3	0.82	96.6	95.8924	74.9718
2015	12	2	21	55	33	0.3	4.3	0.87	99.6	95.8924	78.585

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	2	22	5	33	0.3	4.3	0.84	98.1	95.8924	75.8751
2015	12	2	22	15	33	0.3	4.3	0.85	98.9	95.8924	77.0795
2015	12	2	22	25	33	0.3	4.3	0.84	98.1	95.8924	76.1762
2015	12	2	22	35	33	0.3	4.3	0.82	97.6	95.8924	74.6708
2015	12	2	22	45	33	0.3	4.3	0.83	98.4	95.8924	75.273
2015	12	2	22	55	33	0.3	4.3	0.82	98.9	95.8924	74.6708
2015	12	2	23	5	33	0.3	4.3	0.88	96.9	95.8924	80.0904
2015	12	2	23	15	33	0.3	4.3	0.88	97.5	95.8924	80.0905
2015	12	2	23	25	33	0.3	4.3	0.9	96.7	95.8924	81.5959
2015	12	2	23	35	33	0.3	4.3	0.9	98	95.8924	81.5959
2015	12	2	23	45	33	0.3	4.3	0.89	97.8	95.8924	80.9938
2015	12	2	23	55	33	0.3	4.3	0.83	98.2	95.8924	74.9719
2015	12	3	0	5	33	0.3	4.3	0.87	99.3	95.8924	78.8861
2015	12	3	0	15	33	0.3	4.3	0.87	100	95.8924	78.8861
2015	12	3	0	25	33	0.3	4.3	0.85	97.1	95.8924	77.0796
2015	12	3	0	35	33	0.3	4.3	0.83	97.5	95.8268	75.5203
2015	12	3	0	45	33	0.3	4.3	0.86	97.9	95.8268	77.9273
2015	12	3	0	55	33	0.3	4.3	0.91	97.9	95.8268	82.4405
2015	12	3	1	5	33	0.3	4.3	0.86	96.8	95.8268	77.9273
2015	12	3	1	15	33	0.3	4.3	0.83	97	95.8268	75.5203
2015	12	3	1	25	33	0.3	4.3	0.85	98.4	95.8268	77.3256
2015	12	3	1	35	33	0.3	4.3	0.83	100.2	95.8268	75.2194
2015	12	3	1	45	33	0.3	4.3	0.85	99.6	95.8268	76.4229
2015	12	3	1	55	33	0.3	4.3	0.85	98.9	95.8268	76.7238
2015	12	3	2	5	33	0.3	4.3	0.86	99.2	95.7612	77.8718
2015	12	3	2	15	33	0.3	4.3	0.87	98.2	95.8268	79.1309
2015	12	3	2	25	33	0.3	4.3	0.85	98.9	95.7612	76.6691
2015	12	3	2	35	33	0.3	4.3	0.86	96.4	95.8268	77.9274
2015	12	3	2	45	33	0.3	4.3	0.88	98.3	95.8268	80.0336
2015	12	3	2	55	33	0.3	4.3	0.85	98.7	95.8268	77.0248
2015	12	3	3	5	33	0.3	4.3	0.86	96.4	95.7612	78.1725
2015	12	3	3	15	33	0.3	4.3	0.87	97.8	95.7612	78.7738
2015	12	3	3	25	33	0.3	4.3	0.85	99.6	95.7612	76.6692
2015	12	3	3	35	33	0.3	4.3	0.81	98.6	95.7612	73.3619
2015	12	3	3	45	33	0.3	4.3	0.83	97.5	95.7612	75.4666
2015	12	3	3	55	33	0.3	4.3	0.85	99.5	95.7612	76.9699
2015	12	3	4	5	33	0.3	4.3	0.84	98.9	95.7612	76.3686
2015	12	3	4	15	33	0.3	4.3	0.83	98.4	95.7612	75.166
2015	12	3	4	25	33	0.3	4.3	0.86	98.6	95.7612	77.5713
2015	12	3	4	35	33	0.3	4.3	0.86	98.1	95.7612	78.4733
2015	12	3	4	45	33	0.3	4.3	0.85	98	95.7612	77.2707
2015	12	3	4	55	33	0.3	4.3	0.83	97.5	95.7612	75.166
2015	12	3	5	5	33	0.3	4.3	0.86	97.9	95.7612	78.4734
2015	12	3	5	15	33	0.3	4.3	0.84	98.1	95.7612	75.7674
2015	12	3	5	25	33	0.3	4.3	0.82	97.6	95.7612	74.5648
2015	12	3	5	35	33	0.3	4.3	0.89	98.9	95.7612	80.2774

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	5	45	33	0.3	4.3	0.88	97.5	95.7612	79.6761
2015	12	3	5	55	33	0.3	4.3	0.86	98.8	95.7612	77.8721
2015	12	3	6	5	33	0.3	4.3	0.83	98.4	95.6955	75.1125
2015	12	3	6	15	33	0.3	4.3	0.81	97.5	95.6955	73.3098
2015	12	3	6	25	33	0.3	4.3	0.87	99.4	95.7612	78.4735
2015	12	3	6	35	33	0.3	4.3	0.86	97.2	95.7612	78.1729
2015	12	3	6	45	33	0.3	4.3	0.81	98.4	95.6955	73.3099
2015	12	3	6	55	33	0.3	4.3	0.82	96.9	95.6955	74.2112
2015	12	3	7	5	33	0.3	4.3	0.84	97.4	95.6955	76.6148
2015	12	3	7	15	33	0.3	4.3	0.9	98.2	95.6955	81.1216
2015	12	3	7	25	33	0.3	4.3	0.85	99.5	95.6955	77.2158
2015	12	3	7	35	33	0.3	4.3	0.87	98.5	95.6955	78.4176
2015	12	3	7	45	33	0.3	4.3	0.89	99.8	95.6955	80.2203
2015	12	3	7	55	33	0.3	4.3	0.84	99.4	95.6955	76.014
2015	12	3	8	5	33	0.3	4.3	0.82	96.2	95.6955	74.8122
2015	12	3	8	15	33	0.3	4.3	0.84	98.6	95.6955	75.7135
2015	12	3	8	25	33	0.3	4.3	0.84	97.8	95.6955	76.3143
2015	12	3	8	35	33	0.3	4.3	0.84	97.8	95.7612	76.3688
2015	12	3	8	45	33	0.3	4.3	0.85	97.9	95.7612	77.5714
2015	12	3	8	55	33	0.3	4.3	0.86	99.4	95.6955	78.117
2015	12	3	9	5	33	0.3	4.3	0.85	98.8	95.6955	77.2156
2015	12	3	9	15	33	0.3	4.3	0.85	99.5	95.6955	77.2155
2015	12	3	9	25	33	0.3	4.3	0.83	99.4	95.7612	74.8653
2015	12	3	9	35	33	0.3	4.3	0.79	97.4	95.7612	71.8586
2015	12	3	9	45	33	0.3	4.3	0.87	96.9	95.7612	79.0745
2015	12	3	9	55	33	0.3	4.3	0.82	98.1	95.7612	73.9632
2015	12	3	10	5	33	0.3	4.3	0.88	98.8	95.7612	79.9765
2015	12	3	10	15	33	0.3	4.3	0.86	100.1	95.7612	77.5711
2015	12	3	10	25	33	0.3	4.3	0.84	98.1	95.7612	76.0677
2015	12	3	10	35	33	0.3	4.3	0.84	96.3	95.7612	76.0678
2015	12	3	10	45	33	0.3	4.3	0.85	99.1	95.7612	76.6691
2015	12	3	10	55	33	0.3	4.3	0.82	98.5	95.7612	74.5646
2015	12	3	11	5	33	0.3	4.3	0.87	99.1	95.7612	78.473
2015	12	3	11	15	33	0.3	4.3	0.84	98.5	95.7612	76.3684
2015	12	3	11	25	33	0.3	4.3	0.84	98.3	95.6955	76.0135
2015	12	3	11	35	33	0.3	4.3	0.87	97.8	95.7612	79.0743
2015	12	3	11	45	33	0.3	4.3	0.86	98.6	95.7612	77.571
2015	12	3	11	55	33	0.3	4.3	0.84	97.4	95.6955	76.3138
2015	12	3	12	5	33	0.3	4.3	0.87	99.8	95.7612	78.4728
2015	12	3	12	15	33	0.3	4.3	0.85	100.3	95.7612	76.3682
2015	12	3	12	25	33	0.3	4.3	0.86	99.6	95.7612	77.8715
2015	12	3	12	35	33	0.3	4.3	0.81	98.6	95.6955	73.3092
2015	12	3	12	45	33	0.3	4.3	0.82	100.3	95.6955	74.2105
2015	12	3	12	55	33	0.3	4.3	0.82	99.7	95.6955	74.2105
2015	12	3	13	5	33	0.3	4.3	0.81	97.9	95.6299	73.557
2015	12	3	13	15	33	0.3	4.3	0.84	99.9	95.6955	75.7128

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	13	25	33	0.3	4.3	0.83	97.5	95.6299	75.6586
2015	12	3	13	35	33	0.3	4.3	0.82	99	95.6299	74.1575
2015	12	3	13	45	33	0.3	4.3	0.81	97.9	95.5643	73.2045
2015	12	3	13	55	33	0.3	4.3	0.83	97.9	95.6299	75.3584
2015	12	3	14	5	33	0.3	4.3	0.87	100	95.5643	78.0047
2015	12	3	14	15	33	0.3	4.3	0.83	99.6	95.6299	74.4577
2015	12	3	14	25	33	0.3	4.3	0.79	99.1	95.4987	71.0535
2015	12	3	14	35	33	0.3	4.3	0.85	99.8	95.4987	76.1501
2015	12	3	14	45	33	0.3	4.3	0.81	101.3	95.5643	72.3044
2015	12	3	14	55	33	0.3	4.3	0.83	99.6	95.4987	74.3513
2015	12	3	15	5	33	0.3	4.3	0.77	96.1	95.4987	69.8543
2015	12	3	15	15	33	0.3	4.3	0.78	100.2	95.4987	69.8543
2015	12	3	15	25	33	0.3	4.3	0.81	97.7	95.4987	73.452
2015	12	3	15	35	33	0.3	4.3	0.81	98.4	95.4331	73.3994
2015	12	3	15	45	33	0.3	4.3	0.8	99.9	95.4331	72.201
2015	12	3	15	55	33	0.3	4.3	0.83	98.6	95.4987	75.2508
2015	12	3	16	5	33	0.3	4.3	0.84	98.9	95.4987	76.1502
2015	12	3	16	15	33	0.3	4.3	0.83	98.9	95.4331	74.8973
2015	12	3	16	25	33	0.3	4.3	0.82	100.2	95.4331	73.3994
2015	12	3	16	35	33	0.3	4.3	0.82	98.9	95.4331	74.2981
2015	12	3	16	45	33	0.3	4.3	0.81	97.2	95.4331	73.0998
2015	12	3	16	55	33	0.3	4.3	0.84	98.3	95.4331	75.7961
2015	12	3	17	5	33	0.3	4.3	0.82	97.3	95.4331	74.5977
2015	12	3	17	15	33	0.3	4.3	0.81	100.7	95.4331	72.8001
2015	12	3	17	25	33	0.3	4.3	0.86	98.8	95.4331	77.294
2015	12	3	17	35	33	0.3	4.3	0.84	99	95.4331	75.4964
2015	12	3	17	45	33	0.3	4.3	0.87	98.7	95.4331	78.4923
2015	12	3	17	55	33	0.3	4.3	0.87	97.8	95.4331	79.0915
2015	12	3	18	5	33	0.3	4.3	0.85	97.1	95.4331	77.294
2015	12	3	18	15	33	0.3	4.3	0.83	101	95.4331	74.2981
2015	12	3	18	25	33	0.3	4.3	0.81	101	95.4331	72.5005
2015	12	3	18	35	33	0.3	4.3	0.82	98.8	95.4331	73.6989
2015	12	3	18	45	33	0.3	4.3	0.82	97.6	95.4331	74.298
2015	12	3	18	55	33	0.3	4.3	0.8	97.1	95.4987	72.2526
2015	12	3	19	5	33	0.3	4.3	0.86	99.9	95.4331	77.2939
2015	12	3	19	15	33	0.3	4.3	0.84	99.2	95.4331	76.0956
2015	12	3	19	25	33	0.3	4.3	0.86	97.2	95.4331	77.8931
2015	12	3	19	35	33	0.3	4.3	0.87	96.9	95.4331	79.0914
2015	12	3	19	45	33	0.3	4.3	0.86	99.2	95.4331	77.8931
2015	12	3	19	55	33	0.3	4.3	0.83	99.5	95.4331	74.8972
2015	12	3	20	5	33	0.3	4.3	0.8	95.9	95.4987	72.5524
2015	12	3	20	15	33	0.3	4.3	0.78	95.3	95.4331	70.7029
2015	12	3	20	25	33	0.3	4.3	0.83	98.4	95.4987	74.9508
2015	12	3	20	35	33	0.3	4.3	0.83	96.6	95.4331	75.1967
2015	12	3	20	45	33	0.3	4.3	0.83	95.5	95.4331	75.1967
2015	12	3	20	55	33	0.3	4.3	0.83	98.4	95.4987	75.2505

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	3	21	5	33	0.3	4.3	0.84	96.5	95.4331	76.0955
2015	12	3	21	15	33	0.3	4.3	0.82	97.5	95.4331	74.5975
2015	12	3	21	25	33	0.3	4.3	0.86	98.5	95.4987	77.9487
2015	12	3	21	35	33	0.3	4.3	0.82	97.3	95.3675	74.544
2015	12	3	21	45	33	0.3	4.3	0.82	98.5	95.4331	74.2979
2015	12	3	21	55	33	0.3	4.3	0.86	95.5	95.4987	77.9487
2015	12	3	22	5	33	0.3	4.3	0.81	97.6	95.4331	73.6987
2015	12	3	22	15	33	0.3	4.3	0.78	97.3	95.4987	70.4536
2015	12	3	22	25	33	0.3	4.3	0.8	97	95.4987	72.852
2015	12	3	22	35	33	0.3	4.3	0.83	98.9	95.4331	74.897
2015	12	3	22	45	33	0.3	4.3	0.83	97.3	95.4987	75.2504
2015	12	3	22	55	33	0.3	4.3	0.83	95.9	95.4987	75.85
2015	12	3	23	5	33	0.3	4.3	0.84	95.8	95.4331	76.3948
2015	12	3	23	15	33	0.3	4.3	0.85	99.4	95.4331	76.3948
2015	12	3	23	25	33	0.3	4.3	0.84	97.7	95.4987	75.8499
2015	12	3	23	35	33	0.3	4.3	0.78	97.8	95.4331	70.403
2015	12	3	23	45	33	0.3	4.3	0.83	98.2	95.4987	74.9505
2015	12	3	23	55	33	0.3	4.3	0.79	96.9	95.4331	71.6014
2015	12	4	0	5	33	0.3	4.3	0.85	98.8	95.4987	77.0491
2015	12	4	0	15	33	0.3	4.3	0.81	97	95.4331	73.6985
2015	12	4	0	25	33	0.3	4.3	0.84	97.4	95.4331	76.3947
2015	12	4	0	35	33	0.3	4.3	0.85	95.8	95.4331	76.9939
2015	12	4	0	45	33	0.3	4.3	0.86	99.9	95.4331	77.2935
2015	12	4	0	55	33	0.3	4.3	0.84	98.7	95.4987	76.1496
2015	12	4	1	5	33	0.3	4.3	0.79	98.8	95.4987	71.3528
2015	12	4	1	15	33	0.3	4.3	0.83	97.7	95.4987	74.9504
2015	12	4	1	25	33	0.3	4.3	0.87	98.7	95.4987	78.2482
2015	12	4	1	35	33	0.3	4.3	0.82	98.1	95.4987	74.0509
2015	12	4	1	45	33	0.3	4.3	0.89	98.5	95.4987	80.047
2015	12	4	1	55	33	0.3	4.3	0.81	97.6	95.4987	73.7512
2015	12	4	2	5	33	0.3	4.3	0.83	96.4	95.4987	74.9503
2015	12	4	2	15	33	0.3	4.3	0.87	98.4	95.4987	78.8478
2015	12	4	2	25	33	0.3	4.3	0.85	96.9	95.4987	77.3488
2015	12	4	2	35	33	0.3	4.3	0.88	99	95.4987	79.7471
2015	12	4	2	45	33	0.3	4.3	0.85	98.4	95.4987	77.0489
2015	12	4	2	55	33	0.3	4.3	0.86	98.1	95.4987	78.2482
2015	12	4	3	5	33	0.3	4.3	0.85	96.7	95.4987	77.0489
2015	12	4	3	15	33	0.3	4.3	0.83	98.5	95.4987	74.6505
2015	12	4	3	25	33	0.3	4.3	0.89	98.7	95.4987	80.047
2015	12	4	3	35	33	0.3	4.3	0.82	99.5	95.4987	73.7512
2015	12	4	3	45	33	0.3	4.3	0.84	96.9	95.4987	76.4494
2015	12	4	3	55	33	0.3	4.3	0.86	97.9	95.4987	78.2482
2015	12	4	4	5	33	0.3	4.3	0.85	99.1	95.4987	76.7492
2015	12	4	4	15	33	0.3	4.3	0.86	100.1	95.4987	77.049
2015	12	4	4	25	33	0.3	4.3	0.87	99.4	95.4987	78.2482
2015	12	4	4	35	33	0.3	4.3	0.86	98.5	95.4987	77.9484

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	4	45	33	0.3	4.3	0.85	98.4	95.4987	77.049
2015	12	4	4	55	33	0.3	4.3	0.88	98.2	95.4987	79.1476
2015	12	4	5	5	33	0.3	4.3	0.88	99.2	95.4987	79.4475
2015	12	4	5	15	33	0.3	4.3	0.85	98.2	95.4987	77.0491
2015	12	4	5	25	33	0.3	4.3	0.86	99.7	95.4987	77.3489
2015	12	4	5	35	33	0.3	4.3	0.83	99.1	95.4987	75.2503
2015	12	4	5	45	33	0.3	4.3	0.84	98	95.4987	76.4495
2015	12	4	5	55	33	0.3	4.3	0.87	99.6	95.4987	78.2483
2015	12	4	6	5	33	0.3	4.3	0.85	100.2	95.4987	76.7493
2015	12	4	6	15	33	0.3	4.3	0.83	100	95.4987	74.6507
2015	12	4	6	25	33	0.3	4.3	0.88	100.1	95.4987	79.1478
2015	12	4	6	35	33	0.3	4.3	0.82	98.8	95.4987	73.7513
2015	12	4	6	45	33	0.3	4.3	0.88	97.5	95.4987	79.4476
2015	12	4	6	55	33	0.3	4.3	0.86	97.5	95.4987	77.9486
2015	12	4	7	5	33	0.3	4.3	0.88	99	95.4987	79.7474
2015	12	4	7	15	33	0.3	4.3	0.85	96.9	95.4987	77.0492
2015	12	4	7	25	33	0.3	4.3	0.83	99.8	95.4987	74.6508
2015	12	4	7	35	33	0.3	4.3	0.84	98.3	95.4987	76.1498
2015	12	4	7	45	33	0.3	4.3	0.84	99.7	95.4987	75.2504
2015	12	4	7	55	33	0.3	4.3	0.83	99.3	95.4987	75.2504
2015	12	4	8	5	33	0.3	4.3	0.86	97.7	95.4987	77.6488
2015	12	4	8	15	33	0.3	4.3	0.86	98.6	95.4987	77.3489
2015	12	4	8	25	33	0.3	4.3	0.87	98.7	95.4987	78.2483
2015	12	4	8	35	33	0.3	4.3	0.83	100.2	95.4987	74.6507
2015	12	4	8	45	33	0.3	4.3	0.81	99.1	95.5643	73.204
2015	12	4	8	55	33	0.3	4.3	0.89	99.3	95.4987	80.3468
2015	12	4	9	5	33	0.3	4.3	0.88	98.6	95.5643	79.2042
2015	12	4	9	15	33	0.3	4.3	0.84	98.3	95.5643	76.204
2015	12	4	9	25	33	0.3	4.3	0.85	98.8	95.5643	77.104
2015	12	4	9	35	33	0.3	4.3	0.82	100.1	95.5643	73.8038
2015	12	4	9	45	33	0.3	4.3	0.86	99.6	95.5643	77.704
2015	12	4	9	55	33	0.3	4.3	0.84	99.2	95.5643	75.9038
2015	12	4	10	5	33	0.3	4.3	0.83	100	95.5643	75.0037
2015	12	4	10	15	33	0.3	4.3	0.85	99.3	95.5643	77.1038
2015	12	4	10	25	33	0.3	4.6	0.82	98.5	95.5643	74.1036
2015	12	4	10	35	33	0.3	4.6	0.86	100.3	95.6299	77.4591
2015	12	4	10	45	33	0.3	4.6	0.8	98.7	95.5643	72.6035
2015	12	4	10	55	33	0.3	4.6	0.83	98.8	95.5643	75.3036
2015	12	4	11	5	33	0.3	4.6	0.81	99.1	95.6299	73.2558
2015	12	4	11	15	33	0.3	4.6	0.84	98.8	95.6299	75.6576
2015	12	4	11	25	33	0.3	4.6	0.84	99.7	95.6299	75.6576
2015	12	4	11	35	33	0.3	4.6	0.83	99.6	95.6299	74.4567
2015	12	4	11	45	33	0.3	4.6	0.83	97.5	95.6299	75.6575
2015	12	4	11	55	33	0.3	4.6	0.8	99.4	95.6299	72.6553
2015	12	4	12	5	33	0.3	4.6	0.87	98.9	95.5643	78.3036
2015	12	4	12	15	33	0.3	4.6	0.83	100	95.6299	74.7569

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	12	25	33	0.3	4.6	0.85	98.6	95.5643	77.1035
2015	12	4	12	35	33	0.3	4.6	0.86	99.6	95.5643	77.7036
2015	12	4	12	45	33	0.3	4.6	0.86	98.4	95.5643	77.4036
2015	12	4	12	55	33	0.3	4.6	0.83	99.1	95.6299	75.0571
2015	12	4	13	5	33	0.3	4.6	0.85	99.6	95.6299	76.5582
2015	12	4	13	15	33	0.3	4.6	0.81	99.5	95.6299	73.5559
2015	12	4	13	25	33	0.3	4.6	0.81	97.2	95.5643	73.5034
2015	12	4	13	35	33	0.3	4.6	0.84	100.1	95.6299	75.6575
2015	12	4	13	45	33	0.3	4.6	0.83	100	95.5643	74.7035
2015	12	4	13	55	33	0.3	4.6	0.82	98.3	95.5643	74.4034
2015	12	4	14	5	33	0.3	4.6	0.86	97.7	95.5643	77.7036
2015	12	4	14	15	33	0.3	4.6	0.84	99.9	95.5643	75.6035
2015	12	4	14	25	33	0.3	4.6	0.85	98.7	95.5643	76.5035
2015	12	4	14	35	33	0.3	4.6	0.86	101	95.5643	77.1036
2015	12	4	14	45	33	0.3	4.6	0.8	98.7	95.5643	72.6034
2015	12	4	14	55	33	0.3	4.6	0.84	98.1	95.5643	76.2036
2015	12	4	15	5	33	0.3	4.6	0.8	98.7	95.5643	72.6034
2015	12	4	15	15	33	0.3	4.6	0.84	100.3	95.5643	75.9036
2015	12	4	15	25	33	0.3	4.6	0.82	98.3	95.5643	74.4035
2015	12	4	15	35	33	0.3	4.6	0.82	100.4	95.5643	73.8035
2015	12	4	15	45	33	0.3	4.6	0.81	96.8	95.5643	73.2035
2015	12	4	15	55	33	0.3	4.6	0.84	98.4	95.5643	75.6036
2015	12	4	16	5	33	0.3	4.6	0.85	98.3	95.5643	76.5037
2015	12	4	16	15	33	0.3	4.6	0.84	99.2	95.5643	76.2036
2015	12	4	16	25	33	0.3	4.6	0.86	101.9	95.5643	76.8037
2015	12	4	16	35	33	0.3	4.6	0.86	99	95.5643	77.7037
2015	12	4	16	45	33	0.3	4.6	0.85	99.8	95.5643	76.8037
2015	12	4	16	55	33	0.3	4.6	0.86	98.1	95.5643	77.7037
2015	12	4	17	5	33	0.3	4.6	0.82	98.6	95.5643	73.8036
2015	12	4	17	15	33	0.3	4.6	0.83	99.1	95.5643	75.0036
2015	12	4	17	25	33	0.3	4.6	0.85	97.5	95.5643	77.1037
2015	12	4	17	35	33	0.3	4.6	0.83	97.9	95.5643	75.3036
2015	12	4	17	45	33	0.3	4.6	0.81	97.6	95.5643	73.8036
2015	12	4	17	55	33	0.3	4.6	0.84	99	95.6299	75.9579
2015	12	4	18	5	33	0.3	4.6	0.84	98	95.5643	76.5037
2015	12	4	18	15	33	0.3	4.6	0.86	99	95.6299	77.7593
2015	12	4	18	25	33	0.3	4.6	0.81	97	95.6299	73.2559
2015	12	4	18	35	33	0.3	4.6	0.83	100	95.6299	75.0573
2015	12	4	18	45	33	0.3	4.3	0.83	100.1	95.6299	74.4569
2015	12	4	18	55	33	0.3	4.3	0.83	98.5	95.5643	74.7037
2015	12	4	19	5	33	0.3	4.3	0.82	98.6	95.6299	73.8564
2015	12	4	19	15	33	0.3	4.3	0.85	100.2	95.6299	76.8587
2015	12	4	19	25	33	0.3	4.3	0.83	96.6	95.6299	75.3576
2015	12	4	19	35	33	0.3	4.3	0.89	98	95.6299	81.062
2015	12	4	19	45	33	0.3	4.3	0.89	98	95.6299	81.062
2015	12	4	19	55	33	0.3	4.3	0.88	97.9	95.6299	79.8611

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	4	20	5	33	0.3	4.3	0.86	97.2	95.6299	78.0597
2015	12	4	20	15	33	0.3	4.3	0.85	99.4	95.6299	76.5586
2015	12	4	20	25	33	0.3	4.3	0.84	98.3	95.6299	75.9581
2015	12	4	20	35	33	0.3	4.3	0.84	98.9	95.6299	76.2583
2015	12	4	20	45	33	0.3	4.3	0.9	99.7	95.6299	80.7618
2015	12	4	20	55	33	0.3	4.3	0.85	97.3	95.6299	77.4593
2015	12	4	21	5	33	0.3	4.3	0.84	97.4	95.6299	76.2584
2015	12	4	21	15	33	0.3	4.3	0.87	99.3	95.6299	78.6602
2015	12	4	21	25	33	0.3	4.3	0.86	98.1	95.6299	78.0598
2015	12	4	21	35	33	0.3	4.3	0.86	98.3	95.6299	77.7596
2015	12	4	21	45	33	0.3	4.3	0.84	97.8	95.6955	76.3129
2015	12	4	21	55	33	0.3	4.3	0.87	98.7	95.6955	78.7165
2015	12	4	22	5	33	0.3	4.3	0.8	97.8	95.6955	72.4072
2015	12	4	22	15	33	0.3	4.3	0.83	98.4	95.7612	75.4655
2015	12	4	22	25	33	0.3	4.3	0.87	98.5	95.7612	78.4721
2015	12	4	22	35	33	0.3	4.3	0.84	98.1	95.7612	76.3675
2015	12	4	22	45	33	0.3	4.3	0.87	99.5	95.7612	78.7728
2015	12	4	22	55	33	0.3	4.3	0.84	98.3	95.8268	76.422
2015	12	4	23	5	33	0.3	4.3	0.86	98.4	95.8924	77.6808
2015	12	4	23	15	33	0.3	4.3	0.84	95.6	95.8924	76.7776
2015	12	4	23	25	33	0.3	4.3	0.83	97.5	95.8924	75.2722
2015	12	4	23	35	33	0.3	4.3	0.85	98	95.8924	77.3798
2015	12	4	23	45	33	0.3	4.3	0.9	98.6	95.8924	81.294
2015	12	4	23	55	33	0.3	4.3	0.84	98.7	95.8924	76.4765
2015	12	5	0	5	33	0.3	4.3	0.88	98.8	95.8924	79.4874
2015	12	5	0	15	33	0.3	4.3	0.81	97.9	95.8924	74.0678
2015	12	5	0	25	33	0.3	4.3	0.86	98.8	95.8924	77.6809
2015	12	5	0	35	33	0.3	4.3	0.79	97.6	95.8924	72.2613
2015	12	5	0	45	33	0.3	4.3	0.88	99.2	95.8924	79.7886
2015	12	5	0	55	33	0.3	4.3	0.85	97.5	95.8924	77.3799
2015	12	5	1	5	33	0.3	4.3	0.83	99.3	95.8924	75.5734
2015	12	5	1	15	33	0.3	4.3	0.85	99.6	95.8924	76.4766
2015	12	5	1	25	33	0.3	4.3	0.8	98.9	95.8924	72.8636
2015	12	5	1	35	33	0.3	4.3	0.87	98.7	95.8924	78.5843
2015	12	5	1	45	33	0.3	4.3	0.87	97.8	95.8924	78.8854
2015	12	5	1	55	33	0.3	4.3	0.85	97.3	95.958	77.4351
2015	12	5	2	5	33	0.3	4.3	0.86	98.1	95.8924	77.9821
2015	12	5	2	15	33	0.3	4.3	0.83	98.9	95.958	75.0247
2015	12	5	2	25	33	0.3	4.3	0.85	99.4	95.958	76.8325
2015	12	5	2	35	33	0.3	4.3	0.86	99.2	95.958	78.3391
2015	12	5	2	45	33	0.3	4.3	0.85	98.9	95.958	77.1339
2015	12	5	2	55	33	0.3	4.3	0.84	96.5	95.958	76.8326
2015	12	5	3	5	33	0.3	4.3	0.88	98.1	95.958	80.4482
2015	12	5	3	15	33	0.3	4.3	0.79	96.9	95.958	72.0117
2015	12	5	3	25	33	0.3	4.3	0.82	99.2	95.958	74.7235
2015	12	5	3	35	33	0.3	4.3	0.85	99.8	95.958	77.1339

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	3	45	33	0.3	4.3	0.86	98.8	95.958	77.7366
2015	12	5	3	55	33	0.3	4.3	0.85	97.1	95.958	77.4353
2015	12	5	4	5	33	0.3	4.3	0.84	98.5	95.958	76.5314
2015	12	5	4	15	33	0.3	4.3	0.83	96.6	95.958	75.9288
2015	12	5	4	25	33	0.3	4.3	0.86	97.7	95.958	78.0379
2015	12	5	4	35	33	0.3	4.3	0.84	98.3	95.958	76.5314
2015	12	5	4	45	33	0.3	4.3	0.86	99.2	95.958	77.7367
2015	12	5	4	55	33	0.3	4.3	0.8	99.7	95.958	72.6145
2015	12	5	5	5	33	0.3	4.3	0.87	98.6	95.958	79.2433
2015	12	5	5	15	33	0.3	4.3	0.82	98.5	95.958	74.7237
2015	12	5	5	25	33	0.3	4.3	0.82	98.9	95.958	74.7237
2015	12	5	5	35	33	0.3	4.3	0.86	98.8	95.958	78.0381
2015	12	5	5	45	33	0.3	4.3	0.87	99.5	95.958	79.2433
2015	12	5	5	55	33	0.3	4.3	0.85	98.9	95.958	76.8329
2015	12	5	6	5	33	0.3	4.3	0.79	98.6	95.958	71.4094
2015	12	5	6	15	33	0.3	4.3	0.86	98.1	95.958	78.0382
2015	12	5	6	25	33	0.3	4.3	0.84	97.2	95.958	76.2304
2015	12	5	6	35	33	0.3	4.3	0.85	98.8	95.958	77.4356
2015	12	5	6	45	33	0.3	4.3	0.8	98.7	95.958	72.6147
2015	12	5	6	55	33	0.3	4.3	0.82	99.7	95.958	74.4226
2015	12	5	7	5	33	0.3	4.3	0.8	99.9	95.958	72.6148
2015	12	5	7	15	33	0.3	4.3	0.81	100.2	95.958	73.5187
2015	12	5	7	25	33	0.3	4.3	0.85	98.5	95.958	76.8331
2015	12	5	7	35	33	0.3	4.3	0.89	97.8	95.958	81.3527
2015	12	5	7	45	33	0.3	4.3	0.85	99.1	95.958	76.8331
2015	12	5	7	55	33	0.3	4.3	0.81	97.4	95.958	73.82
2015	12	5	8	5	33	0.3	4.3	0.81	98.2	95.958	73.2174
2015	12	5	8	15	33	0.3	4.3	0.83	99.3	95.958	75.6278
2015	12	5	8	25	33	0.3	4.3	0.81	97.4	95.958	73.8199
2015	12	5	8	35	33	0.3	4.3	0.84	98.8	95.958	76.2304
2015	12	5	8	45	33	0.3	4.3	0.82	97.4	96.0236	74.777
2015	12	5	8	55	33	0.3	4.3	0.84	98.1	96.0236	75.9831
2015	12	5	9	5	33	0.3	4.3	0.85	96.7	96.0236	77.1891
2015	12	5	9	15	33	0.3	4.3	0.86	99	96.0236	78.3951
2015	12	5	9	25	33	0.3	4.3	0.84	99.2	96.0236	76.586
2015	12	5	9	35	33	0.3	4.3	0.83	98.2	96.0236	75.3799
2015	12	5	9	45	33	0.3	4.3	0.82	97.3	96.0236	75.0784
2015	12	5	9	55	33	0.3	4.3	0.78	98.9	96.0236	71.1586
2015	12	5	10	5	33	0.3	4.3	0.87	100.5	96.0892	78.4508
2015	12	5	10	15	33	0.3	4.3	0.84	100.5	96.0892	76.3386
2015	12	5	10	25	33	0.3	4.3	0.81	97.6	96.0892	74.2264
2015	12	5	10	35	33	0.3	4.3	0.83	97.9	96.0892	75.7351
2015	12	5	10	45	33	0.3	4.3	0.85	99.8	96.0892	77.2437
2015	12	5	10	55	33	0.3	4.3	0.8	98.5	96.0892	73.0195
2015	12	5	11	5	33	0.3	4.3	0.82	99	96.0236	74.1737
2015	12	5	11	15	33	0.3	4.3	0.82	98.5	96.0892	74.5282

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	11	25	33	0.3	4.3	0.83	97.7	96.0892	76.0368
2015	12	5	11	35	33	0.3	4.3	0.83	96.8	96.0892	75.4333
2015	12	5	11	45	33	0.3	4.3	0.85	98.3	96.0892	76.942
2015	12	5	11	55	33	0.3	4.3	0.85	97.9	96.0892	77.8471
2015	12	5	12	5	33	0.3	4.3	0.85	97.1	96.0892	77.5453
2015	12	5	12	15	33	0.3	4.3	0.79	97.4	96.0892	71.8124
2015	12	5	12	25	33	0.3	4.3	0.82	99.7	96.0892	74.2262
2015	12	5	12	35	33	0.3	4.3	0.85	99.1	96.1549	77.2984
2015	12	5	12	45	33	0.3	4.3	0.82	98	96.0892	74.8297
2015	12	5	12	55	33	0.3	4.3	0.86	97.7	96.0892	78.1488
2015	12	5	13	5	33	0.3	4.3	0.85	98.4	96.0892	77.2436
2015	12	5	13	15	33	0.3	4.3	0.85	98.4	96.0892	77.2436
2015	12	5	13	25	33	0.3	4.3	0.87	99.3	96.0892	79.0539
2015	12	5	13	35	33	0.3	4.3	0.8	99.7	96.1549	72.4673
2015	12	5	13	45	33	0.3	4.3	0.81	99.5	96.0892	73.9244
2015	12	5	13	55	33	0.3	4.3	0.84	98.3	96.0892	76.64
2015	12	5	14	5	33	0.3	4.3	0.84	101	96.0892	75.7348
2015	12	5	14	15	33	0.3	4.3	0.87	100	96.0892	78.7522
2015	12	5	14	25	33	0.3	4.3	0.85	99.1	96.0892	77.5452
2015	12	5	14	35	33	0.3	4.3	0.86	99.7	96.0892	77.5452
2015	12	5	14	45	33	0.3	4.3	0.8	98.5	96.0892	72.7175
2015	12	5	14	55	33	0.3	4.3	0.81	96.8	96.0892	73.6227
2015	12	5	15	5	33	0.3	4.3	0.82	101	96.0892	74.2262
2015	12	5	15	15	33	0.3	4.3	0.82	99.7	96.0892	74.5279
2015	12	5	15	25	33	0.3	4.3	0.83	97.3	96.0892	75.7349
2015	12	5	15	35	33	0.3	4.3	0.82	96	96.0892	75.1314
2015	12	5	15	45	33	0.3	4.3	0.85	98.9	96.0892	77.2436
2015	12	5	15	55	33	0.3	4.3	0.84	98.4	96.0892	76.0366
2015	12	5	16	5	33	0.3	4.3	0.84	98.1	96.0892	76.0366
2015	12	5	16	15	33	0.3	4.3	0.88	98.8	96.0892	79.6574
2015	12	5	16	25	33	0.3	4.3	0.85	98.6	96.0892	77.5453
2015	12	5	16	35	33	0.3	4.3	0.83	96.4	96.0892	75.4332
2015	12	5	16	45	33	0.3	4.3	0.86	98.6	96.0892	77.847
2015	12	5	16	55	33	0.3	4.3	0.82	100	96.0892	73.9245
2015	12	5	17	5	33	0.3	4.3	0.86	99.7	96.0892	77.5453
2015	12	5	17	15	33	0.3	4.3	0.83	99.3	96.1549	75.4868
2015	12	5	17	25	33	0.3	4.3	0.87	98.6	96.0892	79.3557
2015	12	5	17	35	33	0.3	4.3	0.82	99.2	96.0892	74.8297
2015	12	5	17	45	33	0.3	4.3	0.82	99	96.0892	74.2262
2015	12	5	17	55	33	0.3	4.3	0.83	98	96.0892	75.4331
2015	12	5	18	5	33	0.3	4.3	0.82	100	96.0892	73.9245
2015	12	5	18	15	33	0.3	4.3	0.85	99.3	96.1549	77.6004
2015	12	5	18	25	33	0.3	4.3	0.83	99.1	96.1549	75.4868
2015	12	5	18	35	33	0.3	4.3	0.84	98.8	96.0892	76.0366
2015	12	5	18	45	33	0.3	4.3	0.89	100.2	96.1549	80.3179
2015	12	5	18	55	33	0.3	4.3	0.88	98.2	96.1549	79.7141

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	5	19	5	33	0.3	4.3	0.86	98.1	96.1549	78.2044
2015	12	5	19	15	33	0.3	4.3	0.87	98.5	96.1549	78.8082
2015	12	5	19	25	33	0.3	4.3	0.83	99.1	96.1549	75.7888
2015	12	5	19	35	33	0.3	4.3	0.88	100.5	96.1549	79.7141
2015	12	5	19	45	33	0.3	4.3	0.88	96.8	96.1549	80.62
2015	12	5	19	55	33	0.3	4.3	0.83	99.3	96.1549	75.4869
2015	12	5	20	5	33	0.3	4.3	0.84	98.3	96.1549	76.6947
2015	12	5	20	15	33	0.3	4.3	0.83	99.3	96.1549	75.7888
2015	12	5	20	25	33	0.3	4.3	0.84	99.6	96.1549	76.3927
2015	12	5	20	35	33	0.3	4.3	0.86	97.2	96.1549	78.8083
2015	12	5	20	45	33	0.3	4.3	0.81	96.7	96.1549	74.2791
2015	12	5	20	55	33	0.3	4.3	0.82	96.4	96.1549	75.1849
2015	12	5	21	5	33	0.3	4.3	0.85	99.6	96.1549	76.6947
2015	12	5	21	15	33	0.3	4.3	0.88	98.6	96.1549	79.7142
2015	12	5	21	25	33	0.3	4.3	0.81	98	96.1549	73.3733
2015	12	5	21	35	33	0.3	4.3	0.84	97.6	96.1549	76.9966
2015	12	5	21	45	33	0.3	4.3	0.9	97.3	96.1549	82.1297
2015	12	5	21	55	33	0.3	4.3	0.84	99.2	96.1549	76.6947
2015	12	5	22	5	33	0.3	4.3	0.86	98.2	96.1549	77.9025
2015	12	5	22	15	33	0.3	4.3	0.84	97.4	96.1549	76.9967
2015	12	5	22	25	33	0.3	4.3	0.83	98.5	96.1549	75.185
2015	12	5	22	35	33	0.3	4.3	0.81	96.3	96.1549	73.9772
2015	12	5	22	45	33	0.3	4.3	0.8	97.1	96.1549	73.0714
2015	12	5	22	55	33	0.3	4.3	0.88	98.8	96.1549	79.7142
2015	12	5	23	5	33	0.3	4.3	0.85	99.8	96.1549	76.9967
2015	12	5	23	15	33	0.3	4.3	0.85	99.1	96.1549	77.2986
2015	12	5	23	25	33	0.3	4.3	0.83	96.6	96.1549	75.4869
2015	12	5	23	35	33	0.3	4.3	0.85	98.2	96.0892	77.2437
2015	12	5	23	45	33	0.3	4.3	0.81	97.4	96.0892	73.9246
2015	12	5	23	55	33	0.3	4.3	0.82	97.5	96.0892	75.1316
2015	12	6	0	5	33	0.3	4.3	0.83	98.6	96.0892	75.7351
2015	12	6	0	15	33	0.3	4.3	0.8	97.5	96.0892	73.3212
2015	12	6	0	25	33	0.3	4.3	0.82	99.7	96.0892	74.5281
2015	12	6	0	35	33	0.3	4.3	0.81	97.7	96.0892	73.9247
2015	12	6	0	45	33	0.3	4.3	0.82	97.8	96.0236	74.4751
2015	12	6	0	55	33	0.3	4.3	0.81	97.4	96.0236	73.8721
2015	12	6	1	5	33	0.3	4.3	0.86	97.2	96.0236	78.6964
2015	12	6	1	15	33	0.3	4.3	0.84	98	95.958	76.8326
2015	12	6	1	25	33	0.3	4.3	0.85	99.6	95.958	76.5313
2015	12	6	1	35	33	0.3	4.3	0.81	98.7	95.8924	73.1648
2015	12	6	1	45	33	0.3	4.3	0.82	97.2	95.8924	74.3692
2015	12	6	1	55	33	0.3	4.3	0.85	98.4	95.8268	77.325
2015	12	6	2	5	33	0.3	4.3	0.84	97.9	95.7612	76.0672
2015	12	6	2	15	33	0.3	4.3	0.78	98	95.6955	70.9053
2015	12	6	2	25	33	0.3	4.3	0.85	99.8	95.4987	76.7495
2015	12	6	2	35	33	0.3	4.3	0.83	99.3	95.4987	75.2505

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	2	45	33	0.3	4.3	0.83	99.6	95.4331	74.5975
2015	12	6	2	55	33	0.3	4.3	0.86	97.7	95.4331	77.8929
2015	12	6	3	5	33	0.3	4.3	0.86	99.7	95.3675	76.939
2015	12	6	3	15	33	0.3	4.3	0.84	98.9	95.3018	75.9864
2015	12	6	3	25	33	0.3	4.3	0.85	98.9	95.3018	76.2856
2015	12	6	3	35	33	0.3	4.3	0.82	98.1	95.2362	73.5404
2015	12	6	3	45	33	0.3	4.3	0.84	97.9	95.1706	75.5788
2015	12	6	3	55	33	0.3	4.3	0.8	97.3	95.105	71.9423
2015	12	6	4	5	33	0.3	4.3	0.8	98.8	95.0394	71.5923
2015	12	6	4	15	33	0.3	4.3	0.82	96.6	94.9081	74.1702
2015	12	6	4	25	33	0.3	4.3	0.81	96.8	94.7769	72.5762
2015	12	6	4	35	33	0.3	4.3	0.78	99.2	94.7113	69.5516
2015	12	6	4	45	33	0.3	4.3	0.82	97.8	94.6457	73.9566
2015	12	6	4	55	33	0.3	4.3	0.83	98.6	94.58	74.4968
2015	12	6	5	5	33	0.3	4.3	0.79	99.3	94.5144	70.2908
2015	12	6	5	15	33	0.3	4.3	0.83	97.5	94.4488	74.0928
2015	12	6	5	25	33	0.3	4.3	0.79	98.8	94.3832	70.7814
2015	12	6	5	35	33	0.3	4.3	0.83	99.8	94.3176	73.6896
2015	12	6	5	45	33	0.3	4.3	0.81	99.3	94.252	72.4533
2015	12	6	5	55	33	0.3	4.3	0.86	98.8	93.9895	76.3713
2015	12	6	6	5	33	0.3	4.3	0.81	98.4	93.9239	71.6013
2015	12	6	6	15	33	0.3	4.3	0.79	98.4	93.7927	70.026
2015	12	6	6	25	33	0.3	4.3	0.83	99.3	93.727	73.7971
2015	12	6	6	35	33	0.3	4.3	0.83	99.6	93.727	72.9151
2015	12	6	6	45	33	0.3	4.3	0.84	99.9	93.6614	73.7434
2015	12	6	6	55	33	0.3	4.3	0.83	98.7	93.5958	73.1024
2015	12	6	7	5	33	0.3	4.3	0.83	99.4	93.4646	72.9956
2015	12	6	7	15	33	0.3	4.3	0.83	97.9	93.2021	73.6589
2015	12	6	7	25	33	0.3	4.3	0.81	98.4	93.1365	71.5603
2015	12	6	7	35	33	0.3	4.3	0.81	98.4	93.0709	70.9241
2015	12	6	7	45	33	0.3	4.3	0.78	97.8	93.0053	68.5387
2015	12	6	7	55	33	0.3	4.3	0.8	98.1	92.9396	69.9455
2015	12	6	8	5	33	0.3	4.3	0.81	98.6	92.874	71.059
2015	12	6	8	15	33	0.3	4.3	0.79	99.3	92.8084	69.5516
2015	12	6	8	25	33	0.3	4.3	0.81	99.1	92.6116	70.8497
2015	12	6	8	35	33	0.3	4.3	0.82	99.9	92.4147	71.2721
2015	12	6	8	45	33	0.3	4.3	0.83	99.1	92.3491	72.3774
2015	12	6	8	55	33	0.3	4.3	0.81	99.3	92.2835	70.8773
2015	12	6	9	5	33	0.3	4.3	0.78	99.7	92.2835	67.9843
2015	12	6	9	15	33	0.3	4.3	0.83	100.6	92.2179	72.2701
2015	12	6	9	25	33	0.3	4.3	0.8	98.7	92.1522	69.6167
2015	12	6	9	35	33	0.3	4.3	0.79	96.9	91.9554	68.8852
2015	12	6	9	45	33	0.3	4.3	0.82	99.2	91.7585	71.3196
2015	12	6	9	55	33	0.3	4.3	0.79	99.3	91.6929	68.1055
2015	12	6	10	5	33	0.3	4.3	0.76	97.5	91.6273	65.7574
2015	12	6	10	15	33	0.3	4.3	0.83	98.9	91.5617	71.447

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	10	25	33	0.3	4.3	0.79	100.8	91.4961	67.953
2015	12	6	10	35	33	0.3	4.3	0.75	98.5	91.4305	65.0371
2015	12	6	10	45	33	0.3	4.3	0.76	101.7	91.168	64.5569
2015	12	6	10	55	33	0.3	4.3	0.75	98.1	91.0368	64.4601
2015	12	6	11	5	33	0.3	4.3	0.78	99.9	90.9055	66.6416
2015	12	6	11	15	33	0.3	4.3	0.74	98.5	90.8399	63.1765
2015	12	6	11	25	33	0.3	4.3	0.75	98.6	90.8399	64.0301
2015	12	6	11	35	33	0.3	4.3	0.77	97.9	90.7743	65.6881
2015	12	6	11	45	33	0.3	4.3	0.75	99.1	90.5774	63.8373
2015	12	6	11	55	33	0.3	4.3	0.72	98.6	90.315	61.3815
2015	12	6	12	5	33	0.3	4.3	0.74	97.9	90.2494	62.7482
2015	12	6	12	15	33	0.3	4.3	0.72	97.4	90.1837	61.2885
2015	12	6	12	25	33	0.3	4.3	0.76	100.4	90.1181	64.3465
2015	12	6	12	35	33	0.3	4.3	0.74	98.6	90.0525	63.1697
2015	12	6	12	45	33	0.3	4.3	0.74	99.2	89.9213	62.5105
2015	12	6	12	55	33	0.3	4.3	0.73	100.8	89.79	61.8531
2015	12	6	13	5	33	0.3	4.3	0.72	100.2	89.6588	60.6359
2015	12	6	13	15	33	0.3	4.3	0.76	101.6	89.5276	63.9068
2015	12	6	13	25	33	0.3	4.3	0.75	97.6	89.462	63.2978
2015	12	6	13	35	33	0.3	4.3	0.74	102.3	89.462	61.8974
2015	12	6	13	45	33	0.3	4.3	0.71	98.5	89.3963	60.1709
2015	12	6	13	55	33	0.3	4.3	0.74	99.2	89.3307	62.0824
2015	12	6	14	5	33	0.3	4.3	0.72	98.9	89.2651	60.6376
2015	12	6	14	15	33	0.3	4.3	0.74	98.4	89.1995	62.2665
2015	12	6	14	25	33	0.3	4.3	0.7	99.1	88.937	59.0134
2015	12	6	14	35	33	0.3	4.3	0.76	101.2	88.8714	63.1403
2015	12	6	14	45	33	0.3	4.3	0.75	100	88.7402	62.7654
2015	12	6	14	55	33	0.3	4.3	0.75	99.8	88.6745	62.4394
2015	12	6	15	5	33	0.3	4.3	0.71	100.2	88.6745	58.8319
2015	12	6	15	15	33	0.3	4.3	0.79	97.9	88.6089	66.2734
2015	12	6	15	25	33	0.3	4.3	0.75	98.8	88.5433	62.6202
2015	12	6	15	35	33	0.3	4.3	0.76	100.2	88.4777	62.8487
2015	12	6	15	45	33	0.3	4.3	0.77	100.3	88.4121	63.6301
2015	12	6	15	55	33	0.3	3.9	0.75	101.4	88.2808	61.8742
2015	12	6	16	5	33	0.3	3.9	0.77	101.1	88.084	63.1082
2015	12	6	16	15	33	0.3	3.9	0.72	100.2	88.0184	59.7548
2015	12	6	16	25	33	0.3	3.9	0.78	100.4	88.0184	64.436
2015	12	6	16	35	33	0.3	3.9	0.76	100.2	87.9528	63.0102
2015	12	6	16	45	33	0.3	3.9	0.73	98.5	87.8871	60.4867
2015	12	6	16	55	33	0.3	3.9	0.75	100.3	87.8871	62.1363
2015	12	6	17	5	33	0.3	3.9	0.78	100.9	87.8215	64.2857
2015	12	6	17	15	33	0.3	3.9	0.85	99.1	87.7559	70.2748
2015	12	6	17	25	33	0.3	3.9	0.78	100.2	87.7559	64.2356
2015	12	6	17	35	33	0.3	3.9	0.77	100.8	87.6903	63.3626
2015	12	6	17	45	33	0.3	3.9	0.76	98.4	87.6247	62.765
2015	12	6	17	55	33	0.3	3.9	0.73	99.9	87.4934	59.6567

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	6	18	5	33	0.3	3.9	0.78	100.9	87.3622	63.935
2015	12	6	18	15	33	0.3	3.9	0.74	101.3	87.2966	60.0628
2015	12	6	18	25	33	0.3	3.9	0.73	97.7	87.231	60.5613
2015	12	6	18	35	33	0.3	3.9	0.8	100.6	87.231	65.4716
2015	12	6	18	45	33	0.3	3.9	0.78	100.2	87.1654	63.7847
2015	12	6	18	55	33	0.3	3.9	0.73	97.4	87.1654	60.5137
2015	12	6	19	5	33	0.3	3.9	0.76	98.4	87.1654	62.6944
2015	12	6	19	15	33	0.3	3.9	0.75	98.8	87.0997	61.8281
2015	12	6	19	25	33	0.3	3.9	0.74	99.4	87.0997	61.011
2015	12	6	19	35	33	0.3	3.9	0.78	98.7	87.0341	63.6846
2015	12	6	19	45	33	0.3	3.9	0.76	100.6	87.0341	62.3238
2015	12	6	19	55	33	0.3	3.9	0.76	100.7	86.9685	61.7309
2015	12	6	20	5	33	0.3	3.9	0.75	99.3	86.9685	61.1871
2015	12	6	20	15	33	0.3	3.9	0.75	98	86.8373	61.6338
2015	12	6	20	25	33	0.3	3.9	0.75	99.1	86.9029	61.4106
2015	12	6	20	35	33	0.3	3.9	0.76	98.7	86.8373	62.4483
2015	12	6	20	45	33	0.3	3.9	0.78	98.7	86.7717	64.0269
2015	12	6	20	55	33	0.3	3.9	0.77	97.6	86.6404	63.1132
2015	12	6	21	5	33	0.3	3.9	0.76	96.2	86.5748	62.2514
2015	12	6	21	15	33	0.3	3.9	0.76	98.5	86.5092	61.6613
2015	12	6	21	25	33	0.3	3.9	0.79	99.6	86.5092	64.0953
2015	12	6	21	35	33	0.3	3.9	0.82	98	86.5092	67.3406
2015	12	6	21	45	33	0.3	3.9	0.79	99.5	86.4436	64.3148
2015	12	6	21	55	33	0.3	3.9	0.74	96.3	86.4436	60.8018
2015	12	6	22	5	33	0.3	3.9	0.76	98.7	86.4436	62.153
2015	12	6	22	15	33	0.3	3.9	0.81	99.6	86.4436	65.666
2015	12	6	22	25	33	0.3	3.9	0.76	97.2	86.378	61.8338
2015	12	6	22	35	33	0.3	3.9	0.77	97.3	86.378	62.9138
2015	12	6	22	45	33	0.3	3.9	0.79	96.9	86.378	64.2639
2015	12	6	22	55	33	0.3	3.9	0.79	97.2	86.3123	64.213
2015	12	6	23	5	33	0.3	3.9	0.81	97.2	86.3123	66.1016
2015	12	6	23	15	33	0.3	3.9	0.74	99.5	86.3123	59.6264
2015	12	6	23	25	33	0.3	3.9	0.73	98.3	86.3123	59.0868
2015	12	6	23	35	33	0.3	3.9	0.79	100.3	86.2467	63.6229
2015	12	6	23	45	33	0.3	3.9	0.75	98	86.3123	61.2452
2015	12	6	23	55	33	0.3	3.9	0.8	96.9	86.2467	64.9709
2015	12	7	0	5	33	0.3	3.9	0.77	99.3	86.2467	62.8142
2015	12	7	0	15	33	0.3	3.9	0.78	98.9	86.1811	63.3031
2015	12	7	0	25	33	0.3	3.9	0.78	97	86.1811	63.5724
2015	12	7	0	35	33	0.3	3.9	0.78	97	86.1811	63.8418
2015	12	7	0	45	33	0.3	3.9	0.79	98.8	86.1811	64.3806
2015	12	7	0	55	33	0.3	3.9	0.74	99.2	86.1811	60.0706
2015	12	7	1	5	33	0.3	3.9	0.79	97.9	86.1811	63.8419
2015	12	7	1	15	33	0.3	3.9	0.75	98.6	86.1155	60.8304
2015	12	7	1	25	33	0.3	3.9	0.75	98.6	86.1155	60.5612
2015	12	7	1	35	33	0.3	3.9	0.77	98.1	86.1155	62.7145

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	1	45	33	0.3	3.9	0.71	97.1	86.1155	58.1388
2015	12	7	1	55	33	0.3	3.9	0.76	99.1	86.0499	61.8578
2015	12	7	2	5	33	0.3	3.9	0.78	98	86.0499	63.4715
2015	12	7	2	15	33	0.3	3.9	0.78	97.5	86.0499	63.7405
2015	12	7	2	25	33	0.3	3.9	0.73	99.1	86.0499	58.8995
2015	12	7	2	35	33	0.3	3.9	0.76	99.1	85.9843	61.8087
2015	12	7	2	45	33	0.3	3.9	0.74	96.3	85.9843	60.465
2015	12	7	2	55	33	0.3	3.9	0.75	97.3	85.9186	60.9539
2015	12	7	3	5	33	0.3	3.9	0.7	95.1	85.853	56.6124
2015	12	7	3	15	33	0.3	3.9	0.76	99.5	85.853	61.1736
2015	12	7	3	25	33	0.3	3.9	0.73	99.1	85.7874	58.712
2015	12	7	3	35	33	0.3	3.9	0.73	100.4	85.7874	58.712
2015	12	7	3	45	33	0.3	3.9	0.73	99.6	85.7874	58.7121
2015	12	7	3	55	33	0.3	3.9	0.76	100.7	85.7218	60.8082
2015	12	7	4	5	33	0.3	3.9	0.75	98.1	85.7218	60.2725
2015	12	7	4	15	33	0.3	3.9	0.72	96.8	85.7218	58.3973
2015	12	7	4	25	33	0.3	3.9	0.71	97.2	85.7218	57.3258
2015	12	7	4	35	33	0.3	3.9	0.72	99.4	85.7218	58.3974
2015	12	7	4	45	33	0.3	3.9	0.77	98.9	85.7218	61.8798
2015	12	7	4	55	33	0.3	3.9	0.78	97.5	85.7218	63.4871
2015	12	7	5	5	33	0.3	3.9	0.75	97.1	85.6562	60.4921
2015	12	7	5	15	33	0.3	3.9	0.75	99.6	85.6562	60.2244
2015	12	7	5	25	33	0.3	3.9	0.71	100.1	85.6562	57.0125
2015	12	7	5	35	33	0.3	3.9	0.75	98.8	85.6562	60.7598
2015	12	7	5	45	33	0.3	3.9	0.76	100	85.6562	60.7598
2015	12	7	5	55	33	0.3	3.9	0.77	98.1	85.6562	62.0981
2015	12	7	6	5	33	0.3	3.9	0.73	97.5	85.6562	58.8861
2015	12	7	6	15	33	0.3	3.9	0.73	98.8	85.6562	58.8862
2015	12	7	6	25	33	0.3	3.9	0.75	98.1	85.6562	60.2245
2015	12	7	6	35	33	0.3	3.9	0.77	99.1	85.6562	62.0981
2015	12	7	6	45	33	0.3	3.9	0.75	99.3	85.6562	60.2245
2015	12	7	6	55	33	0.3	3.9	0.72	97.9	85.6562	58.0832
2015	12	7	7	5	33	0.3	3.9	0.78	98.5	85.5906	62.8509
2015	12	7	7	15	33	0.3	3.9	0.76	98.5	85.5906	60.9787
2015	12	7	7	25	33	0.3	3.9	0.79	97.2	85.6562	63.9718
2015	12	7	7	35	33	0.3	3.9	0.74	98.1	85.5906	59.9089
2015	12	7	7	45	33	0.3	3.9	0.74	98.7	85.5906	59.374
2015	12	7	7	55	33	0.3	3.9	0.72	98.1	85.6562	58.0832
2015	12	7	8	5	33	0.3	3.9	0.71	97.4	85.6562	57.5478
2015	12	7	8	15	33	0.3	3.9	0.74	99.2	85.5906	59.6414
2015	12	7	8	25	33	0.3	3.9	0.7	99.2	85.5906	56.1645
2015	12	7	8	35	33	0.3	3.9	0.76	98.7	85.6562	61.5626
2015	12	7	8	45	33	0.3	3.9	0.74	96.8	85.6562	60.2242
2015	12	7	8	55	33	0.3	3.9	0.76	98.7	85.6562	61.0272
2015	12	7	9	5	33	0.3	3.9	0.7	99.2	85.6562	56.2093
2015	12	7	9	15	33	0.3	3.9	0.78	98.3	85.6562	62.6331

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	9	25	33	0.3	3.9	0.76	98.4	85.6562	61.5624
2015	12	7	9	35	33	0.3	3.9	0.71	99	85.6562	57.2798
2015	12	7	9	45	33	0.3	3.9	0.74	97.9	85.6562	59.6887
2015	12	7	9	55	33	0.3	3.9	0.72	98.1	85.7218	58.397
2015	12	7	10	5	33	0.3	3.9	0.74	98.9	85.7218	60.0042
2015	12	7	10	15	33	0.3	3.9	0.73	96.2	85.7218	59.4685
2015	12	7	10	25	33	0.3	3.9	0.71	96.4	85.7218	57.5933
2015	12	7	10	35	33	0.3	3.9	0.76	97.6	85.7218	61.8794
2015	12	7	10	45	33	0.3	3.9	0.72	98.1	85.7218	58.129
2015	12	7	10	55	33	0.3	3.9	0.75	98.6	85.7218	60.54
2015	12	7	11	5	33	0.3	3.9	0.78	100	85.7218	62.415
2015	12	7	11	15	33	0.3	3.9	0.76	100.7	85.7218	60.8077
2015	12	7	11	25	33	0.3	3.9	0.77	101.1	85.7218	61.3435
2015	12	7	11	35	33	0.3	3.9	0.76	99.5	85.7218	60.8078
2015	12	7	11	45	33	0.3	3.9	0.75	99.3	85.7218	60.8078
2015	12	7	11	55	33	0.3	3.9	0.77	102.3	85.7218	61.3435
2015	12	7	12	5	33	0.3	3.9	0.74	97.4	85.7218	60.0042
2015	12	7	12	15	33	0.3	3.9	0.73	97.7	85.7218	59.2005
2015	12	7	12	25	33	0.3	3.9	0.74	99.7	85.7218	59.7362
2015	12	7	12	35	33	0.3	3.9	0.77	102.4	85.7218	61.0755
2015	12	7	12	45	33	0.3	3.9	0.74	99.4	85.7218	60.004
2015	12	7	12	55	33	0.3	3.9	0.73	100.7	85.7218	58.3968
2015	12	7	13	5	33	0.3	3.9	0.73	100.4	85.7218	58.6647
2015	12	7	13	15	33	0.3	3.9	0.72	100.5	85.7218	57.861
2015	12	7	13	25	33	0.3	3.9	0.76	98.2	85.7218	61.6113
2015	12	7	13	35	33	0.3	3.9	0.74	99.7	85.7218	59.7361
2015	12	7	13	45	33	0.3	3.9	0.7	100.2	85.7218	56.5216
2015	12	7	13	55	33	0.3	3.9	0.72	100.7	85.7218	57.861
2015	12	7	14	5	33	0.3	3.9	0.74	98.6	85.6562	59.9562
2015	12	7	14	15	33	0.3	3.9	0.72	101.1	85.6562	57.2795
2015	12	7	14	25	33	0.3	3.9	0.72	101.9	85.6562	57.2795
2015	12	7	14	35	33	0.3	3.9	0.69	97.3	85.6562	56.2089
2015	12	7	14	45	33	0.3	3.9	0.74	98.6	85.6562	59.9562
2015	12	7	14	55	33	0.3	3.9	0.74	99	85.6562	59.4209
2015	12	7	15	5	33	0.3	3.9	0.74	99.9	85.6562	59.6885
2015	12	7	15	15	33	0.3	3.9	0.76	99.7	85.6562	61.0269
2015	12	7	15	25	33	0.3	3.9	0.68	96.6	85.5906	55.3617
2015	12	7	15	35	33	0.3	3.9	0.74	97.6	85.6562	60.2239
2015	12	7	15	45	33	0.3	3.9	0.74	100.3	85.6562	59.1532
2015	12	7	15	55	33	0.3	3.9	0.77	100.3	85.6562	61.5622
2015	12	7	16	5	33	0.3	3.9	0.7	99.2	85.6562	56.4766
2015	12	7	16	15	33	0.3	3.9	0.74	99.4	85.6562	59.9562
2015	12	7	16	25	33	0.3	3.9	0.73	98.5	85.6562	58.8856
2015	12	7	16	35	33	0.3	3.9	0.72	99.7	85.6562	57.8149
2015	12	7	16	45	33	0.3	3.9	0.71	99	85.6562	57.5473
2015	12	7	16	55	33	0.3	3.9	0.76	100.4	85.6562	61.0269

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	7	17	5	33	0.3	3.9	0.77	99.3	85.6562	62.3652
2015	12	7	17	15	33	0.3	3.9	0.72	99.5	85.6562	57.5473
2015	12	7	17	25	33	0.3	3.9	0.69	98.7	85.5906	55.6291
2015	12	7	17	35	33	0.3	3.9	0.74	100.3	85.6562	59.1532
2015	12	7	17	45	33	0.3	3.9	0.7	99.5	85.6562	56.209
2015	12	7	17	55	33	0.3	3.9	0.75	100.3	85.5906	60.4432
2015	12	7	18	5	33	0.3	3.9	0.72	97.9	85.5906	57.7687
2015	12	7	18	15	33	0.3	3.9	0.75	101.9	85.6562	59.6886
2015	12	7	18	25	33	0.3	3.9	0.72	98.9	85.5906	57.7687
2015	12	7	18	35	33	0.3	3.9	0.74	100.5	85.5906	59.1059
2015	12	7	18	45	33	0.3	3.9	0.74	97.9	85.5906	59.6408
2015	12	7	18	55	33	0.3	3.9	0.71	99.5	85.5906	57.2338
2015	12	7	19	5	33	0.3	3.9	0.74	101.5	85.5906	59.3734
2015	12	7	19	15	33	0.3	3.9	0.72	98.9	85.5906	58.3036
2015	12	7	19	25	33	0.3	3.9	0.72	100.8	85.5906	57.5013
2015	12	7	19	35	33	0.3	3.9	0.7	100.5	85.5906	56.4315
2015	12	7	19	45	33	0.3	3.9	0.76	99.5	85.5906	60.7106
2015	12	7	19	55	33	0.3	3.9	0.77	101.8	85.5906	61.2455
2015	12	7	20	5	33	0.3	3.9	0.75	99.3	85.5906	60.7106
2015	12	7	20	15	33	0.3	3.9	0.77	98.6	85.5906	62.0479
2015	12	7	20	25	33	0.3	3.9	0.74	102.6	85.5906	58.8385
2015	12	7	20	35	33	0.3	3.9	0.73	99.6	85.5906	58.3036
2015	12	7	20	45	33	0.3	3.9	0.73	100.6	85.5906	58.8385
2015	12	7	20	55	33	0.3	3.9	0.71	102	85.5906	56.6989
2015	12	7	21	5	33	0.3	3.9	0.74	99.8	85.5906	59.106
2015	12	7	21	15	33	0.3	3.9	0.68	100.5	85.5249	54.7829
2015	12	7	21	25	33	0.3	3.9	0.75	100	85.5249	60.3948
2015	12	7	21	35	33	0.3	3.9	0.72	100.5	85.5249	57.7225
2015	12	7	21	45	33	0.3	3.9	0.77	97.8	85.5249	62.2655
2015	12	7	21	55	33	0.3	3.9	0.71	98.7	85.5249	57.4553
2015	12	7	22	5	33	0.3	3.9	0.69	99.6	85.5249	55.3174
2015	12	7	22	15	33	0.3	3.9	0.77	98.9	85.5249	61.731
2015	12	7	22	25	33	0.3	3.9	0.72	98.9	85.5249	57.9898
2015	12	7	22	35	33	0.3	3.9	0.76	100.9	85.5249	60.9293
2015	12	7	22	45	33	0.3	3.9	0.77	98.9	85.5249	61.731
2015	12	7	22	55	33	0.3	3.9	0.76	101	85.5249	60.3949
2015	12	7	23	5	33	0.3	3.9	0.74	99.5	85.5249	59.326
2015	12	7	23	15	33	0.3	3.9	0.74	101	85.4593	59.0114
2015	12	7	23	25	33	0.3	3.9	0.75	99.1	85.4593	60.0795
2015	12	7	23	35	33	0.3	3.9	0.72	99.7	85.4593	57.9433
2015	12	7	23	45	33	0.3	3.9	0.76	100	85.4593	60.6135
2015	12	7	23	55	33	0.3	3.9	0.77	101.4	85.3937	61.0986
2015	12	8	0	5	33	0.3	3.9	0.7	101.6	85.3937	56.0293
2015	12	8	0	15	33	0.3	3.9	0.78	100	85.3937	62.1658
2015	12	8	0	25	33	0.3	3.9	0.74	99.5	85.3937	58.9642
2015	12	8	0	35	33	0.3	3.9	0.76	98.7	85.3937	61.0986

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	0	45	33	0.3	3.9	0.72	101.6	85.3937	57.3633
2015	12	8	0	55	33	0.3	3.9	0.76	99.9	85.3281	61.0496
2015	12	8	1	5	33	0.3	3.9	0.74	99	85.3281	59.1835
2015	12	8	1	15	33	0.3	3.9	0.77	99.8	85.3281	61.8494
2015	12	8	1	25	33	0.3	3.9	0.76	98.7	85.3281	61.3162
2015	12	8	1	35	33	0.3	3.9	0.77	101.8	85.2625	61.0007
2015	12	8	1	45	33	0.3	3.9	0.75	100.1	85.1969	59.887
2015	12	8	1	55	33	0.3	3.9	0.74	100.5	85.1312	59.041
2015	12	8	2	5	33	0.3	3.9	0.71	101.2	85.1312	56.6475
2015	12	8	2	15	33	0.3	3.9	0.73	101.9	85.0656	57.9306
2015	12	8	2	25	33	0.3	3.9	0.71	98.5	85.0656	56.6019
2015	12	8	2	35	33	0.3	3.9	0.77	100.6	85.0656	61.1194
2015	12	8	2	45	33	0.3	3.9	0.73	102.7	85.0656	57.9306
2015	12	8	2	55	33	0.3	3.9	0.78	102.2	85.0656	61.6509
2015	12	8	3	5	33	0.3	3.9	0.71	100.8	85	56.8219
2015	12	8	3	15	33	0.3	3.9	0.79	100.2	85	63.1945
2015	12	8	3	25	33	0.3	3.9	0.76	99.5	85	60.2737
2015	12	8	3	35	33	0.3	3.9	0.75	97.7	84.9344	60.4905
2015	12	8	3	45	33	0.3	3.9	0.74	100.5	84.9344	58.6333
2015	12	8	3	55	33	0.3	3.9	0.74	99.2	84.9344	59.1639
2015	12	8	4	5	33	0.3	3.9	0.7	99.7	84.9344	55.7149
2015	12	8	4	15	33	0.3	3.9	0.7	98.1	84.9344	55.7149
2015	12	8	4	25	33	0.3	3.9	0.72	98.4	84.9344	57.3068
2015	12	8	4	35	33	0.3	3.9	0.71	99.9	84.9344	56.5109
2015	12	8	4	45	33	0.3	3.9	0.71	96.6	84.8688	56.9955
2015	12	8	4	55	33	0.3	3.9	0.7	99.2	84.8688	55.9351
2015	12	8	5	5	33	0.3	3.9	0.75	100.9	84.8688	59.3814
2015	12	8	5	15	33	0.3	3.9	0.7	99.9	84.8688	55.9351
2015	12	8	5	25	33	0.3	3.9	0.67	99.6	84.8032	53.2412
2015	12	8	5	35	33	0.3	3.9	0.74	99.5	84.8032	58.8037
2015	12	8	5	45	33	0.3	3.9	0.69	101.5	84.8032	54.5656
2015	12	8	5	55	33	0.3	3.9	0.73	98.8	84.8032	58.274
2015	12	8	6	5	33	0.3	3.9	0.73	99.5	84.8032	58.274
2015	12	8	6	15	33	0.3	3.9	0.7	99.5	84.7375	55.5802
2015	12	8	6	25	33	0.3	3.9	0.72	101.4	84.7375	56.6389
2015	12	8	6	35	33	0.3	3.9	0.67	97.9	84.7375	53.7276
2015	12	8	6	45	33	0.3	3.9	0.72	98.9	84.7375	57.1683
2015	12	8	6	55	33	0.3	3.9	0.71	99.8	84.7375	56.6389
2015	12	8	7	5	33	0.3	3.9	0.69	100.5	84.7375	54.5216
2015	12	8	7	15	33	0.3	3.9	0.73	100.4	84.6719	57.9154
2015	12	8	7	25	33	0.3	3.9	0.69	97.9	84.6719	55.0064
2015	12	8	7	35	33	0.3	3.9	0.73	99.1	84.6719	57.9154
2015	12	8	7	45	33	0.3	3.9	0.7	99.5	84.6719	55.5353
2015	12	8	7	55	33	0.3	3.9	0.72	97.1	84.6063	57.34
2015	12	8	8	5	33	0.3	3.9	0.68	100.2	84.6063	54.1691
2015	12	8	8	15	33	0.3	3.9	0.69	101.3	84.6063	54.4334

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	8	25	33	0.3	3.9	0.68	102	84.6063	53.3764
2015	12	8	8	35	33	0.3	3.9	0.7	99.8	84.4751	55.1366
2015	12	8	8	45	33	0.3	3.9	0.69	99.2	84.4751	55.1365
2015	12	8	8	55	33	0.3	3.9	0.67	97.6	84.3438	53.4668
2015	12	8	9	5	33	0.3	3.9	0.7	97.8	84.3438	55.5738
2015	12	8	9	15	33	0.3	3.9	0.67	101.5	84.3438	52.94
2015	12	8	9	25	33	0.3	3.9	0.7	100.8	84.2782	55.2654
2015	12	8	9	35	33	0.3	3.9	0.71	97.9	84.3438	56.6273
2015	12	8	9	45	33	0.3	3.9	0.69	97.6	84.2782	55.0022
2015	12	8	9	55	33	0.3	3.9	0.68	97.4	84.2782	54.4759
2015	12	8	10	5	33	0.3	3.9	0.69	98.7	84.2782	54.739
2015	12	8	10	15	33	0.3	3.9	0.7	98.9	84.2126	55.4833
2015	12	8	10	25	33	0.3	3.9	0.71	100.6	84.2782	56.0548
2015	12	8	10	35	33	0.3	3.9	0.69	97.4	84.2126	54.6944
2015	12	8	10	45	33	0.3	3.9	0.7	98.1	84.2126	55.7462
2015	12	8	10	55	33	0.3	3.9	0.68	98.1	84.2126	53.6425
2015	12	8	11	5	33	0.3	3.9	0.67	100.2	84.2126	52.8536
2015	12	8	11	15	33	0.3	3.9	0.69	97.6	84.2126	54.9572
2015	12	8	11	25	33	0.3	3.9	0.72	98.9	84.2126	57.0608
2015	12	8	11	35	33	0.3	3.9	0.75	96	84.2126	59.6903
2015	12	8	11	45	33	0.3	3.9	0.66	98	84.2126	52.0647
2015	12	8	11	55	33	0.3	3.9	0.69	100.1	84.147	54.6497
2015	12	8	12	5	33	0.3	3.9	0.69	97.9	84.147	54.6498
2015	12	8	12	15	33	0.3	3.9	0.67	99.3	84.0814	52.7677
2015	12	8	12	25	33	0.3	3.9	0.68	97.5	84.0814	53.5553
2015	12	8	12	35	33	0.3	3.9	0.77	100.1	84.0158	60.3318
2015	12	8	12	45	33	0.3	3.9	0.7	99.5	84.0158	55.0855
2015	12	8	12	55	33	0.3	3.9	0.71	102	83.9501	55.5648
2015	12	8	13	5	33	0.3	3.9	0.73	99.1	83.9501	57.3994
2015	12	8	13	15	33	0.3	3.9	0.72	101.6	83.9501	56.0889
2015	12	8	13	25	33	0.3	3.9	0.71	99.1	83.8189	55.7357
2015	12	8	13	35	33	0.3	3.9	0.71	100.9	83.7533	55.4287
2015	12	8	13	45	33	0.3	3.9	0.7	103.5	83.6877	54.3384
2015	12	8	13	55	33	0.3	3.9	0.74	101	83.6877	57.7345
2015	12	8	14	5	33	0.3	3.9	0.72	101	83.6877	56.4283
2015	12	8	14	15	33	0.3	3.9	0.67	100.2	83.6221	52.2057
2015	12	8	14	25	33	0.3	3.9	0.74	102	83.6221	57.9483
2015	12	8	14	35	33	0.3	3.9	0.71	100.9	83.5564	55.2927
2015	12	8	14	45	33	0.3	3.9	0.72	101.9	83.5564	55.8143
2015	12	8	14	55	33	0.3	3.9	0.71	100.2	83.5564	55.2927
2015	12	8	15	5	33	0.3	3.9	0.69	101	83.5564	53.467
2015	12	8	15	15	33	0.3	3.9	0.66	101.1	83.5564	51.6413
2015	12	8	15	25	33	0.3	3.9	0.71	100.6	83.4908	55.508
2015	12	8	15	35	33	0.3	3.9	0.71	102.4	83.4908	54.7262
2015	12	8	15	45	33	0.3	3.9	0.68	101.7	83.4908	52.902
2015	12	8	15	55	33	0.3	3.9	0.72	100.5	83.4908	56.0292

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	16	5	33	0.3	3.9	0.68	99.1	83.4252	53.6397
2015	12	8	16	15	33	0.3	3.9	0.67	102.7	83.4252	51.817
2015	12	8	16	25	33	0.3	3.9	0.71	101	83.4252	54.9416
2015	12	8	16	35	33	0.3	3.9	0.66	98.8	83.4252	52.0774
2015	12	8	16	45	33	0.3	3.9	0.68	100.1	83.4252	52.8585
2015	12	8	16	55	33	0.3	3.9	0.69	100.1	83.3596	53.8558
2015	12	8	17	5	33	0.3	3.9	0.69	101.3	83.3596	53.5956
2015	12	8	17	15	33	0.3	3.9	0.68	100.8	83.3596	53.0753
2015	12	8	17	25	33	0.3	3.9	0.68	100.6	83.3596	53.0753
2015	12	8	17	35	33	0.3	3.9	0.68	97.5	83.3596	53.3354
2015	12	8	17	45	33	0.3	3.9	0.67	100.7	83.294	52.2518
2015	12	8	17	55	33	0.3	3.9	0.71	99.6	83.294	55.1113
2015	12	8	18	5	33	0.3	3.9	0.77	101.1	83.294	59.7906
2015	12	8	18	15	33	0.3	3.9	0.67	98.8	83.294	52.2517
2015	12	8	18	25	33	0.3	3.9	0.7	98.7	83.2284	54.5465
2015	12	8	18	35	33	0.3	3.9	0.69	100.5	83.2284	53.5075
2015	12	8	18	45	33	0.3	3.9	0.69	98.2	83.1627	53.9825
2015	12	8	18	55	33	0.3	3.9	0.7	97.9	83.1627	54.5016
2015	12	8	19	5	33	0.3	3.9	0.73	96.7	83.0315	57.0028
2015	12	8	19	15	33	0.3	3.9	0.67	101.8	83.0315	52.0798
2015	12	8	19	25	33	0.3	3.9	0.71	96.1	82.9659	55.6613
2015	12	8	19	35	33	0.3	3.9	0.69	101.5	82.9659	53.5902
2015	12	8	19	45	33	0.3	3.9	0.72	100.3	82.9659	55.6613
2015	12	8	19	55	33	0.3	3.9	0.72	98.4	82.9659	55.9202
2015	12	8	20	5	33	0.3	3.9	0.7	98.1	82.9003	54.5806
2015	12	8	20	15	33	0.3	3.9	0.67	98.7	82.9003	52.5112
2015	12	8	20	25	33	0.3	3.9	0.73	100.4	82.9003	56.3914
2015	12	8	20	35	33	0.3	3.9	0.7	100	82.9003	54.322
2015	12	8	20	45	33	0.3	3.9	0.69	99.6	82.9003	53.8046
2015	12	8	20	55	33	0.3	3.9	0.73	100.1	82.8347	56.8617
2015	12	8	21	5	33	0.3	3.9	0.66	98	82.9003	51.7352
2015	12	8	21	15	33	0.3	3.9	0.72	99.9	82.8347	56.0863
2015	12	8	21	25	33	0.3	3.9	0.7	101.9	82.8347	54.0186
2015	12	8	21	35	33	0.3	3.9	0.66	98	82.8347	51.6925
2015	12	8	21	45	33	0.3	3.9	0.68	101.4	82.8347	52.4678
2015	12	8	21	55	33	0.3	3.9	0.67	99.3	82.8347	51.9509
2015	12	8	22	5	33	0.3	3.9	0.68	98.6	82.769	53.1992
2015	12	8	22	15	33	0.3	3.9	0.7	101.4	82.8347	54.0186
2015	12	8	22	25	33	0.3	3.9	0.68	101.7	82.769	52.4244
2015	12	8	22	35	33	0.3	3.9	0.7	100	82.769	54.2322
2015	12	8	22	45	33	0.3	3.9	0.67	98.5	82.769	51.9079
2015	12	8	22	55	33	0.3	3.9	0.73	100.1	82.769	56.8147
2015	12	8	23	5	33	0.3	3.9	0.68	101.7	82.769	52.4244
2015	12	8	23	15	33	0.3	3.9	0.69	100.9	82.769	53.4574
2015	12	8	23	25	33	0.3	3.9	0.72	98.9	82.769	55.7817
2015	12	8	23	35	33	0.3	3.9	0.69	99.6	82.769	53.7157

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	8	23	45	33	0.3	3.9	0.71	101.3	82.7034	54.4453
2015	12	8	23	55	33	0.3	3.9	0.69	100.9	82.769	53.4575
2015	12	9	0	5	33	0.3	3.9	0.75	102.2	82.7034	57.2837
2015	12	9	0	15	33	0.3	3.9	0.69	99.6	82.7034	53.1552
2015	12	9	0	25	33	0.3	3.9	0.72	97.8	82.7034	56.2516
2015	12	9	0	35	33	0.3	3.9	0.77	99.6	82.7034	59.348
2015	12	9	0	45	33	0.3	3.9	0.72	97.8	82.7034	56.2516
2015	12	9	0	55	33	0.3	3.9	0.74	100.5	82.7034	57.2837
2015	12	9	1	5	33	0.3	3.9	0.73	98.8	82.7034	56.5096
2015	12	9	1	15	33	0.3	3.9	0.69	101.5	82.7034	53.1552
2015	12	9	1	25	33	0.3	3.9	0.71	98	82.7034	55.2195
2015	12	9	1	35	33	0.3	3.9	0.66	98.8	82.6378	51.5642
2015	12	9	1	45	33	0.3	3.9	0.72	101.6	82.6378	55.1737
2015	12	9	1	55	33	0.3	3.9	0.73	100.6	82.6378	56.4628
2015	12	9	2	5	33	0.3	3.9	0.69	99	82.6378	53.6268
2015	12	9	2	15	33	0.3	3.9	0.67	100.8	82.6378	51.5642
2015	12	9	2	25	33	0.3	3.9	0.7	99.2	82.6378	54.4003
2015	12	9	2	35	33	0.3	3.9	0.69	99.2	82.6378	53.8846
2015	12	9	2	45	33	0.3	3.9	0.67	97.9	82.6378	52.3377
2015	12	9	2	55	33	0.3	3.9	0.7	99.8	82.6378	53.8846
2015	12	9	3	5	33	0.3	3.9	0.7	99.8	82.5722	53.84
2015	12	9	3	15	33	0.3	3.9	0.68	100.3	82.6378	52.5956
2015	12	9	3	25	33	0.3	3.9	0.69	100.4	82.5722	53.5824
2015	12	9	3	35	33	0.3	3.9	0.7	100.2	82.5722	54.3552
2015	12	9	3	45	33	0.3	3.9	0.67	99.6	82.5722	52.0368
2015	12	9	3	55	33	0.3	3.9	0.67	100.4	82.5722	52.0368
2015	12	9	4	5	33	0.3	3.9	0.72	99.2	82.5722	55.6433
2015	12	9	4	15	33	0.3	3.9	0.72	97.1	82.5722	56.1585
2015	12	9	4	25	33	0.3	3.9	0.69	98.2	82.5722	53.3248
2015	12	9	4	35	33	0.3	3.9	0.7	97	82.5066	54.8249
2015	12	9	4	45	33	0.3	3.9	0.7	100	82.5066	54.0527
2015	12	9	4	55	33	0.3	3.9	0.7	102.5	82.5066	53.538
2015	12	9	5	5	33	0.3	3.9	0.74	98.4	82.5066	57.3989
2015	12	9	5	15	33	0.3	3.9	0.71	101.2	82.5066	54.5676
2015	12	9	5	25	33	0.3	3.9	0.72	99.4	82.5066	56.1119
2015	12	9	5	35	33	0.3	3.9	0.68	100.6	82.5066	52.5084
2015	12	9	5	45	33	0.3	3.9	0.73	99.6	82.4409	56.0653
2015	12	9	5	55	33	0.3	3.9	0.73	100.4	82.4409	56.0653
2015	12	9	6	5	33	0.3	3.9	0.7	101.3	82.4409	54.0079
2015	12	9	6	15	33	0.3	3.9	0.74	99.7	82.4409	57.3512
2015	12	9	6	25	33	0.3	3.9	0.71	99	82.4409	55.2938
2015	12	9	6	35	33	0.3	3.9	0.72	102.3	82.4409	55.2938
2015	12	9	6	45	33	0.3	3.9	0.71	101.7	82.4409	54.5223
2015	12	9	6	55	33	0.3	3.9	0.7	99.4	82.3753	54.22
2015	12	9	7	5	33	0.3	3.9	0.72	99.1	82.3753	56.0188
2015	12	9	7	15	33	0.3	3.9	0.71	100.4	82.3753	54.477

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	7	25	33	0.3	3.9	0.69	100.9	82.3753	53.4491
2015	12	9	7	35	33	0.3	3.9	0.72	100.8	82.3753	55.2479
2015	12	9	7	45	33	0.3	3.9	0.71	100.4	82.3097	54.4316
2015	12	9	7	55	33	0.3	3.9	0.71	102.5	82.2441	54.3863
2015	12	9	8	5	33	0.3	3.9	0.71	101.3	82.2441	54.1298
2015	12	9	8	15	33	0.3	3.9	0.76	99.4	82.1785	58.6985
2015	12	9	8	25	33	0.3	3.9	0.72	99.1	82.1785	55.8789
2015	12	9	8	35	33	0.3	3.9	0.73	99.8	82.1785	56.1352
2015	12	9	8	45	33	0.3	3.9	0.71	101	82.1785	54.0845
2015	12	9	8	55	33	0.3	3.9	0.69	101.3	82.1785	52.8029
2015	12	9	9	5	33	0.3	3.9	0.74	98.9	82.1785	57.1604
2015	12	9	9	15	33	0.3	3.9	0.71	99.3	82.1785	54.5971
2015	12	9	9	25	33	0.3	3.9	0.7	99.5	82.1785	53.8281
2015	12	9	9	35	33	0.3	3.9	0.69	101.5	82.1785	52.8028
2015	12	9	9	45	33	0.3	3.9	0.72	99.2	82.1785	55.366
2015	12	9	9	55	33	0.3	3.9	0.68	101.2	82.1785	51.7774
2015	12	9	10	5	33	0.3	3.9	0.69	100.4	82.1785	53.3153
2015	12	9	10	15	33	0.3	3.9	0.7	99.2	82.1785	53.8279
2015	12	9	10	25	33	0.3	3.9	0.69	100.9	82.1785	53.0589
2015	12	9	10	35	33	0.3	3.9	0.71	98.8	82.1785	54.5968
2015	12	9	10	45	33	0.3	3.9	0.69	100.6	82.1785	53.3151
2015	12	9	10	55	33	0.3	3.9	0.71	97.9	82.1785	55.1093
2015	12	9	11	5	33	0.3	3.9	0.67	99.6	82.1785	51.5208
2015	12	9	11	15	33	0.3	3.9	0.7	97.3	82.1785	54.0841
2015	12	9	11	25	33	0.3	3.9	0.68	99.7	82.1785	52.2898
2015	12	9	11	35	33	0.3	3.9	0.71	98.3	82.1129	54.5511
2015	12	9	11	45	33	0.3	3.9	0.71	101.2	82.1785	54.5967
2015	12	9	11	55	33	0.3	3.9	0.72	99.7	82.1129	55.3195
2015	12	9	12	5	33	0.3	3.9	0.68	100.8	82.1129	52.5022
2015	12	9	12	15	33	0.3	3.9	0.71	100.1	82.1129	54.8072
2015	12	9	12	25	33	0.3	3.9	0.74	97.9	82.1129	57.3682
2015	12	9	12	35	33	0.3	3.9	0.69	97.7	82.1129	53.2704
2015	12	9	12	45	33	0.3	3.9	0.68	101.2	82.1129	51.7338
2015	12	9	12	55	33	0.3	3.9	0.67	100.7	82.1129	51.4777
2015	12	9	13	5	33	0.3	3.9	0.69	98.8	82.1129	53.0143
2015	12	9	13	15	33	0.3	3.9	0.69	100.2	82.1129	52.7582
2015	12	9	13	25	33	0.3	3.9	0.72	97.9	82.1129	55.5754
2015	12	9	13	35	33	0.3	3.9	0.69	99.3	82.1129	53.2704
2015	12	9	13	45	33	0.3	3.9	0.65	102.2	82.0472	49.6434
2015	12	9	13	55	33	0.3	3.9	0.68	98.6	82.0472	52.4583
2015	12	9	14	5	33	0.3	3.9	0.7	102.9	82.0472	53.4818
2015	12	9	14	15	33	0.3	3.9	0.67	100.2	82.0472	51.1788
2015	12	9	14	25	33	0.3	3.9	0.68	99.8	81.9816	51.9031
2015	12	9	14	35	33	0.3	3.9	0.65	98.7	81.9816	49.8577
2015	12	9	14	45	33	0.3	3.9	0.66	100.6	81.9816	50.6247
2015	12	9	14	55	33	0.3	3.9	0.67	100.8	81.916	51.0934

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	15	5	33	0.3	3.9	0.67	98.7	81.916	51.6043
2015	12	9	15	15	33	0.3	3.9	0.71	99.3	81.916	54.4145
2015	12	9	15	25	33	0.3	3.9	0.69	99.2	81.916	53.3926
2015	12	9	15	35	33	0.3	3.9	0.69	100.4	81.916	52.8817
2015	12	9	15	45	33	0.3	3.9	0.69	100.5	81.916	52.6262
2015	12	9	15	55	33	0.3	3.9	0.67	99	81.916	51.6044
2015	12	9	16	5	33	0.3	3.9	0.72	98.4	81.916	55.6918
2015	12	9	16	15	33	0.3	3.9	0.74	98.2	81.8504	56.9215
2015	12	9	16	25	33	0.3	3.9	0.67	97.6	81.8504	51.5612
2015	12	9	16	35	33	0.3	3.9	0.67	97.6	81.8504	51.5612
2015	12	9	16	45	33	0.3	3.9	0.7	99.2	81.8504	53.6032
2015	12	9	16	55	33	0.3	3.9	0.7	98.1	81.8504	53.8584
2015	12	9	17	5	33	0.3	3.9	0.66	100.4	81.8504	50.2849
2015	12	9	17	15	33	0.3	3.9	0.68	98.6	81.7848	52.028
2015	12	9	17	25	33	0.3	3.6	0.68	98.3	81.7192	52.2393
2015	12	9	17	35	33	0.3	3.6	0.71	98	81.7192	54.2779
2015	12	9	17	45	33	0.3	3.6	0.7	100	81.6535	53.4685
2015	12	9	17	55	33	0.3	3.6	0.71	98.5	81.6535	54.2323
2015	12	9	18	5	33	0.3	3.6	0.69	96.3	81.6535	53.4685
2015	12	9	18	15	33	0.3	3.6	0.72	99.9	81.5879	55.2044
2015	12	9	18	25	33	0.3	3.6	0.67	96.7	81.5879	51.8972
2015	12	9	18	35	33	0.3	3.6	0.69	99.3	81.5879	52.6604
2015	12	9	18	45	33	0.3	3.6	0.76	101	81.5879	57.7483
2015	12	9	18	55	33	0.3	3.6	0.77	100.1	81.5879	58.5115
2015	12	9	19	5	33	0.3	3.6	0.71	98.3	81.5879	54.1868
2015	12	9	19	15	33	0.3	3.6	0.72	97.3	81.5879	55.7132
2015	12	9	19	25	33	0.3	3.6	0.68	98.8	81.5879	52.406
2015	12	9	19	35	33	0.3	3.6	0.68	98.8	81.5879	52.406
2015	12	9	19	45	33	0.3	3.6	0.72	98.7	81.5879	54.95
2015	12	9	19	55	33	0.3	3.6	0.75	98.6	81.5879	57.2396
2015	12	9	20	5	33	0.3	3.6	0.7	99.2	81.5879	53.4236
2015	12	9	20	15	33	0.3	3.6	0.71	100.4	81.5879	54.1868
2015	12	9	20	25	33	0.3	3.6	0.7	100.3	81.5879	53.4236
2015	12	9	20	35	33	0.3	3.6	0.7	97	81.5879	53.9324
2015	12	9	20	45	33	0.3	3.6	0.71	99	81.5879	54.4412
2015	12	9	20	55	33	0.3	3.6	0.69	99.6	81.5879	52.406
2015	12	9	21	5	33	0.3	3.6	0.73	98.1	81.5223	55.6664
2015	12	9	21	15	33	0.3	3.6	0.71	97.5	81.5879	54.4412
2015	12	9	21	25	33	0.3	3.6	0.65	99.7	81.5879	49.3533
2015	12	9	21	35	33	0.3	3.6	0.73	98.3	81.5879	55.9676
2015	12	9	21	45	33	0.3	3.6	0.73	98.1	81.5879	55.7132
2015	12	9	21	55	33	0.3	3.6	0.72	100.4	81.5223	55.1581
2015	12	9	22	5	33	0.3	3.6	0.71	96.9	81.5879	54.6957
2015	12	9	22	15	33	0.3	3.6	0.69	99.6	81.5223	52.6162
2015	12	9	22	25	33	0.3	3.6	0.72	98.2	81.5879	54.9501
2015	12	9	22	35	33	0.3	3.6	0.75	99.8	81.5223	57.1916

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	9	22	45	33	0.3	3.6	0.72	98.4	81.5879	55.4589
2015	12	9	22	55	33	0.3	3.6	0.73	97.5	81.5879	55.9677
2015	12	9	23	5	33	0.3	3.6	0.7	98.4	81.5879	53.6781
2015	12	9	23	15	33	0.3	3.6	0.69	98.2	81.5879	52.9149
2015	12	9	23	25	33	0.3	3.6	0.72	99.2	81.5223	54.9039
2015	12	9	23	35	33	0.3	3.6	0.71	98.5	81.5879	54.1869
2015	12	9	23	45	33	0.3	3.6	0.7	99.5	81.5223	53.1246
2015	12	9	23	55	33	0.3	3.6	0.7	99.1	81.5223	53.8872
2015	12	10	0	5	33	0.3	3.6	0.7	97.9	81.5223	53.3788
2015	12	10	0	15	33	0.3	3.6	0.68	101.4	81.5223	51.8537
2015	12	10	0	25	33	0.3	3.6	0.71	99	81.5223	54.3956
2015	12	10	0	35	33	0.3	3.6	0.71	97.9	81.5223	54.6498
2015	12	10	0	45	33	0.3	3.6	0.68	98.6	81.5223	52.3621
2015	12	10	0	55	33	0.3	3.6	0.72	98.9	81.5223	54.904
2015	12	10	1	5	33	0.3	3.6	0.74	100.3	81.5223	56.1749
2015	12	10	1	15	33	0.3	3.6	0.69	97.9	81.5223	53.1247
2015	12	10	1	25	33	0.3	3.6	0.69	99	81.5223	52.8705
2015	12	10	1	35	33	0.3	3.6	0.68	98.3	81.5223	52.1079
2015	12	10	1	45	33	0.3	3.6	0.73	98.3	81.5223	55.9207
2015	12	10	1	55	33	0.3	3.6	0.69	100.6	81.5223	52.8705
2015	12	10	2	5	33	0.3	3.6	0.72	97.8	81.5223	55.4124
2015	12	10	2	15	33	0.3	3.6	0.72	97.6	81.5223	54.904
2015	12	10	2	25	33	0.3	3.6	0.68	99.7	81.5223	52.108
2015	12	10	2	35	33	0.3	3.6	0.69	99	81.5223	53.1247
2015	12	10	2	45	33	0.3	3.6	0.73	98.6	81.5223	55.6666
2015	12	10	2	55	33	0.3	3.6	0.71	101.2	81.5223	53.8873
2015	12	10	3	5	33	0.3	3.6	0.71	99.9	81.5879	54.187
2015	12	10	3	15	33	0.3	3.6	0.68	97.5	81.5223	52.3622
2015	12	10	3	25	33	0.3	3.6	0.69	97.4	81.5223	52.8706
2015	12	10	3	35	33	0.3	3.6	0.71	100.3	81.5223	54.3957
2015	12	10	3	45	33	0.3	3.6	0.76	99.7	81.5223	57.9543
2015	12	10	3	55	33	0.3	3.6	0.72	101.1	81.5223	54.3957
2015	12	10	4	5	33	0.3	3.6	0.72	98.9	81.5223	55.1583
2015	12	10	4	15	33	0.3	3.6	0.73	100.1	81.5223	55.9208
2015	12	10	4	25	33	0.3	3.6	0.73	101.7	81.5223	55.1583
2015	12	10	4	35	33	0.3	3.6	0.68	100.5	81.5223	52.1081
2015	12	10	4	45	33	0.3	3.6	0.71	102.2	81.5223	53.8874
2015	12	10	4	55	33	0.3	3.6	0.72	100.7	81.5223	54.9041
2015	12	10	5	5	33	0.3	3.6	0.71	100.6	81.5223	54.1416
2015	12	10	5	15	33	0.3	3.6	0.71	100.4	81.5223	53.8874
2015	12	10	5	25	33	0.3	3.6	0.72	98.7	81.5223	54.9042
2015	12	10	5	35	33	0.3	3.6	0.72	100.5	81.4567	54.858
2015	12	10	5	45	33	0.3	3.6	0.71	97.8	81.5223	54.1416
2015	12	10	5	55	33	0.3	3.6	0.71	100.2	81.5223	53.8874
2015	12	10	6	5	33	0.3	3.6	0.71	99.3	81.4567	54.0961
2015	12	10	6	15	33	0.3	3.6	0.68	100.1	81.4567	51.5564

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	6	25	33	0.3	3.6	0.71	100.1	81.4567	54.0961
2015	12	10	6	35	33	0.3	3.6	0.71	100.6	81.4567	54.0962
2015	12	10	6	45	33	0.3	3.6	0.73	100.6	81.4567	55.62
2015	12	10	6	55	33	0.3	3.6	0.72	101.3	81.4567	54.6041
2015	12	10	7	5	33	0.3	3.6	0.71	100.9	81.4567	53.8422
2015	12	10	7	15	33	0.3	3.6	0.72	98.7	81.4567	54.8581
2015	12	10	7	25	33	0.3	3.6	0.71	97.2	81.4567	54.6041
2015	12	10	7	35	33	0.3	3.6	0.76	99.5	81.4567	57.6518
2015	12	10	7	45	33	0.3	3.6	0.71	98	81.4567	54.3501
2015	12	10	7	55	33	0.3	3.6	0.69	99.8	81.3911	52.7818
2015	12	10	8	5	33	0.3	3.6	0.7	97.8	81.4567	53.8421
2015	12	10	8	15	33	0.3	3.6	0.72	99.1	81.4567	55.3659
2015	12	10	8	25	33	0.3	3.6	0.73	98	81.4567	55.8738
2015	12	10	8	35	33	0.3	3.6	0.72	100.7	81.3911	54.8118
2015	12	10	8	45	33	0.3	3.6	0.72	98.7	81.3911	54.8118
2015	12	10	8	55	33	0.3	3.6	0.72	98.9	81.4567	55.1118
2015	12	10	9	5	33	0.3	3.6	0.69	96.3	81.4567	53.08
2015	12	10	9	15	33	0.3	3.6	0.65	98.7	81.3911	49.4828
2015	12	10	9	25	33	0.3	3.6	0.74	100	81.3911	56.3343
2015	12	10	9	35	33	0.3	3.6	0.67	101.3	81.4567	51.0483
2015	12	10	9	45	33	0.3	3.6	0.68	97.5	81.3911	51.7665
2015	12	10	9	55	33	0.3	3.6	0.68	98.6	81.3911	52.0201
2015	12	10	10	5	33	0.3	3.6	0.69	100.1	81.4567	52.5718
2015	12	10	10	15	33	0.3	3.6	0.68	97.2	81.4567	52.3177
2015	12	10	10	25	33	0.3	3.6	0.67	99.2	81.4567	51.5559
2015	12	10	10	35	33	0.3	3.6	0.73	98.7	81.4567	56.1274
2015	12	10	10	45	33	0.3	3.6	0.71	99.2	81.4567	54.6037
2015	12	10	10	55	33	0.3	3.6	0.72	100	81.3911	54.5577
2015	12	10	11	5	33	0.3	3.6	0.7	99.7	81.3911	53.289
2015	12	10	11	15	33	0.3	3.6	0.75	97.6	81.3911	57.3491
2015	12	10	11	25	33	0.3	3.6	0.7	98.9	81.3911	53.5427
2015	12	10	11	35	33	0.3	3.6	0.72	98.9	81.3911	54.8115
2015	12	10	11	45	33	0.3	3.6	0.72	98.7	81.3911	54.8114
2015	12	10	11	55	33	0.3	3.6	0.71	99.5	81.3255	54.2581
2015	12	10	12	5	33	0.3	3.6	0.7	99.5	81.3911	53.2888
2015	12	10	12	15	33	0.3	3.6	0.69	100.4	81.3911	52.7813
2015	12	10	12	25	33	0.3	3.6	0.71	100.1	81.3255	54.2581
2015	12	10	12	35	33	0.3	3.6	0.72	98.1	81.3255	55.0187
2015	12	10	12	45	33	0.3	3.6	0.69	98.7	81.3255	52.9903
2015	12	10	12	55	33	0.3	3.6	0.7	96.8	81.3255	53.4974
2015	12	10	13	5	33	0.3	3.6	0.7	98.4	81.3255	53.4974
2015	12	10	13	15	33	0.3	3.6	0.71	100.1	81.3255	54.0045
2015	12	10	13	25	33	0.3	3.6	0.7	99.2	81.3255	53.2439
2015	12	10	13	35	33	0.3	3.6	0.7	98.6	81.2598	53.7056
2015	12	10	13	45	33	0.3	3.6	0.69	100.6	81.3255	52.7368
2015	12	10	13	55	33	0.3	3.6	0.7	98.1	81.2598	53.199

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	14	5	33	0.3	3.6	0.69	100.2	81.2598	52.1856
2015	12	10	14	15	33	0.3	3.6	0.67	98.7	81.1942	51.3822
2015	12	10	14	25	33	0.3	3.6	0.71	100.3	81.1942	54.1665
2015	12	10	14	35	33	0.3	3.6	0.71	100.9	81.1942	53.9133
2015	12	10	14	45	33	0.3	3.6	0.68	98.6	81.063	51.8008
2015	12	10	14	55	33	0.3	3.6	0.7	98.9	81.1286	53.362
2015	12	10	15	5	33	0.3	3.6	0.72	98.9	81.063	54.5803
2015	12	10	15	15	33	0.3	3.6	0.72	99.5	81.063	54.5803
2015	12	10	15	25	33	0.3	3.6	0.71	100.4	81.1286	53.8677
2015	12	10	15	35	33	0.3	3.6	0.75	97.5	81.1286	57.6612
2015	12	10	15	45	33	0.3	3.6	0.7	100.6	81.063	52.8114
2015	12	10	15	55	33	0.3	3.6	0.66	98.8	80.9974	50.4945
2015	12	10	16	5	33	0.3	3.6	0.73	100.7	81.1286	55.1322
2015	12	10	16	15	33	0.3	3.6	0.69	98	81.063	52.306
2015	12	10	16	25	33	0.3	3.6	0.69	99	80.9974	52.5143
2015	12	10	16	35	33	0.3	3.6	0.68	100.3	80.9974	51.2519
2015	12	10	16	45	33	0.3	3.6	0.69	100.7	80.9974	52.2618
2015	12	10	16	55	33	0.3	3.6	0.72	101.3	80.9974	54.2815
2015	12	10	17	5	33	0.3	3.6	0.72	99.7	80.9974	54.7864
2015	12	10	17	15	33	0.3	3.6	0.72	100	80.9974	54.2815
2015	12	10	17	25	33	0.3	3.6	0.68	100.3	80.9974	51.5043
2015	12	10	17	35	33	0.3	3.6	0.75	100.1	81.063	56.8543
2015	12	10	17	45	33	0.3	3.6	0.68	99.5	81.063	51.2952
2015	12	10	17	55	33	0.3	3.6	0.73	100.4	81.063	55.3381
2015	12	10	18	5	33	0.3	3.6	0.72	100.5	80.9974	54.2814
2015	12	10	18	15	33	0.3	3.6	0.67	99	80.9974	50.7468
2015	12	10	18	25	33	0.3	3.6	0.67	100.1	80.9974	50.9993
2015	12	10	18	35	33	0.3	3.6	0.69	99.6	80.9974	52.2616
2015	12	10	18	45	33	0.3	3.6	0.68	98.6	80.9974	52.0091
2015	12	10	18	55	33	0.3	3.6	0.73	99.8	80.9974	55.2913
2015	12	10	19	5	33	0.3	3.6	0.7	100.3	80.9974	53.019
2015	12	10	19	15	33	0.3	3.6	0.7	98.9	80.9974	53.019
2015	12	10	19	25	33	0.3	3.6	0.67	100.8	80.9974	50.4943
2015	12	10	19	35	33	0.3	3.6	0.66	98.8	80.9974	50.4943
2015	12	10	19	45	33	0.3	3.6	0.7	98.9	80.9974	53.019
2015	12	10	19	55	33	0.3	3.6	0.68	100	80.9974	51.5041
2015	12	10	20	5	33	0.3	3.6	0.68	100.3	80.9974	51.5041
2015	12	10	20	15	33	0.3	3.6	0.72	101.6	80.9974	54.2813
2015	12	10	20	25	33	0.3	3.6	0.71	100.4	81.063	53.5692
2015	12	10	20	35	33	0.3	3.6	0.69	100.7	80.9974	52.2615
2015	12	10	20	45	33	0.3	3.6	0.68	99.5	81.063	51.295
2015	12	10	20	55	33	0.3	3.6	0.69	99.6	81.063	52.5584
2015	12	10	21	5	33	0.3	3.6	0.68	100.8	80.9974	51.5041
2015	12	10	21	15	33	0.3	3.6	0.68	100.8	81.063	51.5477
2015	12	10	21	25	33	0.3	3.6	0.74	98.7	81.063	56.096
2015	12	10	21	35	33	0.3	3.6	0.7	102.2	81.063	52.8111

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	10	21	45	33	0.3	3.6	0.7	102.4	81.063	52.8111
2015	12	10	21	55	33	0.3	3.6	0.65	98.1	80.9974	49.7368
2015	12	10	22	5	33	0.3	3.6	0.68	98.6	81.063	52.053
2015	12	10	22	15	33	0.3	3.6	0.71	102.2	81.063	53.8218
2015	12	10	22	25	33	0.3	3.6	0.7	99.4	81.063	53.3164
2015	12	10	22	35	33	0.3	3.6	0.74	100	81.063	55.8433
2015	12	10	22	45	33	0.3	3.6	0.72	99.2	81.063	54.5798
2015	12	10	22	55	33	0.3	3.6	0.74	97.6	81.063	56.6013
2015	12	10	23	5	33	0.3	3.6	0.69	100.4	81.063	52.3057
2015	12	10	23	15	33	0.3	3.6	0.74	98.9	81.1286	56.3963
2015	12	10	23	25	33	0.3	3.6	0.73	99.3	81.1286	55.3847
2015	12	10	23	35	33	0.3	3.6	0.72	99.7	81.063	54.5798
2015	12	10	23	45	33	0.3	3.6	0.7	100.7	81.1286	53.3615
2015	12	10	23	55	33	0.3	3.6	0.71	100.4	81.063	53.8217
2015	12	11	0	5	33	0.3	3.6	0.68	98.6	81.063	51.8003
2015	12	11	0	15	33	0.3	3.6	0.72	98.9	81.1286	54.8789
2015	12	11	0	25	33	0.3	3.6	0.74	98.9	81.1286	56.6491
2015	12	11	0	35	33	0.3	3.6	0.71	101.3	81.1286	53.3615
2015	12	11	0	45	33	0.3	3.6	0.71	100.4	81.1286	53.6143
2015	12	11	0	55	33	0.3	3.6	0.69	100.4	81.1942	52.6472
2015	12	11	1	5	33	0.3	3.6	0.74	97.2	81.1942	56.4439
2015	12	11	1	15	33	0.3	3.6	0.74	99.9	81.1942	56.4439
2015	12	11	1	25	33	0.3	3.6	0.73	97.8	81.1942	55.6845
2015	12	11	1	35	33	0.3	3.6	0.7	101.2	81.1942	52.6472
2015	12	11	1	45	33	0.3	3.6	0.73	99.8	81.2598	55.4782
2015	12	11	1	55	33	0.3	3.6	0.73	99.6	81.1942	55.4314
2015	12	11	2	5	33	0.3	3.6	0.71	101.5	81.2598	53.4516
2015	12	11	2	15	33	0.3	3.6	0.71	100.2	81.1942	53.6597
2015	12	11	2	25	33	0.3	3.6	0.72	98.2	81.1942	54.6721
2015	12	11	2	35	33	0.3	3.6	0.73	100.3	81.2598	55.7316
2015	12	11	2	45	33	0.3	3.6	0.72	101.3	81.2598	54.465
2015	12	11	2	55	33	0.3	3.6	0.7	99.7	81.2598	53.1983
2015	12	11	3	5	33	0.3	3.6	0.69	100.2	81.2598	52.185
2015	12	11	3	15	33	0.3	3.6	0.71	97.2	81.2598	54.465
2015	12	11	3	25	33	0.3	3.6	0.73	99.8	81.2598	55.7316
2015	12	11	3	35	33	0.3	3.6	0.74	101.6	81.2598	55.7316
2015	12	11	3	45	33	0.3	3.6	0.7	98.8	81.3255	53.7503
2015	12	11	3	55	33	0.3	3.6	0.72	99.7	81.2598	54.7183
2015	12	11	4	5	33	0.3	3.6	0.7	100.6	81.3255	52.9897
2015	12	11	4	15	33	0.3	3.6	0.75	99.6	81.3255	56.7928
2015	12	11	4	25	33	0.3	3.6	0.71	102	81.3255	53.7503
2015	12	11	4	35	33	0.3	3.6	0.71	100.2	81.3255	53.7503
2015	12	11	4	45	33	0.3	3.6	0.73	99.5	81.3255	55.7786
2015	12	11	4	55	33	0.3	3.6	0.72	100.2	81.3255	54.7645
2015	12	11	5	5	33	0.3	3.6	0.7	99.1	81.3255	53.7503
2015	12	11	5	15	33	0.3	3.6	0.7	101.8	81.3255	53.2433

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	5	25	33	0.3	3.6	0.71	99.8	81.3255	54.2574
2015	12	11	5	35	33	0.3	3.6	0.72	99.5	81.3255	54.7645
2015	12	11	5	45	33	0.3	3.6	0.72	101.9	81.3255	54.2574
2015	12	11	5	55	33	0.3	3.6	0.71	100.2	81.3255	53.7504
2015	12	11	6	5	33	0.3	3.6	0.67	103.6	81.3255	50.4543
2015	12	11	6	15	33	0.3	3.6	0.75	101.6	81.3255	56.7928
2015	12	11	6	25	33	0.3	3.6	0.71	100.7	81.3255	53.7504
2015	12	11	6	35	33	0.3	3.6	0.69	102.7	81.3255	51.7221
2015	12	11	6	45	33	0.3	3.6	0.68	101.1	81.3255	51.7221
2015	12	11	6	55	33	0.3	3.6	0.72	100.4	81.3255	55.0181
2015	12	11	7	5	33	0.3	3.6	0.73	102.3	81.2598	54.7184
2015	12	11	7	15	33	0.3	3.6	0.71	101.5	81.3255	53.4969
2015	12	11	7	25	33	0.3	3.6	0.71	101.5	81.2598	53.4517
2015	12	11	7	35	33	0.3	3.6	0.71	100.7	81.1286	53.6145
2015	12	11	7	45	33	0.3	3.6	0.7	98.3	81.1942	53.6598
2015	12	11	7	55	33	0.3	3.6	0.7	99.7	81.2598	53.1984
2015	12	11	8	5	33	0.3	3.6	0.72	100.2	81.1942	54.6722
2015	12	11	8	15	33	0.3	3.6	0.71	100.4	81.2598	53.9583
2015	12	11	8	25	33	0.3	3.6	0.69	100.7	81.3255	52.229
2015	12	11	8	35	33	0.3	3.6	0.73	98	81.3255	55.7785
2015	12	11	8	45	33	0.3	3.6	0.73	101.1	81.3255	55.525
2015	12	11	8	55	33	0.3	3.6	0.71	100.7	81.3255	53.7502
2015	12	11	9	5	33	0.3	3.6	0.7	99.7	81.3255	53.2431
2015	12	11	9	15	33	0.3	3.6	0.69	101.3	81.3255	51.9753
2015	12	11	9	25	33	0.3	3.6	0.71	101.4	81.3255	54.0036
2015	12	11	9	35	33	0.3	3.6	0.72	99.4	81.3255	55.2712
2015	12	11	9	45	33	0.3	3.6	0.74	100	81.3255	56.0317
2015	12	11	9	55	33	0.3	3.6	0.72	99.4	81.2598	54.9712
2015	12	11	10	5	33	0.3	3.6	0.75	101.3	81.2598	56.9977
2015	12	11	10	15	33	0.3	3.6	0.71	100.4	81.1942	53.9124
2015	12	11	10	25	33	0.3	3.6	0.71	99.3	81.1942	54.1655
2015	12	11	10	35	33	0.3	3.6	0.73	99	81.1942	55.9373
2015	12	11	10	45	33	0.3	3.6	0.74	101.5	81.1942	55.9373
2015	12	11	10	55	33	0.3	3.6	0.72	100.2	81.1942	54.9248
2015	12	11	11	5	33	0.3	3.6	0.71	100.9	81.1942	53.9122
2015	12	11	11	15	33	0.3	3.6	0.73	101	81.1942	54.9246
2015	12	11	11	25	33	0.3	3.6	0.72	98.9	81.1942	54.6715
2015	12	11	11	35	33	0.3	3.6	0.71	98.2	81.1942	54.4183
2015	12	11	11	45	33	0.3	3.6	0.7	102.5	81.1286	52.3492
2015	12	11	11	55	33	0.3	3.6	0.67	101.5	81.1942	50.8748
2015	12	11	12	5	33	0.3	3.6	0.74	101	81.1942	55.9369
2015	12	11	12	15	33	0.3	3.6	0.72	100.5	81.1942	54.6714
2015	12	11	12	25	33	0.3	3.6	0.67	97.3	81.1286	51.0848
2015	12	11	12	35	33	0.3	3.6	0.71	100.3	81.1286	54.1194
2015	12	11	12	45	33	0.3	3.6	0.68	101.2	81.1286	51.0847
2015	12	11	12	55	33	0.3	3.6	0.7	99.2	81.1286	53.1079

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	13	5	33	0.3	3.6	0.66	97.2	81.1286	50.326
2015	12	11	13	15	33	0.3	3.6	0.69	95.5	81.063	52.8103
2015	12	11	13	25	33	0.3	3.6	0.66	99.2	81.063	50.0308
2015	12	11	13	35	33	0.3	3.6	0.71	96.1	81.063	54.3264
2015	12	11	13	45	33	0.3	3.6	0.7	98.9	81.063	53.3157
2015	12	11	13	55	33	0.3	3.6	0.68	98.9	81.063	51.7996
2015	12	11	14	5	33	0.3	3.6	0.74	96.4	81.063	56.3479
2015	12	11	14	15	33	0.3	3.6	0.72	98.1	81.063	54.8318
2015	12	11	14	25	33	0.3	3.6	0.71	96.1	81.063	54.5791
2015	12	11	14	35	33	0.3	3.6	0.73	96.7	81.063	55.8426
2015	12	11	14	45	33	0.3	3.6	0.73	100.1	81.063	55.5899
2015	12	11	14	55	33	0.3	3.6	0.71	93.2	81.063	54.3265
2015	12	11	15	5	33	0.3	3.6	0.71	97.4	81.063	54.3265
2015	12	11	15	15	33	0.3	3.6	0.75	96.6	81.063	57.106
2015	12	11	15	25	33	0.3	3.6	0.72	99.1	80.9974	55.038
2015	12	11	15	35	33	0.3	3.6	0.71	97.5	80.9974	54.0281
2015	12	11	15	45	33	0.3	3.6	0.69	99.9	80.9974	52.0084
2015	12	11	15	55	33	0.3	3.6	0.66	100	80.9974	49.9887
2015	12	11	16	5	33	0.3	3.6	0.7	99.2	80.9974	53.2708
2015	12	11	16	15	33	0.3	3.6	0.71	98.2	80.9318	54.2347
2015	12	11	16	25	33	0.3	3.6	0.7	97.6	80.9318	52.9734
2015	12	11	16	35	33	0.3	3.6	0.74	97.9	80.9974	56.0479
2015	12	11	16	45	33	0.3	3.6	0.68	93.9	80.9974	52.2609
2015	12	11	16	55	33	0.3	3.6	0.73	99.6	80.9318	55.2437
2015	12	11	17	5	33	0.3	3.6	0.68	97.4	80.9318	52.2166
2015	12	11	17	15	33	0.3	3.6	0.68	97.5	80.9974	52.0084
2015	12	11	17	25	33	0.3	3.6	0.68	102.5	80.9318	51.2076
2015	12	11	17	35	33	0.3	3.6	0.7	97.9	80.9974	53.0183
2015	12	11	17	45	33	0.3	3.6	0.72	98.2	80.9318	54.4869
2015	12	11	17	55	33	0.3	3.6	0.73	100.1	80.9974	55.2905
2015	12	11	18	5	33	0.3	3.6	0.69	99.9	80.9974	52.0084
2015	12	11	18	15	33	0.3	3.6	0.71	99.2	80.9974	54.2806
2015	12	11	18	25	33	0.3	3.6	0.74	99.5	80.9974	55.7954
2015	12	11	18	35	33	0.3	3.6	0.69	99.8	80.9974	52.5133
2015	12	11	18	45	33	0.3	3.6	0.71	99.8	80.9974	54.0281
2015	12	11	18	55	33	0.3	3.6	0.71	100.6	80.9974	54.0281
2015	12	11	19	5	33	0.3	3.6	0.73	101.4	80.9974	55.038
2015	12	11	19	15	33	0.3	3.6	0.71	100.6	80.9974	53.7757
2015	12	11	19	25	33	0.3	3.6	0.72	99.2	80.9974	54.5331
2015	12	11	19	35	33	0.3	3.6	0.71	100.3	80.9974	54.0281
2015	12	11	19	45	33	0.3	3.6	0.68	100.9	80.9974	51.251
2015	12	11	19	55	33	0.3	3.6	0.7	98.4	80.9974	53.0183
2015	12	11	20	5	33	0.3	3.6	0.68	98.8	80.9974	52.0084
2015	12	11	20	15	33	0.3	3.6	0.73	100.1	80.9974	55.038
2015	12	11	20	25	33	0.3	3.6	0.7	98.7	80.9974	53.0183
2015	12	11	20	35	33	0.3	3.6	0.71	100.4	80.9974	53.5233

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	11	20	45	33	0.3	3.6	0.69	99.6	80.9974	52.0085
2015	12	11	20	55	33	0.3	3.6	0.73	101.4	80.9974	55.0381
2015	12	11	21	5	33	0.3	3.6	0.74	100.7	80.9974	56.048
2015	12	11	21	15	33	0.3	3.6	0.67	100.7	80.9974	50.9986
2015	12	11	21	25	33	0.3	3.6	0.73	101.1	80.9974	55.2906
2015	12	11	21	35	33	0.3	3.6	0.7	100.5	80.9974	53.0184
2015	12	11	21	45	33	0.3	3.6	0.7	98.6	80.9974	53.2709
2015	12	11	21	55	33	0.3	3.6	0.71	100.4	80.9974	53.7758
2015	12	11	22	5	33	0.3	3.6	0.74	99	80.9974	56.048
2015	12	11	22	15	33	0.3	3.6	0.71	98.5	80.9974	53.7758
2015	12	11	22	25	33	0.3	3.6	0.7	102.4	80.9974	52.766
2015	12	11	22	35	33	0.3	3.6	0.7	99.2	80.9974	53.2709
2015	12	11	22	45	33	0.3	3.6	0.73	99.6	80.9974	55.2907
2015	12	11	22	55	33	0.3	3.6	0.72	98.9	80.9974	54.5333
2015	12	11	23	5	33	0.3	3.6	0.72	100.3	80.9974	54.2808
2015	12	11	23	15	33	0.3	3.6	0.69	99.6	80.9974	52.2611
2015	12	11	23	25	33	0.3	3.6	0.71	100.4	80.9974	53.5234
2015	12	11	23	35	33	0.3	3.6	0.69	100.6	80.9974	52.5136
2015	12	11	23	45	33	0.3	3.6	0.72	99.7	80.9974	54.5333
2015	12	11	23	55	33	0.3	3.6	0.7	101.8	80.9974	53.0185
2015	12	12	0	5	33	0.3	3.6	0.68	102	80.9974	51.2512
2015	12	12	0	15	33	0.3	3.6	0.71	99.3	80.9974	53.7759
2015	12	12	0	25	33	0.3	3.6	0.71	100.2	80.9974	53.5235
2015	12	12	0	35	33	0.3	3.6	0.71	98.5	80.9974	53.7759
2015	12	12	0	45	33	0.3	3.6	0.73	100.1	80.9974	55.5432
2015	12	12	0	55	33	0.3	3.6	0.75	99.8	80.9974	56.8056
2015	12	12	1	5	33	0.3	3.6	0.76	101.4	80.9974	57.563
2015	12	12	1	15	33	0.3	3.6	0.71	100.4	80.9974	53.776
2015	12	12	1	25	33	0.3	3.6	0.71	99.3	80.9974	53.776
2015	12	12	1	35	33	0.3	3.6	0.72	100	80.9974	54.2809
2015	12	12	1	45	33	0.3	3.6	0.7	99.7	80.9974	53.0186
2015	12	12	1	55	33	0.3	3.6	0.72	102.6	80.9974	54.0285
2015	12	12	2	5	33	0.3	3.6	0.68	100.2	80.9974	51.7563
2015	12	12	2	15	33	0.3	3.6	0.7	98.1	80.9974	53.5236
2015	12	12	2	25	33	0.3	3.6	0.72	101.3	80.9974	54.281
2015	12	12	2	35	33	0.3	3.6	0.73	99.8	80.9974	55.5433
2015	12	12	2	45	33	0.3	3.6	0.7	100.3	80.9974	53.0187
2015	12	12	2	55	33	0.3	3.6	0.75	100.6	80.9974	56.5532
2015	12	12	3	5	33	0.3	3.6	0.74	100.8	80.9974	55.7958
2015	12	12	3	15	33	0.3	3.6	0.72	99.2	80.9974	54.5335
2015	12	12	3	25	33	0.3	3.6	0.72	102.6	80.9974	54.0286
2015	12	12	3	35	33	0.3	3.6	0.7	102.5	80.9974	52.2613
2015	12	12	3	45	33	0.3	3.6	0.7	102.5	80.9974	52.2613
2015	12	12	3	55	33	0.3	3.6	0.71	99.2	80.9974	54.2811
2015	12	12	4	5	33	0.3	3.6	0.71	100.9	80.9974	53.5237
2015	12	12	4	15	33	0.3	3.6	0.74	100.7	80.9974	56.3009

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	4	25	33	0.3	3.6	0.73	98.8	80.9974	55.291
2015	12	12	4	35	33	0.3	3.6	0.74	99.8	80.9974	55.7959
2015	12	12	4	45	33	0.3	3.6	0.74	100.4	80.9974	56.3009
2015	12	12	4	55	33	0.3	3.6	0.73	99	80.9974	55.796
2015	12	12	5	5	33	0.3	3.6	0.71	99.6	81.063	53.5691
2015	12	12	5	15	33	0.3	3.6	0.74	99.8	80.9974	55.796
2015	12	12	5	25	33	0.3	3.6	0.73	100.9	80.9974	55.0386
2015	12	12	5	35	33	0.3	3.6	0.71	101.5	80.9974	53.2713
2015	12	12	5	45	33	0.3	3.6	0.71	100.1	81.063	53.8218
2015	12	12	5	55	33	0.3	3.6	0.72	102	80.9974	54.5337
2015	12	12	6	5	33	0.3	3.6	0.7	101.2	81.063	52.5584
2015	12	12	6	15	33	0.3	3.6	0.75	102.3	80.9974	56.5535
2015	12	12	6	25	33	0.3	3.6	0.71	100.6	80.9974	54.0288
2015	12	12	6	35	33	0.3	3.6	0.73	100.9	81.063	55.338
2015	12	12	6	45	33	0.3	3.6	0.72	101.5	81.063	54.5799
2015	12	12	6	55	33	0.3	3.6	0.73	100.1	80.9974	55.2912
2015	12	12	7	5	33	0.3	3.6	0.7	100.8	81.063	52.8112
2015	12	12	7	15	33	0.3	3.6	0.73	100.9	81.063	55.338
2015	12	12	7	25	33	0.3	3.6	0.71	98.8	81.063	53.8219
2015	12	12	7	35	33	0.3	3.6	0.72	98.6	81.063	55.0853
2015	12	12	7	45	33	0.3	3.6	0.72	99.2	81.063	54.8327
2015	12	12	7	55	33	0.3	3.6	0.69	102.1	81.063	51.8004
2015	12	12	8	5	33	0.3	3.6	0.72	98.9	81.063	54.5799
2015	12	12	8	15	33	0.3	3.6	0.76	99.1	81.063	58.1175
2015	12	12	8	25	33	0.3	3.6	0.7	99.7	81.063	53.0637
2015	12	12	8	35	33	0.3	3.6	0.73	100.1	81.063	55.0852
2015	12	12	8	45	33	0.3	3.6	0.7	99.7	81.1286	53.1085
2015	12	12	8	55	33	0.3	3.6	0.71	100.2	81.1286	53.6143
2015	12	12	9	5	33	0.3	3.6	0.69	102	81.1286	52.3498
2015	12	12	9	15	33	0.3	3.6	0.71	99.8	81.1286	54.12
2015	12	12	9	25	33	0.3	3.6	0.69	100.4	81.1286	52.3497
2015	12	12	9	35	33	0.3	3.6	0.73	96.2	81.1286	55.8902
2015	12	12	9	45	33	0.3	3.6	0.71	99.8	81.1286	54.1199
2015	12	12	9	55	33	0.3	3.6	0.68	99.7	81.1942	51.6345
2015	12	12	10	5	33	0.3	3.6	0.71	96.6	81.1942	54.4187
2015	12	12	10	15	33	0.3	3.6	0.7	99.2	81.1286	53.1082
2015	12	12	10	25	33	0.3	3.6	0.71	99.6	81.1286	53.614
2015	12	12	10	35	33	0.3	3.6	0.71	99.3	81.1286	54.1197
2015	12	12	10	45	33	0.3	3.6	0.73	101	81.1942	54.9248
2015	12	12	10	55	33	0.3	3.6	0.7	95.9	81.1286	53.6139
2015	12	12	11	5	33	0.3	3.6	0.72	99.1	81.1286	55.1313
2015	12	12	11	15	33	0.3	3.6	0.67	99.8	81.1286	51.0849
2015	12	12	11	25	33	0.3	3.6	0.69	99.6	81.1286	52.6023
2015	12	12	11	35	33	0.3	3.6	0.71	100.4	81.1286	53.6139
2015	12	12	11	45	33	0.3	3.6	0.69	100.7	81.1286	52.0965
2015	12	12	11	55	33	0.3	3.6	0.68	100.9	81.1286	51.3378

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	12	5	33	0.3	3.6	0.66	100	81.1286	50.3262
2015	12	12	12	15	33	0.3	3.6	0.72	99.4	81.1286	54.8783
2015	12	12	12	25	33	0.3	3.6	0.68	102	81.1286	51.0849
2015	12	12	12	35	33	0.3	3.6	0.69	99.1	81.1286	52.3494
2015	12	12	12	45	33	0.3	3.6	0.7	99.5	81.1286	52.8552
2015	12	12	12	55	33	0.3	3.6	0.67	103.2	81.1286	50.5792
2015	12	12	13	5	33	0.3	3.6	0.71	100.2	81.063	53.5685
2015	12	12	13	15	33	0.3	3.6	0.68	102	81.063	51.0417
2015	12	12	13	25	33	0.3	3.6	0.7	100.5	81.063	53.0632
2015	12	12	13	35	33	0.3	3.6	0.67	99	81.063	51.0417
2015	12	12	13	45	33	0.3	3.6	0.66	98	81.063	50.031
2015	12	12	13	55	33	0.3	3.6	0.69	98.4	81.1286	52.8552
2015	12	12	14	5	33	0.3	3.6	0.7	98.4	81.1286	53.1081
2015	12	12	14	15	33	0.3	3.6	0.72	98.9	81.063	54.832
2015	12	12	14	25	33	0.3	3.6	0.73	100.6	81.1286	55.637
2015	12	12	14	35	33	0.3	3.6	0.7	100.3	81.1286	52.8552
2015	12	12	14	45	33	0.3	3.6	0.71	99.8	81.1942	54.1655
2015	12	12	14	55	33	0.3	3.6	0.7	100.3	81.063	52.8108
2015	12	12	15	5	33	0.3	3.6	0.69	101.5	81.063	52.0527
2015	12	12	15	15	33	0.3	3.6	0.68	98.6	80.9974	52.0087
2015	12	12	15	25	33	0.3	3.6	0.7	102.5	80.9974	52.2612
2015	12	12	15	35	33	0.3	3.6	0.68	105.2	80.9974	50.2414
2015	12	12	15	45	33	0.3	3.6	0.67	101.9	80.9974	50.4939
2015	12	12	15	55	33	0.3	3.6	0.7	102.5	80.9974	52.5136
2015	12	12	16	5	33	0.3	3.6	0.67	104.5	80.9974	49.7365
2015	12	12	16	15	33	0.3	3.6	0.66	102.9	80.9974	49.7365
2015	12	12	16	25	33	0.3	3.6	0.67	105.7	80.9974	49.484
2015	12	12	16	35	33	0.3	3.6	0.7	106.6	80.9318	51.7124
2015	12	12	16	45	33	0.3	3.6	0.66	103.4	80.9318	49.6943
2015	12	12	16	55	33	0.3	3.6	0.67	104.2	80.9318	49.6943
2015	12	12	17	5	33	0.3	3.6	0.67	105	80.9318	49.9466
2015	12	12	17	15	33	0.3	3.6	0.67	104.8	80.9318	49.6943
2015	12	12	17	25	33	0.3	3.6	0.66	105.1	80.9318	48.6853
2015	12	12	17	35	33	0.3	3.6	0.67	106.8	80.9318	49.1898
2015	12	12	17	45	33	0.3	3.6	0.64	103.9	80.9318	47.9285
2015	12	12	17	55	33	0.3	3.6	0.68	104.8	80.9318	50.7033
2015	12	12	18	5	33	0.3	3.6	0.67	102.2	80.9318	50.1988
2015	12	12	18	15	33	0.3	3.6	0.64	105.2	80.9318	47.424
2015	12	12	18	25	33	0.3	3.6	0.67	105.3	80.9318	49.6943
2015	12	12	18	35	33	0.3	3.6	0.67	103.3	80.9318	50.1988
2015	12	12	18	45	33	0.3	3.6	0.66	106.5	80.9318	48.6853
2015	12	12	18	55	33	0.3	3.6	0.67	103.5	80.9318	50.4511
2015	12	12	19	5	33	0.3	3.6	0.67	104.5	80.9318	49.6943
2015	12	12	19	15	33	0.3	3.6	0.68	107.7	80.9318	49.9466
2015	12	12	19	25	33	0.3	3.6	0.66	107.1	80.9318	48.4331
2015	12	12	19	35	33	0.3	3.6	0.69	104.3	80.9318	51.4601

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	12	19	45	33	0.3	3.6	0.64	107.4	80.9318	46.6673
2015	12	12	19	55	33	0.3	3.6	0.64	107.7	80.9318	46.6673
2015	12	12	20	5	33	0.3	3.6	0.65	106.8	80.9318	47.6763
2015	12	12	20	15	33	0.3	3.6	0.64	108.6	80.9318	46.415
2015	12	12	20	25	33	0.3	3.6	0.66	109	80.9318	47.6763
2015	12	12	20	35	33	0.3	3.6	0.66	106	80.9318	48.4331
2015	12	12	20	45	33	0.3	3.6	0.73	103.6	80.9318	54.235
2015	12	12	20	55	33	0.3	3.6	0.76	100.4	80.9318	57.5143
2015	12	12	21	5	33	0.3	3.6	0.69	100.7	80.9318	52.2169
2015	12	12	21	15	33	0.3	3.6	0.69	98.2	80.9318	52.217
2015	12	12	21	25	33	0.3	3.6	0.71	99.3	80.9318	53.9828
2015	12	12	21	35	33	0.3	3.6	0.72	100.3	80.9318	54.235
2015	12	12	21	45	33	0.3	3.6	0.7	100	80.9318	52.7215
2015	12	12	21	55	33	0.3	3.6	0.66	100.9	80.9318	49.6944
2015	12	12	22	5	33	0.3	3.6	0.67	101	80.9318	50.4512
2015	12	12	22	15	33	0.3	3.6	0.71	99.6	80.9318	53.4783
2015	12	12	22	25	33	0.3	3.6	0.69	102.1	80.9318	51.7125
2015	12	12	22	35	33	0.3	3.6	0.7	101.9	80.9318	52.7215
2015	12	12	22	45	33	0.3	3.6	0.7	100.3	80.9318	52.7215
2015	12	12	22	55	33	0.3	3.6	0.69	100.2	80.9318	51.9648
2015	12	12	23	5	33	0.3	3.6	0.66	100.9	80.9318	49.6945
2015	12	12	23	15	33	0.3	3.6	0.71	100.9	80.9318	53.4783
2015	12	12	23	25	33	0.3	3.6	0.66	100.1	80.9318	49.6945
2015	12	12	23	35	33	0.3	3.6	0.66	100	80.9318	49.9467
2015	12	12	23	45	33	0.3	3.6	0.71	99.3	80.9318	53.9828
2015	12	12	23	55	33	0.3	3.6	0.69	101	80.9318	51.7125
2015	12	13	0	5	33	0.3	3.6	0.72	100.7	80.9318	54.4874
2015	12	13	0	15	33	0.3	3.6	0.71	100.2	80.9318	53.4783
2015	12	13	0	25	33	0.3	3.6	0.67	103.4	80.9318	49.9468
2015	12	13	0	35	33	0.3	3.6	0.73	99.8	80.9318	55.4964
2015	12	13	0	45	33	0.3	3.6	0.71	100.4	80.9318	53.4784
2015	12	13	0	55	33	0.3	3.6	0.72	103.4	80.9318	53.9829
2015	12	13	1	5	33	0.3	3.6	0.71	102.4	80.9318	52.9739
2015	12	13	1	15	33	0.3	3.6	0.71	101.5	80.9974	53.5237
2015	12	13	1	25	33	0.3	3.6	0.67	100.4	80.9318	50.7036
2015	12	13	1	35	33	0.3	3.6	0.68	99.7	80.9974	51.7564
2015	12	13	1	45	33	0.3	3.6	0.68	103.2	80.9974	50.7466
2015	12	13	1	55	33	0.3	3.6	0.68	102.5	80.9974	51.2515
2015	12	13	2	5	33	0.3	3.6	0.72	100.2	80.9974	54.5337
2015	12	13	2	15	33	0.3	3.6	0.7	101.7	80.9974	52.5139
2015	12	13	2	25	33	0.3	3.6	0.69	99.9	80.9974	52.2614
2015	12	13	2	35	33	0.3	3.6	0.69	100.7	80.9318	51.965
2015	12	13	2	45	33	0.3	3.6	0.66	101.8	80.9974	49.7368
2015	12	13	2	55	33	0.3	3.6	0.68	101.9	80.9974	51.5041
2015	12	13	3	5	33	0.3	3.6	0.69	102.4	80.9974	51.5041
2015	12	13	3	15	33	0.3	3.6	0.69	101.3	80.9974	51.7566

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	3	25	33	0.3	3.6	0.7	103.3	80.9974	52.2615
2015	12	13	3	35	33	0.3	3.6	0.68	100.5	80.9974	51.7566
2015	12	13	3	45	33	0.3	3.6	0.72	102.8	80.9974	54.2813
2015	12	13	3	55	33	0.3	3.6	0.68	101.5	80.9974	50.9992
2015	12	13	4	5	33	0.3	3.6	0.66	103	80.9974	49.2319
2015	12	13	4	15	33	0.3	3.6	0.68	98.8	80.9974	52.0092
2015	12	13	4	25	33	0.3	3.6	0.7	102.2	80.9974	52.7666
2015	12	13	4	35	33	0.3	3.6	0.69	100.6	80.9974	52.5141
2015	12	13	4	45	33	0.3	3.6	0.69	99.6	80.9974	52.0092
2015	12	13	4	55	33	0.3	3.6	0.68	100	80.9974	51.7567
2015	12	13	5	5	33	0.3	3.6	0.68	100.8	80.9974	51.5043
2015	12	13	5	15	33	0.3	3.6	0.69	102.6	80.9974	51.7568
2015	12	13	5	25	33	0.3	3.6	0.67	103.3	80.9974	50.242
2015	12	13	5	35	33	0.3	3.6	0.68	99.5	80.9974	51.2519
2015	12	13	5	45	33	0.3	3.6	0.73	102.2	80.9974	55.039
2015	12	13	5	55	33	0.3	3.6	0.71	103.1	80.9974	53.0192
2015	12	13	6	5	33	0.3	3.6	0.74	101.3	80.9974	55.7964
2015	12	13	6	15	33	0.3	3.6	0.7	102.5	80.9974	52.2618
2015	12	13	6	25	33	0.3	3.6	0.68	102.3	81.063	51.0426
2015	12	13	6	35	33	0.3	3.6	0.73	100.9	81.063	55.3383
2015	12	13	6	45	33	0.3	3.6	0.71	100.6	81.063	54.0749
2015	12	13	6	55	33	0.3	3.6	0.72	101.1	81.063	54.0749
2015	12	13	7	5	33	0.3	3.6	0.71	101.7	81.1286	53.8678
2015	12	13	7	15	33	0.3	3.6	0.72	100.5	81.1286	54.3736
2015	12	13	7	25	33	0.3	3.6	0.65	99.3	81.1286	49.5685
2015	12	13	7	35	33	0.3	3.6	0.66	100.5	81.1942	50.3697
2015	12	13	7	45	33	0.3	3.6	0.69	99.9	81.1286	52.0975
2015	12	13	7	55	33	0.3	3.6	0.7	100.3	81.1942	53.154
2015	12	13	8	5	33	0.3	3.6	0.71	99.3	81.1942	54.1664
2015	12	13	8	15	33	0.3	3.6	0.72	98.9	81.1942	55.1788
2015	12	13	8	25	33	0.3	3.6	0.69	100.6	81.1942	52.6477
2015	12	13	8	35	33	0.3	3.6	0.68	99.5	81.1942	51.3821
2015	12	13	8	45	33	0.3	3.6	0.66	98.6	81.2598	50.4121
2015	12	13	8	55	33	0.3	3.6	0.69	100.2	81.2598	52.1854
2015	12	13	9	5	33	0.3	3.6	0.71	100.4	81.1942	53.9131
2015	12	13	9	15	33	0.3	3.6	0.66	99.2	81.2598	50.1587
2015	12	13	9	25	33	0.3	3.6	0.67	101.3	81.2598	50.9186
2015	12	13	9	35	33	0.3	3.6	0.68	98.9	81.1942	51.635
2015	12	13	9	45	33	0.3	3.6	0.68	100.5	81.2598	51.9319
2015	12	13	9	55	33	0.3	3.6	0.69	99.3	81.2598	52.6919
2015	12	13	10	5	33	0.3	3.6	0.71	100.1	81.2598	54.2118
2015	12	13	10	15	33	0.3	3.6	0.68	100.8	81.2598	51.6785
2015	12	13	10	25	33	0.3	3.6	0.72	96.3	81.1942	54.9254
2015	12	13	10	35	33	0.3	3.6	0.72	98.2	81.2598	54.7184
2015	12	13	10	45	33	0.3	3.6	0.69	99.6	81.2598	52.4385
2015	12	13	10	55	33	0.3	3.6	0.68	101.4	81.2598	51.6785

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	11	5	33	0.3	3.6	0.69	100.6	81.2598	52.6917
2015	12	13	11	15	33	0.3	3.6	0.69	100.7	81.2598	52.1851
2015	12	13	11	25	33	0.3	3.6	0.67	99.9	81.1286	50.5796
2015	12	13	11	35	33	0.3	3.6	0.71	100.2	81.1942	53.6597
2015	12	13	11	45	33	0.3	3.6	0.69	98.5	81.1942	52.6473
2015	12	13	11	55	33	0.3	3.6	0.68	102.3	81.2598	50.9184
2015	12	13	12	5	33	0.3	3.6	0.67	99.9	81.2598	50.9184
2015	12	13	12	15	33	0.3	3.6	0.65	98.5	81.1286	49.3151
2015	12	13	12	25	33	0.3	3.6	0.65	98.7	81.1286	49.568
2015	12	13	12	35	33	0.3	3.6	0.7	99.5	81.1286	52.8557
2015	12	13	12	45	33	0.3	3.6	0.67	99.4	81.1286	50.5797
2015	12	13	12	55	33	0.3	3.6	0.68	98.1	81.063	51.5477
2015	12	13	13	5	33	0.3	3.6	0.64	97.7	81.1286	48.5566
2015	12	13	13	15	33	0.3	3.6	0.69	99.8	81.1286	52.603
2015	12	13	13	25	33	0.3	3.6	0.66	95.4	81.1286	50.5798
2015	12	13	13	35	33	0.3	3.6	0.66	98.3	81.063	50.5371
2015	12	13	13	45	33	0.3	3.6	0.68	98.8	81.063	52.0532
2015	12	13	13	55	33	0.3	3.6	0.66	99.4	81.063	50.2844
2015	12	13	14	5	33	0.3	3.6	0.72	100.8	81.063	54.3274
2015	12	13	14	15	33	0.3	3.6	0.67	100.4	81.063	50.7898
2015	12	13	14	25	33	0.3	3.6	0.7	96.2	81.063	53.3166
2015	12	13	14	35	33	0.3	3.6	0.65	96.7	81.063	49.779
2015	12	13	14	45	33	0.3	3.6	0.69	97.1	81.1286	52.603
2015	12	13	14	55	33	0.3	3.6	0.66	98.5	81.063	50.5371
2015	12	13	15	5	33	0.3	3.6	0.67	97.7	81.063	50.7897
2015	12	13	15	15	33	0.3	3.6	0.69	98.7	81.063	52.8112
2015	12	13	15	25	33	0.3	3.6	0.68	98.6	81.1286	52.0972
2015	12	13	15	35	33	0.3	3.6	0.69	100.2	81.063	52.0531
2015	12	13	15	45	33	0.3	3.6	0.68	99.5	81.063	51.5478
2015	12	13	15	55	33	0.3	3.6	0.68	97.5	81.063	51.5477
2015	12	13	16	5	33	0.3	3.6	0.66	98.8	81.1286	50.5797
2015	12	13	16	15	33	0.3	3.6	0.71	100.1	81.1286	53.8674
2015	12	13	16	25	33	0.3	3.6	0.72	102.4	81.2598	53.9584
2015	12	13	16	35	33	0.3	3.6	0.72	101	81.3255	54.7645
2015	12	13	16	45	33	0.3	3.6	0.67	98.1	81.3255	51.4685
2015	12	13	16	55	33	0.3	3.6	0.71	100.9	81.3255	54.0039
2015	12	13	17	5	33	0.3	3.6	0.69	100.4	81.1286	52.3499
2015	12	13	17	15	33	0.3	3.6	0.72	97.9	81.2598	54.9717
2015	12	13	17	25	33	0.3	3.6	0.68	100.9	81.3255	51.4685
2015	12	13	17	35	33	0.3	3.6	0.71	100.2	81.2598	53.705
2015	12	13	17	45	33	0.3	3.6	0.7	98.4	81.2598	53.1984
2015	12	13	17	55	33	0.3	3.6	0.72	100.7	81.2598	54.7183
2015	12	13	18	5	33	0.3	3.6	0.69	99.2	81.1942	52.9003
2015	12	13	18	15	33	0.3	3.6	0.72	99.5	81.1942	54.6721
2015	12	13	18	25	33	0.3	3.6	0.68	101.6	81.1942	51.6348
2015	12	13	18	35	33	0.3	3.6	0.76	99.5	81.3255	57.8069

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	13	18	45	33	0.3	3.6	0.72	97.6	81.2598	54.9716
2015	12	13	18	55	33	0.3	3.6	0.7	101.8	81.3911	53.2881
2015	12	13	19	5	33	0.3	3.6	0.7	98.4	81.3911	53.2881
2015	12	13	19	15	33	0.3	3.6	0.74	98.4	81.3255	56.7927
2015	12	13	19	25	33	0.3	3.6	0.67	99.9	81.3911	50.7505
2015	12	13	19	35	33	0.3	3.6	0.71	99	81.3911	54.3031
2015	12	13	19	45	33	0.3	3.6	0.71	98.7	81.1942	54.419
2015	12	13	19	55	33	0.3	3.6	0.7	98.9	81.3911	53.2881
2015	12	13	20	5	33	0.3	3.6	0.7	100	81.3911	53.0343
2015	12	13	20	15	33	0.3	3.6	0.68	98.6	81.3255	52.229
2015	12	13	20	25	33	0.3	3.6	0.72	99.4	81.3911	55.3181
2015	12	13	20	35	33	0.3	3.6	0.7	97.3	81.3255	53.7503
2015	12	13	20	45	33	0.3	3.6	0.71	98.3	81.3911	54.0493
2015	12	13	20	55	33	0.3	3.6	0.74	101.5	81.4567	56.3805
2015	12	13	21	5	33	0.3	3.6	0.76	100.4	81.4567	57.9043
2015	12	13	21	15	33	0.3	3.6	0.73	99	81.4567	56.1266
2015	12	13	21	25	33	0.3	3.6	0.71	102.2	81.4567	53.8409
2015	12	13	21	35	33	0.3	3.6	0.74	102	81.4567	56.1266
2015	12	13	21	45	33	0.3	3.6	0.71	100.6	81.4567	54.3488
2015	12	13	21	55	33	0.3	3.6	0.71	100.9	81.4567	53.8409
2015	12	13	22	5	33	0.3	3.6	0.73	101	81.4567	55.1107
2015	12	13	22	15	33	0.3	3.6	0.75	100.1	81.4567	56.8885
2015	12	13	22	25	33	0.3	3.6	0.7	97.6	81.5223	53.3778
2015	12	13	22	35	33	0.3	3.6	0.72	103	81.5223	54.1404
2015	12	13	22	45	33	0.3	3.6	0.67	99.3	81.5223	51.3444
2015	12	13	22	55	33	0.3	3.6	0.69	97.3	81.5223	53.3778
2015	12	13	23	5	33	0.3	3.6	0.69	98.2	81.5223	53.1237
2015	12	13	23	15	33	0.3	3.6	0.7	98.6	81.5223	53.632
2015	12	13	23	25	33	0.3	3.6	0.74	100.5	81.5223	56.1738
2015	12	13	23	35	33	0.3	3.6	0.71	99.8	81.5223	54.3946
2015	12	13	23	45	33	0.3	3.6	0.69	98.7	81.5223	52.8695
2015	12	13	23	55	33	0.3	3.6	0.71	99.9	81.5223	53.8862
2015	12	14	0	5	33	0.3	3.6	0.72	97.3	81.5223	55.6655
2015	12	14	0	15	33	0.3	3.6	0.71	99.3	81.5223	54.1404
2015	12	14	0	25	33	0.3	3.6	0.68	97.8	81.5223	51.8528
2015	12	14	0	35	33	0.3	3.6	0.69	100.6	81.5223	52.8695
2015	12	14	0	45	33	0.3	3.6	0.68	98.8	81.5223	52.3612
2015	12	14	0	55	33	0.3	3.6	0.7	98.8	81.5879	53.9316
2015	12	14	1	5	33	0.3	3.6	0.7	97.3	81.5223	53.6321
2015	12	14	1	15	33	0.3	3.6	0.7	100.5	81.5223	53.3779
2015	12	14	1	25	33	0.3	3.6	0.7	98.1	81.5223	53.3779
2015	12	14	1	35	33	0.3	3.6	0.68	100.8	81.5223	51.8528
2015	12	14	1	45	33	0.3	3.6	0.66	97.2	81.5223	50.5819
2015	12	14	1	55	33	0.3	3.6	0.72	100	81.5879	54.9492
2015	12	14	2	5	33	0.3	3.6	0.68	99.7	81.5879	52.1508
2015	12	14	2	15	33	0.3	3.6	0.71	101.3	81.5879	53.6772

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	2	25	33	0.3	3.6	0.73	96.5	81.5223	56.1739
2015	12	14	2	35	33	0.3	3.6	0.69	97.9	81.5223	52.8696
2015	12	14	2	45	33	0.3	3.6	0.7	95.9	81.5223	54.1405
2015	12	14	2	55	33	0.3	3.6	0.7	98.4	81.5879	53.6773
2015	12	14	3	5	33	0.3	3.6	0.72	99.2	81.5879	54.9492
2015	12	14	3	15	33	0.3	3.6	0.74	97.7	81.5879	56.73
2015	12	14	3	25	33	0.3	3.6	0.7	99.1	81.5879	53.9317
2015	12	14	3	35	33	0.3	3.6	0.72	97.9	81.5879	54.9493
2015	12	14	3	45	33	0.3	3.6	0.68	96.1	81.5879	52.6597
2015	12	14	3	55	33	0.3	3.6	0.67	100.4	81.5879	51.1334
2015	12	14	4	5	33	0.3	3.6	0.73	96.9	81.5879	56.4757
2015	12	14	4	15	33	0.3	3.6	0.69	98.5	81.5879	52.9142
2015	12	14	4	25	33	0.3	3.6	0.69	99.2	81.5879	53.1685
2015	12	14	4	35	33	0.3	3.6	0.68	99.7	81.5879	52.151
2015	12	14	4	45	33	0.3	3.6	0.66	98	81.5879	50.879
2015	12	14	4	55	33	0.3	3.6	0.64	98.8	81.5879	49.3527
2015	12	14	5	5	33	0.3	3.6	0.67	98.7	81.5879	51.6422
2015	12	14	5	15	33	0.3	3.6	0.67	99.3	81.5879	51.3878
2015	12	14	5	25	33	0.3	3.6	0.72	98.9	81.6535	55.2502
2015	12	14	5	35	33	0.3	3.6	0.68	97	81.6535	52.1949
2015	12	14	5	45	33	0.3	3.6	0.69	100.6	81.5879	52.9142
2015	12	14	5	55	33	0.3	3.6	0.7	97.5	81.5879	54.1862
2015	12	14	6	5	33	0.3	3.6	0.69	99.3	81.5879	52.9143
2015	12	14	6	15	33	0.3	3.6	0.68	100.1	81.5879	51.6423
2015	12	14	6	25	33	0.3	3.6	0.68	100.3	81.6535	51.9403
2015	12	14	6	35	33	0.3	3.6	0.66	100.1	81.6535	50.1581
2015	12	14	6	45	33	0.3	3.6	0.66	98.3	81.5879	50.3704
2015	12	14	6	55	33	0.3	3.6	0.71	99.2	81.5879	54.6951
2015	12	14	7	5	33	0.3	3.6	0.69	96.3	81.5879	53.1687
2015	12	14	7	15	33	0.3	3.6	0.71	99.8	81.5879	54.4407
2015	12	14	7	25	33	0.3	3.6	0.67	97.1	81.5879	51.388
2015	12	14	7	35	33	0.3	3.6	0.68	98.6	81.5879	51.8968
2015	12	14	7	45	33	0.3	3.6	0.68	100	81.5879	52.1511
2015	12	14	7	55	33	0.3	3.6	0.7	96.7	81.5879	54.1863
2015	12	14	8	5	33	0.3	3.6	0.7	98.1	81.5879	53.4231
2015	12	14	8	15	33	0.3	3.6	0.66	96.8	81.5879	51.1335
2015	12	14	8	25	33	0.3	3.6	0.71	97.4	81.5879	54.9494
2015	12	14	8	35	33	0.3	3.6	0.69	96	81.5879	53.423
2015	12	14	8	45	33	0.3	3.6	0.7	98.1	81.6535	53.7225
2015	12	14	8	55	33	0.3	3.6	0.71	98.5	81.6535	54.7409
2015	12	14	9	5	33	0.3	3.6	0.69	97.9	81.6535	52.9586
2015	12	14	9	15	33	0.3	3.6	0.72	97.3	81.6535	55.5047
2015	12	14	9	25	33	0.3	3.6	0.67	97.3	81.6535	51.6855
2015	12	14	9	35	33	0.3	3.6	0.69	100.7	81.6535	52.7039
2015	12	14	9	45	33	0.3	3.6	0.75	97.6	81.6535	57.5415
2015	12	14	9	55	33	0.3	3.6	0.73	98.3	81.7192	56.0608

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	10	5	33	0.3	3.6	0.71	97.2	81.7192	54.5319
2015	12	14	10	15	33	0.3	3.6	0.7	97.8	81.7192	53.7673
2015	12	14	10	25	33	0.3	3.6	0.72	99.1	81.7192	55.5511
2015	12	14	10	35	33	0.3	3.6	0.71	97.9	81.7192	54.7866
2015	12	14	10	45	33	0.3	3.6	0.72	98.9	81.7192	55.0414
2015	12	14	10	55	33	0.3	3.6	0.71	98.8	81.7848	54.3225
2015	12	14	11	5	33	0.3	3.6	0.68	95.8	81.7192	52.2384
2015	12	14	11	15	33	0.3	3.6	0.71	97.9	81.7848	54.8325
2015	12	14	11	25	33	0.3	3.6	0.73	99.9	81.7192	55.551
2015	12	14	11	35	33	0.3	3.6	0.7	98.4	81.7848	53.8123
2015	12	14	11	45	33	0.3	3.6	0.72	97.4	81.7192	55.2961
2015	12	14	11	55	33	0.3	3.6	0.68	96.6	81.7848	52.5372
2015	12	14	12	5	33	0.3	3.6	0.73	96.7	81.7192	56.5702
2015	12	14	12	15	33	0.3	3.6	0.71	96.4	81.7848	54.5774
2015	12	14	12	25	33	0.3	3.6	0.7	98.1	81.7848	53.5573
2015	12	14	12	35	33	0.3	3.6	0.66	97.7	81.7848	51.0069
2015	12	14	12	45	33	0.3	3.6	0.67	97.7	81.7848	51.262
2015	12	14	12	55	33	0.3	3.6	0.72	97.6	81.7848	55.0875
2015	12	14	13	5	33	0.3	3.6	0.7	97	81.7848	53.8123
2015	12	14	13	15	33	0.3	3.6	0.69	97.9	81.7192	53.2576
2015	12	14	13	25	33	0.3	3.6	0.69	96.3	81.7848	53.3023
2015	12	14	13	35	33	0.3	3.6	0.7	99.2	81.7192	53.7673
2015	12	14	13	45	33	0.3	3.6	0.69	97.7	81.7192	52.7481
2015	12	14	13	55	33	0.3	3.6	0.66	98	81.7192	50.7095
2015	12	14	14	5	33	0.3	3.6	0.69	97.7	81.7192	52.7481
2015	12	14	14	15	33	0.3	3.6	0.69	97.9	81.7192	53.2577
2015	12	14	14	25	33	0.3	3.6	0.75	96.5	81.7192	57.8445
2015	12	14	14	35	33	0.3	3.6	0.68	96.4	81.7192	52.4932
2015	12	14	14	45	33	0.3	3.6	0.72	97.9	81.7192	55.2963
2015	12	14	14	55	33	0.3	3.6	0.7	96.2	81.7192	54.0222
2015	12	14	15	5	33	0.3	3.6	0.65	98.4	81.7192	49.9451
2015	12	14	15	15	33	0.3	3.6	0.72	97.1	81.6535	55.25
2015	12	14	15	25	33	0.3	3.6	0.69	96.3	81.6535	52.9585
2015	12	14	15	35	33	0.3	3.6	0.69	98.5	81.7192	52.7482
2015	12	14	15	45	33	0.3	3.6	0.71	96.9	81.7192	55.0416
2015	12	14	15	55	33	0.3	3.6	0.69	98.5	81.6535	52.9585
2015	12	14	16	5	33	0.3	3.6	0.7	97.3	81.6535	53.7224
2015	12	14	16	15	33	0.3	3.6	0.68	99.4	81.6535	52.4493
2015	12	14	16	25	33	0.3	3.6	0.68	99.8	81.6535	51.6855
2015	12	14	16	35	33	0.3	3.6	0.71	97.7	81.6535	54.4862
2015	12	14	16	45	33	0.3	3.6	0.68	99.5	81.7192	51.9837
2015	12	14	16	55	33	0.3	3.6	0.68	97.5	81.6535	52.1947
2015	12	14	17	5	33	0.3	3.6	0.69	97.3	81.6535	53.4678
2015	12	14	17	15	33	0.3	3.6	0.66	98	81.6535	50.9217
2015	12	14	17	25	33	0.3	3.6	0.69	96.3	81.6535	52.9586
2015	12	14	17	35	33	0.3	3.6	0.71	96.3	81.6535	54.9954

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	14	17	45	33	0.3	3.6	0.66	95.4	81.7192	50.9644
2015	12	14	17	55	33	0.3	3.6	0.7	98.3	81.7192	54.0223
2015	12	14	18	5	33	0.3	3.6	0.66	97.4	81.6535	51.1763
2015	12	14	18	15	33	0.3	3.6	0.69	97.4	81.6535	52.9586
2015	12	14	18	25	33	0.3	3.6	0.68	97.2	81.7192	52.4934
2015	12	14	18	35	33	0.3	3.6	0.67	101.1	81.7192	50.7096
2015	12	14	18	45	33	0.3	3.6	0.66	96.6	81.6535	50.9217
2015	12	14	18	55	33	0.3	3.6	0.71	96.6	81.7192	54.7868
2015	12	14	19	5	33	0.3	3.6	0.66	98	81.7192	50.9645
2015	12	14	19	15	33	0.3	3.6	0.67	96.7	81.7192	51.729
2015	12	14	19	25	33	0.3	3.6	0.67	98.8	81.7192	51.2193
2015	12	14	19	35	33	0.3	3.6	0.69	96.6	81.7192	53.0031
2015	12	14	19	45	33	0.3	3.6	0.69	97.9	81.7192	53.0031
2015	12	14	19	55	33	0.3	3.6	0.67	96.5	81.7192	51.4742
2015	12	14	20	5	33	0.3	3.6	0.7	97	81.7848	54.0677
2015	12	14	20	15	33	0.3	3.6	0.7	99.4	81.7192	53.7676
2015	12	14	20	25	33	0.3	3.6	0.69	97.7	81.7192	53.0032
2015	12	14	20	35	33	0.3	3.6	0.69	100.9	81.7192	52.7483
2015	12	14	20	45	33	0.3	3.6	0.66	97.7	81.7192	50.9646
2015	12	14	20	55	33	0.3	3.6	0.68	100.8	81.7192	51.9839
2015	12	14	21	5	33	0.3	3.6	0.68	98.6	81.7192	52.2387
2015	12	14	21	15	33	0.3	3.6	0.7	98.6	81.7848	54.0678
2015	12	14	21	25	33	0.3	3.6	0.67	96.4	81.7192	51.9839
2015	12	14	21	35	33	0.3	3.6	0.67	101	81.7848	51.0074
2015	12	14	21	45	33	0.3	3.6	0.71	99.2	81.7848	54.8329
2015	12	14	21	55	33	0.3	3.6	0.66	100.1	81.7848	50.2423
2015	12	14	22	5	33	0.3	3.6	0.7	100.5	81.7192	53.5129
2015	12	14	22	15	33	0.3	3.6	0.67	99.8	81.7848	51.5175
2015	12	14	22	25	33	0.3	3.6	0.7	100.5	81.7848	53.8128
2015	12	14	22	35	33	0.3	3.6	0.7	100.7	81.7848	53.8128
2015	12	14	22	45	33	0.3	3.6	0.72	99.5	81.7848	54.833
2015	12	14	22	55	33	0.3	3.9	0.72	100	81.7848	54.833
2015	12	14	23	5	33	0.3	3.6	0.68	99.4	81.7848	52.5377
2015	12	14	23	15	33	0.3	3.9	0.7	99.5	81.7848	53.3028
2015	12	14	23	25	33	0.3	3.6	0.68	99.4	81.7848	52.5377
2015	12	14	23	35	33	0.3	3.9	0.67	97.6	81.8504	51.816
2015	12	14	23	45	33	0.3	3.9	0.7	101.3	81.8504	53.6028
2015	12	14	23	55	33	0.3	3.9	0.73	100.1	81.8504	55.9
2015	12	15	0	5	33	0.3	3.9	0.68	97.4	81.916	52.8813
2015	12	15	0	15	33	0.3	3.9	0.7	99.4	81.916	53.9031
2015	12	15	0	25	33	0.3	3.9	0.7	100.3	81.916	53.6477
2015	12	15	0	35	33	0.3	3.9	0.69	100.6	81.916	53.1368
2015	12	15	0	45	33	0.3	3.9	0.69	100.4	81.916	53.1368
2015	12	15	0	55	33	0.3	3.9	0.76	100.7	81.9816	58.2948
2015	12	15	1	5	33	0.3	3.9	0.7	100.3	81.8504	53.6028
2015	12	15	1	15	33	0.3	3.9	0.71	98.8	81.916	54.6696

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	1	25	33	0.3	3.9	0.67	98.4	81.916	51.604
2015	12	15	1	35	33	0.3	3.9	0.69	101.3	81.9816	52.6699
2015	12	15	1	45	33	0.3	3.9	0.68	100.3	81.9816	51.9029
2015	12	15	1	55	33	0.3	3.9	0.71	100.1	81.9816	54.7154
2015	12	15	2	5	33	0.3	3.9	0.72	99.1	81.9816	55.7381
2015	12	15	2	15	33	0.3	3.9	0.69	100.7	81.916	52.8814
2015	12	15	2	25	33	0.3	3.9	0.69	98.8	81.9816	52.9256
2015	12	15	2	35	33	0.3	3.9	0.68	97.8	81.9816	52.4143
2015	12	15	2	45	33	0.3	3.9	0.66	99.5	81.9816	50.3689
2015	12	15	2	55	33	0.3	3.9	0.69	100.7	81.9816	52.9257
2015	12	15	3	5	33	0.3	3.9	0.71	98.5	81.9816	54.7154
2015	12	15	3	15	33	0.3	3.9	0.67	99.2	81.9816	51.903
2015	12	15	3	25	33	0.3	3.9	0.66	100.1	81.9816	50.3689
2015	12	15	3	35	33	0.3	3.9	0.69	100.2	81.9816	52.67
2015	12	15	3	45	33	0.3	3.9	0.7	100.3	82.0472	53.7376
2015	12	15	3	55	33	0.3	3.9	0.7	99.4	82.0472	54.2494
2015	12	15	4	5	33	0.3	3.9	0.69	100.1	82.0472	52.97
2015	12	15	4	15	33	0.3	3.9	0.7	102.2	82.0472	53.4818
2015	12	15	4	25	33	0.3	3.9	0.67	97.6	82.0472	51.6905
2015	12	15	4	35	33	0.3	3.9	0.66	101.1	82.0472	50.667
2015	12	15	4	45	33	0.3	3.9	0.72	99.2	82.0472	55.529
2015	12	15	4	55	33	0.3	3.9	0.7	97.6	82.0472	53.7377
2015	12	15	5	5	33	0.3	3.9	0.69	99.6	82.0472	52.97
2015	12	15	5	15	33	0.3	3.9	0.7	99.2	82.0472	53.7377
2015	12	15	5	25	33	0.3	3.9	0.65	99.6	82.0472	49.8993
2015	12	15	5	35	33	0.3	3.9	0.69	98.5	82.0472	52.9701
2015	12	15	5	45	33	0.3	3.9	0.67	98.8	82.0472	51.4347
2015	12	15	5	55	33	0.3	3.9	0.68	98.6	82.0472	52.2024
2015	12	15	6	5	33	0.3	3.9	0.68	99.8	82.0472	51.9465
2015	12	15	6	15	33	0.3	3.9	0.68	99.8	82.0472	51.9465
2015	12	15	6	25	33	0.3	3.9	0.69	98.2	82.0472	53.226
2015	12	15	6	35	33	0.3	3.9	0.67	98.7	82.1129	51.99
2015	12	15	6	45	33	0.3	3.9	0.7	98.7	82.0472	53.7378
2015	12	15	6	55	33	0.3	3.9	0.74	99.2	82.0472	56.8086
2015	12	15	7	5	33	0.3	3.9	0.7	99.1	82.1129	54.295
2015	12	15	7	15	33	0.3	3.9	0.66	100.9	82.0472	50.6671
2015	12	15	7	25	33	0.3	3.9	0.72	98.4	82.1129	55.5755
2015	12	15	7	35	33	0.3	3.9	0.68	96.6	82.0472	52.9702
2015	12	15	7	45	33	0.3	3.9	0.72	98.4	82.1129	55.5755
2015	12	15	7	55	33	0.3	3.9	0.71	99.9	82.0472	54.2496
2015	12	15	8	5	33	0.3	3.9	0.72	97.1	82.1129	55.8316
2015	12	15	8	15	33	0.3	3.9	0.68	100.5	82.1129	52.5021
2015	12	15	8	25	33	0.3	3.9	0.7	96.5	82.1129	54.2949
2015	12	15	8	35	33	0.3	3.9	0.69	98.8	82.1129	53.0143
2015	12	15	8	45	33	0.3	3.9	0.7	101.9	82.1785	53.5712
2015	12	15	8	55	33	0.3	3.9	0.7	98.9	82.1129	53.7826

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	9	5	33	0.3	3.9	0.71	97.7	82.1785	55.109
2015	12	15	9	15	33	0.3	3.9	0.7	97.6	82.1785	53.8274
2015	12	15	9	25	33	0.3	3.9	0.71	97.2	82.1785	54.8527
2015	12	15	9	35	33	0.3	3.9	0.69	98.7	82.1785	53.571
2015	12	15	9	45	33	0.3	3.9	0.72	97	82.1785	56.1342
2015	12	15	9	55	33	0.3	3.9	0.7	99.2	82.2441	54.1287
2015	12	15	10	5	33	0.3	3.9	0.72	99.5	82.2441	55.4114
2015	12	15	10	15	33	0.3	3.9	0.75	99.1	82.1785	57.9284
2015	12	15	10	25	33	0.3	3.9	0.75	96.3	82.2441	58.2332
2015	12	15	10	35	33	0.3	3.9	0.7	96.7	82.2441	54.6417
2015	12	15	10	45	33	0.3	3.9	0.74	95.3	82.2441	57.7201
2015	12	15	10	55	33	0.3	3.9	0.71	97.1	82.3097	55.4575
2015	12	15	11	5	33	0.3	3.9	0.76	97.5	82.2441	58.7462
2015	12	15	11	15	33	0.3	3.9	0.69	98.2	82.2441	53.1025
2015	12	15	11	25	33	0.3	3.6	0.71	98.8	82.3097	54.6872
2015	12	15	11	35	33	0.3	3.6	0.7	97.8	82.3097	54.1737
2015	12	15	11	45	33	0.3	3.6	0.72	98.6	82.3097	55.9709
2015	12	15	11	55	33	0.3	3.6	0.7	97.5	82.3097	54.6872
2015	12	15	12	5	33	0.3	3.6	0.73	97	82.3097	56.7411
2015	12	15	12	15	33	0.3	3.6	0.72	96.8	82.3753	56.2744
2015	12	15	12	25	33	0.3	3.6	0.71	96.1	82.3753	55.2466
2015	12	15	12	35	33	0.3	3.9	0.71	96.1	82.3753	54.9897
2015	12	15	12	45	33	0.3	3.6	0.69	96	82.3097	53.4034
2015	12	15	12	55	33	0.3	3.9	0.74	96.9	82.3753	57.3023
2015	12	15	13	5	33	0.3	3.9	0.73	96.9	82.3753	57.0454
2015	12	15	13	15	33	0.3	3.6	0.7	96.2	82.3753	54.7327
2015	12	15	13	25	33	0.3	3.9	0.72	97	82.3753	56.2745
2015	12	15	13	35	33	0.3	3.6	0.72	97	82.3753	56.2745
2015	12	15	13	45	33	0.3	3.6	0.71	96.9	82.3753	55.2467
2015	12	15	13	55	33	0.3	3.9	0.71	95.8	82.3753	55.2467
2015	12	15	14	5	33	0.3	3.9	0.7	97.8	82.4409	54.264
2015	12	15	14	15	33	0.3	3.9	0.72	97.3	82.3753	56.0176
2015	12	15	14	25	33	0.3	3.9	0.75	98.8	82.4409	57.8645
2015	12	15	14	35	33	0.3	3.9	0.74	95.6	82.4409	58.1217
2015	12	15	14	45	33	0.3	3.9	0.72	97.1	82.4409	56.0643
2015	12	15	14	55	33	0.3	3.9	0.74	95.6	82.4409	58.1217
2015	12	15	15	5	33	0.3	3.9	0.72	98.9	82.4409	56.0643
2015	12	15	15	15	33	0.3	3.9	0.72	97.9	82.4409	55.55
2015	12	15	15	25	33	0.3	3.9	0.69	94.9	82.4409	53.7498
2015	12	15	15	35	33	0.3	3.9	0.73	96.9	82.4409	57.0931
2015	12	15	15	45	33	0.3	3.9	0.7	97	82.4409	54.5213
2015	12	15	15	55	33	0.3	3.9	0.7	99.5	82.4409	53.7498
2015	12	15	16	5	33	0.3	3.9	0.68	99.7	82.5066	52.5075
2015	12	15	16	15	33	0.3	3.9	0.63	97.2	82.5066	48.9041
2015	12	15	16	25	33	0.3	3.9	0.7	98.7	82.5066	54.0519
2015	12	15	16	35	33	0.3	3.9	0.71	98.5	82.5066	55.0815

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	15	16	45	33	0.3	3.9	0.7	98.1	82.5066	54.0519
2015	12	15	16	55	33	0.3	3.9	0.71	98.2	82.5066	55.0815
2015	12	15	17	5	33	0.3	3.9	0.64	101	82.5722	49.2023
2015	12	15	17	15	33	0.3	3.9	0.63	102.9	82.5722	48.1719
2015	12	15	17	25	33	0.3	3.9	0.68	98.8	82.7034	53.1545
2015	12	15	17	35	33	0.3	3.9	0.7	99.7	82.5722	54.3544
2015	12	15	17	45	33	0.3	3.9	0.69	98	82.6378	53.3682
2015	12	15	17	55	33	0.3	3.9	0.7	97.8	82.6378	54.6573
2015	12	15	18	5	33	0.3	3.9	0.7	96.2	82.5722	54.612
2015	12	15	18	15	33	0.3	3.9	0.68	100	82.5066	52.7649
2015	12	15	18	25	33	0.3	3.9	0.67	97.9	82.7034	52.1223
2015	12	15	18	35	33	0.3	3.9	0.7	97.9	82.6378	54.1417
2015	12	15	18	45	33	0.3	3.9	0.71	97.2	82.7034	55.4768
2015	12	15	18	55	33	0.3	3.9	0.7	98.7	82.6378	54.1417
2015	12	15	19	5	33	0.3	3.9	0.68	97.8	82.7034	52.8965
2015	12	15	19	15	33	0.3	3.9	0.71	98.3	82.7034	54.9607
2015	12	15	19	25	33	0.3	3.9	0.66	98.5	82.7034	51.6063
2015	12	15	19	35	33	0.3	3.9	0.66	99.4	82.7034	51.3483
2015	12	15	19	45	33	0.3	3.9	0.68	97.2	82.7034	53.1545
2015	12	15	19	55	33	0.3	3.9	0.68	99.8	82.7034	52.3804
2015	12	15	20	5	33	0.3	3.9	0.68	99.8	82.7034	52.3804
2015	12	15	20	15	33	0.3	3.9	0.67	97.6	82.7034	52.3804
2015	12	15	20	25	33	0.3	3.9	0.66	97.1	82.7034	51.6063
2015	12	15	20	35	33	0.3	3.9	0.7	95.9	82.7034	54.9608
2015	12	15	20	45	33	0.3	3.9	0.66	98	82.7034	51.3483
2015	12	15	20	55	33	0.3	3.9	0.67	96.2	82.7034	52.1224
2015	12	15	21	5	33	0.3	3.9	0.65	97.9	82.7034	50.3162
2015	12	15	21	15	33	0.3	3.9	0.68	96.4	82.7034	53.1546
2015	12	15	21	25	33	0.3	3.9	0.71	98.2	82.7034	55.2188
2015	12	15	21	35	33	0.3	3.9	0.68	98.6	82.7034	53.1546
2015	12	15	21	45	33	0.3	3.9	0.65	98.7	82.7034	50.8323
2015	12	15	21	55	33	0.3	3.9	0.63	99.2	82.7034	49.2841
2015	12	15	22	5	33	0.3	3.9	0.69	99	82.7034	53.6707
2015	12	15	22	15	33	0.3	3.9	0.68	98.6	82.769	53.1987
2015	12	15	22	25	33	0.3	3.9	0.67	98.7	82.7034	52.3805
2015	12	15	22	35	33	0.3	3.9	0.64	96.8	82.7034	49.8002
2015	12	15	22	45	33	0.3	3.9	0.71	97.5	82.7034	55.2189
2015	12	15	22	55	33	0.3	3.9	0.64	97.6	82.7034	50.0583
2015	12	15	23	5	33	0.3	3.9	0.67	97.7	82.7034	51.8645
2015	12	15	23	15	33	0.3	3.9	0.65	101.3	82.7034	50.3163
2015	12	15	23	25	33	0.3	3.9	0.67	99.8	82.769	52.1657
2015	12	15	23	35	33	0.3	3.9	0.65	96.4	82.769	50.8745
2015	12	15	23	45	33	0.3	3.9	0.64	99.1	82.769	50.0998
2015	12	15	23	55	33	0.3	3.9	0.62	93.6	82.769	48.8085
2015	12	16	0	5	33	0.3	3.9	0.66	98.9	82.769	51.1328
2015	12	16	0	15	33	0.3	3.9	0.71	97.2	82.769	55.2647

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	0	25	33	0.3	3.9	0.68	97.2	82.7034	53.1547
2015	12	16	0	35	33	0.3	3.9	0.67	95.4	82.769	52.1658
2015	12	16	0	45	33	0.3	3.9	0.66	97.5	82.769	51.1328
2015	12	16	0	55	33	0.3	3.9	0.65	95.2	82.769	50.6163
2015	12	16	1	5	33	0.3	3.9	0.68	94.4	82.769	53.457
2015	12	16	1	15	33	0.3	3.9	0.68	96.4	82.769	53.1988
2015	12	16	1	25	33	0.3	3.9	0.73	99	82.769	57.0725
2015	12	16	1	35	33	0.3	3.9	0.7	96.2	82.769	55.0065
2015	12	16	1	45	33	0.3	3.9	0.69	93.5	82.769	54.2318
2015	12	16	1	55	33	0.3	3.9	0.67	97.6	82.769	52.4241
2015	12	16	2	5	33	0.3	3.9	0.68	97.4	82.769	53.4571
2015	12	16	2	15	33	0.3	3.9	0.7	95.6	82.769	55.0065
2015	12	16	2	25	33	0.3	3.9	0.69	97.4	82.769	53.9736
2015	12	16	2	35	33	0.3	3.9	0.64	96.2	82.769	49.8416
2015	12	16	2	45	33	0.3	3.9	0.68	95.3	82.769	52.9406
2015	12	16	2	55	33	0.3	3.9	0.66	95.4	82.769	51.9076
2015	12	16	3	5	33	0.3	3.9	0.65	94	82.769	51.1329
2015	12	16	3	15	33	0.3	3.9	0.65	95.5	82.769	50.8746
2015	12	16	3	25	33	0.3	3.9	0.66	98	82.8347	51.6922
2015	12	16	3	35	33	0.3	3.9	0.68	96.1	82.8347	52.9845
2015	12	16	3	45	33	0.3	3.9	0.65	94.9	82.769	51.1329
2015	12	16	3	55	33	0.3	3.9	0.66	95.2	82.769	51.3912
2015	12	16	4	5	33	0.3	3.9	0.63	96.5	82.769	49.5835
2015	12	16	4	15	33	0.3	3.9	0.69	97.7	82.769	53.7155
2015	12	16	4	25	33	0.3	3.9	0.68	95.6	82.769	52.9407
2015	12	16	4	35	33	0.3	3.9	0.7	96.2	82.769	54.4902
2015	12	16	4	45	33	0.3	3.9	0.66	94.6	82.8347	51.6923
2015	12	16	4	55	33	0.3	3.9	0.67	93.9	82.8347	52.4677
2015	12	16	5	5	33	0.3	3.9	0.68	95.2	82.769	53.4573
2015	12	16	5	15	33	0.3	3.9	0.63	95.9	82.769	49.5836
2015	12	16	5	25	33	0.3	3.9	0.67	97.9	82.8347	52.4678
2015	12	16	5	35	33	0.3	3.9	0.69	97.1	82.769	53.7156
2015	12	16	5	45	33	0.3	3.9	0.67	98.4	82.769	52.4244
2015	12	16	5	55	33	0.3	3.9	0.69	95.2	82.8347	53.7601
2015	12	16	6	5	33	0.3	3.9	0.67	94.5	82.8347	52.7263
2015	12	16	6	15	33	0.3	3.9	0.69	96.6	82.769	53.7157
2015	12	16	6	25	33	0.3	3.9	0.67	96.4	82.769	52.6827
2015	12	16	6	35	33	0.3	3.9	0.69	97.4	82.8347	53.7602
2015	12	16	6	45	33	0.3	3.9	0.68	93.9	82.769	53.7158
2015	12	16	6	55	33	0.3	3.9	0.65	93.8	82.8347	50.9172
2015	12	16	7	5	33	0.3	3.9	0.63	94.5	82.8347	49.6249
2015	12	16	7	15	33	0.3	3.9	0.69	96	82.8347	54.0187
2015	12	16	7	25	33	0.3	3.9	0.66	94.5	82.769	52.1663
2015	12	16	7	35	33	0.3	3.9	0.7	95.4	82.8347	54.5357
2015	12	16	7	45	33	0.3	3.9	0.65	95.8	82.8347	50.6588
2015	12	16	7	55	33	0.3	3.9	0.67	95.1	82.8347	52.2095

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	8	5	33	0.3	3.9	0.68	98.1	82.8347	52.9849
2015	12	16	8	15	33	0.3	3.9	0.65	95.8	82.8347	51.1757
2015	12	16	8	25	33	0.3	3.9	0.7	96	82.8347	54.5357
2015	12	16	8	35	33	0.3	3.9	0.64	99.2	82.8347	49.6249
2015	12	16	8	45	33	0.3	3.9	0.65	97.6	82.8347	50.6587
2015	12	16	8	55	33	0.3	3.9	0.66	95.4	82.9003	51.7353
2015	12	16	9	5	33	0.3	3.9	0.65	95.8	82.9003	50.9592
2015	12	16	9	15	33	0.3	3.9	0.65	96.3	82.9003	51.2179
2015	12	16	9	25	33	0.3	3.9	0.68	94.4	82.9003	53.8046
2015	12	16	9	35	33	0.3	3.9	0.7	96.2	82.9003	54.8392
2015	12	16	9	45	33	0.3	3.9	0.67	94.8	82.9659	52.5545
2015	12	16	9	55	33	0.3	3.9	0.67	94.8	82.9003	52.5111
2015	12	16	10	5	33	0.3	3.9	0.67	95	82.9659	52.8134
2015	12	16	10	15	33	0.3	3.9	0.64	98.3	82.9659	49.9655
2015	12	16	10	25	33	0.3	3.9	0.66	93.7	82.9659	52.2955
2015	12	16	10	35	33	0.3	3.9	0.67	97.3	82.9659	52.8132
2015	12	16	10	45	33	0.3	3.9	0.62	96	82.9659	48.9299
2015	12	16	10	55	33	0.3	3.9	0.65	95.5	82.9659	51.2599
2015	12	16	11	5	33	0.3	3.9	0.64	93.8	82.9659	50.2243
2015	12	16	11	15	33	0.3	3.9	0.67	96.7	82.9659	52.8132
2015	12	16	11	25	33	0.3	3.9	0.68	97.7	83.0315	53.375
2015	12	16	11	35	33	0.3	3.9	0.63	93.6	83.0315	49.7475
2015	12	16	11	45	33	0.3	3.9	0.68	95	83.0315	53.634
2015	12	16	11	55	33	0.3	3.9	0.65	94.3	83.0315	51.5612
2015	12	16	12	5	33	0.3	3.9	0.63	94.8	83.0315	49.7475
2015	12	16	12	15	33	0.3	3.9	0.65	93.5	83.0971	51.3445
2015	12	16	12	25	33	0.3	3.9	0.63	94.8	83.0315	49.4884
2015	12	16	12	35	33	0.3	3.9	0.66	94.6	83.0315	51.8203
2015	12	16	12	45	33	0.3	3.9	0.64	94.7	83.0971	50.3072
2015	12	16	12	55	33	0.3	3.9	0.65	94.7	83.0971	50.8258
2015	12	16	13	5	33	0.3	3.9	0.66	94	83.1627	51.9059
2015	12	16	13	15	33	0.3	3.9	0.65	94.1	83.2284	51.1694
2015	12	16	13	25	33	0.3	3.9	0.65	97.2	83.2284	51.1694
2015	12	16	13	35	33	0.3	3.9	0.69	97.9	83.294	54.3311
2015	12	16	13	45	33	0.3	3.9	0.66	99.7	83.294	51.7315
2015	12	16	13	55	33	0.3	3.9	0.65	96.6	83.294	51.4716
2015	12	16	14	5	33	0.3	3.9	0.66	97.1	83.3596	52.0343
2015	12	16	14	15	33	0.3	3.9	0.72	96.1	83.3596	56.4572
2015	12	16	14	25	33	0.3	3.9	0.69	97.3	83.3596	54.6361
2015	12	16	14	35	33	0.3	3.9	0.68	96.4	83.294	53.2914
2015	12	16	14	45	33	0.3	3.9	0.7	95.4	83.294	54.8512
2015	12	16	14	55	33	0.3	3.9	0.62	100.1	83.294	48.0923
2015	12	16	15	5	33	0.3	3.9	0.69	96.6	83.294	54.0714
2015	12	16	15	15	33	0.3	3.9	0.7	96.4	83.294	55.3712
2015	12	16	15	25	33	0.3	3.9	0.68	95.6	83.3596	53.3354
2015	12	16	15	35	33	0.3	3.9	0.66	96.5	83.294	52.2517

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	15	45	33	0.3	3.9	0.65	98.4	83.3596	51.254
2015	12	16	15	55	33	0.3	3.9	0.63	96.9	83.3596	49.693
2015	12	16	16	5	33	0.3	3.9	0.64	92.4	83.3596	50.4735
2015	12	16	16	15	33	0.3	3.9	0.7	94.6	83.3596	55.1566
2015	12	16	16	25	33	0.3	3.9	0.67	96.8	83.3596	52.5549
2015	12	16	16	35	33	0.3	3.9	0.75	95.8	83.3596	59.0592
2015	12	16	16	45	33	0.3	3.9	0.64	96.7	83.4252	50.7754
2015	12	16	16	55	33	0.3	3.9	0.71	97.2	83.4252	55.7228
2015	12	16	17	5	33	0.3	3.9	0.68	96.9	83.4252	53.6397
2015	12	16	17	15	33	0.3	3.9	0.59	94.8	83.4252	46.6092
2015	12	16	17	25	33	0.3	3.9	0.67	97	83.4252	52.8585
2015	12	16	17	35	33	0.3	3.9	0.7	95.6	83.4252	55.4624
2015	12	16	17	45	33	0.3	3.9	0.68	94.7	83.4252	53.6397
2015	12	16	17	55	33	0.3	3.9	0.69	95.2	83.4252	54.1605
2015	12	16	18	5	33	0.3	3.9	0.7	95.1	83.4252	55.202
2015	12	16	18	15	33	0.3	3.9	0.66	97.4	83.4252	51.817
2015	12	16	18	25	33	0.3	3.9	0.68	95.2	83.4252	53.9001
2015	12	16	18	35	33	0.3	3.9	0.66	96.2	83.4252	52.3378
2015	12	16	18	45	33	0.3	3.9	0.65	94.7	83.4252	51.0358
2015	12	16	18	55	33	0.3	3.9	0.68	95.3	83.4252	53.3793
2015	12	16	19	5	33	0.3	3.9	0.66	97.1	83.4252	52.3378
2015	12	16	19	15	33	0.3	3.9	0.68	94.7	83.4252	54.1605
2015	12	16	19	25	33	0.3	3.9	0.69	96.3	83.4252	54.1605
2015	12	16	19	35	33	0.3	3.9	0.66	95.4	83.4252	52.0774
2015	12	16	19	45	33	0.3	3.9	0.64	99.2	83.4252	49.9944
2015	12	16	19	55	33	0.3	3.9	0.69	96.3	83.4252	54.6813
2015	12	16	20	5	33	0.3	3.9	0.69	95.8	83.4252	54.1606
2015	12	16	20	15	33	0.3	3.9	0.65	98.7	83.4252	50.7755
2015	12	16	20	25	33	0.3	3.9	0.7	98.6	83.4252	54.9417
2015	12	16	20	35	33	0.3	3.9	0.72	97.9	83.4252	56.5041
2015	12	16	20	45	33	0.3	3.9	0.7	97.5	83.4252	55.2022
2015	12	16	20	55	33	0.3	3.9	0.72	97.4	83.4252	56.5041
2015	12	16	21	5	33	0.3	3.9	0.74	97.7	83.4252	58.0665
2015	12	16	21	15	33	0.3	3.9	0.72	95.5	83.4252	56.7645
2015	12	16	21	25	33	0.3	3.9	0.72	96.1	83.4252	56.5042
2015	12	16	21	35	33	0.3	3.9	0.72	99.9	83.4252	56.5042
2015	12	16	21	45	33	0.3	3.9	0.7	95.7	83.4252	54.9419
2015	12	16	21	55	33	0.3	3.9	0.69	97.3	83.4252	54.6815
2015	12	16	22	5	33	0.3	3.9	0.67	95.9	83.4252	53.1192
2015	12	16	22	15	33	0.3	3.9	0.69	95.8	83.4252	54.1607
2015	12	16	22	25	33	0.3	3.9	0.7	96.2	83.4252	55.2023
2015	12	16	22	35	33	0.3	3.9	0.7	95.4	83.4252	55.2023
2015	12	16	22	45	33	0.3	3.9	0.71	96.1	83.4252	55.7231
2015	12	16	22	55	33	0.3	3.9	0.7	95.6	83.4252	55.4627
2015	12	16	23	5	33	0.3	3.9	0.72	96.8	83.4252	57.0251
2015	12	16	23	15	33	0.3	3.9	0.71	96.1	83.4252	55.9835

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	16	23	25	33	0.3	3.9	0.68	96.9	83.4252	53.9005
2015	12	16	23	35	33	0.3	3.9	0.71	96.7	83.4252	55.7232
2015	12	16	23	45	33	0.3	3.9	0.7	96.4	83.4252	55.4628
2015	12	16	23	55	33	0.3	3.9	0.68	96.3	83.4252	53.9005
2015	12	17	0	5	33	0.3	3.9	0.7	97.3	83.4252	55.2025
2015	12	17	0	15	33	0.3	3.9	0.66	97.4	83.4252	52.0778
2015	12	17	0	25	33	0.3	3.9	0.72	96	83.4252	56.7648
2015	12	17	0	35	33	0.3	3.9	0.65	97.5	83.4252	51.2967
2015	12	17	0	45	33	0.3	3.9	0.72	98.1	83.4252	56.5045
2015	12	17	0	55	33	0.3	3.9	0.69	97.3	83.4252	54.6818
2015	12	17	1	5	33	0.3	3.9	0.68	95.5	83.4252	53.6402
2015	12	17	1	15	33	0.3	3.9	0.69	96.3	83.4252	54.4214
2015	12	17	1	25	33	0.3	3.9	0.66	95.2	83.4252	51.8175
2015	12	17	1	35	33	0.3	3.9	0.68	95.3	83.4252	53.6403
2015	12	17	1	45	33	0.3	3.9	0.69	96	83.4252	54.6818
2015	12	17	1	55	33	0.3	3.9	0.68	95	83.4252	53.6403
2015	12	17	2	5	33	0.3	3.9	0.73	94.9	83.4252	57.5462
2015	12	17	2	15	33	0.3	3.9	0.65	93.5	83.4252	51.5572
2015	12	17	2	25	33	0.3	3.9	0.67	95.3	83.4252	53.1196
2015	12	17	2	35	33	0.3	3.9	0.69	95.8	83.4908	54.2056
2015	12	17	2	45	33	0.3	3.9	0.69	97.3	83.4252	54.6819
2015	12	17	2	55	33	0.3	3.9	0.7	97	83.4252	54.9424
2015	12	17	3	5	33	0.3	3.9	0.68	97.4	83.4252	53.9008
2015	12	17	3	15	33	0.3	3.9	0.72	96.1	83.4252	56.5047
2015	12	17	3	25	33	0.3	3.9	0.66	96.8	83.4252	52.0781
2015	12	17	3	35	33	0.3	3.9	0.7	95.1	83.4252	55.4632
2015	12	17	3	45	33	0.3	3.9	0.69	97.4	83.4252	54.4217
2015	12	17	3	55	33	0.3	3.9	0.68	99.1	83.4252	53.6405
2015	12	17	4	5	33	0.3	3.9	0.68	96.3	83.4252	53.9009
2015	12	17	4	15	33	0.3	3.9	0.71	98.5	83.4252	55.4633
2015	12	17	4	25	33	0.3	3.9	0.71	96.1	83.4252	55.9841
2015	12	17	4	35	33	0.3	3.9	0.65	97.2	83.4252	51.5575
2015	12	17	4	45	33	0.3	3.9	0.7	96.7	83.4252	55.203
2015	12	17	4	55	33	0.3	3.9	0.66	95.7	83.4252	51.8179
2015	12	17	5	5	33	0.3	3.9	0.7	96.5	83.4252	54.9426
2015	12	17	5	15	33	0.3	3.9	0.69	95.7	83.4252	54.4218
2015	12	17	5	25	33	0.3	3.9	0.67	95.9	83.4252	52.8595
2015	12	17	5	35	33	0.3	3.9	0.7	96.7	83.4252	55.203
2015	12	17	5	45	33	0.3	3.9	0.69	96	83.4252	54.1615
2015	12	17	5	55	33	0.3	3.9	0.67	96.4	83.4252	53.1199
2015	12	17	6	5	33	0.3	3.9	0.69	97.9	83.4908	54.206
2015	12	17	6	15	33	0.3	3.9	0.69	94.9	83.4908	54.4666
2015	12	17	6	25	33	0.3	3.9	0.68	96.4	83.4908	53.4242
2015	12	17	6	35	33	0.3	3.9	0.71	95.9	83.4908	55.7697
2015	12	17	6	45	33	0.3	3.9	0.71	98.2	83.4908	56.0303
2015	12	17	6	55	33	0.3	3.9	0.7	97.3	83.4908	55.2485

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	7	5	33	0.3	3.9	0.7	100	83.4908	54.7273
2015	12	17	7	15	33	0.3	3.9	0.7	98.6	83.5564	55.033
2015	12	17	7	25	33	0.3	3.9	0.73	98.6	83.4908	57.0727
2015	12	17	7	35	33	0.3	3.9	0.66	98.3	83.5564	51.6424
2015	12	17	7	45	33	0.3	3.9	0.73	99	83.5564	57.3804
2015	12	17	7	55	33	0.3	3.9	0.71	96.9	83.5564	56.0763
2015	12	17	8	5	33	0.3	3.9	0.71	98	83.5564	55.5546
2015	12	17	8	15	33	0.3	3.9	0.74	97.2	83.6221	58.2105
2015	12	17	8	25	33	0.3	3.9	0.7	99.4	83.5564	55.0329
2015	12	17	8	35	33	0.3	3.9	0.68	98.6	83.5564	53.468
2015	12	17	8	45	33	0.3	3.9	0.75	96.3	83.6221	59.2545
2015	12	17	8	55	33	0.3	3.9	0.73	97.5	83.5564	57.3802
2015	12	17	9	5	33	0.3	3.9	0.71	97.7	83.6221	55.861
2015	12	17	9	15	33	0.3	3.9	0.72	97.8	83.6221	56.9051
2015	12	17	9	25	33	0.3	3.9	0.71	95.8	83.6221	56.383
2015	12	17	9	35	33	0.3	3.9	0.73	97.8	83.6221	57.166
2015	12	17	9	45	33	0.3	3.9	0.71	95.3	83.6221	55.8608
2015	12	17	9	55	33	0.3	3.9	0.7	98.3	83.6221	55.3387
2015	12	17	10	5	33	0.3	3.9	0.73	98.8	83.6221	57.427
2015	12	17	10	15	33	0.3	3.9	0.7	98.9	83.6877	54.8615
2015	12	17	10	25	33	0.3	3.9	0.72	98.9	83.6877	56.6902
2015	12	17	10	35	33	0.3	3.9	0.69	96.8	83.6877	54.6002
2015	12	17	10	45	33	0.3	3.9	0.7	95.1	83.6221	55.0776
2015	12	17	10	55	33	0.3	3.9	0.69	97.7	83.6877	54.0777
2015	12	17	11	5	33	0.3	3.9	0.7	94.8	83.6877	55.6452
2015	12	17	11	15	33	0.3	3.9	0.7	96.4	83.6877	55.6452
2015	12	17	11	25	33	0.3	3.9	0.69	98	83.6877	54.0777
2015	12	17	11	35	33	0.3	3.9	0.7	101	83.6877	54.8614
2015	12	17	11	45	33	0.3	3.9	0.69	99.3	83.6221	54.0334
2015	12	17	11	55	33	0.3	3.9	0.73	99.1	83.6877	57.2126
2015	12	17	12	5	33	0.3	3.9	0.73	97.7	83.6877	57.9963
2015	12	17	12	15	33	0.3	3.9	0.72	98.4	83.7533	56.475
2015	12	17	12	25	33	0.3	3.9	0.72	100.2	83.8189	56.7829
2015	12	17	12	35	33	0.3	3.9	0.73	97.5	83.7533	57.7823
2015	12	17	12	45	33	0.3	3.9	0.71	98	83.8189	55.9979
2015	12	17	12	55	33	0.3	3.9	0.69	97.7	83.8189	54.1662
2015	12	17	13	5	33	0.3	3.9	0.67	97	83.8189	53.1195
2015	12	17	13	15	33	0.3	3.9	0.71	97.7	83.8189	55.9979
2015	12	17	13	25	33	0.3	3.9	0.69	95.2	83.8189	54.9512
2015	12	17	13	35	33	0.3	3.9	0.7	99.7	83.8845	54.9962
2015	12	17	13	45	33	0.3	3.9	0.68	96.3	83.8845	54.2105
2015	12	17	13	55	33	0.3	3.9	0.69	99.6	83.8845	54.4725
2015	12	17	14	5	33	0.3	3.9	0.71	98.8	83.8845	55.7819
2015	12	17	14	15	33	0.3	3.9	0.74	97.7	83.8845	58.4008
2015	12	17	14	25	33	0.3	3.9	0.69	97.7	83.8845	54.2106
2015	12	17	14	35	33	0.3	3.9	0.69	99.1	83.8845	54.2106

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	14	45	33	0.3	3.9	0.7	98.1	83.8845	54.9963
2015	12	17	14	55	33	0.3	3.9	0.68	96.9	83.8845	53.9488
2015	12	17	15	5	33	0.3	3.9	0.7	98.7	83.8845	54.9963
2015	12	17	15	15	33	0.3	3.9	0.66	97.2	83.8845	52.1156
2015	12	17	15	25	33	0.3	3.9	0.71	98	83.8189	55.9982
2015	12	17	15	35	33	0.3	3.9	0.73	96.9	83.8189	58.0916
2015	12	17	15	45	33	0.3	3.9	0.7	97	83.8845	55.7821
2015	12	17	15	55	33	0.3	3.9	0.67	98.4	83.8845	52.9013
2015	12	17	16	5	33	0.3	3.9	0.73	98	83.8845	57.8772
2015	12	17	16	15	33	0.3	3.9	0.71	97.5	83.8845	56.044
2015	12	17	16	25	33	0.3	3.9	0.69	97.7	83.8845	54.2108
2015	12	17	16	35	33	0.3	3.9	0.71	99	83.8845	56.044
2015	12	17	16	45	33	0.3	3.9	0.68	95.5	83.8845	54.2108
2015	12	17	16	55	33	0.3	3.9	0.67	96.4	83.8845	53.4251
2015	12	17	17	5	33	0.3	3.9	0.7	96.5	83.8845	55.2583
2015	12	17	17	15	33	0.3	3.9	0.67	94.8	83.8845	53.4251
2015	12	17	17	25	33	0.3	3.9	0.69	99.9	83.8845	54.2108
2015	12	17	17	35	33	0.3	3.9	0.7	98.1	83.8845	54.9964
2015	12	17	17	45	33	0.3	3.9	0.69	95.8	83.8845	54.4726
2015	12	17	17	55	33	0.3	3.9	0.68	97.7	83.8845	53.9489
2015	12	17	18	5	33	0.3	3.9	0.7	96.4	83.8845	55.7821
2015	12	17	18	15	33	0.3	3.9	0.68	96.9	83.8845	54.2107
2015	12	17	18	25	33	0.3	3.9	0.68	98.8	83.8845	53.9489
2015	12	17	18	35	33	0.3	3.9	0.72	98.9	83.9501	56.876
2015	12	17	18	45	33	0.3	3.9	0.71	97.2	83.8845	56.0439
2015	12	17	18	55	33	0.3	3.9	0.7	100	83.9501	55.0413
2015	12	17	19	5	33	0.3	3.9	0.73	101.1	83.8845	57.3534
2015	12	17	19	15	33	0.3	3.9	0.69	97.6	83.9501	54.7792
2015	12	17	19	25	33	0.3	3.9	0.71	99.1	83.8845	55.7821
2015	12	17	19	35	33	0.3	3.9	0.69	97.9	83.8845	54.7345
2015	12	17	19	45	33	0.3	3.9	0.72	98.9	83.8845	56.8296
2015	12	17	19	55	33	0.3	3.9	0.71	98.2	83.9501	56.3518
2015	12	17	20	5	33	0.3	3.9	0.7	99.1	83.8845	55.5202
2015	12	17	20	15	33	0.3	3.9	0.75	100.3	83.9501	58.9729
2015	12	17	20	25	33	0.3	3.9	0.69	100.2	83.8845	53.9489
2015	12	17	20	35	33	0.3	3.9	0.69	96.6	83.9501	54.7792
2015	12	17	20	45	33	0.3	3.9	0.68	96.6	83.9501	53.9929
2015	12	17	20	55	33	0.3	3.9	0.71	96.1	83.9501	56.3519
2015	12	17	21	5	33	0.3	3.9	0.72	97.9	83.9501	56.614
2015	12	17	21	15	33	0.3	3.9	0.67	95.6	83.8845	53.4251
2015	12	17	21	25	33	0.3	3.9	0.67	96.4	83.9501	53.4688
2015	12	17	21	35	33	0.3	3.9	0.67	96.2	83.9501	53.2067
2015	12	17	21	45	33	0.3	3.9	0.73	96.9	83.9501	58.1866
2015	12	17	21	55	33	0.3	3.9	0.72	97.9	83.9501	56.614
2015	12	17	22	5	33	0.3	3.9	0.73	96	83.9501	57.6624
2015	12	17	22	15	33	0.3	3.9	0.69	98.4	83.9501	54.7793

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	17	22	25	33	0.3	3.9	0.69	96	83.9501	54.7793
2015	12	17	22	35	33	0.3	3.9	0.68	97.2	83.9501	53.993
2015	12	17	22	45	33	0.3	3.9	0.72	96.3	83.9501	56.8762
2015	12	17	22	55	33	0.3	3.9	0.64	96.1	83.9501	51.1099
2015	12	17	23	5	33	0.3	3.9	0.67	96.7	83.9501	53.2068
2015	12	17	23	15	33	0.3	3.9	0.7	100.8	83.9501	54.7794
2015	12	17	23	25	33	0.3	3.9	0.74	97.3	83.9501	58.973
2015	12	17	23	35	33	0.3	3.9	0.65	96.1	83.9501	51.6342
2015	12	17	23	45	33	0.3	3.9	0.7	96.2	83.9501	55.8278
2015	12	17	23	55	33	0.3	3.9	0.71	98.5	83.9501	56.0899
2015	12	18	0	5	33	0.3	3.9	0.65	97.3	83.9501	51.3721
2015	12	18	0	15	33	0.3	3.9	0.69	96	83.9501	54.7794
2015	12	18	0	25	33	0.3	3.9	0.67	94.8	83.9501	53.4689
2015	12	18	0	35	33	0.3	3.9	0.68	94.1	83.9501	54.2552
2015	12	18	0	45	33	0.3	3.9	0.72	97.9	83.9501	56.6142
2015	12	18	0	55	33	0.3	3.9	0.68	96.1	83.9501	53.7311
2015	12	18	1	5	33	0.3	3.9	0.68	98.3	83.9501	53.7311
2015	12	18	1	15	33	0.3	3.9	0.67	97.3	83.9501	53.2069
2015	12	18	1	25	33	0.3	3.9	0.69	98.5	83.9501	54.2553
2015	12	18	1	35	33	0.3	3.9	0.66	96.3	83.9501	52.4206
2015	12	18	1	45	33	0.3	3.9	0.67	97.9	83.9501	52.9448
2015	12	18	1	55	33	0.3	3.9	0.7	94	83.9501	55.828
2015	12	18	2	5	33	0.3	3.9	0.66	96.5	83.9501	52.6827
2015	12	18	2	15	33	0.3	3.9	0.69	95.8	83.9501	54.5175
2015	12	18	2	25	33	0.3	3.9	0.66	95.4	83.9501	52.4207
2015	12	18	2	35	33	0.3	3.9	0.68	97.8	83.9501	53.4691
2015	12	18	2	45	33	0.3	3.9	0.72	97.6	83.9501	56.8764
2015	12	18	2	55	33	0.3	3.9	0.66	95.7	83.9501	52.6828
2015	12	18	3	5	33	0.3	3.9	0.66	95.4	83.9501	52.6828
2015	12	18	3	15	33	0.3	3.9	0.67	97.9	83.9501	52.6828
2015	12	18	3	25	33	0.3	3.9	0.63	93.9	83.9501	50.3239
2015	12	18	3	35	33	0.3	3.9	0.69	95.2	83.9501	55.0418
2015	12	18	3	45	33	0.3	3.9	0.7	97	83.9501	55.8281
2015	12	18	3	55	33	0.3	3.9	0.67	97	83.9501	53.4692
2015	12	18	4	5	33	0.3	3.9	0.69	95.8	83.9501	54.5176
2015	12	18	4	15	33	0.3	3.9	0.67	96.7	83.9501	53.2071
2015	12	18	4	25	33	0.3	3.9	0.7	95.9	83.9501	55.566
2015	12	18	4	35	33	0.3	3.9	0.68	95.3	83.9501	53.7313
2015	12	18	4	45	33	0.3	3.9	0.69	97.1	83.9501	54.7797
2015	12	18	4	55	33	0.3	3.9	0.67	98.2	83.9501	52.6829
2015	12	18	5	5	33	0.3	3.9	0.69	97.1	83.9501	54.7797
2015	12	18	5	15	33	0.3	3.9	0.68	96.1	84.0158	53.7752
2015	12	18	5	25	33	0.3	3.9	0.67	97.3	83.9501	53.4692
2015	12	18	5	35	33	0.3	3.9	0.65	96.1	84.0158	51.6766
2015	12	18	5	45	33	0.3	3.9	0.66	97.4	84.0158	52.2012
2015	12	18	5	55	33	0.3	3.9	0.66	96	84.0158	52.7259

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	6	5	33	0.3	3.9	0.68	96.7	84.0158	53.7752
2015	12	18	6	15	33	0.3	3.9	0.71	97.7	84.0158	56.136
2015	12	18	6	25	33	0.3	3.9	0.68	96.1	84.0158	54.0375
2015	12	18	6	35	33	0.3	3.9	0.64	96.8	84.0814	50.9312
2015	12	18	6	45	33	0.3	3.9	0.69	96	84.0158	54.5621
2015	12	18	6	55	33	0.3	3.9	0.68	95.3	84.0814	54.0816
2015	12	18	7	5	33	0.3	3.9	0.67	94.2	84.0814	53.2939
2015	12	18	7	15	33	0.3	3.9	0.67	95.9	84.0814	53.294
2015	12	18	7	25	33	0.3	3.9	0.66	94.6	84.0814	52.7689
2015	12	18	7	35	33	0.3	3.9	0.69	96.8	84.0814	55.1317
2015	12	18	7	45	33	0.3	3.9	0.7	98.1	84.0814	55.1316
2015	12	18	7	55	33	0.3	3.9	0.71	95.8	84.0814	56.7068
2015	12	18	8	5	33	0.3	3.9	0.69	98.2	84.0814	54.6065
2015	12	18	8	15	33	0.3	3.9	0.74	98.4	84.147	58.5922
2015	12	18	8	25	33	0.3	3.9	0.68	95.2	84.147	54.3882
2015	12	18	8	35	33	0.3	3.9	0.64	98.8	84.147	50.9725
2015	12	18	8	45	33	0.3	3.9	0.69	95.7	84.147	54.9136
2015	12	18	8	55	33	0.3	3.9	0.65	94.4	84.147	51.7606
2015	12	18	9	5	33	0.3	3.9	0.68	95.3	84.147	53.8625
2015	12	18	9	15	33	0.3	3.9	0.64	96.8	84.147	50.9723
2015	12	18	9	25	33	0.3	3.9	0.65	97.5	84.147	51.7605
2015	12	18	9	35	33	0.3	3.9	0.68	94.4	84.147	54.1252
2015	12	18	9	45	33	0.3	3.9	0.69	97.4	84.2126	54.9581
2015	12	18	9	55	33	0.3	3.9	0.64	95.6	84.147	51.2349
2015	12	18	10	5	33	0.3	3.9	0.71	94.8	84.2126	56.7987
2015	12	18	10	15	33	0.3	3.9	0.67	96.2	84.2126	53.3803
2015	12	18	10	25	33	0.3	3.9	0.7	97.5	84.2126	55.7468
2015	12	18	10	35	33	0.3	3.9	0.67	94.8	84.2126	53.3802
2015	12	18	10	45	33	0.3	3.9	0.66	98.9	84.147	52.2858
2015	12	18	10	55	33	0.3	3.9	0.68	95.3	84.2126	53.9061
2015	12	18	11	5	33	0.3	3.9	0.64	93.8	84.2126	51.2765
2015	12	18	11	15	33	0.3	3.9	0.65	97.2	84.2126	52.0654
2015	12	18	11	25	33	0.3	3.9	0.71	95.8	84.2126	56.7986
2015	12	18	11	35	33	0.3	3.9	0.68	97.4	84.2126	54.4319
2015	12	18	11	45	33	0.3	3.9	0.69	96	84.2126	54.6949
2015	12	18	11	55	33	0.3	3.9	0.67	97.9	84.2126	53.3801
2015	12	18	12	5	33	0.3	3.9	0.68	97.5	84.2126	54.169
2015	12	18	12	15	33	0.3	3.9	0.66	96.3	84.2126	52.5913
2015	12	18	12	25	33	0.3	3.9	0.7	97.3	84.2126	55.4838
2015	12	18	12	35	33	0.3	3.9	0.67	95.6	84.2126	53.6431
2015	12	18	12	45	33	0.3	3.9	0.67	95.6	84.2126	53.6431
2015	12	18	12	55	33	0.3	3.9	0.64	95	84.147	51.2348
2015	12	18	13	5	33	0.3	3.9	0.68	97.2	84.147	53.8623
2015	12	18	13	15	33	0.3	3.9	0.72	97.5	84.147	57.5407
2015	12	18	13	25	33	0.3	3.9	0.68	95.3	84.147	54.1251
2015	12	18	13	35	33	0.3	3.9	0.65	94.6	84.147	52.0231

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	13	45	33	0.3	3.9	0.64	94.4	84.2126	50.7507
2015	12	18	13	55	33	0.3	3.9	0.63	97.2	84.2126	49.6989
2015	12	18	14	5	33	0.3	3.9	0.65	95.8	84.2126	51.5396
2015	12	18	14	15	33	0.3	3.9	0.65	94.6	84.2126	52.0656
2015	12	18	14	25	33	0.3	3.9	0.67	96.2	84.147	53.5997
2015	12	18	14	35	33	0.3	3.9	0.65	94.3	84.2126	52.3286
2015	12	18	14	45	33	0.3	3.9	0.64	96.1	84.2126	51.2768
2015	12	18	14	55	33	0.3	3.9	0.69	96	84.2126	54.6953
2015	12	18	15	5	33	0.3	3.9	0.66	96.3	84.147	52.2861
2015	12	18	15	15	33	0.3	3.9	0.65	96.4	84.2126	51.8028
2015	12	18	15	25	33	0.3	3.9	0.64	96.8	84.2126	51.014
2015	12	18	15	35	33	0.3	3.9	0.66	97.7	84.147	52.549
2015	12	18	15	45	33	0.3	3.9	0.66	97.4	84.2126	52.5918
2015	12	18	15	55	33	0.3	3.9	0.73	98.5	84.2782	58.1612
2015	12	18	16	5	33	0.3	3.9	0.71	99.2	84.3438	56.6281
2015	12	18	16	15	33	0.3	3.9	0.71	96.3	84.3438	56.8915
2015	12	18	16	25	33	0.3	3.9	0.7	98.1	84.2782	55.2663
2015	12	18	16	35	33	0.3	3.9	0.68	95.8	84.3438	54.2577
2015	12	18	16	45	33	0.3	3.9	0.72	97.1	84.3438	57.155
2015	12	18	16	55	33	0.3	3.9	0.66	96.8	84.3438	52.6774
2015	12	18	17	5	33	0.3	3.9	0.71	96.9	84.3438	56.8916
2015	12	18	17	15	33	0.3	3.9	0.7	96.2	84.4095	55.8834
2015	12	18	17	25	33	0.3	3.9	0.7	95.9	84.3438	56.1014
2015	12	18	17	35	33	0.3	3.9	0.68	97	84.3438	53.9943
2015	12	18	17	45	33	0.3	3.9	0.71	97.7	84.3438	56.3648
2015	12	18	17	55	33	0.3	3.9	0.7	97.8	84.3438	55.5746
2015	12	18	18	5	33	0.3	3.9	0.7	98.1	84.3438	55.3112
2015	12	18	18	15	33	0.3	3.9	0.69	95.2	84.4095	55.3561
2015	12	18	18	25	33	0.3	3.9	0.71	97.1	84.3438	56.8915
2015	12	18	18	35	33	0.3	3.9	0.7	94	84.3438	55.838
2015	12	18	18	45	33	0.3	3.9	0.68	99.5	84.4095	53.7745
2015	12	18	18	55	33	0.3	3.9	0.7	100.7	84.4095	55.6197
2015	12	18	19	5	33	0.3	3.9	0.66	96.2	84.3438	52.9407
2015	12	18	19	15	33	0.3	3.9	0.71	96.1	84.4095	56.6741
2015	12	18	19	25	33	0.3	3.9	0.69	96.3	84.4095	54.8289
2015	12	18	19	35	33	0.3	3.9	0.7	95.9	84.4095	55.8833
2015	12	18	19	45	33	0.3	3.9	0.69	97.9	84.3438	54.7844
2015	12	18	19	55	33	0.3	3.9	0.71	98	84.4095	56.1469
2015	12	18	20	5	33	0.3	3.9	0.69	97.9	84.4095	54.829
2015	12	18	20	15	33	0.3	3.9	0.68	98.3	84.4095	54.3017
2015	12	18	20	25	33	0.3	3.9	0.66	96.8	84.4095	52.7201
2015	12	18	20	35	33	0.3	3.9	0.71	98.5	84.4095	56.6742
2015	12	18	20	45	33	0.3	3.9	0.67	95.6	84.4095	53.7746
2015	12	18	20	55	33	0.3	3.9	0.66	96	84.4095	52.7202
2015	12	18	21	5	33	0.3	3.9	0.66	96.8	84.4095	52.9838
2015	12	18	21	15	33	0.3	3.9	0.74	99.2	84.4095	58.783

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	18	21	25	33	0.3	3.9	0.72	97.3	84.4095	57.465
2015	12	18	21	35	33	0.3	3.9	0.71	94.8	84.4095	56.9378
2015	12	18	21	45	33	0.3	3.9	0.69	99.3	84.4095	54.829
2015	12	18	21	55	33	0.3	3.9	0.73	93.8	84.4095	58.783
2015	12	18	22	5	33	0.3	3.9	0.72	97.6	84.4095	56.9378
2015	12	18	22	15	33	0.3	3.9	0.67	94.7	84.4095	54.0382
2015	12	18	22	25	33	0.3	3.9	0.7	95.1	84.4751	56.1926
2015	12	18	22	35	33	0.3	3.9	0.7	95.9	84.4751	55.9288
2015	12	18	22	45	33	0.3	3.9	0.67	96.2	84.4751	53.8183
2015	12	18	22	55	33	0.3	3.9	0.65	96.1	84.4751	52.2354
2015	12	18	23	5	33	0.3	3.9	0.64	95.3	84.4751	51.444
2015	12	18	23	15	33	0.3	3.9	0.65	95.8	84.4751	51.9716
2015	12	18	23	25	33	0.3	3.9	0.69	96.6	84.4751	55.1374
2015	12	18	23	35	33	0.3	3.9	0.7	95.9	84.4751	56.1926
2015	12	18	23	45	33	0.3	3.9	0.69	93.5	84.4751	55.665
2015	12	18	23	55	33	0.3	3.9	0.63	93.3	84.4751	50.9163
2015	12	19	0	5	33	0.3	3.9	0.7	97.8	84.4751	55.9288
2015	12	19	0	15	33	0.3	3.9	0.63	95.4	84.4751	50.6525
2015	12	19	0	25	33	0.3	3.9	0.67	94.5	84.5407	53.862
2015	12	19	0	35	33	0.3	3.9	0.71	94.8	84.4751	56.7203
2015	12	19	0	45	33	0.3	3.9	0.7	97.5	84.5407	56.2382
2015	12	19	0	55	33	0.3	3.9	0.7	96.7	84.5407	55.9742
2015	12	19	1	5	33	0.3	3.9	0.69	97.1	84.5407	55.4461
2015	12	19	1	15	33	0.3	3.9	0.69	94.4	84.4751	55.1374
2015	12	19	1	25	33	0.3	3.9	0.67	96.7	84.5407	53.862
2015	12	19	1	35	33	0.3	3.9	0.66	95.4	84.5407	52.8058
2015	12	19	1	45	33	0.3	3.9	0.68	97.5	84.5407	53.862
2015	12	19	1	55	33	0.3	3.9	0.69	94.1	84.5407	55.1821
2015	12	19	2	5	33	0.3	3.9	0.66	96.3	84.5407	52.8058
2015	12	19	2	15	33	0.3	3.9	0.7	93.2	84.5407	56.2382
2015	12	19	2	25	33	0.3	3.9	0.7	99.4	84.5407	55.7102
2015	12	19	2	35	33	0.3	3.9	0.69	95.2	84.6063	54.9626
2015	12	19	2	45	33	0.3	3.9	0.68	96.4	84.5407	54.126
2015	12	19	2	55	33	0.3	3.9	0.66	98	84.6063	52.5844
2015	12	19	3	5	33	0.3	3.9	0.66	97.4	84.6063	53.1129
2015	12	19	3	15	33	0.3	3.9	0.65	95.2	84.5407	52.2778
2015	12	19	3	25	33	0.3	3.9	0.68	97.8	84.6063	53.9056
2015	12	19	3	35	33	0.3	3.9	0.71	96.4	84.6063	56.8123
2015	12	19	3	45	33	0.3	3.9	0.66	97.5	84.6063	52.3201
2015	12	19	3	55	33	0.3	3.9	0.64	98	84.6063	50.9989
2015	12	19	4	5	33	0.3	3.9	0.71	96.9	84.6063	56.8123
2015	12	19	4	15	33	0.3	3.9	0.66	96.8	84.6063	53.1129
2015	12	19	4	25	33	0.3	3.9	0.71	96.9	84.6063	56.548
2015	12	19	4	35	33	0.3	3.9	0.68	98.4	84.6063	53.9056
2015	12	19	4	45	33	0.3	3.9	0.67	97.1	84.6063	53.3771
2015	12	19	4	55	33	0.3	3.9	0.69	97.4	84.6063	55.2268

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	5	5	33	0.3	3.9	0.69	95.7	84.6063	55.2268
2015	12	19	5	15	33	0.3	3.9	0.63	98.1	84.6063	49.942
2015	12	19	5	25	33	0.3	3.9	0.64	95.3	84.6063	50.9989
2015	12	19	5	35	33	0.3	3.9	0.67	95	84.6063	53.9056
2015	12	19	5	45	33	0.3	3.9	0.66	97.8	84.6063	52.3202
2015	12	19	5	55	33	0.3	3.9	0.63	95.4	84.6063	50.2062
2015	12	19	6	5	33	0.3	3.9	0.62	93.6	84.6063	50.2062
2015	12	19	6	15	33	0.3	3.9	0.64	94.4	84.6063	51.2632
2015	12	19	6	25	33	0.3	3.9	0.66	95.7	84.6063	52.5844
2015	12	19	6	35	33	0.3	3.9	0.66	94.9	84.6063	52.5844
2015	12	19	6	45	33	0.3	3.9	0.68	96.1	84.6063	54.6983
2015	12	19	6	55	33	0.3	3.9	0.64	94.4	84.6063	50.9989
2015	12	19	7	5	33	0.3	3.9	0.67	96.2	84.6719	53.9492
2015	12	19	7	15	33	0.3	3.9	0.69	95.2	84.6063	54.9626
2015	12	19	7	25	33	0.3	3.9	0.69	95.2	84.6063	54.9626
2015	12	19	7	35	33	0.3	3.9	0.71	98.8	84.6719	56.3294
2015	12	19	7	45	33	0.3	3.9	0.68	97.5	84.6719	54.2137
2015	12	19	7	55	33	0.3	3.9	0.66	94.8	84.6719	53.1558
2015	12	19	8	5	33	0.3	3.9	0.66	96	84.6719	52.8913
2015	12	19	8	15	33	0.3	3.9	0.7	95.1	84.6719	56.0648
2015	12	19	8	25	33	0.3	3.9	0.65	95.8	84.6719	52.0979
2015	12	19	8	35	33	0.3	3.9	0.69	95.2	84.6719	55.2713
2015	12	19	8	45	33	0.3	3.9	0.7	96	84.6719	55.8002
2015	12	19	8	55	33	0.3	3.9	0.67	95.9	84.6719	53.6845
2015	12	19	9	5	33	0.3	3.9	0.65	97.9	84.6719	51.5688
2015	12	19	9	15	33	0.3	3.9	0.63	95.7	84.6719	50.7754
2015	12	19	9	25	33	0.3	3.9	0.67	95.1	84.6719	53.6844
2015	12	19	9	35	33	0.3	3.9	0.66	94.8	84.6719	53.1555
2015	12	19	9	45	33	0.3	3.9	0.65	96.6	84.6719	52.3621
2015	12	19	9	55	33	0.3	3.9	0.68	95	84.7375	54.2571
2015	12	19	10	5	33	0.3	3.9	0.62	97.3	84.7375	49.493
2015	12	19	10	15	33	0.3	3.9	0.68	97.5	84.7375	53.9923
2015	12	19	10	25	33	0.3	3.9	0.65	96.3	84.7375	52.4043
2015	12	19	10	35	33	0.3	3.9	0.67	98.2	84.7375	53.4629
2015	12	19	10	45	33	0.3	3.9	0.65	94.3	84.7375	52.6689
2015	12	19	10	55	33	0.3	3.9	0.65	94	84.7375	52.6689
2015	12	19	11	5	33	0.3	3.9	0.67	95.3	84.7375	53.9923
2015	12	19	11	15	33	0.3	3.9	0.63	94.5	84.7375	50.2869
2015	12	19	11	25	33	0.3	3.9	0.66	95.2	84.7375	52.6689
2015	12	19	11	35	33	0.3	3.9	0.66	99.1	84.7375	52.6689
2015	12	19	11	45	33	0.3	3.9	0.65	94.6	84.7375	52.1395
2015	12	19	11	55	33	0.3	3.9	0.67	98.7	84.7375	53.4628
2015	12	19	12	5	33	0.3	3.9	0.69	97.4	84.7375	55.3156
2015	12	19	12	15	33	0.3	3.9	0.72	97.9	84.7375	57.433
2015	12	19	12	25	33	0.3	3.9	0.62	94.9	84.7375	49.493
2015	12	19	12	35	33	0.3	3.9	0.61	93.7	84.7375	49.4931

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	12	45	33	0.3	3.9	0.65	97.5	84.6719	52.0976
2015	12	19	12	55	33	0.3	3.9	0.66	94.3	84.7375	52.9336
2015	12	19	13	5	33	0.3	3.9	0.65	95.2	84.7375	52.1397
2015	12	19	13	15	33	0.3	3.9	0.63	96.2	84.7375	50.8164
2015	12	19	13	25	33	0.3	3.9	0.65	96.3	84.7375	52.4044
2015	12	19	13	35	33	0.3	3.9	0.65	95.2	84.7375	52.4044
2015	12	19	13	45	33	0.3	3.9	0.69	97.4	84.7375	55.3157
2015	12	19	13	55	33	0.3	3.9	0.68	94.4	84.7375	55.051
2015	12	19	14	5	33	0.3	3.9	0.66	94.2	84.7375	53.4631
2015	12	19	14	15	33	0.3	3.9	0.7	93.8	84.6719	56.3289
2015	12	19	14	25	33	0.3	3.9	0.7	97.5	84.7375	56.1099
2015	12	19	14	35	33	0.3	3.9	0.67	95.9	84.6719	53.42
2015	12	19	14	45	33	0.3	3.9	0.67	97	84.6719	53.9489
2015	12	19	14	55	33	0.3	3.9	0.68	97	84.6719	54.2135
2015	12	19	15	5	33	0.3	3.9	0.65	97.5	84.6719	52.0978
2015	12	19	15	15	33	0.3	3.9	0.69	99.1	84.6719	54.7424
2015	12	19	15	25	33	0.3	3.9	0.67	96.2	84.6719	53.9491
2015	12	19	15	35	33	0.3	3.9	0.69	97.1	84.6719	55.5358
2015	12	19	15	45	33	0.3	3.9	0.67	96.7	84.6063	53.6412
2015	12	19	15	55	33	0.3	3.9	0.62	95.8	84.6063	49.6776
2015	12	19	16	5	33	0.3	3.9	0.66	96.3	84.6719	52.6268
2015	12	19	16	15	33	0.3	3.9	0.71	96.9	84.6719	56.5937
2015	12	19	16	25	33	0.3	3.9	0.7	96.2	84.6719	56.0648
2015	12	19	16	35	33	0.3	3.9	0.67	93.6	84.6719	54.2136
2015	12	19	16	45	33	0.3	3.9	0.66	96.2	84.6719	53.1558
2015	12	19	16	55	33	0.3	3.9	0.69	94.1	84.6719	55.8004
2015	12	19	17	5	33	0.3	3.9	0.69	94.1	84.6719	55.5359
2015	12	19	17	15	33	0.3	3.9	0.68	96.3	84.6719	54.7425
2015	12	19	17	25	33	0.3	3.9	0.68	95.3	84.6719	54.2136
2015	12	19	17	35	33	0.3	3.9	0.67	97.1	84.6719	53.4203
2015	12	19	17	45	33	0.3	3.9	0.7	96.7	84.6719	56.3293
2015	12	19	17	55	33	0.3	3.9	0.67	94.5	84.6719	53.6847
2015	12	19	18	5	33	0.3	3.9	0.69	94.1	84.6719	55.5359
2015	12	19	18	15	33	0.3	3.9	0.67	97	84.6719	53.9492
2015	12	19	18	25	33	0.3	3.9	0.65	96.3	84.6719	52.3624
2015	12	19	18	35	33	0.3	3.9	0.68	97.8	84.6719	53.9492
2015	12	19	18	45	33	0.3	3.9	0.71	97.7	84.6719	56.5937
2015	12	19	18	55	33	0.3	3.9	0.71	96.9	84.6719	56.8581
2015	12	19	19	5	33	0.3	3.9	0.66	96.3	84.6719	52.6268
2015	12	19	19	15	33	0.3	3.9	0.68	96.4	84.6719	54.2136
2015	12	19	19	25	33	0.3	3.9	0.65	95.5	84.6719	52.0979
2015	12	19	19	35	33	0.3	3.9	0.68	94.4	84.6719	55.007
2015	12	19	19	45	33	0.3	3.9	0.69	96	84.6719	55.2714
2015	12	19	19	55	33	0.3	3.9	0.73	97.2	84.6719	58.4449
2015	12	19	20	5	33	0.3	3.9	0.72	96.3	84.6719	57.3871
2015	12	19	20	15	33	0.3	3.9	0.69	95.8	84.6719	55.0069

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	19	20	25	33	0.3	3.9	0.64	94.4	84.6719	51.8335
2015	12	19	20	35	33	0.3	3.9	0.68	96.1	84.6719	54.2136
2015	12	19	20	45	33	0.3	3.9	0.69	95.2	84.6719	55.007
2015	12	19	20	55	33	0.3	3.9	0.7	98.1	84.6719	56.0648
2015	12	19	21	5	33	0.3	3.9	0.7	95.9	84.6719	56.0648
2015	12	19	21	15	33	0.3	3.9	0.69	96.3	84.6719	55.007
2015	12	19	21	25	33	0.3	3.9	0.67	93.4	84.6719	53.9491
2015	12	19	21	35	33	0.3	3.9	0.69	94.4	84.6063	55.2267
2015	12	19	21	45	33	0.3	3.9	0.65	94.4	84.6719	52.0979
2015	12	19	21	55	33	0.3	3.9	0.65	93.8	84.6719	52.3624
2015	12	19	22	5	33	0.3	3.9	0.64	93.8	84.6719	51.569
2015	12	19	22	15	33	0.3	3.9	0.67	96.2	84.6719	53.4202
2015	12	19	22	25	33	0.3	3.9	0.69	96.8	84.6719	55.5359
2015	12	19	22	35	33	0.3	3.9	0.68	93.6	84.6063	54.9625
2015	12	19	22	45	33	0.3	3.9	0.66	95.5	84.6063	52.5843
2015	12	19	22	55	33	0.3	3.9	0.69	95.7	84.6719	55.2714
2015	12	19	23	5	33	0.3	3.9	0.67	98.2	84.6063	53.1128
2015	12	19	23	15	33	0.3	3.9	0.67	97.3	84.6719	53.4202
2015	12	19	23	25	33	0.3	3.9	0.72	95.5	84.6063	57.8692
2015	12	19	23	35	33	0.3	3.9	0.69	95.2	84.6063	54.9625
2015	12	19	23	45	33	0.3	3.9	0.7	98.1	84.6063	56.0195
2015	12	19	23	55	33	0.3	3.9	0.68	98.6	84.6063	53.9055
2015	12	20	0	5	33	0.3	3.9	0.72	97.9	84.6063	57.3407
2015	12	20	0	15	33	0.3	3.9	0.66	99.4	84.6063	52.5843
2015	12	20	0	25	33	0.3	3.9	0.65	98.7	84.6063	51.7916
2015	12	20	0	35	33	0.3	3.9	0.67	98.4	84.6063	53.6413
2015	12	20	0	45	33	0.3	3.9	0.67	98.4	84.6063	53.3771
2015	12	20	0	55	33	0.3	3.9	0.65	98.1	84.6063	52.0558
2015	12	20	1	5	33	0.3	3.9	0.71	96.4	84.6063	56.548
2015	12	20	1	15	33	0.3	3.9	0.68	98.3	84.6063	54.1698
2015	12	20	1	25	33	0.3	3.9	0.69	98.7	84.6063	54.9625
2015	12	20	1	35	33	0.3	3.9	0.66	96	84.6063	53.1128
2015	12	20	1	45	33	0.3	3.9	0.63	100.3	84.6063	49.6777
2015	12	20	1	55	33	0.3	3.9	0.64	95.6	84.6063	51.5274
2015	12	20	2	5	33	0.3	3.9	0.63	99	84.6063	50.2062
2015	12	20	2	15	33	0.3	3.9	0.65	96.9	84.6063	52.0559
2015	12	20	2	25	33	0.3	3.9	0.66	97.8	84.6063	52.3201
2015	12	20	2	35	33	0.3	3.9	0.69	98.7	84.6063	54.9625
2015	12	20	2	45	33	0.3	3.9	0.64	97.1	84.6063	50.9989
2015	12	20	2	55	33	0.3	3.9	0.66	98	84.6063	52.5844
2015	12	20	3	5	33	0.3	3.9	0.64	97.7	84.6063	50.7347
2015	12	20	3	15	33	0.3	3.9	0.66	96.2	84.6063	53.1129
2015	12	20	3	25	33	0.3	3.9	0.67	99	84.6063	53.6413
2015	12	20	3	35	33	0.3	3.9	0.62	96.9	84.6063	49.9419
2015	12	20	3	45	33	0.3	3.9	0.66	97.7	84.6063	52.8486
2015	12	20	3	55	33	0.3	3.9	0.65	99.6	84.6063	51.7916

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	4	5	33	0.3	3.9	0.67	98.4	84.6063	53.3771
2015	12	20	4	15	33	0.3	3.9	0.68	97.2	84.6063	54.1698
2015	12	20	4	25	33	0.3	3.9	0.65	95.2	84.6063	52.0559
2015	12	20	4	35	33	0.3	3.9	0.67	97.7	84.6063	53.1129
2015	12	20	4	45	33	0.3	3.9	0.68	95	84.6063	54.4341
2015	12	20	4	55	33	0.3	3.9	0.68	97.2	84.6063	54.6983
2015	12	20	5	5	33	0.3	3.9	0.66	98.5	84.6063	52.8486
2015	12	20	5	15	33	0.3	3.9	0.64	96.2	84.6063	50.9989
2015	12	20	5	25	33	0.3	3.9	0.67	99.3	84.6063	53.3771
2015	12	20	5	35	33	0.3	3.9	0.68	95.3	84.6063	54.1698
2015	12	20	5	45	33	0.3	3.9	0.66	99.7	84.6063	52.5844
2015	12	20	5	55	33	0.3	3.9	0.64	94.4	84.6063	50.9989
2015	12	20	6	5	33	0.3	3.9	0.63	99	84.6063	50.2062
2015	12	20	6	15	33	0.3	3.9	0.63	97.5	84.6063	50.4704
2015	12	20	6	25	33	0.3	3.9	0.71	96.9	84.6063	56.8123
2015	12	20	6	35	33	0.3	3.9	0.64	97	84.6063	51.5274
2015	12	20	6	45	33	0.3	3.9	0.69	97.1	84.6063	54.9626
2015	12	20	6	55	33	0.3	3.9	0.66	95.4	84.6063	53.1129
2015	12	20	7	5	33	0.3	3.9	0.64	98	84.6063	50.9989
2015	12	20	7	15	33	0.3	3.9	0.67	99.3	84.6719	53.4203
2015	12	20	7	25	33	0.3	3.9	0.62	96.4	84.6063	49.4135
2015	12	20	7	35	33	0.3	3.9	0.64	96.5	84.6719	51.3047
2015	12	20	7	45	33	0.3	3.9	0.7	97	84.6063	56.0195
2015	12	20	7	55	33	0.3	3.9	0.62	95.8	84.6719	49.4534
2015	12	20	8	5	33	0.3	3.9	0.66	97.4	84.6719	53.1558
2015	12	20	8	15	33	0.3	3.9	0.63	98.1	84.6719	50.2467
2015	12	20	8	25	33	0.3	3.9	0.64	100	84.6719	50.7756
2015	12	20	8	35	33	0.3	3.9	0.67	97.9	84.6719	53.4201
2015	12	20	8	45	33	0.3	3.9	0.7	98.1	84.6719	55.5358
2015	12	20	8	55	33	0.3	3.9	0.65	97.2	84.6719	52.0979
2015	12	20	9	5	33	0.3	3.9	0.64	96.8	84.6719	51.3045
2015	12	20	9	15	33	0.3	3.9	0.62	95.4	84.7375	50.0225
2015	12	20	9	25	33	0.3	3.9	0.62	95.7	84.6719	49.9821
2015	12	20	9	35	33	0.3	3.9	0.61	95.8	84.6719	49.1888
2015	12	20	9	45	33	0.3	3.9	0.62	95.4	84.6719	49.9821
2015	12	20	9	55	33	0.3	3.9	0.66	97.5	84.7375	52.4045
2015	12	20	10	5	33	0.3	3.9	0.66	98.6	84.7375	52.4045
2015	12	20	10	15	33	0.3	3.9	0.65	96.6	84.7375	52.4045
2015	12	20	10	25	33	0.3	3.9	0.64	96.5	84.7375	51.0811
2015	12	20	10	35	33	0.3	3.9	0.67	98.1	84.7375	53.7278
2015	12	20	10	45	33	0.3	3.9	0.64	99.5	84.7375	50.8165
2015	12	20	10	55	33	0.3	3.9	0.68	95	84.7375	54.5219
2015	12	20	11	5	33	0.3	3.9	0.62	95.2	84.7375	49.7578
2015	12	20	11	15	33	0.3	3.9	0.63	96.9	84.7375	50.5517
2015	12	20	11	25	33	0.3	3.9	0.67	95.1	84.7375	53.7276
2015	12	20	11	35	33	0.3	3.9	0.63	94.5	84.7375	50.287

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	11	45	33	0.3	3.9	0.63	97.5	84.7375	50.287
2015	12	20	11	55	33	0.3	3.9	0.66	93.7	84.7375	52.9337
2015	12	20	12	5	33	0.3	3.9	0.64	96.5	84.7375	51.0811
2015	12	20	12	15	33	0.3	3.9	0.64	95.3	84.7375	51.6103
2015	12	20	12	25	33	0.3	3.9	0.68	95.3	84.7375	54.257
2015	12	20	12	35	33	0.3	3.9	0.65	96.1	84.8032	52.1818
2015	12	20	12	45	33	0.3	3.9	0.63	98.1	84.8032	50.3275
2015	12	20	12	55	33	0.3	3.9	0.67	93.1	84.8032	54.0359
2015	12	20	13	5	33	0.3	3.9	0.67	97.3	84.8032	53.771
2015	12	20	13	15	33	0.3	3.9	0.64	93.8	84.8032	51.652
2015	12	20	13	25	33	0.3	3.9	0.66	94.6	84.7375	52.9336
2015	12	20	13	35	33	0.3	3.9	0.66	95.4	84.7375	53.1983
2015	12	20	13	45	33	0.3	3.9	0.66	95.4	84.7375	52.9337
2015	12	20	13	55	33	0.3	3.9	0.65	96.1	84.7375	52.4044
2015	12	20	14	5	33	0.3	3.9	0.63	99	84.7375	50.2871
2015	12	20	14	15	33	0.3	3.9	0.63	96.2	84.7375	50.8164
2015	12	20	14	25	33	0.3	3.9	0.67	95.9	84.7375	53.4631
2015	12	20	14	35	33	0.3	3.9	0.64	95.6	84.6719	51.3043
2015	12	20	14	45	33	0.3	3.9	0.67	95.9	84.6719	53.42
2015	12	20	14	55	33	0.3	3.9	0.69	94.4	84.6719	55.2712
2015	12	20	15	5	33	0.3	3.9	0.62	96.9	84.6719	49.9821
2015	12	20	15	15	33	0.3	3.9	0.64	96.5	84.6719	51.04
2015	12	20	15	25	33	0.3	3.9	0.66	94.3	84.6719	52.8912
2015	12	20	15	35	33	0.3	3.9	0.66	97.7	84.6719	52.8912
2015	12	20	15	45	33	0.3	3.9	0.64	95	84.6719	51.3045
2015	12	20	15	55	33	0.3	3.9	0.69	94.9	84.6719	55.2713
2015	12	20	16	5	33	0.3	3.9	0.66	95.7	84.6719	52.6268
2015	12	20	16	15	33	0.3	3.9	0.65	96.4	84.6719	52.0979
2015	12	20	16	25	33	0.3	3.9	0.68	96.1	84.6719	54.7424
2015	12	20	16	35	33	0.3	3.9	0.65	95	84.6719	51.8334
2015	12	20	16	45	33	0.3	3.9	0.62	99.1	84.6719	49.7178
2015	12	20	16	55	33	0.3	3.9	0.66	95.4	84.6719	53.1557
2015	12	20	17	5	33	0.3	3.9	0.69	97.1	84.6719	55.2714
2015	12	20	17	15	33	0.3	3.9	0.65	93.8	84.6719	52.0979
2015	12	20	17	25	33	0.3	3.9	0.63	94.5	84.6719	50.2467
2015	12	20	17	35	33	0.3	3.9	0.67	98.4	84.6719	53.4202
2015	12	20	17	45	33	0.3	3.9	0.63	94.5	84.6719	50.5111
2015	12	20	17	55	33	0.3	3.9	0.66	96.3	84.6719	52.6268
2015	12	20	18	5	33	0.3	3.9	0.65	94.6	84.6719	52.0979
2015	12	20	18	15	33	0.3	3.9	0.63	98.1	84.6719	49.9822
2015	12	20	18	25	33	0.3	3.9	0.68	96.3	84.6719	54.7424
2015	12	20	18	35	33	0.3	3.9	0.68	94.1	84.6719	54.7424
2015	12	20	18	45	33	0.3	3.9	0.64	97.7	84.6719	51.0401
2015	12	20	18	55	33	0.3	3.9	0.62	96.3	84.6719	49.9822
2015	12	20	19	5	33	0.3	3.9	0.59	97.1	84.6719	46.8088
2015	12	20	19	15	33	0.3	3.9	0.69	96	84.6719	55.0069

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	20	19	25	33	0.3	3.9	0.68	98.3	84.6719	54.2135
2015	12	20	19	35	33	0.3	3.9	0.65	95.8	84.6719	52.0979
2015	12	20	19	45	33	0.3	3.9	0.66	97.4	84.6719	52.6268
2015	12	20	19	55	33	0.3	3.9	0.65	94	84.6719	52.6268
2015	12	20	20	5	33	0.3	3.9	0.66	98.3	84.6719	52.3624
2015	12	20	20	15	33	0.3	3.9	0.65	96.4	84.6719	52.0979
2015	12	20	20	25	33	0.3	3.9	0.66	99.2	84.6063	52.32
2015	12	20	20	35	33	0.3	3.9	0.61	99.4	84.6063	48.0921
2015	12	20	20	45	33	0.3	3.9	0.65	97.9	84.6719	51.569
2015	12	20	20	55	33	0.3	3.9	0.65	98.4	84.6719	51.8335
2015	12	20	21	5	33	0.3	3.9	0.62	97.3	84.6719	49.4534
2015	12	20	21	15	33	0.3	3.9	0.66	96	84.6719	52.8913
2015	12	20	21	25	33	0.3	3.9	0.64	97.1	84.6719	51.0401
2015	12	20	21	35	33	0.3	3.9	0.64	96.8	84.6719	51.0401
2015	12	20	21	45	33	0.3	3.9	0.64	97.3	84.6063	51.2631
2015	12	20	21	55	33	0.3	3.9	0.67	97.7	84.6063	53.1128
2015	12	20	22	5	33	0.3	3.9	0.65	97.2	84.6063	52.0558
2015	12	20	22	15	33	0.3	3.9	0.65	97.6	84.6719	51.8335
2015	12	20	22	25	33	0.3	3.9	0.67	95.3	84.6719	53.9492
2015	12	20	22	35	33	0.3	3.9	0.69	96	84.6063	54.9625
2015	12	20	22	45	33	0.3	3.9	0.63	99.6	84.6063	50.2062
2015	12	20	22	55	33	0.3	3.9	0.68	96.9	84.6063	54.6983
2015	12	20	23	5	33	0.3	3.9	0.64	97.7	84.6063	50.9989
2015	12	20	23	15	33	0.3	3.9	0.63	97.5	84.6063	50.4704
2015	12	20	23	25	33	0.3	3.9	0.65	95.2	84.6063	52.3201
2015	12	20	23	35	33	0.3	3.9	0.66	94.6	84.6063	52.8486
2015	12	20	23	45	33	0.3	3.9	0.64	98	84.6063	50.9989
2015	12	20	23	55	33	0.3	3.9	0.61	96.1	84.6063	49.1492
2015	12	21	0	5	33	0.3	3.9	0.61	98	84.6063	48.6207
2015	12	21	0	15	33	0.3	3.9	0.67	94.8	84.6063	53.9056
2015	12	21	0	25	33	0.3	3.9	0.62	98.9	84.6063	49.1492
2015	12	21	0	35	33	0.3	3.9	0.65	96.4	84.6063	51.7916
2015	12	21	0	45	33	0.3	3.9	0.66	97.4	84.6063	52.8486
2015	12	21	0	55	33	0.3	3.9	0.62	96.1	84.6719	49.7179
2015	12	21	1	5	33	0.3	3.9	0.63	97.2	84.6063	50.2062
2015	12	21	1	15	33	0.3	3.9	0.63	97.8	84.6063	50.2062
2015	12	21	1	25	33	0.3	3.9	0.63	97.2	84.6063	50.2062
2015	12	21	1	35	33	0.3	3.9	0.64	95.9	84.6063	51.2632
2015	12	21	1	45	33	0.3	3.9	0.67	97.6	84.6063	53.6413
2015	12	21	1	55	33	0.3	3.9	0.65	99	84.6063	51.7916
2015	12	21	2	5	33	0.3	3.9	0.62	97.9	84.6063	49.4135
2015	12	21	2	15	33	0.3	3.9	0.67	98.5	84.6063	53.1129
2015	12	21	2	25	33	0.3	3.9	0.64	96.2	84.6063	50.9989
2015	12	21	2	35	33	0.3	3.9	0.63	96.6	84.6063	50.4704
2015	12	21	2	45	33	0.3	3.9	0.64	98.2	84.6063	51.2632
2015	12	21	2	55	33	0.3	3.9	0.67	94.2	84.6719	53.9492

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	3	5	33	0.3	3.9	0.62	95.7	84.6063	49.942
2015	12	21	3	15	33	0.3	3.9	0.68	99.5	84.6063	53.6414
2015	12	21	3	25	33	0.3	3.9	0.62	95.5	84.6719	49.4535
2015	12	21	3	35	33	0.3	3.9	0.66	98.3	84.6063	52.8486
2015	12	21	3	45	33	0.3	3.9	0.64	97.7	84.6063	50.7347
2015	12	21	3	55	33	0.3	3.9	0.64	96.8	84.6063	50.9989
2015	12	21	4	5	33	0.3	3.9	0.64	95	84.6063	50.9989
2015	12	21	4	15	33	0.3	3.9	0.64	95	84.6719	51.3047
2015	12	21	4	25	33	0.3	3.9	0.67	97.7	84.6063	53.1129
2015	12	21	4	35	33	0.3	3.9	0.63	96.8	84.6063	50.7347
2015	12	21	4	45	33	0.3	3.9	0.66	97.8	84.6063	52.3201
2015	12	21	4	55	33	0.3	3.9	0.64	99.1	84.6719	51.0402
2015	12	21	5	5	33	0.3	3.9	0.63	97.5	84.6063	50.4704
2015	12	21	5	15	33	0.3	3.9	0.64	94.4	84.6719	51.0402
2015	12	21	5	25	33	0.3	3.9	0.64	96.8	84.6719	51.0402
2015	12	21	5	35	33	0.3	3.9	0.66	98.3	84.6719	52.8914
2015	12	21	5	45	33	0.3	3.9	0.64	96.5	84.6719	51.0402
2015	12	21	5	55	33	0.3	3.9	0.61	96.2	84.6719	48.9246
2015	12	21	6	5	33	0.3	3.9	0.62	94.6	84.6719	49.7179
2015	12	21	6	15	33	0.3	3.9	0.62	99.2	84.6719	49.189
2015	12	21	6	25	33	0.3	3.9	0.65	97.6	84.6719	51.8336
2015	12	21	6	35	33	0.3	3.9	0.67	99	84.6719	53.1559
2015	12	21	6	45	33	0.3	3.9	0.63	96.8	84.6719	50.7758
2015	12	21	6	55	33	0.3	3.9	0.67	95.9	84.6719	53.6848
2015	12	21	7	5	33	0.3	3.9	0.68	99.7	84.6719	53.9492
2015	12	21	7	15	33	0.3	3.9	0.64	97.4	84.6719	51.0402
2015	12	21	7	25	33	0.3	3.9	0.62	100.4	84.6719	49.189
2015	12	21	7	35	33	0.3	3.9	0.64	96.8	84.6719	51.0402
2015	12	21	7	45	33	0.3	3.9	0.66	98.6	84.6719	52.3625
2015	12	21	7	55	33	0.3	3.9	0.66	97.2	84.6719	52.6269
2015	12	21	8	5	33	0.3	3.9	0.62	96.9	84.6719	49.9823
2015	12	21	8	15	33	0.3	3.9	0.63	98.9	84.6719	50.5112
2015	12	21	8	25	33	0.3	3.9	0.62	96.3	84.6719	49.9823
2015	12	21	8	35	33	0.3	3.9	0.63	98.1	84.6719	50.2468
2015	12	21	8	45	33	0.3	3.9	0.64	100.1	84.6719	50.5112
2015	12	21	8	55	33	0.3	3.9	0.63	95.1	84.7375	50.5519
2015	12	21	9	5	33	0.3	3.9	0.66	96	84.7375	52.9339
2015	12	21	9	15	33	0.3	3.9	0.63	97.5	84.7375	50.5519
2015	12	21	9	25	33	0.3	3.9	0.64	95.6	84.7375	51.6106
2015	12	21	9	35	33	0.3	3.9	0.6	97.5	84.7375	48.1698
2015	12	21	9	45	33	0.3	3.9	0.63	93.9	84.7375	50.5518
2015	12	21	9	55	33	0.3	3.9	0.59	98.6	84.7375	47.3757
2015	12	21	10	5	33	0.3	3.9	0.65	98.5	84.7375	51.6104
2015	12	21	10	15	33	0.3	3.9	0.62	97.9	84.7375	49.4931
2015	12	21	10	25	33	0.3	3.9	0.65	98.4	84.7375	52.1398
2015	12	21	10	35	33	0.3	3.9	0.66	97.8	84.7375	52.4045

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	10	45	33	0.3	3.9	0.64	95.6	84.7375	51.3458
2015	12	21	10	55	33	0.3	3.9	0.64	95.6	84.7375	51.6104
2015	12	21	11	5	33	0.3	3.9	0.63	96	84.7375	50.2871
2015	12	21	11	15	33	0.3	3.9	0.64	94.7	84.7375	51.3458
2015	12	21	11	25	33	0.3	3.9	0.66	97.2	84.7375	52.6692
2015	12	21	11	35	33	0.3	3.9	0.67	96.4	84.7375	53.9925
2015	12	21	11	45	33	0.3	3.9	0.71	96.4	84.7375	56.6392
2015	12	21	11	55	33	0.3	3.9	0.68	98.3	84.7375	54.2572
2015	12	21	12	5	33	0.3	3.9	0.67	96.7	84.7375	53.7279
2015	12	21	12	15	33	0.3	3.9	0.68	97	84.6719	54.2134
2015	12	21	12	25	33	0.3	3.9	0.64	95.9	84.6719	51.3044
2015	12	21	12	35	33	0.3	3.9	0.63	96.9	84.7375	50.2872
2015	12	21	12	45	33	0.3	3.9	0.68	96.9	84.6719	54.7423
2015	12	21	12	55	33	0.3	3.9	0.64	95.9	84.7375	51.0812
2015	12	21	13	5	33	0.3	3.9	0.65	96.1	84.7375	52.1399
2015	12	21	13	15	33	0.3	3.9	0.65	95.8	84.6719	51.8333
2015	12	21	13	25	33	0.3	3.9	0.63	97.8	84.7375	50.2872
2015	12	21	13	35	33	0.3	3.9	0.65	97.5	84.6719	52.0978
2015	12	21	13	45	33	0.3	3.9	0.66	99.8	84.7375	52.1399
2015	12	21	13	55	33	0.3	3.9	0.7	97.5	84.7375	56.11
2015	12	21	14	5	33	0.3	3.9	0.66	94.6	84.6719	52.8911
2015	12	21	14	15	33	0.3	3.9	0.64	96.5	84.7375	51.0812
2015	12	21	14	25	33	0.3	3.9	0.69	96.6	84.7375	55.0513
2015	12	21	14	35	33	0.3	3.9	0.71	97.4	84.6719	56.858
2015	12	21	14	45	33	0.3	3.9	0.67	97.1	84.7375	53.4633
2015	12	21	14	55	33	0.3	3.9	0.65	94.4	84.6719	52.0978
2015	12	21	15	5	33	0.3	3.9	0.68	97.2	84.6719	54.7424
2015	12	21	15	15	33	0.3	3.9	0.69	96.8	84.6719	55.5358
2015	12	21	15	25	33	0.3	3.9	0.69	95.2	84.6719	55.2713
2015	12	21	15	35	33	0.3	3.9	0.75	96	84.6719	60.296
2015	12	21	15	45	33	0.3	3.9	0.7	98.1	84.6719	56.0647
2015	12	21	15	55	33	0.3	3.9	0.73	98.6	84.6719	57.9159
2015	12	21	16	5	33	0.3	3.9	0.68	95	84.6719	54.478
2015	12	21	16	15	33	0.3	3.9	0.69	97.1	84.6719	55.0069
2015	12	21	16	25	33	0.3	3.9	0.7	98.4	84.6719	55.5358
2015	12	21	16	35	33	0.3	3.9	0.67	98.1	84.6719	53.6846
2015	12	21	16	45	33	0.3	3.9	0.68	95.6	84.6719	54.2136
2015	12	21	16	55	33	0.3	3.9	0.67	96.2	84.6719	53.6846
2015	12	21	17	5	33	0.3	3.9	0.66	96.3	84.6719	52.6268
2015	12	21	17	15	33	0.3	3.9	0.68	97.2	84.6719	54.2136
2015	12	21	17	25	33	0.3	3.9	0.66	96.5	84.6719	53.1557
2015	12	21	17	35	33	0.3	3.9	0.69	95.5	84.6719	55.0069
2015	12	21	17	45	33	0.3	3.9	0.7	97.3	84.6719	55.8003
2015	12	21	17	55	33	0.3	3.9	0.65	96.7	84.6719	52.0979
2015	12	21	18	5	33	0.3	3.9	0.66	96.2	84.6719	53.1557
2015	12	21	18	15	33	0.3	3.9	0.69	97.4	84.6719	55.2714

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	21	18	25	33	0.3	3.9	0.7	97.6	84.6719	55.5358
2015	12	21	18	35	33	0.3	3.9	0.68	96.3	84.6719	54.7425
2015	12	21	18	45	33	0.3	3.9	0.66	97.2	84.6719	52.6268
2015	12	21	18	55	33	0.3	3.9	0.69	99	84.6719	55.0069
2015	12	21	19	5	33	0.3	3.9	0.7	98.6	84.7375	55.8454
2015	12	21	19	15	33	0.3	3.9	0.69	96	84.6719	55.0069
2015	12	21	19	25	33	0.3	3.9	0.66	97.2	84.6719	52.6268
2015	12	21	19	35	33	0.3	3.9	0.67	96.7	84.7375	53.7281
2015	12	21	19	45	33	0.3	3.9	0.68	97.8	84.6719	54.2136
2015	12	21	19	55	33	0.3	3.9	0.68	96.1	84.6719	54.478
2015	12	21	20	5	33	0.3	3.9	0.68	98.3	84.6719	54.2135
2015	12	21	20	15	33	0.3	3.9	0.68	98.4	84.6719	53.9491
2015	12	21	20	25	33	0.3	3.9	0.68	95	84.6719	54.2136
2015	12	21	20	35	33	0.3	3.9	0.69	95.2	84.6719	55.2714
2015	12	21	20	45	33	0.3	3.9	0.66	94	84.6719	53.4202
2015	12	21	20	55	33	0.3	3.9	0.68	96.4	84.6719	54.2136
2015	12	21	21	5	33	0.3	3.9	0.71	96.9	84.6719	57.1226
2015	12	21	21	15	33	0.3	3.9	0.64	96.8	84.6719	51.0401
2015	12	21	21	25	33	0.3	3.9	0.66	96	84.6719	52.8913
2015	12	21	21	35	33	0.3	3.9	0.65	98.9	84.6719	52.0979
2015	12	21	21	45	33	0.3	3.9	0.66	96	84.6719	53.1557
2015	12	21	21	55	33	0.3	3.9	0.69	96.3	84.6719	55.5359
2015	12	21	22	5	33	0.3	3.9	0.66	96.6	84.7375	52.6694
2015	12	21	22	15	33	0.3	3.9	0.69	97.1	84.6719	55.5359
2015	12	21	22	25	33	0.3	3.9	0.66	98.3	84.6719	52.3624
2015	12	21	22	35	33	0.3	3.9	0.69	95.2	84.6719	55.2714
2015	12	21	22	45	33	0.3	3.9	0.68	97.8	84.7375	54.2574
2015	12	21	22	55	33	0.3	3.9	0.66	94.9	84.7375	52.6694
2015	12	21	23	5	33	0.3	3.9	0.67	96.2	84.6719	53.6847
2015	12	21	23	15	33	0.3	3.9	0.69	94.9	84.6719	55.8003
2015	12	21	23	25	33	0.3	3.9	0.69	98.2	84.6719	55.2714
2015	12	21	23	35	33	0.3	3.9	0.68	99.2	84.6719	53.9491
2015	12	21	23	45	33	0.3	3.9	0.66	98.3	84.6719	52.3624
2015	12	21	23	55	33	0.3	3.9	0.66	97.1	84.6719	53.1558
2015	12	22	0	5	33	0.3	3.9	0.63	98.7	84.6719	50.2467
2015	12	22	0	15	33	0.3	3.9	0.69	97.1	84.6719	55.5359
2015	12	22	0	25	33	0.3	3.9	0.7	97.8	84.6719	56.0648
2015	12	22	0	35	33	0.3	3.9	0.68	100.8	84.6719	53.9491
2015	12	22	0	45	33	0.3	3.9	0.68	98.9	84.6719	54.2136
2015	12	22	0	55	33	0.3	3.9	0.68	96.9	84.6719	54.7425
2015	12	22	1	5	33	0.3	3.9	0.67	97	84.6719	53.9491
2015	12	22	1	15	33	0.3	3.9	0.68	97.2	84.6719	54.478
2015	12	22	1	25	33	0.3	3.9	0.68	95.2	84.6719	54.7425
2015	12	22	1	35	33	0.3	3.9	0.7	97.8	84.6719	56.0648
2015	12	22	1	45	33	0.3	3.9	0.67	98.1	84.6719	53.6847
2015	12	22	1	55	33	0.3	3.9	0.71	98.8	84.6719	56.3293

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	2	5	33	0.3	3.9	0.69	99.6	84.6719	55.007
2015	12	22	2	15	33	0.3	3.9	0.69	98.2	84.6719	54.7425
2015	12	22	2	25	33	0.3	3.9	0.73	96.2	84.6719	58.1804
2015	12	22	2	35	33	0.3	3.9	0.65	96.9	84.6719	52.0979
2015	12	22	2	45	33	0.3	3.9	0.69	95.8	84.6719	55.007
2015	12	22	2	55	33	0.3	3.9	0.68	96.9	84.6719	54.7425
2015	12	22	3	5	33	0.3	3.9	0.66	95.7	84.6719	53.1558
2015	12	22	3	15	33	0.3	3.9	0.65	96.1	84.6719	52.3624
2015	12	22	3	25	33	0.3	3.9	0.69	95.2	84.6719	55.007
2015	12	22	3	35	33	0.3	3.9	0.61	97	84.6719	49.1889
2015	12	22	3	45	33	0.3	3.9	0.66	98.3	84.6719	52.3624
2015	12	22	3	55	33	0.3	3.9	0.66	95.4	84.6719	52.8913
2015	12	22	4	5	33	0.3	3.9	0.66	95.5	84.6719	52.6269
2015	12	22	4	15	33	0.3	3.9	0.64	95.6	84.6719	51.569
2015	12	22	4	25	33	0.3	3.9	0.69	96.6	84.6719	55.007
2015	12	22	4	35	33	0.3	3.9	0.67	98.2	84.6719	53.1558
2015	12	22	4	45	33	0.3	3.9	0.66	98.3	84.6719	52.8913
2015	12	22	4	55	33	0.3	3.9	0.66	96.5	84.6719	53.1558
2015	12	22	5	5	33	0.3	3.9	0.64	95.6	84.6719	51.569
2015	12	22	5	15	33	0.3	3.9	0.65	97.9	84.6719	51.569
2015	12	22	5	25	33	0.3	3.9	0.67	95.3	84.6719	53.6847
2015	12	22	5	35	33	0.3	3.9	0.67	99	84.6719	53.6847
2015	12	22	5	45	33	0.3	3.9	0.65	99.6	84.6719	51.8335
2015	12	22	5	55	33	0.3	3.9	0.67	98.7	84.6719	53.4202
2015	12	22	6	5	33	0.3	3.9	0.68	99.2	84.6719	53.9491
2015	12	22	6	15	33	0.3	3.9	0.62	98	84.6719	49.1889
2015	12	22	6	25	33	0.3	3.9	0.63	96.8	84.6719	50.7757
2015	12	22	6	35	33	0.3	3.9	0.65	97.5	84.6719	52.0979
2015	12	22	6	45	33	0.3	3.9	0.66	96.3	84.6719	52.6268
2015	12	22	6	55	33	0.3	3.9	0.63	98.4	84.6719	50.2467
2015	12	22	7	5	33	0.3	3.9	0.71	98.8	84.7375	56.6395
2015	12	22	7	15	33	0.3	3.9	0.62	99.5	84.6719	49.1889
2015	12	22	7	25	33	0.3	3.9	0.68	95.8	84.6719	54.2136
2015	12	22	7	35	33	0.3	3.9	0.66	97.2	84.6719	52.6268
2015	12	22	7	45	33	0.3	3.9	0.69	97.4	84.6719	55.0069
2015	12	22	7	55	33	0.3	3.9	0.67	99.6	84.7375	52.934
2015	12	22	8	5	33	0.3	3.9	0.67	96.2	84.7375	53.728
2015	12	22	8	15	33	0.3	3.9	0.68	96.6	84.7375	54.522
2015	12	22	8	25	33	0.3	3.9	0.62	97	84.7375	49.4932
2015	12	22	8	35	33	0.3	3.9	0.67	95.3	84.7375	53.7279
2015	12	22	8	45	33	0.3	3.9	0.65	98.7	84.7375	51.8752
2015	12	22	8	55	33	0.3	3.9	0.67	95.4	84.7375	53.4632
2015	12	22	9	5	33	0.3	3.9	0.65	95.2	84.7375	52.4045
2015	12	22	9	15	33	0.3	3.9	0.65	95.2	84.7375	52.4045
2015	12	22	9	25	33	0.3	3.9	0.64	98	84.7375	50.8164
2015	12	22	9	35	33	0.3	3.9	0.64	97.3	84.7375	51.3457

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	9	45	33	0.3	3.9	0.68	97.5	84.7375	54.2571
2015	12	22	9	55	33	0.3	3.9	0.66	97.5	84.7375	52.4044
2015	12	22	10	5	33	0.3	3.9	0.64	96.2	84.8032	51.3871
2015	12	22	10	15	33	0.3	3.9	0.64	95.3	84.8032	51.652
2015	12	22	10	25	33	0.3	3.9	0.66	96.8	84.8032	52.9764
2015	12	22	10	35	33	0.3	3.9	0.68	95.3	84.8032	54.5656
2015	12	22	10	45	33	0.3	3.9	0.61	97	84.8032	49.268
2015	12	22	10	55	33	0.3	3.9	0.63	94.1	84.8032	51.1221
2015	12	22	11	5	33	0.3	3.9	0.67	95.3	84.8032	53.7708
2015	12	22	11	15	33	0.3	3.9	0.68	95	84.8688	54.3444
2015	12	22	11	25	33	0.3	3.9	0.69	97.9	84.8688	55.1397
2015	12	22	11	35	33	0.3	3.9	0.68	99.5	84.8688	53.8143
2015	12	22	11	45	33	0.3	3.9	0.67	96.5	84.8032	53.7708
2015	12	22	11	55	33	0.3	3.9	0.66	96.6	84.8032	52.7113
2015	12	22	12	5	33	0.3	3.9	0.63	95.7	84.8032	50.8571
2015	12	22	12	15	33	0.3	3.9	0.67	97.3	84.8032	53.5059
2015	12	22	12	25	33	0.3	3.9	0.69	98.2	84.8032	54.8303
2015	12	22	12	35	33	0.3	3.9	0.64	96.8	84.8032	51.3869
2015	12	22	12	45	33	0.3	3.9	0.69	94.4	84.8032	55.625
2015	12	22	12	55	33	0.3	3.9	0.71	94.8	84.8032	57.2143
2015	12	22	13	5	33	0.3	3.9	0.66	99.1	84.8032	52.9763
2015	12	22	13	15	33	0.3	3.9	0.74	95.9	84.8032	59.0686
2015	12	22	13	25	33	0.3	3.9	0.69	97.4	84.8032	55.0954
2015	12	22	13	35	33	0.3	3.9	0.74	95.6	84.8032	59.3335
2015	12	22	13	45	33	0.3	3.9	0.7	98.1	84.7375	56.1095
2015	12	22	13	55	33	0.3	3.9	0.74	97.6	84.7375	59.5502
2015	12	22	14	5	33	0.3	3.9	0.72	96.3	84.7375	57.9622
2015	12	22	14	15	33	0.3	3.9	0.73	97.5	84.7375	58.4916
2015	12	22	14	25	33	0.3	3.9	0.74	99.2	84.6719	58.9732
2015	12	22	14	35	33	0.3	3.9	0.73	96.2	84.7375	58.7563
2015	12	22	14	45	33	0.3	3.9	0.76	98.2	84.6063	60.5109
2015	12	22	14	55	33	0.3	3.9	0.73	96.2	84.6719	58.4443
2015	12	22	15	5	33	0.3	3.9	0.72	98.1	84.6719	57.3865
2015	12	22	15	15	33	0.3	3.9	0.73	95.7	84.6719	58.4443
2015	12	22	15	25	33	0.3	3.9	0.75	96.3	84.6719	59.7666
2015	12	22	15	35	33	0.3	3.9	0.71	98	84.6719	56.5931
2015	12	22	15	45	33	0.3	3.9	0.77	98.6	84.6719	61.3533
2015	12	22	15	55	33	0.3	3.9	0.75	95.3	84.6719	60.031
2015	12	22	16	5	33	0.3	3.9	0.74	97.7	84.6719	58.9732
2015	12	22	16	15	33	0.3	3.9	0.72	96.1	84.6719	57.3864
2015	12	22	16	25	33	0.3	3.9	0.76	97	84.6719	60.5599
2015	12	22	16	35	33	0.3	3.9	0.7	96.2	84.6719	56.0642
2015	12	22	16	45	33	0.3	3.9	0.74	96.9	84.6719	59.2376
2015	12	22	16	55	33	0.3	3.9	0.73	97.7	84.6719	58.4442
2015	12	22	17	5	33	0.3	3.9	0.74	97.1	84.6719	59.502
2015	12	22	17	15	33	0.3	3.9	0.72	97	84.6719	57.9153

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	22	17	25	33	0.3	3.9	0.72	97	84.7375	57.9621
2015	12	22	17	35	33	0.3	3.9	0.69	97.3	84.7375	55.5801
2015	12	22	17	45	33	0.3	3.9	0.7	98.4	84.7375	55.5801
2015	12	22	17	55	33	0.3	3.9	0.75	98.1	84.7375	59.5501
2015	12	22	18	5	33	0.3	3.9	0.72	98.9	84.7375	57.4328
2015	12	22	18	15	33	0.3	3.9	0.75	95	84.6719	60.2954
2015	12	22	18	25	33	0.3	3.9	0.72	94.7	84.6063	58.1327
2015	12	22	18	35	33	0.3	3.9	0.75	97.8	84.6063	59.7181
2015	12	22	18	45	33	0.3	3.9	0.74	96.6	84.7375	59.2855
2015	12	22	18	55	33	0.3	3.9	0.73	98.8	84.7375	58.2268
2015	12	22	19	5	33	0.3	3.9	0.74	100.2	84.7375	58.7562
2015	12	22	19	15	33	0.3	3.9	0.74	98.4	84.7375	59.0208
2015	12	22	19	25	33	0.3	3.9	0.71	97.1	84.6719	57.122
2015	12	22	19	35	33	0.3	3.9	0.71	97.1	84.7375	57.1682
2015	12	22	19	45	33	0.3	3.9	0.68	98.3	84.7375	54.5215
2015	12	22	19	55	33	0.3	3.9	0.69	98.7	84.7375	55.0508
2015	12	22	20	5	33	0.3	3.9	0.73	95.9	84.7375	58.4915
2015	12	22	20	15	33	0.3	3.9	0.73	99.6	84.7375	57.9622
2015	12	22	20	25	33	0.3	3.9	0.71	99.3	84.7375	56.6389
2015	12	22	20	35	33	0.3	3.9	0.71	98.7	84.6719	56.8575
2015	12	22	20	45	33	0.3	3.9	0.74	99.2	84.6719	58.9732
2015	12	22	20	55	33	0.3	3.9	0.74	97.1	84.6719	59.5021
2015	12	22	21	5	33	0.3	3.9	0.68	96.4	84.6719	54.4775
2015	12	22	21	15	33	0.3	3.9	0.72	97	84.6719	57.9154
2015	12	22	21	25	33	0.3	3.9	0.73	95.9	84.7375	58.4916
2015	12	22	21	35	33	0.3	3.9	0.7	98.3	84.6719	56.0642
2015	12	22	21	45	33	0.3	3.9	0.69	96.6	84.6063	54.9619
2015	12	22	21	55	33	0.3	3.9	0.73	96.7	84.6719	58.4443
2015	12	22	22	5	33	0.3	3.9	0.7	97.8	84.6719	55.7998
2015	12	22	22	15	33	0.3	3.9	0.75	98.8	84.6063	59.454
2015	12	22	22	25	33	0.3	3.9	0.76	100.2	84.6719	60.2955
2015	12	22	22	35	33	0.3	3.9	0.73	98.7	84.6719	58.4443
2015	12	22	22	45	33	0.3	3.9	0.72	97.5	84.7375	57.9622
2015	12	22	22	55	33	0.3	3.9	0.71	99.6	84.6719	56.3287
2015	12	22	23	5	33	0.3	3.9	0.72	97.9	84.7375	57.4329
2015	12	22	23	15	33	0.3	3.9	0.71	97.8	84.6719	56.3287
2015	12	22	23	25	33	0.3	3.9	0.72	98.1	84.7375	57.6976
2015	12	22	23	35	33	0.3	3.9	0.73	96.2	84.6719	58.7088
2015	12	22	23	45	33	0.3	3.9	0.7	98.3	84.7375	56.1096
2015	12	22	23	55	33	0.3	3.9	0.71	96.7	84.7375	56.6389
2015	12	23	0	5	33	0.3	3.9	0.68	96.3	84.7375	54.7862
2015	12	23	0	15	33	0.3	3.9	0.72	98.6	84.7375	57.6976
2015	12	23	0	25	33	0.3	3.9	0.75	97.8	84.7375	59.8149
2015	12	23	0	35	33	0.3	3.9	0.73	96.7	84.6719	58.4443
2015	12	23	0	45	33	0.3	3.9	0.71	97.7	84.7375	56.6389
2015	12	23	0	55	33	0.3	3.9	0.69	97.3	84.7375	55.5802

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	1	5	33	0.3	3.9	0.73	97.7	84.7375	58.4916
2015	12	23	1	15	33	0.3	3.9	0.69	97.6	84.7375	55.3156
2015	12	23	1	25	33	0.3	3.9	0.68	98.9	84.7375	54.2569
2015	12	23	1	35	33	0.3	3.9	0.76	96.2	84.6719	60.5599
2015	12	23	1	45	33	0.3	3.9	0.7	98.9	84.6719	55.5353
2015	12	23	1	55	33	0.3	3.9	0.71	100.6	84.6063	56.5473
2015	12	23	2	5	33	0.3	3.9	0.75	98	84.6063	59.9825
2015	12	23	2	15	33	0.3	3.9	0.77	99.3	84.6063	61.5679
2015	12	23	2	25	33	0.3	3.9	0.72	97.9	84.6719	57.3865
2015	12	23	2	35	33	0.3	3.9	0.68	97.5	84.6719	53.9486
2015	12	23	2	45	33	0.3	3.9	0.73	98	84.6063	58.1328
2015	12	23	2	55	33	0.3	3.9	0.74	97.6	84.6719	59.2377
2015	12	23	3	5	33	0.3	3.9	0.76	98.7	84.6719	60.8244
2015	12	23	3	15	33	0.3	3.9	0.7	94.8	84.6719	56.3287
2015	12	23	3	25	33	0.3	3.9	0.74	98.2	84.7375	58.7562
2015	12	23	3	35	33	0.3	3.9	0.74	97.9	84.6719	58.9732
2015	12	23	3	45	33	0.3	3.9	0.76	99.5	84.7375	60.3443
2015	12	23	3	55	33	0.3	3.9	0.73	95.7	84.6719	58.1798
2015	12	23	4	5	33	0.3	3.9	0.75	95.2	84.6063	60.5109
2015	12	23	4	15	33	0.3	3.9	0.7	96.2	84.6719	56.0642
2015	12	23	4	25	33	0.3	3.9	0.72	96.3	84.6719	57.9154
2015	12	23	4	35	33	0.3	3.9	0.76	96	84.6719	60.56
2015	12	23	4	45	33	0.3	3.9	0.73	94.9	84.6719	58.7088
2015	12	23	4	55	33	0.3	3.9	0.73	99.6	84.6719	57.9154
2015	12	23	5	5	33	0.3	3.9	0.74	97.1	84.7375	59.5503
2015	12	23	5	15	33	0.3	3.9	0.71	97.8	84.7375	56.3743
2015	12	23	5	25	33	0.3	3.9	0.66	99.5	84.6719	52.3619
2015	12	23	5	35	33	0.3	3.9	0.68	97.7	84.6719	54.4775
2015	12	23	5	45	33	0.3	3.9	0.71	96.1	84.7375	56.639
2015	12	23	5	55	33	0.3	3.9	0.72	97.9	84.7375	57.433
2015	12	23	6	5	33	0.3	3.9	0.68	99.4	84.7375	54.5216
2015	12	23	6	15	33	0.3	3.9	0.68	96.4	84.7375	54.5216
2015	12	23	6	25	33	0.3	3.9	0.66	98.9	84.7375	52.4043
2015	12	23	6	35	33	0.3	3.9	0.69	95.5	84.7375	55.3157
2015	12	23	6	45	33	0.3	3.9	0.7	96.2	84.7375	56.1097
2015	12	23	6	55	33	0.3	3.9	0.66	97.7	84.7375	52.669
2015	12	23	7	5	33	0.3	3.9	0.69	94.7	84.7375	55.3157
2015	12	23	7	15	33	0.3	3.9	0.68	96.1	84.7375	54.5217
2015	12	23	7	25	33	0.3	3.9	0.68	96.3	84.7375	54.7863
2015	12	23	7	35	33	0.3	3.9	0.68	96.1	84.7375	54.5217
2015	12	23	7	45	33	0.3	3.9	0.64	92.6	84.7375	51.875
2015	12	23	7	55	33	0.3	3.9	0.62	96.3	84.7375	50.0223
2015	12	23	8	5	33	0.3	3.9	0.69	96	84.7375	55.5803
2015	12	23	8	15	33	0.3	3.9	0.69	94.9	84.7375	55.845
2015	12	23	8	25	33	0.3	3.9	0.64	95.6	84.8032	51.652
2015	12	23	8	35	33	0.3	3.9	0.66	95.2	84.7375	52.6689

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	8	45	33	0.3	3.9	0.66	93.1	84.7375	53.4629
2015	12	23	8	55	33	0.3	3.9	0.66	92.9	84.8032	52.9763
2015	12	23	9	5	33	0.3	3.9	0.65	94.6	84.7375	52.6688
2015	12	23	9	15	33	0.3	3.9	0.65	93.8	84.8032	52.1816
2015	12	23	9	25	33	0.3	3.9	0.63	98.1	84.8032	50.3274
2015	12	23	9	35	33	0.3	3.9	0.65	95.8	84.8032	52.4464
2015	12	23	9	45	33	0.3	3.9	0.69	95.2	84.8032	55.0952
2015	12	23	9	55	33	0.3	3.9	0.63	94.8	84.8032	50.8571
2015	12	23	10	5	33	0.3	3.9	0.67	93.1	84.8032	54.0356
2015	12	23	10	15	33	0.3	3.9	0.7	95.4	84.8032	56.1546
2015	12	23	10	25	33	0.3	3.9	0.65	94.4	84.8032	52.1814
2015	12	23	10	35	33	0.3	3.9	0.71	97.2	84.8032	56.6843
2015	12	23	10	45	33	0.3	3.9	0.67	94.5	84.8032	54.3004
2015	12	23	10	55	33	0.3	3.9	0.66	97.1	84.8032	53.2409
2015	12	23	11	5	33	0.3	3.9	0.72	96.5	84.8032	58.0087
2015	12	23	11	15	33	0.3	3.9	0.68	94.1	84.8032	54.8301
2015	12	23	11	25	33	0.3	3.9	0.68	94.4	84.8688	55.1395
2015	12	23	11	35	33	0.3	3.9	0.68	95.3	84.8032	54.5652
2015	12	23	11	45	33	0.3	3.9	0.68	96.7	84.8688	54.3442
2015	12	23	11	55	33	0.3	3.9	0.66	94.6	84.8032	52.9759
2015	12	23	12	5	33	0.3	3.9	0.62	95.7	84.8032	50.0622
2015	12	23	12	15	33	0.3	3.9	0.65	97.5	84.8032	52.1812
2015	12	23	12	25	33	0.3	3.9	0.65	96.1	84.8688	51.9583
2015	12	23	12	35	33	0.3	3.9	0.71	94.5	84.8032	56.9491
2015	12	23	12	45	33	0.3	3.9	0.7	94.3	84.8032	56.4193
2015	12	23	12	55	33	0.3	3.9	0.67	96.4	84.8032	54.0354
2015	12	23	13	5	33	0.3	3.9	0.64	97.6	84.8032	51.3866
2015	12	23	13	15	33	0.3	3.9	0.68	95.8	84.8032	54.83
2015	12	23	13	25	33	0.3	3.9	0.69	96.3	84.8032	55.3598
2015	12	23	13	35	33	0.3	3.9	0.67	95.3	84.8032	54.0354
2015	12	23	13	45	33	0.3	3.9	0.65	95.8	84.8032	51.9164
2015	12	23	13	55	33	0.3	3.9	0.68	94.7	84.8032	54.5652
2015	12	23	14	5	33	0.3	3.9	0.65	98.4	84.8032	52.1813
2015	12	23	14	15	33	0.3	3.9	0.67	94.5	84.8032	54.0354
2015	12	23	14	25	33	0.3	3.9	0.66	96.5	84.8032	53.2408
2015	12	23	14	35	33	0.3	3.9	0.65	98.7	84.8032	51.9164
2015	12	23	14	45	33	0.3	3.9	0.64	97.7	84.8032	50.8569
2015	12	23	14	55	33	0.3	3.9	0.67	97.9	84.8032	53.7706
2015	12	23	15	5	33	0.3	3.9	0.63	98.7	84.8032	50.0623
2015	12	23	15	15	33	0.3	3.9	0.65	96.7	84.8032	51.9165
2015	12	23	15	25	33	0.3	3.9	0.65	96.1	84.8032	52.1813
2015	12	23	15	35	33	0.3	3.9	0.66	98.8	84.8032	52.976
2015	12	23	15	45	33	0.3	3.9	0.63	96.8	84.7375	50.8159
2015	12	23	15	55	33	0.3	3.9	0.66	99.5	84.7375	52.4039
2015	12	23	16	5	33	0.3	3.9	0.74	98.5	84.7375	58.7559
2015	12	23	16	15	33	0.3	3.9	0.68	96.1	84.7375	54.5212

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	23	16	25	33	0.3	3.9	0.63	96.9	84.7375	50.2865
2015	12	23	16	35	33	0.3	3.9	0.64	97.4	84.8032	51.1218
2015	12	23	16	45	33	0.3	3.9	0.66	94.9	84.7375	52.9332
2015	12	23	16	55	33	0.3	3.9	0.61	96.4	84.7375	49.2279
2015	12	23	17	5	33	0.3	3.9	0.62	95.7	84.7375	50.0219
2015	12	23	17	15	33	0.3	3.9	0.67	95.9	84.7375	53.4626
2015	12	23	17	25	33	0.3	3.9	0.65	96.1	84.7375	51.8745
2015	12	23	17	35	33	0.3	3.9	0.63	97.2	84.7375	50.5512
2015	12	23	17	45	33	0.3	3.9	0.61	98.3	84.7375	48.6986
2015	12	23	17	55	33	0.3	3.9	0.64	96.2	84.7375	51.3452
2015	12	23	18	5	33	0.3	3.9	0.64	96.7	84.7375	51.6099
2015	12	23	18	15	33	0.3	3.9	0.61	97	84.7375	49.2279
2015	12	23	18	25	33	0.3	3.9	0.61	97.7	84.7375	48.6986
2015	12	23	18	35	33	0.3	3.9	0.64	95.6	84.7375	51.0806
2015	12	23	18	45	33	0.3	3.9	0.69	98.2	84.7375	54.7859
2015	12	23	18	55	33	0.3	3.9	0.67	99.6	84.7375	52.9333
2015	12	23	19	5	33	0.3	3.9	0.64	96.2	84.7375	51.3453
2015	12	23	19	15	33	0.3	3.9	0.63	99.4	84.7375	49.7573
2015	12	23	19	25	33	0.3	3.9	0.62	98.3	84.7375	49.2279
2015	12	23	19	35	33	0.3	3.9	0.63	94.5	84.7375	50.5513
2015	12	23	19	45	33	0.3	3.9	0.64	97.6	84.7375	51.3453
2015	12	23	19	55	33	0.3	3.9	0.65	97.5	84.7375	52.1393
2015	12	23	20	5	33	0.3	3.9	0.67	96.7	84.7375	53.992
2015	12	23	20	15	33	0.3	3.9	0.58	97.8	84.7375	46.3167
2015	12	23	20	25	33	0.3	3.9	0.68	97.5	84.7375	53.992
2015	12	23	20	35	33	0.3	3.9	0.67	96.8	84.7375	53.4627
2015	12	23	20	45	33	0.3	3.9	0.61	100.5	84.7375	48.6987
2015	12	23	20	55	33	0.3	3.9	0.65	95.8	84.7375	52.404
2015	12	23	21	5	33	0.3	3.9	0.64	96.5	84.7375	51.0807
2015	12	23	21	15	33	0.3	3.9	0.7	95.9	84.6719	56.064
2015	12	23	21	25	33	0.3	3.9	0.65	99.9	84.7375	51.61
2015	12	23	21	35	33	0.3	3.9	0.67	97.3	84.7375	53.4627
2015	12	23	21	45	33	0.3	3.9	0.61	99.4	84.7375	48.1694
2015	12	23	21	55	33	0.3	3.9	0.64	97.7	84.7375	50.8161
2015	12	23	22	5	33	0.3	3.9	0.67	97.6	84.7375	53.4627
2015	12	23	22	15	33	0.3	3.9	0.72	96.8	84.7375	57.6974
2015	12	23	22	25	33	0.3	3.9	0.66	99.7	84.7375	52.4041
2015	12	23	22	35	33	0.3	3.9	0.64	96.8	84.7375	51.3454
2015	12	23	22	45	33	0.3	3.9	0.64	96.4	84.7375	51.6101
2015	12	23	22	55	33	0.3	3.9	0.66	98.9	84.7375	52.6688
2015	12	23	23	5	33	0.3	3.9	0.65	102.3	84.7375	51.0808
2015	12	23	23	15	33	0.3	3.9	0.67	97.9	84.7375	53.1981
2015	12	23	23	25	33	0.3	3.9	0.65	99	84.6719	51.5684
2015	12	23	23	35	33	0.3	3.9	0.61	100.5	84.7375	48.4341
2015	12	23	23	45	33	0.3	3.9	0.64	99.1	84.7375	51.0808
2015	12	23	23	55	33	0.3	3.9	0.65	99.6	84.7375	51.6101

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	0	5	33	0.3	3.9	0.67	97.9	84.7375	53.1981
2015	12	24	0	15	33	0.3	3.9	0.63	99.2	84.6719	50.5106
2015	12	24	0	25	33	0.3	3.9	0.63	100.5	84.7375	49.7575
2015	12	24	0	35	33	0.3	3.9	0.63	96.6	84.6719	50.2462
2015	12	24	0	45	33	0.3	3.9	0.62	98.2	84.6719	49.7173
2015	12	24	0	55	33	0.3	3.9	0.62	93.9	84.7375	50.0222
2015	12	24	1	5	33	0.3	3.9	0.62	98.2	84.6719	49.7173
2015	12	24	1	15	33	0.3	3.9	0.61	98.6	84.6719	48.924
2015	12	24	1	25	33	0.3	3.9	0.65	95.5	84.6719	52.3619
2015	12	24	1	35	33	0.3	3.9	0.63	98.3	84.6719	50.5107
2015	12	24	1	45	33	0.3	3.9	0.61	98	84.6719	48.6595
2015	12	24	1	55	33	0.3	3.9	0.62	99.1	84.6719	49.7174
2015	12	24	2	5	33	0.3	3.9	0.63	98	84.6719	50.5108
2015	12	24	2	15	33	0.3	3.9	0.61	99.7	84.6719	48.1307
2015	12	24	2	25	33	0.3	3.9	0.63	99.6	84.6719	49.9819
2015	12	24	2	35	33	0.3	3.9	0.63	96.6	84.6719	50.5108
2015	12	24	2	45	33	0.3	3.9	0.68	98.1	84.6719	54.2132
2015	12	24	2	55	33	0.3	3.9	0.62	98.8	84.6719	49.453
2015	12	24	3	5	33	0.3	3.9	0.68	98	84.6719	54.4777
2015	12	24	3	15	33	0.3	3.9	0.62	99.7	84.6719	49.4531
2015	12	24	3	25	33	0.3	3.9	0.61	98.3	84.6719	48.6597
2015	12	24	3	35	33	0.3	3.9	0.6	100.6	84.6719	47.8664
2015	12	24	3	45	33	0.3	3.9	0.62	99.7	84.6719	49.4531
2015	12	24	3	55	33	0.3	3.9	0.65	99.8	84.6719	51.8332
2015	12	24	4	5	33	0.3	3.9	0.59	97.7	84.6719	47.0731
2015	12	24	4	15	33	0.3	3.9	0.62	100.6	84.6719	49.4532
2015	12	24	4	25	33	0.3	3.9	0.61	94.6	84.6719	49.1887
2015	12	24	4	35	33	0.3	3.9	0.68	95.8	84.6719	54.2134
2015	12	24	4	45	33	0.3	3.9	0.64	101	84.6719	50.2466
2015	12	24	4	55	33	0.3	3.9	0.66	97.4	84.6719	52.6267
2015	12	24	5	5	33	0.3	3.9	0.64	99.5	84.6719	50.7755
2015	12	24	5	15	33	0.3	3.9	0.67	97.1	84.6719	53.4201
2015	12	24	5	25	33	0.3	3.9	0.67	99.9	84.6063	52.8484
2015	12	24	5	35	33	0.3	3.9	0.66	98.9	84.6063	52.5842
2015	12	24	5	45	33	0.3	3.9	0.68	96.7	84.6063	54.1697
2015	12	24	5	55	33	0.3	3.9	0.63	100.1	84.6063	50.206
2015	12	24	6	5	33	0.3	3.9	0.68	98.6	84.6719	53.9491
2015	12	24	6	15	33	0.3	3.9	0.67	97.9	84.6719	53.1557
2015	12	24	6	25	33	0.3	3.9	0.69	97.1	84.6063	55.4909
2015	12	24	6	35	33	0.3	3.9	0.75	98.1	84.6719	59.5027
2015	12	24	6	45	33	0.3	3.9	0.63	98.7	84.6719	49.9823
2015	12	24	6	55	33	0.3	3.9	0.67	99.6	84.6719	53.1558
2015	12	24	7	5	33	0.3	3.9	0.65	97.2	84.6063	52.0558
2015	12	24	7	15	33	0.3	3.9	0.68	96.1	84.6719	54.4781
2015	12	24	7	25	33	0.3	3.9	0.68	97.8	84.6063	53.9055
2015	12	24	7	35	33	0.3	3.9	0.71	100.9	84.6719	56.3293

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	7	45	33	0.3	3.9	0.7	99.2	84.6719	55.5359
2015	12	24	7	55	33	0.3	3.9	0.7	98.8	84.6719	56.0648
2015	12	24	8	5	33	0.3	3.9	0.7	98.8	84.6719	56.0648
2015	12	24	8	15	33	0.3	3.9	0.67	99	84.6719	53.1557
2015	12	24	8	25	33	0.3	3.9	0.67	99.6	84.6719	52.8912
2015	12	24	8	35	33	0.3	3.9	0.66	97.4	84.6719	52.8912
2015	12	24	8	45	33	0.3	3.9	0.66	95.1	84.6719	52.8912
2015	12	24	8	55	33	0.3	3.9	0.68	99.4	84.6719	54.2134
2015	12	24	9	5	33	0.3	3.9	0.63	97.5	84.6719	50.2466
2015	12	24	9	15	33	0.3	3.9	0.67	97.3	84.6719	53.9489
2015	12	24	9	25	33	0.3	3.9	0.68	95.8	84.6719	54.2133
2015	12	24	9	35	33	0.3	3.9	0.62	97	84.6719	49.4531
2015	12	24	9	45	33	0.3	3.9	0.66	98	84.6719	52.6265
2015	12	24	9	55	33	0.3	3.9	0.63	97.5	84.6719	50.2464
2015	12	24	10	5	33	0.3	3.9	0.64	93.8	84.6719	51.5687
2015	12	24	10	15	33	0.3	3.9	0.65	96.3	84.7375	52.4044
2015	12	24	10	25	33	0.3	3.9	0.69	97.1	84.7375	55.051
2015	12	24	10	35	33	0.3	3.9	0.64	95.3	84.7375	51.6103
2015	12	24	10	45	33	0.3	3.9	0.67	97.6	84.7375	53.463
2015	12	24	10	55	33	0.3	3.9	0.66	95.5	84.7375	52.6689
2015	12	24	11	5	33	0.3	3.9	0.67	95.6	84.7375	53.9923
2015	12	24	11	15	33	0.3	3.9	0.59	95.7	84.7375	47.3755
2015	12	24	11	25	33	0.3	3.9	0.67	97.3	84.7375	53.4629
2015	12	24	11	35	33	0.3	3.9	0.67	99.6	84.8032	53.5061
2015	12	24	11	45	33	0.3	3.9	0.66	97.7	84.7375	52.6689
2015	12	24	11	55	33	0.3	3.9	0.63	95.7	84.7375	50.5515
2015	12	24	12	5	33	0.3	3.9	0.65	97.9	84.7375	51.6102
2015	12	24	12	15	33	0.3	3.9	0.63	96.3	84.7375	50.5515
2015	12	24	12	25	33	0.3	3.9	0.63	96.6	84.7375	50.2869
2015	12	24	12	35	33	0.3	3.9	0.6	95.9	84.6719	48.395
2015	12	24	12	45	33	0.3	3.9	0.68	96.1	84.7375	54.7862
2015	12	24	12	55	33	0.3	3.9	0.67	97.6	84.7375	53.7276
2015	12	24	13	5	33	0.3	3.9	0.67	95.6	84.7375	53.9922
2015	12	24	13	15	33	0.3	3.9	0.67	96.8	84.7375	53.4629
2015	12	24	13	25	33	0.3	3.9	0.61	98.4	84.7375	48.4342
2015	12	24	13	35	33	0.3	3.9	0.68	96.1	84.7375	54.257
2015	12	24	13	45	33	0.3	3.9	0.66	98.8	84.7375	52.9336
2015	12	24	13	55	33	0.3	3.9	0.75	98.3	84.7375	59.815
2015	12	24	14	5	33	0.3	3.9	0.72	97.9	84.7375	57.1684
2015	12	24	14	15	33	0.3	3.9	0.7	97.3	84.7375	55.845
2015	12	24	14	25	33	0.3	3.9	0.68	97.5	84.8032	54.3009
2015	12	24	14	35	33	0.3	3.9	0.68	97.2	84.7375	54.5217
2015	12	24	14	45	33	0.3	3.9	0.72	98.9	84.8032	57.4795
2015	12	24	14	55	33	0.3	3.9	0.67	98.4	84.8032	53.5063
2015	12	24	15	5	33	0.3	3.9	0.69	96	84.7375	55.5804
2015	12	24	15	15	33	0.3	3.9	0.65	96.4	84.7375	51.875

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	15	25	33	0.3	3.9	0.67	95.9	84.7375	53.7277
2015	12	24	15	35	33	0.3	3.9	0.68	100	84.8032	54.036
2015	12	24	15	45	33	0.3	3.9	0.68	96.1	84.8032	54.5657
2015	12	24	15	55	33	0.3	3.9	0.67	95.4	84.7375	53.463
2015	12	24	16	5	33	0.3	3.9	0.66	97.5	84.8032	52.4467
2015	12	24	16	15	33	0.3	3.9	0.68	96.1	84.8032	54.8306
2015	12	24	16	25	33	0.3	3.9	0.67	99.3	84.7375	53.1983
2015	12	24	16	35	33	0.3	3.9	0.62	95.2	84.7375	49.7576
2015	12	24	16	45	33	0.3	3.9	0.66	97.1	84.8032	53.2413
2015	12	24	16	55	33	0.3	3.9	0.67	96.2	84.8032	53.771
2015	12	24	17	5	33	0.3	3.9	0.67	98.2	84.8032	53.5061
2015	12	24	17	15	33	0.3	3.9	0.65	97.2	84.8032	52.4466
2015	12	24	17	25	33	0.3	3.9	0.69	96.8	84.8032	55.3603
2015	12	24	17	35	33	0.3	3.9	0.66	99.1	84.8032	52.9763
2015	12	24	17	45	33	0.3	3.9	0.68	99.4	84.8032	54.5656
2015	12	24	17	55	33	0.3	3.9	0.66	96.2	84.8032	53.2412
2015	12	24	18	5	33	0.3	3.9	0.63	99.4	84.8032	49.7977
2015	12	24	18	15	33	0.3	3.9	0.66	98.6	84.8032	52.4465
2015	12	24	18	25	33	0.3	3.9	0.68	96.7	84.8032	54.3007
2015	12	24	18	35	33	0.3	3.9	0.68	97.2	84.8032	54.8304
2015	12	24	18	45	33	0.3	3.9	0.66	98.6	84.8032	52.7114
2015	12	24	18	55	33	0.3	3.9	0.73	97.8	84.8032	58.009
2015	12	24	19	5	33	0.3	3.9	0.66	97.4	84.8032	52.9762
2015	12	24	19	15	33	0.3	3.9	0.67	96.7	84.8032	53.7709
2015	12	24	19	25	33	0.3	3.9	0.66	97.1	84.7375	53.1981
2015	12	24	19	35	33	0.3	3.9	0.66	98.9	84.8032	52.4465
2015	12	24	19	45	33	0.3	3.9	0.69	98	84.8032	54.8304
2015	12	24	19	55	33	0.3	3.9	0.68	96.4	84.7375	54.5215
2015	12	24	20	5	33	0.3	3.9	0.71	99.1	84.8032	56.4197
2015	12	24	20	15	33	0.3	3.9	0.68	97.4	84.8032	54.8304
2015	12	24	20	25	33	0.3	3.9	0.66	99.4	84.8032	52.7113
2015	12	24	20	35	33	0.3	3.9	0.67	96.2	84.8032	53.7709
2015	12	24	20	45	33	0.3	3.9	0.69	98.7	84.8032	55.0953
2015	12	24	20	55	33	0.3	3.9	0.65	95.8	84.8032	52.4464
2015	12	24	21	5	33	0.3	3.9	0.67	99.2	84.8032	53.7708
2015	12	24	21	15	33	0.3	3.9	0.65	96.9	84.8032	52.1816
2015	12	24	21	25	33	0.3	3.9	0.67	99.3	84.8032	53.2411
2015	12	24	21	35	33	0.3	3.9	0.67	96.7	84.8032	53.7708
2015	12	24	21	45	33	0.3	3.9	0.68	96.7	84.8032	54.3006
2015	12	24	21	55	33	0.3	3.9	0.69	98.2	84.8032	55.3601
2015	12	24	22	5	33	0.3	3.9	0.64	98.5	84.8032	51.3869
2015	12	24	22	15	33	0.3	3.9	0.68	96.9	84.8032	54.5655
2015	12	24	22	25	33	0.3	3.9	0.65	98.7	84.8032	51.6518
2015	12	24	22	35	33	0.3	3.9	0.62	99.1	84.8032	49.7976
2015	12	24	22	45	33	0.3	3.9	0.67	99.6	84.8032	53.2411
2015	12	24	22	55	33	0.3	3.9	0.65	97.5	84.8032	52.1816

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	24	23	5	33	0.3	3.9	0.64	97.6	84.8032	51.3869
2015	12	24	23	15	33	0.3	3.9	0.65	100.5	84.8032	51.6518
2015	12	24	23	25	33	0.3	3.9	0.65	97.8	84.8032	51.9167
2015	12	24	23	35	33	0.3	3.9	0.63	99	84.8032	50.3274
2015	12	24	23	45	33	0.3	3.9	0.67	95.6	84.8032	54.0357
2015	12	24	23	55	33	0.3	3.9	0.65	97.8	84.8032	52.1816
2015	12	25	0	5	33	0.3	3.9	0.67	97.9	84.8032	53.7709
2015	12	25	0	15	33	0.3	3.9	0.66	95.7	84.8032	52.7113
2015	12	25	0	25	33	0.3	3.9	0.62	96.9	84.8032	50.0625
2015	12	25	0	35	33	0.3	3.9	0.65	96.9	84.8032	52.1816
2015	12	25	0	45	33	0.3	3.9	0.61	93.4	84.8032	49.5328
2015	12	25	0	55	33	0.3	3.9	0.7	98.1	84.8032	56.1548
2015	12	25	1	5	33	0.3	3.9	0.68	96.1	84.8032	54.5655
2015	12	25	1	15	33	0.3	3.9	0.66	95.4	84.8032	53.2411
2015	12	25	1	25	33	0.3	3.9	0.64	97.7	84.8032	50.8572
2015	12	25	1	35	33	0.3	3.9	0.67	98.4	84.8032	53.7709
2015	12	25	1	45	33	0.3	3.9	0.62	94.5	84.8032	50.0626
2015	12	25	1	55	33	0.3	3.9	0.7	96.2	84.8032	56.4198
2015	12	25	2	5	33	0.3	3.9	0.71	97.2	84.8032	56.6846
2015	12	25	2	15	33	0.3	3.9	0.64	97.6	84.8032	51.387
2015	12	25	2	25	33	0.3	3.9	0.68	96.6	84.8032	54.5656
2015	12	25	2	35	33	0.3	3.9	0.67	97.9	84.8032	53.2412
2015	12	25	2	45	33	0.3	3.9	0.65	95.8	84.8032	52.4466
2015	12	25	2	55	33	0.3	3.9	0.67	94.8	84.8032	53.771
2015	12	25	3	5	33	0.3	3.9	0.64	97.6	84.8032	51.3871
2015	12	25	3	15	33	0.3	3.9	0.66	98.9	84.8032	52.7115
2015	12	25	3	25	33	0.3	3.9	0.67	98.8	84.7375	53.1983
2015	12	25	3	35	33	0.3	3.9	0.65	97.6	84.7375	51.6103
2015	12	25	3	45	33	0.3	3.9	0.68	97.4	84.8032	54.8306
2015	12	25	3	55	33	0.3	3.9	0.64	95	84.7375	51.081
2015	12	25	4	5	33	0.3	3.9	0.65	97.9	84.7375	51.6103
2015	12	25	4	15	33	0.3	3.9	0.65	95.5	84.7375	52.4043
2015	12	25	4	25	33	0.3	3.9	0.65	95.2	84.7375	52.1397
2015	12	25	4	35	33	0.3	3.9	0.67	96.2	84.7375	53.4631
2015	12	25	4	45	33	0.3	3.9	0.67	97.1	84.7375	53.4631
2015	12	25	4	55	33	0.3	3.9	0.67	95.9	84.7375	53.7278
2015	12	25	5	5	33	0.3	3.9	0.64	94.7	84.7375	51.3458
2015	12	25	5	15	33	0.3	3.9	0.63	94.8	84.7375	50.8164
2015	12	25	5	25	33	0.3	3.9	0.66	95.4	84.7375	52.9338
2015	12	25	5	35	33	0.3	3.9	0.68	94.4	84.7375	54.5218
2015	12	25	5	45	33	0.3	3.9	0.67	96.2	84.7375	53.4632
2015	12	25	5	55	33	0.3	3.9	0.66	98	84.7375	52.4045
2015	12	25	6	5	33	0.3	3.9	0.62	95.7	84.7375	50.0225
2015	12	25	6	15	33	0.3	3.9	0.65	94.4	84.6719	52.0977
2015	12	25	6	25	33	0.3	3.9	0.63	95.7	84.6719	50.7755
2015	12	25	6	35	33	0.3	3.9	0.67	98.7	84.6719	53.4201

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	6	45	33	0.3	3.9	0.61	96.2	84.6719	48.9243
2015	12	25	6	55	33	0.3	3.9	0.67	94.5	84.6719	54.2134
2015	12	25	7	5	33	0.3	3.9	0.71	99.3	84.6719	56.5936
2015	12	25	7	15	33	0.3	3.9	0.68	98.3	84.6719	54.2135
2015	12	25	7	25	33	0.3	3.9	0.65	97.2	84.6719	52.0978
2015	12	25	7	35	33	0.3	3.9	0.71	96.9	84.6719	56.5936
2015	12	25	7	45	33	0.3	3.9	0.7	96.2	84.6719	56.0647
2015	12	25	7	55	33	0.3	3.9	0.69	98.2	84.6719	54.7424
2015	12	25	8	5	33	0.3	3.9	0.69	97.4	84.6719	55.2713
2015	12	25	8	15	33	0.3	3.9	0.68	98	84.6719	54.4779
2015	12	25	8	25	33	0.3	3.9	0.67	95.3	84.6719	53.949
2015	12	25	8	35	33	0.3	3.9	0.7	95.9	84.6719	56.3291
2015	12	25	8	45	33	0.3	3.9	0.75	96	84.6719	60.0315
2015	12	25	8	55	33	0.3	3.9	0.67	97.1	84.6719	53.42
2015	12	25	9	5	33	0.3	3.9	0.68	96.4	84.7375	54.2572
2015	12	25	9	15	33	0.3	3.9	0.62	96.1	84.7375	49.7578
2015	12	25	9	25	33	0.3	3.9	0.67	95.7	84.7375	53.4632
2015	12	25	9	35	33	0.3	3.9	0.63	95.7	84.7375	50.5518
2015	12	25	9	45	33	0.3	3.9	0.65	95.8	84.7375	52.4044
2015	12	25	9	55	33	0.3	3.9	0.74	98.4	84.7375	59.0211
2015	12	25	10	5	33	0.3	3.9	0.69	97.9	84.7375	55.3157
2015	12	25	10	15	33	0.3	3.9	0.65	96.7	84.7375	51.875
2015	12	25	10	25	33	0.3	3.9	0.7	94	84.8032	56.42
2015	12	25	10	35	33	0.3	3.9	0.68	95.8	84.7375	54.257
2015	12	25	10	45	33	0.3	3.9	0.7	94.8	84.8032	56.4199
2015	12	25	10	55	33	0.3	3.9	0.73	98	84.8032	58.2741
2015	12	25	11	5	33	0.3	3.9	0.67	96.2	84.8032	53.7711
2015	12	25	11	15	33	0.3	3.9	0.73	99	84.8032	58.5389
2015	12	25	11	25	33	0.3	3.9	0.72	97.4	84.8032	57.4794
2015	12	25	11	35	33	0.3	3.9	0.68	98.3	84.8032	54.5657
2015	12	25	11	45	33	0.3	3.9	0.77	98.6	84.8032	61.4526
2015	12	25	11	55	33	0.3	3.9	0.71	98	84.8032	56.6847
2015	12	25	12	5	33	0.3	3.9	0.72	96.8	84.8032	57.7442
2015	12	25	12	15	33	0.3	3.9	0.68	97.5	84.8032	54.5656
2015	12	25	12	25	33	0.3	3.9	0.69	94.9	84.8032	55.6251
2015	12	25	12	35	33	0.3	3.9	0.66	95.5	84.8032	52.7115
2015	12	25	12	45	33	0.3	3.9	0.72	98.6	84.8032	57.4793
2015	12	25	12	55	33	0.3	3.9	0.71	96.4	84.8032	56.6847
2015	12	25	13	5	33	0.3	3.9	0.7	97	84.8032	56.4198
2015	12	25	13	15	33	0.3	3.9	0.72	97.6	84.8032	57.4793
2015	12	25	13	25	33	0.3	3.9	0.69	97.7	84.8032	54.8305
2015	12	25	13	35	33	0.3	3.9	0.68	96.7	84.8032	54.3008
2015	12	25	13	45	33	0.3	3.9	0.72	96.8	84.8032	57.7442
2015	12	25	13	55	33	0.3	3.9	0.72	96.3	84.8032	57.7442
2015	12	25	14	5	33	0.3	3.9	0.68	97.5	84.8032	54.5657
2015	12	25	14	15	33	0.3	3.9	0.69	95.2	84.8032	55.6252

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	14	25	33	0.3	3.9	0.68	94.2	84.7375	54.5216
2015	12	25	14	35	33	0.3	3.9	0.69	93.5	84.7375	55.5803
2015	12	25	14	45	33	0.3	3.9	0.65	96.4	84.8032	51.9169
2015	12	25	14	55	33	0.3	3.9	0.68	96.9	84.7375	54.7863
2015	12	25	15	5	33	0.3	3.9	0.68	95.5	84.8032	54.5658
2015	12	25	15	15	33	0.3	3.9	0.69	95.5	84.7375	55.3157
2015	12	25	15	25	33	0.3	3.9	0.71	96.6	84.7375	56.9037
2015	12	25	15	35	33	0.3	3.9	0.67	96.5	84.7375	53.463
2015	12	25	15	45	33	0.3	3.9	0.68	97.2	84.7375	54.5217
2015	12	25	15	55	33	0.3	3.9	0.68	94.2	84.7375	54.5217
2015	12	25	16	5	33	0.3	3.9	0.73	96.7	84.8032	58.2742
2015	12	25	16	15	33	0.3	3.9	0.66	96.3	84.8032	52.9765
2015	12	25	16	25	33	0.3	3.9	0.68	95.3	84.8032	54.3009
2015	12	25	16	35	33	0.3	3.9	0.68	95.3	84.8032	54.5658
2015	12	25	16	45	33	0.3	3.9	0.71	94.7	84.7375	57.4331
2015	12	25	16	55	33	0.3	3.9	0.67	94.5	84.7375	54.257
2015	12	25	17	5	33	0.3	3.9	0.64	95.6	84.7375	51.6103
2015	12	25	17	15	33	0.3	3.9	0.68	95	84.7375	54.5217
2015	12	25	17	25	33	0.3	3.9	0.69	96	84.8032	55.0955
2015	12	25	17	35	33	0.3	3.9	0.7	95.6	84.8032	56.4199
2015	12	25	17	45	33	0.3	3.9	0.67	95.4	84.8032	53.5062
2015	12	25	17	55	33	0.3	3.9	0.7	98.1	84.8032	56.155
2015	12	25	18	5	33	0.3	3.9	0.7	96	84.8032	55.8901
2015	12	25	18	15	33	0.3	3.9	0.66	94.8	84.8032	53.2413
2015	12	25	18	25	33	0.3	3.9	0.67	96.8	84.8032	53.5062
2015	12	25	18	35	33	0.3	3.9	0.67	97.6	84.8032	53.5062
2015	12	25	18	45	33	0.3	3.9	0.7	94.8	84.8032	56.4199
2015	12	25	18	55	33	0.3	3.9	0.68	95.8	84.8032	54.3008
2015	12	25	19	5	33	0.3	3.9	0.68	93.1	84.7375	54.5216
2015	12	25	19	15	33	0.3	3.9	0.67	97.6	84.7375	53.463
2015	12	25	19	25	33	0.3	3.9	0.71	97.2	84.7375	56.9037
2015	12	25	19	35	33	0.3	3.9	0.67	97.7	84.7375	53.1983
2015	12	25	19	45	33	0.3	3.9	0.68	95	84.7375	54.5217
2015	12	25	19	55	33	0.3	3.9	0.72	96.8	84.7375	57.9624
2015	12	25	20	5	33	0.3	3.9	0.66	96.5	84.7375	53.1983
2015	12	25	20	15	33	0.3	3.9	0.7	96.7	84.7375	56.1097
2015	12	25	20	25	33	0.3	3.9	0.67	95.7	84.7375	53.463
2015	12	25	20	35	33	0.3	3.9	0.72	96.1	84.8032	57.4795
2015	12	25	20	45	33	0.3	3.9	0.68	95.8	84.8032	54.5658
2015	12	25	20	55	33	0.3	3.9	0.64	96.4	84.8032	51.6521
2015	12	25	21	5	33	0.3	3.9	0.66	94.3	84.8032	52.9765
2015	12	25	21	15	33	0.3	3.9	0.65	90.9	84.7375	52.4044
2015	12	25	21	25	33	0.3	3.9	0.7	95.4	84.7375	56.3744
2015	12	25	21	35	33	0.3	3.9	0.66	94	84.7375	53.4631
2015	12	25	21	45	33	0.3	3.9	0.65	94.3	84.7375	52.4044
2015	12	25	21	55	33	0.3	3.9	0.65	95.5	84.7375	52.4044

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	25	22	5	33	0.3	3.9	0.67	95.9	84.7375	53.7278
2015	12	25	22	15	33	0.3	3.9	0.67	93.1	84.7375	53.7277
2015	12	25	22	25	33	0.3	3.9	0.68	96.4	84.7375	54.5218
2015	12	25	22	35	33	0.3	3.9	0.68	97.2	84.7375	54.5218
2015	12	25	22	45	33	0.3	3.9	0.68	95.8	84.7375	54.2571
2015	12	25	22	55	33	0.3	3.9	0.65	96.4	84.7375	52.1398
2015	12	25	23	5	33	0.3	3.9	0.69	96	84.7375	55.0511
2015	12	25	23	15	33	0.3	3.9	0.67	96.5	84.7375	53.4631
2015	12	25	23	25	33	0.3	3.9	0.66	96.3	84.7375	52.9338
2015	12	25	23	35	33	0.3	3.9	0.68	96.6	84.7375	54.5218
2015	12	25	23	45	33	0.3	3.9	0.68	96.9	84.7375	54.7865
2015	12	25	23	55	33	0.3	3.9	0.67	93.6	84.7375	54.2571
2015	12	26	0	5	33	0.3	3.9	0.66	95.4	84.7375	53.1985
2015	12	26	0	15	33	0.3	3.9	0.66	96	84.7375	52.9338
2015	12	26	0	25	33	0.3	3.9	0.67	96.5	84.7375	53.4632
2015	12	26	0	35	33	0.3	3.9	0.67	95.9	84.7375	53.4632
2015	12	26	0	45	33	0.3	3.9	0.67	96.4	84.7375	53.9925
2015	12	26	0	55	33	0.3	3.9	0.65	94.6	84.7375	52.4045
2015	12	26	1	5	33	0.3	3.9	0.68	94.4	84.7375	55.0512
2015	12	26	1	15	33	0.3	3.9	0.63	97.1	84.7375	50.8165
2015	12	26	1	25	33	0.3	3.9	0.64	98.2	84.7375	51.3458
2015	12	26	1	35	33	0.3	3.9	0.69	97.1	84.7375	55.0512
2015	12	26	1	45	33	0.3	3.9	0.68	96.3	84.7375	54.7865
2015	12	26	1	55	33	0.3	3.9	0.67	97	84.7375	53.9925
2015	12	26	2	5	33	0.3	3.9	0.7	96.5	84.6719	55.8001
2015	12	26	2	15	33	0.3	3.9	0.68	95.8	84.7375	54.5219
2015	12	26	2	25	33	0.3	3.9	0.65	95.5	84.6719	52.0977
2015	12	26	2	35	33	0.3	3.9	0.69	96.8	84.7375	55.5806
2015	12	26	2	45	33	0.3	3.9	0.69	96.3	84.6719	55.2712
2015	12	26	2	55	33	0.3	3.9	0.69	96	84.7375	55.0513
2015	12	26	3	5	33	0.3	3.9	0.67	96.8	84.6719	53.4201
2015	12	26	3	15	33	0.3	3.9	0.69	95.2	84.6719	55.5357
2015	12	26	3	25	33	0.3	3.9	0.62	95.2	84.6719	49.7177
2015	12	26	3	35	33	0.3	3.9	0.71	95.6	84.6719	56.5935
2015	12	26	3	45	33	0.3	3.9	0.66	98.3	84.6719	52.3623
2015	12	26	3	55	33	0.3	3.9	0.69	93.5	84.6719	55.8002
2015	12	26	4	5	33	0.3	3.9	0.68	95.8	84.6719	54.4779
2015	12	26	4	15	33	0.3	3.9	0.69	98.5	84.6719	54.7424
2015	12	26	4	25	33	0.3	3.9	0.7	97	84.6719	55.8002
2015	12	26	4	35	33	0.3	3.9	0.72	97	84.6719	57.9159
2015	12	26	4	45	33	0.3	3.9	0.71	95.6	84.6719	57.1225
2015	12	26	4	55	33	0.3	3.9	0.7	98.9	84.7375	55.5807
2015	12	26	5	5	33	0.3	3.9	0.72	99.5	84.7375	57.1688
2015	12	26	5	15	33	0.3	3.9	0.72	97.9	84.7375	57.1688
2015	12	26	5	25	33	0.3	3.9	0.66	97.1	84.7375	53.1987
2015	12	26	5	35	33	0.3	3.9	0.67	97.3	84.7375	53.4634

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	5	45	33	0.3	3.9	0.67	97.9	84.7375	53.1987
2015	12	26	5	55	33	0.3	3.9	0.64	96.5	84.6719	51.3046
2015	12	26	6	5	33	0.3	3.9	0.67	93.6	84.7375	54.2574
2015	12	26	6	15	33	0.3	3.9	0.7	97	84.7375	56.1102
2015	12	26	6	25	33	0.3	3.9	0.65	95.5	84.6719	52.3624
2015	12	26	6	35	33	0.3	3.9	0.66	98.6	84.7375	52.4048
2015	12	26	6	45	33	0.3	3.9	0.7	96.2	84.7375	56.1102
2015	12	26	6	55	33	0.3	3.9	0.72	95.2	84.7375	57.6982
2015	12	26	7	5	33	0.3	3.9	0.71	96.9	84.7375	56.6395
2015	12	26	7	15	33	0.3	3.9	0.72	98.2	84.7375	57.1689
2015	12	26	7	25	33	0.3	3.9	0.71	96.9	84.7375	56.9042
2015	12	26	7	35	33	0.3	3.9	0.7	99.4	84.8032	56.1555
2015	12	26	7	45	33	0.3	3.9	0.71	96.9	84.8032	57.2151
2015	12	26	7	55	33	0.3	3.9	0.68	97.2	84.8032	54.3013
2015	12	26	8	5	33	0.3	3.9	0.69	97.1	84.8032	55.3609
2015	12	26	8	15	33	0.3	3.9	0.66	97.4	84.8032	53.2418
2015	12	26	8	25	33	0.3	3.9	0.65	94.3	84.8032	52.712
2015	12	26	8	35	33	0.3	3.9	0.69	97.1	84.8032	55.0959
2015	12	26	8	45	33	0.3	3.9	0.65	96.1	84.8032	52.1822
2015	12	26	8	55	33	0.3	3.9	0.69	98.7	84.8032	55.0959
2015	12	26	9	5	33	0.3	3.9	0.68	95.8	84.8032	54.3012
2015	12	26	9	15	33	0.3	3.9	0.61	99.9	84.8032	48.7386
2015	12	26	9	25	33	0.3	3.9	0.67	94.8	84.8688	53.5497
2015	12	26	9	35	33	0.3	3.9	0.69	96.8	84.8688	55.6705
2015	12	26	9	45	33	0.3	3.9	0.65	95.2	84.8688	52.2242
2015	12	26	9	55	33	0.3	3.9	0.68	96.1	84.8688	54.6101
2015	12	26	10	5	33	0.3	3.9	0.7	95.9	84.8688	56.2006
2015	12	26	10	15	33	0.3	3.9	0.71	95.9	84.8688	56.7308
2015	12	26	10	25	33	0.3	3.9	0.67	95.7	84.8688	53.5496
2015	12	26	10	35	33	0.3	3.9	0.72	96.8	84.8688	58.0563
2015	12	26	10	45	33	0.3	3.9	0.67	98.2	84.8688	53.5496
2015	12	26	10	55	33	0.3	3.9	0.68	97.2	84.8688	54.3449
2015	12	26	11	5	33	0.3	3.9	0.68	96.9	84.8688	54.875
2015	12	26	11	15	33	0.3	3.9	0.67	97.9	84.9344	53.3275
2015	12	26	11	25	33	0.3	3.9	0.68	95.2	84.9344	54.9193
2015	12	26	11	35	33	0.3	3.9	0.7	96.7	84.9344	56.2459
2015	12	26	11	45	33	0.3	3.9	0.68	99.1	84.9344	54.654
2015	12	26	11	55	33	0.3	3.9	0.69	93.5	85	56.0257
2015	12	26	12	5	33	0.3	3.9	0.7	97.6	84.9344	55.7152
2015	12	26	12	15	33	0.3	3.9	0.72	96.6	84.9344	57.5724
2015	12	26	12	25	33	0.3	3.9	0.69	97.1	85	55.2291
2015	12	26	12	35	33	0.3	3.9	0.73	98.3	85	58.4154
2015	12	26	12	45	33	0.3	3.9	0.7	96	85	56.0257
2015	12	26	12	55	33	0.3	3.9	0.68	94.1	85	54.9636
2015	12	26	13	5	33	0.3	3.9	0.69	97.9	85	55.2291
2015	12	26	13	15	33	0.3	3.9	0.7	97.6	85.0656	55.8051

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	13	25	33	0.3	3.9	0.7	95.1	85.0656	56.6023
2015	12	26	13	35	33	0.3	3.9	0.74	95.1	85.1312	59.8393
2015	12	26	13	45	33	0.3	3.9	0.73	96	85.0656	58.4625
2015	12	26	13	55	33	0.3	3.9	0.7	94	85.1312	56.6479
2015	12	26	14	5	33	0.3	3.9	0.7	96.7	85.1312	56.6479
2015	12	26	14	15	33	0.3	3.9	0.69	97.7	85.1312	55.0522
2015	12	26	14	25	33	0.3	3.9	0.69	97.7	85.1312	55.0522
2015	12	26	14	35	33	0.3	3.9	0.73	96.2	85.1312	58.5096
2015	12	26	14	45	33	0.3	3.9	0.72	96.8	85.1969	58.2905
2015	12	26	14	55	33	0.3	3.9	0.69	97.4	85.1969	55.3627
2015	12	26	15	5	33	0.3	3.9	0.68	94.1	85.1969	55.0965
2015	12	26	15	15	33	0.3	3.9	0.74	95.9	85.1969	59.6214
2015	12	26	15	25	33	0.3	3.9	0.69	96.8	85.1969	55.8951
2015	12	26	15	35	33	0.3	3.9	0.72	97.3	85.1969	58.0244
2015	12	26	15	45	33	0.3	3.9	0.68	97.8	85.1969	54.5643
2015	12	26	15	55	33	0.3	3.9	0.7	95.9	85.1969	56.6936
2015	12	26	16	5	33	0.3	3.9	0.69	96	85.2625	55.6737
2015	12	26	16	15	33	0.3	3.9	0.67	94.2	85.2625	54.6081
2015	12	26	16	25	33	0.3	3.9	0.7	95.6	85.2625	56.7392
2015	12	26	16	35	33	0.3	3.9	0.63	96.2	85.3281	51.1863
2015	12	26	16	45	33	0.3	3.9	0.66	94.9	85.2625	53.0099
2015	12	26	16	55	33	0.3	3.9	0.67	98.1	85.2625	54.0754
2015	12	26	17	5	33	0.3	3.9	0.7	94.8	85.3281	56.7848
2015	12	26	17	15	33	0.3	3.9	0.7	97.6	85.3281	55.985
2015	12	26	17	25	33	0.3	3.9	0.69	98.2	85.3281	55.1852
2015	12	26	17	35	33	0.3	3.9	0.65	97.3	85.3281	52.2526
2015	12	26	17	45	33	0.3	3.9	0.62	97.4	85.3281	49.5867
2015	12	26	17	55	33	0.3	3.9	0.64	96.1	85.3281	51.986
2015	12	26	18	5	33	0.3	3.9	0.67	97.3	85.3281	53.8522
2015	12	26	18	15	33	0.3	3.9	0.69	98.4	85.3281	55.7184
2015	12	26	18	25	33	0.3	3.9	0.67	98.4	85.3937	53.8954
2015	12	26	18	35	33	0.3	3.9	0.68	95.3	85.3937	54.9627
2015	12	26	18	45	33	0.3	3.9	0.67	96.8	85.3937	53.8954
2015	12	26	18	55	33	0.3	3.9	0.65	97.3	85.3937	52.2946
2015	12	26	19	5	33	0.3	3.9	0.64	98.6	85.3937	51.2274
2015	12	26	19	15	33	0.3	3.9	0.66	97.7	85.3281	53.319
2015	12	26	19	25	33	0.3	3.9	0.69	97.4	85.3937	55.4963
2015	12	26	19	35	33	0.3	3.9	0.66	96.3	85.3937	53.3618
2015	12	26	19	45	33	0.3	3.9	0.66	96.5	85.3937	53.6287
2015	12	26	19	55	33	0.3	3.9	0.62	98.5	85.3937	50.1601
2015	12	26	20	5	33	0.3	3.9	0.59	99.3	85.3937	47.4921
2015	12	26	20	15	33	0.3	3.9	0.62	98.2	85.3937	49.8933
2015	12	26	20	25	33	0.3	3.9	0.65	97.6	85.3937	52.0278
2015	12	26	20	35	33	0.3	3.9	0.66	93.1	85.3937	53.8955
2015	12	26	20	45	33	0.3	3.9	0.69	95.2	85.3281	55.7184
2015	12	26	20	55	33	0.3	3.9	0.64	94.4	85.3937	52.0278

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	26	21	5	33	0.3	3.9	0.62	97.9	85.3937	50.1602
2015	12	26	21	15	33	0.3	3.9	0.64	94.4	85.3281	51.4529
2015	12	26	21	25	33	0.3	3.9	0.62	98.8	85.3281	49.8534
2015	12	26	21	35	33	0.3	3.9	0.64	97.4	85.3281	51.453
2015	12	26	21	45	33	0.3	3.9	0.6	100.4	85.3281	47.9872
2015	12	26	21	55	33	0.3	3.9	0.61	98.1	85.3281	48.787
2015	12	26	22	5	33	0.3	3.9	0.58	99.7	85.3281	46.6542
2015	12	26	22	15	33	0.3	3.9	0.64	97.7	85.3281	51.453
2015	12	26	22	25	33	0.3	3.9	0.62	101	85.3281	49.3202
2015	12	26	22	35	33	0.3	3.9	0.64	99.8	85.3281	50.9198
2015	12	26	22	45	33	0.3	3.9	0.64	98.5	85.3281	51.453
2015	12	26	22	55	33	0.3	3.9	0.65	98.7	85.3937	52.2947
2015	12	26	23	5	33	0.3	3.9	0.65	97.5	85.3937	52.5615
2015	12	26	23	15	33	0.3	3.9	0.63	99.2	85.3281	50.9198
2015	12	26	23	25	33	0.3	3.9	0.61	98.3	85.3281	49.0536
2015	12	26	23	35	33	0.3	3.9	0.65	97.6	85.3281	52.2528
2015	12	26	23	45	33	0.3	3.9	0.66	97.4	85.3281	53.3192
2015	12	26	23	55	33	0.3	3.9	0.62	102.4	85.3281	49.5869
2015	12	27	0	5	33	0.3	3.9	0.63	99.2	85.3281	50.9198
2015	12	27	0	15	33	0.3	3.9	0.64	99.1	85.3281	51.453
2015	12	27	0	25	33	0.3	3.9	0.62	98	85.3281	49.5869
2015	12	27	0	35	33	0.3	3.9	0.63	102.7	85.3281	49.8535
2015	12	27	0	45	33	0.3	3.9	0.61	98.6	85.2625	49.2807
2015	12	27	0	55	33	0.3	3.9	0.62	103.7	85.3281	49.0537
2015	12	27	1	5	33	0.3	3.9	0.61	99.2	85.2625	49.2807
2015	12	27	1	15	33	0.3	3.9	0.67	97.7	85.2625	53.5429
2015	12	27	1	25	33	0.3	3.9	0.65	97.9	85.2625	51.9446
2015	12	27	1	35	33	0.3	3.9	0.65	100.7	85.2625	52.211
2015	12	27	1	45	33	0.3	3.9	0.64	101.3	85.2625	50.8791
2015	12	27	1	55	33	0.3	3.9	0.67	101.3	85.2625	53.2765
2015	12	27	2	5	33	0.3	3.9	0.68	100.6	85.2625	54.0757
2015	12	27	2	15	33	0.3	3.9	0.67	101	85.2625	53.2765
2015	12	27	2	25	33	0.3	3.9	0.68	99.2	85.2625	54.3421
2015	12	27	2	35	33	0.3	3.9	0.68	99.4	85.2625	54.6085
2015	12	27	2	45	33	0.3	3.9	0.68	99.5	85.2625	54.0757
2015	12	27	2	55	33	0.3	3.9	0.68	98.9	85.2625	54.6085
2015	12	27	3	5	33	0.3	3.9	0.66	99.5	85.1969	52.4353
2015	12	27	3	15	33	0.3	3.9	0.63	98.3	85.1969	50.8383
2015	12	27	3	25	33	0.3	3.9	0.68	102.5	85.1969	54.0323
2015	12	27	3	35	33	0.3	3.9	0.64	100.1	85.1969	50.8383
2015	12	27	3	45	33	0.3	3.9	0.65	98.7	85.1969	52.1691
2015	12	27	3	55	33	0.3	3.9	0.65	99.8	85.1969	52.1691
2015	12	27	4	5	33	0.3	3.9	0.68	98.4	85.1969	54.2985
2015	12	27	4	15	33	0.3	3.9	0.61	99.3	85.1969	48.9751
2015	12	27	4	25	33	0.3	3.9	0.67	99.4	85.1969	53.2338
2015	12	27	4	35	33	0.3	3.9	0.68	99.4	85.1969	54.5646

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	4	45	33	0.3	3.9	0.63	98.9	85.1969	50.8383
2015	12	27	4	55	33	0.3	3.9	0.64	97.7	85.1969	51.3706
2015	12	27	5	5	33	0.3	3.9	0.62	102.4	85.1969	49.5074
2015	12	27	5	15	33	0.3	3.9	0.64	100.3	85.1969	51.1044
2015	12	27	5	25	33	0.3	3.9	0.64	100.6	85.1969	51.3706
2015	12	27	5	35	33	0.3	3.9	0.65	96.3	85.1969	52.7015
2015	12	27	5	45	33	0.3	3.9	0.65	99.3	85.1969	52.1691
2015	12	27	5	55	33	0.3	3.9	0.66	97.8	85.1969	52.7015
2015	12	27	6	5	33	0.3	3.9	0.66	99.2	85.1969	52.7015
2015	12	27	6	15	33	0.3	3.9	0.63	97.8	85.1969	50.5721
2015	12	27	6	25	33	0.3	3.9	0.62	100.7	85.1969	49.2413
2015	12	27	6	35	33	0.3	3.9	0.65	98.4	85.1969	52.1691
2015	12	27	6	45	33	0.3	3.9	0.68	98.9	85.1969	54.2985
2015	12	27	6	55	33	0.3	3.9	0.64	98.2	85.1969	51.6368
2015	12	27	7	5	33	0.3	3.9	0.68	99.5	85.1969	54.0323
2015	12	27	7	15	33	0.3	3.9	0.69	99.6	85.1969	55.3632
2015	12	27	7	25	33	0.3	3.9	0.68	97.8	85.1969	54.5646
2015	12	27	7	35	33	0.3	3.9	0.7	100	85.1969	55.8955
2015	12	27	7	45	33	0.3	3.9	0.68	97.8	85.1969	54.5646
2015	12	27	7	55	33	0.3	3.9	0.7	98.1	85.1969	56.1616
2015	12	27	8	5	33	0.3	3.9	0.67	99.6	85.1969	53.7661
2015	12	27	8	15	33	0.3	3.9	0.68	100	85.1312	54.2547
2015	12	27	8	25	33	0.3	3.9	0.68	95.2	85.1312	55.0526
2015	12	27	8	35	33	0.3	3.9	0.66	99.8	85.1312	52.393
2015	12	27	8	45	33	0.3	3.9	0.62	96.9	85.1312	50.2654
2015	12	27	8	55	33	0.3	3.9	0.62	100.4	85.1312	49.2015
2015	12	27	9	5	33	0.3	3.9	0.66	97.4	85.1312	52.9249
2015	12	27	9	15	33	0.3	3.9	0.65	99.3	85.1312	51.861
2015	12	27	9	25	33	0.3	3.9	0.65	101.1	85.1312	51.3291
2015	12	27	9	35	33	0.3	3.9	0.67	99.9	85.0656	53.1479
2015	12	27	9	45	33	0.3	3.9	0.69	98.7	85	55.2293
2015	12	27	9	55	33	0.3	3.9	0.63	95.1	85.0656	50.7562
2015	12	27	10	5	33	0.3	3.9	0.61	97.7	85	49.1222
2015	12	27	10	15	33	0.3	3.9	0.61	99.2	85	49.1222
2015	12	27	10	25	33	0.3	3.9	0.6	98.1	85.0656	48.3646
2015	12	27	10	35	33	0.3	3.9	0.65	98.5	85	51.7774
2015	12	27	10	45	33	0.3	3.9	0.63	97.2	85.0656	50.4905
2015	12	27	10	55	33	0.3	3.9	0.63	99.9	85.0656	50.4904
2015	12	27	11	5	33	0.3	3.9	0.59	98.6	85.1969	47.6439
2015	12	27	11	15	33	0.3	3.9	0.6	99.5	85.1969	47.6439
2015	12	27	11	25	33	0.3	3.9	0.63	99.4	85.2625	50.0796
2015	12	27	11	35	33	0.3	3.9	0.59	100.2	85.2625	47.4158
2015	12	27	11	45	33	0.3	3.9	0.64	98	85.2625	51.1452
2015	12	27	11	55	33	0.3	3.9	0.63	100.7	85.3281	50.653
2015	12	27	12	5	33	0.3	3.9	0.57	99.3	85.2625	45.5511
2015	12	27	12	15	33	0.3	3.9	0.61	96.4	85.2625	49.5469

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	12	25	33	0.3	3.9	0.56	96.3	85.2625	45.5512
2015	12	27	12	35	33	0.3	3.9	0.61	96.1	85.2625	49.5469
2015	12	27	12	45	33	0.3	3.9	0.61	94.7	85.2625	49.0141
2015	12	27	12	55	33	0.3	3.9	0.59	97	85.2625	47.6822
2015	12	27	13	5	33	0.3	3.9	0.62	97.4	85.3281	49.5867
2015	12	27	13	15	33	0.3	3.9	0.6	97.6	85.3281	48.2537
2015	12	27	13	25	33	0.3	3.9	0.63	100.4	85.3281	50.6531
2015	12	27	13	35	33	0.3	3.9	0.67	99.9	85.3281	53.5857
2015	12	27	13	45	33	0.3	3.9	0.63	96.8	85.3281	51.1863
2015	12	27	13	55	33	0.3	3.9	0.55	99.7	85.2625	43.6866
2015	12	27	14	5	33	0.3	3.9	0.6	101	85.2625	47.9487
2015	12	27	14	15	33	0.3	3.9	0.65	98.1	85.3281	52.5193
2015	12	27	14	25	33	0.3	3.9	0.62	99.1	85.3281	49.8534
2015	12	27	14	35	33	0.3	3.9	0.6	102.1	85.3281	47.4541
2015	12	27	14	45	33	0.3	3.9	0.62	99.8	85.3281	49.5868
2015	12	27	14	55	33	0.3	3.9	0.61	100.5	85.3281	49.0537
2015	12	27	15	5	33	0.3	3.9	0.59	99.3	85.3281	47.4541
2015	12	27	15	15	33	0.3	3.9	0.65	101	85.3937	52.028
2015	12	27	15	25	33	0.3	3.9	0.66	96.8	85.3937	53.362
2015	12	27	15	35	33	0.3	3.9	0.62	98	85.3937	49.6267
2015	12	27	15	45	33	0.3	3.9	0.61	100.5	85.3281	48.7871
2015	12	27	15	55	33	0.3	3.9	0.66	97.2	85.3937	53.0953
2015	12	27	16	5	33	0.3	3.9	0.62	98.3	85.3937	49.6268
2015	12	27	16	15	33	0.3	3.9	0.62	97.6	85.3937	50.1604
2015	12	27	16	25	33	0.3	3.9	0.64	98.5	85.3937	51.4945
2015	12	27	16	35	33	0.3	3.9	0.65	99.9	85.3937	52.0281
2015	12	27	16	45	33	0.3	3.9	0.61	98.3	85.3937	49.0932
2015	12	27	16	55	33	0.3	3.9	0.65	95.8	85.3937	52.2949
2015	12	27	17	5	33	0.3	3.9	0.67	95.1	85.4593	54.206
2015	12	27	17	15	33	0.3	3.9	0.68	96.4	85.4593	54.7401
2015	12	27	17	25	33	0.3	3.9	0.63	98.9	85.3937	50.9609
2015	12	27	17	35	33	0.3	3.9	0.63	96	85.4593	51.0017
2015	12	27	17	45	33	0.3	3.9	0.65	97.2	85.4593	52.6039
2015	12	27	17	55	33	0.3	3.9	0.65	96.1	85.4593	52.6039
2015	12	27	18	5	33	0.3	3.9	0.58	94.8	85.4593	47.2634
2015	12	27	18	15	33	0.3	3.9	0.63	96.6	85.4593	51.0017
2015	12	27	18	25	33	0.3	3.9	0.65	96.9	85.5249	52.9133
2015	12	27	18	35	33	0.3	3.9	0.6	94.7	85.4593	48.8655
2015	12	27	18	45	33	0.3	3.9	0.58	97.2	85.4593	46.7293
2015	12	27	18	55	33	0.3	3.9	0.61	97.2	85.4593	48.8656
2015	12	27	19	5	33	0.3	3.9	0.63	95.1	85.4593	50.7347
2015	12	27	19	15	33	0.3	3.9	0.64	96.2	85.5249	51.5771
2015	12	27	19	25	33	0.3	3.9	0.66	96.2	85.5249	53.715
2015	12	27	19	35	33	0.3	3.9	0.62	96.9	85.5249	50.5081
2015	12	27	19	45	33	0.3	3.9	0.61	98.6	85.5249	49.4392
2015	12	27	19	55	33	0.3	3.9	0.63	97.2	85.5249	50.5081

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	27	20	5	33	0.3	3.9	0.61	98	85.5249	49.172
2015	12	27	20	15	33	0.3	3.9	0.67	98.2	85.5249	53.715
2015	12	27	20	25	33	0.3	3.9	0.58	100.1	85.5249	46.4996
2015	12	27	20	35	33	0.3	3.9	0.61	97.1	85.5249	49.172
2015	12	27	20	45	33	0.3	3.9	0.56	101.2	85.5906	44.6646
2015	12	27	20	55	33	0.3	3.9	0.6	103.3	85.5906	47.3392
2015	12	27	21	5	33	0.3	3.9	0.67	98.4	85.5906	54.0255
2015	12	27	21	15	33	0.3	3.9	0.62	102.6	85.5906	49.2113
2015	12	27	21	25	33	0.3	3.9	0.64	99.7	85.6562	51.6597
2015	12	27	21	35	33	0.3	3.9	0.67	98.5	85.6562	53.801
2015	12	27	21	45	33	0.3	3.9	0.66	97.4	85.6562	53.801
2015	12	27	21	55	33	0.3	3.9	0.64	98	85.7218	51.701
2015	12	27	22	5	33	0.3	3.9	0.62	95.8	85.7874	50.4019
2015	12	27	22	15	33	0.3	3.9	0.65	98.5	85.7874	52.2785
2015	12	27	22	25	33	0.3	3.9	0.66	99.2	85.853	53.1252
2015	12	27	22	35	33	0.3	3.9	0.63	98.1	85.853	50.9787
2015	12	27	22	45	33	0.3	3.9	0.62	98.5	85.853	50.4421
2015	12	27	22	55	33	0.3	3.9	0.63	98.9	85.853	51.247
2015	12	27	23	5	33	0.3	3.9	0.65	98.7	85.9186	52.6305
2015	12	27	23	15	33	0.3	3.9	0.64	98.5	85.9186	51.8249
2015	12	27	23	25	33	0.3	3.9	0.63	99.6	85.9186	51.0194
2015	12	27	23	35	33	0.3	3.9	0.61	100.9	85.9186	48.8712
2015	12	27	23	45	33	0.3	3.9	0.62	100.6	85.9186	50.2138
2015	12	27	23	55	33	0.3	3.9	0.61	99.4	85.9186	48.8712
2015	12	28	0	5	33	0.3	3.9	0.61	100.2	85.9186	49.1397
2015	12	28	0	15	33	0.3	3.9	0.57	105.5	85.9843	44.6103
2015	12	28	0	25	33	0.3	3.9	0.6	98.2	85.9186	48.6027
2015	12	28	0	35	33	0.3	3.9	0.58	103.3	85.9843	46.4915
2015	12	28	0	45	33	0.3	3.9	0.58	102.8	85.9843	46.2228
2015	12	28	0	55	33	0.3	3.9	0.58	99.8	85.9843	46.7602
2015	12	28	1	5	33	0.3	3.9	0.59	103.5	85.9843	47.029
2015	12	28	1	15	33	0.3	3.9	0.59	103.4	85.9843	47.2977
2015	12	28	1	25	33	0.3	3.9	0.54	102.5	85.9843	43.5354
2015	12	28	1	35	33	0.3	3.9	0.62	100.6	85.9843	50.2538
2015	12	28	1	45	33	0.3	3.9	0.57	106.4	85.9843	44.8791
2015	12	28	1	55	33	0.3	3.9	0.58	103.7	85.9843	46.2228
2015	12	28	2	5	33	0.3	3.9	0.61	98.9	85.9843	49.7163
2015	12	28	2	15	33	0.3	3.9	0.63	99	86.0499	51.1007
2015	12	28	2	25	33	0.3	3.9	0.64	96.8	86.0499	51.9075
2015	12	28	2	35	33	0.3	3.9	0.57	103.4	86.0499	45.1838
2015	12	28	2	45	33	0.3	3.9	0.57	101.6	86.0499	45.7217
2015	12	28	2	55	33	0.3	3.3	0.59	96.4	86.0499	47.8733
2015	12	28	3	5	33	0.3	3.9	0.58	103.6	86.0499	46.5285
2015	12	28	3	15	33	0.3	3.9	0.61	95.9	86.0499	49.7559
2015	12	28	3	25	33	0.3	3.9	0.59	99	86.0499	47.6043
2015	12	28	3	35	33	0.3	3.3	0.66	99.5	86.0499	52.9834

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	3	45	33	0.3	3.9	0.5	107.7	86.0499	38.7289
2015	12	28	3	55	33	0.3	3.9	0.56	93.3	86.0499	45.9906
2015	12	28	4	5	33	0.3	3.9	0.56	92.4	86.0499	45.7217
2015	12	28	4	15	33	0.3	3.3	0.62	98.8	86.0499	50.2938
2015	12	28	4	25	33	0.3	3.9	0.59	94.8	86.1155	47.9114
2015	12	28	4	35	33	0.3	3.9	0.44	108.7	86.1811	34.2111
2015	12	28	4	45	33	0.3	3.9	0.66	119.6	86.1155	46.8347
2015	12	28	4	55	33	0.3	3.9	0.58	100.5	86.1155	46.5655
2015	12	28	5	5	33	0.3	3.3	0.59	96	86.0499	48.4112
2015	12	28	5	15	33	0.3	3.9	0.5	99.2	86.1811	40.1375
2015	12	28	5	25	33	0.3	3.3	0.66	97.4	86.0499	53.7902
2015	12	28	5	35	33	0.3	3.9	0.49	113.1	86.0499	36.5773
2015	12	28	5	45	33	0.3	3.9	0.43	121.1	85.9843	29.8298
2015	12	28	5	55	33	0.3	3.3	0.63	99	86.0499	50.8317
2015	12	28	6	5	33	0.3	3.3	0.57	96.2	85.9186	46.723
2015	12	28	6	15	33	0.3	3.3	0.61	96.1	85.9843	49.9851
2015	12	28	6	25	33	0.3	3.9	0.5	100.2	85.9186	40.2784
2015	12	28	6	35	33	0.3	3.3	0.66	98.6	85.9186	53.4361
2015	12	28	6	45	33	0.3	3.3	0.62	95.8	85.9843	50.2538
2015	12	28	6	55	33	0.3	3.9	0.46	94.5	85.9843	37.8919
2015	12	28	7	5	33	0.3	3.3	0.65	98.1	85.9186	52.6305
2015	12	28	7	15	33	0.3	3.3	0.63	98.1	85.7218	50.8974
2015	12	28	7	25	33	0.3	3.3	0.66	96.8	85.9186	53.9731
2015	12	28	7	35	33	0.3	3	0.74	96.8	85.5906	60.1769
2015	12	28	7	45	33	0.3	3.9	0.63	98.4	85.6562	50.589
2015	12	28	7	55	33	0.3	3	0.71	98	85.5249	57.1891
2015	12	28	8	5	33	0.3	3	0.66	98.3	85.5249	52.9133
2015	12	28	8	15	33	0.3	3	0.7	97	85.5906	56.7
2015	12	28	8	25	33	0.3	3	0.7	98.8	85.5249	56.6546
2015	12	28	8	35	33	0.3	3.3	0.73	98.3	85.7218	58.6658
2015	12	28	8	45	33	0.3	3	0.66	98.8	85.5906	53.4905
2015	12	28	8	55	33	0.3	3	0.72	96.8	85.5906	58.3046
2015	12	28	9	5	33	0.3	3	0.71	98.7	85.6562	57.5482
2015	12	28	9	15	33	0.3	3	0.72	100	85.4593	57.4102
2015	12	28	9	25	33	0.3	3	0.68	100.3	85.5906	54.5602
2015	12	28	9	35	33	0.3	3.3	0.67	101.3	85.7218	53.576
2015	12	28	9	45	33	0.3	3.3	0.69	100.4	85.7218	55.719
2015	12	28	9	55	33	0.3	3	0.67	96.2	85.6562	54.3361
2015	12	28	10	5	33	0.3	3	0.69	95.7	85.5249	55.8526
2015	12	28	10	15	33	0.3	3	0.66	98.6	85.5249	53.1803
2015	12	28	10	25	33	0.3	3	0.68	100.5	85.5906	54.8275
2015	12	28	10	35	33	0.3	3	0.67	97.6	85.5906	54.0252
2015	12	28	10	45	33	0.3	3	0.69	97.4	85.6562	55.942
2015	12	28	10	55	33	0.3	3	0.7	97.2	85.5906	56.9671
2015	12	28	11	5	33	0.3	3	0.69	98.4	85.5249	55.8526
2015	12	28	11	15	33	0.3	3	0.73	97.8	85.5906	58.5718

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	11	25	33	0.3	3	0.73	96.7	85.5906	59.3742
2015	12	28	11	35	33	0.3	3	0.7	98.1	85.6562	56.4774
2015	12	28	11	45	33	0.3	3.9	0.42	78.8	85.5906	33.6989
2015	12	28	11	55	33	0.3	3.3	0.65	97.8	85.7874	52.8143
2015	12	28	12	5	33	0.3	3.3	0.68	98.3	85.853	55.2713
2015	12	28	12	15	33	0.3	3.3	0.71	98.2	85.7218	57.594
2015	12	28	12	25	33	0.3	3	0.64	95.6	85.6562	52.1947
2015	12	28	12	35	33	0.3	3.3	0.65	96.3	85.7218	53.0401
2015	12	28	12	45	33	0.3	3.3	0.73	100.6	85.7218	58.9335
2015	12	28	12	55	33	0.3	3.3	0.69	100.1	85.7874	55.7635
2015	12	28	13	5	33	0.3	3.3	0.69	98.7	85.7874	56.0316
2015	12	28	13	15	33	0.3	3.3	0.62	97.3	85.9186	50.2136
2015	12	28	13	25	33	0.3	3.3	0.6	95.1	85.7218	48.4863
2015	12	28	13	35	33	0.3	3.9	0.59	99.4	85.7874	47.1846
2015	12	28	13	45	33	0.3	3.3	0.68	99.4	85.9843	55.0909
2015	12	28	13	55	33	0.3	3.9	0.51	101.6	86.0499	40.6115
2015	12	28	14	5	33	0.3	3.9	0.52	101.9	86.0499	41.9563
2015	12	28	14	15	33	0.3	3.9	0.48	100.9	86.1155	39.0288
2015	12	28	14	25	33	0.3	3.9	0.45	102.1	86.1155	36.3372
2015	12	28	14	35	33	0.3	3.9	0.54	106.2	86.1155	42.528
2015	12	28	14	45	33	0.3	3.9	0.54	105.6	86.1155	42.528
2015	12	28	14	55	33	0.3	3.9	0.53	101.4	86.0499	42.7631
2015	12	28	15	5	33	0.3	3.9	0.54	104	85.9186	42.9636
2015	12	28	15	15	33	0.3	3.9	0.5	102.6	85.9843	39.773
2015	12	28	15	25	33	0.3	3.9	0.52	106.5	85.9843	40.8479
2015	12	28	15	35	33	0.3	3.9	0.48	104.7	85.9186	37.8617
2015	12	28	15	45	33	0.3	3.9	0.55	103.8	85.853	43.7343
2015	12	28	15	55	33	0.3	3.9	0.52	99.9	85.853	41.5878
2015	12	28	16	5	33	0.3	3.9	0.51	107	85.853	40.2463
2015	12	28	16	15	33	0.3	3.9	0.52	100.5	85.7874	42.0909
2015	12	28	16	25	33	0.3	3.9	0.56	98.7	85.853	45.6125
2015	12	28	16	35	33	0.3	3.9	0.52	99.8	85.7874	41.8228
2015	12	28	16	45	33	0.3	3.9	0.57	101.3	85.7218	45.5397
2015	12	28	16	55	33	0.3	3.9	0.48	107	85.6562	37.741
2015	12	28	17	5	33	0.3	3.9	0.54	105	85.6562	42.8267
2015	12	28	17	15	33	0.3	3.9	0.63	99.3	85.5249	50.5081
2015	12	28	17	25	33	0.3	3	0.73	99.9	85.5906	58.3047
2015	12	28	17	35	33	0.3	3.9	0.7	96.2	85.2625	56.7396
2015	12	28	17	45	33	0.3	3	0.69	98.7	85.1969	55.6293
2015	12	28	17	55	33	0.3	3	0.71	98.8	85	56.8228
2015	12	28	18	5	33	0.3	3	0.71	97.4	84.8688	56.9963
2015	12	28	18	15	33	0.3	3	0.7	98.8	84.8032	56.1557
2015	12	28	18	25	33	0.3	3	0.69	98.5	84.8032	55.0961
2015	12	28	18	35	33	0.3	3	0.66	98.6	84.8688	52.7547
2015	12	28	18	45	33	0.3	3	0.67	95.9	84.9344	53.8586
2015	12	28	18	55	33	0.3	3	0.69	97.7	84.9344	54.9198

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	28	19	5	33	0.3	3	0.71	98	85	56.5573
2015	12	28	19	15	33	0.3	3	0.69	96	85	55.2296
2015	12	28	19	25	33	0.3	3	0.71	98.3	85	56.5573
2015	12	28	19	35	33	0.3	3	0.69	100.1	84.9344	54.9198
2015	12	28	19	45	33	0.3	3	0.7	98.1	84.9344	56.2464
2015	12	28	19	55	33	0.3	3	0.69	98.2	84.8688	55.4057
2015	12	28	20	5	33	0.3	3	0.71	95.8	85	57.0883
2015	12	28	20	15	33	0.3	3	0.68	100.3	85	53.902
2015	12	28	20	25	33	0.3	3	0.68	97.2	85	54.6986
2015	12	28	20	35	33	0.3	3	0.67	98.2	85	53.3709
2015	12	28	20	45	33	0.3	3	0.68	97.2	85	54.433
2015	12	28	20	55	33	0.3	3	0.66	97.1	84.9344	53.3279
2015	12	28	21	5	33	0.3	3	0.69	96.9	84.9344	55.1851
2015	12	28	21	15	33	0.3	3.9	0.56	95	85.0656	45.176
2015	12	28	21	25	33	0.3	3	0.7	99.2	85.0656	56.0714
2015	12	28	21	35	33	0.3	3	0.69	96.6	84.9344	55.4504
2015	12	28	21	45	33	0.3	3	0.65	97.8	85	52.0433
2015	12	28	21	55	33	0.3	3	0.7	99.2	84.9344	55.7158
2015	12	28	22	5	33	0.3	3	0.67	98.1	85	53.902
2015	12	28	22	15	33	0.3	3	0.68	96.9	85	54.9641
2015	12	28	22	25	33	0.3	3	0.68	96.1	85	54.9641
2015	12	28	22	35	33	0.3	3	0.67	99.9	84.9344	53.3279
2015	12	28	22	45	33	0.3	3.9	0.5	99	85.0656	40.3926
2015	12	28	22	55	33	0.3	3	0.64	94.4	85.0656	51.8195
2015	12	28	23	5	33	0.3	3	0.63	93.9	85	50.9812
2015	12	28	23	15	33	0.3	3	0.65	94.4	85.0656	52.351
2015	12	28	23	25	33	0.3	3	0.65	94.6	85	52.3088
2015	12	28	23	35	33	0.3	3	0.66	96.8	85.0656	53.4139
2015	12	28	23	45	33	0.3	3	0.65	98.7	85.2625	52.2111
2015	12	28	23	55	33	0.3	3.9	0.61	102.2	85.1312	48.1378
2015	12	29	0	5	33	0.3	3	0.68	97.8	85.1969	54.2985
2015	12	29	0	15	33	0.3	3.9	0.76	98.7	85.2625	61.2681
2015	12	29	0	25	33	0.3	3.9	0.59	105	85.3281	46.6545
2015	12	29	0	35	33	0.3	3	0.68	97.2	85.3937	54.9631
2015	12	29	0	45	33	0.3	3	0.72	98.6	85.3281	58.1181
2015	12	29	0	55	33	0.3	3	0.71	96.6	85.3281	57.5849
2015	12	29	1	5	33	0.3	3.9	0.42	98	85.2625	34.097
2015	12	29	1	15	33	0.3	3	0.67	95.3	85.1312	54.2548
2015	12	29	1	25	33	0.3	3.9	0.51	96.6	85.1312	41.223
2015	12	29	1	35	33	0.3	3	0.69	97.1	85.2625	55.4076
2015	12	29	1	45	33	0.3	3	0.64	94.1	85.2625	52.2111
2015	12	29	1	55	33	0.3	3	0.64	94.4	85.1969	51.6368
2015	12	29	2	5	33	0.3	3	0.67	94.2	85.1312	54.2548
2015	12	29	2	15	33	0.3	3	0.69	100.6	85.1312	55.3186
2015	12	29	2	25	33	0.3	3.9	0.55	95.4	85.2625	44.7523
2015	12	29	2	35	33	0.3	3	0.65	99.8	85.1969	52.1691

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	2	45	33	0.3	3	0.66	95.4	85.2625	53.543
2015	12	29	2	55	33	0.3	3.9	0.57	104.8	85.2625	44.486
2015	12	29	3	5	33	0.3	3	0.6	96	85.3281	48.254
2015	12	29	3	15	33	0.3	3	0.68	99.5	85.3281	54.1192
2015	12	29	3	25	33	0.3	3	0.69	97.1	85.3281	55.7188
2015	12	29	3	35	33	0.3	3	0.7	96.5	85.3937	56.5639
2015	12	29	3	45	33	0.3	3	0.63	99.6	85.3937	50.4273
2015	12	29	3	55	33	0.3	3	0.64	96.8	85.3937	51.7613
2015	12	29	4	5	33	0.3	3	0.68	97.2	85.4593	55.2742
2015	12	29	4	15	33	0.3	3	0.63	96.6	85.3937	50.9609
2015	12	29	4	25	33	0.3	3	0.67	96.2	85.5249	54.5167
2015	12	29	4	35	33	0.3	3	0.66	100.9	85.5249	52.9133
2015	12	29	4	45	33	0.3	3	0.65	100.7	85.3937	52.0281
2015	12	29	4	55	33	0.3	3	0.7	99.7	85.3937	56.2971
2015	12	29	5	5	33	0.3	3.9	0.4	100.9	85.4593	31.776
2015	12	29	5	15	33	0.3	3	0.68	96.1	85.4593	55.0071
2015	12	29	5	25	33	0.3	3	0.64	96.4	85.5249	52.1116
2015	12	29	5	35	33	0.3	3	0.65	95.5	85.4593	52.8709
2015	12	29	5	45	33	0.3	3	0.62	93.9	85.3937	50.6941
2015	12	29	5	55	33	0.3	3	0.64	98.3	85.3937	51.2277
2015	12	29	6	5	33	0.3	3	0.67	99.4	85.4593	53.405
2015	12	29	6	15	33	0.3	3	0.63	96.2	85.3937	51.2277
2015	12	29	6	25	33	0.3	3	0.65	96.9	85.3937	52.5618
2015	12	29	6	35	33	0.3	3.9	0.55	93.1	85.4593	44.5932
2015	12	29	6	45	33	0.3	3	0.66	96.8	85.4593	53.405
2015	12	29	6	55	33	0.3	3	0.63	94.2	85.3937	50.9609
2015	12	29	7	5	33	0.3	3	0.64	96.4	85.3937	52.0281
2015	12	29	7	15	33	0.3	3.9	0.61	102.2	85.3281	48.254
2015	12	29	7	25	33	0.3	3	0.62	93.3	85.3281	50.6534
2015	12	29	7	35	33	0.3	3	0.67	95.7	85.3281	53.8526
2015	12	29	7	45	33	0.3	3	0.64	99.5	85.2625	51.1455
2015	12	29	7	55	33	0.3	3	0.69	99.8	85.3281	55.4521
2015	12	29	8	5	33	0.3	3	0.69	96	85.0656	55.8056
2015	12	29	8	15	33	0.3	3	0.72	98.4	85.0656	57.6658
2015	12	29	8	25	33	0.3	3	0.68	97.8	85.0656	54.2111
2015	12	29	8	35	33	0.3	3	0.72	98.6	85	57.8848
2015	12	29	8	45	33	0.3	3	0.64	96.1	84.8688	51.6943
2015	12	29	8	55	33	0.3	3	0.68	97.8	85	54.433
2015	12	29	9	5	33	0.3	3	0.72	99.4	84.9344	57.8381
2015	12	29	9	15	33	0.3	3	0.66	95.4	85.0656	53.1481
2015	12	29	9	25	33	0.3	3.9	0.45	93.3	85.0656	36.6722
2015	12	29	9	35	33	0.3	3	0.66	99.8	85.0656	52.3508
2015	12	29	9	45	33	0.3	3	0.67	97.7	85.0656	53.4138
2015	12	29	9	55	33	0.3	3	0.69	98.7	85.0656	55.274
2015	12	29	10	5	33	0.3	3	0.66	98	84.9344	52.7971
2015	12	29	10	15	33	0.3	3	0.69	99.1	85.0656	55.0082

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	10	25	33	0.3	3.9	0.55	105.5	85.1969	43.1192
2015	12	29	10	35	33	0.3	3	0.63	96.8	85	50.981
2015	12	29	10	45	33	0.3	3	0.67	100.9	84.9344	53.593
2015	12	29	10	55	33	0.3	3	0.68	98.8	85	54.6983
2015	12	29	11	5	33	0.3	3	0.65	98.7	85	52.3086
2015	12	29	11	15	33	0.3	3	0.64	98.5	85.0656	51.2878
2015	12	29	11	25	33	0.3	3	0.74	101.8	85.1312	58.5098
2015	12	29	11	35	33	0.3	3	0.72	98.6	85.0656	57.6655
2015	12	29	11	45	33	0.3	3	0.69	99.9	85	54.9638
2015	12	29	11	55	33	0.3	3	0.68	100.6	85.0656	53.9452
2015	12	29	12	5	33	0.3	3	0.68	100.2	85	54.4328
2015	12	29	12	15	33	0.3	3	0.74	99	85.3937	59.2317
2015	12	29	12	25	33	0.3	3	0.74	99.4	85.0656	59.26
2015	12	29	12	35	33	0.3	3	0.63	100	85.1312	49.9993
2015	12	29	12	45	33	0.3	3	0.65	98.1	85.0656	52.3507
2015	12	29	12	55	33	0.3	3	0.67	101.8	85.2625	53.5427
2015	12	29	13	5	33	0.3	3	0.66	100.9	85.0656	52.6165
2015	12	29	13	15	33	0.3	3	0.67	98.4	85.0656	53.9452
2015	12	29	13	25	33	0.3	3	0.69	98.7	85.0656	55.2739
2015	12	29	13	35	33	0.3	3.9	0.52	85	85.0656	42.2526
2015	12	29	13	45	33	0.3	3	0.65	98.7	85.0656	52.3508
2015	12	29	13	55	33	0.3	3.9	0.5	99	85.3281	40.5226
2015	12	29	14	5	33	0.3	3	0.69	97.7	85.2625	55.1411
2015	12	29	14	15	33	0.3	3	0.65	96.1	85.0656	52.6165
2015	12	29	14	25	33	0.3	3	0.67	95.7	85	53.6363
2015	12	29	14	35	33	0.3	3.9	0.5	93.8	85.0656	40.3925
2015	12	29	14	45	33	0.3	3.9	0.52	86	85.0656	41.987
2015	12	29	14	55	33	0.3	3	0.64	95.6	85.1969	51.3705
2015	12	29	15	5	33	0.3	3	0.68	93.3	85.5249	55.5856
2015	12	29	15	15	33	0.3	3	0.66	94.8	85.1969	53.4999
2015	12	29	15	25	33	0.3	3	0.65	95.8	85.1969	52.169
2015	12	29	15	35	33	0.3	3	0.68	100	85	54.433
2015	12	29	15	45	33	0.3	3	0.62	97	85.0656	49.9593
2015	12	29	15	55	33	0.3	3	0.69	93	85.1312	55.5845
2015	12	29	16	5	33	0.3	3	0.75	98.1	84.9344	59.6954
2015	12	29	16	15	33	0.3	3	0.67	96.2	85.1312	53.7229
2015	12	29	16	25	33	0.3	3	0.66	97.7	85.0656	53.1482
2015	12	29	16	35	33	0.3	3	0.63	94.8	85.1312	51.0633
2015	12	29	16	45	33	0.3	3	0.65	96.9	85.0656	52.351
2015	12	29	16	55	33	0.3	3	0.64	94.4	85.0656	51.288
2015	12	29	17	5	33	0.3	3	0.65	95.5	85.3281	52.5196
2015	12	29	17	15	33	0.3	3	0.69	98.2	85.2625	55.1413
2015	12	29	17	25	33	0.3	3	0.63	99.6	85.1312	50.2655
2015	12	29	17	35	33	0.3	3	0.64	96.4	85.0656	51.8195
2015	12	29	17	45	33	0.3	3	0.62	98	85.1969	49.5074
2015	12	29	17	55	33	0.3	3	0.63	99	85.1312	50.5314

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	29	18	5	33	0.3	3	0.68	96.3	85.1969	55.0969
2015	12	29	18	15	33	0.3	3.9	0.65	94.6	85.1312	52.3931
2015	12	29	18	25	33	0.3	3	0.69	96.3	85.3937	55.4966
2015	12	29	18	35	33	0.3	3	0.63	95.1	85.3281	50.92
2015	12	29	18	45	33	0.3	3	0.61	97.8	85.3937	48.8264
2015	12	29	18	55	33	0.3	3	0.67	96.2	85.4593	53.939
2015	12	29	19	5	33	0.3	3.9	0.41	94.6	85.3281	33.3246
2015	12	29	19	15	33	0.3	3	0.64	97.1	85.2625	51.4119
2015	12	29	19	25	33	0.3	3	0.63	94.5	85.3281	51.1866
2015	12	29	19	35	33	0.3	3	0.65	95	85.1969	52.1691
2015	12	29	19	45	33	0.3	3	0.65	98.7	85.3281	52.253
2015	12	29	19	55	33	0.3	3	0.69	97.9	85.3937	55.4966
2015	12	29	20	5	33	0.3	3	0.65	97.5	85.3281	52.5196
2015	12	29	20	15	33	0.3	3.9	0.56	111.4	85.3281	42.1223
2015	12	29	20	25	33	0.3	3	0.65	95	85.2625	52.211
2015	12	29	20	35	33	0.3	3	0.65	96.9	85.0656	52.351
2015	12	29	20	45	33	0.3	3	0.69	98.2	85.1969	55.097
2015	12	29	20	55	33	0.3	3	0.68	100.3	85.2625	54.0757
2015	12	29	21	5	33	0.3	3	0.63	98.1	85.0656	50.225
2015	12	29	21	15	33	0.3	3.9	0.44	92.1	85.1969	35.9328
2015	12	29	21	25	33	0.3	3	0.64	94.4	84.9344	51.4707
2015	12	29	21	35	33	0.3	3.9	0.55	109.6	85.0656	41.7213
2015	12	29	21	45	33	0.3	3	0.64	99.1	84.9344	51.2054
2015	12	29	21	55	33	0.3	3	0.66	99.7	85	52.8399
2015	12	29	22	5	33	0.3	3	0.65	100.7	84.9344	52.0014
2015	12	29	22	15	33	0.3	3	0.67	99.4	84.8688	53.0198
2015	12	29	22	25	33	0.3	3	0.6	93.4	85	48.857
2015	12	29	22	35	33	0.3	3	0.64	96.8	84.8032	51.3877
2015	12	29	22	45	33	0.3	3	0.6	96	84.8688	48.248
2015	12	29	22	55	33	0.3	3	0.63	98.3	84.8688	50.6339
2015	12	29	23	5	33	0.3	3	0.64	98.8	84.7375	51.0815
2015	12	29	23	15	33	0.3	3	0.69	99.1	84.7375	54.7869
2015	12	29	23	25	33	0.3	3	0.65	97.2	84.8032	52.1824
2015	12	29	23	35	33	0.3	3	0.64	100	84.6719	50.7758
2015	12	29	23	45	33	0.3	3	0.61	96.1	84.6719	49.1891
2015	12	29	23	55	33	0.3	3	0.64	95.9	84.8032	51.3877
2015	12	30	0	5	33	0.3	3	0.62	99.2	84.6063	49.1493
2015	12	30	0	15	33	0.3	3	0.6	95.7	84.6719	47.8668
2015	12	30	0	25	33	0.3	3	0.66	95.4	84.6719	52.8915
2015	12	30	0	35	33	0.3	3	0.63	96.2	84.5407	50.6937
2015	12	30	0	45	33	0.3	3	0.66	101.5	84.6063	51.7917
2015	12	30	0	55	33	0.3	3	0.61	98.3	84.6063	48.885
2015	12	30	1	5	33	0.3	3	0.6	96.9	84.5407	47.7893
2015	12	30	1	15	33	0.3	3	0.61	97.1	84.4751	48.8059
2015	12	30	1	25	33	0.3	3	0.63	97.5	84.6063	49.942
2015	12	30	1	35	33	0.3	3	0.66	96	84.3438	52.9409

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	1	45	33	0.3	3	0.61	97.1	84.4095	48.5027
2015	12	30	1	55	33	0.3	3	0.61	95.3	84.2782	48.6871
2015	12	30	2	5	33	0.3	3	0.64	98.5	84.4751	50.9164
2015	12	30	2	15	33	0.3	3	0.59	97.6	84.4095	47.1847
2015	12	30	2	25	33	0.3	3	0.61	95.9	84.2782	48.6871
2015	12	30	2	35	33	0.3	3.9	0.56	106.8	84.3438	42.6688
2015	12	30	2	45	33	0.3	3	0.57	94.7	84.147	45.1923
2015	12	30	2	55	33	0.3	3	0.63	93.3	84.2126	50.7512
2015	12	30	3	5	33	0.3	3	0.58	97.4	84.2126	46.2809
2015	12	30	3	15	33	0.3	3	0.6	96.6	84.0814	47.5183
2015	12	30	3	25	33	0.3	3	0.6	98.8	84.147	47.2943
2015	12	30	3	35	33	0.3	3	0.64	99.1	84.0814	50.9312
2015	12	30	3	45	33	0.3	3	0.64	95.3	84.0814	50.6687
2015	12	30	3	55	33	0.3	3	0.64	98.9	84.2126	50.4883
2015	12	30	4	5	33	0.3	3	0.63	100.5	84.0158	49.5781
2015	12	30	4	15	33	0.3	3	0.67	95.3	84.0158	53.2506
2015	12	30	4	25	33	0.3	3	0.57	96.6	84.0158	45.381
2015	12	30	4	35	33	0.3	3	0.57	96.2	83.9501	45.6061
2015	12	30	4	45	33	0.3	3	0.65	99.8	84.0814	51.4563
2015	12	30	4	55	33	0.3	3	0.69	102.1	83.9501	53.7314
2015	12	30	5	5	33	0.3	3.9	0.5	109.3	83.9501	37.4809
2015	12	30	5	15	33	0.3	3	0.6	97.2	83.9501	47.703
2015	12	30	5	25	33	0.3	3.9	0.56	108.8	83.8845	42.4262
2015	12	30	5	35	33	0.3	3	0.67	99.3	83.9501	52.9451
2015	12	30	5	45	33	0.3	3	0.61	97	83.8189	48.6718
2015	12	30	5	55	33	0.3	3	0.66	102	83.8189	51.5503
2015	12	30	6	5	33	0.3	3	0.61	94.9	83.8189	48.6718
2015	12	30	6	15	33	0.3	3.9	0.5	94.2	83.6221	39.4163
2015	12	30	6	25	33	0.3	3.9	0.52	92.9	83.7533	41.3111
2015	12	30	6	35	33	0.3	3	0.55	95.2	83.5564	43.2963
2015	12	30	6	45	33	0.3	3	0.66	100.5	83.6221	51.9459
2015	12	30	6	55	33	0.3	3	0.63	100.8	83.6221	49.3356
2015	12	30	7	5	33	0.3	3	0.58	94.9	83.4908	45.8668
2015	12	30	7	15	33	0.3	3.9	0.62	95.7	83.5564	49.2952
2015	12	30	7	25	33	0.3	3	0.53	91.4	83.5564	42.253
2015	12	30	7	35	33	0.3	3.9	0.62	104.1	83.4908	47.6911
2015	12	30	7	45	33	0.3	3	0.6	100.1	83.4908	46.6486
2015	12	30	7	55	33	0.3	3	0.6	96	83.4908	47.4305
2015	12	30	8	5	33	0.3	3	0.61	95.9	83.4252	48.1727
2015	12	30	8	15	33	0.3	3.9	0.28	90	83.4252	21.873
2015	12	30	8	25	33	0.3	3	0.59	99.6	83.294	46.2738
2015	12	30	8	35	33	0.3	3	0.64	99.5	83.2284	49.8723
2015	12	30	8	45	33	0.3	3	0.61	96.1	83.2284	48.3137
2015	12	30	8	55	33	0.3	3	0.6	94.7	83.2284	47.5345
2015	12	30	9	5	33	0.3	3.9	0.27	102	83.294	20.7972
2015	12	30	9	15	33	0.3	3	0.6	97.2	83.2284	47.0149

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	9	25	33	0.3	3	0.56	102.2	83.1627	43.0832
2015	12	30	9	35	33	0.3	3	0.63	101.4	83.1627	48.793
2015	12	30	9	45	33	0.3	3.9	0.44	101.6	83.1627	34.2589
2015	12	30	9	55	33	0.3	3	0.57	96.9	82.8347	44.7149
2015	12	30	10	5	33	0.3	3	0.66	97.8	82.9003	51.2189
2015	12	30	10	15	33	0.3	3	0.6	97.5	83.0315	47.1579
2015	12	30	10	25	33	0.3	3	0.58	97.2	83.0971	45.3815
2015	12	30	10	35	33	0.3	3	0.63	96.9	82.9659	49.1901
2015	12	30	10	45	33	0.3	3	0.64	99.1	82.9659	50.2257
2015	12	30	10	55	33	0.3	3	0.62	100.7	82.9659	48.1545
2015	12	30	11	5	33	0.3	3	0.63	99.6	83.0315	49.2307
2015	12	30	11	15	33	0.3	3	0.65	99.3	83.1627	50.6096
2015	12	30	11	25	33	0.3	3	0.68	101.4	83.2284	52.9891
2015	12	30	11	35	33	0.3	3	0.64	99.8	83.1627	49.5715
2015	12	30	11	45	33	0.3	3	0.64	101	83.294	49.3932
2015	12	30	11	55	33	0.3	3	0.61	100.8	83.294	47.8334
2015	12	30	12	5	33	0.3	3	0.64	96.8	83.294	50.1731
2015	12	30	12	15	33	0.3	3	0.61	97.7	83.3596	48.1329
2015	12	30	12	25	33	0.3	3	0.63	100.8	83.3596	49.1737
2015	12	30	12	35	33	0.3	3.9	0.6	96.6	83.4252	47.3913
2015	12	30	12	45	33	0.3	3	0.61	97.1	83.4908	48.2121
2015	12	30	12	55	33	0.3	3	0.63	95.4	83.4908	49.5151
2015	12	30	13	5	33	0.3	3	0.64	101.8	83.4908	50.0363
2015	12	30	13	15	33	0.3	3	0.64	96.5	82.9003	49.9255
2015	12	30	13	25	33	0.3	3	0.64	98	82.3097	49.5541
2015	12	30	13	42	15	0.3	3	0.61	97.2	82.8347	47.2996
2015	12	30	13	52	15	0.3	3.9	0.59	95.5	82.9659	46.0834
2015	12	30	14	2	15	0.3	3	0.59	97.6	83.0315	46.3805
2015	12	30	14	12	15	0.3	3	0.6	97.9	83.0315	46.6397
2015	12	30	14	22	15	0.3	3	0.64	97.3	82.9003	50.1842
2015	12	30	14	32	15	0.3	3	0.64	102.5	83.4252	49.2142
2015	12	30	14	42	15	0.3	3	0.63	103.3	83.0971	48.2341
2015	12	30	14	52	15	0.3	3	0.64	98.8	82.9659	49.9669
2015	12	30	15	2	15	0.3	3	0.64	97.6	83.0971	50.3087
2015	12	30	15	12	15	0.3	3	0.62	96.9	83.0971	49.0121
2015	12	30	15	22	15	0.3	3	0.61	102.5	83.1627	46.9763
2015	12	30	15	32	15	0.3	3	0.65	97.6	83.1627	50.6098
2015	12	30	15	42	15	0.3	3	0.61	101.6	83.2284	47.015
2015	12	30	15	52	15	0.3	3	0.62	98.8	83.1627	48.5335
2015	12	30	16	2	15	0.3	3	0.66	99.8	83.294	51.2131
2015	12	30	16	12	15	0.3	3	0.62	96.9	83.1627	49.0526
2015	12	30	16	22	15	0.3	3	0.66	96.6	83.1627	51.648
2015	12	30	16	32	15	0.3	3	0.61	97.4	83.2284	47.7943
2015	12	30	16	42	15	0.3	3	0.62	98	83.1627	48.274
2015	12	30	16	52	15	0.3	3	0.62	100.4	83.2284	48.054
2015	12	30	17	2	15	0.3	3.9	0.54	110.4	83.1627	39.7093

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	30	17	12	15	0.3	3.9	0.53	103	83.2284	40.5212
2015	12	30	17	22	15	0.3	3	0.64	102.1	83.1627	49.5717
2015	12	30	17	32	15	0.3	3	0.63	99	83.1627	49.0526
2015	12	30	17	42	15	0.3	3	0.62	101.6	83.0971	47.9749
2015	12	30	17	52	15	0.3	3.9	0.59	110.3	83.1627	43.6023
2015	12	30	18	2	15	0.3	3	0.69	97.4	83.294	54.0728
2015	12	30	18	12	15	0.3	3	0.64	99.5	83.3596	49.9544
2015	12	30	18	22	15	0.3	3	0.67	100.4	83.3596	52.5562
2015	12	30	18	32	15	0.3	3	0.67	102.1	83.2284	51.9503
2015	12	30	18	42	15	0.3	3	0.66	99.4	83.2284	51.6906
2015	12	30	18	52	15	0.3	3.9	0.52	103.5	83.0971	39.9359
2015	12	30	19	2	15	0.3	3.9	0.53	104.2	83.0971	40.9732
2015	12	30	19	12	15	0.3	3.9	0.56	105.7	83.1627	42.5642
2015	12	30	19	22	15	0.3	3	0.67	99	83.294	52.773
2015	12	30	19	32	15	0.3	3	0.67	99.6	83.1627	51.9075
2015	12	30	19	42	15	0.3	3	0.65	97.8	83.0971	50.8275
2015	12	30	19	52	15	0.3	3	0.59	99.4	83.1627	45.6786
2015	12	30	20	2	15	0.3	3	0.64	98.8	83.2284	50.3918
2015	12	30	20	12	15	0.3	3	0.57	95.9	83.1627	45.1596
2015	12	30	20	22	15	0.3	3.9	0.49	100.7	83.1627	38.4116
2015	12	30	20	32	15	0.3	3	0.6	96.3	83.294	47.0537
2015	12	30	20	42	15	0.3	3	0.67	92.3	83.294	52.773
2015	12	30	20	52	15	0.3	3	0.62	95.7	83.1627	49.0526
2015	12	30	21	2	15	0.3	3	0.67	97.7	83.294	52.253
2015	12	30	21	12	15	0.3	3	0.67	97.7	83.294	52.253
2015	12	30	21	22	15	0.3	3	0.74	98.7	83.294	57.9723
2015	12	30	21	32	15	0.3	3	0.69	99	83.1627	53.9838
2015	12	30	21	42	15	0.3	3	0.69	97.1	83.294	54.5927
2015	12	30	21	52	15	0.3	3	0.67	94.8	83.294	52.513
2015	12	30	22	2	15	0.3	3	0.62	97	83.3596	48.9137
2015	12	30	22	12	15	0.3	3	0.71	99.3	83.3596	55.6784
2015	12	30	22	22	15	0.3	3	0.69	103.6	83.3596	52.8164
2015	12	30	22	32	15	0.3	3.9	0.46	118.7	83.294	32.2357
2015	12	30	22	42	15	0.3	3	0.71	96.9	83.2284	55.5868
2015	12	30	22	52	15	0.3	3	0.67	95	83.2284	52.9893
2015	12	30	23	2	15	0.3	3	0.67	96.2	83.0971	52.9021
2015	12	30	23	12	15	0.3	3	0.68	98	83.0971	53.4207
2015	12	30	23	22	15	0.3	3	0.6	96.9	83.0315	47.4171
2015	12	30	23	32	15	0.3	3	0.69	98.2	83.1627	53.9838
2015	12	30	23	42	15	0.3	3	0.7	97	83.1627	54.7625
2015	12	30	23	52	15	0.3	3	0.61	97.1	83.1627	48.0145
2015	12	31	0	2	15	0.3	3	0.68	95	83.0971	53.4207
2015	12	31	0	12	15	0.3	3	0.68	97.5	83.0971	53.4207
2015	12	31	0	22	15	0.3	3	0.67	96.2	82.9003	52.7712
2015	12	31	0	32	15	0.3	3	0.68	93.9	82.9659	53.5915
2015	12	31	0	42	15	0.3	3	0.66	97.2	83.0971	51.6054

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	0	52	15	0.3	3	0.71	97.7	83.0315	55.4496
2015	12	31	1	2	15	0.3	3	0.65	94.4	83.1627	51.1289
2015	12	31	1	12	15	0.3	3	0.66	96	83.2284	52.2101
2015	12	31	1	22	15	0.3	3	0.74	98.2	83.2284	57.9246
2015	12	31	1	32	15	0.3	3	0.65	96.4	83.1627	51.1289
2015	12	31	1	42	15	0.3	3	0.71	97.4	83.0315	55.9678
2015	12	31	1	52	15	0.3	3	0.65	98.7	83.1627	50.6099
2015	12	31	2	2	15	0.3	3	0.66	96.6	83.0315	51.5629
2015	12	31	2	12	15	0.3	3	0.68	94.9	83.0971	53.9394
2015	12	31	2	22	15	0.3	3	0.7	97.8	83.0315	54.6722
2015	12	31	2	32	15	0.3	3	0.67	95.9	83.0971	52.9021
2015	12	31	2	42	15	0.3	3	0.67	97.3	82.9003	52.7712
2015	12	31	2	52	15	0.3	3	0.68	98.6	82.9003	53.0299
2015	12	31	3	2	15	0.3	3	0.66	98.5	82.8347	51.6937
2015	12	31	3	12	15	0.3	3	0.71	97.7	82.9003	55.6167
2015	12	31	3	22	15	0.3	3	0.66	97.4	83.0315	52.0811
2015	12	31	3	32	15	0.3	3	0.67	97	83.1627	52.9457
2015	12	31	3	42	15	0.3	3	0.7	97.6	83.0971	54.458
2015	12	31	3	52	15	0.3	3	0.67	99.6	82.9659	52.297
2015	12	31	4	2	15	0.3	3	0.7	96.7	83.0315	54.9313
2015	12	31	4	12	15	0.3	3	0.65	96.1	83.0315	51.3038
2015	12	31	4	22	15	0.3	3	0.65	98.1	83.1627	50.8694
2015	12	31	4	32	15	0.3	3	0.67	97.7	83.1627	52.1671
2015	12	31	4	42	15	0.3	3	0.66	95.4	83.1627	52.1671
2015	12	31	4	52	15	0.3	3	0.71	97.2	83.1627	55.5411
2015	12	31	5	2	15	0.3	3	0.65	98.4	83.0971	50.8275
2015	12	31	5	12	15	0.3	3	0.69	98.5	83.0971	53.68
2015	12	31	5	22	15	0.3	3	0.66	101.8	83.1627	51.1289
2015	12	31	5	32	15	0.3	3	0.67	100.1	83.0971	52.3834
2015	12	31	5	42	15	0.3	3	0.64	99.8	83.0315	49.7491
2015	12	31	5	52	15	0.3	3	0.67	98.1	83.1627	52.6862
2015	12	31	6	2	15	0.3	3	0.73	99.3	82.9003	57.1688
2015	12	31	6	12	15	0.3	3	0.69	98.5	83.1627	53.9839
2015	12	31	6	22	15	0.3	3	0.66	96.5	83.0315	52.0811
2015	12	31	6	32	15	0.3	3	0.66	98	83.0971	51.6054
2015	12	31	6	42	15	0.3	3	0.69	96	82.9003	54.0646
2015	12	31	6	52	15	0.3	3	0.71	96.6	82.769	55.783
2015	12	31	7	2	15	0.3	3	0.7	98.1	82.7034	54.4466
2015	12	31	7	12	15	0.3	3	0.7	97.6	82.8347	54.2784
2015	12	31	7	22	15	0.3	3	0.73	96.7	82.769	57.3326
2015	12	31	7	32	15	0.3	3	0.69	96.3	82.8347	53.7615
2015	12	31	7	42	15	0.3	3	0.73	96.9	82.769	57.3326
2015	12	31	7	52	15	0.3	3	0.71	97.2	82.769	55.2665
2015	12	31	8	2	15	0.3	3	0.69	97.9	82.6378	53.8858
2015	12	31	8	12	15	0.3	3	0.71	96.9	82.7034	55.4788
2015	12	31	8	22	15	0.3	3	0.74	98.4	82.6378	57.4954

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	8	32	15	0.3	3	0.67	97.9	82.5722	51.7802
2015	12	31	8	42	15	0.3	3	0.71	98.3	82.5722	54.8715
2015	12	31	8	52	15	0.3	3	0.72	94.7	82.5066	56.6278
2015	12	31	9	2	15	0.3	3	0.71	99.2	82.5066	55.3408
2015	12	31	9	12	15	0.3	3	0.73	96.9	82.5066	57.1425
2015	12	31	9	22	15	0.3	3	0.68	97.2	82.5722	52.8106
2015	12	31	9	32	15	0.3	3	0.67	98.1	82.3753	52.1651
2015	12	31	9	42	15	0.3	3	0.71	99.1	82.3753	54.7348
2015	12	31	9	52	15	0.3	3	0.7	95.9	82.2441	54.3872
2015	12	31	10	2	15	0.3	3	0.7	98.1	82.4409	54.5231
2015	12	31	10	12	15	0.3	3	0.73	96.7	82.3097	56.7433
2015	12	31	10	22	15	0.3	3	0.74	96.1	82.2441	57.2091
2015	12	31	10	32	15	0.3	3	0.74	97.4	82.3097	57.5135
2015	12	31	10	42	15	0.3	3	0.73	98.3	82.5066	56.6276
2015	12	31	10	52	15	0.3	3	0.71	95	82.3753	55.7626
2015	12	31	11	2	15	0.3	3	0.69	97.4	82.3753	53.4499
2015	12	31	11	12	15	0.3	3	0.67	96.2	82.3097	52.3784
2015	12	31	11	22	15	0.3	3	0.71	98.3	82.1785	54.5981
2015	12	31	11	32	15	0.3	3	0.64	97.3	82.3097	49.8108
2015	12	31	11	42	15	0.3	3	0.68	99.4	82.3753	52.9359
2015	12	31	11	52	15	0.3	3	0.69	97.1	82.3753	53.7068
2015	12	31	12	2	15	0.3	3	0.73	96.7	82.4409	56.8377
2015	12	31	12	12	15	0.3	3	0.7	99.1	82.7034	54.7044
2015	12	31	12	22	15	0.3	3	0.7	98.6	82.5066	54.311
2015	12	31	12	32	15	0.3	3	0.71	98	82.6378	54.9169
2015	12	31	12	42	15	0.3	3	0.71	96.6	82.5066	55.3406
2015	12	31	12	52	15	0.3	3	0.69	97.1	82.5722	53.8409
2015	12	31	13	2	15	0.3	3	0.72	99.2	82.6378	55.6903
2015	12	31	13	12	15	0.3	3	0.75	101.2	82.5722	57.4475
2015	12	31	13	22	15	0.3	3	0.7	95.9	82.7034	54.7044
2015	12	31	13	32	15	0.3	3	0.7	98.8	82.769	54.7497
2015	12	31	13	42	15	0.3	3	0.68	98.3	82.7034	52.8981
2015	12	31	13	52	15	0.3	3	0.73	98	82.5722	56.9323
2015	12	31	14	2	15	0.3	3	0.72	96.3	82.769	56.5575
2015	12	31	14	12	15	0.3	3	0.69	96.3	82.5722	53.841
2015	12	31	14	22	15	0.3	3	0.69	96	82.5066	53.5389
2015	12	31	14	32	15	0.3	3	0.72	98.2	82.7034	55.7366
2015	12	31	14	42	15	0.3	3	0.66	99.2	82.769	51.1343
2015	12	31	14	52	15	0.3	3	0.7	94	82.8347	54.7952
2015	12	31	15	2	15	0.3	3	0.72	94.9	82.769	56.8159
2015	12	31	15	12	15	0.3	3	0.72	95.5	82.769	56.0411
2015	12	31	15	22	15	0.3	3	0.71	97.4	82.8347	55.5706
2015	12	31	15	32	15	0.3	3	0.69	92.2	82.769	53.9752
2015	12	31	15	42	15	0.3	3	0.68	97.8	82.8347	52.7275
2015	12	31	15	52	15	0.3	3	0.7	96.7	82.769	55.0082
2015	12	31	16	2	15	0.3	3	0.67	96.2	82.7034	52.3823

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	16	12	15	0.3	3	0.69	96	83.0315	53.8949
2015	12	31	16	22	15	0.3	3	0.67	99.3	83.2284	52.4698
2015	12	31	16	32	15	0.3	3	0.66	98.5	83.1627	51.9075
2015	12	31	16	42	15	0.3	3	0.68	93	82.9659	53.8504
2015	12	31	16	52	15	0.3	3	0.67	96.7	83.0971	52.9021
2015	12	31	17	2	15	0.3	3	0.66	97.5	83.0315	51.3038
2015	12	31	17	12	15	0.3	3	0.67	96.2	83.0315	52.5993
2015	12	31	17	22	15	0.3	3	0.66	95.4	82.9659	52.0381
2015	12	31	17	32	15	0.3	3	0.73	95.7	82.9003	56.9101
2015	12	31	17	42	15	0.3	3	0.71	99.9	83.0315	54.9313
2015	12	31	17	52	15	0.3	3	0.67	96.5	82.8347	52.2106
2015	12	31	18	2	15	0.3	3	0.66	99.5	82.9003	50.9604
2015	12	31	18	12	15	0.3	3	0.68	93.6	83.0971	53.9393
2015	12	31	18	22	15	0.3	3	0.68	97.8	82.8347	52.986
2015	12	31	18	32	15	0.3	3	0.71	99.1	82.8347	55.0538
2015	12	31	18	42	15	0.3	3	0.73	99	82.769	56.816
2015	12	31	18	52	15	0.3	3	0.72	97.5	82.769	56.5577
2015	12	31	19	2	15	0.3	3	0.66	97.4	82.9659	51.7792
2015	12	31	19	12	15	0.3	3	0.68	98.3	82.7034	52.8983
2015	12	31	19	22	15	0.3	3	0.72	100	82.9003	55.6167
2015	12	31	19	32	15	0.3	3	0.72	99.1	82.8347	56.3461
2015	12	31	19	42	15	0.3	3	0.7	97	82.7034	54.7046
2015	12	31	19	52	15	0.3	3	0.69	96.3	82.8347	54.2784
2015	12	31	20	2	15	0.3	3	0.71	98.3	82.769	55.0082
2015	12	31	20	12	15	0.3	3	0.74	96.7	82.7034	57.5431
2015	12	31	20	22	15	0.3	3	0.68	98.9	82.769	52.9422
2015	12	31	20	32	15	0.3	3	0.67	95.3	82.769	52.4257
2015	12	31	20	42	15	0.3	3	0.7	95.4	82.8347	55.0538
2015	12	31	20	52	15	0.3	3	0.69	100.4	82.769	53.4587
2015	12	31	21	2	15	0.3	3	0.68	96.9	82.8347	53.503
2015	12	31	21	12	15	0.3	3	0.69	99.1	83.1627	53.7243
2015	12	31	21	22	15	0.3	3	0.67	99.6	83.1627	52.4266
2015	12	31	21	32	15	0.3	3	0.7	97.3	82.8347	54.5368
2015	12	31	21	42	15	0.3	3	0.71	98	82.9659	55.4038
2015	12	31	21	52	15	0.3	3	0.67	99.9	82.9659	52.0381
2015	12	31	22	2	15	0.3	3	0.72	97.1	82.9659	56.4394
2015	12	31	22	12	15	0.3	3	0.69	98.2	82.769	53.717
2015	12	31	22	22	15	0.3	3	0.72	99.7	82.769	55.783
2015	12	31	22	32	15	0.3	3	0.71	99.3	82.8347	55.3122
2015	12	31	22	42	15	0.3	3	0.66	100.3	82.8347	51.4352
2015	12	31	22	52	15	0.3	3	0.69	104.7	82.769	52.1674
2015	12	31	23	2	15	0.3	3	0.69	97.9	82.769	53.9752
2015	12	31	23	12	15	0.3	3	0.68	101.5	82.7034	52.1243
2015	12	31	23	22	15	0.3	3	0.7	99.9	82.7034	54.4466
2015	12	31	23	32	15	0.3	3	0.68	99.4	82.769	52.9422
2015	12	31	23	42	15	0.3	3	0.72	99.4	82.7034	56.2529

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	12	31	23	52	15	0.3	3	0.7	97.6	82.7034	54.1886

Alabama Gates Release
Station 0087

Date	Flow (cfs)
12/1/2015	0
12/2/2015	0
12/3/2015	0
12/4/2015	0
12/5/2015	0
12/6/2015	0
12/7/2015	0
12/8/2015	0
12/9/2015	0
12/10/2015	0
12/11/2015	0
12/12/2015	0
12/13/2015	0
12/14/2015	0
12/15/2015	0
12/16/2015	0
12/17/2015	0
12/18/2015	0
12/19/2015	0
12/20/2015	0
12/21/2015	0
12/22/2015	0
12/23/2015	0
12/24/2015	0
12/25/2015	0
12/26/2015	0
12/27/2015	0
12/28/2015	0
12/29/2015	0
12/30/2015	0
12/31/2015	0

Pumpback Station Discharge (0364)

12/1/15 0:00 == 47.4
12/1/15 0:05 == 47.2
12/1/15 0:10 == 47.2
12/1/15 0:15 == 47.4
12/1/15 0:20 == 47.3
12/1/15 0:25 == 47.4
12/1/15 0:30 == 47.4
12/1/15 0:35 == 47.2
12/1/15 0:40 == 47.3
12/1/15 0:45 == 47.3
12/1/15 0:50 == 47.4
12/1/15 0:55 == 47.2
12/1/15 1:00 == 47.2
12/1/15 1:05 == 47.4
12/1/15 1:10 == 47.4
12/1/15 1:15 == 47.4
12/1/15 1:20 == 47.3
12/1/15 1:25 == 47.3
12/1/15 1:30 == 47.3
12/1/15 1:35 == 47.3
12/1/15 1:40 == 47.3
12/1/15 1:45 == 47.3
12/1/15 1:50 == 47.3
12/1/15 1:55 == 47.4
12/1/15 2:00 == 47.3
12/1/15 2:05 == 47.3
12/1/15 2:10 == 47.3
12/1/15 2:15 == 47.4
12/1/15 2:20 == 47.2
12/1/15 2:25 == 47.3
12/1/15 2:30 == 47.3
12/1/15 2:35 == 47.2
12/1/15 2:40 == 47.4
12/1/15 2:45 == 47.3
12/1/15 2:50 == 47.3
12/1/15 2:55 == 47.1
12/1/15 3:00 == 47.1
12/1/15 3:05 == 47.2
12/1/15 3:10 == 47.2
12/1/15 3:15 == 47.2
12/1/15 3:20 == 47.2
12/1/15 3:25 == 47.2
12/1/15 3:30 == 47.1
12/1/15 3:35 == 47.2
12/1/15 3:40 == 47.2
12/1/15 3:45 == 47.2
12/1/15 3:50 == 47.2
12/1/15 3:55 == 47
12/1/15 4:00 == 47.2
12/1/15 4:05 == 47.1
12/1/15 4:10 == 47.2
12/1/15 4:15 == 47.2
12/1/15 4:20 == 47.2
12/1/15 4:25 == 47.2
12/1/15 4:30 == 47.1
12/1/15 4:35 == 47.2
12/1/15 4:40 == 47.2
12/1/15 4:45 == 47.2
12/1/15 4:50 == 47.3
12/1/15 4:55 == 47.2
12/1/15 5:00 == 47.2
12/1/15 5:05 == 47.2
12/1/15 5:10 == 47.2
12/1/15 5:15 == 47.2
12/1/15 5:20 == 47.1
12/1/15 5:25 == 47.1
12/1/15 5:30 == 47.1
12/1/15 5:35 == 47.1
12/1/15 5:40 == 47.2
12/1/15 5:45 == 47.2
12/1/15 5:50 == 47.2
12/1/15 5:55 == 47.2
12/1/15 6:00 == 47.2
12/1/15 6:05 == 47.2
12/1/15 6:10 == 47.2
12/1/15 6:15 == 47.1
12/1/15 6:20 == 47.2
12/1/15 6:25 == 47
12/1/15 6:30 == 47.1
12/1/15 6:35 == 47.4
12/1/15 6:40 == 47.2
12/1/15 6:45 == 47.2
12/1/15 6:50 == 47.2
12/1/15 6:55 == 47.2
12/1/15 7:00 == 47.2
12/1/15 7:05 == 47.4
12/1/15 7:10 == 47.2
12/1/15 7:15 == 47.2
12/1/15 7:20 == 47.2
12/1/15 7:25 == 47.3
12/1/15 7:30 == 47.3
12/1/15 7:35 == 47.3
12/1/15 7:40 == 47.3
12/1/15 7:45 == 47.3
12/1/15 7:50 == 47
12/1/15 7:55 == 47.2
12/1/15 8:00 == 47.1
12/1/15 8:05 == 47.1
12/1/15 8:10 == 47.2
12/1/15 8:15 == 47.2
12/1/15 8:20 == 47.3
12/1/15 8:25 == 47.2
12/1/15 8:30 == 47.3
12/1/15 8:35 == 47.4
12/1/15 8:40 == 47.2
12/1/15 8:45 == 47.4
12/1/15 8:50 == 47.4
12/1/15 8:55 == 46.8
12/1/15 9:00 == 47.5
12/1/15 9:05 == 47.5
12/1/15 9:10 == 47.4
12/1/15 9:15 == 47.5
12/1/15 9:20 == 47.5
12/1/15 9:25 == 47.1
12/1/15 9:30 == 47.2
12/1/15 9:35 == 47.5
12/1/15 9:40 == 47.5
12/1/15 9:45 == 47.1
12/1/15 9:50 == 47.4
12/1/15 9:55 == 47.2
12/1/15 10:00 == 47.4
12/1/15 10:05 == 47.2
12/1/15 10:10 == 47.3
12/1/15 10:15 == 47.5
12/1/15 10:20 == 47.4
12/1/15 10:25 == 47
12/1/15 10:30 == 47.4
12/1/15 10:35 == 47.2
12/1/15 10:40 == 47.4
12/1/15 10:45 == 47.5
12/1/15 10:50 == 47.4
12/1/15 10:55 == 47
12/1/15 11:00 == 47.2
12/1/15 11:05 == 47.5
12/1/15 11:10 == 47.3
12/1/15 11:15 == 47.1
12/1/15 11:20 == 47.1
12/1/15 11:25 == 47.4
12/1/15 11:30 == 47
12/1/15 11:35 == 47.5
12/1/15 11:40 == 47.2
12/1/15 11:45 == 47.3
12/1/15 11:50 == 47.6
12/1/15 11:55 == 47.2
12/1/15 12:00 == 47.3
12/1/15 12:05 == 47.3
12/1/15 12:10 == 47.1
12/1/15 12:15 == 47.2
12/1/15 12:20 == 47.1
12/1/15 12:25 == 47.1
12/1/15 12:30 == 47.4
12/1/15 12:35 == 47.1
12/1/15 12:40 == 47.2
12/1/15 12:45 == 47.1
12/1/15 12:50 == 47.1
12/1/15 12:55 == 47.1
12/1/15 13:00 == 46.8
12/1/15 13:05 == 47.2
12/1/15 13:10 == 47.2
12/1/15 13:15 == 47.1
12/1/15 13:20 == 47.2
12/1/15 13:25 == 47.1
12/1/15 13:30 == 47.1
12/1/15 13:35 == 47
12/1/15 13:40 == 47.2
12/1/15 13:45 == 47.1
12/1/15 13:50 == 47
12/1/15 13:55 == 47.2
12/1/15 14:00 == 47.2
12/1/15 14:05 == 47.2
12/1/15 14:10 == 47
12/1/15 14:15 == 47.4
12/1/15 14:20 == 47.2
12/1/15 14:25 == 47.2
12/1/15 14:30 == 47.1
12/1/15 14:35 == 47.2
12/1/15 14:40 == 47.1
12/1/15 14:45 == 47.1
12/1/15 14:50 == 47.2
12/1/15 14:55 == 47
12/1/15 15:00 == 47.1
12/1/15 15:05 == 47.1
12/1/15 15:10 == 47.2
12/1/15 15:15 == 47.1
12/1/15 15:20 == 47.1
12/1/15 15:25 == 47.2
12/1/15 15:30 == 47.1
12/1/15 15:35 == 47.1
12/1/15 15:40 == 47
12/1/15 15:45 == 47.1
12/1/15 15:50 == 47.1
12/1/15 15:55 == 47.1
12/1/15 16:00 == 47.1
12/1/15 16:05 == 47.2
12/1/15 16:10 == 47.1
12/1/15 16:15 == 47.2
12/1/15 16:20 == 47.1
12/1/15 16:25 == 47.1
12/1/15 16:30 == 47.2
12/1/15 16:35 == 47.1
12/1/15 16:40 == 47.1
12/1/15 16:45 == 47.1
12/1/15 16:50 == 47.1
12/1/15 16:55 == 47.1
12/1/15 17:00 == 47.2
12/1/15 17:05 == 47.2
12/1/15 17:10 == 47.2
12/1/15 17:15 == 47.2
12/1/15 17:20 == 47.2
12/1/15 17:25 == 47.3
12/1/15 17:30 == 47.2
12/1/15 17:35 == 47.3
12/1/15 17:40 == 47.2
12/1/15 17:45 == 47.2
12/1/15 17:50 == 47.3
12/1/15 17:55 == 47

Pumpback Station Discharge (0364)

12/1/15 18:00 == 47.2
12/1/15 18:05 == 47
12/1/15 18:10 == 47.1
12/1/15 18:15 == 47.2
12/1/15 18:20 == 47.1
12/1/15 18:25 == 47.2
12/1/15 18:30 == 47.1
12/1/15 18:35 == 47.2
12/1/15 18:40 == 46.9
12/1/15 18:45 == 47.2
12/1/15 18:50 == 47.2
12/1/15 18:55 == 47.3
12/1/15 19:00 == 47.2
12/1/15 19:05 == 47.2
12/1/15 19:10 == 47.3
12/1/15 19:15 == 47.2
12/1/15 19:20 == 47.4
12/1/15 19:25 == 47
12/1/15 19:30 == 47.2
12/1/15 19:35 == 47.1
12/1/15 19:40 == 47.2
12/1/15 19:45 == 47.2
12/1/15 19:50 == 47.1
12/1/15 19:55 == 47.1
12/1/15 20:00 == 47.1
12/1/15 20:05 == 47.1
12/1/15 20:10 == 47.1
12/1/15 20:15 == 47.2
12/1/15 20:20 == 47.1
12/1/15 20:25 == 47.1
12/1/15 20:30 == 47.1
12/1/15 20:35 == 47.1
12/1/15 20:40 == 47.2
12/1/15 20:45 == 47.1
12/1/15 20:50 == 47.2
12/1/15 20:55 == 47.2
12/1/15 21:00 == 47.1
12/1/15 21:05 == 47.2
12/1/15 21:10 == 47.1
12/1/15 21:15 == 47
12/1/15 21:20 == 47.1
12/1/15 21:25 == 47
12/1/15 21:30 == 47.2
12/1/15 21:35 == 47.1
12/1/15 21:40 == 47.1
12/1/15 21:45 == 47.2
12/1/15 21:50 == 47
12/1/15 21:55 == 47.1
12/1/15 22:00 == 47.2
12/1/15 22:05 == 47.1
12/1/15 22:10 == 47.2
12/1/15 22:15 == 47.2
12/1/15 22:20 == 47.2
12/1/15 22:25 == 47.1
12/1/15 22:30 == 47.1
12/1/15 22:35 == 47
12/1/15 22:40 == 47.2
12/1/15 22:45 == 47.1
12/1/15 22:50 == 47.2
12/1/15 22:55 == 47.1
12/1/15 23:00 == 47.1
12/1/15 23:05 == 47.1
12/1/15 23:10 == 47.1
12/1/15 23:15 == 47.1
12/1/15 23:20 == 47.1
12/1/15 23:25 == 47.1
12/1/15 23:30 == 47
12/1/15 23:35 == 47.1
12/1/15 23:40 == 47.2
12/1/15 23:45 == 47.3
12/1/15 23:50 == 47.1
12/1/15 23:55 == 47.1
12/2/15 0:00 == 47
12/2/15 0:05 == 47.1
12/2/15 0:10 == 47.1
12/2/15 0:15 == 47.2
12/2/15 0:20 == 47.1
12/2/15 0:25 == 47.2
12/2/15 0:30 == 47.1
12/2/15 0:35 == 47.1
12/2/15 0:40 == 47.1
12/2/15 0:45 == 47.1
12/2/15 0:50 == 47.1
12/2/15 0:55 == 47.2
12/2/15 1:00 == 47
12/2/15 1:05 == 47.3
12/2/15 1:10 == 47.2
12/2/15 1:15 == 47.2
12/2/15 1:20 == 47.1
12/2/15 1:25 == 47.2
12/2/15 1:30 == 47.1
12/2/15 1:35 == 47.2
12/2/15 1:40 == 47.1
12/2/15 1:45 == 47
12/2/15 1:50 == 47.2
12/2/15 1:55 == 47.1
12/2/15 2:00 == 47.2
12/2/15 2:05 == 47
12/2/15 2:10 == 47
12/2/15 2:15 == 47
12/2/15 2:20 == 47.2
12/2/15 2:25 == 47.2
12/2/15 2:30 == 47.1
12/2/15 2:35 == 47.1
12/2/15 2:40 == 47.1
12/2/15 2:45 == 47.1
12/2/15 2:50 == 47.1
12/2/15 2:55 == 47
12/2/15 3:00 == 47.1
12/2/15 3:05 == 47
12/2/15 3:10 == 47.1
12/2/15 3:15 == 47.1
12/2/15 3:20 == 47.1
12/2/15 3:25 == 47
12/2/15 3:30 == 47.1
12/2/15 3:35 == 47.1
12/2/15 3:40 == 47.2
12/2/15 3:45 == 47
12/2/15 3:50 == 47.1
12/2/15 3:55 == 47.1
12/2/15 4:00 == 47.2
12/2/15 4:05 == 47
12/2/15 4:10 == 47.2
12/2/15 4:15 == 47.3
12/2/15 4:20 == 47.1
12/2/15 4:25 == 47.1
12/2/15 4:30 == 47.1
12/2/15 4:35 == 47.1
12/2/15 4:40 == 47.1
12/2/15 4:45 == 47.1
12/2/15 4:50 == 47.2
12/2/15 4:55 == 47.1
12/2/15 5:00 == 47.1
12/2/15 5:05 == 47
12/2/15 5:10 == 47.1
12/2/15 5:15 == 47
12/2/15 5:20 == 47.1
12/2/15 5:25 == 47
12/2/15 5:30 == 47.1
12/2/15 5:35 == 47.1
12/2/15 5:40 == 47.1
12/2/15 5:45 == 47.1
12/2/15 5:50 == 47.1
12/2/15 5:55 == 47.2
12/2/15 6:00 == 47.1
12/2/15 6:05 == 47.2
12/2/15 6:10 == 47.2
12/2/15 6:15 == 47.2
12/2/15 6:20 == 47.1
12/2/15 6:25 == 47.1
12/2/15 6:30 == 47.1
12/2/15 6:35 == 47.2
12/2/15 6:40 == 47
12/2/15 6:45 == 47.1
12/2/15 6:50 == 47.1
12/2/15 6:55 == 47.1
12/2/15 7:00 == 47.1
12/2/15 7:05 == 47.2
12/2/15 7:10 == 47.1
12/2/15 7:15 == 47
12/2/15 7:20 == 47
12/2/15 7:25 == 47.1
12/2/15 7:30 == 47.1
12/2/15 7:35 == 47.1
12/2/15 7:40 == 47
12/2/15 7:45 == 47.1
12/2/15 7:50 == 47.1
12/2/15 7:55 == 47.1
12/2/15 8:00 == 47.2
12/2/15 8:05 == 47
12/2/15 8:10 == 47.1
12/2/15 8:15 == 46.9
12/2/15 8:20 == 47.2
12/2/15 8:25 == 47
12/2/15 8:30 == 47.1
12/2/15 8:35 == 47.1
12/2/15 8:40 == 47.4
12/2/15 8:45 == 47.3
12/2/15 8:50 == 46.9
12/2/15 8:55 == 47.4
12/2/15 9:00 == 47.3
12/2/15 9:05 == 47.3
12/2/15 9:10 == 47.3
12/2/15 9:15 == 47.4
12/2/15 9:20 == 46.9
12/2/15 9:25 == 47.2
12/2/15 9:30 == 47.2
12/2/15 9:35 == 47.4
12/2/15 9:40 == 43.5
12/2/15 9:45 == 38.7
12/2/15 9:50 == 47.3
12/2/15 9:55 == 47.5
12/2/15 10:00 == 47.3
12/2/15 10:05 == 47
12/2/15 10:10 == 47.4
12/2/15 10:15 == 47.2
12/2/15 10:20 == 47.3
12/2/15 10:25 == 47.4
12/2/15 10:30 == 46.8
12/2/15 10:35 == 47.7
12/2/15 10:40 == 46.7
12/2/15 10:45 == 47.6
12/2/15 10:50 == 47.2
12/2/15 10:55 == 47.5
12/2/15 11:00 == 47
12/2/15 11:05 == 47.2
12/2/15 11:10 == 47.1
12/2/15 11:15 == 46.9
12/2/15 11:20 == 47.3
12/2/15 11:25 == 47.1
12/2/15 11:30 == 47.2
12/2/15 11:35 == 47.3
12/2/15 11:40 == 47.1
12/2/15 11:45 == 47.2
12/2/15 11:50 == 47.3
12/2/15 11:55 == 47

Pumpback Station Discharge (0364)

12/2/15 12:00 == 47
12/2/15 12:05 == 47.2
12/2/15 12:10 == 46.8
12/2/15 12:15 == 47.1
12/2/15 12:20 == 47.1
12/2/15 12:25 == 47.1
12/2/15 12:30 == 47.1
12/2/15 12:35 == 47.1
12/2/15 12:40 == 47
12/2/15 12:45 == 47.1
12/2/15 12:50 == 47.2
12/2/15 12:55 == 47.1
12/2/15 13:00 == 47.2
12/2/15 13:05 == 47.1
12/2/15 13:10 == 47.1
12/2/15 13:15 == 47.1
12/2/15 13:20 == 47.2
12/2/15 13:25 == 47.2
12/2/15 13:30 == 47.2
12/2/15 13:35 == 47.1
12/2/15 13:40 == 47.3
12/2/15 13:45 == 47.3
12/2/15 13:50 == 47.2
12/2/15 13:55 == 47.1
12/2/15 14:00 == 47.2
12/2/15 14:05 == 47.2
12/2/15 14:10 == 46.7
12/2/15 14:15 == 47.2
12/2/15 14:20 == 47.1
12/2/15 14:25 == 47.3
12/2/15 14:30 == 47.2
12/2/15 14:35 == 47.2
12/2/15 14:40 == 47.1
12/2/15 14:45 == 47
12/2/15 14:50 == 47.2
12/2/15 14:55 == 47.1
12/2/15 15:00 == 47.3
12/2/15 15:05 == 47.3
12/2/15 15:10 == 47.1
12/2/15 15:15 == 47.1
12/2/15 15:20 == 47.1
12/2/15 15:25 == 47.2
12/2/15 15:30 == 47.2
12/2/15 15:35 == 47.3
12/2/15 15:40 == 47.1
12/2/15 15:45 == 47.2
12/2/15 15:50 == 47.3
12/2/15 15:55 == 47
12/2/15 16:00 == 47.1
12/2/15 16:05 == 47.2
12/2/15 16:10 == 47.2
12/2/15 16:15 == 47.1
12/2/15 16:20 == 47.2
12/2/15 16:25 == 47.1
12/2/15 16:30 == 47.1
12/2/15 16:35 == 47.2
12/2/15 16:40 == 47.1
12/2/15 16:45 == 47.2
12/2/15 16:50 == 47.3
12/2/15 16:55 == 47.1
12/2/15 17:00 == 47
12/2/15 17:05 == 47.2
12/2/15 17:10 == 47.1
12/2/15 17:15 == 47.3
12/2/15 17:20 == 47.2
12/2/15 17:25 == 47.3
12/2/15 17:30 == 47.2
12/2/15 17:35 == 47.3
12/2/15 17:40 == 47.3
12/2/15 17:45 == 47.3
12/2/15 17:50 == 47.2
12/2/15 17:55 == 47
12/2/15 18:00 == 47.1
12/2/15 18:05 == 47.3
12/2/15 18:10 == 47
12/2/15 18:15 == 47.1
12/2/15 18:20 == 47.2
12/2/15 18:25 == 47.1
12/2/15 18:30 == 47.1
12/2/15 18:35 == 47.4
12/2/15 18:40 == 47
12/2/15 18:45 == 47.2
12/2/15 18:50 == 47.2
12/2/15 18:55 == 47.2
12/2/15 19:00 == 47.2
12/2/15 19:05 == 47.3
12/2/15 19:10 == 47.2
12/2/15 19:15 == 47.2
12/2/15 19:20 == 47.2
12/2/15 19:25 == 47.1
12/2/15 19:30 == 47.2
12/2/15 19:35 == 47.1
12/2/15 19:40 == 47
12/2/15 19:45 == 47.1
12/2/15 19:50 == 47.1
12/2/15 19:55 == 47.1
12/2/15 20:00 == 47.1
12/2/15 20:05 == 47.2
12/2/15 20:10 == 47
12/2/15 20:15 == 47.1
12/2/15 20:20 == 47.1
12/2/15 20:25 == 47.1
12/2/15 20:30 == 47.1
12/2/15 20:35 == 47.4
12/2/15 20:40 == 47
12/2/15 20:45 == 47.2
12/2/15 20:50 == 47.2
12/2/15 20:55 == 47.1
12/2/15 21:00 == 47.2
12/2/15 21:05 == 47.2
12/2/15 21:10 == 47.1
12/2/15 21:15 == 47.1
12/2/15 21:20 == 47.3
12/2/15 21:25 == 47.2
12/2/15 21:30 == 47.2
12/2/15 21:35 == 47.1
12/2/15 21:40 == 47.1
12/2/15 21:45 == 47.1
12/2/15 21:50 == 47.2
12/2/15 21:55 == 47.2
12/2/15 22:00 == 47.2
12/2/15 22:05 == 47.1
12/2/15 22:10 == 47.1
12/2/15 22:15 == 47.2
12/2/15 22:20 == 47.1
12/2/15 22:25 == 47.1
12/2/15 22:30 == 47.1
12/2/15 22:35 == 47.2
12/2/15 22:40 == 47.2
12/2/15 22:45 == 47.1
12/2/15 22:50 == 47.3
12/2/15 22:55 == 47
12/2/15 23:00 == 47.1
12/2/15 23:05 == 47.2
12/2/15 23:10 == 47.1
12/2/15 23:15 == 47.1
12/2/15 23:20 == 47.1
12/2/15 23:25 == 47.2
12/2/15 23:30 == 47.2
12/2/15 23:35 == 47.1
12/2/15 23:40 == 47.2
12/2/15 23:45 == 47.1
12/2/15 23:50 == 47.3
12/2/15 23:55 == 47
12/3/15 0:00 == 47.1
12/3/15 0:05 == 47.1
12/3/15 0:10 == 47
12/3/15 0:15 == 47.2
12/3/15 0:20 == 47.1
12/3/15 0:25 == 47
12/3/15 0:30 == 47.2
12/3/15 0:35 == 47.2
12/3/15 0:40 == 47
12/3/15 0:45 == 47.2
12/3/15 0:50 == 47.2
12/3/15 0:55 == 47.2
12/3/15 1:00 == 47.1
12/3/15 1:05 == 47.1
12/3/15 1:10 == 47.2
12/3/15 1:15 == 47
12/3/15 1:20 == 47.2
12/3/15 1:25 == 47.1
12/3/15 1:30 == 47.1
12/3/15 1:35 == 47.1
12/3/15 1:40 == 47.1
12/3/15 1:45 == 47.1
12/3/15 1:50 == #
12/3/15 1:55 == 47
12/3/15 2:00 == 47.1
12/3/15 2:05 == 47.1
12/3/15 2:10 == 47.1
12/3/15 2:15 == 47.1
12/3/15 2:20 == 47.1
12/3/15 2:25 == 47.2
12/3/15 2:30 == 47.1
12/3/15 2:35 == 47.1
12/3/15 2:40 == 47.3
12/3/15 2:45 == 47.2
12/3/15 2:50 == 47
12/3/15 2:55 == 47.3
12/3/15 3:00 == 47.1
12/3/15 3:05 == 47.1
12/3/15 3:10 == 47.2
12/3/15 3:15 == 47.1
12/3/15 3:20 == 47.1
12/3/15 3:25 == 47.2
12/3/15 3:30 == 47
12/3/15 3:35 == 47.2
12/3/15 3:40 == 47.3
12/3/15 3:45 == 47
12/3/15 3:50 == 47
12/3/15 3:55 == 47.1
12/3/15 4:00 == 47.2
12/3/15 4:05 == 47.1
12/3/15 4:10 == 47
12/3/15 4:15 == 47.1
12/3/15 4:20 == 47.1
12/3/15 4:25 == 47.2
12/3/15 4:30 == 47
12/3/15 4:35 == 47.2
12/3/15 4:40 == 47.1
12/3/15 4:45 == 47.2
12/3/15 4:50 == 47.2
12/3/15 4:55 == 46.9
12/3/15 5:00 == 47.1
12/3/15 5:05 == 47.1
12/3/15 5:10 == 47.2
12/3/15 5:15 == 47.1
12/3/15 5:20 == 47.1
12/3/15 5:25 == 47
12/3/15 5:30 == 47.1
12/3/15 5:35 == 47
12/3/15 5:40 == 47.1
12/3/15 5:45 == 47.2
12/3/15 5:50 == 47.1
12/3/15 5:55 == 47.1

Pumpback Station Discharge (0364)

12/3/15 6:00 == 47.1
12/3/15 6:05 == 47
12/3/15 6:10 == 47.2
12/3/15 6:15 == 47.1
12/3/15 6:20 == 47.1
12/3/15 6:25 == 47.2
12/3/15 6:30 == 47.1
12/3/15 6:35 == 47.2
12/3/15 6:40 == 47.1
12/3/15 6:45 == 47
12/3/15 6:50 == 47.1
12/3/15 6:55 == 47.1
12/3/15 7:00 == 47.1
12/3/15 7:05 == 47.2
12/3/15 7:10 == 47.1
12/3/15 7:15 == 47
12/3/15 7:20 == 47.2
12/3/15 7:25 == 47.2
12/3/15 7:30 == 47.1
12/3/15 7:35 == 47.1
12/3/15 7:40 == 47.2
12/3/15 7:45 == 47.2
12/3/15 7:50 == 47.1
12/3/15 7:55 == 47.1
12/3/15 8:00 == 47.1
12/3/15 8:05 == 47.1
12/3/15 8:10 == 47.3
12/3/15 8:15 == 47.4
12/3/15 8:20 == 47.1
12/3/15 8:25 == 47.2
12/3/15 8:30 == 47.2
12/3/15 8:35 == 47.2
12/3/15 8:40 == 47.6
12/3/15 8:45 == 46.8
12/3/15 8:50 == 47.4
12/3/15 8:55 == 47.5
12/3/15 9:00 == 47.2
12/3/15 9:05 == 47.3
12/3/15 9:10 == 47.2
12/3/15 9:15 == 47.2
12/3/15 9:20 == 47.1
12/3/15 9:25 == 47.3
12/3/15 9:30 == 47.4
12/3/15 9:35 == 46.9
12/3/15 9:40 == 46.8
12/3/15 9:45 == 47.4
12/3/15 9:50 == 47.5
12/3/15 9:55 == 47
12/3/15 10:00 == 47.4
12/3/15 10:05 == 47.3
12/3/15 10:10 == 47.2
12/3/15 10:15 == 47.3
12/3/15 10:20 == 47
12/3/15 10:25 == 47.5
12/3/15 10:30 == 47.2
12/3/15 10:35 == 47.3
12/3/15 10:40 == 47.5
12/3/15 10:45 == 47.2
12/3/15 10:50 == 47.4
12/3/15 10:55 == 47.2
12/3/15 11:00 == 47.3
12/3/15 11:05 == 47.2
12/3/15 11:10 == 47.5
12/3/15 11:15 == 46.9
12/3/15 11:20 == 47.1
12/3/15 11:25 == 47.4
12/3/15 11:30 == 47.3
12/3/15 11:35 == 47.2
12/3/15 11:40 == 47.3
12/3/15 11:45 == 47.2
12/3/15 11:50 == 47.5
12/3/15 11:55 == 47.3
12/3/15 12:00 == 47.3
12/3/15 12:05 == 47.4
12/3/15 12:10 == 47.6
12/3/15 12:15 == 46.5
12/3/15 12:20 == 47.3
12/3/15 12:25 == 46.9
12/3/15 12:30 == 47.2
12/3/15 12:35 == 47.2
12/3/15 12:40 == 47.1
12/3/15 12:45 == 46.8
12/3/15 12:50 == 47.3
12/3/15 12:55 == 47.1
12/3/15 13:00 == 47.2
12/3/15 13:05 == 46.9
12/3/15 13:10 == 47.4
12/3/15 13:15 == 47.2
12/3/15 13:20 == 47.1
12/3/15 13:25 == 47.1
12/3/15 13:30 == 47.1
12/3/15 13:35 == 47.1
12/3/15 13:40 == 47.2
12/3/15 13:45 == 47.2
12/3/15 13:50 == 47.2
12/3/15 13:55 == 47.2
12/3/15 14:00 == 47.1
12/3/15 14:05 == 47.2
12/3/15 14:10 == 47.2
12/3/15 14:15 == 46.6
12/3/15 14:20 == 46.9
12/3/15 14:25 == 47.2
12/3/15 14:30 == 47.1
12/3/15 14:35 == 47.1
12/3/15 14:40 == 47.1
12/3/15 14:45 == 47.1
12/3/15 14:50 == 47.2
12/3/15 14:55 == 47.4
12/3/15 15:00 == 47
12/3/15 15:05 == 47.1
12/3/15 15:10 == 47.3
12/3/15 15:15 == 46.9
12/3/15 15:20 == 47.2
12/3/15 15:25 == 47.2
12/3/15 15:30 == 47.1
12/3/15 15:35 == 47.3
12/3/15 15:40 == 47.2
12/3/15 15:45 == 46.9
12/3/15 15:50 == 47
12/3/15 15:55 == 47.2
12/3/15 16:00 == 47
12/3/15 16:05 == 47
12/3/15 16:10 == 47.1
12/3/15 16:15 == 47
12/3/15 16:20 == 47.3
12/3/15 16:25 == 47.2
12/3/15 16:30 == 47.2
12/3/15 16:35 == 47.1
12/3/15 16:40 == 47.2
12/3/15 16:45 == 47.1
12/3/15 16:50 == 47.2
12/3/15 16:55 == 47.2
12/3/15 17:00 == 47.1
12/3/15 17:05 == 47.1
12/3/15 17:10 == 47.1
12/3/15 17:15 == 47.1
12/3/15 17:20 == 47
12/3/15 17:25 == 47.1
12/3/15 17:30 == 47
12/3/15 17:35 == 47.1
12/3/15 17:40 == 47.1
12/3/15 17:45 == 47.2
12/3/15 17:50 == 47.1
12/3/15 17:55 == 47.2
12/3/15 18:00 == 47.1
12/3/15 18:05 == 47.1
12/3/15 18:10 == 47.2
12/3/15 18:15 == 47
12/3/15 18:20 == 47.2
12/3/15 18:25 == 47.2
12/3/15 18:30 == 47.2
12/3/15 18:35 == 47.1
12/3/15 18:40 == 47.2
12/3/15 18:45 == 47.3
12/3/15 18:50 == 47.1
12/3/15 18:55 == 47.3
12/3/15 19:00 == 47.1
12/3/15 19:05 == 47.2
12/3/15 19:10 == 47.2
12/3/15 19:15 == 47
12/3/15 19:20 == 47.1
12/3/15 19:25 == 47.1
12/3/15 19:30 == 47.2
12/3/15 19:35 == 47.1
12/3/15 19:40 == 47.2
12/3/15 19:45 == 47.1
12/3/15 19:50 == 47.1
12/3/15 19:55 == 47.1
12/3/15 20:00 == 47.1
12/3/15 20:05 == 47.2
12/3/15 20:10 == 47.2
12/3/15 20:15 == 47.1
12/3/15 20:20 == 47.1
12/3/15 20:25 == 47.3
12/3/15 20:30 == 47.2
12/3/15 20:35 == 47.1
12/3/15 20:40 == 47.2
12/3/15 20:45 == 47.1
12/3/15 20:50 == 47.1
12/3/15 20:55 == 47.2
12/3/15 21:00 == 47.2
12/3/15 21:05 == 47.1
12/3/15 21:10 == 47.1
12/3/15 21:15 == 47.2
12/3/15 21:20 == 47.2
12/3/15 21:25 == 47.1
12/3/15 21:30 == 47.1
12/3/15 21:35 == 47.2
12/3/15 21:40 == 47.3
12/3/15 21:45 == 47.2
12/3/15 21:50 == 47.2
12/3/15 21:55 == 47.2
12/3/15 22:00 == 47.1
12/3/15 22:05 == 47.2
12/3/15 22:10 == 47
12/3/15 22:15 == 47.1
12/3/15 22:20 == 47
12/3/15 22:25 == 47.3
12/3/15 22:30 == 47.1
12/3/15 22:35 == 47.2
12/3/15 22:40 == 47.1
12/3/15 22:45 == 47.2
12/3/15 22:50 == 47.1
12/3/15 22:55 == 47.3
12/3/15 23:00 == 47.1
12/3/15 23:05 == 47.1
12/3/15 23:10 == 47.2
12/3/15 23:15 == 47.2
12/3/15 23:20 == 47.1
12/3/15 23:25 == 47.2
12/3/15 23:30 == 47.2
12/3/15 23:35 == 47.1
12/3/15 23:40 == 47.2
12/3/15 23:45 == 47.3
12/3/15 23:50 == 47.3
12/3/15 23:55 == 47

Pumpback Station Discharge (0364)

12/4/15 0:00 == 47
12/4/15 0:05 == 47.1
12/4/15 0:10 == 47.1
12/4/15 0:15 == 47.1
12/4/15 0:20 == 47.1
12/4/15 0:25 == 47.1
12/4/15 0:30 == 47.1
12/4/15 0:35 == 47.3
12/4/15 0:40 == 47.3
12/4/15 0:45 == 47
12/4/15 0:50 == 47.2
12/4/15 0:55 == 47.1
12/4/15 1:00 == 47.1
12/4/15 1:05 == 47
12/4/15 1:10 == 47.1
12/4/15 1:15 == 47.2
12/4/15 1:20 == 47.1
12/4/15 1:25 == 47.1
12/4/15 1:30 == 47.1
12/4/15 1:35 == #
12/4/15 1:40 == 47.1
12/4/15 1:45 == 47.1
12/4/15 1:50 == 47.1
12/4/15 1:55 == 47.1
12/4/15 2:00 == 47
12/4/15 2:05 == 47.1
12/4/15 2:10 == 47.2
12/4/15 2:15 == 47.1
12/4/15 2:20 == 47.1
12/4/15 2:25 == 47
12/4/15 2:30 == 47.1
12/4/15 2:35 == 47.2
12/4/15 2:40 == 47.1
12/4/15 2:45 == 47.1
12/4/15 2:50 == 47.1
12/4/15 2:55 == 47
12/4/15 3:00 == 47.1
12/4/15 3:05 == 47.2
12/4/15 3:10 == 47.1
12/4/15 3:15 == 47.1
12/4/15 3:20 == 47.1
12/4/15 3:25 == 47
12/4/15 3:30 == 47
12/4/15 3:35 == 47.2
12/4/15 3:40 == 47.3
12/4/15 3:45 == 47
12/4/15 3:50 == 47
12/4/15 3:55 == 47.1
12/4/15 4:00 == 47.2
12/4/15 4:05 == 47.2
12/4/15 4:10 == 47.2
12/4/15 4:15 == 47.2
12/4/15 4:20 == 47.2
12/4/15 4:25 == 47.2
12/4/15 4:30 == 47.1
12/4/15 4:35 == 47.1
12/4/15 4:40 == 47.1
12/4/15 4:45 == 47
12/4/15 4:50 == 47
12/4/15 4:55 == 47.1
12/4/15 5:00 == 47
12/4/15 5:05 == 47
12/4/15 5:10 == 47.1
12/4/15 5:15 == 47
12/4/15 5:20 == 47
12/4/15 5:25 == 47
12/4/15 5:30 == 47.1
12/4/15 5:35 == 47
12/4/15 5:40 == 47.1
12/4/15 5:45 == 47
12/4/15 5:50 == 47
12/4/15 5:55 == 47
12/4/15 6:00 == 47.1
12/4/15 6:05 == 47.1
12/4/15 6:10 == 47.1
12/4/15 6:15 == 47.1
12/4/15 6:20 == 47.1
12/4/15 6:25 == 47.1
12/4/15 6:30 == 46.9
12/4/15 6:35 == 47.1
12/4/15 6:40 == 47.1
12/4/15 6:45 == 47.2
12/4/15 6:50 == 47.1
12/4/15 6:55 == 47.1
12/4/15 7:00 == 47.1
12/4/15 7:05 == 47.2
12/4/15 7:10 == 47.1
12/4/15 7:15 == 47.1
12/4/15 7:20 == 47.3
12/4/15 7:25 == 47.2
12/4/15 7:30 == 47
12/4/15 7:35 == 47.2
12/4/15 7:40 == 47.2
12/4/15 7:45 == 47
12/4/15 7:50 == 47.1
12/4/15 7:55 == 47.3
12/4/15 8:00 == 47.1
12/4/15 8:05 == 47
12/4/15 8:10 == 47.4
12/4/15 8:15 == 47.1
12/4/15 8:20 == 47
12/4/15 8:25 == 47.1
12/4/15 8:30 == 47.1
12/4/15 8:35 == 47.3
12/4/15 8:40 == 47.6
12/4/15 8:45 == 46.4
12/4/15 8:50 == 47.3
12/4/15 8:55 == 47.3
12/4/15 9:00 == 47.2
12/4/15 9:05 == 47.2
12/4/15 9:10 == 47.3
12/4/15 9:15 == 47
12/4/15 9:20 == 47.3
12/4/15 9:25 == 47
12/4/15 9:30 == 47.2
12/4/15 9:35 == 47.2
12/4/15 9:40 == 47.2
12/4/15 9:45 == 47.3
12/4/15 9:50 == 47.2
12/4/15 9:55 == 47.2
12/4/15 10:00 == 47
12/4/15 10:05 == 47.1
12/4/15 10:10 == 47.2
12/4/15 10:15 == 47.1
12/4/15 10:20 == 47.2
12/4/15 10:25 == 47.1
12/4/15 10:30 == 47.1
12/4/15 10:35 == 47.1
12/4/15 10:40 == 47.2
12/4/15 10:45 == 47.1
12/4/15 10:50 == 47.2
12/4/15 10:55 == 47.3
12/4/15 11:00 == 47.1
12/4/15 11:05 == 47.1
12/4/15 11:10 == 47.1
12/4/15 11:15 == 47
12/4/15 11:20 == 46.7
12/4/15 11:25 == 47.1
12/4/15 11:30 == 46.8
12/4/15 11:35 == 46.9
12/4/15 11:40 == 46.9
12/4/15 11:45 == 46.8
12/4/15 11:50 == 46.9
12/4/15 11:55 == 47.2
12/4/15 12:00 == 47
12/4/15 12:05 == 47
12/4/15 12:10 == 47.2
12/4/15 12:15 == 47.1
12/4/15 12:20 == 47.1
12/4/15 12:25 == 47.2
12/4/15 12:30 == 47.1
12/4/15 12:35 == 47.1
12/4/15 12:40 == 47.1
12/4/15 12:45 == 47.1
12/4/15 12:50 == 47.2
12/4/15 12:55 == 47.1
12/4/15 13:00 == 47.2
12/4/15 13:05 == 47.1
12/4/15 13:10 == 47
12/4/15 13:15 == 47.1
12/4/15 13:20 == 47.2
12/4/15 13:25 == 47.1
12/4/15 13:30 == 47.1
12/4/15 13:35 == 47.2
12/4/15 13:40 == 47.3
12/4/15 13:45 == 47.1
12/4/15 13:50 == 47.2
12/4/15 13:55 == 47.3
12/4/15 14:00 == 47.1
12/4/15 14:05 == 47
12/4/15 14:10 == 47.3
12/4/15 14:15 == 47.2
12/4/15 14:20 == 47.4
12/4/15 14:25 == 47.3
12/4/15 14:30 == 47.4
12/4/15 14:35 == 47.4
12/4/15 14:40 == 47.4
12/4/15 14:45 == 47.2
12/4/15 14:50 == 47.3
12/4/15 14:55 == 47.4
12/4/15 15:00 == 47.2
12/4/15 15:05 == 47.3
12/4/15 15:10 == 47.3
12/4/15 15:15 == 47.3
12/4/15 15:20 == 47.3
12/4/15 15:25 == 47.2
12/4/15 15:30 == 47.1
12/4/15 15:35 == 47.2
12/4/15 15:40 == 47.3
12/4/15 15:45 == 47.1
12/4/15 15:50 == 47.1
12/4/15 15:55 == 47.1
12/4/15 16:00 == 47.1
12/4/15 16:05 == 47.1
12/4/15 16:10 == 47.2
12/4/15 16:15 == 47.2
12/4/15 16:20 == 47.2
12/4/15 16:25 == 47.2
12/4/15 16:30 == 47.1
12/4/15 16:35 == 47.2
12/4/15 16:40 == 47.1
12/4/15 16:45 == 47.1
12/4/15 16:50 == 47.2
12/4/15 16:55 == 47.1
12/4/15 17:00 == 47.2
12/4/15 17:05 == 47.2
12/4/15 17:10 == 47.2
12/4/15 17:15 == 47
12/4/15 17:20 == 47.1
12/4/15 17:25 == 47.1
12/4/15 17:30 == 47.1
12/4/15 17:35 == 47.1
12/4/15 17:40 == 47.2
12/4/15 17:45 == 47.2
12/4/15 17:50 == 47
12/4/15 17:55 == 47.1

Pumpback Station Discharge (0364)

12/4/15 18:00 == 47.2
12/4/15 18:05 == 47.1
12/4/15 18:10 == 47.3
12/4/15 18:15 == 47.1
12/4/15 18:20 == 47
12/4/15 18:25 == 47
12/4/15 18:30 == 47.2
12/4/15 18:35 == 47.1
12/4/15 18:40 == 47.2
12/4/15 18:45 == 47
12/4/15 18:50 == 47.1
12/4/15 18:55 == 47.3
12/4/15 19:00 == 47.1
12/4/15 19:05 == 47.2
12/4/15 19:10 == 47.2
12/4/15 19:15 == 47
12/4/15 19:20 == 47.1
12/4/15 19:25 == 47.2
12/4/15 19:30 == 47.2
12/4/15 19:35 == 47.1
12/4/15 19:40 == 47
12/4/15 19:45 == 47.1
12/4/15 19:50 == 47.1
12/4/15 19:55 == 47.1
12/4/15 20:00 == 47
12/4/15 20:05 == 46.9
12/4/15 20:10 == 47.1
12/4/15 20:15 == 47.1
12/4/15 20:20 == 47.1
12/4/15 20:25 == 47.1
12/4/15 20:30 == 47
12/4/15 20:35 == 47.2
12/4/15 20:40 == 47.1
12/4/15 20:45 == 47.1
12/4/15 20:50 == 47.2
12/4/15 20:55 == 47.1
12/4/15 21:00 == 47.1
12/4/15 21:05 == 47.1
12/4/15 21:10 == 47.1
12/4/15 21:15 == 47.1
12/4/15 21:20 == 47
12/4/15 21:25 == 47.1
12/4/15 21:30 == 47.2
12/4/15 21:35 == 47.3
12/4/15 21:40 == 47.3
12/4/15 21:45 == 47.3
12/4/15 21:50 == 47.2
12/4/15 21:55 == 47.3
12/4/15 22:00 == 47.3
12/4/15 22:05 == 47.3
12/4/15 22:10 == 47.3
12/4/15 22:15 == 47.3
12/4/15 22:20 == 47.3
12/4/15 22:25 == 47.4
12/4/15 22:30 == 47.1
12/4/15 22:35 == 47.1
12/4/15 22:40 == 47.2
12/4/15 22:45 == 47.2
12/4/15 22:50 == 47.2
12/4/15 22:55 == 47.1
12/4/15 23:00 == 47.1
12/4/15 23:05 == 47.1
12/4/15 23:10 == 47.2
12/4/15 23:15 == 47.1
12/4/15 23:20 == 47.1
12/4/15 23:25 == 47.1
12/4/15 23:30 == 47.1
12/4/15 23:35 == 47.3
12/4/15 23:40 == 47.1
12/4/15 23:45 == 47.1
12/4/15 23:50 == 47.3
12/4/15 23:55 == 47
12/5/15 0:00 == 47.2
12/5/15 0:05 == 47
12/5/15 0:10 == 47.1
12/5/15 0:15 == 47.3
12/5/15 0:20 == 47.2
12/5/15 0:25 == 47
12/5/15 0:30 == 47.2
12/5/15 0:35 == 47.2
12/5/15 0:40 == 47.2
12/5/15 0:45 == 47.2
12/5/15 0:50 == 47.3
12/5/15 0:55 == 47.1
12/5/15 1:00 == 47
12/5/15 1:05 == 47.2
12/5/15 1:10 == 47.1
12/5/15 1:15 == 47.2
12/5/15 1:20 == 47.1
12/5/15 1:25 == 47.1
12/5/15 1:30 == 47.3
12/5/15 1:35 == 47.2
12/5/15 1:40 == 47.1
12/5/15 1:45 == 47.1
12/5/15 1:50 == 47
12/5/15 1:55 == 47.1
12/5/15 2:00 == 47.1
12/5/15 2:05 == 47.1
12/5/15 2:10 == 47.2
12/5/15 2:15 == 47.2
12/5/15 2:20 == 47.2
12/5/15 2:25 == 47
12/5/15 2:30 == 47.1
12/5/15 2:35 == 47.1
12/5/15 2:40 == 47.2
12/5/15 2:45 == 47.2
12/5/15 2:50 == 47.2
12/5/15 2:55 == 47.1
12/5/15 3:00 == 47.1
12/5/15 3:05 == 47.1
12/5/15 3:10 == 47.2
12/5/15 3:15 == 47.2
12/5/15 3:20 == 47
12/5/15 3:25 == 47.2
12/5/15 3:30 == 47.2
12/5/15 3:35 == 47.1
12/5/15 3:40 == 47.2
12/5/15 3:45 == 47.2
12/5/15 3:50 == 47.2
12/5/15 3:55 == 47.2
12/5/15 4:00 == 47.1
12/5/15 4:05 == 47.2
12/5/15 4:10 == 47.3
12/5/15 4:15 == 47.1
12/5/15 4:20 == 47.2
12/5/15 4:25 == 47.2
12/5/15 4:30 == 47.2
12/5/15 4:35 == 47.1
12/5/15 4:40 == 47.1
12/5/15 4:45 == 47.2
12/5/15 4:50 == 47.1
12/5/15 4:55 == 47
12/5/15 5:00 == 47
12/5/15 5:05 == 47.2
12/5/15 5:10 == 47.1
12/5/15 5:15 == 47.3
12/5/15 5:20 == 47.1
12/5/15 5:25 == 47.2
12/5/15 5:30 == 47
12/5/15 5:35 == 47.2
12/5/15 5:40 == 47.1
12/5/15 5:45 == 47.2
12/5/15 5:50 == 47.2
12/5/15 5:55 == 47.2
12/5/15 6:00 == 47.1
12/5/15 6:05 == 47.2
12/5/15 6:10 == 47.3
12/5/15 6:15 == 47.1
12/5/15 6:20 == 47.2
12/5/15 6:25 == 47.2
12/5/15 6:30 == 47.2
12/5/15 6:35 == 47.3
12/5/15 6:40 == 47.1
12/5/15 6:45 == 47.2
12/5/15 6:50 == 47.2
12/5/15 6:55 == 47.2
12/5/15 7:00 == 47.2
12/5/15 7:05 == 47.2
12/5/15 7:10 == 47.2
12/5/15 7:15 == 47.3
12/5/15 7:20 == 47.1
12/5/15 7:25 == 47.1
12/5/15 7:30 == 47.1
12/5/15 7:35 == 47.2
12/5/15 7:40 == 47.2
12/5/15 7:45 == 47.1
12/5/15 7:50 == 47.1
12/5/15 7:55 == 47
12/5/15 8:00 == 47.1
12/5/15 8:05 == 47.1
12/5/15 8:10 == 47.2
12/5/15 8:15 == 47.2
12/5/15 8:20 == 47.2
12/5/15 8:25 == 47.4
12/5/15 8:30 == 46.8
12/5/15 8:35 == 47.3
12/5/15 8:40 == 47.3
12/5/15 8:45 == 47.2
12/5/15 8:50 == 47.2
12/5/15 8:55 == 47.2
12/5/15 9:00 == 47.2
12/5/15 9:05 == 47.2
12/5/15 9:10 == 47.2
12/5/15 9:15 == 47.2
12/5/15 9:20 == 47.3
12/5/15 9:25 == 47.4
12/5/15 9:30 == 47.1
12/5/15 9:35 == 47.3
12/5/15 9:40 == 47.5
12/5/15 9:45 == 47.3
12/5/15 9:50 == 47.3
12/5/15 9:55 == 47.3
12/5/15 10:00 == 47.4
12/5/15 10:05 == 47.2
12/5/15 10:10 == 47.4
12/5/15 10:15 == 47.2
12/5/15 10:20 == 47.5
12/5/15 10:25 == 47.3
12/5/15 10:30 == 47.2
12/5/15 10:35 == 47.4
12/5/15 10:40 == 47.3
12/5/15 10:45 == 47.5
12/5/15 10:50 == 47.5
12/5/15 10:55 == 47.4
12/5/15 11:00 == 47.4
12/5/15 11:05 == 47.5
12/5/15 11:10 == 47.5
12/5/15 11:15 == 47.3
12/5/15 11:20 == 47.4
12/5/15 11:25 == 47.4
12/5/15 11:30 == 47.5
12/5/15 11:35 == 47.5
12/5/15 11:40 == 47.3
12/5/15 11:45 == 47.1
12/5/15 11:50 == 47.5
12/5/15 11:55 == 47.3

Pumpback Station Discharge (0364)

12/5/15 12:00 == 47.3
12/5/15 12:05 == 47.4
12/5/15 12:10 == 47.3
12/5/15 12:15 == 47.3
12/5/15 12:20 == 47.3
12/5/15 12:25 == 47.4
12/5/15 12:30 == 47.3
12/5/15 12:35 == 47.4
12/5/15 12:40 == 47.4
12/5/15 12:45 == 47.3
12/5/15 12:50 == 47.4
12/5/15 12:55 == 47.5
12/5/15 13:00 == 47.2
12/5/15 13:05 == 47.3
12/5/15 13:10 == 47.2
12/5/15 13:15 == 47.3
12/5/15 13:20 == 47.3
12/5/15 13:25 == 47.1
12/5/15 13:30 == 47.2
12/5/15 13:35 == 47.3
12/5/15 13:40 == 47.3
12/5/15 13:45 == 47.3
12/5/15 13:50 == 47.4
12/5/15 13:55 == 47.4
12/5/15 14:00 == 47.3
12/5/15 14:05 == 47.3
12/5/15 14:10 == 47.5
12/5/15 14:15 == 47.4
12/5/15 14:20 == 47.5
12/5/15 14:25 == 47.6
12/5/15 14:30 == 47.4
12/5/15 14:35 == 47.5
12/5/15 14:40 == 47.4
12/5/15 14:45 == 47.3
12/5/15 14:50 == 47.4
12/5/15 14:55 == 47.2
12/5/15 15:00 == 47.4
12/5/15 15:05 == 47.4
12/5/15 15:10 == 47.4
12/5/15 15:15 == 47.5
12/5/15 15:20 == 47.4
12/5/15 15:25 == 47.2
12/5/15 15:30 == 47.1
12/5/15 15:35 == 47.2
12/5/15 15:40 == 47.2
12/5/15 15:45 == 47.3
12/5/15 15:50 == 47.3
12/5/15 15:55 == 47.3
12/5/15 16:00 == 47.2
12/5/15 16:05 == 47.3
12/5/15 16:10 == 47.3
12/5/15 16:15 == 47.4
12/5/15 16:20 == 47.3
12/5/15 16:25 == 47.3
12/5/15 16:30 == 47.3
12/5/15 16:35 == 47.2
12/5/15 16:40 == 47.4
12/5/15 16:45 == 47.2
12/5/15 16:50 == 47.3
12/5/15 16:55 == 47.3
12/5/15 17:00 == 47.3
12/5/15 17:05 == 47.3
12/5/15 17:10 == 47.3
12/5/15 17:15 == 47.2
12/5/15 17:20 == 47.3
12/5/15 17:25 == 47.3
12/5/15 17:30 == 47.2
12/5/15 17:35 == 47.4
12/5/15 17:40 == 47.3
12/5/15 17:45 == 47.3
12/5/15 17:50 == 47.2
12/5/15 17:55 == 47.3
12/5/15 18:00 == 47.3
12/5/15 18:05 == 47.2
12/5/15 18:10 == 47.3
12/5/15 18:15 == 47.4
12/5/15 18:20 == 47.3
12/5/15 18:25 == 47.3
12/5/15 18:30 == 47.3
12/5/15 18:35 == 47.2
12/5/15 18:40 == 47.4
12/5/15 18:45 == 47.3
12/5/15 18:50 == 47.3
12/5/15 18:55 == 47.4
12/5/15 19:00 == 47.2
12/5/15 19:05 == 47.4
12/5/15 19:10 == 47.3
12/5/15 19:15 == 47.2
12/5/15 19:20 == 47.3
12/5/15 19:25 == 47.3
12/5/15 19:30 == 47.3
12/5/15 19:35 == 47.3
12/5/15 19:40 == 47.1
12/5/15 19:45 == 47.3
12/5/15 19:50 == 47.3
12/5/15 19:55 == 47.3
12/5/15 20:00 == 47.4
12/5/15 20:05 == 47.4
12/5/15 20:10 == 47.4
12/5/15 20:15 == 47.2
12/5/15 20:20 == 47.2
12/5/15 20:25 == 47.2
12/5/15 20:30 == 47.3
12/5/15 20:35 == 47.3
12/5/15 20:40 == 47.3
12/5/15 20:45 == 47.4
12/5/15 20:50 == 47.3
12/5/15 20:55 == 47.3
12/5/15 21:00 == 47.2
12/5/15 21:05 == 47.3
12/5/15 21:10 == 47.2
12/5/15 21:15 == 47.2
12/5/15 21:20 == 47.1
12/5/15 21:25 == 47.2
12/5/15 21:30 == 47.4
12/5/15 21:35 == 47.3
12/5/15 21:40 == 47.4
12/5/15 21:45 == 47.5
12/5/15 21:50 == 47.4
12/5/15 21:55 == 47.4
12/5/15 22:00 == 47.4
12/5/15 22:05 == 47.4
12/5/15 22:10 == 47.2
12/5/15 22:15 == 47.3
12/5/15 22:20 == 47.4
12/5/15 22:25 == 47.3
12/5/15 22:30 == 47.4
12/5/15 22:35 == 47.4
12/5/15 22:40 == 47.3
12/5/15 22:45 == 47.4
12/5/15 22:50 == 47.3
12/5/15 22:55 == 47.3
12/5/15 23:00 == 47.3
12/5/15 23:05 == 47.3
12/5/15 23:10 == 47.3
12/5/15 23:15 == 47.2
12/5/15 23:20 == 47.2
12/5/15 23:25 == 47.2
12/5/15 23:30 == 47.3
12/5/15 23:35 == 47.2
12/5/15 23:40 == 47.2
12/5/15 23:45 == 47.2
12/5/15 23:50 == 47.4
12/5/15 23:55 == 47.3
12/6/15 0:00 == 47.2
12/6/15 0:05 == 47.3
12/6/15 0:10 == 47.1
12/6/15 0:15 == 47.2
12/6/15 0:20 == 47.2
12/6/15 0:25 == 47.3
12/6/15 0:30 == 47.2
12/6/15 0:35 == 47.2
12/6/15 0:40 == 47.2
12/6/15 0:45 == 47.3
12/6/15 0:50 == 47.1
12/6/15 0:55 == 47.2
12/6/15 1:00 == 47.3
12/6/15 1:05 == 47.2
12/6/15 1:10 == 47.3
12/6/15 1:15 == 47.2
12/6/15 1:20 == 47.2
12/6/15 1:25 == 47.2
12/6/15 1:30 == 47.2
12/6/15 1:35 == 47.2
12/6/15 1:40 == 47.3
12/6/15 1:45 == 47.1
12/6/15 1:50 == 47.2
12/6/15 1:55 == 47.2
12/6/15 2:00 == 47.4
12/6/15 2:05 == 47.2
12/6/15 2:10 == 47.1
12/6/15 2:15 == 47.2
12/6/15 2:20 == 47.1
12/6/15 2:25 == 47.2
12/6/15 2:30 == 47.1
12/6/15 2:35 == 47.2
12/6/15 2:40 == 47.2
12/6/15 2:45 == 47.3
12/6/15 2:50 == 47
12/6/15 2:55 == 47.2
12/6/15 3:00 == 47.2
12/6/15 3:05 == 47
12/6/15 3:10 == 47.1
12/6/15 3:15 == 47
12/6/15 3:20 == 47.1
12/6/15 3:25 == 47
12/6/15 3:30 == 47.1
12/6/15 3:35 == 47.1
12/6/15 3:40 == 47.1
12/6/15 3:45 == 47
12/6/15 3:50 == 47.1
12/6/15 3:55 == 47.1
12/6/15 4:00 == 47
12/6/15 4:05 == 47
12/6/15 4:10 == 47
12/6/15 4:15 == 47
12/6/15 4:20 == 47
12/6/15 4:25 == 47.1
12/6/15 4:30 == 47.1
12/6/15 4:35 == 46.9
12/6/15 4:40 == 47
12/6/15 4:45 == 47
12/6/15 4:50 == 47
12/6/15 4:55 == 46.9
12/6/15 5:00 == 47
12/6/15 5:05 == 47
12/6/15 5:10 == 46.9
12/6/15 5:15 == 47
12/6/15 5:20 == 47
12/6/15 5:25 == 47
12/6/15 5:30 == 46.9
12/6/15 5:35 == 47
12/6/15 5:40 == 46.9
12/6/15 5:45 == 47
12/6/15 5:50 == 47.1
12/6/15 5:55 == 46.8

Pumpback Station Discharge (0364)

12/6/15 6:00 == 47.1
12/6/15 6:05 == 47
12/6/15 6:10 == 47.1
12/6/15 6:15 == 46.9
12/6/15 6:20 == 47
12/6/15 6:25 == 47.1
12/6/15 6:30 == 47.1
12/6/15 6:35 == 47
12/6/15 6:40 == 46.9
12/6/15 6:45 == 47.1
12/6/15 6:50 == 47
12/6/15 6:55 == 46.9
12/6/15 7:00 == 47.1
12/6/15 7:05 == 46.9
12/6/15 7:10 == 46.9
12/6/15 7:15 == 46.9
12/6/15 7:20 == 47
12/6/15 7:25 == 46.9
12/6/15 7:30 == 46.9
12/6/15 7:35 == 47
12/6/15 7:40 == 46.9
12/6/15 7:45 == 46.9
12/6/15 7:50 == 46.9
12/6/15 7:55 == 47
12/6/15 8:00 == 46.8
12/6/15 8:05 == 46.9
12/6/15 8:10 == 46.9
12/6/15 8:15 == 47
12/6/15 8:20 == 46.9
12/6/15 8:25 == 47
12/6/15 8:30 == 46.9
12/6/15 8:35 == 46.9
12/6/15 8:40 == 47.1
12/6/15 8:45 == 46.8
12/6/15 8:50 == 46.9
12/6/15 8:55 == 46.9
12/6/15 9:00 == 47
12/6/15 9:05 == 46.9
12/6/15 9:10 == 46.8
12/6/15 9:15 == 46.9
12/6/15 9:20 == 46.9
12/6/15 9:25 == 47.1
12/6/15 9:30 == 47
12/6/15 9:35 == 46.9
12/6/15 9:40 == 47
12/6/15 9:45 == 46.9
12/6/15 9:50 == 46.9
12/6/15 9:55 == 47
12/6/15 10:00 == 47
12/6/15 10:05 == 47
12/6/15 10:10 == 47
12/6/15 10:15 == 46.9
12/6/15 10:20 == 46.9
12/6/15 10:25 == 47
12/6/15 10:30 == 47
12/6/15 10:35 == 47
12/6/15 10:40 == 47.1
12/6/15 10:45 == 47
12/6/15 10:50 == 46.9
12/6/15 10:55 == 46.8
12/6/15 11:00 == 46.9
12/6/15 11:05 == 46.9
12/6/15 11:10 == 47
12/6/15 11:15 == 47
12/6/15 11:20 == 46.9
12/6/15 11:25 == 46.9
12/6/15 11:30 == 47
12/6/15 11:35 == 46.9
12/6/15 11:40 == 46.8
12/6/15 11:45 == 46.8
12/6/15 11:50 == 47
12/6/15 11:55 == 46.8
12/6/15 12:00 == 46.9
12/6/15 12:05 == 46.9
12/6/15 12:10 == 47
12/6/15 12:15 == 46.9
12/6/15 12:20 == 46.9
12/6/15 12:25 == 46.9
12/6/15 12:30 == 46.9
12/6/15 12:35 == 47
12/6/15 12:40 == 46.8
12/6/15 12:45 == 46.8
12/6/15 12:50 == 46.8
12/6/15 12:55 == 46.8
12/6/15 13:00 == 46.9
12/6/15 13:05 == 46.8
12/6/15 13:10 == 46.9
12/6/15 13:15 == 46.9
12/6/15 13:20 == 46.8
12/6/15 13:25 == 46.8
12/6/15 13:30 == 46.9
12/6/15 13:35 == 46.8
12/6/15 13:40 == 47
12/6/15 13:45 == 46.9
12/6/15 13:50 == 46.8
12/6/15 13:55 == 46.8
12/6/15 14:00 == 46.9
12/6/15 14:05 == 46.9
12/6/15 14:10 == 46.9
12/6/15 14:15 == 47.1
12/6/15 14:20 == 46.9
12/6/15 14:25 == 47
12/6/15 14:30 == 47.1
12/6/15 14:35 == 47
12/6/15 14:40 == 46.8
12/6/15 14:45 == 47.1
12/6/15 14:50 == 46.9
12/6/15 14:55 == 46.8
12/6/15 15:00 == 47.1
12/6/15 15:05 == 47
12/6/15 15:10 == 46.8
12/6/15 15:15 == 47
12/6/15 15:20 == 47.1
12/6/15 15:25 == 46.8
12/6/15 15:30 == 46.8
12/6/15 15:35 == 46.8
12/6/15 15:40 == 46.9
12/6/15 15:45 == 46.8
12/6/15 15:50 == 47
12/6/15 15:55 == 46.8
12/6/15 16:00 == 46.9
12/6/15 16:05 == 46.8
12/6/15 16:10 == 46.9
12/6/15 16:15 == 47
12/6/15 16:20 == 46.8
12/6/15 16:25 == 46.9
12/6/15 16:30 == 46.8
12/6/15 16:35 == 46.9
12/6/15 16:40 == 46.7
12/6/15 16:45 == 46.8
12/6/15 16:50 == 46.9
12/6/15 16:55 == 46.9
12/6/15 17:00 == 46.8
12/6/15 17:05 == 46.9
12/6/15 17:10 == 46.8
12/6/15 17:15 == 46.9
12/6/15 17:20 == 46.8
12/6/15 17:25 == 46.8
12/6/15 17:30 == 46.9
12/6/15 17:35 == 46.8
12/6/15 17:40 == 46.8
12/6/15 17:45 == 46.8
12/6/15 17:50 == 46.8
12/6/15 17:55 == 46.7
12/6/15 18:00 == 46.7
12/6/15 18:05 == 46.8
12/6/15 18:10 == 46.9
12/6/15 18:15 == 46.7
12/6/15 18:20 == 46.8
12/6/15 18:25 == 46.7
12/6/15 18:30 == 46.7
12/6/15 18:35 == 46.8
12/6/15 18:40 == 46.8
12/6/15 18:45 == 46.8
12/6/15 18:50 == 46.9
12/6/15 18:55 == 46.8
12/6/15 19:00 == 46.7
12/6/15 19:05 == 46.8
12/6/15 19:10 == 46.6
12/6/15 19:15 == 46.8
12/6/15 19:20 == 46.8
12/6/15 19:25 == 46.7
12/6/15 19:30 == 46.7
12/6/15 19:35 == 46.9
12/6/15 19:40 == 46.6
12/6/15 19:45 == 46.8
12/6/15 19:50 == 46.8
12/6/15 19:55 == 46.6
12/6/15 20:00 == 46.8
12/6/15 20:05 == 46.7
12/6/15 20:10 == 46.8
12/6/15 20:15 == 46.8
12/6/15 20:20 == 46.7
12/6/15 20:25 == 46.7
12/6/15 20:30 == 46.7
12/6/15 20:35 == 46.7
12/6/15 20:40 == 46.8
12/6/15 20:45 == 46.8
12/6/15 20:50 == 46.7
12/6/15 20:55 == 46.8
12/6/15 21:00 == 46.8
12/6/15 21:05 == 46.7
12/6/15 21:10 == 46.8
12/6/15 21:15 == 46.7
12/6/15 21:20 == 46.8
12/6/15 21:25 == 46.7
12/6/15 21:30 == 47
12/6/15 21:35 == 46.7
12/6/15 21:40 == 46.9
12/6/15 21:45 == 46.8
12/6/15 21:50 == 46.9
12/6/15 21:55 == 46.7
12/6/15 22:00 == 46.9
12/6/15 22:05 == 46.8
12/6/15 22:10 == 46.8
12/6/15 22:15 == 46.9
12/6/15 22:20 == 46.7
12/6/15 22:25 == 46.8
12/6/15 22:30 == 46.8
12/6/15 22:35 == 47
12/6/15 22:40 == 46.8
12/6/15 22:45 == 46.7
12/6/15 22:50 == 46.9
12/6/15 22:55 == 46.7
12/6/15 23:00 == 46.6
12/6/15 23:05 == 46.7
12/6/15 23:10 == 46.6
12/6/15 23:15 == 46.8
12/6/15 23:20 == 46.7
12/6/15 23:25 == 46.8
12/6/15 23:30 == 46.7
12/6/15 23:35 == 46.6
12/6/15 23:40 == 46.6
12/6/15 23:45 == 46.6
12/6/15 23:50 == 46.7
12/6/15 23:55 == 46.7

Pumpback Station Discharge (0364)

12/7/15 0:00 == 46.6
12/7/15 0:05 == 46.7
12/7/15 0:10 == 46.8
12/7/15 0:15 == 46.8
12/7/15 0:20 == 46.8
12/7/15 0:25 == 46.6
12/7/15 0:30 == 46.7
12/7/15 0:35 == 46.8
12/7/15 0:40 == 46.9
12/7/15 0:45 == 46.6
12/7/15 0:50 == 46.7
12/7/15 0:55 == 46.7
12/7/15 1:00 == 46.6
12/7/15 1:05 == 46.7
12/7/15 1:10 == 46.7
12/7/15 1:15 == 46.7
12/7/15 1:20 == 46.7
12/7/15 1:25 == 46.7
12/7/15 1:30 == 46.7
12/7/15 1:35 == 46.8
12/7/15 1:40 == 46.7
12/7/15 1:45 == 46.7
12/7/15 1:50 == 46.7
12/7/15 1:55 == 46.6
12/7/15 2:00 == 46.6
12/7/15 2:05 == 46.7
12/7/15 2:10 == 46.7
12/7/15 2:15 == 46.7
12/7/15 2:20 == 46.6
12/7/15 2:25 == 46.7
12/7/15 2:30 == 46.6
12/7/15 2:35 == 46.7
12/7/15 2:40 == 46.7
12/7/15 2:45 == 46.7
12/7/15 2:50 == 46.7
12/7/15 2:55 == 46.6
12/7/15 3:00 == 46.9
12/7/15 3:05 == 46.8
12/7/15 3:10 == 46.6
12/7/15 3:15 == 46.8
12/7/15 3:20 == 46.6
12/7/15 3:25 == 46.6
12/7/15 3:30 == 46.7
12/7/15 3:35 == 46.7
12/7/15 3:40 == 46.7
12/7/15 3:45 == 46.7
12/7/15 3:50 == 46.9
12/7/15 3:55 == 46.7
12/7/15 4:00 == 46.7
12/7/15 4:05 == 46.7
12/7/15 4:10 == 46.8
12/7/15 4:15 == 46.7
12/7/15 4:20 == 46.8
12/7/15 4:25 == 46.6
12/7/15 4:30 == 46.8
12/7/15 4:35 == 46.8
12/7/15 4:40 == 46.7
12/7/15 4:45 == 46.7
12/7/15 4:50 == 46.7
12/7/15 4:55 == 46.6
12/7/15 5:00 == 46.7
12/7/15 5:05 == 46.7
12/7/15 5:10 == 46.6
12/7/15 5:15 == 46.6
12/7/15 5:20 == 46.6
12/7/15 5:25 == 46.6
12/7/15 5:30 == 46.7
12/7/15 5:35 == 46.8
12/7/15 5:40 == 46.6
12/7/15 5:45 == 46.6
12/7/15 5:50 == 46.7
12/7/15 5:55 == 46.7
12/7/15 6:00 == 46.7
12/7/15 6:05 == 46.7
12/7/15 6:10 == 46.6
12/7/15 6:15 == 46.7
12/7/15 6:20 == 46.7
12/7/15 6:25 == 46.7
12/7/15 6:30 == 46.8
12/7/15 6:35 == 46.6
12/7/15 6:40 == 46.6
12/7/15 6:45 == 46.7
12/7/15 6:50 == 46.7
12/7/15 6:55 == 46.7
12/7/15 7:00 == 46.6
12/7/15 7:05 == 46.7
12/7/15 7:10 == 46.7
12/7/15 7:15 == 46.7
12/7/15 7:20 == 46.9
12/7/15 7:25 == 46.7
12/7/15 7:30 == 46.6
12/7/15 7:35 == 46.6
12/7/15 7:40 == 46.7
12/7/15 7:45 == 46.7
12/7/15 7:50 == 46.7
12/7/15 7:55 == 46.8
12/7/15 8:00 == 46.8
12/7/15 8:05 == 46.8
12/7/15 8:10 == 46.8
12/7/15 8:15 == 46.6
12/7/15 8:20 == 46.8
12/7/15 8:25 == 46.8
12/7/15 8:30 == 46.7
12/7/15 8:35 == 46.9
12/7/15 8:40 == 46.8
12/7/15 8:45 == 46.8
12/7/15 8:50 == 47
12/7/15 8:55 == 46.9
12/7/15 9:00 == 46.7
12/7/15 9:05 == 46.8
12/7/15 9:10 == 46.8
12/7/15 9:15 == 46.7
12/7/15 9:20 == 46.8
12/7/15 9:25 == 46.8
12/7/15 9:30 == 46.8
12/7/15 9:35 == 46.8
12/7/15 9:40 == 46.9
12/7/15 9:45 == 46.7
12/7/15 9:50 == 46.8
12/7/15 9:55 == 47
12/7/15 10:00 == 47
12/7/15 10:05 == 46.5
12/7/15 10:10 == 47
12/7/15 10:15 == 46.7
12/7/15 10:20 == 46.8
12/7/15 10:25 == 46.9
12/7/15 10:30 == 47
12/7/15 10:35 == 46.7
12/7/15 10:40 == 47
12/7/15 10:45 == 46.9
12/7/15 10:50 == 46.9
12/7/15 10:55 == 46.5
12/7/15 11:00 == 47.2
12/7/15 11:05 == 46.5
12/7/15 11:10 == 46.7
12/7/15 11:15 == 47.3
12/7/15 11:20 == 46.6
12/7/15 11:25 == 46.8
12/7/15 11:30 == 46.7
12/7/15 11:35 == 46.8
12/7/15 11:40 == 46.9
12/7/15 11:45 == 46.7
12/7/15 11:50 == 47
12/7/15 11:55 == 46.5
12/7/15 12:00 == 46.6
12/7/15 12:05 == 46.7
12/7/15 12:10 == 46.7
12/7/15 12:15 == 46.7
12/7/15 12:20 == 46.8
12/7/15 12:25 == 46.7
12/7/15 12:30 == 46.7
12/7/15 12:35 == 46.8
12/7/15 12:40 == 46.7
12/7/15 12:45 == 46.7
12/7/15 12:50 == 46.9
12/7/15 12:55 == 46.9
12/7/15 13:00 == 47
12/7/15 13:05 == 47
12/7/15 13:10 == 46.9
12/7/15 13:15 == 46.9
12/7/15 13:20 == 47
12/7/15 13:25 == 47.1
12/7/15 13:30 == 47.2
12/7/15 13:35 == 47.2
12/7/15 13:40 == 46.8
12/7/15 13:45 == 47.3
12/7/15 13:50 == 47.2
12/7/15 13:55 == 47.3
12/7/15 14:00 == 46.9
12/7/15 14:05 == 47.4
12/7/15 14:10 == 47.3
12/7/15 14:15 == 47.3
12/7/15 14:20 == 47.3
12/7/15 14:25 == 47.4
12/7/15 14:30 == 47.4
12/7/15 14:35 == 47.3
12/7/15 14:40 == 47.1
12/7/15 14:45 == 47.4
12/7/15 14:50 == 47.3
12/7/15 14:55 == 47.1
12/7/15 15:00 == 47.3
12/7/15 15:05 == 47.3
12/7/15 15:10 == 47.4
12/7/15 15:15 == 47.3
12/7/15 15:20 == 47.3
12/7/15 15:25 == 47.2
12/7/15 15:30 == 46.9
12/7/15 15:35 == 47.2
12/7/15 15:40 == 47.3
12/7/15 15:45 == 47.3
12/7/15 15:50 == 47.1
12/7/15 15:55 == 47.3
12/7/15 16:00 == 47.1
12/7/15 16:05 == 47.2
12/7/15 16:10 == 47.2
12/7/15 16:15 == 47.3
12/7/15 16:20 == 47.2
12/7/15 16:25 == 47.1
12/7/15 16:30 == 47.2
12/7/15 16:35 == 47.1
12/7/15 16:40 == 47.1
12/7/15 16:45 == 47.3
12/7/15 16:50 == 47.2
12/7/15 16:55 == 47.2
12/7/15 17:00 == 47.2
12/7/15 17:05 == 47.3
12/7/15 17:10 == 47.2
12/7/15 17:15 == 47.2
12/7/15 17:20 == 47.2
12/7/15 17:25 == 47.3
12/7/15 17:30 == 47.2
12/7/15 17:35 == 47.3
12/7/15 17:40 == 47.1
12/7/15 17:45 == 47.2
12/7/15 17:50 == 47.3
12/7/15 17:55 == 47.2

Pumpback Station Discharge (0364)

12/7/15 18:00 == 47.2
12/7/15 18:05 == 47.3
12/7/15 18:10 == 47.2
12/7/15 18:15 == 47.3
12/7/15 18:20 == 47.2
12/7/15 18:25 == 47.2
12/7/15 18:30 == 47.2
12/7/15 18:35 == 47.2
12/7/15 18:40 == 47.3
12/7/15 18:45 == 47.2
12/7/15 18:50 == 47.2
12/7/15 18:55 == 47.2
12/7/15 19:00 == 47.1
12/7/15 19:05 == 47.2
12/7/15 19:10 == 47.2
12/7/15 19:15 == 47.3
12/7/15 19:20 == 47.4
12/7/15 19:25 == 47.2
12/7/15 19:30 == 47.2
12/7/15 19:35 == 47.3
12/7/15 19:40 == 47.1
12/7/15 19:45 == 47.3
12/7/15 19:50 == 47.2
12/7/15 19:55 == 47.2
12/7/15 20:00 == 47.3
12/7/15 20:05 == 47.2
12/7/15 20:10 == 47.2
12/7/15 20:15 == 47.2
12/7/15 20:20 == 47.3
12/7/15 20:25 == 47.3
12/7/15 20:30 == 47.1
12/7/15 20:35 == 47.2
12/7/15 20:40 == 47.4
12/7/15 20:45 == 47.3
12/7/15 20:50 == 47.2
12/7/15 20:55 == 47.2
12/7/15 21:00 == 47.3
12/7/15 21:05 == 47.1
12/7/15 21:10 == 47.3
12/7/15 21:15 == 47.2
12/7/15 21:20 == 47.3
12/7/15 21:25 == 47.3
12/7/15 21:30 == 47.5
12/7/15 21:35 == 47.2
12/7/15 21:40 == 47.5
12/7/15 21:45 == 47.4
12/7/15 21:50 == 47.5
12/7/15 21:55 == 47.3
12/7/15 22:00 == 47.4
12/7/15 22:05 == 47.3
12/7/15 22:10 == 47.3
12/7/15 22:15 == 47.3
12/7/15 22:20 == 47.4
12/7/15 22:25 == 47.5
12/7/15 22:30 == 47.4
12/7/15 22:35 == 47.3
12/7/15 22:40 == 47.4
12/7/15 22:45 == 47.3
12/7/15 22:50 == 47.3
12/7/15 22:55 == 47.2
12/7/15 23:00 == 47.3
12/7/15 23:05 == 47.2
12/7/15 23:10 == 47.3
12/7/15 23:15 == 47.2
12/7/15 23:20 == 47.2
12/7/15 23:25 == 47.3
12/7/15 23:30 == 47.3
12/7/15 23:35 == 47.2
12/7/15 23:40 == 47.2
12/7/15 23:45 == 47.2
12/7/15 23:50 == 47.1
12/7/15 23:55 == 47.1
12/8/15 0:00 == 47.3
12/8/15 0:05 == 47.2
12/8/15 0:10 == 47.1
12/8/15 0:15 == 47.3
12/8/15 0:20 == 47.2
12/8/15 0:25 == 47.3
12/8/15 0:30 == 47.1
12/8/15 0:35 == 47.2
12/8/15 0:40 == 47.3
12/8/15 0:45 == 47.2
12/8/15 0:50 == 47.2
12/8/15 0:55 == 47.1
12/8/15 1:00 == 47.2
12/8/15 1:05 == 47.1
12/8/15 1:10 == 47.3
12/8/15 1:15 == 47.3
12/8/15 1:20 == 47.2
12/8/15 1:25 == 47.2
12/8/15 1:30 == 47.2
12/8/15 1:35 == 47.2
12/8/15 1:40 == 47.2
12/8/15 1:45 == 47.2
12/8/15 1:50 == 47.2
12/8/15 1:55 == 47.2
12/8/15 2:00 == 47.3
12/8/15 2:05 == 47.2
12/8/15 2:10 == 47.2
12/8/15 2:15 == 47.3
12/8/15 2:20 == 47.3
12/8/15 2:25 == 47.3
12/8/15 2:30 == 47.2
12/8/15 2:35 == 47.1
12/8/15 2:40 == 47.2
12/8/15 2:45 == 47.2
12/8/15 2:50 == 47.3
12/8/15 2:55 == 47.3
12/8/15 3:00 == 47.3
12/8/15 3:05 == 47.3
12/8/15 3:10 == 47.2
12/8/15 3:15 == 47.2
12/8/15 3:20 == 47.2
12/8/15 3:25 == 47.1
12/8/15 3:30 == 47.2
12/8/15 3:35 == 47.2
12/8/15 3:40 == 47.3
12/8/15 3:45 == 47.2
12/8/15 3:50 == 47.2
12/8/15 3:55 == 47.1
12/8/15 4:00 == 47.3
12/8/15 4:05 == 47.2
12/8/15 4:10 == 47.2
12/8/15 4:15 == 47.3
12/8/15 4:20 == 47.2
12/8/15 4:25 == 47.3
12/8/15 4:30 == 47.1
12/8/15 4:35 == 47.3
12/8/15 4:40 == 47.1
12/8/15 4:45 == 47.2
12/8/15 4:50 == 47.3
12/8/15 4:55 == 47.1
12/8/15 5:00 == 47.3
12/8/15 5:05 == 47.2
12/8/15 5:10 == 47.2
12/8/15 5:15 == 47.2
12/8/15 5:20 == 47.1
12/8/15 5:25 == 47.3
12/8/15 5:30 == 47.1
12/8/15 5:35 == 47.3
12/8/15 5:40 == 47.1
12/8/15 5:45 == 47.1
12/8/15 5:50 == 47.2
12/8/15 5:55 == 47.1
12/8/15 6:00 == 47.3
12/8/15 6:05 == 47.3
12/8/15 6:10 == 47.1
12/8/15 6:15 == 47.2
12/8/15 6:20 == 47.2
12/8/15 6:25 == 47.1
12/8/15 6:30 == 47.2
12/8/15 6:35 == 47.2
12/8/15 6:40 == 47.1
12/8/15 6:45 == 47.1
12/8/15 6:50 == 47.2
12/8/15 6:55 == 47.2
12/8/15 7:00 == 47.2
12/8/15 7:05 == 47.2
12/8/15 7:10 == 47.2
12/8/15 7:15 == 47.1
12/8/15 7:20 == 47.3
12/8/15 7:25 == 47.2
12/8/15 7:30 == 47.2
12/8/15 7:35 == 47.1
12/8/15 7:40 == 47.2
12/8/15 7:45 == 47.2
12/8/15 7:50 == 47.2
12/8/15 7:55 == 47.1
12/8/15 8:00 == 47.3
12/8/15 8:05 == 47.4
12/8/15 8:10 == 47.2
12/8/15 8:15 == 47.1
12/8/15 8:20 == 47.4
12/8/15 8:25 == 47.4
12/8/15 8:30 == 47.2
12/8/15 8:35 == 47.4
12/8/15 8:40 == 47.6
12/8/15 8:45 == 47.2
12/8/15 8:50 == 47.2
12/8/15 8:55 == 47.4
12/8/15 9:00 == 47.1
12/8/15 9:05 == 47
12/8/15 9:10 == 47.1
12/8/15 9:15 == 47.2
12/8/15 9:20 == 47.3
12/8/15 9:25 == 47.2
12/8/15 9:30 == 47.4
12/8/15 9:35 == 47.4
12/8/15 9:40 == 47.3
12/8/15 9:45 == 47.4
12/8/15 9:50 == 47.3
12/8/15 9:55 == 47
12/8/15 10:00 == 47.2
12/8/15 10:05 == 47.3
12/8/15 10:10 == 47.2
12/8/15 10:15 == 47.1
12/8/15 10:20 == 47.4
12/8/15 10:25 == 47.1
12/8/15 10:30 == 47.2
12/8/15 10:35 == 47.1
12/8/15 10:40 == 47.1
12/8/15 10:45 == 47.2
12/8/15 10:50 == 47.4
12/8/15 10:55 == 47.2
12/8/15 11:00 == 47.2
12/8/15 11:05 == 47.4
12/8/15 11:10 == 47.2
12/8/15 11:15 == 47.2
12/8/15 11:20 == 46.7
12/8/15 11:25 == 47.2
12/8/15 11:30 == 47
12/8/15 11:35 == 47.1
12/8/15 11:40 == 47
12/8/15 11:45 == 47.2
12/8/15 11:50 == 47.4
12/8/15 11:55 == 47.3

Pumpback Station Discharge (0364)

12/8/15 12:00 == 47.4
12/8/15 12:05 == 47.3
12/8/15 12:10 == 47.4
12/8/15 12:15 == 47
12/8/15 12:20 == 47.1
12/8/15 12:25 == 47.1
12/8/15 12:30 == 46.4
12/8/15 12:35 == 47.3
12/8/15 12:40 == 46.9
12/8/15 12:45 == 47.1
12/8/15 12:50 == 47.4
12/8/15 12:55 == 47.4
12/8/15 13:00 == 47.2
12/8/15 13:05 == 47.5
12/8/15 13:10 == 47.1
12/8/15 13:15 == 47.2
12/8/15 13:20 == 47.3
12/8/15 13:25 == 47.3
12/8/15 13:30 == 47.4
12/8/15 13:35 == 47.3
12/8/15 13:40 == 47.4
12/8/15 13:45 == 47.1
12/8/15 13:50 == 47.3
12/8/15 13:55 == 47.3
12/8/15 14:00 == 47.1
12/8/15 14:05 == 47.3
12/8/15 14:10 == 47.4
12/8/15 14:15 == 47.3
12/8/15 14:20 == 47.1
12/8/15 14:25 == 47.3
12/8/15 14:30 == 47.2
12/8/15 14:35 == 47.3
12/8/15 14:40 == 47.1
12/8/15 14:45 == 47.2
12/8/15 14:50 == 47
12/8/15 14:55 == 47.2
12/8/15 15:00 == 47.3
12/8/15 15:05 == 47.4
12/8/15 15:10 == 47.1
12/8/15 15:15 == 47.3
12/8/15 15:20 == 47.3
12/8/15 15:25 == 47
12/8/15 15:30 == 47
12/8/15 15:35 == 47
12/8/15 15:40 == 47.2
12/8/15 15:45 == 47.1
12/8/15 15:50 == 47.1
12/8/15 15:55 == 47.1
12/8/15 16:00 == 47.1
12/8/15 16:05 == 47.1
12/8/15 16:10 == 47.2
12/8/15 16:15 == 47.1
12/8/15 16:20 == 47.1
12/8/15 16:25 == 47.1
12/8/15 16:30 == 46.9
12/8/15 16:35 == 47
12/8/15 16:40 == 47.1
12/8/15 16:45 == 47.1
12/8/15 16:50 == 47
12/8/15 16:55 == 47
12/8/15 17:00 == 47.1
12/8/15 17:05 == 47
12/8/15 17:10 == 47.1
12/8/15 17:15 == 47
12/8/15 17:20 == 47.1
12/8/15 17:25 == 47.1
12/8/15 17:30 == 47
12/8/15 17:35 == 47.1
12/8/15 17:40 == 47.1
12/8/15 17:45 == 47.1
12/8/15 17:50 == 47.1
12/8/15 17:55 == 47.2
12/8/15 18:00 == 47.1
12/8/15 18:05 == 47.1
12/8/15 18:10 == 47.2
12/8/15 18:15 == 46.9
12/8/15 18:20 == 47
12/8/15 18:25 == 47.1
12/8/15 18:30 == 47
12/8/15 18:35 == 47.1
12/8/15 18:40 == 47
12/8/15 18:45 == 47.2
12/8/15 18:50 == 47.1
12/8/15 18:55 == 47.1
12/8/15 19:00 == 47
12/8/15 19:05 == 47.1
12/8/15 19:10 == 47
12/8/15 19:15 == 47.1
12/8/15 19:20 == 47
12/8/15 19:25 == 47
12/8/15 19:30 == 47.1
12/8/15 19:35 == 47
12/8/15 19:40 == 47
12/8/15 19:45 == 47.1
12/8/15 19:50 == 47.1
12/8/15 19:55 == 47.2
12/8/15 20:00 == 47.1
12/8/15 20:05 == 47.2
12/8/15 20:10 == 47
12/8/15 20:15 == 47.1
12/8/15 20:20 == 47.1
12/8/15 20:25 == 47.1
12/8/15 20:30 == 47
12/8/15 20:35 == 47.1
12/8/15 20:40 == 47.1
12/8/15 20:45 == 47
12/8/15 20:50 == 47.1
12/8/15 20:55 == 47.1
12/8/15 21:00 == 47.1
12/8/15 21:05 == 47.2
12/8/15 21:10 == 47.1
12/8/15 21:15 == 47
12/8/15 21:20 == 47
12/8/15 21:25 == 47.1
12/8/15 21:30 == 47.5
12/8/15 21:35 == 47.1
12/8/15 21:40 == 47.2
12/8/15 21:45 == 47.2
12/8/15 21:50 == 47.2
12/8/15 21:55 == 47.2
12/8/15 22:00 == 47.1
12/8/15 22:05 == 47.1
12/8/15 22:10 == 47.3
12/8/15 22:15 == 47.3
12/8/15 22:20 == 47.3
12/8/15 22:25 == 47.2
12/8/15 22:30 == 47.3
12/8/15 22:35 == 47.2
12/8/15 22:40 == 47.2
12/8/15 22:45 == 47.2
12/8/15 22:50 == 47.2
12/8/15 22:55 == 47.1
12/8/15 23:00 == 47.2
12/8/15 23:05 == 47.1
12/8/15 23:10 == 47.1
12/8/15 23:15 == 47.1
12/8/15 23:20 == 47.1
12/8/15 23:25 == 47
12/8/15 23:30 == 47.2
12/8/15 23:35 == 47.1
12/8/15 23:40 == 47
12/8/15 23:45 == 47.1
12/8/15 23:50 == 47.1
12/8/15 23:55 == 47.1
12/9/15 0:00 == 47.1
12/9/15 0:05 == 47.1
12/9/15 0:10 == 47.1
12/9/15 0:15 == 47
12/9/15 0:20 == 47
12/9/15 0:25 == 47
12/9/15 0:30 == 47.1
12/9/15 0:35 == 47
12/9/15 0:40 == 47.1
12/9/15 0:45 == 47.1
12/9/15 0:50 == 47.1
12/9/15 0:55 == 47.1
12/9/15 1:00 == 47.1
12/9/15 1:05 == 47
12/9/15 1:10 == 47.1
12/9/15 1:15 == 47.1
12/9/15 1:20 == 47.1
12/9/15 1:25 == 47.1
12/9/15 1:30 == 47.1
12/9/15 1:35 == 47.2
12/9/15 1:40 == 47.1
12/9/15 1:45 == 46.9
12/9/15 1:50 == 47.1
12/9/15 1:55 == 47.1
12/9/15 2:00 == 47.1
12/9/15 2:05 == 47.1
12/9/15 2:10 == 47.1
12/9/15 2:15 == 47.1
12/9/15 2:20 == 47.1
12/9/15 2:25 == 47
12/9/15 2:30 == 47.1
12/9/15 2:35 == 47.1
12/9/15 2:40 == 47
12/9/15 2:45 == 47.2
12/9/15 2:50 == 47.1
12/9/15 2:55 == 47
12/9/15 3:00 == 47.1
12/9/15 3:05 == 47.1
12/9/15 3:10 == 47
12/9/15 3:15 == 47.1
12/9/15 3:20 == 47
12/9/15 3:25 == 47.1
12/9/15 3:30 == 47.1
12/9/15 3:35 == 47.2
12/9/15 3:40 == 47.2
12/9/15 3:45 == 47
12/9/15 3:50 == 47.1
12/9/15 3:55 == 47.1
12/9/15 4:00 == 47.2
12/9/15 4:05 == 47.1
12/9/15 4:10 == 47.1
12/9/15 4:15 == 47.1
12/9/15 4:20 == 47
12/9/15 4:25 == 47.2
12/9/15 4:30 == 47
12/9/15 4:35 == 47.1
12/9/15 4:40 == 47
12/9/15 4:45 == 47
12/9/15 4:50 == 47
12/9/15 4:55 == 47.1
12/9/15 5:00 == 47.1
12/9/15 5:05 == 47.1
12/9/15 5:10 == 47.1
12/9/15 5:15 == 47
12/9/15 5:20 == 47.1
12/9/15 5:25 == 47
12/9/15 5:30 == 47.1
12/9/15 5:35 == 47.1
12/9/15 5:40 == 47.1
12/9/15 5:45 == 47.1
12/9/15 5:50 == 47.1
12/9/15 5:55 == 47

Pumpback Station Discharge (0364)

12/9/15 6:00 == 47
12/9/15 6:05 == 47
12/9/15 6:10 == 47.1
12/9/15 6:15 == 47
12/9/15 6:20 == 46.9
12/9/15 6:25 == 47.2
12/9/15 6:30 == 47.1
12/9/15 6:35 == 47.1
12/9/15 6:40 == 47
12/9/15 6:45 == 47
12/9/15 6:50 == 47.2
12/9/15 6:55 == 47.1
12/9/15 7:00 == 47
12/9/15 7:05 == 47.1
12/9/15 7:10 == 46.9
12/9/15 7:15 == 47.1
12/9/15 7:20 == 47
12/9/15 7:25 == 47.1
12/9/15 7:30 == 47
12/9/15 7:35 == 47.1
12/9/15 7:40 == 47.1
12/9/15 7:45 == 47.1
12/9/15 7:50 == 47.1
12/9/15 7:55 == 47.1
12/9/15 8:00 == 47.1
12/9/15 8:05 == 47.2
12/9/15 8:10 == 47.6
12/9/15 8:15 == 47.6
12/9/15 8:20 == 47.3
12/9/15 8:25 == 47.3
12/9/15 8:30 == 47.3
12/9/15 8:35 == 47.4
12/9/15 8:40 == 47.6
12/9/15 8:45 == 47.4
12/9/15 8:50 == 47.5
12/9/15 8:55 == 47.6
12/9/15 9:00 == 47.4
12/9/15 9:05 == 47.6
12/9/15 9:10 == 47.4
12/9/15 9:15 == 47.5
12/9/15 9:20 == 47.4
12/9/15 9:25 == 47.3
12/9/15 9:30 == 47.6
12/9/15 9:35 == 47.5
12/9/15 9:40 == 47.3
12/9/15 9:45 == 47.4
12/9/15 9:50 == 47.5
12/9/15 9:55 == 47.4
12/9/15 10:00 == 47.5
12/9/15 10:05 == 47.4
12/9/15 10:10 == 47.2
12/9/15 10:15 == 47.6
12/9/15 10:20 == 47.3
12/9/15 10:25 == 47.4
12/9/15 10:30 == 47.3
12/9/15 10:35 == 47.5
12/9/15 10:40 == 47.2
12/9/15 10:45 == 47.4
12/9/15 10:50 == 47.4
12/9/15 10:55 == 47.5
12/9/15 11:00 == 47.4
12/9/15 11:05 == 47.5
12/9/15 11:10 == 47.3
12/9/15 11:15 == 47.2
12/9/15 11:20 == 47.5
12/9/15 11:25 == 47.4
12/9/15 11:30 == 47.3
12/9/15 11:35 == 47.3
12/9/15 11:40 == 47
12/9/15 11:45 == 47.2
12/9/15 11:50 == 47.4
12/9/15 11:55 == 47.4
12/9/15 12:00 == 47.3
12/9/15 12:05 == 47.3
12/9/15 12:10 == 46.9
12/9/15 12:15 == 47.2
12/9/15 12:20 == 47.1
12/9/15 12:25 == 47
12/9/15 12:30 == 47.1
12/9/15 12:35 == 47.1
12/9/15 12:40 == 47.1
12/9/15 12:45 == 47.1
12/9/15 12:50 == 47.2
12/9/15 12:55 == 46.9
12/9/15 13:00 == 47
12/9/15 13:05 == 47
12/9/15 13:10 == 46.9
12/9/15 13:15 == 47.2
12/9/15 13:20 == 47.1
12/9/15 13:25 == 46.9
12/9/15 13:30 == 47.2
12/9/15 13:35 == 47
12/9/15 13:40 == 47.2
12/9/15 13:45 == 47.1
12/9/15 13:50 == 47
12/9/15 13:55 == 47.2
12/9/15 14:00 == 46.9
12/9/15 14:05 == 47.1
12/9/15 14:10 == 47.4
12/9/15 14:15 == 47.5
12/9/15 14:20 == 45.9
12/9/15 14:25 == 34.7
12/9/15 14:30 == 33.2
12/9/15 14:35 == 33.2
12/9/15 14:40 == 33.2
12/9/15 14:45 == 33.3
12/9/15 14:50 == 47.5
12/9/15 14:55 == 47.3
12/9/15 15:00 == 46.7
12/9/15 15:05 == 45.6
12/9/15 15:10 == 45.6
12/9/15 15:15 == 46.7
12/9/15 15:20 == 46.3
12/9/15 15:25 == 47.9
12/9/15 15:30 == 44.8
12/9/15 15:35 == 1.4
12/9/15 15:40 == 0
12/9/15 15:45 == 0
12/9/15 15:50 == 13.7
12/9/15 15:55 == 45.7
12/9/15 16:00 == 46.9
12/9/15 16:05 == 48
12/9/15 16:10 == 48
12/9/15 16:15 == 47.9
12/9/15 16:20 == 48
12/9/15 16:25 == 48
12/9/15 16:30 == 47.9
12/9/15 16:35 == 48
12/9/15 16:40 == 47.8
12/9/15 16:45 == 48
12/9/15 16:50 == 48.2
12/9/15 16:55 == 48
12/9/15 17:00 == 48.1
12/9/15 17:05 == 48.1
12/9/15 17:10 == 47.9
12/9/15 17:15 == 48
12/9/15 17:20 == 48
12/9/15 17:25 == 48
12/9/15 17:30 == 48
12/9/15 17:35 == 48.1
12/9/15 17:40 == 48
12/9/15 17:45 == 48
12/9/15 17:50 == 47.9
12/9/15 17:55 == 48.1
12/9/15 18:00 == 48
12/9/15 18:05 == 48
12/9/15 18:10 == 48
12/9/15 18:15 == 47.9
12/9/15 18:20 == 47.9
12/9/15 18:25 == 48
12/9/15 18:30 == 47.9
12/9/15 18:35 == 48.1
12/9/15 18:40 == 48
12/9/15 18:45 == 47.9
12/9/15 18:50 == 47.9
12/9/15 18:55 == 48
12/9/15 19:00 == 48
12/9/15 19:05 == 48
12/9/15 19:10 == 48
12/9/15 19:15 == 48
12/9/15 19:20 == 48
12/9/15 19:25 == 48
12/9/15 19:30 == 47.9
12/9/15 19:35 == 48
12/9/15 19:40 == 48
12/9/15 19:45 == 48.1
12/9/15 19:50 == 48
12/9/15 19:55 == 48.1
12/9/15 20:00 == 48
12/9/15 20:05 == 47.9
12/9/15 20:10 == 48
12/9/15 20:15 == 48
12/9/15 20:20 == 48
12/9/15 20:25 == 48
12/9/15 20:30 == 48
12/9/15 20:35 == 48
12/9/15 20:40 == 48
12/9/15 20:45 == 48.1
12/9/15 20:50 == 48
12/9/15 20:55 == 48
12/9/15 21:00 == 47.9
12/9/15 21:05 == 48
12/9/15 21:10 == 48
12/9/15 21:15 == 48
12/9/15 21:20 == 48
12/9/15 21:25 == 48
12/9/15 21:30 == 48
12/9/15 21:35 == 47.8
12/9/15 21:40 == 48
12/9/15 21:45 == 48
12/9/15 21:50 == 48
12/9/15 21:55 == 48.1
12/9/15 22:00 == 48
12/9/15 22:05 == 48
12/9/15 22:10 == 48
12/9/15 22:15 == 48
12/9/15 22:20 == 48
12/9/15 22:25 == 48
12/9/15 22:30 == 48
12/9/15 22:35 == 48
12/9/15 22:40 == 48.1
12/9/15 22:45 == 48
12/9/15 22:50 == 48
12/9/15 22:55 == 47.9
12/9/15 23:00 == 48
12/9/15 23:05 == 48
12/9/15 23:10 == 48
12/9/15 23:15 == 48
12/9/15 23:20 == 48
12/9/15 23:25 == 48
12/9/15 23:30 == 48
12/9/15 23:35 == 48
12/9/15 23:40 == 48
12/9/15 23:45 == 48
12/9/15 23:50 == 48.1
12/9/15 23:55 == 47.8

Pumpback Station Discharge (0364)

12/10/15 0:00 == 48
12/10/15 0:05 == 47.9
12/10/15 0:10 == 48
12/10/15 0:15 == 48
12/10/15 0:20 == 48
12/10/15 0:25 == 48
12/10/15 0:30 == 48
12/10/15 0:35 == 48.1
12/10/15 0:40 == 47.9
12/10/15 0:45 == 48.1
12/10/15 0:50 == 48
12/10/15 0:55 == 47.9
12/10/15 1:00 == 47.9
12/10/15 1:05 == 47.9
12/10/15 1:10 == 48
12/10/15 1:15 == 48
12/10/15 1:20 == 48.1
12/10/15 1:25 == 48.1
12/10/15 1:30 == 48
12/10/15 1:35 == 48
12/10/15 1:40 == 47.9
12/10/15 1:45 == 48.1
12/10/15 1:50 == 48
12/10/15 1:55 == 47.9
12/10/15 2:00 == 48
12/10/15 2:05 == 48
12/10/15 2:10 == 48
12/10/15 2:15 == 47.9
12/10/15 2:20 == 48
12/10/15 2:25 == 48
12/10/15 2:30 == 47.9
12/10/15 2:35 == 47.9
12/10/15 2:40 == 47.9
12/10/15 2:45 == 48
12/10/15 2:50 == 48
12/10/15 2:55 == 48.1
12/10/15 3:00 == 48.1
12/10/15 3:05 == 47.9
12/10/15 3:10 == 48
12/10/15 3:15 == 48
12/10/15 3:20 == 48.1
12/10/15 3:25 == 47.9
12/10/15 3:30 == 47.9
12/10/15 3:35 == 48.1
12/10/15 3:40 == 47.8
12/10/15 3:45 == 48
12/10/15 3:50 == 47.9
12/10/15 3:55 == 48
12/10/15 4:00 == 47.9
12/10/15 4:05 == 48
12/10/15 4:10 == 48
12/10/15 4:15 == 48
12/10/15 4:20 == 48.1
12/10/15 4:25 == 48
12/10/15 4:30 == 47.9
12/10/15 4:35 == 48
12/10/15 4:40 == 48.1
12/10/15 4:45 == 48
12/10/15 4:50 == 48
12/10/15 4:55 == 48
12/10/15 5:00 == 47.9
12/10/15 5:05 == 48
12/10/15 5:10 == 47.9
12/10/15 5:15 == 48
12/10/15 5:20 == 48
12/10/15 5:25 == 48
12/10/15 5:30 == 48
12/10/15 5:35 == 48.1
12/10/15 5:40 == 48
12/10/15 5:45 == 48
12/10/15 5:50 == 47.9
12/10/15 5:55 == 48
12/10/15 6:00 == 48
12/10/15 6:05 == 47.9
12/10/15 6:10 == 47.9
12/10/15 6:15 == 47.9
12/10/15 6:20 == 48
12/10/15 6:25 == 48.1
12/10/15 6:30 == 47.8
12/10/15 6:35 == 48
12/10/15 6:40 == 48
12/10/15 6:45 == 48
12/10/15 6:50 == 47.9
12/10/15 6:55 == 48
12/10/15 7:00 == 48
12/10/15 7:05 == 48.1
12/10/15 7:10 == 48
12/10/15 7:15 == 48.1
12/10/15 7:20 == 48
12/10/15 7:25 == 47.9
12/10/15 7:30 == 48
12/10/15 7:35 == 48
12/10/15 7:40 == 47.9
12/10/15 7:45 == 48.2
12/10/15 7:50 == 48
12/10/15 7:55 == 48.1
12/10/15 8:00 == 48
12/10/15 8:05 == 48.1
12/10/15 8:10 == 48.1
12/10/15 8:15 == 48
12/10/15 8:20 == 48
12/10/15 8:25 == 48
12/10/15 8:30 == 47.9
12/10/15 8:35 == 39
12/10/15 8:40 == 30.7
12/10/15 8:45 == 34.1
12/10/15 8:50 == 35.5
12/10/15 8:55 == 47.8
12/10/15 9:00 == 48
12/10/15 9:05 == 47.8
12/10/15 9:10 == 48.2
12/10/15 9:15 == 48.1
12/10/15 9:20 == 47.9
12/10/15 9:25 == 48.1
12/10/15 9:30 == 47.9
12/10/15 9:35 == 48
12/10/15 9:40 == 47.9
12/10/15 9:45 == 48.2
12/10/15 9:50 == 47.9
12/10/15 9:55 == 47.9
12/10/15 10:00 == 47.9
12/10/15 10:05 == 48.1
12/10/15 10:10 == 47.8
12/10/15 10:15 == 48.1
12/10/15 10:20 == 47.9
12/10/15 10:25 == 48.1
12/10/15 10:30 == 48
12/10/15 10:35 == 43.8
12/10/15 10:40 == 31.5
12/10/15 10:45 == 33.8
12/10/15 10:50 == 35
12/10/15 10:55 == 47.6
12/10/15 11:00 == 48.1
12/10/15 11:05 == 48
12/10/15 11:10 == 47.1
12/10/15 11:15 == 45.6
12/10/15 11:20 == 28.5
12/10/15 11:25 == 28
12/10/15 11:30 == 27.9
12/10/15 11:35 == 28.2
12/10/15 11:40 == 27.6
12/10/15 11:45 == 28
12/10/15 11:50 == 27.7
12/10/15 11:55 == 31.2
12/10/15 12:00 == 46.1
12/10/15 12:05 == 45.6
12/10/15 12:10 == 46.7
12/10/15 12:15 == 45.6
12/10/15 12:20 == 45.9
12/10/15 12:25 == 45.5
12/10/15 12:30 == 45.5
12/10/15 12:35 == 46
12/10/15 12:40 == 47.3
12/10/15 12:45 == 45.6
12/10/15 12:50 == 45.8
12/10/15 12:55 == 45.8
12/10/15 13:00 == 45.7
12/10/15 13:05 == 45.8
12/10/15 13:10 == 45.6
12/10/15 13:15 == 45.6
12/10/15 13:20 == 45.7
12/10/15 13:25 == 45.6
12/10/15 13:30 == 45.7
12/10/15 13:35 == 46
12/10/15 13:40 == 46.4
12/10/15 13:45 == 46.3
12/10/15 13:50 == 45.8
12/10/15 13:55 == 48
12/10/15 14:00 == 48.1
12/10/15 14:05 == 48
12/10/15 14:10 == 47.7
12/10/15 14:15 == 46
12/10/15 14:20 == 45.9
12/10/15 14:25 == 45.5
12/10/15 14:30 == 45.8
12/10/15 14:35 == 45.5
12/10/15 14:40 == 46.1
12/10/15 14:45 == 45.9
12/10/15 14:50 == 45.6
12/10/15 14:55 == 46.3
12/10/15 15:00 == 46.5
12/10/15 15:05 == 46.9
12/10/15 15:10 == 47.3
12/10/15 15:15 == 47.9
12/10/15 15:20 == 48
12/10/15 15:25 == 47.7
12/10/15 15:30 == 48.1
12/10/15 15:35 == 47
12/10/15 15:40 == 46.2
12/10/15 15:45 == 46
12/10/15 15:50 == 47.5
12/10/15 15:55 == 45.6
12/10/15 16:00 == 47.4
12/10/15 16:05 == 47.5
12/10/15 16:10 == 47
12/10/15 16:15 == 47.4
12/10/15 16:20 == 47.3
12/10/15 16:25 == 47.3
12/10/15 16:30 == 47.5
12/10/15 16:35 == 47.4
12/10/15 16:40 == 47.4
12/10/15 16:45 == 47.4
12/10/15 16:50 == 47.4
12/10/15 16:55 == 45.4
12/10/15 17:00 == 47.4
12/10/15 17:05 == 47.3
12/10/15 17:10 == 47.4
12/10/15 17:15 == 47.3
12/10/15 17:20 == 47.5
12/10/15 17:25 == 47.3
12/10/15 17:30 == 47.4
12/10/15 17:35 == 47.4
12/10/15 17:40 == 47.4
12/10/15 17:45 == 47.4
12/10/15 17:50 == 47.5
12/10/15 17:55 == 47.3

Pumpback Station Discharge (0364)

12/10/15 18:00 == 47.5
12/10/15 18:05 == 47.4
12/10/15 18:10 == 46.9
12/10/15 18:15 == 47.2
12/10/15 18:20 == 47.3
12/10/15 18:25 == 47.3
12/10/15 18:30 == 47.2
12/10/15 18:35 == 47.4
12/10/15 18:40 == 47.2
12/10/15 18:45 == 47.3
12/10/15 18:50 == 47.3
12/10/15 18:55 == 46.8
12/10/15 19:00 == 47.2
12/10/15 19:05 == 47.2
12/10/15 19:10 == 47.1
12/10/15 19:15 == 47
12/10/15 19:20 == 47.1
12/10/15 19:25 == 47.1
12/10/15 19:30 == 47.1
12/10/15 19:35 == 47.2
12/10/15 19:40 == 47.1
12/10/15 19:45 == 46.9
12/10/15 19:50 == 47.1
12/10/15 19:55 == 47.1
12/10/15 20:00 == 47.1
12/10/15 20:05 == 47
12/10/15 20:10 == 47
12/10/15 20:15 == 47
12/10/15 20:20 == 47.1
12/10/15 20:25 == 47
12/10/15 20:30 == 47.1
12/10/15 20:35 == 47.1
12/10/15 20:40 == 47
12/10/15 20:45 == 47.1
12/10/15 20:50 == 47
12/10/15 20:55 == 47
12/10/15 21:00 == 47
12/10/15 21:05 == 47
12/10/15 21:10 == 47.1
12/10/15 21:15 == 47.1
12/10/15 21:20 == 47
12/10/15 21:25 == 47.1
12/10/15 21:30 == 47.1
12/10/15 21:35 == 47
12/10/15 21:40 == 47.2
12/10/15 21:45 == 47.1
12/10/15 21:50 == 47
12/10/15 21:55 == 47
12/10/15 22:00 == 47
12/10/15 22:05 == 47.1
12/10/15 22:10 == 47.1
12/10/15 22:15 == 47.1
12/10/15 22:20 == 47.1
12/10/15 22:25 == 47.1
12/10/15 22:30 == 47.1
12/10/15 22:35 == 47.2
12/10/15 22:40 == 47
12/10/15 22:45 == 47.3
12/10/15 22:50 == 47
12/10/15 22:55 == 47.1
12/10/15 23:00 == 47
12/10/15 23:05 == 47.1
12/10/15 23:10 == 47
12/10/15 23:15 == 47.1
12/10/15 23:20 == 47
12/10/15 23:25 == 47.1
12/10/15 23:30 == 47
12/10/15 23:35 == 47
12/10/15 23:40 == 47.2
12/10/15 23:45 == 47.1
12/10/15 23:50 == 47.2
12/10/15 23:55 == 47
12/11/15 0:00 == 47.1
12/11/15 0:05 == 47
12/11/15 0:10 == 47.1
12/11/15 0:15 == 47
12/11/15 0:20 == 47
12/11/15 0:25 == 47
12/11/15 0:30 == 47.1
12/11/15 0:35 == 47.1
12/11/15 0:40 == 47.1
12/11/15 0:45 == 47.2
12/11/15 0:50 == 47
12/11/15 0:55 == 47.1
12/11/15 1:00 == 47
12/11/15 1:05 == 47.1
12/11/15 1:10 == 47
12/11/15 1:15 == 47.1
12/11/15 1:20 == 47
12/11/15 1:25 == 47
12/11/15 1:30 == 47
12/11/15 1:35 == 47.1
12/11/15 1:40 == 47.1
12/11/15 1:45 == 47
12/11/15 1:50 == 47
12/11/15 1:55 == 47
12/11/15 2:00 == 47.1
12/11/15 2:05 == 47
12/11/15 2:10 == 47
12/11/15 2:15 == 46.9
12/11/15 2:20 == 47.1
12/11/15 2:25 == 47.1
12/11/15 2:30 == 47
12/11/15 2:35 == 47.1
12/11/15 2:40 == 47.1
12/11/15 2:45 == 47
12/11/15 2:50 == 47
12/11/15 2:55 == 46.9
12/11/15 3:00 == 47
12/11/15 3:05 == 47
12/11/15 3:10 == 47
12/11/15 3:15 == 47
12/11/15 3:20 == 47
12/11/15 3:25 == 46.9
12/11/15 3:30 == 47
12/11/15 3:35 == 47
12/11/15 3:40 == 47
12/11/15 3:45 == 46.9
12/11/15 3:50 == 47
12/11/15 3:55 == 47
12/11/15 4:00 == 47.1
12/11/15 4:05 == 47
12/11/15 4:10 == 47
12/11/15 4:15 == 47.1
12/11/15 4:20 == 47
12/11/15 4:25 == 47.1
12/11/15 4:30 == 47.1
12/11/15 4:35 == 46.9
12/11/15 4:40 == 46.9
12/11/15 4:45 == 47
12/11/15 4:50 == 46.9
12/11/15 4:55 == 47.1
12/11/15 5:00 == 47
12/11/15 5:05 == 47.1
12/11/15 5:10 == 46.9
12/11/15 5:15 == 47
12/11/15 5:20 == 46.9
12/11/15 5:25 == 46.9
12/11/15 5:30 == 46.9
12/11/15 5:35 == 47
12/11/15 5:40 == 46.9
12/11/15 5:45 == 46.9
12/11/15 5:50 == 47
12/11/15 5:55 == 46.9
12/11/15 6:00 == 47.1
12/11/15 6:05 == 47
12/11/15 6:10 == 47
12/11/15 6:15 == 47
12/11/15 6:20 == 47
12/11/15 6:25 == 46.9
12/11/15 6:30 == 47
12/11/15 6:35 == 46.9
12/11/15 6:40 == 47
12/11/15 6:45 == 47.1
12/11/15 6:50 == 47.1
12/11/15 6:55 == 47.4
12/11/15 7:00 == 47.2
12/11/15 7:05 == 47.3
12/11/15 7:10 == 47.2
12/11/15 7:15 == 47.1
12/11/15 7:20 == 47.2
12/11/15 7:25 == 47.2
12/11/15 7:30 == 47.2
12/11/15 7:35 == 47.4
12/11/15 7:40 == 47.5
12/11/15 7:45 == 47.4
12/11/15 7:50 == 47.3
12/11/15 7:55 == 47.2
12/11/15 8:00 == 47.3
12/11/15 8:05 == 47.3
12/11/15 8:10 == 47.2
12/11/15 8:15 == 47.5
12/11/15 8:20 == 47.5
12/11/15 8:25 == 47.4
12/11/15 8:30 == 47.4
12/11/15 8:35 == 47.6
12/11/15 8:40 == 47.5
12/11/15 8:45 == 47.4
12/11/15 8:50 == 47.5
12/11/15 8:55 == 47.3
12/11/15 9:00 == 47.6
12/11/15 9:05 == 47.6
12/11/15 9:10 == 46.8
12/11/15 9:15 == 46.2
12/11/15 9:20 == 47.4
12/11/15 9:25 == 47.6
12/11/15 9:30 == 47.6
12/11/15 9:35 == 47.6
12/11/15 9:40 == 47.3
12/11/15 9:45 == 47.5
12/11/15 9:50 == 47.5
12/11/15 9:55 == 47.3
12/11/15 10:00 == 47.4
12/11/15 10:05 == 47.7
12/11/15 10:10 == 46.8
12/11/15 10:15 == 47.5
12/11/15 10:20 == 47.3
12/11/15 10:25 == 47.5
12/11/15 10:30 == 47.4
12/11/15 10:35 == 47.4
12/11/15 10:40 == 45.5
12/11/15 10:45 == 47.2
12/11/15 10:50 == 47.5
12/11/15 10:55 == 47.4
12/11/15 11:00 == 47.3
12/11/15 11:05 == 47.5
12/11/15 11:10 == 47.1
12/11/15 11:15 == 47.4
12/11/15 11:20 == 47.2
12/11/15 11:25 == 47.3
12/11/15 11:30 == 47.3
12/11/15 11:35 == 47.5
12/11/15 11:40 == 45.1
12/11/15 11:45 == 47.2
12/11/15 11:50 == 47.2
12/11/15 11:55 == 47.4

Pumpback Station Discharge (0364)

12/11/15 12:00 == 46.9
12/11/15 12:05 == 47.3
12/11/15 12:10 == 46.9
12/11/15 12:15 == 47.2
12/11/15 12:20 == 47.1
12/11/15 12:25 == 47.1
12/11/15 12:30 == 47
12/11/15 12:35 == 47.4
12/11/15 12:40 == 46.6
12/11/15 12:45 == 47.1
12/11/15 12:50 == 47.1
12/11/15 12:55 == 47.2
12/11/15 13:00 == 47.2
12/11/15 13:05 == 47.2
12/11/15 13:10 == 47
12/11/15 13:15 == 46.6
12/11/15 13:20 == 47.1
12/11/15 13:25 == 47.1
12/11/15 13:30 == 47.1
12/11/15 13:35 == 47.2
12/11/15 13:40 == 47.2
12/11/15 13:45 == 47.1
12/11/15 13:50 == 47.3
12/11/15 13:55 == 46.8
12/11/15 14:00 == 46.9
12/11/15 14:05 == 47
12/11/15 14:10 == 47.2
12/11/15 14:15 == 47
12/11/15 14:20 == 47.1
12/11/15 14:25 == 47.2
12/11/15 14:30 == 47
12/11/15 14:35 == #
12/11/15 14:40 == 47.1
12/11/15 14:45 == 46.9
12/11/15 14:50 == 47.1
12/11/15 14:55 == 47
12/11/15 15:00 == 46.8
12/11/15 15:05 == 46.9
12/11/15 15:10 == 47
12/11/15 15:15 == 47
12/11/15 15:20 == 47.1
12/11/15 15:25 == 46.9
12/11/15 15:30 == 47
12/11/15 15:35 == 47
12/11/15 15:40 == 47
12/11/15 15:45 == 47
12/11/15 15:50 == 46.8
12/11/15 15:55 == 47.1
12/11/15 16:00 == 46.8
12/11/15 16:05 == 47.1
12/11/15 16:10 == 47.1
12/11/15 16:15 == 47
12/11/15 16:20 == 46.9
12/11/15 16:25 == 46.9
12/11/15 16:30 == 47
12/11/15 16:35 == 46.9
12/11/15 16:40 == 47
12/11/15 16:45 == 46.8
12/11/15 16:50 == 47
12/11/15 16:55 == 46.9
12/11/15 17:00 == 46.9
12/11/15 17:05 == 47
12/11/15 17:10 == 47
12/11/15 17:15 == 46.9
12/11/15 17:20 == 47.1
12/11/15 17:25 == 46.8
12/11/15 17:30 == 47.1
12/11/15 17:35 == 46.8
12/11/15 17:40 == 47
12/11/15 17:45 == 46.9
12/11/15 17:50 == 47.1
12/11/15 17:55 == 46.9
12/11/15 18:00 == 47
12/11/15 18:05 == 46.8
12/11/15 18:10 == 47.1
12/11/15 18:15 == 46.7
12/11/15 18:20 == 46.8
12/11/15 18:25 == 47
12/11/15 18:30 == 46.8
12/11/15 18:35 == 46.9
12/11/15 18:40 == 46.8
12/11/15 18:45 == 47
12/11/15 18:50 == 46.9
12/11/15 18:55 == 47.2
12/11/15 19:00 == 46.9
12/11/15 19:05 == 47
12/11/15 19:10 == 47
12/11/15 19:15 == 46.8
12/11/15 19:20 == 46.9
12/11/15 19:25 == 46.9
12/11/15 19:30 == 46.8
12/11/15 19:35 == 46.8
12/11/15 19:40 == 46.9
12/11/15 19:45 == 46.8
12/11/15 19:50 == 46.9
12/11/15 19:55 == 46.8
12/11/15 20:00 == 46.8
12/11/15 20:05 == 46.8
12/11/15 20:10 == 46.8
12/11/15 20:15 == 46.7
12/11/15 20:20 == 46.8
12/11/15 20:25 == 46.8
12/11/15 20:30 == 46.8
12/11/15 20:35 == 46.8
12/11/15 20:40 == 46.9
12/11/15 20:45 == 46.8
12/11/15 20:50 == 46.9
12/11/15 20:55 == 46.9
12/11/15 21:00 == 46.8
12/11/15 21:05 == 46.8
12/11/15 21:10 == 46.9
12/11/15 21:15 == 46.8
12/11/15 21:20 == 46.9
12/11/15 21:25 == 47
12/11/15 21:30 == 47
12/11/15 21:35 == 46.8
12/11/15 21:40 == 46.9
12/11/15 21:45 == 46.9
12/11/15 21:50 == 47
12/11/15 21:55 == 46.9
12/11/15 22:00 == 46.9
12/11/15 22:05 == 46.9
12/11/15 22:10 == 46.8
12/11/15 22:15 == 47
12/11/15 22:20 == 46.8
12/11/15 22:25 == 46.9
12/11/15 22:30 == 46.9
12/11/15 22:35 == 47
12/11/15 22:40 == 47
12/11/15 22:45 == 46.8
12/11/15 22:50 == 46.9
12/11/15 22:55 == 47
12/11/15 23:00 == 46.7
12/11/15 23:05 == 47
12/11/15 23:10 == 46.9
12/11/15 23:15 == 47
12/11/15 23:20 == 47
12/11/15 23:25 == 46.8
12/11/15 23:30 == 46.8
12/11/15 23:35 == 46.8
12/11/15 23:40 == 46.9
12/11/15 23:45 == 46.8
12/11/15 23:50 == 47
12/11/15 23:55 == 46.9
12/12/15 0:00 == 46.8
12/12/15 0:05 == 46.8
12/12/15 0:10 == 46.8
12/12/15 0:15 == 46.8
12/12/15 0:20 == 46.9
12/12/15 0:25 == 46.9
12/12/15 0:30 == 46.9
12/12/15 0:35 == 46.8
12/12/15 0:40 == 47
12/12/15 0:45 == 46.7
12/12/15 0:50 == 46.9
12/12/15 0:55 == 46.9
12/12/15 1:00 == 47.1
12/12/15 1:05 == 46.8
12/12/15 1:10 == 46.9
12/12/15 1:15 == 46.9
12/12/15 1:20 == 46.7
12/12/15 1:25 == 46.8
12/12/15 1:30 == 46.9
12/12/15 1:35 == 46.9
12/12/15 1:40 == 46.9
12/12/15 1:45 == 46.9
12/12/15 1:50 == 46.8
12/12/15 1:55 == 46.8
12/12/15 2:00 == 46.7
12/12/15 2:05 == 46.8
12/12/15 2:10 == 46.7
12/12/15 2:15 == 46.7
12/12/15 2:20 == 46.9
12/12/15 2:25 == 46.8
12/12/15 2:30 == 46.8
12/12/15 2:35 == 46.8
12/12/15 2:40 == 46.8
12/12/15 2:45 == 46.7
12/12/15 2:50 == 46.8
12/12/15 2:55 == 46.8
12/12/15 3:00 == 46.7
12/12/15 3:05 == 46.9
12/12/15 3:10 == 46.9
12/12/15 3:15 == 46.8
12/12/15 3:20 == 46.8
12/12/15 3:25 == 46.9
12/12/15 3:30 == 46.9
12/12/15 3:35 == 46.8
12/12/15 3:40 == 47.1
12/12/15 3:45 == 46.7
12/12/15 3:50 == 46.8
12/12/15 3:55 == 46.9
12/12/15 4:00 == 46.9
12/12/15 4:05 == 46.9
12/12/15 4:10 == 46.9
12/12/15 4:15 == 46.8
12/12/15 4:20 == 46.9
12/12/15 4:25 == 46.9
12/12/15 4:30 == 46.7
12/12/15 4:35 == 46.8
12/12/15 4:40 == 46.8
12/12/15 4:45 == 46.9
12/12/15 4:50 == 46.8
12/12/15 4:55 == 46.9
12/12/15 5:00 == 46.8
12/12/15 5:05 == 46.8
12/12/15 5:10 == 46.7
12/12/15 5:15 == 46.9
12/12/15 5:20 == 46.9
12/12/15 5:25 == 46.8
12/12/15 5:30 == 46.9
12/12/15 5:35 == 46.8
12/12/15 5:40 == 46.9
12/12/15 5:45 == 46.8
12/12/15 5:50 == 46.9
12/12/15 5:55 == 46.8

Pumpback Station Discharge (0364)

12/12/15 6:00 == 46.7
12/12/15 6:05 == 46.9
12/12/15 6:10 == 47
12/12/15 6:15 == 46.8
12/12/15 6:20 == 46.8
12/12/15 6:25 == 46.8
12/12/15 6:30 == 46.8
12/12/15 6:35 == 46.9
12/12/15 6:40 == 46.8
12/12/15 6:45 == 46.8
12/12/15 6:50 == 46.9
12/12/15 6:55 == 46.8
12/12/15 7:00 == 46.8
12/12/15 7:05 == 46.8
12/12/15 7:10 == 46.8
12/12/15 7:15 == 46.8
12/12/15 7:20 == 46.8
12/12/15 7:25 == 46.8
12/12/15 7:30 == 46.7
12/12/15 7:35 == 46.8
12/12/15 7:40 == 46.9
12/12/15 7:45 == 46.7
12/12/15 7:50 == 46.9
12/12/15 7:55 == 46.9
12/12/15 8:00 == 46.7
12/12/15 8:05 == 46.9
12/12/15 8:10 == 47
12/12/15 8:15 == 46.8
12/12/15 8:20 == 47
12/12/15 8:25 == 47.1
12/12/15 8:30 == 47
12/12/15 8:35 == 46.9
12/12/15 8:40 == 47
12/12/15 8:45 == 47
12/12/15 8:50 == 46.9
12/12/15 8:55 == 47
12/12/15 9:00 == 47
12/12/15 9:05 == 47.1
12/12/15 9:10 == 47
12/12/15 9:15 == 46.8
12/12/15 9:20 == 46.9
12/12/15 9:25 == 47.2
12/12/15 9:30 == 47.1
12/12/15 9:35 == 47.1
12/12/15 9:40 == 47
12/12/15 9:45 == 47
12/12/15 9:50 == 47.1
12/12/15 9:55 == 47
12/12/15 10:00 == 47
12/12/15 10:05 == 47.2
12/12/15 10:10 == 47.3
12/12/15 10:15 == 46.9
12/12/15 10:20 == 47
12/12/15 10:25 == 47.1
12/12/15 10:30 == 47
12/12/15 10:35 == 47.2
12/12/15 10:40 == 47.2
12/12/15 10:45 == 47.1
12/12/15 10:50 == 47
12/12/15 10:55 == 47.2
12/12/15 11:00 == 47
12/12/15 11:05 == 47.1
12/12/15 11:10 == 47.1
12/12/15 11:15 == 46.9
12/12/15 11:20 == 46.9
12/12/15 11:25 == 47.1
12/12/15 11:30 == 47
12/12/15 11:35 == 47.1
12/12/15 11:40 == 46.9
12/12/15 11:45 == 47.2
12/12/15 11:50 == 47.1
12/12/15 11:55 == 47.3
12/12/15 12:00 == 47.2
12/12/15 12:05 == 47.2
12/12/15 12:10 == 47.2
12/12/15 12:15 == 47.2
12/12/15 12:20 == 47.1
12/12/15 12:25 == 47.2
12/12/15 12:30 == 47.2
12/12/15 12:35 == 47.3
12/12/15 12:40 == 47.3
12/12/15 12:45 == 47.3
12/12/15 12:50 == 47.1
12/12/15 12:55 == 47.2
12/12/15 13:00 == 47.3
12/12/15 13:05 == 47.2
12/12/15 13:10 == 47.3
12/12/15 13:15 == 47.2
12/12/15 13:20 == 47.2
12/12/15 13:25 == 47.2
12/12/15 13:30 == 47.2
12/12/15 13:35 == 47.2
12/12/15 13:40 == 47.4
12/12/15 13:45 == 47
12/12/15 13:50 == 47.2
12/12/15 13:55 == 47.4
12/12/15 14:00 == 47.3
12/12/15 14:05 == 47.2
12/12/15 14:10 == 47.3
12/12/15 14:15 == 47.3
12/12/15 14:20 == 47.3
12/12/15 14:25 == 47.2
12/12/15 14:30 == 47.2
12/12/15 14:35 == 47.2
12/12/15 14:40 == 47.3
12/12/15 14:45 == 47.2
12/12/15 14:50 == 47.2
12/12/15 14:55 == 47.1
12/12/15 15:00 == 47.1
12/12/15 15:05 == 47.1
12/12/15 15:10 == 47.2
12/12/15 15:15 == 47.3
12/12/15 15:20 == 47.3
12/12/15 15:25 == 47.3
12/12/15 15:30 == 47.2
12/12/15 15:35 == 47.2
12/12/15 15:40 == 47.3
12/12/15 15:45 == 47.2
12/12/15 15:50 == 47.2
12/12/15 15:55 == 47.4
12/12/15 16:00 == 47.2
12/12/15 16:05 == 47.3
12/12/15 16:10 == 47.4
12/12/15 16:15 == 47.2
12/12/15 16:20 == 47.3
12/12/15 16:25 == 47.3
12/12/15 16:30 == 47.3
12/12/15 16:35 == 47.3
12/12/15 16:40 == 47.3
12/12/15 16:45 == 47.1
12/12/15 16:50 == 47.3
12/12/15 16:55 == 47.3
12/12/15 17:00 == 47.2
12/12/15 17:05 == 47.3
12/12/15 17:10 == 47.4
12/12/15 17:15 == 47.1
12/12/15 17:20 == 47.3
12/12/15 17:25 == 47.4
12/12/15 17:30 == 47.2
12/12/15 17:35 == 47.4
12/12/15 17:40 == 47.2
12/12/15 17:45 == 47.3
12/12/15 17:50 == 47.2
12/12/15 17:55 == 47.2
12/12/15 18:00 == 47.3
12/12/15 18:05 == 47.3
12/12/15 18:10 == 47.3
12/12/15 18:15 == 47.2
12/12/15 18:20 == 47.3
12/12/15 18:25 == 47.1
12/12/15 18:30 == 47.3
12/12/15 18:35 == 47.2
12/12/15 18:40 == 47.3
12/12/15 18:45 == 47.1
12/12/15 18:50 == 47.3
12/12/15 18:55 == 47.3
12/12/15 19:00 == 47.2
12/12/15 19:05 == 47.2
12/12/15 19:10 == 47.2
12/12/15 19:15 == 47.2
12/12/15 19:20 == 47.1
12/12/15 19:25 == 47.3
12/12/15 19:30 == 47.2
12/12/15 19:35 == 47.2
12/12/15 19:40 == 47.2
12/12/15 19:45 == 47.3
12/12/15 19:50 == 47.3
12/12/15 19:55 == 47.2
12/12/15 20:00 == 47.2
12/12/15 20:05 == 47.1
12/12/15 20:10 == 47.3
12/12/15 20:15 == 47.2
12/12/15 20:20 == 47.1
12/12/15 20:25 == 47.1
12/12/15 20:30 == 47.2
12/12/15 20:35 == 47.1
12/12/15 20:40 == 47.2
12/12/15 20:45 == 47.2
12/12/15 20:50 == 47.1
12/12/15 20:55 == 47.3
12/12/15 21:00 == 47.2
12/12/15 21:05 == 47.2
12/12/15 21:10 == 47.1
12/12/15 21:15 == 47.1
12/12/15 21:20 == 47.1
12/12/15 21:25 == 47.2
12/12/15 21:30 == 47.2
12/12/15 21:35 == 47.1
12/12/15 21:40 == 47.3
12/12/15 21:45 == 47.1
12/12/15 21:50 == 47.3
12/12/15 21:55 == 47.2
12/12/15 22:00 == 47.3
12/12/15 22:05 == 47.1
12/12/15 22:10 == 47.3
12/12/15 22:15 == 47.2
12/12/15 22:20 == 47.3
12/12/15 22:25 == 47.2
12/12/15 22:30 == 47.2
12/12/15 22:35 == 47.2
12/12/15 22:40 == 47.2
12/12/15 22:45 == 47.1
12/12/15 22:50 == 47.3
12/12/15 22:55 == 47.3
12/12/15 23:00 == 47.2
12/12/15 23:05 == 47.2
12/12/15 23:10 == 47.2
12/12/15 23:15 == 47.1
12/12/15 23:20 == 47.1
12/12/15 23:25 == 47.2
12/12/15 23:30 == 47.2
12/12/15 23:35 == 47.2
12/12/15 23:40 == 47.2
12/12/15 23:45 == 47.2
12/12/15 23:50 == 47.3
12/12/15 23:55 == 47.3

Pumpback Station Discharge (0364)

12/13/15 0:00 == 47.2
12/13/15 0:05 == 47.2
12/13/15 0:10 == 47.2
12/13/15 0:15 == 47.2
12/13/15 0:20 == 47.3
12/13/15 0:25 == 47.3
12/13/15 0:30 == 47.2
12/13/15 0:35 == 47.2
12/13/15 0:40 == 47.4
12/13/15 0:45 == 47.3
12/13/15 0:50 == 47.1
12/13/15 0:55 == 47.2
12/13/15 1:00 == 47.2
12/13/15 1:05 == 47.2
12/13/15 1:10 == 47.3
12/13/15 1:15 == 47.2
12/13/15 1:20 == 47.1
12/13/15 1:25 == 47.2
12/13/15 1:30 == 47.3
12/13/15 1:35 == 47.3
12/13/15 1:40 == 47.3
12/13/15 1:45 == 47.2
12/13/15 1:50 == 47.2
12/13/15 1:55 == 47.3
12/13/15 2:00 == 47.2
12/13/15 2:05 == 47.2
12/13/15 2:10 == 47.2
12/13/15 2:15 == 47.1
12/13/15 2:20 == 47.1
12/13/15 2:25 == 47.1
12/13/15 2:30 == 47.1
12/13/15 2:35 == 47.1
12/13/15 2:40 == 47.1
12/13/15 2:45 == 47.1
12/13/15 2:50 == 47.2
12/13/15 2:55 == 47.2
12/13/15 3:00 == 47.3
12/13/15 3:05 == 47.2
12/13/15 3:10 == 47.1
12/13/15 3:15 == 47.1
12/13/15 3:20 == 47
12/13/15 3:25 == 47.1
12/13/15 3:30 == 47.2
12/13/15 3:35 == 47.2
12/13/15 3:40 == 47.3
12/13/15 3:45 == 47.1
12/13/15 3:50 == 47.1
12/13/15 3:55 == 47.1
12/13/15 4:00 == 47.3
12/13/15 4:05 == 47.1
12/13/15 4:10 == 47.3
12/13/15 4:15 == 47.2
12/13/15 4:20 == 47.2
12/13/15 4:25 == 47.2
12/13/15 4:30 == 47.1
12/13/15 4:35 == 47.2
12/13/15 4:40 == 47.2
12/13/15 4:45 == 47.2
12/13/15 4:50 == 47.1
12/13/15 4:55 == 47.1
12/13/15 5:00 == 47.1
12/13/15 5:05 == 47.3
12/13/15 5:10 == 47.2
12/13/15 5:15 == 47.2
12/13/15 5:20 == 47.2
12/13/15 5:25 == 47.2
12/13/15 5:30 == 47.2
12/13/15 5:35 == 47.2
12/13/15 5:40 == 47.2
12/13/15 5:45 == 47.1
12/13/15 5:50 == 47.1
12/13/15 5:55 == 47.3
12/13/15 6:00 == 47.1
12/13/15 6:05 == 47.2
12/13/15 6:10 == 47.4
12/13/15 6:15 == 47.1
12/13/15 6:20 == 47.2
12/13/15 6:25 == 47.2
12/13/15 6:30 == 47.3
12/13/15 6:35 == 47.2
12/13/15 6:40 == 47.2
12/13/15 6:45 == 47.1
12/13/15 6:50 == 47.2
12/13/15 6:55 == 47.3
12/13/15 7:00 == 47.1
12/13/15 7:05 == 47.2
12/13/15 7:10 == 47.2
12/13/15 7:15 == 47.2
12/13/15 7:20 == 47.2
12/13/15 7:25 == 47.1
12/13/15 7:30 == 47.2
12/13/15 7:35 == 47.2
12/13/15 7:40 == 47.2
12/13/15 7:45 == 47.3
12/13/15 7:50 == 47.1
12/13/15 7:55 == 47.3
12/13/15 8:00 == 47.2
12/13/15 8:05 == 47.3
12/13/15 8:10 == 47.3
12/13/15 8:15 == 47.2
12/13/15 8:20 == 47.3
12/13/15 8:25 == 47.3
12/13/15 8:30 == 47.4
12/13/15 8:35 == 47.4
12/13/15 8:40 == 47.4
12/13/15 8:45 == 47.2
12/13/15 8:50 == 47.3
12/13/15 8:55 == 47.3
12/13/15 9:00 == 47.4
12/13/15 9:05 == 47.3
12/13/15 9:10 == 47.4
12/13/15 9:15 == 47.3
12/13/15 9:20 == 47.3
12/13/15 9:25 == 47.3
12/13/15 9:30 == 47.4
12/13/15 9:35 == 47.3
12/13/15 9:40 == 47.4
12/13/15 9:45 == 47.4
12/13/15 9:50 == 47.5
12/13/15 9:55 == 47.3
12/13/15 10:00 == 47.4
12/13/15 10:05 == 47.4
12/13/15 10:10 == 47.4
12/13/15 10:15 == 47.3
12/13/15 10:20 == 47.3
12/13/15 10:25 == 47.4
12/13/15 10:30 == 47.3
12/13/15 10:35 == 47.4
12/13/15 10:40 == 47.4
12/13/15 10:45 == 47.4
12/13/15 10:50 == 47.2
12/13/15 10:55 == 47.4
12/13/15 11:00 == 47.3
12/13/15 11:05 == 47.4
12/13/15 11:10 == 47.4
12/13/15 11:15 == 47.3
12/13/15 11:20 == 47.2
12/13/15 11:25 == 47.2
12/13/15 11:30 == 47.2
12/13/15 11:35 == 47.3
12/13/15 11:40 == 47.3
12/13/15 11:45 == 47
12/13/15 11:50 == 47.3
12/13/15 11:55 == 47.4
12/13/15 12:00 == 47.4
12/13/15 12:05 == 47.6
12/13/15 12:10 == 47.2
12/13/15 12:15 == 47.3
12/13/15 12:20 == 47.3
12/13/15 12:25 == 47.5
12/13/15 12:30 == 47.1
12/13/15 12:35 == 47.2
12/13/15 12:40 == 47
12/13/15 12:45 == 47.3
12/13/15 12:50 == 47.3
12/13/15 12:55 == 47.1
12/13/15 13:00 == 47.3
12/13/15 13:05 == 47.2
12/13/15 13:10 == 47.1
12/13/15 13:15 == 47.1
12/13/15 13:20 == 47.1
12/13/15 13:25 == 47.2
12/13/15 13:30 == 47.2
12/13/15 13:35 == 47.2
12/13/15 13:40 == 47.3
12/13/15 13:45 == 0.5
12/13/15 13:50 == 0
12/13/15 13:55 == 0
12/13/15 14:00 == #
12/13/15 14:05 == #
12/13/15 14:10 == #
12/13/15 14:15 == 0
12/13/15 14:20 == 0
12/13/15 14:25 == #
12/13/15 14:30 == 0
12/13/15 14:35 == #
12/13/15 14:40 == #
12/13/15 14:45 == 0
12/13/15 14:50 == 0
12/13/15 14:55 == #
12/13/15 15:00 == #
12/13/15 15:05 == #
12/13/15 15:10 == #
12/13/15 15:15 == #
12/13/15 15:20 == 13.4
12/13/15 15:25 == 45.6
12/13/15 15:30 == 46.6
12/13/15 15:35 == 47.5
12/13/15 15:40 == 47.4
12/13/15 15:45 == 47.6
12/13/15 15:50 == 47.6
12/13/15 15:55 == 47.6
12/13/15 16:00 == 47.6
12/13/15 16:05 == 47.3
12/13/15 16:10 == 47.6
12/13/15 16:15 == 46.1
12/13/15 16:20 == 46.8
12/13/15 16:25 == 47.4
12/13/15 16:30 == 47.6
12/13/15 16:35 == 47.5
12/13/15 16:40 == 47.6
12/13/15 16:45 == 47.4
12/13/15 16:50 == 47.5
12/13/15 16:55 == 47.2
12/13/15 17:00 == 47.4
12/13/15 17:05 == 47.5
12/13/15 17:10 == 47.3
12/13/15 17:15 == 46.1
12/13/15 17:20 == 47.4
12/13/15 17:25 == 47.4
12/13/15 17:30 == 47.6
12/13/15 17:35 == 47.5
12/13/15 17:40 == 47.5
12/13/15 17:45 == 47.4
12/13/15 17:50 == 47.6
12/13/15 17:55 == 47.3

Pumpback Station Discharge (0364)

12/13/15 18:00 == 47.7
12/13/15 18:05 == 47.5
12/13/15 18:10 == 47.5
12/13/15 18:15 == 47.1
12/13/15 18:20 == 47.5
12/13/15 18:25 == 47.3
12/13/15 18:30 == 47.4
12/13/15 18:35 == 47.2
12/13/15 18:40 == 47.5
12/13/15 18:45 == 47.2
12/13/15 18:50 == 47.4
12/13/15 18:55 == 47.1
12/13/15 19:00 == 47.5
12/13/15 19:05 == 47.4
12/13/15 19:10 == 47.3
12/13/15 19:15 == 47
12/13/15 19:20 == 47.3
12/13/15 19:25 == 47.1
12/13/15 19:30 == 47.2
12/13/15 19:35 == 47.3
12/13/15 19:40 == 47.1
12/13/15 19:45 == 47.3
12/13/15 19:50 == 47.2
12/13/15 19:55 == 47.2
12/13/15 20:00 == 47.3
12/13/15 20:05 == 47.2
12/13/15 20:10 == 47.2
12/13/15 20:15 == 47.2
12/13/15 20:20 == 47.3
12/13/15 20:25 == 47.2
12/13/15 20:30 == 47.2
12/13/15 20:35 == 47.3
12/13/15 20:40 == 47.4
12/13/15 20:45 == 47.2
12/13/15 20:50 == 47.2
12/13/15 20:55 == 47.3
12/13/15 21:00 == 47.3
12/13/15 21:05 == 47.2
12/13/15 21:10 == 47.2
12/13/15 21:15 == 47.3
12/13/15 21:20 == 47.2
12/13/15 21:25 == 47.2
12/13/15 21:30 == 47.3
12/13/15 21:35 == 47.2
12/13/15 21:40 == 47.3
12/13/15 21:45 == 47.4
12/13/15 21:50 == 47.3
12/13/15 21:55 == 47.2
12/13/15 22:00 == 47.3
12/13/15 22:05 == 47.3
12/13/15 22:10 == 47.1
12/13/15 22:15 == 47.2
12/13/15 22:20 == 47.2
12/13/15 22:25 == 47.3
12/13/15 22:30 == 47.2
12/13/15 22:35 == 47.2
12/13/15 22:40 == 47.4
12/13/15 22:45 == 47.3
12/13/15 22:50 == 47.3
12/13/15 22:55 == 47.2
12/13/15 23:00 == 47.2
12/13/15 23:05 == 47.2
12/13/15 23:10 == 47.2
12/13/15 23:15 == 47.1
12/13/15 23:20 == 47.3
12/13/15 23:25 == 47.2
12/13/15 23:30 == 47.3
12/13/15 23:35 == 47.3
12/13/15 23:40 == 47.2
12/13/15 23:45 == 47.3
12/13/15 23:50 == 47.3
12/13/15 23:55 == 47.3
12/14/15 0:00 == 47.3
12/14/15 0:05 == 47.3
12/14/15 0:10 == 47
12/14/15 0:15 == 47.1
12/14/15 0:20 == 47.2
12/14/15 0:25 == 47.1
12/14/15 0:30 == 47.2
12/14/15 0:35 == 47.2
12/14/15 0:40 == 47.2
12/14/15 0:45 == 47.3
12/14/15 0:50 == 47.3
12/14/15 0:55 == 47.2
12/14/15 1:00 == 47.2
12/14/15 1:05 == 47.2
12/14/15 1:10 == 47.2
12/14/15 1:15 == 47.4
12/14/15 1:20 == 47.3
12/14/15 1:25 == 47.3
12/14/15 1:30 == 47.4
12/14/15 1:35 == 47.4
12/14/15 1:40 == 47.3
12/14/15 1:45 == 47.4
12/14/15 1:50 == 47.4
12/14/15 1:55 == 47.5
12/14/15 2:00 == 47.3
12/14/15 2:05 == 47.4
12/14/15 2:10 == 47.5
12/14/15 2:15 == 47.3
12/14/15 2:20 == 47.3
12/14/15 2:25 == 47.4
12/14/15 2:30 == 47.4
12/14/15 2:35 == 47.4
12/14/15 2:40 == 47.3
12/14/15 2:45 == 47.4
12/14/15 2:50 == 47.3
12/14/15 2:55 == 47.2
12/14/15 3:00 == 47.4
12/14/15 3:05 == 47.4
12/14/15 3:10 == 47.4
12/14/15 3:15 == 47.5
12/14/15 3:20 == 47.5
12/14/15 3:25 == 47.4
12/14/15 3:30 == 47.5
12/14/15 3:35 == 47.5
12/14/15 3:40 == 47.4
12/14/15 3:45 == 47.4
12/14/15 3:50 == 47.4
12/14/15 3:55 == 47.4
12/14/15 4:00 == 47.5
12/14/15 4:05 == 47.5
12/14/15 4:10 == 47.3
12/14/15 4:15 == 47.4
12/14/15 4:20 == 47.4
12/14/15 4:25 == 47.3
12/14/15 4:30 == 47.5
12/14/15 4:35 == 47.4
12/14/15 4:40 == 47.3
12/14/15 4:45 == 47.5
12/14/15 4:50 == 47.3
12/14/15 4:55 == 47.3
12/14/15 5:00 == 47.5
12/14/15 5:05 == 47.4
12/14/15 5:10 == 47.3
12/14/15 5:15 == 47.3
12/14/15 5:20 == 47.4
12/14/15 5:25 == 47.3
12/14/15 5:30 == 47.3
12/14/15 5:35 == 47.4
12/14/15 5:40 == 47.3
12/14/15 5:45 == 47.4
12/14/15 5:50 == 47.5
12/14/15 5:55 == 47.3
12/14/15 6:00 == 47.2
12/14/15 6:05 == 47.5
12/14/15 6:10 == 47.4
12/14/15 6:15 == 47.4
12/14/15 6:20 == 47.3
12/14/15 6:25 == 47.3
12/14/15 6:30 == 47.4
12/14/15 6:35 == 47.3
12/14/15 6:40 == 47.2
12/14/15 6:45 == 47.5
12/14/15 6:50 == 47.4
12/14/15 6:55 == 47.4
12/14/15 7:00 == 47.4
12/14/15 7:05 == 47.5
12/14/15 7:10 == 47.2
12/14/15 7:15 == 47.5
12/14/15 7:20 == 47
12/14/15 7:25 == 47.4
12/14/15 7:30 == 47.4
12/14/15 7:35 == 47.3
12/14/15 7:40 == 47.4
12/14/15 7:45 == 47.5
12/14/15 7:50 == 47.2
12/14/15 7:55 == 46.6
12/14/15 8:00 == 46.3
12/14/15 8:05 == 47.5
12/14/15 8:10 == 47.6
12/14/15 8:15 == 47.6
12/14/15 8:20 == 47.9
12/14/15 8:25 == 47.8
12/14/15 8:30 == 47.9
12/14/15 8:35 == 47.7
12/14/15 8:40 == 47.7
12/14/15 8:45 == 47.5
12/14/15 8:50 == 47.7
12/14/15 8:55 == 47.4
12/14/15 9:00 == 47.8
12/14/15 9:05 == 47.7
12/14/15 9:10 == 47.8
12/14/15 9:15 == 47.4
12/14/15 9:20 == 47.8
12/14/15 9:25 == 47.5
12/14/15 9:30 == 47.7
12/14/15 9:35 == 47.5
12/14/15 9:40 == 47.8
12/14/15 9:45 == 47.4
12/14/15 9:50 == 47.7
12/14/15 9:55 == 47.5
12/14/15 10:00 == 47.4
12/14/15 10:05 == 47.2
12/14/15 10:10 == 47.6
12/14/15 10:15 == 47.2
12/14/15 10:20 == 47.6
12/14/15 10:25 == 47.3
12/14/15 10:30 == 47.6
12/14/15 10:35 == 47.2
12/14/15 10:40 == 46.7
12/14/15 10:45 == 46.4
12/14/15 10:50 == 47.5
12/14/15 10:55 == 47.5
12/14/15 11:00 == 47.5
12/14/15 11:05 == 47.3
12/14/15 11:10 == 47.3
12/14/15 11:15 == 47.3
12/14/15 11:20 == 47.6
12/14/15 11:25 == 47.5
12/14/15 11:30 == 47.3
12/14/15 11:35 == 47.6
12/14/15 11:40 == 46.3
12/14/15 11:45 == 46.5
12/14/15 11:50 == 47.5
12/14/15 11:55 == 47.4

Pumpback Station Discharge (0364)

12/14/15 12:00 == 47.4
12/14/15 12:05 == 47.4
12/14/15 12:10 == 47.1
12/14/15 12:15 == 47.2
12/14/15 12:20 == 47.2
12/14/15 12:25 == 47.2
12/14/15 12:30 == 47.3
12/14/15 12:35 == 47.2
12/14/15 12:40 == 47
12/14/15 12:45 == 47.2
12/14/15 12:50 == 47.2
12/14/15 12:55 == 47.1
12/14/15 13:00 == 47.3
12/14/15 13:05 == 47.4
12/14/15 13:10 == 47.1
12/14/15 13:15 == 47.2
12/14/15 13:20 == 47.2
12/14/15 13:25 == 47.2
12/14/15 13:30 == 47.2
12/14/15 13:35 == 47.1
12/14/15 13:40 == 47.3
12/14/15 13:45 == 47.2
12/14/15 13:50 == 47.2
12/14/15 13:55 == 47.2
12/14/15 14:00 == 47.2
12/14/15 14:05 == 47.2
12/14/15 14:10 == 47.2
12/14/15 14:15 == 47.3
12/14/15 14:20 == 47.1
12/14/15 14:25 == 47.1
12/14/15 14:30 == 47.2
12/14/15 14:35 == 47.2
12/14/15 14:40 == 47.1
12/14/15 14:45 == 47.2
12/14/15 14:50 == 47.3
12/14/15 14:55 == 47.3
12/14/15 15:00 == 47.4
12/14/15 15:05 == 47.4
12/14/15 15:10 == 47.4
12/14/15 15:15 == 47.4
12/14/15 15:20 == 47.5
12/14/15 15:25 == 47.5
12/14/15 15:30 == 47.4
12/14/15 15:35 == 47.4
12/14/15 15:40 == 47.4
12/14/15 15:45 == 47.4
12/14/15 15:50 == 47.5
12/14/15 15:55 == 47.2
12/14/15 16:00 == 47.7
12/14/15 16:05 == 47.5
12/14/15 16:10 == 46.8
12/14/15 16:15 == 46.2
12/14/15 16:20 == 46.9
12/14/15 16:25 == 47.3
12/14/15 16:30 == 47.4
12/14/15 16:35 == 47.5
12/14/15 16:40 == 47.2
12/14/15 16:45 == 47.4
12/14/15 16:50 == 47.3
12/14/15 16:55 == 47.2
12/14/15 17:00 == 47.4
12/14/15 17:05 == 47.5
12/14/15 17:10 == 47.1
12/14/15 17:15 == 47.3
12/14/15 17:20 == 47.2
12/14/15 17:25 == 47.5
12/14/15 17:30 == 47.3
12/14/15 17:35 == 47.4
12/14/15 17:40 == 47.2
12/14/15 17:45 == 47.4
12/14/15 17:50 == 47.2
12/14/15 17:55 == 47.3
12/14/15 18:00 == 47.5
12/14/15 18:05 == 47.5
12/14/15 18:10 == 47.2
12/14/15 18:15 == 47.6
12/14/15 18:20 == 47.1
12/14/15 18:25 == 47.4
12/14/15 18:30 == 47.2
12/14/15 18:35 == 47.4
12/14/15 18:40 == 47.1
12/14/15 18:45 == 47.4
12/14/15 18:50 == 47.1
12/14/15 18:55 == 47.1
12/14/15 19:00 == 47.3
12/14/15 19:05 == 47.2
12/14/15 19:10 == 47.1
12/14/15 19:15 == 47.1
12/14/15 19:20 == 47.2
12/14/15 19:25 == 47.2
12/14/15 19:30 == 47.2
12/14/15 19:35 == 47.2
12/14/15 19:40 == 47.2
12/14/15 19:45 == 47.2
12/14/15 19:50 == 47.2
12/14/15 19:55 == 47.3
12/14/15 20:00 == 47.3
12/14/15 20:05 == 47.1
12/14/15 20:10 == 47.1
12/14/15 20:15 == 47.2
12/14/15 20:20 == 47.1
12/14/15 20:25 == 47.2
12/14/15 20:30 == 47.2
12/14/15 20:35 == 47.2
12/14/15 20:40 == 47.3
12/14/15 20:45 == 47.2
12/14/15 20:50 == 47.3
12/14/15 20:55 == 47.4
12/14/15 21:00 == 47.1
12/14/15 21:05 == 47.3
12/14/15 21:10 == 47.2
12/14/15 21:15 == 47.2
12/14/15 21:20 == 47.2
12/14/15 21:25 == 47.2
12/14/15 21:30 == 47.2
12/14/15 21:35 == 47.2
12/14/15 21:40 == 47.3
12/14/15 21:45 == 47.2
12/14/15 21:50 == 47.3
12/14/15 21:55 == 47.1
12/14/15 22:00 == 47.4
12/14/15 22:05 == 47.2
12/14/15 22:10 == 47.4
12/14/15 22:15 == 47.2
12/14/15 22:20 == 47.3
12/14/15 22:25 == 47.3
12/14/15 22:30 == 47.2
12/14/15 22:35 == 47.3
12/14/15 22:40 == 47.3
12/14/15 22:45 == 47.3
12/14/15 22:50 == 47.4
12/14/15 22:55 == 47.4
12/14/15 23:00 == 47.3
12/14/15 23:05 == 47.3
12/14/15 23:10 == 47.3
12/14/15 23:15 == 47.3
12/14/15 23:20 == 47.5
12/14/15 23:25 == 47.2
12/14/15 23:30 == 47.3
12/14/15 23:35 == 47.3
12/14/15 23:40 == 47.3
12/14/15 23:45 == 47.3
12/14/15 23:50 == 47.3
12/14/15 23:55 == 47.3
12/15/15 0:00 == 47.3
12/15/15 0:05 == 47.3
12/15/15 0:10 == 47.2
12/15/15 0:15 == 47.2
12/15/15 0:20 == 47.1
12/15/15 0:25 == 47.2
12/15/15 0:30 == 47.1
12/15/15 0:35 == 47.3
12/15/15 0:40 == 47.3
12/15/15 0:45 == 47.2
12/15/15 0:50 == 47.3
12/15/15 0:55 == 47.3
12/15/15 1:00 == 47.3
12/15/15 1:05 == 47.2
12/15/15 1:10 == 47.2
12/15/15 1:15 == 47.2
12/15/15 1:20 == 47.1
12/15/15 1:25 == 47.2
12/15/15 1:30 == 47.2
12/15/15 1:35 == 47.2
12/15/15 1:40 == 47.3
12/15/15 1:45 == 47.2
12/15/15 1:50 == 47.1
12/15/15 1:55 == 47.2
12/15/15 2:00 == 47.1
12/15/15 2:05 == 47.2
12/15/15 2:10 == 47.3
12/15/15 2:15 == 47.3
12/15/15 2:20 == 47.2
12/15/15 2:25 == 47.3
12/15/15 2:30 == 47.2
12/15/15 2:35 == 47.2
12/15/15 2:40 == 47.3
12/15/15 2:45 == 47.3
12/15/15 2:50 == 47.4
12/15/15 2:55 == 47.2
12/15/15 3:00 == 47.4
12/15/15 3:05 == 47.2
12/15/15 3:10 == 47.2
12/15/15 3:15 == 47.3
12/15/15 3:20 == 47.2
12/15/15 3:25 == 47.3
12/15/15 3:30 == 47.4
12/15/15 3:35 == 47
12/15/15 3:40 == 47.2
12/15/15 3:45 == 47.2
12/15/15 3:50 == 47.2
12/15/15 3:55 == 47.2
12/15/15 4:00 == 47.2
12/15/15 4:05 == 47.3
12/15/15 4:10 == 47.3
12/15/15 4:15 == 47.3
12/15/15 4:20 == 47.3
12/15/15 4:25 == 47.3
12/15/15 4:30 == 47.2
12/15/15 4:35 == 47.3
12/15/15 4:40 == 47.2
12/15/15 4:45 == 47.4
12/15/15 4:50 == 47.2
12/15/15 4:55 == 47.3
12/15/15 5:00 == 47.3
12/15/15 5:05 == 47.3
12/15/15 5:10 == 47.4
12/15/15 5:15 == 47.3
12/15/15 5:20 == 47.2
12/15/15 5:25 == 47.2
12/15/15 5:30 == 47.2
12/15/15 5:35 == 47.4
12/15/15 5:40 == 47.2
12/15/15 5:45 == 47.2
12/15/15 5:50 == 47.2
12/15/15 5:55 == 47.2

Pumpback Station Discharge (0364)

12/15/15 6:00 == 47.2
12/15/15 6:05 == 47.2
12/15/15 6:10 == 47.4
12/15/15 6:15 == 47.2
12/15/15 6:20 == 47.2
12/15/15 6:25 == 47.2
12/15/15 6:30 == 47.1
12/15/15 6:35 == 47.2
12/15/15 6:40 == 47.1
12/15/15 6:45 == 47.3
12/15/15 6:50 == 47.2
12/15/15 6:55 == 47.3
12/15/15 7:00 == 47.6
12/15/15 7:05 == 47.3
12/15/15 7:10 == 47.3
12/15/15 7:15 == 47.3
12/15/15 7:20 == 47.3
12/15/15 7:25 == 47.3
12/15/15 7:30 == 47.4
12/15/15 7:35 == 47.4
12/15/15 7:40 == 47.5
12/15/15 7:45 == 47.5
12/15/15 7:50 == 47.7
12/15/15 7:55 == 47.1
12/15/15 8:00 == 47.6
12/15/15 8:05 == 47.4
12/15/15 8:10 == 47.5
12/15/15 8:15 == 47.5
12/15/15 8:20 == 47.4
12/15/15 8:25 == 47.5
12/15/15 8:30 == 47.4
12/15/15 8:35 == 47.4
12/15/15 8:40 == 47.6
12/15/15 8:45 == 47.6
12/15/15 8:50 == 47.4
12/15/15 8:55 == 47.5
12/15/15 9:00 == 47.5
12/15/15 9:05 == 47.5
12/15/15 9:10 == 47.3
12/15/15 9:15 == 47.6
12/15/15 9:20 == 47.4
12/15/15 9:25 == 47.8
12/15/15 9:30 == 47.6
12/15/15 9:35 == 47.6
12/15/15 9:40 == 47.4
12/15/15 9:45 == 47.7
12/15/15 9:50 == 47.6
12/15/15 9:55 == 47.8
12/15/15 10:00 == 47.5
12/15/15 10:05 == 47.7
12/15/15 10:10 == 47.3
12/15/15 10:15 == 47.6
12/15/15 10:20 == 47.6
12/15/15 10:25 == 47.7
12/15/15 10:30 == 47.4
12/15/15 10:35 == 47.6
12/15/15 10:40 == 46.4
12/15/15 10:45 == 46.9
12/15/15 10:50 == 47.4
12/15/15 10:55 == 47.5
12/15/15 11:00 == 47.4
12/15/15 11:05 == 47.7
12/15/15 11:10 == 47.4
12/15/15 11:15 == 47.5
12/15/15 11:20 == 47.4
12/15/15 11:25 == 47.6
12/15/15 11:30 == 47.4
12/15/15 11:35 == 47.5
12/15/15 11:40 == 46.3
12/15/15 11:45 == 46.6
12/15/15 11:50 == 47.3
12/15/15 11:55 == 47.6
12/15/15 12:00 == 47.4
12/15/15 12:05 == 47.4
12/15/15 12:10 == 47.3
12/15/15 12:15 == 47.5
12/15/15 12:20 == 47.4
12/15/15 12:25 == 47.5
12/15/15 12:30 == 47.4
12/15/15 12:35 == 47.5
12/15/15 12:40 == 47.2
12/15/15 12:45 == 47.5
12/15/15 12:50 == 47.3
12/15/15 12:55 == 47.5
12/15/15 13:00 == 47.4
12/15/15 13:05 == 47.5
12/15/15 13:10 == 47.4
12/15/15 13:15 == 47.4
12/15/15 13:20 == 47.4
12/15/15 13:25 == 47.3
12/15/15 13:30 == 47.4
12/15/15 13:35 == 47.4
12/15/15 13:40 == 47.5
12/15/15 13:45 == 47.3
12/15/15 13:50 == 47.4
12/15/15 13:55 == 47.3
12/15/15 14:00 == 47.6
12/15/15 14:05 == 47.3
12/15/15 14:10 == 47.5
12/15/15 14:15 == 47.4
12/15/15 14:20 == 47.4
12/15/15 14:25 == 47.3
12/15/15 14:30 == 47.5
12/15/15 14:35 == 47.3
12/15/15 14:40 == 47.3
12/15/15 14:45 == 47.4
12/15/15 14:50 == 47.4
12/15/15 14:55 == 47.4
12/15/15 15:00 == 47.1
12/15/15 15:05 == 47.3
12/15/15 15:10 == 47.3
12/15/15 15:15 == 47.1
12/15/15 15:20 == 47.4
12/15/15 15:25 == 47.4
12/15/15 15:30 == 47.2
12/15/15 15:35 == 47.2
12/15/15 15:40 == 47.3
12/15/15 15:45 == 47.3
12/15/15 15:50 == 47.4
12/15/15 15:55 == 47.3
12/15/15 16:00 == 47.3
12/15/15 16:05 == 47.4
12/15/15 16:10 == 47.5
12/15/15 16:15 == 47.3
12/15/15 16:20 == 47.3
12/15/15 16:25 == 47.1
12/15/15 16:30 == 47.4
12/15/15 16:35 == 47
12/15/15 16:40 == 47.3
12/15/15 16:45 == 47.2
12/15/15 16:50 == 47.2
12/15/15 16:55 == 47.2
12/15/15 17:00 == 47.1
12/15/15 17:05 == 47.3
12/15/15 17:10 == 47.1
12/15/15 17:15 == 47.4
12/15/15 17:20 == 47.3
12/15/15 17:25 == 47.3
12/15/15 17:30 == 47.2
12/15/15 17:35 == 47.2
12/15/15 17:40 == 47.3
12/15/15 17:45 == 47.3
12/15/15 17:50 == 45.8
12/15/15 17:55 == 46.7
12/15/15 18:00 == 47.2
12/15/15 18:05 == 47.1
12/15/15 18:10 == 47.4
12/15/15 18:15 == 47.3
12/15/15 18:20 == 47.4
12/15/15 18:25 == 47.3
12/15/15 18:30 == 47.2
12/15/15 18:35 == 47.3
12/15/15 18:40 == 47.3
12/15/15 18:45 == 47.4
12/15/15 18:50 == 47.4
12/15/15 18:55 == 47.5
12/15/15 19:00 == 47.3
12/15/15 19:05 == 47.3
12/15/15 19:10 == 47.2
12/15/15 19:15 == 47.3
12/15/15 19:20 == 47.2
12/15/15 19:25 == 47.4
12/15/15 19:30 == 47.3
12/15/15 19:35 == 47.3
12/15/15 19:40 == 47.2
12/15/15 19:45 == 47.3
12/15/15 19:50 == 47.2
12/15/15 19:55 == 47.2
12/15/15 20:00 == 47.2
12/15/15 20:05 == 47.3
12/15/15 20:10 == 47.3
12/15/15 20:15 == 47.3
12/15/15 20:20 == 47.1
12/15/15 20:25 == 47.3
12/15/15 20:30 == 47.4
12/15/15 20:35 == 47.3
12/15/15 20:40 == 47.4
12/15/15 20:45 == 47.1
12/15/15 20:50 == 47.3
12/15/15 20:55 == 47.4
12/15/15 21:00 == 47.3
12/15/15 21:05 == 47.3
12/15/15 21:10 == 47.2
12/15/15 21:15 == 47.3
12/15/15 21:20 == 47.4
12/15/15 21:25 == 47.2
12/15/15 21:30 == 47.2
12/15/15 21:35 == 47.3
12/15/15 21:40 == 47.3
12/15/15 21:45 == 47.3
12/15/15 21:50 == 47.4
12/15/15 21:55 == 47.2
12/15/15 22:00 == 47.3
12/15/15 22:05 == 47.2
12/15/15 22:10 == 47.2
12/15/15 22:15 == 47.1
12/15/15 22:20 == 47.2
12/15/15 22:25 == 47.3
12/15/15 22:30 == 47.2
12/15/15 22:35 == 47.3
12/15/15 22:40 == 47.2
12/15/15 22:45 == 47.4
12/15/15 22:50 == 47.3
12/15/15 22:55 == 47.5
12/15/15 23:00 == 47.3
12/15/15 23:05 == 47.2
12/15/15 23:10 == 47.3
12/15/15 23:15 == 47.3
12/15/15 23:20 == 47.4
12/15/15 23:25 == 47.3
12/15/15 23:30 == 47.3
12/15/15 23:35 == 47.4
12/15/15 23:40 == 47.3
12/15/15 23:45 == 47.3
12/15/15 23:50 == 47.4
12/15/15 23:55 == 47.2

Pumpback Station Discharge (0364)

12/16/15 0:00 == 47.2
12/16/15 0:05 == 47.3
12/16/15 0:10 == 47.1
12/16/15 0:15 == 47.2
12/16/15 0:20 == 47.2
12/16/15 0:25 == 47.2
12/16/15 0:30 == 47.2
12/16/15 0:35 == 47.2
12/16/15 0:40 == 47.4
12/16/15 0:45 == 47.2
12/16/15 0:50 == 47.3
12/16/15 0:55 == 47.2
12/16/15 1:00 == 47.3
12/16/15 1:05 == 47.3
12/16/15 1:10 == 47.3
12/16/15 1:15 == 47.3
12/16/15 1:20 == 47.4
12/16/15 1:25 == 47.3
12/16/15 1:30 == 47.3
12/16/15 1:35 == 47.2
12/16/15 1:40 == 47.2
12/16/15 1:45 == 47.3
12/16/15 1:50 == 47.3
12/16/15 1:55 == 47.4
12/16/15 2:00 == 47.3
12/16/15 2:05 == 47.2
12/16/15 2:10 == 47.3
12/16/15 2:15 == 47.2
12/16/15 2:20 == 47.3
12/16/15 2:25 == 47.2
12/16/15 2:30 == 47.3
12/16/15 2:35 == 47.4
12/16/15 2:40 == 47.3
12/16/15 2:45 == 47.3
12/16/15 2:50 == 47.3
12/16/15 2:55 == 47.4
12/16/15 3:00 == 47.3
12/16/15 3:05 == 47.2
12/16/15 3:10 == 47.2
12/16/15 3:15 == 47.3
12/16/15 3:20 == 47.3
12/16/15 3:25 == 47.2
12/16/15 3:30 == 47.4
12/16/15 3:35 == 47.2
12/16/15 3:40 == 47.4
12/16/15 3:45 == 47.1
12/16/15 3:50 == 47.3
12/16/15 3:55 == 47.3
12/16/15 4:00 == 47.2
12/16/15 4:05 == 47.3
12/16/15 4:10 == 47.2
12/16/15 4:15 == 47.2
12/16/15 4:20 == 47.3
12/16/15 4:25 == 47.2
12/16/15 4:30 == 47.2
12/16/15 4:35 == 47.3
12/16/15 4:40 == 47.1
12/16/15 4:45 == 47.3
12/16/15 4:50 == 47.3
12/16/15 4:55 == 47.2
12/16/15 5:00 == 47.3
12/16/15 5:05 == 47.2
12/16/15 5:10 == 47.3
12/16/15 5:15 == 47.3
12/16/15 5:20 == 47.2
12/16/15 5:25 == 47.2
12/16/15 5:30 == 47.2
12/16/15 5:35 == 47.2
12/16/15 5:40 == 47.2
12/16/15 5:45 == 47.3
12/16/15 5:50 == 47.2
12/16/15 5:55 == 47.3
12/16/15 6:00 == 47.2
12/16/15 6:05 == 47.4
12/16/15 6:10 == 47.2
12/16/15 6:15 == 47.3
12/16/15 6:20 == 47.4
12/16/15 6:25 == 47.2
12/16/15 6:30 == 47.3
12/16/15 6:35 == 47.2
12/16/15 6:40 == 47.2
12/16/15 6:45 == 47.3
12/16/15 6:50 == 47.3
12/16/15 6:55 == 47.3
12/16/15 7:00 == 47.3
12/16/15 7:05 == 47.2
12/16/15 7:10 == 47.3
12/16/15 7:15 == 47.2
12/16/15 7:20 == 47.3
12/16/15 7:25 == 47.2
12/16/15 7:30 == 47.3
12/16/15 7:35 == 47.3
12/16/15 7:40 == 47.5
12/16/15 7:45 == 47.3
12/16/15 7:50 == 47.4
12/16/15 7:55 == 47.4
12/16/15 8:00 == 47.4
12/16/15 8:05 == 47.4
12/16/15 8:10 == 47.6
12/16/15 8:15 == 47.5
12/16/15 8:20 == 47.6
12/16/15 8:25 == 47.6
12/16/15 8:30 == 47.5
12/16/15 8:35 == 47.6
12/16/15 8:40 == 47.5
12/16/15 8:45 == 47.3
12/16/15 8:50 == 47.3
12/16/15 8:55 == 47.5
12/16/15 9:00 == 47.5
12/16/15 9:05 == 47.3
12/16/15 9:10 == 47.2
12/16/15 9:15 == 47.3
12/16/15 9:20 == 47.3
12/16/15 9:25 == 47.3
12/16/15 9:30 == 47.3
12/16/15 9:35 == 45.9
12/16/15 9:40 == 47
12/16/15 9:45 == 47.2
12/16/15 9:50 == 47.3
12/16/15 9:55 == 47.1
12/16/15 10:00 == 47.2
12/16/15 10:05 == 47.4
12/16/15 10:10 == 47.4
12/16/15 10:15 == 47.4
12/16/15 10:20 == 47.3
12/16/15 10:25 == 47.4
12/16/15 10:30 == 47.1
12/16/15 10:35 == 47.2
12/16/15 10:40 == 46
12/16/15 10:45 == 46.8
12/16/15 10:50 == 47.2
12/16/15 10:55 == 47.2
12/16/15 11:00 == 47.2
12/16/15 11:05 == 47.5
12/16/15 11:10 == 47.4
12/16/15 11:15 == 47.3
12/16/15 11:20 == 47.3
12/16/15 11:25 == 47.3
12/16/15 11:30 == 47.4
12/16/15 11:35 == 47.2
12/16/15 11:40 == 46
12/16/15 11:45 == 46
12/16/15 11:50 == 47.1
12/16/15 11:55 == 47.3
12/16/15 12:00 == 47
12/16/15 12:05 == 47.1
12/16/15 12:10 == 47.2
12/16/15 12:15 == 47.1
12/16/15 12:20 == 47.2
12/16/15 12:25 == 47.1
12/16/15 12:30 == 47.3
12/16/15 12:35 == 47
12/16/15 12:40 == 47
12/16/15 12:45 == 46.8
12/16/15 12:50 == 47
12/16/15 12:55 == 47.2
12/16/15 13:00 == 47
12/16/15 13:05 == 47
12/16/15 13:10 == 47
12/16/15 13:15 == 47
12/16/15 13:20 == 47
12/16/15 13:25 == 46.9
12/16/15 13:30 == 47.1
12/16/15 13:35 == 47
12/16/15 13:40 == 47.1
12/16/15 13:45 == 46.9
12/16/15 13:50 == 47.1
12/16/15 13:55 == 46.8
12/16/15 14:00 == 47.1
12/16/15 14:05 == 47.1
12/16/15 14:10 == 47
12/16/15 14:15 == 47.1
12/16/15 14:20 == 47
12/16/15 14:25 == 46.9
12/16/15 14:30 == 46.9
12/16/15 14:35 == 47.1
12/16/15 14:40 == 46.9
12/16/15 14:45 == 46.8
12/16/15 14:50 == 47
12/16/15 14:55 == 47
12/16/15 15:00 == 47
12/16/15 15:05 == 47
12/16/15 15:10 == 47
12/16/15 15:15 == 47
12/16/15 15:20 == 46.9
12/16/15 15:25 == 46.9
12/16/15 15:30 == 46.8
12/16/15 15:35 == 46.8
12/16/15 15:40 == 46.7
12/16/15 15:45 == 47.1
12/16/15 15:50 == 46.7
12/16/15 15:55 == 47
12/16/15 16:00 == 47.1
12/16/15 16:05 == 47
12/16/15 16:10 == 47
12/16/15 16:15 == 47.1
12/16/15 16:20 == 47
12/16/15 16:25 == 47.1
12/16/15 16:30 == 46.9
12/16/15 16:35 == 47
12/16/15 16:40 == 47.1
12/16/15 16:45 == 46.9
12/16/15 16:50 == 47.1
12/16/15 16:55 == 47
12/16/15 17:00 == 47
12/16/15 17:05 == 47
12/16/15 17:10 == 47
12/16/15 17:15 == 46.9
12/16/15 17:20 == 47
12/16/15 17:25 == 47.1
12/16/15 17:30 == 47.1
12/16/15 17:35 == 47.1
12/16/15 17:40 == 46.9
12/16/15 17:45 == 47
12/16/15 17:50 == 47
12/16/15 17:55 == 47

Pumpback Station Discharge (0364)

12/16/15 18:00 == 46.9
12/16/15 18:05 == 47.2
12/16/15 18:10 == 47.1
12/16/15 18:15 == 47
12/16/15 18:20 == 47
12/16/15 18:25 == 47.1
12/16/15 18:30 == 47
12/16/15 18:35 == 47.1
12/16/15 18:40 == 47.1
12/16/15 18:45 == 47.1
12/16/15 18:50 == 47.1
12/16/15 18:55 == 47
12/16/15 19:00 == 46.8
12/16/15 19:05 == 47
12/16/15 19:10 == 46.9
12/16/15 19:15 == 47
12/16/15 19:20 == 46.9
12/16/15 19:25 == 47
12/16/15 19:30 == 46.9
12/16/15 19:35 == 47
12/16/15 19:40 == 47
12/16/15 19:45 == 47
12/16/15 19:50 == 47
12/16/15 19:55 == 46.9
12/16/15 20:00 == 46.9
12/16/15 20:05 == 47
12/16/15 20:10 == 46.9
12/16/15 20:15 == 47
12/16/15 20:20 == 46.9
12/16/15 20:25 == 47
12/16/15 20:30 == 47
12/16/15 20:35 == 46.9
12/16/15 20:40 == 47
12/16/15 20:45 == 47
12/16/15 20:50 == 47
12/16/15 20:55 == 47
12/16/15 21:00 == 47
12/16/15 21:05 == 47
12/16/15 21:10 == 47.1
12/16/15 21:15 == 47
12/16/15 21:20 == 47.2
12/16/15 21:25 == 47.1
12/16/15 21:30 == 47.1
12/16/15 21:35 == 47
12/16/15 21:40 == 47
12/16/15 21:45 == 47.1
12/16/15 21:50 == 47
12/16/15 21:55 == 46.9
12/16/15 22:00 == 46.9
12/16/15 22:05 == 47
12/16/15 22:10 == 46.9
12/16/15 22:15 == 47
12/16/15 22:20 == 47.1
12/16/15 22:25 == 47
12/16/15 22:30 == 46.9
12/16/15 22:35 == 47
12/16/15 22:40 == 46.9
12/16/15 22:45 == 47
12/16/15 22:50 == 47
12/16/15 22:55 == 47.1
12/16/15 23:00 == 46.9
12/16/15 23:05 == 46.9
12/16/15 23:10 == 46.9
12/16/15 23:15 == 46.9
12/16/15 23:20 == 46.9
12/16/15 23:25 == 46.9
12/16/15 23:30 == 47
12/16/15 23:35 == 47
12/16/15 23:40 == 46.9
12/16/15 23:45 == 47
12/16/15 23:50 == 46.9
12/16/15 23:55 == 46.9
12/17/15 0:00 == 46.9
12/17/15 0:05 == 46.9
12/17/15 0:10 == 46.8
12/17/15 0:15 == 46.9
12/17/15 0:20 == 47
12/17/15 0:25 == 47
12/17/15 0:30 == 47
12/17/15 0:35 == 46.9
12/17/15 0:40 == 47.2
12/17/15 0:45 == 47
12/17/15 0:50 == 47
12/17/15 0:55 == 47
12/17/15 1:00 == 46.9
12/17/15 1:05 == 46.9
12/17/15 1:10 == 47
12/17/15 1:15 == 47
12/17/15 1:20 == 46.9
12/17/15 1:25 == 46.8
12/17/15 1:30 == 47
12/17/15 1:35 == 46.9
12/17/15 1:40 == 46.9
12/17/15 1:45 == 47.1
12/17/15 1:50 == 46.9
12/17/15 1:55 == 47
12/17/15 2:00 == 47
12/17/15 2:05 == 46.9
12/17/15 2:10 == 46.9
12/17/15 2:15 == 46.9
12/17/15 2:20 == 47
12/17/15 2:25 == 47.1
12/17/15 2:30 == 46.9
12/17/15 2:35 == 46.9
12/17/15 2:40 == 47
12/17/15 2:45 == 47
12/17/15 2:50 == 47
12/17/15 2:55 == 47
12/17/15 3:00 == 47.1
12/17/15 3:05 == 47
12/17/15 3:10 == 47
12/17/15 3:15 == 47
12/17/15 3:20 == 47
12/17/15 3:25 == 47
12/17/15 3:30 == 47
12/17/15 3:35 == 47
12/17/15 3:40 == 46.9
12/17/15 3:45 == 47
12/17/15 3:50 == 47
12/17/15 3:55 == 47
12/17/15 4:00 == 47
12/17/15 4:05 == 46.9
12/17/15 4:10 == 46.9
12/17/15 4:15 == 47.1
12/17/15 4:20 == 46.9
12/17/15 4:25 == 47
12/17/15 4:30 == 47.1
12/17/15 4:35 == 46.9
12/17/15 4:40 == 47
12/17/15 4:45 == 47
12/17/15 4:50 == 47
12/17/15 4:55 == 46.8
12/17/15 5:00 == 47.1
12/17/15 5:05 == 46.9
12/17/15 5:10 == 47
12/17/15 5:15 == 46.9
12/17/15 5:20 == 46.9
12/17/15 5:25 == 47
12/17/15 5:30 == 47
12/17/15 5:35 == 46.9
12/17/15 5:40 == 47
12/17/15 5:45 == 46.9
12/17/15 5:50 == 47
12/17/15 5:55 == 47
12/17/15 6:00 == 46.9
12/17/15 6:05 == 47
12/17/15 6:10 == 46.9
12/17/15 6:15 == 47
12/17/15 6:20 == 46.9
12/17/15 6:25 == 46.9
12/17/15 6:30 == 47
12/17/15 6:35 == 46.9
12/17/15 6:40 == 46.8
12/17/15 6:45 == 47
12/17/15 6:50 == 46.9
12/17/15 6:55 == 46.9
12/17/15 7:00 == 47
12/17/15 7:05 == 46.9
12/17/15 7:10 == 47
12/17/15 7:15 == 46.9
12/17/15 7:20 == 47
12/17/15 7:25 == 46.9
12/17/15 7:30 == 47.1
12/17/15 7:35 == 46.9
12/17/15 7:40 == 47
12/17/15 7:45 == 47
12/17/15 7:50 == 47
12/17/15 7:55 == 47
12/17/15 8:00 == 47
12/17/15 8:05 == 47
12/17/15 8:10 == 46.9
12/17/15 8:15 == 47.1
12/17/15 8:20 == 47
12/17/15 8:25 == 47
12/17/15 8:30 == 47.1
12/17/15 8:35 == 47
12/17/15 8:40 == 47.1
12/17/15 8:45 == 47.1
12/17/15 8:50 == 46.9
12/17/15 8:55 == 47.1
12/17/15 9:00 == 46.9
12/17/15 9:05 == 46.9
12/17/15 9:10 == 46.9
12/17/15 9:15 == 47
12/17/15 9:20 == 47
12/17/15 9:25 == 46.9
12/17/15 9:30 == 47
12/17/15 9:35 == 46.9
12/17/15 9:40 == 46.8
12/17/15 9:45 == 46.9
12/17/15 9:50 == 46.9
12/17/15 9:55 == 46.9
12/17/15 10:00 == 47
12/17/15 10:05 == 46.9
12/17/15 10:10 == 47
12/17/15 10:15 == 46.8
12/17/15 10:20 == 46.8
12/17/15 10:25 == 46.9
12/17/15 10:30 == 46.8
12/17/15 10:35 == 47.1
12/17/15 10:40 == 46.9
12/17/15 10:45 == 46.9
12/17/15 10:50 == 46.8
12/17/15 10:55 == 47
12/17/15 11:00 == 46.7
12/17/15 11:05 == 47
12/17/15 11:10 == 46.9
12/17/15 11:15 == 47
12/17/15 11:20 == 46.7
12/17/15 11:25 == 46.9
12/17/15 11:30 == 46.9
12/17/15 11:35 == 46.9
12/17/15 11:40 == 46.8
12/17/15 11:45 == 46.7
12/17/15 11:50 == 47
12/17/15 11:55 == 46.8

Pumpback Station Discharge (0364)

12/17/15 12:00 == 46.9
12/17/15 12:05 == 46.9
12/17/15 12:10 == 46.9
12/17/15 12:15 == 46.9
12/17/15 12:20 == 47
12/17/15 12:25 == 46.8
12/17/15 12:30 == 46.9
12/17/15 12:35 == 46.7
12/17/15 12:40 == 46.9
12/17/15 12:45 == 47
12/17/15 12:50 == 46.9
12/17/15 12:55 == 46.9
12/17/15 13:00 == 46.9
12/17/15 13:05 == 46.9
12/17/15 13:10 == 46.8
12/17/15 13:15 == 46.8
12/17/15 13:20 == 46.9
12/17/15 13:25 == 46.7
12/17/15 13:30 == 46.9
12/17/15 13:35 == 47
12/17/15 13:40 == 46.9
12/17/15 13:45 == 46.7
12/17/15 13:50 == 46.9
12/17/15 13:55 == 46.9
12/17/15 14:00 == 46.8
12/17/15 14:05 == 46.9
12/17/15 14:10 == 47.1
12/17/15 14:15 == 46.8
12/17/15 14:20 == 47.1
12/17/15 14:25 == 46.7
12/17/15 14:30 == 47
12/17/15 14:35 == 46.8
12/17/15 14:40 == 46.8
12/17/15 14:45 == 46.8
12/17/15 14:50 == 46.8
12/17/15 14:55 == 46.9
12/17/15 15:00 == 46.8
12/17/15 15:05 == 47
12/17/15 15:10 == 46.8
12/17/15 15:15 == 46.7
12/17/15 15:20 == 46.9
12/17/15 15:25 == 46.9
12/17/15 15:30 == 46.7
12/17/15 15:35 == 46.9
12/17/15 15:40 == 46.7
12/17/15 15:45 == 46.8
12/17/15 15:50 == 46.6
12/17/15 15:55 == 46.8
12/17/15 16:00 == 46.8
12/17/15 16:05 == 46.8
12/17/15 16:10 == 46.8
12/17/15 16:15 == 46.8
12/17/15 16:20 == 46.8
12/17/15 16:25 == 46.6
12/17/15 16:30 == 46.9
12/17/15 16:35 == 46.8
12/17/15 16:40 == 46.7
12/17/15 16:45 == 47
12/17/15 16:50 == 46.8
12/17/15 16:55 == 46.9
12/17/15 17:00 == 46.9
12/17/15 17:05 == 46.7
12/17/15 17:10 == 46.9
12/17/15 17:15 == 47.1
12/17/15 17:20 == 46.8
12/17/15 17:25 == 46.8
12/17/15 17:30 == 47
12/17/15 17:35 == 46.8
12/17/15 17:40 == 46.8
12/17/15 17:45 == 46.9
12/17/15 17:50 == 46.8
12/17/15 17:55 == 46.9
12/17/15 18:00 == 46.8
12/17/15 18:05 == 46.9
12/17/15 18:10 == 46.9
12/17/15 18:15 == 46.8
12/17/15 18:20 == 46.7
12/17/15 18:25 == 46.9
12/17/15 18:30 == 47
12/17/15 18:35 == 46.9
12/17/15 18:40 == 47
12/17/15 18:45 == 46.9
12/17/15 18:50 == 47
12/17/15 18:55 == 46.9
12/17/15 19:00 == 46.8
12/17/15 19:05 == 46.8
12/17/15 19:10 == 46.9
12/17/15 19:15 == 46.8
12/17/15 19:20 == 46.9
12/17/15 19:25 == 46.8
12/17/15 19:30 == 46.8
12/17/15 19:35 == 46.8
12/17/15 19:40 == 46.8
12/17/15 19:45 == 46.8
12/17/15 19:50 == 46.9
12/17/15 19:55 == 46.8
12/17/15 20:00 == 46.8
12/17/15 20:05 == 46.8
12/17/15 20:10 == 46.8
12/17/15 20:15 == 46.8
12/17/15 20:20 == 46.8
12/17/15 20:25 == 46.8
12/17/15 20:30 == 46.8
12/17/15 20:35 == 46.8
12/17/15 20:40 == 47
12/17/15 20:45 == 46.9
12/17/15 20:50 == 46.9
12/17/15 20:55 == 46.9
12/17/15 21:00 == 46.8
12/17/15 21:05 == 46.8
12/17/15 21:10 == 46.9
12/17/15 21:15 == 46.8
12/17/15 21:20 == 46.9
12/17/15 21:25 == 46.9
12/17/15 21:30 == 47
12/17/15 21:35 == 46.9
12/17/15 21:40 == 46.9
12/17/15 21:45 == 46.9
12/17/15 21:50 == 46.8
12/17/15 21:55 == 46.9
12/17/15 22:00 == 47
12/17/15 22:05 == 46.8
12/17/15 22:10 == 46.9
12/17/15 22:15 == 46.8
12/17/15 22:20 == 46.8
12/17/15 22:25 == 46.8
12/17/15 22:30 == 46.8
12/17/15 22:35 == 46.9
12/17/15 22:40 == 46.9
12/17/15 22:45 == 47
12/17/15 22:50 == 47
12/17/15 22:55 == 46.8
12/17/15 23:00 == 46.9
12/17/15 23:05 == 46.9
12/17/15 23:10 == 46.8
12/17/15 23:15 == 46.8
12/17/15 23:20 == 47
12/17/15 23:25 == 46.9
12/17/15 23:30 == 47
12/17/15 23:35 == 47
12/17/15 23:40 == 47
12/17/15 23:45 == 46.9
12/17/15 23:50 == 47
12/17/15 23:55 == 46.9
12/18/15 0:00 == 47
12/18/15 0:05 == 46.7
12/18/15 0:10 == 46.9
12/18/15 0:15 == 46.9
12/18/15 0:20 == 46.8
12/18/15 0:25 == 46.8
12/18/15 0:30 == 46.8
12/18/15 0:35 == 46.9
12/18/15 0:40 == 46.9
12/18/15 0:45 == 46.9
12/18/15 0:50 == 46.9
12/18/15 0:55 == 46.9
12/18/15 1:00 == 46.9
12/18/15 1:05 == 46.9
12/18/15 1:10 == 46.7
12/18/15 1:15 == 46.8
12/18/15 1:20 == 46.8
12/18/15 1:25 == 46.8
12/18/15 1:30 == 46.9
12/18/15 1:35 == 46.9
12/18/15 1:40 == 46.8
12/18/15 1:45 == 47
12/18/15 1:50 == 46.9
12/18/15 1:55 == 46.8
12/18/15 2:00 == 46.9
12/18/15 2:05 == 46.8
12/18/15 2:10 == 46.9
12/18/15 2:15 == 46.8
12/18/15 2:20 == 46.9
12/18/15 2:25 == 46.9
12/18/15 2:30 == 46.9
12/18/15 2:35 == 46.9
12/18/15 2:40 == 46.9
12/18/15 2:45 == 46.7
12/18/15 2:50 == 46.8
12/18/15 2:55 == 46.7
12/18/15 3:00 == 46.8
12/18/15 3:05 == 46.8
12/18/15 3:10 == 46.8
12/18/15 3:15 == 46.8
12/18/15 3:20 == 46.8
12/18/15 3:25 == 46.8
12/18/15 3:30 == 46.8
12/18/15 3:35 == 47
12/18/15 3:40 == 46.8
12/18/15 3:45 == 46.8
12/18/15 3:50 == 46.8
12/18/15 3:55 == 47
12/18/15 4:00 == 47
12/18/15 4:05 == 47
12/18/15 4:10 == 46.8
12/18/15 4:15 == 46.9
12/18/15 4:20 == 46.9
12/18/15 4:25 == 46.8
12/18/15 4:30 == 46.9
12/18/15 4:35 == 46.9
12/18/15 4:40 == 46.8
12/18/15 4:45 == 46.8
12/18/15 4:50 == 46.9
12/18/15 4:55 == 47
12/18/15 5:00 == 46.9
12/18/15 5:05 == 46.8
12/18/15 5:10 == 46.9
12/18/15 5:15 == 46.8
12/18/15 5:20 == 46.7
12/18/15 5:25 == 46.8
12/18/15 5:30 == 46.7
12/18/15 5:35 == 46.8
12/18/15 5:40 == 46.8
12/18/15 5:45 == 46.8
12/18/15 5:50 == 46.8
12/18/15 5:55 == 46.9

Pumpback Station Discharge (0364)

12/18/15 6:00 == 47
12/18/15 6:05 == 46.8
12/18/15 6:10 == 46.9
12/18/15 6:15 == 47
12/18/15 6:20 == 46.9
12/18/15 6:25 == 46.8
12/18/15 6:30 == 46.8
12/18/15 6:35 == 46.9
12/18/15 6:40 == 46.9
12/18/15 6:45 == 46.8
12/18/15 6:50 == 46.9
12/18/15 6:55 == 46.8
12/18/15 7:00 == 46.9
12/18/15 7:05 == 46.8
12/18/15 7:10 == 46.8
12/18/15 7:15 == 46.9
12/18/15 7:20 == 46.8
12/18/15 7:25 == 46.7
12/18/15 7:30 == 46.9
12/18/15 7:35 == 46.9
12/18/15 7:40 == 46.9
12/18/15 7:45 == 47.3
12/18/15 7:50 == 47.1
12/18/15 7:55 == 47
12/18/15 8:00 == 47
12/18/15 8:05 == 47.1
12/18/15 8:10 == 47
12/18/15 8:15 == 47.1
12/18/15 8:20 == 47.2
12/18/15 8:25 == 47.1
12/18/15 8:30 == 47.1
12/18/15 8:35 == 46.6
12/18/15 8:40 == 46
12/18/15 8:45 == 47.3
12/18/15 8:50 == 47.3
12/18/15 8:55 == 46.1
12/18/15 9:00 == 45.2
12/18/15 9:05 == 46.7
12/18/15 9:10 == 46.8
12/18/15 9:15 == 46.8
12/18/15 9:20 == 46.7
12/18/15 9:25 == 46.8
12/18/15 9:30 == 47.2
12/18/15 9:35 == 47.4
12/18/15 9:40 == 47.3
12/18/15 9:45 == 47.3
12/18/15 9:50 == 47.5
12/18/15 9:55 == 47.3
12/18/15 10:00 == 47.3
12/18/15 10:05 == 47.3
12/18/15 10:10 == 47.4
12/18/15 10:15 == 47.2
12/18/15 10:20 == 47.4
12/18/15 10:25 == 47.2
12/18/15 10:30 == 47.4
12/18/15 10:35 == 47.2
12/18/15 10:40 == 47.3
12/18/15 10:45 == 47.3
12/18/15 10:50 == 47.3
12/18/15 10:55 == 47.5
12/18/15 11:00 == 47.4
12/18/15 11:05 == 47.4
12/18/15 11:10 == 47.5
12/18/15 11:15 == 47.4
12/18/15 11:20 == 47.4
12/18/15 11:25 == 47.3
12/18/15 11:30 == 47.5
12/18/15 11:35 == 47.4
12/18/15 11:40 == 47.2
12/18/15 11:45 == 47.3
12/18/15 11:50 == 47.3
12/18/15 11:55 == 47.5
12/18/15 12:00 == 47.3
12/18/15 12:05 == 47.3
12/18/15 12:10 == 47.4
12/18/15 12:15 == 47.3
12/18/15 12:20 == 47.5
12/18/15 12:25 == 47.7
12/18/15 12:30 == 47.5
12/18/15 12:35 == 47.5
12/18/15 12:40 == 47.5
12/18/15 12:45 == 47.5
12/18/15 12:50 == 47.6
12/18/15 12:55 == 47.5
12/18/15 13:00 == 47.5
12/18/15 13:05 == 47.3
12/18/15 13:10 == 47.4
12/18/15 13:15 == 47.3
12/18/15 13:20 == 47.3
12/18/15 13:25 == 47.4
12/18/15 13:30 == 47.4
12/18/15 13:35 == 47.4
12/18/15 13:40 == 47.3
12/18/15 13:45 == 47.3
12/18/15 13:50 == 47.5
12/18/15 13:55 == 47.4
12/18/15 14:00 == 47.5
12/18/15 14:05 == 47.5
12/18/15 14:10 == 47.5
12/18/15 14:15 == 47.4
12/18/15 14:20 == 47.5
12/18/15 14:25 == 47.4
12/18/15 14:30 == 47.4
12/18/15 14:35 == 47.4
12/18/15 14:40 == 47.2
12/18/15 14:45 == 47.4
12/18/15 14:50 == 47.3
12/18/15 14:55 == 47.3
12/18/15 15:00 == 47.3
12/18/15 15:05 == 47.4
12/18/15 15:10 == 47.3
12/18/15 15:15 == 47.3
12/18/15 15:20 == 47.2
12/18/15 15:25 == 47.3
12/18/15 15:30 == 47.3
12/18/15 15:35 == 47.3
12/18/15 15:40 == 47.3
12/18/15 15:45 == 47.3
12/18/15 15:50 == 47.3
12/18/15 15:55 == 47.2
12/18/15 16:00 == 47.4
12/18/15 16:05 == 47.4
12/18/15 16:10 == 47.3
12/18/15 16:15 == 47.3
12/18/15 16:20 == 47.2
12/18/15 16:25 == 47.4
12/18/15 16:30 == 47.4
12/18/15 16:35 == 47.2
12/18/15 16:40 == 47.2
12/18/15 16:45 == 47.1
12/18/15 16:50 == 47.2
12/18/15 16:55 == 47.4
12/18/15 17:00 == 47.3
12/18/15 17:05 == 47.3
12/18/15 17:10 == 47.3
12/18/15 17:15 == 47.3
12/18/15 17:20 == 47.3
12/18/15 17:25 == 47.3
12/18/15 17:30 == 47.3
12/18/15 17:35 == 47.4
12/18/15 17:40 == 47.5
12/18/15 17:45 == 47.2
12/18/15 17:50 == 47.4
12/18/15 17:55 == 47.3
12/18/15 18:00 == 47.4
12/18/15 18:05 == 47
12/18/15 18:10 == 45.6
12/18/15 18:15 == 47.3
12/18/15 18:20 == 47.2
12/18/15 18:25 == 47.3
12/18/15 18:30 == 47.2
12/18/15 18:35 == 47.3
12/18/15 18:40 == 47.4
12/18/15 18:45 == 47.4
12/18/15 18:50 == 47.5
12/18/15 18:55 == 47.3
12/18/15 19:00 == 47.2
12/18/15 19:05 == 47.2
12/18/15 19:10 == 47.2
12/18/15 19:15 == 47.4
12/18/15 19:20 == 47.3
12/18/15 19:25 == 47.3
12/18/15 19:30 == 47.4
12/18/15 19:35 == 47.5
12/18/15 19:40 == 47.2
12/18/15 19:45 == 47.4
12/18/15 19:50 == 47.2
12/18/15 19:55 == 47.3
12/18/15 20:00 == 47.4
12/18/15 20:05 == 47.2
12/18/15 20:10 == 47.4
12/18/15 20:15 == 47.3
12/18/15 20:20 == 47.3
12/18/15 20:25 == 47.4
12/18/15 20:30 == 47.3
12/18/15 20:35 == 47.3
12/18/15 20:40 == 47.3
12/18/15 20:45 == 47.3
12/18/15 20:50 == 47.3
12/18/15 20:55 == 47.3
12/18/15 21:00 == 47.2
12/18/15 21:05 == 47.5
12/18/15 21:10 == 47.3
12/18/15 21:15 == 47.2
12/18/15 21:20 == 47.3
12/18/15 21:25 == 47.2
12/18/15 21:30 == 47.2
12/18/15 21:35 == 47.4
12/18/15 21:40 == 47.4
12/18/15 21:45 == 47.3
12/18/15 21:50 == 47.3
12/18/15 21:55 == 47.2
12/18/15 22:00 == 47.4
12/18/15 22:05 == 47.3
12/18/15 22:10 == 47.4
12/18/15 22:15 == 47.2
12/18/15 22:20 == 47.2
12/18/15 22:25 == 47.3
12/18/15 22:30 == 47.3
12/18/15 22:35 == 47.3
12/18/15 22:40 == 47.2
12/18/15 22:45 == 47.4
12/18/15 22:50 == 47.4
12/18/15 22:55 == 47.1
12/18/15 23:00 == 47.3
12/18/15 23:05 == 47.2
12/18/15 23:10 == 47.3
12/18/15 23:15 == 47.1
12/18/15 23:20 == 47.3
12/18/15 23:25 == 47.4
12/18/15 23:30 == 47.4
12/18/15 23:35 == 47.3
12/18/15 23:40 == 47.3
12/18/15 23:45 == 47.4
12/18/15 23:50 == 47.4
12/18/15 23:55 == 47.4

Pumpback Station Discharge (0364)

12/19/15 0:00 == 47.4
12/19/15 0:05 == 47.5
12/19/15 0:10 == 47.3
12/19/15 0:15 == 47.3
12/19/15 0:20 == 47.3
12/19/15 0:25 == 47.3
12/19/15 0:30 == 47.2
12/19/15 0:35 == 47.3
12/19/15 0:40 == 47.1
12/19/15 0:45 == 47.3
12/19/15 0:50 == 47.3
12/19/15 0:55 == 47.2
12/19/15 1:00 == 47.4
12/19/15 1:05 == 47.4
12/19/15 1:10 == 47.2
12/19/15 1:15 == 47.4
12/19/15 1:20 == 47.3
12/19/15 1:25 == 47.2
12/19/15 1:30 == 47.3
12/19/15 1:35 == 47.3
12/19/15 1:40 == 47.3
12/19/15 1:45 == 47.3
12/19/15 1:50 == 47.4
12/19/15 1:55 == 47.3
12/19/15 2:00 == 47.4
12/19/15 2:05 == 47.3
12/19/15 2:10 == 47.3
12/19/15 2:15 == 47.2
12/19/15 2:20 == 47.2
12/19/15 2:25 == 47.2
12/19/15 2:30 == 47.2
12/19/15 2:35 == 47.2
12/19/15 2:40 == 47.3
12/19/15 2:45 == 47.3
12/19/15 2:50 == 47.1
12/19/15 2:55 == 47.2
12/19/15 3:00 == 47.3
12/19/15 3:05 == 47.2
12/19/15 3:10 == 47.1
12/19/15 3:15 == 47.3
12/19/15 3:20 == 47.3
12/19/15 3:25 == 47.2
12/19/15 3:30 == 47.3
12/19/15 3:35 == 47.2
12/19/15 3:40 == 47.2
12/19/15 3:45 == 47.2
12/19/15 3:50 == 47.3
12/19/15 3:55 == 47.3
12/19/15 4:00 == 47.3
12/19/15 4:05 == 47.3
12/19/15 4:10 == 47.2
12/19/15 4:15 == 47.2
12/19/15 4:20 == 47.2
12/19/15 4:25 == 47.2
12/19/15 4:30 == 47.3
12/19/15 4:35 == 47.2
12/19/15 4:40 == 47.3
12/19/15 4:45 == 47.3
12/19/15 4:50 == 47.4
12/19/15 4:55 == 47.3
12/19/15 5:00 == 47.3
12/19/15 5:05 == 47.3
12/19/15 5:10 == 47.2
12/19/15 5:15 == 47.4
12/19/15 5:20 == 47.3
12/19/15 5:25 == 47.3
12/19/15 5:30 == 47.3
12/19/15 5:35 == 47.3
12/19/15 5:40 == 47.2
12/19/15 5:45 == 47.2
12/19/15 5:50 == 47.3
12/19/15 5:55 == 47.3
12/19/15 6:00 == 47.3
12/19/15 6:05 == 47.3
12/19/15 6:10 == 47.2
12/19/15 6:15 == 47.3
12/19/15 6:20 == 47.2
12/19/15 6:25 == 47.3
12/19/15 6:30 == 47.2
12/19/15 6:35 == 47.3
12/19/15 6:40 == 47.3
12/19/15 6:45 == 47.2
12/19/15 6:50 == 47.2
12/19/15 6:55 == 47.3
12/19/15 7:00 == 47.3
12/19/15 7:05 == 47.3
12/19/15 7:10 == 47.3
12/19/15 7:15 == 47.2
12/19/15 7:20 == 47.2
12/19/15 7:25 == 47.2
12/19/15 7:30 == 47.4
12/19/15 7:35 == 47.2
12/19/15 7:40 == 47.3
12/19/15 7:45 == 47.3
12/19/15 7:50 == 47.3
12/19/15 7:55 == 47.4
12/19/15 8:00 == 47.3
12/19/15 8:05 == 47.3
12/19/15 8:10 == 47.3
12/19/15 8:15 == 47.4
12/19/15 8:20 == 47.4
12/19/15 8:25 == 47.5
12/19/15 8:30 == 47.4
12/19/15 8:35 == 47.5
12/19/15 8:40 == 47.4
12/19/15 8:45 == 47.3
12/19/15 8:50 == 47.3
12/19/15 8:55 == 47.4
12/19/15 9:00 == 47.4
12/19/15 9:05 == 47.4
12/19/15 9:10 == 47.3
12/19/15 9:15 == 47.4
12/19/15 9:20 == 47.5
12/19/15 9:25 == 47.4
12/19/15 9:30 == 47.6
12/19/15 9:35 == 47.5
12/19/15 9:40 == 47.4
12/19/15 9:45 == 47.5
12/19/15 9:50 == 47.4
12/19/15 9:55 == 47.4
12/19/15 10:00 == 47.4
12/19/15 10:05 == 47.4
12/19/15 10:10 == 47.4
12/19/15 10:15 == 47.4
12/19/15 10:20 == 47.3
12/19/15 10:25 == 47.4
12/19/15 10:30 == 47.3
12/19/15 10:35 == 47.5
12/19/15 10:40 == 47.1
12/19/15 10:45 == 47.3
12/19/15 10:50 == 47.5
12/19/15 10:55 == 47.1
12/19/15 11:00 == 47.3
12/19/15 11:05 == 47.5
12/19/15 11:10 == 47.4
12/19/15 11:15 == 47.2
12/19/15 11:20 == 47.4
12/19/15 11:25 == 47.4
12/19/15 11:30 == 47.3
12/19/15 11:35 == 47.4
12/19/15 11:40 == 47.2
12/19/15 11:45 == 47.4
12/19/15 11:50 == 47.6
12/19/15 11:55 == 47.2
12/19/15 12:00 == 47.3
12/19/15 12:05 == 47.4
12/19/15 12:10 == 47.2
12/19/15 12:15 == 47.3
12/19/15 12:20 == 47.6
12/19/15 12:25 == 47.3
12/19/15 12:30 == 47.3
12/19/15 12:35 == 47.3
12/19/15 12:40 == 47.4
12/19/15 12:45 == 47.4
12/19/15 12:50 == 47.3
12/19/15 12:55 == 47.3
12/19/15 13:00 == 47.3
12/19/15 13:05 == 47.4
12/19/15 13:10 == 47.3
12/19/15 13:15 == 47.4
12/19/15 13:20 == 47.2
12/19/15 13:25 == 47.3
12/19/15 13:30 == 47.4
12/19/15 13:35 == 47.4
12/19/15 13:40 == 47.3
12/19/15 13:45 == 47.2
12/19/15 13:50 == 47.5
12/19/15 13:55 == 47.3
12/19/15 14:00 == 47.4
12/19/15 14:05 == 47.4
12/19/15 14:10 == 47.4
12/19/15 14:15 == 47.2
12/19/15 14:20 == 47.4
12/19/15 14:25 == 47.3
12/19/15 14:30 == 47.1
12/19/15 14:35 == 47.2
12/19/15 14:40 == 47.2
12/19/15 14:45 == 47.3
12/19/15 14:50 == 47.2
12/19/15 14:55 == 47.1
12/19/15 15:00 == 47.2
12/19/15 15:05 == 47.2
12/19/15 15:10 == 47.2
12/19/15 15:15 == 47.2
12/19/15 15:20 == 47.4
12/19/15 15:25 == 47.2
12/19/15 15:30 == 47.2
12/19/15 15:35 == 47.4
12/19/15 15:40 == 47.2
12/19/15 15:45 == 47.3
12/19/15 15:50 == 47.4
12/19/15 15:55 == 47.2
12/19/15 16:00 == 47.3
12/19/15 16:05 == 47.3
12/19/15 16:10 == 47.4
12/19/15 16:15 == 47.4
12/19/15 16:20 == 47.3
12/19/15 16:25 == 47.3
12/19/15 16:30 == 47.2
12/19/15 16:35 == 47.4
12/19/15 16:40 == 47.2
12/19/15 16:45 == 47.2
12/19/15 16:50 == 47.2
12/19/15 16:55 == 47.3
12/19/15 17:00 == 47.3
12/19/15 17:05 == 47.3
12/19/15 17:10 == 47.2
12/19/15 17:15 == 47.3
12/19/15 17:20 == 47.4
12/19/15 17:25 == 47.2
12/19/15 17:30 == 47.2
12/19/15 17:35 == 47.2
12/19/15 17:40 == 47.3
12/19/15 17:45 == 47.4
12/19/15 17:50 == 47.2
12/19/15 17:55 == 47.2

Pumpback Station Discharge (0364)

12/19/15 18:00 == 47.2
12/19/15 18:05 == 47.4
12/19/15 18:10 == 47.4
12/19/15 18:15 == 47.3
12/19/15 18:20 == 47.3
12/19/15 18:25 == 47.3
12/19/15 18:30 == 47.4
12/19/15 18:35 == 47.3
12/19/15 18:40 == 47.3
12/19/15 18:45 == 47.3
12/19/15 18:50 == 47.4
12/19/15 18:55 == 47.3
12/19/15 19:00 == 47.3
12/19/15 19:05 == 47.3
12/19/15 19:10 == 47.3
12/19/15 19:15 == 47.2
12/19/15 19:20 == 47.3
12/19/15 19:25 == 47.1
12/19/15 19:30 == 47.3
12/19/15 19:35 == 47.3
12/19/15 19:40 == 47.3
12/19/15 19:45 == 47.2
12/19/15 19:50 == 47.3
12/19/15 19:55 == 47.4
12/19/15 20:00 == 47.3
12/19/15 20:05 == 47.3
12/19/15 20:10 == 47.2
12/19/15 20:15 == 47.2
12/19/15 20:20 == 47.3
12/19/15 20:25 == 47.3
12/19/15 20:30 == 47.3
12/19/15 20:35 == 47.3
12/19/15 20:40 == 47.3
12/19/15 20:45 == 47.3
12/19/15 20:50 == 47.3
12/19/15 20:55 == 47.3
12/19/15 21:00 == 47.3
12/19/15 21:05 == 47.4
12/19/15 21:10 == 47.3
12/19/15 21:15 == 47.4
12/19/15 21:20 == 47.4
12/19/15 21:25 == 47.2
12/19/15 21:30 == 47.3
12/19/15 21:35 == 47.3
12/19/15 21:40 == 47.3
12/19/15 21:45 == 47.3
12/19/15 21:50 == 47.3
12/19/15 21:55 == 47.4
12/19/15 22:00 == 47.4
12/19/15 22:05 == 47.4
12/19/15 22:10 == 47.3
12/19/15 22:15 == 47.3
12/19/15 22:20 == 47.3
12/19/15 22:25 == 47.2
12/19/15 22:30 == 47.3
12/19/15 22:35 == 47.4
12/19/15 22:40 == 47.4
12/19/15 22:45 == 47.4
12/19/15 22:50 == 47.4
12/19/15 22:55 == 47.3
12/19/15 23:00 == 47.3
12/19/15 23:05 == 47.4
12/19/15 23:10 == 47.3
12/19/15 23:15 == 47.2
12/19/15 23:20 == 47.3
12/19/15 23:25 == 47.4
12/19/15 23:30 == 47.3
12/19/15 23:35 == 47.4
12/19/15 23:40 == 47.3
12/19/15 23:45 == 47.3
12/19/15 23:50 == 47.3
12/19/15 23:55 == 47.3
12/20/15 0:00 == 47.3
12/20/15 0:05 == 47.3
12/20/15 0:10 == 47.3
12/20/15 0:15 == 47.2
12/20/15 0:20 == 47.2
12/20/15 0:25 == 47.3
12/20/15 0:30 == 47.3
12/20/15 0:35 == 47.5
12/20/15 0:40 == 47.4
12/20/15 0:45 == 47.4
12/20/15 0:50 == 47.4
12/20/15 0:55 == 47.3
12/20/15 1:00 == 47.3
12/20/15 1:05 == 47.3
12/20/15 1:10 == 47.3
12/20/15 1:15 == 47.3
12/20/15 1:20 == 47.2
12/20/15 1:25 == 47.3
12/20/15 1:30 == 47.3
12/20/15 1:35 == 47.5
12/20/15 1:40 == 47.3
12/20/15 1:45 == 47.4
12/20/15 1:50 == 47.5
12/20/15 1:55 == 47.2
12/20/15 2:00 == 47.3
12/20/15 2:05 == 47.2
12/20/15 2:10 == 47.3
12/20/15 2:15 == 47.4
12/20/15 2:20 == 47.3
12/20/15 2:25 == #
12/20/15 2:30 == 47.3
12/20/15 2:35 == 47.2
12/20/15 2:40 == 47.2
12/20/15 2:45 == 47.3
12/20/15 2:50 == 47.4
12/20/15 2:55 == 47.4
12/20/15 3:00 == 47.3
12/20/15 3:05 == 47.2
12/20/15 3:10 == 47.4
12/20/15 3:15 == 47.3
12/20/15 3:20 == 47.4
12/20/15 3:25 == 47.3
12/20/15 3:30 == 47.4
12/20/15 3:35 == 47.3
12/20/15 3:40 == 47.5
12/20/15 3:45 == 47.3
12/20/15 3:50 == 47.4
12/20/15 3:55 == 47.3
12/20/15 4:00 == 47.3
12/20/15 4:05 == 47.4
12/20/15 4:10 == 47.5
12/20/15 4:15 == 47.3
12/20/15 4:20 == 47.4
12/20/15 4:25 == 47.3
12/20/15 4:30 == 47.3
12/20/15 4:35 == 47.3
12/20/15 4:40 == 47.3
12/20/15 4:45 == 47.2
12/20/15 4:50 == 47.3
12/20/15 4:55 == 47.2
12/20/15 5:00 == 47.3
12/20/15 5:05 == 47.2
12/20/15 5:10 == 47.2
12/20/15 5:15 == 47.2
12/20/15 5:20 == 47.3
12/20/15 5:25 == 47.3
12/20/15 5:30 == 47.3
12/20/15 5:35 == 47.2
12/20/15 5:40 == 47.2
12/20/15 5:45 == 47.2
12/20/15 5:50 == 47.3
12/20/15 5:55 == 47.3
12/20/15 6:00 == 47.4
12/20/15 6:05 == 47.2
12/20/15 6:10 == 47.3
12/20/15 6:15 == 47.3
12/20/15 6:20 == 47.3
12/20/15 6:25 == 47.3
12/20/15 6:30 == 47.3
12/20/15 6:35 == 47.3
12/20/15 6:40 == 47.4
12/20/15 6:45 == 47.3
12/20/15 6:50 == 47.2
12/20/15 6:55 == 47.3
12/20/15 7:00 == 47.3
12/20/15 7:05 == 47.2
12/20/15 7:10 == 47.3
12/20/15 7:15 == 47.3
12/20/15 7:20 == 47.2
12/20/15 7:25 == 47.2
12/20/15 7:30 == 47.3
12/20/15 7:35 == 47.2
12/20/15 7:40 == 47.2
12/20/15 7:45 == 47.1
12/20/15 7:50 == 47.2
12/20/15 7:55 == 47.3
12/20/15 8:00 == 47.2
12/20/15 8:05 == 47.3
12/20/15 8:10 == 47.4
12/20/15 8:15 == 47.5
12/20/15 8:20 == 47.3
12/20/15 8:25 == 47.2
12/20/15 8:30 == 47.3
12/20/15 8:35 == 47.2
12/20/15 8:40 == 47.4
12/20/15 8:45 == 47.2
12/20/15 8:50 == 47.4
12/20/15 8:55 == 47.3
12/20/15 9:00 == 47.3
12/20/15 9:05 == 47.6
12/20/15 9:10 == 47.3
12/20/15 9:15 == 47.2
12/20/15 9:20 == 47.4
12/20/15 9:25 == 47.4
12/20/15 9:30 == 47.3
12/20/15 9:35 == 47.3
12/20/15 9:40 == 47.4
12/20/15 9:45 == 47.4
12/20/15 9:50 == 47.4
12/20/15 9:55 == 47.4
12/20/15 10:00 == 47.4
12/20/15 10:05 == 47.4
12/20/15 10:10 == 47.4
12/20/15 10:15 == 47.4
12/20/15 10:20 == 47.4
12/20/15 10:25 == 47.5
12/20/15 10:30 == 47.3
12/20/15 10:35 == 47.3
12/20/15 10:40 == 47.4
12/20/15 10:45 == 47.5
12/20/15 10:50 == 47.4
12/20/15 10:55 == 47.4
12/20/15 11:00 == 47.3
12/20/15 11:05 == 47.4
12/20/15 11:10 == 47.2
12/20/15 11:15 == 47.4
12/20/15 11:20 == 47.4
12/20/15 11:25 == 47.4
12/20/15 11:30 == 47.5
12/20/15 11:35 == 47.5
12/20/15 11:40 == 47.5
12/20/15 11:45 == 47.5
12/20/15 11:50 == 47.4
12/20/15 11:55 == 47.4

Pumpback Station Discharge (0364)

12/20/15 12:00 == 47.3
12/20/15 12:05 == 47.1
12/20/15 12:10 == 47.3
12/20/15 12:15 == 47.5
12/20/15 12:20 == 47.3
12/20/15 12:25 == 47.4
12/20/15 12:30 == 47.3
12/20/15 12:35 == 47.3
12/20/15 12:40 == 47.3
12/20/15 12:45 == 47.5
12/20/15 12:50 == 47.3
12/20/15 12:55 == 47.3
12/20/15 13:00 == 47.3
12/20/15 13:05 == 47.4
12/20/15 13:10 == 47.2
12/20/15 13:15 == 47.3
12/20/15 13:20 == 47.2
12/20/15 13:25 == 47.3
12/20/15 13:30 == 47.3
12/20/15 13:35 == 47.3
12/20/15 13:40 == 47.4
12/20/15 13:45 == 47.4
12/20/15 13:50 == 47.3
12/20/15 13:55 == 47.4
12/20/15 14:00 == 47.4
12/20/15 14:05 == 47.4
12/20/15 14:10 == 47.5
12/20/15 14:15 == 47.3
12/20/15 14:20 == 47.3
12/20/15 14:25 == 47.3
12/20/15 14:30 == 47.3
12/20/15 14:35 == 47.4
12/20/15 14:40 == 47.3
12/20/15 14:45 == 47.3
12/20/15 14:50 == 47.2
12/20/15 14:55 == 47.3
12/20/15 15:00 == 47.4
12/20/15 15:05 == 47.4
12/20/15 15:10 == 47.4
12/20/15 15:15 == 47.2
12/20/15 15:20 == 47.2
12/20/15 15:25 == 47.2
12/20/15 15:30 == 47.3
12/20/15 15:35 == 47.2
12/20/15 15:40 == 47.3
12/20/15 15:45 == 47.3
12/20/15 15:50 == 47.3
12/20/15 15:55 == 47.3
12/20/15 16:00 == 47.3
12/20/15 16:05 == 47.3
12/20/15 16:10 == 47.2
12/20/15 16:15 == 47.4
12/20/15 16:20 == 47.3
12/20/15 16:25 == 47.3
12/20/15 16:30 == 47.3
12/20/15 16:35 == 47.3
12/20/15 16:40 == 47.2
12/20/15 16:45 == 47.2
12/20/15 16:50 == 47.4
12/20/15 16:55 == 47.3
12/20/15 17:00 == 47.1
12/20/15 17:05 == 47.3
12/20/15 17:10 == 47.3
12/20/15 17:15 == 47.2
12/20/15 17:20 == 47.4
12/20/15 17:25 == 47.2
12/20/15 17:30 == 47.4
12/20/15 17:35 == 47.3
12/20/15 17:40 == 47.4
12/20/15 17:45 == 47.4
12/20/15 17:50 == 47.4
12/20/15 17:55 == 47.2
12/20/15 18:00 == 47.4
12/20/15 18:05 == 47.4
12/20/15 18:10 == 47.4
12/20/15 18:15 == 47.2
12/20/15 18:20 == 47.4
12/20/15 18:25 == 47.3
12/20/15 18:30 == 47.3
12/20/15 18:35 == 47.2
12/20/15 18:40 == 47.4
12/20/15 18:45 == 47.3
12/20/15 18:50 == 47.2
12/20/15 18:55 == 47.3
12/20/15 19:00 == 47.3
12/20/15 19:05 == 47.4
12/20/15 19:10 == 47.3
12/20/15 19:15 == 47.3
12/20/15 19:20 == 47.3
12/20/15 19:25 == 47.3
12/20/15 19:30 == 47.3
12/20/15 19:35 == 47.4
12/20/15 19:40 == 47.2
12/20/15 19:45 == 47.3
12/20/15 19:50 == 47.3
12/20/15 19:55 == 47.3
12/20/15 20:00 == 47.3
12/20/15 20:05 == 47.3
12/20/15 20:10 == 47.3
12/20/15 20:15 == 47.2
12/20/15 20:20 == 47.4
12/20/15 20:25 == 47.3
12/20/15 20:30 == 47.3
12/20/15 20:35 == 47.4
12/20/15 20:40 == 47.5
12/20/15 20:45 == 47.2
12/20/15 20:50 == 47.3
12/20/15 20:55 == 47.4
12/20/15 21:00 == 47.5
12/20/15 21:05 == 47.4
12/20/15 21:10 == 47.5
12/20/15 21:15 == 47.3
12/20/15 21:20 == 47.3
12/20/15 21:25 == 47.3
12/20/15 21:30 == 47.2
12/20/15 21:35 == 47.3
12/20/15 21:40 == 47.4
12/20/15 21:45 == 47.3
12/20/15 21:50 == 47.4
12/20/15 21:55 == 47.3
12/20/15 22:00 == 47.3
12/20/15 22:05 == 47.3
12/20/15 22:10 == 47.3
12/20/15 22:15 == 47.3
12/20/15 22:20 == 47.3
12/20/15 22:25 == 47.2
12/20/15 22:30 == 47.4
12/20/15 22:35 == 47.2
12/20/15 22:40 == 47.3
12/20/15 22:45 == 47.3
12/20/15 22:50 == 47.3
12/20/15 22:55 == 47.3
12/20/15 23:00 == 47.3
12/20/15 23:05 == 47.3
12/20/15 23:10 == 47.4
12/20/15 23:15 == 47.3
12/20/15 23:20 == 47.3
12/20/15 23:25 == 47.3
12/20/15 23:30 == 47.3
12/20/15 23:35 == 47.5
12/20/15 23:40 == 47.3
12/20/15 23:45 == 47.4
12/20/15 23:50 == 47.4
12/20/15 23:55 == 47.4
12/21/15 0:00 == 47.3
12/21/15 0:05 == 47.3
12/21/15 0:10 == 47.2
12/21/15 0:15 == 47.2
12/21/15 0:20 == 47.4
12/21/15 0:25 == 47.3
12/21/15 0:30 == 47.4
12/21/15 0:35 == 47.2
12/21/15 0:40 == 47.4
12/21/15 0:45 == 47.3
12/21/15 0:50 == 47.4
12/21/15 0:55 == 47.2
12/21/15 1:00 == 47.3
12/21/15 1:05 == 47.3
12/21/15 1:10 == 47.3
12/21/15 1:15 == 47.3
12/21/15 1:20 == 47.2
12/21/15 1:25 == 47.3
12/21/15 1:30 == 47.3
12/21/15 1:35 == 47.3
12/21/15 1:40 == 47.3
12/21/15 1:45 == 47.3
12/21/15 1:50 == 47.3
12/21/15 1:55 == 47.3
12/21/15 2:00 == 47.3
12/21/15 2:05 == 47.3
12/21/15 2:10 == 47.2
12/21/15 2:15 == 47.2
12/21/15 2:20 == 47.3
12/21/15 2:25 == 47.2
12/21/15 2:30 == 47.2
12/21/15 2:35 == 47.3
12/21/15 2:40 == 47.2
12/21/15 2:45 == 47.2
12/21/15 2:50 == 47.1
12/21/15 2:55 == 47.2
12/21/15 3:00 == 47.2
12/21/15 3:05 == 47.2
12/21/15 3:10 == 47.2
12/21/15 3:15 == 47.3
12/21/15 3:20 == 47.3
12/21/15 3:25 == 47.2
12/21/15 3:30 == 47.2
12/21/15 3:35 == 47.4
12/21/15 3:40 == 47.4
12/21/15 3:45 == 47.3
12/21/15 3:50 == 47.4
12/21/15 3:55 == 47.3
12/21/15 4:00 == 47.3
12/21/15 4:05 == 47.4
12/21/15 4:10 == 47.2
12/21/15 4:15 == 47.1
12/21/15 4:20 == 47.3
12/21/15 4:25 == 47.3
12/21/15 4:30 == 47.2
12/21/15 4:35 == 47.3
12/21/15 4:40 == 47.1
12/21/15 4:45 == 47.2
12/21/15 4:50 == 47.1
12/21/15 4:55 == 47.2
12/21/15 5:00 == 47.2
12/21/15 5:05 == 47.3
12/21/15 5:10 == 47.3
12/21/15 5:15 == 47.3
12/21/15 5:20 == 47.1
12/21/15 5:25 == 47.2
12/21/15 5:30 == 47.2
12/21/15 5:35 == 47.2
12/21/15 5:40 == 47.2
12/21/15 5:45 == 47.1
12/21/15 5:50 == 47.2
12/21/15 5:55 == 47.1

Pumpback Station Discharge (0364)

12/21/15 6:00 == 47.3
12/21/15 6:05 == 47.3
12/21/15 6:10 == 47.4
12/21/15 6:15 == 47.2
12/21/15 6:20 == 47.2
12/21/15 6:25 == 47.3
12/21/15 6:30 == 47.2
12/21/15 6:35 == 47.1
12/21/15 6:40 == 47.3
12/21/15 6:45 == 47.3
12/21/15 6:50 == 47.1
12/21/15 6:55 == 47.1
12/21/15 7:00 == 47.2
12/21/15 7:05 == 47.3
12/21/15 7:10 == 47.2
12/21/15 7:15 == 47.2
12/21/15 7:20 == 47.3
12/21/15 7:25 == 47.1
12/21/15 7:30 == 47.2
12/21/15 7:35 == 47.4
12/21/15 7:40 == 47.1
12/21/15 7:45 == 47.2
12/21/15 7:50 == 47.2
12/21/15 7:55 == 47.3
12/21/15 8:00 == 47.1
12/21/15 8:05 == 47.2
12/21/15 8:10 == 47.2
12/21/15 8:15 == 47.3
12/21/15 8:20 == 47.2
12/21/15 8:25 == 47.3
12/21/15 8:30 == 47.3
12/21/15 8:35 == 47.2
12/21/15 8:40 == 47.3
12/21/15 8:45 == 47.1
12/21/15 8:50 == 47.3
12/21/15 8:55 == 47.4
12/21/15 9:00 == 47.3
12/21/15 9:05 == 47.1
12/21/15 9:10 == 47.2
12/21/15 9:15 == 47.2
12/21/15 9:20 == 47.2
12/21/15 9:25 == 47.2
12/21/15 9:30 == 47.2
12/21/15 9:35 == 47.2
12/21/15 9:40 == 47.1
12/21/15 9:45 == 47.2
12/21/15 9:50 == 47.3
12/21/15 9:55 == 47.2
12/21/15 10:00 == 47.1
12/21/15 10:05 == 47.3
12/21/15 10:10 == 47.3
12/21/15 10:15 == 47.1
12/21/15 10:20 == 47.4
12/21/15 10:25 == 47.1
12/21/15 10:30 == 47.3
12/21/15 10:35 == 47
12/21/15 10:40 == 47.2
12/21/15 10:45 == 47.1
12/21/15 10:50 == 47.1
12/21/15 10:55 == 47.1
12/21/15 11:00 == 46.1
12/21/15 11:05 == 46.7
12/21/15 11:10 == 47.7
12/21/15 11:15 == 47.4
12/21/15 11:20 == 47.8
12/21/15 11:25 == 47.6
12/21/15 11:30 == 47.8
12/21/15 11:35 == 47.7
12/21/15 11:40 == 47.9
12/21/15 11:45 == 47.6
12/21/15 11:50 == 47.9
12/21/15 11:55 == 47.8
12/21/15 12:00 == 47.2
12/21/15 12:05 == 47.4
12/21/15 12:10 == 47.4
12/21/15 12:15 == 47.6
12/21/15 12:20 == 47.5
12/21/15 12:25 == 47.6
12/21/15 12:30 == 47.4
12/21/15 12:35 == 47.7
12/21/15 12:40 == 47.7
12/21/15 12:45 == 47.7
12/21/15 12:50 == 47.6
12/21/15 12:55 == 47.6
12/21/15 13:00 == 47.9
12/21/15 13:05 == 47.8
12/21/15 13:10 == 47.9
12/21/15 13:15 == 47.7
12/21/15 13:20 == 47.8
12/21/15 13:25 == 47.8
12/21/15 13:30 == 47.8
12/21/15 13:35 == 47.8
12/21/15 13:40 == 47.9
12/21/15 13:45 == 47.7
12/21/15 13:50 == 47.9
12/21/15 13:55 == 47.8
12/21/15 14:00 == 47.4
12/21/15 14:05 == 46.7
12/21/15 14:10 == 46.9
12/21/15 14:15 == 47.2
12/21/15 14:20 == 47.4
12/21/15 14:25 == 47.4
12/21/15 14:30 == 47.2
12/21/15 14:35 == 47.3
12/21/15 14:40 == 47.2
12/21/15 14:45 == 47.4
12/21/15 14:50 == 47.4
12/21/15 14:55 == 47.5
12/21/15 15:00 == 46.7
12/21/15 15:05 == 47.2
12/21/15 15:10 == 47.1
12/21/15 15:15 == 47.1
12/21/15 15:20 == 47.2
12/21/15 15:25 == 47.1
12/21/15 15:30 == 47.1
12/21/15 15:35 == 47.1
12/21/15 15:40 == 47.1
12/21/15 15:45 == 47.2
12/21/15 15:50 == 47.1
12/21/15 15:55 == 47.1
12/21/15 16:00 == 47.2
12/21/15 16:05 == 47.1
12/21/15 16:10 == 47.2
12/21/15 16:15 == 47.1
12/21/15 16:20 == 47.3
12/21/15 16:25 == 47.1
12/21/15 16:30 == 47.2
12/21/15 16:35 == 47.1
12/21/15 16:40 == 47
12/21/15 16:45 == 47.2
12/21/15 16:50 == 47
12/21/15 16:55 == 47.1
12/21/15 17:00 == 47.2
12/21/15 17:05 == 47.2
12/21/15 17:10 == 47.1
12/21/15 17:15 == 47.1
12/21/15 17:20 == 47.1
12/21/15 17:25 == 47.2
12/21/15 17:30 == 47.1
12/21/15 17:35 == 47.1
12/21/15 17:40 == 47.1
12/21/15 17:45 == 47.2
12/21/15 17:50 == 47.2
12/21/15 17:55 == 47.2
12/21/15 18:00 == 47.1
12/21/15 18:05 == 47.1
12/21/15 18:10 == 47.1
12/21/15 18:15 == 47.1
12/21/15 18:20 == 47.2
12/21/15 18:25 == 47.2
12/21/15 18:30 == 47.2
12/21/15 18:35 == 47.2
12/21/15 18:40 == 47.2
12/21/15 18:45 == 47.2
12/21/15 18:50 == 47.2
12/21/15 18:55 == 47.3
12/21/15 19:00 == 47.2
12/21/15 19:05 == 47.1
12/21/15 19:10 == 47.1
12/21/15 19:15 == 47.1
12/21/15 19:20 == 47.1
12/21/15 19:25 == 47.1
12/21/15 19:30 == 47.3
12/21/15 19:35 == 47.1
12/21/15 19:40 == 47.1
12/21/15 19:45 == 47.1
12/21/15 19:50 == 47.1
12/21/15 19:55 == 47.3
12/21/15 20:00 == 47.1
12/21/15 20:05 == 47.2
12/21/15 20:10 == 47.2
12/21/15 20:15 == 47.1
12/21/15 20:20 == 47.2
12/21/15 20:25 == 47.2
12/21/15 20:30 == 47.2
12/21/15 20:35 == 47.2
12/21/15 20:40 == 47.3
12/21/15 20:45 == 47.2
12/21/15 20:50 == 47.1
12/21/15 20:55 == 47.1
12/21/15 21:00 == 47.1
12/21/15 21:05 == 47
12/21/15 21:10 == 47
12/21/15 21:15 == 47.2
12/21/15 21:20 == 47.1
12/21/15 21:25 == 47.1
12/21/15 21:30 == 47.2
12/21/15 21:35 == 47.2
12/21/15 21:40 == 47.2
12/21/15 21:45 == 47.2
12/21/15 21:50 == 47.1
12/21/15 21:55 == 47.2
12/21/15 22:00 == 47.1
12/21/15 22:05 == 47.1
12/21/15 22:10 == 47.2
12/21/15 22:15 == 47.2
12/21/15 22:20 == 47.2
12/21/15 22:25 == 47.1
12/21/15 22:30 == 47.1
12/21/15 22:35 == 47
12/21/15 22:40 == 47.1
12/21/15 22:45 == 47.2
12/21/15 22:50 == 47.2
12/21/15 22:55 == 47.3
12/21/15 23:00 == 47.2
12/21/15 23:05 == 47.2
12/21/15 23:10 == 47.2
12/21/15 23:15 == 47.2
12/21/15 23:20 == 47.1
12/21/15 23:25 == 47.2
12/21/15 23:30 == 47.2
12/21/15 23:35 == 47.2
12/21/15 23:40 == 47.3
12/21/15 23:45 == 47.2
12/21/15 23:50 == 47.2
12/21/15 23:55 == 47.2

Pumpback Station Discharge (0364)

12/22/15 0:00 == 47.3
12/22/15 0:05 == 47.2
12/22/15 0:10 == 47.1
12/22/15 0:15 == 47
12/22/15 0:20 == 47.2
12/22/15 0:25 == 47.1
12/22/15 0:30 == 47.2
12/22/15 0:35 == 47.1
12/22/15 0:40 == 47.2
12/22/15 0:45 == 47.2
12/22/15 0:50 == 47
12/22/15 0:55 == 47.2
12/22/15 1:00 == 47.2
12/22/15 1:05 == 47.1
12/22/15 1:10 == 47.2
12/22/15 1:15 == 47.1
12/22/15 1:20 == 47.2
12/22/15 1:25 == 47.2
12/22/15 1:30 == 47.3
12/22/15 1:35 == 47.1
12/22/15 1:40 == 47.1
12/22/15 1:45 == 47.1
12/22/15 1:50 == 47.1
12/22/15 1:55 == 47
12/22/15 2:00 == 47.1
12/22/15 2:05 == 47.2
12/22/15 2:10 == 47
12/22/15 2:15 == 47.1
12/22/15 2:20 == 47.1
12/22/15 2:25 == 47.2
12/22/15 2:30 == 47.1
12/22/15 2:35 == 47.1
12/22/15 2:40 == 47.2
12/22/15 2:45 == 47.1
12/22/15 2:50 == 47.1
12/22/15 2:55 == 47.1
12/22/15 3:00 == 47.1
12/22/15 3:05 == 47.2
12/22/15 3:10 == 47.2
12/22/15 3:15 == 47
12/22/15 3:20 == 47.1
12/22/15 3:25 == 47.1
12/22/15 3:30 == 47.1
12/22/15 3:35 == 47.1
12/22/15 3:40 == 47.2
12/22/15 3:45 == 47.1
12/22/15 3:50 == 47.2
12/22/15 3:55 == 47.2
12/22/15 4:00 == 47.1
12/22/15 4:05 == 47.1
12/22/15 4:10 == 47.1
12/22/15 4:15 == 47.1
12/22/15 4:20 == 47.1
12/22/15 4:25 == 47.2
12/22/15 4:30 == 47.1
12/22/15 4:35 == 47.1
12/22/15 4:40 == 47.2
12/22/15 4:45 == 47.1
12/22/15 4:50 == 47.2
12/22/15 4:55 == 47.1
12/22/15 5:00 == 47.2
12/22/15 5:05 == 47.1
12/22/15 5:10 == 47.1
12/22/15 5:15 == 47
12/22/15 5:20 == 47.2
12/22/15 5:25 == 47.1
12/22/15 5:30 == 47.1
12/22/15 5:35 == 47.1
12/22/15 5:40 == 47.1
12/22/15 5:45 == 47
12/22/15 5:50 == 47
12/22/15 5:55 == 47
12/22/15 6:00 == 47.1
12/22/15 6:05 == 47.2
12/22/15 6:10 == 47.1
12/22/15 6:15 == 47.2
12/22/15 6:20 == 47.1
12/22/15 6:25 == 47
12/22/15 6:30 == 47.2
12/22/15 6:35 == 47.1
12/22/15 6:40 == 47.2
12/22/15 6:45 == 47.1
12/22/15 6:50 == 47
12/22/15 6:55 == 47.2
12/22/15 7:00 == 47.1
12/22/15 7:05 == 47.2
12/22/15 7:10 == 47
12/22/15 7:15 == 47.1
12/22/15 7:20 == 47.1
12/22/15 7:25 == 47.1
12/22/15 7:30 == 47.1
12/22/15 7:35 == 47.1
12/22/15 7:40 == 47
12/22/15 7:45 == 47.2
12/22/15 7:50 == 47.1
12/22/15 7:55 == 47.1
12/22/15 8:00 == 47
12/22/15 8:05 == 47.1
12/22/15 8:10 == 47.1
12/22/15 8:15 == 47.1
12/22/15 8:20 == 47.2
12/22/15 8:25 == 47
12/22/15 8:30 == 47.1
12/22/15 8:35 == 47.1
12/22/15 8:40 == 47.2
12/22/15 8:45 == 47.4
12/22/15 8:50 == 47.6
12/22/15 8:55 == 47.6
12/22/15 9:00 == 47.6
12/22/15 9:05 == 47.7
12/22/15 9:10 == 47.5
12/22/15 9:15 == 47.5
12/22/15 9:20 == 47.7
12/22/15 9:25 == 47.6
12/22/15 9:30 == 47.4
12/22/15 9:35 == 47.5
12/22/15 9:40 == 47.8
12/22/15 9:45 == 47.6
12/22/15 9:50 == 47.6
12/22/15 9:55 == 47.6
12/22/15 10:00 == 47.7
12/22/15 10:05 == 47.6
12/22/15 10:10 == 47.6
12/22/15 10:15 == 47.6
12/22/15 10:20 == 47.7
12/22/15 10:25 == 47.6
12/22/15 10:30 == 47.5
12/22/15 10:35 == 47.3
12/22/15 10:40 == 47.4
12/22/15 10:45 == 47.5
12/22/15 10:50 == 47.6
12/22/15 10:55 == 47.5
12/22/15 11:00 == 47.5
12/22/15 11:05 == 47.7
12/22/15 11:10 == 47.6
12/22/15 11:15 == 47.7
12/22/15 11:20 == 47.3
12/22/15 11:25 == 47.6
12/22/15 11:30 == 46.8
12/22/15 11:35 == 47.4
12/22/15 11:40 == 47
12/22/15 11:45 == 47.2
12/22/15 11:50 == 47.2
12/22/15 11:55 == 47.1
12/22/15 12:00 == 47.2
12/22/15 12:05 == 47.1
12/22/15 12:10 == 47.2
12/22/15 12:15 == 47.2
12/22/15 12:20 == 47.2
12/22/15 12:25 == 47.3
12/22/15 12:30 == 47.4
12/22/15 12:35 == 47.2
12/22/15 12:40 == 47.1
12/22/15 12:45 == 47.3
12/22/15 12:50 == 47.1
12/22/15 12:55 == 47.2
12/22/15 13:00 == 47
12/22/15 13:05 == 47.3
12/22/15 13:10 == 47.1
12/22/15 13:15 == 47.2
12/22/15 13:20 == 47.1
12/22/15 13:25 == 47.3
12/22/15 13:30 == 47
12/22/15 13:35 == 47.2
12/22/15 13:40 == 47.1
12/22/15 13:45 == 47.3
12/22/15 13:50 == 47.3
12/22/15 13:55 == 47.1
12/22/15 14:00 == 33.5
12/22/15 14:05 == 0
12/22/15 14:10 == #
12/22/15 14:15 == 0
12/22/15 14:20 == #
12/22/15 14:25 == #
12/22/15 14:30 == 0.3
12/22/15 14:35 == 15
12/22/15 14:40 == 39
12/22/15 14:45 == 47.1
12/22/15 14:50 == 47.4
12/22/15 14:55 == 47.4
12/22/15 15:00 == 47.4
12/22/15 15:05 == 47.4
12/22/15 15:10 == 47.3
12/22/15 15:15 == 47.5
12/22/15 15:20 == 47.4
12/22/15 15:25 == 47.4
12/22/15 15:30 == 46.9
12/22/15 15:35 == 47.3
12/22/15 15:40 == 47.4
12/22/15 15:45 == 47.2
12/22/15 15:50 == 23.9
12/22/15 15:55 == 0
12/22/15 16:00 == 0
12/22/15 16:05 == 0
12/22/15 16:10 == #
12/22/15 16:15 == 13
12/22/15 16:20 == 29.9
12/22/15 16:25 == 18.6
12/22/15 16:30 == 18.6
12/22/15 16:35 == 18.6
12/22/15 16:40 == 26.6
12/22/15 16:45 == 28.4
12/22/15 16:50 == 28.4
12/22/15 16:55 == 26.7
12/22/15 17:00 == 18.7
12/22/15 17:05 == 18.6
12/22/15 17:10 == 14.8
12/22/15 17:15 == 0
12/22/15 17:20 == #
12/22/15 17:25 == #
12/22/15 17:30 == #
12/22/15 17:35 == #
12/22/15 17:40 == 0
12/22/15 17:45 == 0
12/22/15 17:50 == 0
12/22/15 17:55 == 0

Pumpback Station Discharge (0364)

12/22/15 18:00 == 0
12/22/15 18:05 == 0
12/22/15 18:10 == 2.2
12/22/15 18:15 == 13.3
12/22/15 18:20 == 11.8
12/22/15 18:25 == 11.9
12/22/15 18:30 == 11.9
12/22/15 18:35 == 11.9
12/22/15 18:40 == 11.9
12/22/15 18:45 == 16.7
12/22/15 18:50 == 30.4
12/22/15 18:55 == 30.4
12/22/15 19:00 == 30.2
12/22/15 19:05 == 30.3
12/22/15 19:10 == 30
12/22/15 19:15 == 30.1
12/22/15 19:20 == 30.1
12/22/15 19:25 == 30
12/22/15 19:30 == 30
12/22/15 19:35 == 30.2
12/22/15 19:40 == 30.1
12/22/15 19:45 == 30.2
12/22/15 19:50 == 30.1
12/22/15 19:55 == 30.1
12/22/15 20:00 == 30
12/22/15 20:05 == 30.1
12/22/15 20:10 == 30.1
12/22/15 20:15 == 30.1
12/22/15 20:20 == 30.1
12/22/15 20:25 == 30.1
12/22/15 20:30 == 30.2
12/22/15 20:35 == 30.1
12/22/15 20:40 == 30.1
12/22/15 20:45 == 30
12/22/15 20:50 == 30.1
12/22/15 20:55 == 30.1
12/22/15 21:00 == 30.1
12/22/15 21:05 == 30
12/22/15 21:10 == 30.1
12/22/15 21:15 == 30.2
12/22/15 21:20 == 30.1
12/22/15 21:25 == 30.1
12/22/15 21:30 == 30.2
12/22/15 21:35 == 30.1
12/22/15 21:40 == 30.1
12/22/15 21:45 == 30.2
12/22/15 21:50 == 30.1
12/22/15 21:55 == 30.2
12/22/15 22:00 == 30.1
12/22/15 22:05 == 30.2
12/22/15 22:10 == 30.1
12/22/15 22:15 == 30.1
12/22/15 22:20 == 30.1
12/22/15 22:25 == 30.1
12/22/15 22:30 == 30.3
12/22/15 22:35 == 30.1
12/22/15 22:40 == 30.1
12/22/15 22:45 == 30.1
12/22/15 22:50 == 30.2
12/22/15 22:55 == 30.1
12/22/15 23:00 == 30.2
12/22/15 23:05 == 30.2
12/22/15 23:10 == 30.1
12/22/15 23:15 == 30.1
12/22/15 23:20 == 30.1
12/22/15 23:25 == 30.2
12/22/15 23:30 == 30.1
12/22/15 23:35 == 30.1
12/22/15 23:40 == 30.1
12/22/15 23:45 == 30.2
12/22/15 23:50 == 30.1
12/22/15 23:55 == 30.1
12/23/15 0:00 == 30.2
12/23/15 0:05 == 30.2
12/23/15 0:10 == 30.1
12/23/15 0:15 == 30.2
12/23/15 0:20 == 30.1
12/23/15 0:25 == 30.1
12/23/15 0:30 == 30.1
12/23/15 0:35 == 30.2
12/23/15 0:40 == 30.2
12/23/15 0:45 == 30.2
12/23/15 0:50 == 30.2
12/23/15 0:55 == 30.2
12/23/15 1:00 == 30.2
12/23/15 1:05 == 30.2
12/23/15 1:10 == 30.3
12/23/15 1:15 == 30.1
12/23/15 1:20 == 30.2
12/23/15 1:25 == 30.3
12/23/15 1:30 == 30.1
12/23/15 1:35 == 30.1
12/23/15 1:40 == 30.2
12/23/15 1:45 == 30.2
12/23/15 1:50 == 30.2
12/23/15 1:55 == 30.2
12/23/15 2:00 == 30.1
12/23/15 2:05 == 30.2
12/23/15 2:10 == 30.1
12/23/15 2:15 == 30.2
12/23/15 2:20 == 30.1
12/23/15 2:25 == 30.2
12/23/15 2:30 == 30.1
12/23/15 2:35 == 30.1
12/23/15 2:40 == 30.2
12/23/15 2:45 == 30.2
12/23/15 2:50 == 30.2
12/23/15 2:55 == 30.1
12/23/15 3:00 == 30.2
12/23/15 3:05 == 30.2
12/23/15 3:10 == 30.2
12/23/15 3:15 == 30.2
12/23/15 3:20 == 30.3
12/23/15 3:25 == 30.2
12/23/15 3:30 == 30
12/23/15 3:35 == 30.2
12/23/15 3:40 == 30.4
12/23/15 3:45 == 30.2
12/23/15 3:50 == 30.3
12/23/15 3:55 == 30.1
12/23/15 4:00 == 30.3
12/23/15 4:05 == 30.2
12/23/15 4:10 == 30.2
12/23/15 4:15 == 30.2
12/23/15 4:20 == 30.3
12/23/15 4:25 == 30.2
12/23/15 4:30 == 30.2
12/23/15 4:35 == 30.2
12/23/15 4:40 == 30.2
12/23/15 4:45 == 30.1
12/23/15 4:50 == 30.1
12/23/15 4:55 == 30.1
12/23/15 5:00 == 30.1
12/23/15 5:05 == 30.1
12/23/15 5:10 == 30.1
12/23/15 5:15 == 30.2
12/23/15 5:20 == 30.2
12/23/15 5:25 == 30.2
12/23/15 5:30 == 30.1
12/23/15 5:35 == 30.1
12/23/15 5:40 == 30.2
12/23/15 5:45 == 30.2
12/23/15 5:50 == 30.2
12/23/15 5:55 == 30.1
12/23/15 6:00 == 30.1
12/23/15 6:05 == 30.2
12/23/15 6:10 == 30.2
12/23/15 6:15 == 30.2
12/23/15 6:20 == 30.2
12/23/15 6:25 == 30.1
12/23/15 6:30 == 30.2
12/23/15 6:35 == 30.2
12/23/15 6:40 == 30.3
12/23/15 6:45 == 30.2
12/23/15 6:50 == 30.2
12/23/15 6:55 == 30.2
12/23/15 7:00 == 30.2
12/23/15 7:05 == 30.2
12/23/15 7:10 == 30.2
12/23/15 7:15 == 30.2
12/23/15 7:20 == 30.1
12/23/15 7:25 == 30.2
12/23/15 7:30 == 30.2
12/23/15 7:35 == 30.3
12/23/15 7:40 == 30.2
12/23/15 7:45 == 30.1
12/23/15 7:50 == 30.2
12/23/15 7:55 == 30.1
12/23/15 8:00 == 30.2
12/23/15 8:05 == 30.2
12/23/15 8:10 == 30.2
12/23/15 8:15 == 30.2
12/23/15 8:20 == 30.2
12/23/15 8:25 == 30.3
12/23/15 8:30 == 30.9
12/23/15 8:35 == 30.8
12/23/15 8:40 == 30.9
12/23/15 8:45 == 30.9
12/23/15 8:50 == 31
12/23/15 8:55 == 31.1
12/23/15 9:00 == 31
12/23/15 9:05 == 31
12/23/15 9:10 == 30.9
12/23/15 9:15 == 30.8
12/23/15 9:20 == 30.9
12/23/15 9:25 == 31
12/23/15 9:30 == 30.6
12/23/15 9:35 == 30.8
12/23/15 9:40 == 31
12/23/15 9:45 == 31.1
12/23/15 9:50 == 31.1
12/23/15 9:55 == 31.2
12/23/15 10:00 == 31
12/23/15 10:05 == 31.1
12/23/15 10:10 == 31.2
12/23/15 10:15 == 31.2
12/23/15 10:20 == 31.2
12/23/15 10:25 == 31.2
12/23/15 10:30 == 30.8
12/23/15 10:35 == 25
12/23/15 10:40 == 12.6
12/23/15 10:45 == 12.7
12/23/15 10:50 == 12.7
12/23/15 10:55 == 12.7
12/23/15 11:00 == 12.7
12/23/15 11:05 == 12.8
12/23/15 11:10 == 12.7
12/23/15 11:15 == 12.8
12/23/15 11:20 == 17.6
12/23/15 11:25 == 31.1
12/23/15 11:30 == 30.3
12/23/15 11:35 == 30.4
12/23/15 11:40 == 30.3
12/23/15 11:45 == 30.3
12/23/15 11:50 == 35.6
12/23/15 11:55 == 47.6

Pumpback Station Discharge (0364)

12/23/15 12:00 == 47.4
12/23/15 12:05 == 47.5
12/23/15 12:10 == 47.4
12/23/15 12:15 == 47.6
12/23/15 12:20 == 47.3
12/23/15 12:25 == 47.5
12/23/15 12:30 == 47.5
12/23/15 12:35 == 47.4
12/23/15 12:40 == 47.4
12/23/15 12:45 == 47.4
12/23/15 12:50 == 47.4
12/23/15 12:55 == 47.1
12/23/15 13:00 == 47.5
12/23/15 13:05 == 47.4
12/23/15 13:10 == 47.3
12/23/15 13:15 == 47.5
12/23/15 13:20 == 47.3
12/23/15 13:25 == 46.9
12/23/15 13:30 == 47.2
12/23/15 13:35 == 47.4
12/23/15 13:40 == 47.3
12/23/15 13:45 == 47.4
12/23/15 13:50 == 47.3
12/23/15 13:55 == 47.4
12/23/15 14:00 == 47.3
12/23/15 14:05 == 47.2
12/23/15 14:10 == 47.4
12/23/15 14:15 == 47.5
12/23/15 14:20 == 47.3
12/23/15 14:25 == 47.2
12/23/15 14:30 == 47.3
12/23/15 14:35 == 47.3
12/23/15 14:40 == 47.6
12/23/15 14:45 == 47.1
12/23/15 14:50 == 47.3
12/23/15 14:55 == 47.2
12/23/15 15:00 == 47.4
12/23/15 15:05 == 47.4
12/23/15 15:10 == 47.4
12/23/15 15:15 == 47.4
12/23/15 15:20 == 47.2
12/23/15 15:25 == 47.3
12/23/15 15:30 == 47.2
12/23/15 15:35 == 47.3
12/23/15 15:40 == 47
12/23/15 15:45 == 47.4
12/23/15 15:50 == 47.3
12/23/15 15:55 == 47.1
12/23/15 16:00 == 47.2
12/23/15 16:05 == 47.4
12/23/15 16:10 == 47.1
12/23/15 16:15 == 47.2
12/23/15 16:20 == 47.1
12/23/15 16:25 == 47.2
12/23/15 16:30 == 47.1
12/23/15 16:35 == 47.1
12/23/15 16:40 == 47.1
12/23/15 16:45 == 47.1
12/23/15 16:50 == 47.1
12/23/15 16:55 == 47.1
12/23/15 17:00 == 47.1
12/23/15 17:05 == 47.1
12/23/15 17:10 == 47.2
12/23/15 17:15 == 47.2
12/23/15 17:20 == 47.3
12/23/15 17:25 == 47.1
12/23/15 17:30 == 47.2
12/23/15 17:35 == 47.1
12/23/15 17:40 == 47.1
12/23/15 17:45 == 47.1
12/23/15 17:50 == 47.2
12/23/15 17:55 == 47.2
12/23/15 18:00 == 47.1
12/23/15 18:05 == 47.1
12/23/15 18:10 == 47.3
12/23/15 18:15 == 47.1
12/23/15 18:20 == 47.1
12/23/15 18:25 == 47.1
12/23/15 18:30 == 47.1
12/23/15 18:35 == 47.2
12/23/15 18:40 == 47
12/23/15 18:45 == 47.2
12/23/15 18:50 == 47.1
12/23/15 18:55 == 47.1
12/23/15 19:00 == 47.1
12/23/15 19:05 == 47.1
12/23/15 19:10 == 47.1
12/23/15 19:15 == 47.1
12/23/15 19:20 == 47
12/23/15 19:25 == 47.1
12/23/15 19:30 == 47.1
12/23/15 19:35 == 47.3
12/23/15 19:40 == 47.2
12/23/15 19:45 == 47.1
12/23/15 19:50 == 47.1
12/23/15 19:55 == 47.2
12/23/15 20:00 == 47
12/23/15 20:05 == 47.1
12/23/15 20:10 == 47
12/23/15 20:15 == 47
12/23/15 20:20 == 47.1
12/23/15 20:25 == 47.1
12/23/15 20:30 == 47.1
12/23/15 20:35 == 47.2
12/23/15 20:40 == 47.1
12/23/15 20:45 == 47.1
12/23/15 20:50 == 47.1
12/23/15 20:55 == 47.1
12/23/15 21:00 == 47
12/23/15 21:05 == 47.1
12/23/15 21:10 == 47.1
12/23/15 21:15 == 47.1
12/23/15 21:20 == 47.2
12/23/15 21:25 == 47.2
12/23/15 21:30 == 47.4
12/23/15 21:35 == 47.3
12/23/15 21:40 == 47.4
12/23/15 21:45 == 47.2
12/23/15 21:50 == 47.3
12/23/15 21:55 == 47.4
12/23/15 22:00 == 47.3
12/23/15 22:05 == 47.4
12/23/15 22:10 == 47.2
12/23/15 22:15 == 47.4
12/23/15 22:20 == 47.2
12/23/15 22:25 == 47.2
12/23/15 22:30 == 47.2
12/23/15 22:35 == 47.2
12/23/15 22:40 == 47.2
12/23/15 22:45 == 47.2
12/23/15 22:50 == 47
12/23/15 22:55 == 47.2
12/23/15 23:00 == 47.1
12/23/15 23:05 == 47.2
12/23/15 23:10 == 47.1
12/23/15 23:15 == 47.1
12/23/15 23:20 == 47.1
12/23/15 23:25 == 47.1
12/23/15 23:30 == 47.2
12/23/15 23:35 == 47.1
12/23/15 23:40 == 47.3
12/23/15 23:45 == 47.1
12/23/15 23:50 == 47.2
12/23/15 23:55 == 47.2
12/24/15 0:00 == 47.1
12/24/15 0:05 == 47.1
12/24/15 0:10 == 47.1
12/24/15 0:15 == 47
12/24/15 0:20 == 47.1
12/24/15 0:25 == 47.1
12/24/15 0:30 == 47
12/24/15 0:35 == 47
12/24/15 0:40 == 47
12/24/15 0:45 == 47
12/24/15 0:50 == 47.1
12/24/15 0:55 == 47.1
12/24/15 1:00 == 47.2
12/24/15 1:05 == 47.1
12/24/15 1:10 == 47.2
12/24/15 1:15 == 47.1
12/24/15 1:20 == 47.1
12/24/15 1:25 == 47.2
12/24/15 1:30 == 47.2
12/24/15 1:35 == 47.2
12/24/15 1:40 == 47.3
12/24/15 1:45 == 47.3
12/24/15 1:50 == 47.2
12/24/15 1:55 == 47.1
12/24/15 2:00 == 47.2
12/24/15 2:05 == 47.2
12/24/15 2:10 == 47.1
12/24/15 2:15 == 47.1
12/24/15 2:20 == 47.2
12/24/15 2:25 == 47.2
12/24/15 2:30 == 47.1
12/24/15 2:35 == 47.2
12/24/15 2:40 == 47.1
12/24/15 2:45 == 47.1
12/24/15 2:50 == 47.2
12/24/15 2:55 == 47.1
12/24/15 3:00 == 47.1
12/24/15 3:05 == 47.1
12/24/15 3:10 == 47.1
12/24/15 3:15 == 47.2
12/24/15 3:20 == 47.1
12/24/15 3:25 == 47.2
12/24/15 3:30 == 47
12/24/15 3:35 == 47.1
12/24/15 3:40 == 47.2
12/24/15 3:45 == 47.1
12/24/15 3:50 == 47
12/24/15 3:55 == 47.2
12/24/15 4:00 == 47.1
12/24/15 4:05 == 47.1
12/24/15 4:10 == 47
12/24/15 4:15 == 47.1
12/24/15 4:20 == 47.1
12/24/15 4:25 == 47.1
12/24/15 4:30 == 47
12/24/15 4:35 == 47.1
12/24/15 4:40 == 47
12/24/15 4:45 == 47.1
12/24/15 4:50 == 47.1
12/24/15 4:55 == 47.2
12/24/15 5:00 == 47.2
12/24/15 5:05 == 47.1
12/24/15 5:10 == 47.1
12/24/15 5:15 == 47.1
12/24/15 5:20 == 47
12/24/15 5:25 == 47.1
12/24/15 5:30 == 47
12/24/15 5:35 == 47.1
12/24/15 5:40 == 47.1
12/24/15 5:45 == 46.9
12/24/15 5:50 == 47.1
12/24/15 5:55 == 47

Pumpback Station Discharge (0364)

12/24/15 6:00 == 47.1
12/24/15 6:05 == 47.2
12/24/15 6:10 == 47.2
12/24/15 6:15 == 47.2
12/24/15 6:20 == 47.1
12/24/15 6:25 == 47.1
12/24/15 6:30 == 47
12/24/15 6:35 == 47.2
12/24/15 6:40 == 46.9
12/24/15 6:45 == 47.1
12/24/15 6:50 == 47.2
12/24/15 6:55 == 47.3
12/24/15 7:00 == 47.4
12/24/15 7:05 == 47.2
12/24/15 7:10 == 47.3
12/24/15 7:15 == 47.2
12/24/15 7:20 == 47.1
12/24/15 7:25 == 47.3
12/24/15 7:30 == 47.2
12/24/15 7:35 == 47.3
12/24/15 7:40 == 47
12/24/15 7:45 == 47.4
12/24/15 7:50 == 47.1
12/24/15 7:55 == 47.2
12/24/15 8:00 == 47.2
12/24/15 8:05 == 47.1
12/24/15 8:10 == 47.3
12/24/15 8:15 == 47.2
12/24/15 8:20 == 47.1
12/24/15 8:25 == 47.2
12/24/15 8:30 == 47.4
12/24/15 8:35 == 47.3
12/24/15 8:40 == 47.2
12/24/15 8:45 == 47.3
12/24/15 8:50 == 47.2
12/24/15 8:55 == 47.3
12/24/15 9:00 == 47.2
12/24/15 9:05 == 47.3
12/24/15 9:10 == 47.1
12/24/15 9:15 == 47.2
12/24/15 9:20 == 47.1
12/24/15 9:25 == 47.2
12/24/15 9:30 == 47.3
12/24/15 9:35 == 47.1
12/24/15 9:40 == 47.2
12/24/15 9:45 == 47.3
12/24/15 9:50 == 47.1
12/24/15 9:55 == 47.1
12/24/15 10:00 == 47.1
12/24/15 10:05 == 47.2
12/24/15 10:10 == 47.1
12/24/15 10:15 == 47.2
12/24/15 10:20 == 47
12/24/15 10:25 == 47.2
12/24/15 10:30 == 47.1
12/24/15 10:35 == 47.2
12/24/15 10:40 == 47.1
12/24/15 10:45 == 47.1
12/24/15 10:50 == 47
12/24/15 10:55 == 47.2
12/24/15 11:00 == 47
12/24/15 11:05 == 47.1
12/24/15 11:10 == 47.1
12/24/15 11:15 == 47.2
12/24/15 11:20 == 47.1
12/24/15 11:25 == 45.2
12/24/15 11:30 == 47.3
12/24/15 11:35 == 47.2
12/24/15 11:40 == 47.2
12/24/15 11:45 == 47.3
12/24/15 11:50 == 47.4
12/24/15 11:55 == 46.7
12/24/15 12:00 == 47
12/24/15 12:05 == 47
12/24/15 12:10 == 47
12/24/15 12:15 == 47.1
12/24/15 12:20 == 47.1
12/24/15 12:25 == 47
12/24/15 12:30 == 47.2
12/24/15 12:35 == 47.2
12/24/15 12:40 == 47.1
12/24/15 12:45 == 47.1
12/24/15 12:50 == 47.1
12/24/15 12:55 == 47.1
12/24/15 13:00 == 47.1
12/24/15 13:05 == 47.2
12/24/15 13:10 == 47.2
12/24/15 13:15 == 47.1
12/24/15 13:20 == 47.1
12/24/15 13:25 == 47.2
12/24/15 13:30 == 47
12/24/15 13:35 == 47.3
12/24/15 13:40 == 46.8
12/24/15 13:45 == 46.4
12/24/15 13:50 == 46.5
12/24/15 13:55 == 47.1
12/24/15 14:00 == 47.3
12/24/15 14:05 == 47.4
12/24/15 14:10 == 47.3
12/24/15 14:15 == 47.5
12/24/15 14:20 == 47.3
12/24/15 14:25 == 47.2
12/24/15 14:30 == 47.3
12/24/15 14:35 == 47.3
12/24/15 14:40 == 47.2
12/24/15 14:45 == 47.2
12/24/15 14:50 == 47.3
12/24/15 14:55 == 46.9
12/24/15 15:00 == 47.2
12/24/15 15:05 == 47.2
12/24/15 15:10 == 47.3
12/24/15 15:15 == 47.4
12/24/15 15:20 == 47
12/24/15 15:25 == 47.2
12/24/15 15:30 == 47
12/24/15 15:35 == 47.1
12/24/15 15:40 == 47.2
12/24/15 15:45 == 46.8
12/24/15 15:50 == 47.1
12/24/15 15:55 == 46.8
12/24/15 16:00 == 47
12/24/15 16:05 == 46.9
12/24/15 16:10 == 47
12/24/15 16:15 == 47.1
12/24/15 16:20 == 47.1
12/24/15 16:25 == 47
12/24/15 16:30 == 47
12/24/15 16:35 == 46.8
12/24/15 16:40 == 47
12/24/15 16:45 == 47
12/24/15 16:50 == 46.9
12/24/15 16:55 == 47.1
12/24/15 17:00 == 47
12/24/15 17:05 == 47
12/24/15 17:10 == 47
12/24/15 17:15 == 47.1
12/24/15 17:20 == 47
12/24/15 17:25 == 47
12/24/15 17:30 == 47
12/24/15 17:35 == 47.1
12/24/15 17:40 == 47
12/24/15 17:45 == 47
12/24/15 17:50 == 47.1
12/24/15 17:55 == 47.1
12/24/15 18:00 == 47
12/24/15 18:05 == 47
12/24/15 18:10 == 47.1
12/24/15 18:15 == 47.2
12/24/15 18:20 == 47.1
12/24/15 18:25 == 46.9
12/24/15 18:30 == 47
12/24/15 18:35 == 46.9
12/24/15 18:40 == 46.9
12/24/15 18:45 == 47
12/24/15 18:50 == 47
12/24/15 18:55 == 47.1
12/24/15 19:00 == 47
12/24/15 19:05 == 46.9
12/24/15 19:10 == 47
12/24/15 19:15 == 47
12/24/15 19:20 == 47.1
12/24/15 19:25 == 47
12/24/15 19:30 == 46.9
12/24/15 19:35 == 47
12/24/15 19:40 == 47
12/24/15 19:45 == 47.1
12/24/15 19:50 == 47
12/24/15 19:55 == 46.8
12/24/15 20:00 == 47.1
12/24/15 20:05 == 46.8
12/24/15 20:10 == 46.9
12/24/15 20:15 == 47
12/24/15 20:20 == 46.8
12/24/15 20:25 == 47
12/24/15 20:30 == 46.9
12/24/15 20:35 == 47
12/24/15 20:40 == 46.9
12/24/15 20:45 == 47.2
12/24/15 20:50 == 47
12/24/15 20:55 == 47.1
12/24/15 21:00 == 47.1
12/24/15 21:05 == 47.1
12/24/15 21:10 == 46.9
12/24/15 21:15 == 46.9
12/24/15 21:20 == 46.9
12/24/15 21:25 == 46.9
12/24/15 21:30 == 47.3
12/24/15 21:35 == 47
12/24/15 21:40 == 47.1
12/24/15 21:45 == 47.2
12/24/15 21:50 == 47.1
12/24/15 21:55 == 47.2
12/24/15 22:00 == 47.1
12/24/15 22:05 == 47.1
12/24/15 22:10 == 47
12/24/15 22:15 == 47.1
12/24/15 22:20 == 47.1
12/24/15 22:25 == 47.2
12/24/15 22:30 == 47.1
12/24/15 22:35 == 47.1
12/24/15 22:40 == 47.3
12/24/15 22:45 == 47.1
12/24/15 22:50 == 47.2
12/24/15 22:55 == 47
12/24/15 23:00 == 47
12/24/15 23:05 == 47.1
12/24/15 23:10 == 46.9
12/24/15 23:15 == 46.9
12/24/15 23:20 == 47
12/24/15 23:25 == 46.9
12/24/15 23:30 == 47
12/24/15 23:35 == 47
12/24/15 23:40 == 47.1
12/24/15 23:45 == 47
12/24/15 23:50 == 47
12/24/15 23:55 == 47

Pumpback Station Discharge (0364)

12/25/15 0:00 == 47
12/25/15 0:05 == 47
12/25/15 0:10 == 46.9
12/25/15 0:15 == 46.9
12/25/15 0:20 == 46.8
12/25/15 0:25 == 46.9
12/25/15 0:30 == 47
12/25/15 0:35 == 46.9
12/25/15 0:40 == 46.9
12/25/15 0:45 == 47
12/25/15 0:50 == 47
12/25/15 0:55 == 47
12/25/15 1:00 == 46.8
12/25/15 1:05 == 47
12/25/15 1:10 == 46.9
12/25/15 1:15 == 47
12/25/15 1:20 == 46.9
12/25/15 1:25 == 47
12/25/15 1:30 == 47
12/25/15 1:35 == 47
12/25/15 1:40 == 47
12/25/15 1:45 == 46.9
12/25/15 1:50 == 47
12/25/15 1:55 == 47.1
12/25/15 2:00 == 46.9
12/25/15 2:05 == 47
12/25/15 2:10 == 46.9
12/25/15 2:15 == 47
12/25/15 2:20 == 47.1
12/25/15 2:25 == 46.9
12/25/15 2:30 == 47
12/25/15 2:35 == 47
12/25/15 2:40 == 47
12/25/15 2:45 == 46.9
12/25/15 2:50 == 46.9
12/25/15 2:55 == 47
12/25/15 3:00 == 47.1
12/25/15 3:05 == 47
12/25/15 3:10 == 47
12/25/15 3:15 == 46.9
12/25/15 3:20 == 47
12/25/15 3:25 == 46.8
12/25/15 3:30 == 47
12/25/15 3:35 == 46.9
12/25/15 3:40 == 47
12/25/15 3:45 == 47
12/25/15 3:50 == 46.9
12/25/15 3:55 == 47
12/25/15 4:00 == 47
12/25/15 4:05 == 47
12/25/15 4:10 == 47
12/25/15 4:15 == 47
12/25/15 4:20 == 47
12/25/15 4:25 == 47
12/25/15 4:30 == 46.9
12/25/15 4:35 == 46.9
12/25/15 4:40 == 47
12/25/15 4:45 == 46.9
12/25/15 4:50 == 46.9
12/25/15 4:55 == 47
12/25/15 5:00 == 47
12/25/15 5:05 == 47.1
12/25/15 5:10 == 47
12/25/15 5:15 == 47
12/25/15 5:20 == 47
12/25/15 5:25 == 46.9
12/25/15 5:30 == 47.1
12/25/15 5:35 == 46.9
12/25/15 5:40 == 47
12/25/15 5:45 == 46.9
12/25/15 5:50 == 47.1
12/25/15 5:55 == 47
12/25/15 6:00 == 47
12/25/15 6:05 == 47
12/25/15 6:10 == 47.1
12/25/15 6:15 == 47
12/25/15 6:20 == 47
12/25/15 6:25 == 47
12/25/15 6:30 == 47.2
12/25/15 6:35 == 47
12/25/15 6:40 == 47.1
12/25/15 6:45 == 47
12/25/15 6:50 == 47
12/25/15 6:55 == 47.3
12/25/15 7:00 == 47.3
12/25/15 7:05 == 47.2
12/25/15 7:10 == 47.2
12/25/15 7:15 == 47.1
12/25/15 7:20 == 47.1
12/25/15 7:25 == 47.2
12/25/15 7:30 == 47.3
12/25/15 7:35 == 47.3
12/25/15 7:40 == 47.2
12/25/15 7:45 == 47.3
12/25/15 7:50 == 47.3
12/25/15 7:55 == 47.4
12/25/15 8:00 == 47.3
12/25/15 8:05 == 47.4
12/25/15 8:10 == 47.4
12/25/15 8:15 == 47.5
12/25/15 8:20 == 47.3
12/25/15 8:25 == 47.3
12/25/15 8:30 == 47.4
12/25/15 8:35 == 47.4
12/25/15 8:40 == 47.4
12/25/15 8:45 == 47.5
12/25/15 8:50 == 47.5
12/25/15 8:55 == 47.4
12/25/15 9:00 == 47.5
12/25/15 9:05 == 47.5
12/25/15 9:10 == 47.2
12/25/15 9:15 == 47.5
12/25/15 9:20 == 47.3
12/25/15 9:25 == 47.4
12/25/15 9:30 == 47.5
12/25/15 9:35 == 47.4
12/25/15 9:40 == 47.3
12/25/15 9:45 == 47.5
12/25/15 9:50 == 47.4
12/25/15 9:55 == 47.2
12/25/15 10:00 == 47.5
12/25/15 10:05 == 47.5
12/25/15 10:10 == 47.3
12/25/15 10:15 == 47.5
12/25/15 10:20 == 47.4
12/25/15 10:25 == 47.3
12/25/15 10:30 == 47.2
12/25/15 10:35 == 47.6
12/25/15 10:40 == 46.8
12/25/15 10:45 == 47.2
12/25/15 10:50 == 47.2
12/25/15 10:55 == 47.4
12/25/15 11:00 == 47.1
12/25/15 11:05 == 47.2
12/25/15 11:10 == 47.2
12/25/15 11:15 == 47.3
12/25/15 11:20 == 47.3
12/25/15 11:25 == 47.3
12/25/15 11:30 == 47.2
12/25/15 11:35 == 47.2
12/25/15 11:40 == 47.1
12/25/15 11:45 == 47.3
12/25/15 11:50 == 47.2
12/25/15 11:55 == 46.9
12/25/15 12:00 == 47
12/25/15 12:05 == 47.1
12/25/15 12:10 == 47.1
12/25/15 12:15 == 47.1
12/25/15 12:20 == 47.2
12/25/15 12:25 == 47.2
12/25/15 12:30 == 47.3
12/25/15 12:35 == 47.1
12/25/15 12:40 == 47.2
12/25/15 12:45 == 47.1
12/25/15 12:50 == 47.1
12/25/15 12:55 == 47.2
12/25/15 13:00 == 47.3
12/25/15 13:05 == 47.4
12/25/15 13:10 == 47.2
12/25/15 13:15 == 47.3
12/25/15 13:20 == 47.2
12/25/15 13:25 == 47.4
12/25/15 13:30 == 47.2
12/25/15 13:35 == 47.5
12/25/15 13:40 == 47.2
12/25/15 13:45 == 47.2
12/25/15 13:50 == 47.2
12/25/15 13:55 == 47.3
12/25/15 14:00 == 47.1
12/25/15 14:05 == 47.4
12/25/15 14:10 == 47.2
12/25/15 14:15 == 47.4
12/25/15 14:20 == 47.2
12/25/15 14:25 == 47.3
12/25/15 14:30 == 47.2
12/25/15 14:35 == 47.2
12/25/15 14:40 == 47.2
12/25/15 14:45 == 47.2
12/25/15 14:50 == 47.2
12/25/15 14:55 == 47.1
12/25/15 15:00 == 47.1
12/25/15 15:05 == 47.2
12/25/15 15:10 == 47.4
12/25/15 15:15 == 47.2
12/25/15 15:20 == 47
12/25/15 15:25 == 47
12/25/15 15:30 == 47.2
12/25/15 15:35 == 46.9
12/25/15 15:40 == 47
12/25/15 15:45 == 47
12/25/15 15:50 == 47
12/25/15 15:55 == 46.9
12/25/15 16:00 == 47
12/25/15 16:05 == 47.2
12/25/15 16:10 == 47
12/25/15 16:15 == 47
12/25/15 16:20 == 47
12/25/15 16:25 == 46.9
12/25/15 16:30 == 47
12/25/15 16:35 == 47
12/25/15 16:40 == 47
12/25/15 16:45 == 46.8
12/25/15 16:50 == 46.9
12/25/15 16:55 == 47
12/25/15 17:00 == 47.1
12/25/15 17:05 == 46.9
12/25/15 17:10 == 47.1
12/25/15 17:15 == 47
12/25/15 17:20 == 47.2
12/25/15 17:25 == 47
12/25/15 17:30 == 47.1
12/25/15 17:35 == 47
12/25/15 17:40 == 47.1
12/25/15 17:45 == 47.2
12/25/15 17:50 == 47.1
12/25/15 17:55 == 47.2

Pumpback Station Discharge (0364)

12/25/15 18:00 == 47.1
12/25/15 18:05 == 47.1
12/25/15 18:10 == 47.2
12/25/15 18:15 == 47.1
12/25/15 18:20 == 47.1
12/25/15 18:25 == 46.9
12/25/15 18:30 == 47
12/25/15 18:35 == 46.9
12/25/15 18:40 == 46.9
12/25/15 18:45 == 47
12/25/15 18:50 == 47
12/25/15 18:55 == 47
12/25/15 19:00 == 47
12/25/15 19:05 == 46.9
12/25/15 19:10 == 46.9
12/25/15 19:15 == 47
12/25/15 19:20 == 47.1
12/25/15 19:25 == 46.9
12/25/15 19:30 == 47.1
12/25/15 19:35 == 47.2
12/25/15 19:40 == 46.9
12/25/15 19:45 == 47.1
12/25/15 19:50 == 46.9
12/25/15 19:55 == 46.9
12/25/15 20:00 == 47
12/25/15 20:05 == 47
12/25/15 20:10 == 47.1
12/25/15 20:15 == 47
12/25/15 20:20 == 46.9
12/25/15 20:25 == 46.9
12/25/15 20:30 == 47.1
12/25/15 20:35 == 46.9
12/25/15 20:40 == 46.9
12/25/15 20:45 == 47.3
12/25/15 20:50 == 47.1
12/25/15 20:55 == 47
12/25/15 21:00 == 47.1
12/25/15 21:05 == 47.1
12/25/15 21:10 == 47
12/25/15 21:15 == 47.1
12/25/15 21:20 == 47.1
12/25/15 21:25 == 47.1
12/25/15 21:30 == 47.3
12/25/15 21:35 == 47.2
12/25/15 21:40 == 47.2
12/25/15 21:45 == 47.1
12/25/15 21:50 == 47.3
12/25/15 21:55 == 47.2
12/25/15 22:00 == 47.2
12/25/15 22:05 == 47.1
12/25/15 22:10 == 47.3
12/25/15 22:15 == 47.2
12/25/15 22:20 == 47.1
12/25/15 22:25 == 47.1
12/25/15 22:30 == 47
12/25/15 22:35 == 47.1
12/25/15 22:40 == 47.1
12/25/15 22:45 == 47.3
12/25/15 22:50 == 47.2
12/25/15 22:55 == 47
12/25/15 23:00 == 47.1
12/25/15 23:05 == 47
12/25/15 23:10 == 47
12/25/15 23:15 == 47
12/25/15 23:20 == 47
12/25/15 23:25 == 47.1
12/25/15 23:30 == 47
12/25/15 23:35 == 47
12/25/15 23:40 == 47
12/25/15 23:45 == 47.1
12/25/15 23:50 == 47
12/25/15 23:55 == 47
12/26/15 0:00 == 47.1
12/26/15 0:05 == 46.9
12/26/15 0:10 == 46.9
12/26/15 0:15 == 47
12/26/15 0:20 == 47
12/26/15 0:25 == 47
12/26/15 0:30 == 47.1
12/26/15 0:35 == 46.9
12/26/15 0:40 == 46.9
12/26/15 0:45 == 47
12/26/15 0:50 == 47
12/26/15 0:55 == 47
12/26/15 1:00 == 47
12/26/15 1:05 == 47.1
12/26/15 1:10 == 47
12/26/15 1:15 == 46.9
12/26/15 1:20 == 47
12/26/15 1:25 == 47.1
12/26/15 1:30 == 47.1
12/26/15 1:35 == 47
12/26/15 1:40 == 47
12/26/15 1:45 == 47
12/26/15 1:50 == 47
12/26/15 1:55 == 47
12/26/15 2:00 == 47.1
12/26/15 2:05 == 46.9
12/26/15 2:10 == 47
12/26/15 2:15 == 47
12/26/15 2:20 == 47
12/26/15 2:25 == 47.1
12/26/15 2:30 == 47
12/26/15 2:35 == 47.1
12/26/15 2:40 == 46.9
12/26/15 2:45 == 46.9
12/26/15 2:50 == 47.1
12/26/15 2:55 == 47.1
12/26/15 3:00 == 47
12/26/15 3:05 == 47
12/26/15 3:10 == 47
12/26/15 3:15 == 46.9
12/26/15 3:20 == 47
12/26/15 3:25 == 47.1
12/26/15 3:30 == 47
12/26/15 3:35 == 47
12/26/15 3:40 == 47.2
12/26/15 3:45 == 47.1
12/26/15 3:50 == 47
12/26/15 3:55 == 47
12/26/15 4:00 == 47.1
12/26/15 4:05 == 47
12/26/15 4:10 == 47
12/26/15 4:15 == 47
12/26/15 4:20 == 47.1
12/26/15 4:25 == 46.9
12/26/15 4:30 == 47
12/26/15 4:35 == 47
12/26/15 4:40 == 47
12/26/15 4:45 == 46.9
12/26/15 4:50 == 47
12/26/15 4:55 == 46.9
12/26/15 5:00 == 47.1
12/26/15 5:05 == 46.9
12/26/15 5:10 == 47
12/26/15 5:15 == 47.1
12/26/15 5:20 == 46.8
12/26/15 5:25 == 47
12/26/15 5:30 == 46.9
12/26/15 5:35 == 47
12/26/15 5:40 == 47.1
12/26/15 5:45 == 47
12/26/15 5:50 == 46.9
12/26/15 5:55 == 46.9
12/26/15 6:00 == 47.1
12/26/15 6:05 == 47
12/26/15 6:10 == 47
12/26/15 6:15 == 47
12/26/15 6:20 == 47
12/26/15 6:25 == 47
12/26/15 6:30 == 47
12/26/15 6:35 == 47
12/26/15 6:40 == 47
12/26/15 6:45 == 47
12/26/15 6:50 == 45.1
12/26/15 6:55 == 47.2
12/26/15 7:00 == 47.4
12/26/15 7:05 == 47.3
12/26/15 7:10 == 47.3
12/26/15 7:15 == 47.3
12/26/15 7:20 == 47.2
12/26/15 7:25 == 47.4
12/26/15 7:30 == 47.3
12/26/15 7:35 == 47.3
12/26/15 7:40 == 47.3
12/26/15 7:45 == 47.3
12/26/15 7:50 == 47.5
12/26/15 7:55 == 47.5
12/26/15 8:00 == 47.5
12/26/15 8:05 == 47.7
12/26/15 8:10 == 47.6
12/26/15 8:15 == 47.6
12/26/15 8:20 == 47.4
12/26/15 8:25 == 47.3
12/26/15 8:30 == 47.6
12/26/15 8:35 == 47.5
12/26/15 8:40 == 47.6
12/26/15 8:45 == 47.7
12/26/15 8:50 == 47.8
12/26/15 8:55 == 47.4
12/26/15 9:00 == 47.6
12/26/15 9:05 == 47.6
12/26/15 9:10 == 47.5
12/26/15 9:15 == 47.7
12/26/15 9:20 == 47.5
12/26/15 9:25 == 47.7
12/26/15 9:30 == 47.7
12/26/15 9:35 == 47.7
12/26/15 9:40 == 47.3
12/26/15 9:45 == 47.5
12/26/15 9:50 == 47.7
12/26/15 9:55 == 47.3
12/26/15 10:00 == 47.4
12/26/15 10:05 == 47.5
12/26/15 10:10 == 47.4
12/26/15 10:15 == 47.4
12/26/15 10:20 == 47.3
12/26/15 10:25 == 47.4
12/26/15 10:30 == 47.3
12/26/15 10:35 == 47.3
12/26/15 10:40 == 47.1
12/26/15 10:45 == 47.2
12/26/15 10:50 == 47.4
12/26/15 10:55 == 47.1
12/26/15 11:00 == 47.3
12/26/15 11:05 == 47.4
12/26/15 11:10 == 47.2
12/26/15 11:15 == 47.4
12/26/15 11:20 == 47.2
12/26/15 11:25 == 47.5
12/26/15 11:30 == 47.4
12/26/15 11:35 == 47.5
12/26/15 11:40 == 47.4
12/26/15 11:45 == 47.3
12/26/15 11:50 == 47.2
12/26/15 11:55 == 46.9

Pumpback Station Discharge (0364)

12/26/15 12:00 == 47.2
12/26/15 12:05 == 47.3
12/26/15 12:10 == 47.5
12/26/15 12:15 == 47.6
12/26/15 12:20 == 47.5
12/26/15 12:25 == 47.5
12/26/15 12:30 == 47.5
12/26/15 12:35 == 47.4
12/26/15 12:40 == 47.5
12/26/15 12:45 == 47.4
12/26/15 12:50 == 47.6
12/26/15 12:55 == 47.3
12/26/15 13:00 == 47.5
12/26/15 13:05 == 47.6
12/26/15 13:10 == 47.3
12/26/15 13:15 == 47.4
12/26/15 13:20 == 47.4
12/26/15 13:25 == 47.4
12/26/15 13:30 == 47.4
12/26/15 13:35 == 47.6
12/26/15 13:40 == 47.4
12/26/15 13:45 == 47.6
12/26/15 13:50 == 47.5
12/26/15 13:55 == 47.4
12/26/15 14:00 == 47.3
12/26/15 14:05 == 47.7
12/26/15 14:10 == 47.5
12/26/15 14:15 == 47.6
12/26/15 14:20 == 47.4
12/26/15 14:25 == 47
12/26/15 14:30 == 47.4
12/26/15 14:35 == 47.6
12/26/15 14:40 == 47.4
12/26/15 14:45 == 47.6
12/26/15 14:50 == 47.4
12/26/15 14:55 == 47.1
12/26/15 15:00 == 47.4
12/26/15 15:05 == 47.5
12/26/15 15:10 == 47.5
12/26/15 15:15 == 47.4
12/26/15 15:20 == 47.3
12/26/15 15:25 == 47.2
12/26/15 15:30 == 47.3
12/26/15 15:35 == 47.2
12/26/15 15:40 == 47
12/26/15 15:45 == 47.2
12/26/15 15:50 == 47.4
12/26/15 15:55 == 47.2
12/26/15 16:00 == 47.2
12/26/15 16:05 == 47.3
12/26/15 16:10 == 47.4
12/26/15 16:15 == 47.2
12/26/15 16:20 == 47.3
12/26/15 16:25 == 47.2
12/26/15 16:30 == 47.3
12/26/15 16:35 == 47.1
12/26/15 16:40 == 47.1
12/26/15 16:45 == 47.2
12/26/15 16:50 == 47.2
12/26/15 16:55 == 47.2
12/26/15 17:00 == 47.2
12/26/15 17:05 == 47.3
12/26/15 17:10 == 47.3
12/26/15 17:15 == 47.2
12/26/15 17:20 == 47.3
12/26/15 17:25 == 47.3
12/26/15 17:30 == 47.2
12/26/15 17:35 == 47.1
12/26/15 17:40 == 47.2
12/26/15 17:45 == 47
12/26/15 17:50 == 47.1
12/26/15 17:55 == 47.2
12/26/15 18:00 == 47.3
12/26/15 18:05 == 47.1
12/26/15 18:10 == 47.3
12/26/15 18:15 == 47.1
12/26/15 18:20 == 47.1
12/26/15 18:25 == 47.1
12/26/15 18:30 == 47
12/26/15 18:35 == 47.2
12/26/15 18:40 == 47.1
12/26/15 18:45 == 47
12/26/15 18:50 == 47.1
12/26/15 18:55 == 47.2
12/26/15 19:00 == 47.2
12/26/15 19:05 == 47
12/26/15 19:10 == 47.1
12/26/15 19:15 == 47
12/26/15 19:20 == 47
12/26/15 19:25 == 47.2
12/26/15 19:30 == 47.2
12/26/15 19:35 == 47.3
12/26/15 19:40 == 47.1
12/26/15 19:45 == 47.1
12/26/15 19:50 == 47.1
12/26/15 19:55 == 47.1
12/26/15 20:00 == 47
12/26/15 20:05 == 47
12/26/15 20:10 == 47.2
12/26/15 20:15 == 47.1
12/26/15 20:20 == 47.1
12/26/15 20:25 == 47.1
12/26/15 20:30 == 47.2
12/26/15 20:35 == 47.2
12/26/15 20:40 == 47.1
12/26/15 20:45 == 47.2
12/26/15 20:50 == 47.1
12/26/15 20:55 == 47.2
12/26/15 21:00 == 47.2
12/26/15 21:05 == 47.1
12/26/15 21:10 == 47.1
12/26/15 21:15 == 47
12/26/15 21:20 == 47.1
12/26/15 21:25 == 47.2
12/26/15 21:30 == 47.3
12/26/15 21:35 == 47.1
12/26/15 21:40 == 47.3
12/26/15 21:45 == 47.2
12/26/15 21:50 == 47.4
12/26/15 21:55 == 47.3
12/26/15 22:00 == 47.1
12/26/15 22:05 == 47.3
12/26/15 22:10 == 47.1
12/26/15 22:15 == 47.2
12/26/15 22:20 == 47.2
12/26/15 22:25 == 47.3
12/26/15 22:30 == 47.1
12/26/15 22:35 == 47.3
12/26/15 22:40 == 47.3
12/26/15 22:45 == 47.3
12/26/15 22:50 == 47.1
12/26/15 22:55 == 47.1
12/26/15 23:00 == 47.2
12/26/15 23:05 == 47.2
12/26/15 23:10 == 47.1
12/26/15 23:15 == 47.1
12/26/15 23:20 == 47.2
12/26/15 23:25 == 47
12/26/15 23:30 == 47.2
12/26/15 23:35 == 47.2
12/26/15 23:40 == 47.1
12/26/15 23:45 == 47.1
12/26/15 23:50 == 47.2
12/26/15 23:55 == 47.3
12/27/15 0:00 == 47.1
12/27/15 0:05 == 47.1
12/27/15 0:10 == 47
12/27/15 0:15 == 47
12/27/15 0:20 == 47.1
12/27/15 0:25 == 47.1
12/27/15 0:30 == 47.2
12/27/15 0:35 == 47.1
12/27/15 0:40 == 47.2
12/27/15 0:45 == 47
12/27/15 0:50 == 47
12/27/15 0:55 == 47.2
12/27/15 1:00 == 47.2
12/27/15 1:05 == 47.1
12/27/15 1:10 == 47
12/27/15 1:15 == 47.2
12/27/15 1:20 == 47.2
12/27/15 1:25 == 47.2
12/27/15 1:30 == 47.1
12/27/15 1:35 == 47.1
12/27/15 1:40 == 47
12/27/15 1:45 == 47.1
12/27/15 1:50 == 47
12/27/15 1:55 == 47.1
12/27/15 2:00 == 47.1
12/27/15 2:05 == 47.1
12/27/15 2:10 == 47.2
12/27/15 2:15 == 47.1
12/27/15 2:20 == 47.1
12/27/15 2:25 == 47
12/27/15 2:30 == 47.2
12/27/15 2:35 == 47
12/27/15 2:40 == 47.1
12/27/15 2:45 == 47.1
12/27/15 2:50 == 47
12/27/15 2:55 == 47.1
12/27/15 3:00 == 47.1
12/27/15 3:05 == 47.2
12/27/15 3:10 == 47
12/27/15 3:15 == 47
12/27/15 3:20 == 47
12/27/15 3:25 == 47.1
12/27/15 3:30 == 47
12/27/15 3:35 == 47.1
12/27/15 3:40 == 47.2
12/27/15 3:45 == 47
12/27/15 3:50 == 47.1
12/27/15 3:55 == 47
12/27/15 4:00 == 47.1
12/27/15 4:05 == 47.1
12/27/15 4:10 == 47
12/27/15 4:15 == 47.1
12/27/15 4:20 == 47.1
12/27/15 4:25 == 47.2
12/27/15 4:30 == 47.2
12/27/15 4:35 == 47.1
12/27/15 4:40 == 47
12/27/15 4:45 == 47
12/27/15 4:50 == 47.1
12/27/15 4:55 == 47
12/27/15 5:00 == 47
12/27/15 5:05 == 47.1
12/27/15 5:10 == 47
12/27/15 5:15 == 47.1
12/27/15 5:20 == 47
12/27/15 5:25 == 47
12/27/15 5:30 == 47
12/27/15 5:35 == 47.2
12/27/15 5:40 == 47.1
12/27/15 5:45 == 47.1
12/27/15 5:50 == 47
12/27/15 5:55 == 46.9

Pumpback Station Discharge (0364)

12/27/15 6:00 == 47.1
12/27/15 6:05 == 47.1
12/27/15 6:10 == 47.2
12/27/15 6:15 == 47.1
12/27/15 6:20 == 47.1
12/27/15 6:25 == 47
12/27/15 6:30 == 47.1
12/27/15 6:35 == 47.1
12/27/15 6:40 == 46.9
12/27/15 6:45 == 47.1
12/27/15 6:50 == 47
12/27/15 6:55 == 47.5
12/27/15 7:00 == 47.2
12/27/15 7:05 == 47.2
12/27/15 7:10 == 47.3
12/27/15 7:15 == 47.4
12/27/15 7:20 == 47.2
12/27/15 7:25 == 47.5
12/27/15 7:30 == 47.4
12/27/15 7:35 == 47.3
12/27/15 7:40 == 47.5
12/27/15 7:45 == 47.4
12/27/15 7:50 == 47.4
12/27/15 7:55 == 47.6
12/27/15 8:00 == 47.7
12/27/15 8:05 == 47.6
12/27/15 8:10 == 47.6
12/27/15 8:15 == 47.5
12/27/15 8:20 == 47.6
12/27/15 8:25 == 46.9
12/27/15 8:30 == 47.3
12/27/15 8:35 == 47.8
12/27/15 8:40 == 47.6
12/27/15 8:45 == 47.7
12/27/15 8:50 == 47.6
12/27/15 8:55 == 47.4
12/27/15 9:00 == 47.7
12/27/15 9:05 == 47.6
12/27/15 9:10 == 47.5
12/27/15 9:15 == 47.5
12/27/15 9:20 == 47.7
12/27/15 9:25 == 47.6
12/27/15 9:30 == 47.6
12/27/15 9:35 == 47.6
12/27/15 9:40 == 47.6
12/27/15 9:45 == 47.5
12/27/15 9:50 == 47.6
12/27/15 9:55 == 47.3
12/27/15 10:00 == 47.5
12/27/15 10:05 == 47.4
12/27/15 10:10 == 47.4
12/27/15 10:15 == 47.4
12/27/15 10:20 == 47.5
12/27/15 10:25 == 47.4
12/27/15 10:30 == 47.4
12/27/15 10:35 == 47.5
12/27/15 10:40 == 46.9
12/27/15 10:45 == 47.3
12/27/15 10:50 == 47.4
12/27/15 10:55 == 47.3
12/27/15 11:00 == 47.2
12/27/15 11:05 == 47.3
12/27/15 11:10 == 47.5
12/27/15 11:15 == 47.3
12/27/15 11:20 == 47.2
12/27/15 11:25 == 47.2
12/27/15 11:30 == 47.3
12/27/15 11:35 == 47.4
12/27/15 11:40 == 47.4
12/27/15 11:45 == 47.3
12/27/15 11:50 == 47.5
12/27/15 11:55 == 47.2
12/27/15 12:00 == 47.2
12/27/15 12:05 == 47.4
12/27/15 12:10 == 47.5
12/27/15 12:15 == 47.5
12/27/15 12:20 == 47.3
12/27/15 12:25 == 47.5
12/27/15 12:30 == 47.3
12/27/15 12:35 == 47.6
12/27/15 12:40 == 47.3
12/27/15 12:45 == 47.4
12/27/15 12:50 == 47.4
12/27/15 12:55 == 47.4
12/27/15 13:00 == 47.6
12/27/15 13:05 == 47.6
12/27/15 13:10 == 47.4
12/27/15 13:15 == 47.4
12/27/15 13:20 == 47.6
12/27/15 13:25 == 47.4
12/27/15 13:30 == 47.5
12/27/15 13:35 == 47.3
12/27/15 13:40 == 47.5
12/27/15 13:45 == 47.7
12/27/15 13:50 == 47.7
12/27/15 13:55 == 47.3
12/27/15 14:00 == 47.4
12/27/15 14:05 == 47.6
12/27/15 14:10 == 47.6
12/27/15 14:15 == 47.6
12/27/15 14:20 == 47.6
12/27/15 14:25 == 47.7
12/27/15 14:30 == 47.5
12/27/15 14:35 == 47.1
12/27/15 14:40 == 47.1
12/27/15 14:45 == 47.1
12/27/15 14:50 == 47.2
12/27/15 14:55 == 47.1
12/27/15 15:00 == 47.2
12/27/15 15:05 == 47.4
12/27/15 15:10 == 47.2
12/27/15 15:15 == 47.3
12/27/15 15:20 == 47.2
12/27/15 15:25 == 47.2
12/27/15 15:30 == 47.2
12/27/15 15:35 == 47.3
12/27/15 15:40 == 47
12/27/15 15:45 == 47.2
12/27/15 15:50 == 47.1
12/27/15 15:55 == 47.1
12/27/15 16:00 == 47.2
12/27/15 16:05 == 47.2
12/27/15 16:10 == 47.1
12/27/15 16:15 == 47.1
12/27/15 16:20 == 47.1
12/27/15 16:25 == 47.1
12/27/15 16:30 == 47.1
12/27/15 16:35 == 47
12/27/15 16:40 == 47
12/27/15 16:45 == 47
12/27/15 16:50 == 47.1
12/27/15 16:55 == 47.2
12/27/15 17:00 == 47.2
12/27/15 17:05 == 47.2
12/27/15 17:10 == 47.2
12/27/15 17:15 == 47.2
12/27/15 17:20 == 47.1
12/27/15 17:25 == 47.2
12/27/15 17:30 == 47
12/27/15 17:35 == 47.3
12/27/15 17:40 == 47
12/27/15 17:45 == 47.2
12/27/15 17:50 == 47.2
12/27/15 17:55 == 47.2
12/27/15 18:00 == 47.1
12/27/15 18:05 == 47.3
12/27/15 18:10 == 47.1
12/27/15 18:15 == 47.2
12/27/15 18:20 == 47.2
12/27/15 18:25 == 47
12/27/15 18:30 == 47
12/27/15 18:35 == 47.1
12/27/15 18:40 == 47.2
12/27/15 18:45 == 47.2
12/27/15 18:50 == 47.2
12/27/15 18:55 == 46.9
12/27/15 19:00 == 47.1
12/27/15 19:05 == 47.1
12/27/15 19:10 == 47.1
12/27/15 19:15 == 47.1
12/27/15 19:20 == 47.1
12/27/15 19:25 == 47
12/27/15 19:30 == 47
12/27/15 19:35 == 47.1
12/27/15 19:40 == 47.1
12/27/15 19:45 == 47
12/27/15 19:50 == 47.1
12/27/15 19:55 == 47
12/27/15 20:00 == 47.1
12/27/15 20:05 == 47
12/27/15 20:10 == 47
12/27/15 20:15 == 47
12/27/15 20:20 == 47.2
12/27/15 20:25 == 47
12/27/15 20:30 == 47
12/27/15 20:35 == 47.1
12/27/15 20:40 == 47.2
12/27/15 20:45 == 47.1
12/27/15 20:50 == 47.2
12/27/15 20:55 == 47.1
12/27/15 21:00 == 47.1
12/27/15 21:05 == 47.1
12/27/15 21:10 == 47.1
12/27/15 21:15 == 47.1
12/27/15 21:20 == 47.1
12/27/15 21:25 == 47.2
12/27/15 21:30 == 47.2
12/27/15 21:35 == 47.3
12/27/15 21:40 == 47.2
12/27/15 21:45 == 47.4
12/27/15 21:50 == 47.3
12/27/15 21:55 == 47.2
12/27/15 22:00 == 47.1
12/27/15 22:05 == 47.1
12/27/15 22:10 == 47.1
12/27/15 22:15 == 47.1
12/27/15 22:20 == 47.2
12/27/15 22:25 == 47.3
12/27/15 22:30 == 47.2
12/27/15 22:35 == 47.3
12/27/15 22:40 == 47.2
12/27/15 22:45 == 47.2
12/27/15 22:50 == 47.3
12/27/15 22:55 == 47
12/27/15 23:00 == 47.2
12/27/15 23:05 == 47.1
12/27/15 23:10 == 47.2
12/27/15 23:15 == 47
12/27/15 23:20 == 47.1
12/27/15 23:25 == 47
12/27/15 23:30 == 47
12/27/15 23:35 == 47.2
12/27/15 23:40 == 47
12/27/15 23:45 == 47.1
12/27/15 23:50 == 47.2
12/27/15 23:55 == 47.1

Pumpback Station Discharge (0364)

12/28/15 0:00 == 47.1
12/28/15 0:05 == 47.1
12/28/15 0:10 == 47.1
12/28/15 0:15 == 47
12/28/15 0:20 == 47
12/28/15 0:25 == 47
12/28/15 0:30 == 47.1
12/28/15 0:35 == 47.1
12/28/15 0:40 == 47.2
12/28/15 0:45 == 47.1
12/28/15 0:50 == 47
12/28/15 0:55 == 47
12/28/15 1:00 == 47.2
12/28/15 1:05 == 47.1
12/28/15 1:10 == 47
12/28/15 1:15 == 47.1
12/28/15 1:20 == 47.1
12/28/15 1:25 == 47
12/28/15 1:30 == 47.1
12/28/15 1:35 == 47.2
12/28/15 1:40 == 47.1
12/28/15 1:45 == 47.1
12/28/15 1:50 == 47
12/28/15 1:55 == 47
12/28/15 2:00 == 47
12/28/15 2:05 == 47
12/28/15 2:10 == 47.2
12/28/15 2:15 == 47.2
12/28/15 2:20 == 47.1
12/28/15 2:25 == 47
12/28/15 2:30 == 47
12/28/15 2:35 == 47
12/28/15 2:40 == 47.1
12/28/15 2:45 == 47
12/28/15 2:50 == 47.1
12/28/15 2:55 == 47.1
12/28/15 3:00 == 47
12/28/15 3:05 == 47
12/28/15 3:10 == 47
12/28/15 3:15 == 47.1
12/28/15 3:20 == 47
12/28/15 3:25 == 47.1
12/28/15 3:30 == 47
12/28/15 3:35 == 47.2
12/28/15 3:40 == 47.1
12/28/15 3:45 == 47
12/28/15 3:50 == 47
12/28/15 3:55 == 47
12/28/15 4:00 == 47.2
12/28/15 4:05 == 47.1
12/28/15 4:10 == 47.1
12/28/15 4:15 == 47.1
12/28/15 4:20 == 47.1
12/28/15 4:25 == 47
12/28/15 4:30 == 46.9
12/28/15 4:35 == 47.1
12/28/15 4:40 == 47.1
12/28/15 4:45 == 47
12/28/15 4:50 == 47.1
12/28/15 4:55 == 47
12/28/15 5:00 == 47.1
12/28/15 5:05 == 47.2
12/28/15 5:10 == 47.1
12/28/15 5:15 == 47.1
12/28/15 5:20 == 47.2
12/28/15 5:25 == 47.2
12/28/15 5:30 == 47.1
12/28/15 5:35 == 47.1
12/28/15 5:40 == 47.1
12/28/15 5:45 == 47.2
12/28/15 5:50 == 47.1
12/28/15 5:55 == 47
12/28/15 6:00 == 47.2
12/28/15 6:05 == 47.4
12/28/15 6:10 == 47.2
12/28/15 6:15 == 47.3
12/28/15 6:20 == 47.1
12/28/15 6:25 == 47.1
12/28/15 6:30 == 47.1
12/28/15 6:35 == 47.2
12/28/15 6:40 == 47
12/28/15 6:45 == 47.1
12/28/15 6:50 == 47.2
12/28/15 6:55 == 47.4
12/28/15 7:00 == 47.2
12/28/15 7:05 == 47.2
12/28/15 7:10 == 47.3
12/28/15 7:15 == 47.3
12/28/15 7:20 == 47.3
12/28/15 7:25 == 47.2
12/28/15 7:30 == 47.2
12/28/15 7:35 == 47.4
12/28/15 7:40 == 46.7
12/28/15 7:45 == 47.2
12/28/15 7:50 == 47.1
12/28/15 7:55 == 47.1
12/28/15 8:00 == 47.2
12/28/15 8:05 == 47.1
12/28/15 8:10 == 47.2
12/28/15 8:15 == 47.2
12/28/15 8:20 == 47.3
12/28/15 8:25 == 47.1
12/28/15 8:30 == 47.3
12/28/15 8:35 == 47.3
12/28/15 8:40 == 47.3
12/28/15 8:45 == 47.2
12/28/15 8:50 == 47.2
12/28/15 8:55 == 47.2
12/28/15 9:00 == 47.3
12/28/15 9:05 == 47.2
12/28/15 9:10 == 47.1
12/28/15 9:15 == 47.1
12/28/15 9:20 == 47.2
12/28/15 9:25 == 47.3
12/28/15 9:30 == 47.3
12/28/15 9:35 == 47.3
12/28/15 9:40 == 47.2
12/28/15 9:45 == 47.2
12/28/15 9:50 == 47.5
12/28/15 9:55 == 47
12/28/15 10:00 == 47.3
12/28/15 10:05 == 47.2
12/28/15 10:10 == 47.2
12/28/15 10:15 == 47.2
12/28/15 10:20 == 47.3
12/28/15 10:25 == 47.2
12/28/15 10:30 == 47.2
12/28/15 10:35 == 47.4
12/28/15 10:40 == 47.1
12/28/15 10:45 == 47.3
12/28/15 10:50 == 47.5
12/28/15 10:55 == 47.3
12/28/15 11:00 == 47.4
12/28/15 11:05 == 47.4
12/28/15 11:10 == 47.3
12/28/15 11:15 == 47.2
12/28/15 11:20 == 47.4
12/28/15 11:25 == 47.4
12/28/15 11:30 == 47.4
12/28/15 11:35 == 47.4
12/28/15 11:40 == 47.5
12/28/15 11:45 == 47.3
12/28/15 11:50 == 47.3
12/28/15 11:55 == 46.9
12/28/15 12:00 == 47.2
12/28/15 12:05 == 47.3
12/28/15 12:10 == 47.3
12/28/15 12:15 == 47.3
12/28/15 12:20 == 47.3
12/28/15 12:25 == 47.3
12/28/15 12:30 == 47.2
12/28/15 12:35 == 47.4
12/28/15 12:40 == 47.2
12/28/15 12:45 == 47.4
12/28/15 12:50 == 47.3
12/28/15 12:55 == 47.2
12/28/15 13:00 == 47.2
12/28/15 13:05 == 47.3
12/28/15 13:10 == 47.3
12/28/15 13:15 == 47.3
12/28/15 13:20 == 47.4
12/28/15 13:25 == 47.3
12/28/15 13:30 == 47.3
12/28/15 13:35 == 47.3
12/28/15 13:40 == 47.3
12/28/15 13:45 == 47.3
12/28/15 13:50 == 47.5
12/28/15 13:55 == 47.3
12/28/15 14:00 == 47.3
12/28/15 14:05 == 47.2
12/28/15 14:10 == 47.5
12/28/15 14:15 == #
12/28/15 14:20 == 47.4
12/28/15 14:25 == 47.4
12/28/15 14:30 == 47.3
12/28/15 14:35 == 47.4
12/28/15 14:40 == 47.3
12/28/15 14:45 == 47.2
12/28/15 14:50 == 47.3
12/28/15 14:55 == 47.3
12/28/15 15:00 == 47.3
12/28/15 15:05 == 47.5
12/28/15 15:10 == 47.4
12/28/15 15:15 == 47.2
12/28/15 15:20 == 47.3
12/28/15 15:25 == 47.3
12/28/15 15:30 == 47.3
12/28/15 15:35 == 47.3
12/28/15 15:40 == 47.4
12/28/15 15:45 == 47.1
12/28/15 15:50 == 47.3
12/28/15 15:55 == 47.1
12/28/15 16:00 == 47.3
12/28/15 16:05 == 47.3
12/28/15 16:10 == 47.4
12/28/15 16:15 == 47.3
12/28/15 16:20 == 47.3
12/28/15 16:25 == 47.1
12/28/15 16:30 == 47.2
12/28/15 16:35 == 47.4
12/28/15 16:40 == 47.3
12/28/15 16:45 == 47.3
12/28/15 16:50 == 47.2
12/28/15 16:55 == 47.2
12/28/15 17:00 == 47.3
12/28/15 17:05 == 47.2
12/28/15 17:10 == 47.2
12/28/15 17:15 == 47.3
12/28/15 17:20 == 47.3
12/28/15 17:25 == 47.3
12/28/15 17:30 == 47.3
12/28/15 17:35 == 47.3
12/28/15 17:40 == 47.3
12/28/15 17:45 == 47.3
12/28/15 17:50 == 47.3
12/28/15 17:55 == 47.3

Pumpback Station Discharge (0364)

12/28/15 18:00 == 47.4
12/28/15 18:05 == 47.3
12/28/15 18:10 == 47.4
12/28/15 18:15 == 47.4
12/28/15 18:20 == 47.4
12/28/15 18:25 == 47.3
12/28/15 18:30 == 47.2
12/28/15 18:35 == 47.3
12/28/15 18:40 == 47.2
12/28/15 18:45 == 47.3
12/28/15 18:50 == 47.3
12/28/15 18:55 == 47.3
12/28/15 19:00 == 47.2
12/28/15 19:05 == 47.2
12/28/15 19:10 == 47.3
12/28/15 19:15 == 47.3
12/28/15 19:20 == 47.3
12/28/15 19:25 == 47.3
12/28/15 19:30 == 47.3
12/28/15 19:35 == 47.3
12/28/15 19:40 == 47.3
12/28/15 19:45 == 47.3
12/28/15 19:50 == 47.3
12/28/15 19:55 == 47.2
12/28/15 20:00 == 47.2
12/28/15 20:05 == 47.2
12/28/15 20:10 == 47.3
12/28/15 20:15 == 47.2
12/28/15 20:20 == 47.4
12/28/15 20:25 == 47.4
12/28/15 20:30 == 47.3
12/28/15 20:35 == 47.3
12/28/15 20:40 == 47.2
12/28/15 20:45 == 47.2
12/28/15 20:50 == 47.3
12/28/15 20:55 == 47.4
12/28/15 21:00 == 47.3
12/28/15 21:05 == 47.3
12/28/15 21:10 == 47.3
12/28/15 21:15 == 47.3
12/28/15 21:20 == 47.3
12/28/15 21:25 == 47.2
12/28/15 21:30 == 47.3
12/28/15 21:35 == 47.3
12/28/15 21:40 == 47.4
12/28/15 21:45 == 47.4
12/28/15 21:50 == 47.4
12/28/15 21:55 == 47.4
12/28/15 22:00 == 47.3
12/28/15 22:05 == 47.4
12/28/15 22:10 == 47.4
12/28/15 22:15 == 47.3
12/28/15 22:20 == 47.3
12/28/15 22:25 == 47.4
12/28/15 22:30 == 47.3
12/28/15 22:35 == 47.2
12/28/15 22:40 == 47.3
12/28/15 22:45 == 47.4
12/28/15 22:50 == 47.4
12/28/15 22:55 == 47.3
12/28/15 23:00 == 47.4
12/28/15 23:05 == 47.4
12/28/15 23:10 == 47.3
12/28/15 23:15 == 47.3
12/28/15 23:20 == 47.4
12/28/15 23:25 == 47.3
12/28/15 23:30 == 47.3
12/28/15 23:35 == 47.2
12/28/15 23:40 == 47.3
12/28/15 23:45 == 47.4
12/28/15 23:50 == 47.4
12/28/15 23:55 == 47.3
12/29/15 0:00 == 47.3
12/29/15 0:05 == 47.4
12/29/15 0:10 == 47.4
12/29/15 0:15 == 47.3
12/29/15 0:20 == 47.2
12/29/15 0:25 == 47.3
12/29/15 0:30 == 47.2
12/29/15 0:35 == 47.4
12/29/15 0:40 == 47.3
12/29/15 0:45 == 47.3
12/29/15 0:50 == 47.3
12/29/15 0:55 == 47.3
12/29/15 1:00 == 47.3
12/29/15 1:05 == 47.4
12/29/15 1:10 == 47.4
12/29/15 1:15 == 47.4
12/29/15 1:20 == 47.4
12/29/15 1:25 == 47.2
12/29/15 1:30 == 47.4
12/29/15 1:35 == 47.3
12/29/15 1:40 == 47.2
12/29/15 1:45 == 47.3
12/29/15 1:50 == 47.2
12/29/15 1:55 == 47.2
12/29/15 2:00 == 47.3
12/29/15 2:05 == 47.4
12/29/15 2:10 == 47.4
12/29/15 2:15 == 47.3
12/29/15 2:20 == 47.4
12/29/15 2:25 == 47.3
12/29/15 2:30 == 47.4
12/29/15 2:35 == 47.4
12/29/15 2:40 == 47.3
12/29/15 2:45 == 47.3
12/29/15 2:50 == 47.4
12/29/15 2:55 == 47.5
12/29/15 3:00 == 47.4
12/29/15 3:05 == 47.3
12/29/15 3:10 == 47.4
12/29/15 3:15 == 47.3
12/29/15 3:20 == 47.2
12/29/15 3:25 == 47.4
12/29/15 3:30 == 47.4
12/29/15 3:35 == 47.3
12/29/15 3:40 == 47.2
12/29/15 3:45 == 47.3
12/29/15 3:50 == 47.4
12/29/15 3:55 == 47.4
12/29/15 4:00 == 47.3
12/29/15 4:05 == 47.3
12/29/15 4:10 == 47.4
12/29/15 4:15 == 47.3
12/29/15 4:20 == 47.3
12/29/15 4:25 == 47.2
12/29/15 4:30 == 47.3
12/29/15 4:35 == 47.3
12/29/15 4:40 == 47.4
12/29/15 4:45 == 47.3
12/29/15 4:50 == 47.2
12/29/15 4:55 == 47.3
12/29/15 5:00 == 47.3
12/29/15 5:05 == 47.3
12/29/15 5:10 == 47.4
12/29/15 5:15 == 47.3
12/29/15 5:20 == 47.3
12/29/15 5:25 == 47.2
12/29/15 5:30 == 47.2
12/29/15 5:35 == 47.2
12/29/15 5:40 == 47.3
12/29/15 5:45 == 47.2
12/29/15 5:50 == 47.1
12/29/15 5:55 == 47.3
12/29/15 6:00 == 47.4
12/29/15 6:05 == 47.3
12/29/15 6:10 == 47.2
12/29/15 6:15 == 47.2
12/29/15 6:20 == 47.3
12/29/15 6:25 == 47.3
12/29/15 6:30 == 47.2
12/29/15 6:35 == 47.2
12/29/15 6:40 == 47.3
12/29/15 6:45 == 47.2
12/29/15 6:50 == 47.3
12/29/15 6:55 == 47.3
12/29/15 7:00 == 47.7
12/29/15 7:05 == 47.4
12/29/15 7:10 == 47.3
12/29/15 7:15 == 47.2
12/29/15 7:20 == 47.3
12/29/15 7:25 == 47.4
12/29/15 7:30 == 47.4
12/29/15 7:35 == 47.4
12/29/15 7:40 == 47.5
12/29/15 7:45 == 47.1
12/29/15 7:50 == 47.4
12/29/15 7:55 == 47.3
12/29/15 8:00 == 47.4
12/29/15 8:05 == 47.4
12/29/15 8:10 == 47.2
12/29/15 8:15 == 47.4
12/29/15 8:20 == 47.3
12/29/15 8:25 == 47.3
12/29/15 8:30 == 47.3
12/29/15 8:35 == 47.3
12/29/15 8:40 == 47.3
12/29/15 8:45 == 47.4
12/29/15 8:50 == 47.5
12/29/15 8:55 == 47.3
12/29/15 9:00 == 47.3
12/29/15 9:05 == 47.4
12/29/15 9:10 == 47.4
12/29/15 9:15 == 47.2
12/29/15 9:20 == 47.2
12/29/15 9:25 == 47.5
12/29/15 9:30 == 47.3
12/29/15 9:35 == 47.4
12/29/15 9:40 == 47.4
12/29/15 9:45 == 47.3
12/29/15 9:50 == 47.5
12/29/15 9:55 == 47.4
12/29/15 10:00 == 47.3
12/29/15 10:05 == 47.4
12/29/15 10:10 == 47.4
12/29/15 10:15 == 47.4
12/29/15 10:20 == 47.4
12/29/15 10:25 == 47.4
12/29/15 10:30 == 47.4
12/29/15 10:35 == 47.1
12/29/15 10:40 == 47.4
12/29/15 10:45 == 47.3
12/29/15 10:50 == 47.3
12/29/15 10:55 == 47.5
12/29/15 11:00 == 47.3
12/29/15 11:05 == 47.5
12/29/15 11:10 == 47.4
12/29/15 11:15 == 47.5
12/29/15 11:20 == 47.5
12/29/15 11:25 == 47.4
12/29/15 11:30 == 47.5
12/29/15 11:35 == 47.4
12/29/15 11:40 == 47.5
12/29/15 11:45 == 47.4
12/29/15 11:50 == 47.6
12/29/15 11:55 == 47.2

Pumpback Station Discharge (0364)

12/29/15 12:00 == 47.1
12/29/15 12:05 == 47.2
12/29/15 12:10 == 47.5
12/29/15 12:15 == 47.3
12/29/15 12:20 == 47.4
12/29/15 12:25 == 47.5
12/29/15 12:30 == 47.3
12/29/15 12:35 == 47.3
12/29/15 12:40 == 47.4
12/29/15 12:45 == 47.4
12/29/15 12:50 == 47.3
12/29/15 12:55 == 47.4
12/29/15 13:00 == 47.3
12/29/15 13:05 == 47.5
12/29/15 13:10 == 47.4
12/29/15 13:15 == 47.4
12/29/15 13:20 == 47.4
12/29/15 13:25 == 47.5
12/29/15 13:30 == 47.4
12/29/15 13:35 == 47.3
12/29/15 13:40 == 47.5
12/29/15 13:45 == 47.1
12/29/15 13:50 == 47.5
12/29/15 13:55 == 47.3
12/29/15 14:00 == 47.3
12/29/15 14:05 == 47.3
12/29/15 14:10 == 47.3
12/29/15 14:15 == 47.5
12/29/15 14:20 == 47.3
12/29/15 14:25 == 47.3
12/29/15 14:30 == 47.4
12/29/15 14:35 == 47.4
12/29/15 14:40 == 47.4
12/29/15 14:45 == 47.1
12/29/15 14:50 == 47.4
12/29/15 14:55 == 47.5
12/29/15 15:00 == 47.3
12/29/15 15:05 == 47.3
12/29/15 15:10 == 47.4
12/29/15 15:15 == 47.4
12/29/15 15:20 == 47.3
12/29/15 15:25 == 47
12/29/15 15:30 == 47.2
12/29/15 15:35 == 47.1
12/29/15 15:40 == 47.2
12/29/15 15:45 == 47.3
12/29/15 15:50 == 47.3
12/29/15 15:55 == 47.2
12/29/15 16:00 == 47.1
12/29/15 16:05 == 47.3
12/29/15 16:10 == 47
12/29/15 16:15 == 47
12/29/15 16:20 == 47.1
12/29/15 16:25 == 46.9
12/29/15 16:30 == 47.1
12/29/15 16:35 == 47
12/29/15 16:40 == 47
12/29/15 16:45 == 46.9
12/29/15 16:50 == 47.1
12/29/15 16:55 == 47.1
12/29/15 17:00 == 46.9
12/29/15 17:05 == 47
12/29/15 17:10 == 46.9
12/29/15 17:15 == 46.9
12/29/15 17:20 == 46.8
12/29/15 17:25 == 47
12/29/15 17:30 == 46.9
12/29/15 17:35 == 46.9
12/29/15 17:40 == 46.9
12/29/15 17:45 == 47
12/29/15 17:50 == 47
12/29/15 17:55 == 46.9
12/29/15 18:00 == 46.9
12/29/15 18:05 == 47
12/29/15 18:10 == 46.9
12/29/15 18:15 == 46.9
12/29/15 18:20 == 46.9
12/29/15 18:25 == 46.9
12/29/15 18:30 == 46.8
12/29/15 18:35 == 46.8
12/29/15 18:40 == 46.8
12/29/15 18:45 == 46.9
12/29/15 18:50 == 46.9
12/29/15 18:55 == 46.9
12/29/15 19:00 == 46.9
12/29/15 19:05 == 46.8
12/29/15 19:10 == 47
12/29/15 19:15 == 46.9
12/29/15 19:20 == 46.9
12/29/15 19:25 == 46.8
12/29/15 19:30 == 47.1
12/29/15 19:35 == 46.9
12/29/15 19:40 == 47.1
12/29/15 19:45 == 46.9
12/29/15 19:50 == 46.9
12/29/15 19:55 == 47
12/29/15 20:00 == 47
12/29/15 20:05 == 46.9
12/29/15 20:10 == 46.9
12/29/15 20:15 == 47
12/29/15 20:20 == 46.8
12/29/15 20:25 == 46.9
12/29/15 20:30 == 46.9
12/29/15 20:35 == 46.9
12/29/15 20:40 == 46.8
12/29/15 20:45 == 46.9
12/29/15 20:50 == 47
12/29/15 20:55 == 46.9
12/29/15 21:00 == 46.8
12/29/15 21:05 == 46.5
12/29/15 21:10 == 46.9
12/29/15 21:15 == 46.9
12/29/15 21:20 == 47
12/29/15 21:25 == 46.9
12/29/15 21:30 == 47
12/29/15 21:35 == 47
12/29/15 21:40 == 46.8
12/29/15 21:45 == 46.7
12/29/15 21:50 == 46.6
12/29/15 21:55 == 46.9
12/29/15 22:00 == 47.1
12/29/15 22:05 == 46.6
12/29/15 22:10 == 46.5
12/29/15 22:15 == 46.8
12/29/15 22:20 == 46.8
12/29/15 22:25 == 46.7
12/29/15 22:30 == 46.6
12/29/15 22:35 == 46.9
12/29/15 22:40 == 46.8
12/29/15 22:45 == 46.4
12/29/15 22:50 == 46.7
12/29/15 22:55 == 46.8
12/29/15 23:00 == 46.9
12/29/15 23:05 == 46.5
12/29/15 23:10 == 46.6
12/29/15 23:15 == 46.9
12/29/15 23:20 == 46.9
12/29/15 23:25 == 46.5
12/29/15 23:30 == 46.7
12/29/15 23:35 == 47.1
12/29/15 23:40 == 46.7
12/29/15 23:45 == 46.5
12/29/15 23:50 == 46.9
12/29/15 23:55 == 47
12/30/15 0:00 == 46.6
12/30/15 0:05 == 46.6
12/30/15 0:10 == 46.9
12/30/15 0:15 == 46.9
12/30/15 0:20 == 46.5
12/30/15 0:25 == 46.7
12/30/15 0:30 == 46.9
12/30/15 0:35 == 46.6
12/30/15 0:40 == 46.9
12/30/15 0:45 == 46.7
12/30/15 0:50 == 46.6
12/30/15 0:55 == 46.8
12/30/15 1:00 == 46.9
12/30/15 1:05 == 46.6
12/30/15 1:10 == 46.5
12/30/15 1:15 == 46.9
12/30/15 1:20 == 46.9
12/30/15 1:25 == 46.6
12/30/15 1:30 == 46.6
12/30/15 1:35 == 46.8
12/30/15 1:40 == 47
12/30/15 1:45 == 46.6
12/30/15 1:50 == 46.8
12/30/15 1:55 == 46.9
12/30/15 2:00 == 46.6
12/30/15 2:05 == 46.6
12/30/15 2:10 == 46.9
12/30/15 2:15 == 46.7
12/30/15 2:20 == 46.6
12/30/15 2:25 == 46.5
12/30/15 2:30 == 47
12/30/15 2:35 == 46.6
12/30/15 2:40 == 46.5
12/30/15 2:45 == 46.7
12/30/15 2:50 == 46.9
12/30/15 2:55 == 46.7
12/30/15 3:00 == 46.6
12/30/15 3:05 == 46.9
12/30/15 3:10 == 46.6
12/30/15 3:15 == 46.4
12/30/15 3:20 == 46.7
12/30/15 3:25 == 47
12/30/15 3:30 == 46.5
12/30/15 3:35 == 46.5
12/30/15 3:40 == 46.8
12/30/15 3:45 == 46.7
12/30/15 3:50 == 46.5
12/30/15 3:55 == 46.9
12/30/15 4:00 == 46.9
12/30/15 4:05 == 46.4
12/30/15 4:10 == 46.9
12/30/15 4:15 == 46.7
12/30/15 4:20 == 46.4
12/30/15 4:25 == 46.4
12/30/15 4:30 == 46.5
12/30/15 4:35 == 46.5
12/30/15 4:40 == 46.4
12/30/15 4:45 == 46.4
12/30/15 4:50 == 46.5
12/30/15 4:55 == 46.4
12/30/15 5:00 == 46.5
12/30/15 5:05 == 46.5
12/30/15 5:10 == 46.5
12/30/15 5:15 == 46.4
12/30/15 5:20 == 46.5
12/30/15 5:25 == 46.5
12/30/15 5:30 == 46.4
12/30/15 5:35 == 46.5
12/30/15 5:40 == 46.3
12/30/15 5:45 == 46.5
12/30/15 5:50 == 46.5
12/30/15 5:55 == 46.5

Pumpback Station Discharge (0364)

12/30/15 6:00 == 46.6
12/30/15 6:05 == 46.5
12/30/15 6:10 == 46.5
12/30/15 6:15 == 46.6
12/30/15 6:20 == 46.5
12/30/15 6:25 == 46.5
12/30/15 6:30 == 46.5
12/30/15 6:35 == 46.4
12/30/15 6:40 == 46.6
12/30/15 6:45 == 46.8
12/30/15 6:50 == 46.8
12/30/15 6:55 == 46.8
12/30/15 7:00 == 47.4
12/30/15 7:05 == 46.9
12/30/15 7:10 == 46.9
12/30/15 7:15 == 47
12/30/15 7:20 == 47
12/30/15 7:25 == 46.9
12/30/15 7:30 == 47
12/30/15 7:35 == 47
12/30/15 7:40 == 46.9
12/30/15 7:45 == 46.7
12/30/15 7:50 == 47
12/30/15 7:55 == 46.9
12/30/15 8:00 == 46.9
12/30/15 8:05 == 46.9
12/30/15 8:10 == 47
12/30/15 8:15 == 47
12/30/15 8:20 == 47.2
12/30/15 8:25 == 46.8
12/30/15 8:30 == 47.1
12/30/15 8:35 == 46.9
12/30/15 8:40 == 46.9
12/30/15 8:45 == 47
12/30/15 8:50 == 47.1
12/30/15 8:55 == 47
12/30/15 9:00 == 47
12/30/15 9:05 == 46.9
12/30/15 9:10 == 47.1
12/30/15 9:15 == 46.8
12/30/15 9:20 == 46.8
12/30/15 9:25 == 47.1
12/30/15 9:30 == 47.4
12/30/15 9:35 == 47
12/30/15 9:40 == 47.2
12/30/15 9:45 == 47
12/30/15 9:50 == 47
12/30/15 9:55 == 46.7
12/30/15 10:00 == 47.2
12/30/15 10:05 == 47.3
12/30/15 10:10 == 46.8
12/30/15 10:15 == 46.8
12/30/15 10:20 == 47.3
12/30/15 10:25 == 47.1
12/30/15 10:30 == 46.8
12/30/15 10:35 == 46.6
12/30/15 10:40 == 46.9
12/30/15 10:45 == 46.7
12/30/15 10:50 == 46.6
12/30/15 10:55 == 46.8
12/30/15 11:00 == 47
12/30/15 11:05 == 46.6
12/30/15 11:10 == 46.6
12/30/15 11:15 == 47.1
12/30/15 11:20 == 46.9
12/30/15 11:25 == 46.9
12/30/15 11:30 == 47.1
12/30/15 11:35 == 46.8
12/30/15 11:40 == 47
12/30/15 11:45 == 46.9
12/30/15 11:50 == 46.9
12/30/15 11:55 == 46.9
12/30/15 12:00 == 46.7
12/30/15 12:05 == 46.9
12/30/15 12:10 == 46.9
12/30/15 12:15 == 47
12/30/15 12:20 == 46.8
12/30/15 12:25 == 47
12/30/15 12:30 == 47.2
12/30/15 12:35 == 47
12/30/15 12:40 == 47.1
12/30/15 12:45 == 47
12/30/15 12:50 == 47
12/30/15 12:55 == 46.9
12/30/15 13:00 == 47.2
12/30/15 13:05 == 47.1
12/30/15 13:10 == 47.1
12/30/15 13:15 == 47.2
12/30/15 13:20 == 47.1
12/30/15 13:25 == 46.9
12/30/15 13:30 == 47
12/30/15 13:35 == 47
12/30/15 13:40 == 47.1
12/30/15 13:45 == 47
12/30/15 13:50 == 47.1
12/30/15 13:55 == 47
12/30/15 14:00 == 47
12/30/15 14:05 == 47.2
12/30/15 14:10 == 47.2
12/30/15 14:15 == 47.2
12/30/15 14:20 == 47.2
12/30/15 14:25 == 47.2
12/30/15 14:30 == 47.2
12/30/15 14:35 == 47.1
12/30/15 14:40 == 47.1
12/30/15 14:45 == 47
12/30/15 14:50 == 47.1
12/30/15 14:55 == 47.1
12/30/15 15:00 == 47.2
12/30/15 15:05 == 47.1
12/30/15 15:10 == 47.1
12/30/15 15:15 == 47
12/30/15 15:20 == 47.1
12/30/15 15:25 == 47.2
12/30/15 15:30 == 46.9
12/30/15 15:35 == 47.1
12/30/15 15:40 == 47
12/30/15 15:45 == 47.3
12/30/15 15:50 == 47
12/30/15 15:55 == 47
12/30/15 16:00 == 47.1
12/30/15 16:05 == 47.1
12/30/15 16:10 == 47.1
12/30/15 16:15 == 47.1
12/30/15 16:20 == 47
12/30/15 16:25 == 47
12/30/15 16:30 == 47
12/30/15 16:35 == 47.2
12/30/15 16:40 == 47
12/30/15 16:45 == 47
12/30/15 16:50 == 47
12/30/15 16:55 == 47
12/30/15 17:00 == 47.1
12/30/15 17:05 == 47.2
12/30/15 17:10 == 47.1
12/30/15 17:15 == 47
12/30/15 17:20 == 47
12/30/15 17:25 == 47.1
12/30/15 17:30 == 47.1
12/30/15 17:35 == 47.1
12/30/15 17:40 == 47.1
12/30/15 17:45 == 47.1
12/30/15 17:50 == 47.1
12/30/15 17:55 == 47.2
12/30/15 18:00 == 47.2
12/30/15 18:05 == 47.2
12/30/15 18:10 == 47.2
12/30/15 18:15 == 47.1
12/30/15 18:20 == 47.1
12/30/15 18:25 == 47.1
12/30/15 18:30 == 46.9
12/30/15 18:35 == 47.1
12/30/15 18:40 == 47
12/30/15 18:45 == 47
12/30/15 18:50 == 47
12/30/15 18:55 == 47.1
12/30/15 19:00 == 47.1
12/30/15 19:05 == 47
12/30/15 19:10 == 47
12/30/15 19:15 == 46.9
12/30/15 19:20 == 47
12/30/15 19:25 == 47.1
12/30/15 19:30 == 47.1
12/30/15 19:35 == 47.1
12/30/15 19:40 == 47
12/30/15 19:45 == 47.1
12/30/15 19:50 == 47.1
12/30/15 19:55 == 46.9
12/30/15 20:00 == 47.1
12/30/15 20:05 == 47
12/30/15 20:10 == 47.2
12/30/15 20:15 == 47.1
12/30/15 20:20 == 46.9
12/30/15 20:25 == 47.1
12/30/15 20:30 == 47
12/30/15 20:35 == 47.1
12/30/15 20:40 == 47
12/30/15 20:45 == 47
12/30/15 20:50 == 47
12/30/15 20:55 == 47.1
12/30/15 21:00 == 47.1
12/30/15 21:05 == 47.1
12/30/15 21:10 == 47.1
12/30/15 21:15 == 47.1
12/30/15 21:20 == 47.2
12/30/15 21:25 == 47.1
12/30/15 21:30 == 47.1
12/30/15 21:35 == 47
12/30/15 21:40 == 47
12/30/15 21:45 == 47.3
12/30/15 21:50 == 47.1
12/30/15 21:55 == 47.2
12/30/15 22:00 == 47.1
12/30/15 22:05 == 47.2
12/30/15 22:10 == 47.1
12/30/15 22:15 == 47.1
12/30/15 22:20 == 47
12/30/15 22:25 == 47.1
12/30/15 22:30 == 47.1
12/30/15 22:35 == 47.1
12/30/15 22:40 == 47
12/30/15 22:45 == 47.2
12/30/15 22:50 == 47
12/30/15 22:55 == 47
12/30/15 23:00 == 47.1
12/30/15 23:05 == 47
12/30/15 23:10 == 47
12/30/15 23:15 == 47.1
12/30/15 23:20 == 47
12/30/15 23:25 == 47.1
12/30/15 23:30 == 46.9
12/30/15 23:35 == 47.1
12/30/15 23:40 == 47.1
12/30/15 23:45 == 47.3
12/30/15 23:50 == 47.1
12/30/15 23:55 == 47.1

Pumpback Station Discharge (0364)

12/31/15 0:00 == 47.1
12/31/15 0:05 == 47
12/31/15 0:10 == 47
12/31/15 0:15 == 47.1
12/31/15 0:20 == 47
12/31/15 0:25 == 47.1
12/31/15 0:30 == 47
12/31/15 0:35 == 47
12/31/15 0:40 == 47.1
12/31/15 0:45 == 47.1
12/31/15 0:50 == 47.2
12/31/15 0:55 == 47.2
12/31/15 1:00 == 47
12/31/15 1:05 == 47.1
12/31/15 1:10 == 47.1
12/31/15 1:15 == 47.1
12/31/15 1:20 == 47
12/31/15 1:25 == 46.9
12/31/15 1:30 == 47.2
12/31/15 1:35 == 47
12/31/15 1:40 == 47
12/31/15 1:45 == 47.1
12/31/15 1:50 == 47
12/31/15 1:55 == 47.1
12/31/15 2:00 == 47
12/31/15 2:05 == 47.1
12/31/15 2:10 == 47.1
12/31/15 2:15 == 47
12/31/15 2:20 == 47.1
12/31/15 2:25 == 47.1
12/31/15 2:30 == 47.1
12/31/15 2:35 == 47.2
12/31/15 2:40 == 47
12/31/15 2:45 == 47.2
12/31/15 2:50 == 47
12/31/15 2:55 == 47.1
12/31/15 3:00 == 47.1
12/31/15 3:05 == 47.1
12/31/15 3:10 == 47
12/31/15 3:15 == 47.2
12/31/15 3:20 == 47.1
12/31/15 3:25 == 47.1
12/31/15 3:30 == 47.1
12/31/15 3:35 == 47.1
12/31/15 3:40 == 47.1
12/31/15 3:45 == 47
12/31/15 3:50 == 47.1
12/31/15 3:55 == 47.2
12/31/15 4:00 == 47.1
12/31/15 4:05 == 47
12/31/15 4:10 == 47.1
12/31/15 4:15 == 47.1
12/31/15 4:20 == 47.1
12/31/15 4:25 == 47.1
12/31/15 4:30 == 47.1
12/31/15 4:35 == 47.1
12/31/15 4:40 == 46.9
12/31/15 4:45 == 47
12/31/15 4:50 == 47.1
12/31/15 4:55 == 47
12/31/15 5:00 == 47.1
12/31/15 5:05 == 47.1
12/31/15 5:10 == 47.1
12/31/15 5:15 == 47.1
12/31/15 5:20 == 47
12/31/15 5:25 == 46.9
12/31/15 5:30 == 47
12/31/15 5:35 == 47.1
12/31/15 5:40 == 47
12/31/15 5:45 == 47.1
12/31/15 5:50 == 47
12/31/15 5:55 == 46.9
12/31/15 6:00 == 46.8
12/31/15 6:05 == 46.9
12/31/15 6:10 == 46.9
12/31/15 6:15 == 46.9
12/31/15 6:20 == 46.9
12/31/15 6:25 == 46.8
12/31/15 6:30 == 46.9
12/31/15 6:35 == 46.9
12/31/15 6:40 == 46.7
12/31/15 6:45 == 47.1
12/31/15 6:50 == 47
12/31/15 6:55 == 47.1
12/31/15 7:00 == 47.2
12/31/15 7:05 == 47
12/31/15 7:10 == 47
12/31/15 7:15 == 46.9
12/31/15 7:20 == 47.1
12/31/15 7:25 == 46.7
12/31/15 7:30 == 46.9
12/31/15 7:35 == 46.9
12/31/15 7:40 == 46.8
12/31/15 7:45 == 47
12/31/15 7:50 == 47.1
12/31/15 7:55 == 47.1
12/31/15 8:00 == 47.1
12/31/15 8:05 == 47.2
12/31/15 8:10 == 47.1
12/31/15 8:15 == 47.1
12/31/15 8:20 == 47.2
12/31/15 8:25 == 46.8
12/31/15 8:30 == 47.1
12/31/15 8:35 == 47.1
12/31/15 8:40 == 47.2
12/31/15 8:45 == 47.1
12/31/15 8:50 == 47.2
12/31/15 8:55 == 47
12/31/15 9:00 == 47.1
12/31/15 9:05 == 47.3
12/31/15 9:10 == 47
12/31/15 9:15 == 47.1
12/31/15 9:20 == 47.2
12/31/15 9:25 == 47.4
12/31/15 9:30 == 47.2
12/31/15 9:35 == 47.2
12/31/15 9:40 == 47.3
12/31/15 9:45 == 47.3
12/31/15 9:50 == 47.3
12/31/15 9:55 == 47.3
12/31/15 10:00 == 47.3
12/31/15 10:05 == 47.1
12/31/15 10:10 == 47
12/31/15 10:15 == 47.1
12/31/15 10:20 == 47.1
12/31/15 10:25 == 47
12/31/15 10:30 == 47.2
12/31/15 10:35 == 47.1
12/31/15 10:40 == 47.1
12/31/15 10:45 == 47.1
12/31/15 10:50 == 46.8
12/31/15 10:55 == 46.9
12/31/15 11:00 == 47.1
12/31/15 11:05 == 46.9
12/31/15 11:10 == 47.3
12/31/15 11:15 == 47
12/31/15 11:20 == 47.1
12/31/15 11:25 == 47
12/31/15 11:30 == 47.1
12/31/15 11:35 == 47.1
12/31/15 11:40 == 47.2
12/31/15 11:45 == 47.1
12/31/15 11:50 == 47.1
12/31/15 11:55 == 46.8
12/31/15 12:00 == 46.8
12/31/15 12:05 == 46.7
12/31/15 12:10 == 46.9
12/31/15 12:15 == 47
12/31/15 12:20 == 46.9
12/31/15 12:25 == 47.1
12/31/15 12:30 == 46.9
12/31/15 12:35 == 47
12/31/15 12:40 == 47.2
12/31/15 12:45 == 47.2
12/31/15 12:50 == 47.1
12/31/15 12:55 == 46.9
12/31/15 13:00 == 47.1
12/31/15 13:05 == 47.2
12/31/15 13:10 == 47
12/31/15 13:15 == 47.1
12/31/15 13:20 == 47.1
12/31/15 13:25 == 47.1
12/31/15 13:30 == 47.1
12/31/15 13:35 == 47.1
12/31/15 13:40 == 47.1
12/31/15 13:45 == 47.3
12/31/15 13:50 == 47.2
12/31/15 13:55 == 47.2
12/31/15 14:00 == 47.1
12/31/15 14:05 == 47.3
12/31/15 14:10 == 47.2
12/31/15 14:15 == 47.3
12/31/15 14:20 == 47
12/31/15 14:25 == 47.2
12/31/15 14:30 == 47.1
12/31/15 14:35 == 47.2
12/31/15 14:40 == 47.1
12/31/15 14:45 == 47.1
12/31/15 14:50 == 47
12/31/15 14:55 == 47
12/31/15 15:00 == 47
12/31/15 15:05 == 47
12/31/15 15:10 == 47.2
12/31/15 15:15 == 47.2
12/31/15 15:20 == 47.1
12/31/15 15:25 == 47.1
12/31/15 15:30 == 47
12/31/15 15:35 == 47.1
12/31/15 15:40 == 46.7
12/31/15 15:45 == 47
12/31/15 15:50 == 46.8
12/31/15 15:55 == 46.8
12/31/15 16:00 == 46.9
12/31/15 16:05 == 46.8
12/31/15 16:10 == 46.8
12/31/15 16:15 == 46.8
12/31/15 16:20 == 46.9
12/31/15 16:25 == 46.8
12/31/15 16:30 == 46.9
12/31/15 16:35 == 46.7
12/31/15 16:40 == 46.9
12/31/15 16:45 == 46.8
12/31/15 16:50 == 46.8
12/31/15 16:55 == 46.9
12/31/15 17:00 == 46.9
12/31/15 17:05 == 46.8
12/31/15 17:10 == 46.9
12/31/15 17:15 == 46.8
12/31/15 17:20 == 46.9
12/31/15 17:25 == 46.8
12/31/15 17:30 == 47
12/31/15 17:35 == 46.9
12/31/15 17:40 == 46.9
12/31/15 17:45 == 46.9
12/31/15 17:50 == 46.9
12/31/15 17:55 == 46.9

Pumpback Station Discharge (0364)

12/31/15 18:00 == 47.1
12/31/15 18:05 == 47
12/31/15 18:10 == 47
12/31/15 18:15 == 46.9
12/31/15 18:20 == 47
12/31/15 18:25 == 46.8
12/31/15 18:30 == 47
12/31/15 18:35 == 46.9
12/31/15 18:40 == 46.9
12/31/15 18:45 == 46.9
12/31/15 18:50 == 46.9
12/31/15 18:55 == 46.8
12/31/15 19:00 == 46.9
12/31/15 19:05 == 46.8
12/31/15 19:10 == 46.8
12/31/15 19:15 == 46.9
12/31/15 19:20 == 46.9
12/31/15 19:25 == 47
12/31/15 19:30 == 46.8
12/31/15 19:35 == 47
12/31/15 19:40 == 47
12/31/15 19:45 == 46.8
12/31/15 19:50 == 46.9
12/31/15 19:55 == 46.8
12/31/15 20:00 == 46.8
12/31/15 20:05 == 46.9
12/31/15 20:10 == 46.9
12/31/15 20:15 == 46.9
12/31/15 20:20 == 46.8
12/31/15 20:25 == 46.8
12/31/15 20:30 == 46.8
12/31/15 20:35 == 46.9
12/31/15 20:40 == 46.9
12/31/15 20:45 == 47
12/31/15 20:50 == 46.9
12/31/15 20:55 == 47
12/31/15 21:00 == 46.8
12/31/15 21:05 == 46.9
12/31/15 21:10 == 46.8
12/31/15 21:15 == 46.9
12/31/15 21:20 == 46.9
12/31/15 21:25 == 46.8
12/31/15 21:30 == 46.8
12/31/15 21:35 == 46.8
12/31/15 21:40 == 46.7
12/31/15 21:45 == 46.9
12/31/15 21:50 == 46.9
12/31/15 21:55 == 47
12/31/15 22:00 == 46.9
12/31/15 22:05 == 46.7
12/31/15 22:10 == 46.8
12/31/15 22:15 == 46.8
12/31/15 22:20 == 46.8
12/31/15 22:25 == 46.8
12/31/15 22:30 == 46.9
12/31/15 22:35 == 46.9
12/31/15 22:40 == 46.9
12/31/15 22:45 == 46.8
12/31/15 22:50 == 47
12/31/15 22:55 == 46.8
12/31/15 23:00 == 46.9
12/31/15 23:05 == 46.7
12/31/15 23:10 == 46.8
12/31/15 23:15 == 46.9
12/31/15 23:20 == 47
12/31/15 23:25 == 46.8
12/31/15 23:30 == 47
12/31/15 23:35 == 46.9
12/31/15 23:40 == 46.8
12/31/15 23:45 == 46.9
12/31/15 23:50 == 46.7
12/31/15 23:55 == 46.9

Langemann Gate to Delta

DATE	FLOW (CFS)
12/1/2015	3
12/2/2015	3
12/3/2015	3
12/4/2015	3
12/5/2015	3
12/6/2015	3
12/7/2015	3
12/8/2015	3
12/9/2015	3
12/10/2015	3
12/11/2015	3
12/12/2015	3
12/13/2015	3
12/14/2015	3
12/15/2015	3
12/16/2015	3
12/17/2015	3
12/18/2015	3
12/19/2015	3
12/20/2015	3
12/21/2015	3
12/22/2015	3
12/23/2015	3
12/24/2015	3
12/25/2015	3
12/26/2015	3
12/27/2015	3
12/28/2015	3
12/29/2015	3
12/30/2015	3
12/31/2015	3

Pumpback Station Discharge

DATE	FLOW (CFS)
12/1/2015	47
12/2/2015	47
12/3/2015	47
12/4/2015	47
12/5/2015	47
12/6/2015	47
12/7/2015	47
12/8/2015	47
12/9/2015	46
12/10/2015	46
12/11/2015	47
12/12/2015	47
12/13/2015	47
12/14/2015	47
12/15/2015	47
12/16/2015	47
12/17/2015	47
12/18/2015	47
12/19/2015	47
12/20/2015	47
12/21/2015	47
12/22/2015	38
12/23/2015	38
12/24/2015	47
12/25/2015	47
12/26/2015	47
12/27/2015	47
12/28/2015	47
12/29/2015	47
12/30/2015	47
12/31/2015	47

Pumpback Station Weir to Delta

DATE	FLOW (CFS)
12/1/2015	13
12/2/2015	15
12/3/2015	16
12/4/2015	17
12/5/2015	17
12/6/2015	19
12/7/2015	19
12/8/2015	20
12/9/2015	21
12/10/2015	22
12/11/2015	18
12/12/2015	13
12/13/2015	9
12/14/2015	3
12/15/2015	1
12/16/2015	1
12/17/2015	0
12/18/2015	0
12/19/2015	0
12/20/2015	0
12/21/2015	0
12/22/2015	8
12/23/2015	12
12/24/2015	2
12/25/2015	2
12/26/2015	2
12/27/2015	3
12/28/2015	3
12/29/2015	3
12/30/2015	3
12/31/2015	3