

<b>MONO BASIN</b>	Rush Cr @ Dam: 31	Lee Vining Creek: Above 35 (Spill: 28, Conduit: 7	
	West Portal : 0	Mono Lake Elev: 6379.17; (USGS Datum) (Read on: 8/17	
	C Ranch Hi/Lo: 90/50	Precip(Day/Month): 0.00/2.17	
	Parker Cr Abv: 9	Below: 9 Walker Cr Abv: 2 Below: 2	
		Grant Lake Spill: 0	
	<b>(*) Grant Lake El:</b> 7101.2	Outflow: 32 24hr AF Total: 61	
	(7130.0 HW)AF: 19794	Diff AF: 8 Grant Lake Toe Drain: 0.00	
<b>LONG VALLEY</b>	East Portal : 11	Below East Portal: 47	
	<b>(*) L V Resv Elev:</b> 6765.9	Outflow: 27 24hr AF Total: 153	
	(6781.5 HW)AF: 112168	Diff AF: -39	
	L Vally Hi/Lo: 95/50	Precip(Day/Month):0.00/1.49	
	ORG Main Weir: 3.40	Tunnel Drain: 0.15 Toe Drain: 0.46	
	Rock Crk Div : 0		
<b>NORTH OWENS</b>	RC@OR Cur/Ave: 29/29	Gorge: UG Cur/Avg: 40/39 MG Cur/Avg: 0/0	
	<b>(*) P V Resv Elev:</b> 4380.4	Outflow: 150 24hr AF Total: 297	
	(4390.0 HW)AF: 2089	Diff AF: -9	
	Bishop Hi/Lo: 107/62	Precip(Day/Month): 0.00/0.82	
	B C @ Plant 6: 73(avg)	O R Below BP Cr: 152 Fish Sprg @ RR Brdg: 30	
	BP Pwr House : 106/68	Precip(Day/Month): 0.00/0.99 BP Cr Cur/Peak: 29/36	
<b>WELLS</b>		<u>North Wells</u> <u>South Wells</u> <u>* Total *</u>	
	Aqueduct (19)	89.8 (9) 46.6 (28) 136.4	On: W219, W222, W223,
	Domestic (4)	4.9 (3) 1.9 (7) 6.8	
	Enhc./Mitig. (2)	10.8 (5) 11.4 (7) 22.2	Off:
	* Total *	(25) 105.5 (17) 59.9 (42) 165.4	
<b>SOUTH OWENS</b>	<b>(*) Tin Resv Elev:</b> 3862.2	Outflow: 201 24hr AF Total: 385	
	(3866.0 HW)AF: 2845	Diff AF: -108	
	Tin Res Hi/Lo: 106/67	Precip(Day/Month): 0.00/0.72	
	LAA Intake	Precip(Day/Month): 0.00/0.96	
	Indep Hi/Lo: 107/72	Precip(Day/Month): 0.00/0.94	
	Alab Gt Hi/Lo: 107/75	Precip(Day/Month): 0.00/1.16	
	Cotw Gt Hi/Lo: 109/70	Precip(Day/Month): 0.00/1.59	
	Blckrck Spill: 0.0	Thibaut Spillgates: 0.0 Lone Pine Creek: 7	
	Alab Gates GA: 5.21	Flow: 162	
	Cottw Gt Gage: 5.68	Flow: 178 Creek: 4 Power Plant: 0	
	<b>LORP(inflows):</b> Intake 70, Blackrock 1.2, Goose 0.0, Billy 1.1, Locust 0.0,	Georges 0.1, Alabama Gates 0 <b>Total Inflow(cfs): 74</b>	
	(outflows): PumpSta 46, Delta(L.G.) 3, Delta(weir) 0	<b>Total Outflow(cfs): 49</b>	
	Lubkin Splgt: Flow(in/out): 10/0	AF Total(in/out): 38/0 net AF: -38	
	Cartago Splgt: Flow(in/out): 13/0	AF Total(in/out): 24/0 net AF: -24	
	Owens Lk Use : (net avg cfs) PumpSta 45.9, Lubkin -19, Cartago -12	<b>Total: 15</b>	
<b>(*) N Haiwee Elev:</b> 3757.1			
(3757.5 HW)AF: 9779	Diff AF: -35		
<b>(*) S Haiwee Elev:</b> 3735.0			
(3742.0 HW)AF: 21562	Diff AF: -16		
S Haiwe Hi/Lo: 104/70	Precip(Day/Month): 0.00/1.39		
Hai Pwr Plant: 155	24hr AF Total: 307		
LAA #2 S Haiw: 35	24hr AF Total: 69		
<b>SOUTHERN DISTRICT</b>	<b>BOUQUET RELEASE</b>	<b>INST: 1.5 CFS</b> <b>PREV DAY: 1.5 CFS</b>	