

MONO BASIN	Rush Cr @ Dam:	538	Lee Vining Creek: Above 450 (Spill: 450, Conduit: 0)		
	West Portal :	0	Mono Lake Elev: 6380.94; (USGS Datum) (Read on: 6/14 )		
	C Ranch Hi/Lo:	79/38	Precip(Day/Month): 0.00/1.41		
	Parker Cr Abv:	70	Below: 70 Walker Cr Abv: 48 Below: 48		
			Grant Lake Spill: 483		
	<b>(* Grant Lake El:</b>	7132.1	Outflow: 130 24hr AF Total: 246		
	(7130.0 HW)AF:	49513	Diff AF: -11 Grant Lake Toe Drain: 0.12		
LONG VALLEY	East Portal :	13	Below East Portal: 158		
	<b>(* L V Resv Elev:</b>	6761.7	Outflow: 509 24hr AF Total: 999		
	(6781.5 HW)AF:	96394	Diff AF: 1000		
	L Vally Hi/Lo:	81/39	Precip(Day/Month):0.00/0.82		
	ORG Main Weir:	3.00	Tunnel Drain: 0.13 Toe Drain: 0.45		
	Rock Crk Div :	174			
NORTH OWENS	RC@OR Cur/Ave:	385/345	Gorge: UG Cur/Avg: 276/287 MG Cur/Avg: 0/0		
	<b>(* P V Resv Elev:</b>	4398.7	Outflow: 744 24hr AF Total: 1455		
	(4390.0 HW)AF:	3947	Diff AF: -10		
	Bishop Hi/Lo:	95/49	Precip(Day/Month): 0.00/0.31		
	B C @ Plant 6:	444(avg)	O R Below BP Cr: 1270 Fish Sprg @ RR Brdg: 42		
	BP Pwr House :	93/56	Precip(Day/Month): 0.00/0.34 BP Cr Cur/Peak: 261/261		
WELLS		<u>North Wells</u>	<u>South Wells</u>	<u>* Total *</u>	
	Aqueduct	(5) 40.7	(5) 38.5	(10) 79.2	On: W423,
	Domestic	(4) 4.9	(3) 1.9	(7) 6.8	
	Enhc./Mitig.	(0) 0.0	(4) 7.4	(4) 7.4	Off:
	* Total *	(9) 45.6	(12) 47.8	(21) 93.4	
SOUTH OWENS	<b>(* Tin Resv Elev:</b>	3865.8	Outflow: 1124 24hr AF Total: 2229		
	(3866.0 HW)AF:	6097	Diff AF: 163		
	Tin Res Hi/Lo:	93/55	Precip(Day/Month): 0.00/0.50		
	LAA Intake		Precip(Day/Month): 0.00/0.66		
	Indep Hi/Lo:	93/65	Precip(Day/Month): 0.00/0.10		
	Alab Gt Hi/Lo:	93/66	Precip(Day/Month): 0.00/0.60		
	Cotw Gt Hi/Lo:	90/62	Precip(Day/Month): 0.00/0.48		
	Blckrck Spill:	100.2	Thibaut Spillgates: 0.0 Lone Pine Creek: 89		
	Alab Gates GA:	10.72	Flow: 820		
	Cottw Gt Gage:	12.07	Flow: 922 Creek: 319 Power Plant: 0		
	<b>LORP(inflows):</b>	Intake 494, Blackrock 0.5, Goose 0.0, Billy 1.5, Locust 9.2,			
		Georges 9.0, Alabama Gates 32 <b>Total Inflow(cfs): 538</b>			
	(outflows):	PumpSta 48, Delta(L.G.) 0, Delta(weir) 474 <b>Total Outflow(cfs): 522</b>			
	Lubkin Splgt:	Flow(in/out): 0/25	AF Total(in/out): 0/53 net AF: 53		
	Cartago Splgt:	Flow(in/out): 0/56	AF Total(in/out): 0/106 net AF: 106		
Owens Lk Use :	(net avg cfs) PumpSta 47.8, Lubkin 27, Cartago 53	<b>Total: 128</b>			
<b>(* N Haiwee Elev:</b>	3757.0				
(3757.5 HW)AF:	9767	Diff AF: 45			
<b>(* S Haiwee Elev:</b>	3730.5				
(3742.0 HW)AF:	18074	Diff AF: 203			
S Haiwe Hi/Lo:	94/59	Precip(Day/Month): 0.00/0.43			
Hai Pwr Plant:	480	24hr AF Total: 952			
LAA #2 S Haiw:	280	24hr AF Total: 555			
SOUTHERN DISTRICT	<b>BOUQUET RELEASE</b>	<b>INST: 1.0 CFS</b>	<b>PREV DAY: 1.0 CFS</b>		